

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

SigmaPro Properties, LLC (CN605566363) operates the SigmaPro Wastewater Treatment Facility (RN110487162). a domestic wastewater treatment facility. The facility is located at 13241 Harmon Road, in Fort Worth, Tarrant County, Texas 76177.

The application is to renew the permit that authorizes a discharge of treated wastewater at a flow not to exceed 9,500 gallons per day.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand, total suspended solids, ammonia nitrogen, and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater is treated by an activated sludge process plant operated in the extended aeration mode. The treatment units are an aeration basin, secondary clarifier, chlorine contact basis, and sludge holding basin.