

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

South Central Water Company (602602179) operates Cibolo Valley WWTP 105921738. an Domestic Wastewater Treatment Plant. The facility is located approximately 3,000 feet southeast of the intersection of U.S. Highway 281 and Farm to Market Road 1863, in Bulverde, Comal County, Texas 78163.

This permit is to authorize the discharge of the treated domestic wastewater to a volume not to exceed an average flow of 500,000 gpd.

Discharges from the facility are expected to contain 14. List all expected pollutants here. Domestic wastewater will be treated by an activated sludge processing plant and is treated by a bar screen, grit chamber, aeration basin, sludge digester, final clarifier, a belt press and chlorine contact chamber.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS