

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

South Central Wastewater (CN602602179) proposes to operate Lockhart 1290 Wastewater Treatment Plant 5. Enter Regulated Entity Number here (i.e., RN1#####). an activated sludge process plant operated in the complete mix mode. The facility will be located approximately 2.6 miles Northeast of the intersection of HWY 80 and 107, in 10. Enter city name here., Bastrop County, Texas 78655.

This application is for a new discharge at a daily average flow of 950,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli* Additional potential pollutants are included in the Domestic Technical Report 1.0 in the permit application package.v will be treated by Domestic wastewater is treated by an activated sludge process plant and the treatment units include a bar screen, aeration basins, final clarifiers, sludge digesters, and chlorine contact chambers. .