

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Southwest Milam Water Supply Corporation (CN600684062) operates the Anthis Well and Treatment Plant RN104277272. a domestic water treatment facility. The facility is located at 3240 County Road 334, in Rockdale, Milam County, Texas 76567.

Southwest Milam Water Supply Corporation is applying to the TCEQ to renew TPDES Permit NO. WQ0014524001 (EPA ID No. TX0126730) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 60,000 gallon per day.

Discharges from the facility are expected to contain **Iron and Manganese**.from backwashing water filters and is treated by *a settling pond prior to discharge.*

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP