

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

13535 Sralla Rd LLC (CN606114668 ) operates the Mira Mobile Home Community Wastewater Treatment Facility (RN104090998). a conventional activated sludge with nitrification process plant. The facility is located at 13535 Sralla Rd, in Crosby, Harris County, Texas 77532.

This application is for a renewal to discharge at a daily average flow of 20,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7 (Pollutant Analysis of Treated Effluent) in the permit application package. The domestic wastewater from the Mira Mobile Home Community Wastewater Treatment Facility is treated by a conventional activated sludge with nitrification process plant and the treatment units include a bar screen, an aeration basin, a final clarifier, a sludge digester and a chlorine contact basin.

#### SPANISH TRANLATION:

13535 Sralla Rd LLC (CN606114668) opera la instalación de tratamiento de aguas residuales de la comunidad de casas móviles de Mira (RN104090998). una planta convencional de lodos activados con proceso de nitrificación. La instalación está ubicada en 13535 Sralla Rd, en Crosby, condado de Harris, Texas 77532.

Esta solicitud es para una renovación para descargar a un flujo promedio diario de 20,000 galones por día de aguas residuales domésticas tratadas.

Se espera que las descargas de la instalación contengan demanda bioquímica de oxígeno carbónico (CBOD<sub>5</sub>) de cinco días, sólidos suspendidos totales (TSS), nitrógeno amoniacal (NH<sub>3</sub>-N) y *Escherichia coli*. Los contaminantes potenciales adicionales se incluyen en el Informe Técnico Doméstico 1.0, Sección 7 (Análisis de Contaminantes de Efluentes Tratados) en el paquete de solicitud de permiso. y las unidades de tratamiento incluyen tamiz de barras, balsa de aireación, decantador final, digestor de lodos y balsa de contacto de cloro.

