

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

SVAG Investments, LLC (NA) proposes to operate Konle Tract WWTP (New Facility). a single stage nitrification plant with tertiary treatment. The facility will be located approximately 750 ft northeast of the intersection between Ronald Reagan Blvd and CR 289, in Georgetown, Williamson County, Texas 78633.

This application is for a new permit application for the treatment and discharge of up to 0.325 mgd of treated effluent in the final phase.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia-nitrogen (NH₃-N), and Escherichia Coli. Domestic Wastewater will be treated by *an activated sludge process plant and the treatment units include bar screens, aeration basins, final clarifiers, disinfection modules, and aerated sludge holding basins.*

RECEIVED
NOV 10 2023
Water Quality Applications Team

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP