

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

T&W Water Service Company (CN601363005) operates Belle Oaks Wastewater Plant 103002457. an activated sludge treatment plant. The facility is located 1.5 miles north of the intersection of SH73 and Country Club Road, in Taylor Landing, Jefferson County, Texas 77705.

The application is for renewal of the discharge permit for the Belle Oaks Wastewater Treatment Plant.

Discharges from the facility are expected to contain Biological Oxygen Demand, Suspended Solids and Ammonia. Only treated domestic wastewater is discharged from this facility is treated by a bar screen followed by an aeration basin, then a clarifier and a chlorine contact basin. Sludge is trucked to another treatment plant for processing and disposal..

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP