

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

TB College Station Dev LLC (CN606077493) proposes to operate Casata Wastewater Treatment Plant (RN111602934). a 0.12 MGD wastewater treatment plant will be used to serve the community of Casata. The facility will be located approximately 2640 feet southeast of the intersection of Raymond Stotzer Pkwy and Texas 47 Frontage Road in Brazos County, Texas 77845., in College Station, Brazos County, Texas 77845.

New application to process wastewater for the community of Casata with a capacity of .12 MGD.

Discharges from the facility are expected to contain Standard Wastewater pollutants, with nitrogen and phosphorus. Domestic Wastewater will be treated by entering the treatment facility at the headworks before flow will split into 2 aeration basins, 2 clarifiers, 2 aerobic digesters, 1 chlorine contact basin, and then outfall. Solids will be pumped out of the aerobic digesters and then trucked to a landfill.

RECEIVED

AUG 02 2023

Water Quality Applications Team