

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Texas A&M University (CN600307623) operates the TAMU Agrilife Research & Center at Beaumont Wastewater Treatment Facility RN102079506. a domestic wastewater treatment facility. The facility is located at 1509 Aggie Drive, in Beaumont, Jefferson County, Texas 77713.

Request for renewal of a permit authorizing the discharge of 10,000 gallons of treated domestic wastewater per day.

Discharges from the facility are expected to contain BOD(5), Total Suspended Solids and E. coli..Domestic wastewater is treated by **Activated sludge plant utilizing extended aeration process. Automated and manual operation with wet well, eductor pumps, dual aeration chambers with bar screen, scum diffuser, clarifier basin, sludge return, sludge thickener basin, weir, chlorine contact basin, outfall to culvert.**

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS