

Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Texas National Municipal Utility District (CN601364292) operates Texas National Municipal Utility District Wastewater Treatment Plant (RN102916749). a complete mix activated sludge wastewater treatment plant. The facility is located north of Camp Creek, approximately 1.5 miles northeast of the intersection of Texas National Boulevard and Farm-to-Marked Road 2432, in Willis, Montgomery County, Texas 77378.

The application is for a renewal to discharge at a daily average flow of Interim I Phase: 0.075 MGD, Interim Phase II: 0.15 MGD, and Final Phase: 0.225 MGD of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli* . Domestic wastewater is treated by complete mix activated sludge process plant and the treatment units include a manual bar screen, aeration basins, clarifier, sludge digesters, and chlorine disinfection basin.

