

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Upper Leon River Municipal Water District (CN600635700 ) operates the Fritts Wastewater Treatment Plant RN104343181. an activated sludge process plant operated in the extended aeration mode. The facility is located at 1251 Highway 2861, in Comanche, Comanche County, Texas 76442.

The Upper Leon River Municipal Water District has applied for a renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.065 million gallons per day.

Discharges from the facility are expected to contain Carbonaceous Biological Oxygen Demand (5-day), Total Suspended Solids, Ammonia Nitrogen, and E. Coli. Domestic wastewater is treated by an activated sludge process plant operated in extended aeration mode. Treatment units include a bar screen, an aeration basin, a final clarifier, a sludge holding tank, and a chlorine contact chamber.

**Spanish PLS:**