



Technical Package Cover Page

This file contains the following documents:

1. Summary of application (in plain language)
2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
3. Second notice (NAPD-Notice of Preliminary Decision)
4. Application materials (**NOTE:** This application was declared Administratively Complete before June 1, 2024. Application materials are available for review at the Public Viewing Location provided in the NORI.)
5. Draft permit
6. Technical summary or fact sheet



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by [Title 30, Texas Administrative Code \(30 TAC\), Chapter 39, Subchapter H](#). Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in [30 TAC Section 39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package**. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter 'INDUSTRIAL' or 'DOMESTIC' here WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Solvay USA LLC (CN600125330) operates the Vernon Guar Plant (RN100219773), a guar bean processing facility. The facility is located at 201 Harrison Street, in Vernon, Wilbarger County, Texas 76384. The application requests a renewal of TPDES Permit No. WQ0002537000.

Discharges from the facility are expected to contain carbonaceous biochemical oxygen demand, total organic carbon, total suspended solids, ammonia-nitrogen and total dissolved solids. The discharges will consist of treated process wastewater, utility wastewater, and stormwater from process and nonprocess areas of the plant are are treated by physical-chemical and biological wastewater treatment processes.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT RENEWAL

PERMIT NO. WQ0002537000

APPLICATION. Solvay USA LLC, 504 Carnegie Center, Princeton, New Jersey 08540, which owns a guar bean processing facility, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0002537000 (EPA I.D. No. TX0088781) to authorize the discharge of treated wastewater and stormwater at a volume not to exceed a daily average flow of 1,300,000 gallons per day via Outfall 001 and stormwater at an intermittent and flow-variable volume via Outfall 002. The facility is located at 201 Harrison Street, in the city of Vernon, in Wilbarger County, Texas 76384. The discharge route is from the plant site to via Outfall 001 directly to the Pease River and via Outfall 002 to man-made and natural ditches, thence to the Pease River. TCEQ received this application on February 27, 2024. The permit application will be available for viewing and copying at Carnegie City-County Library, Front Desk, 2810 Wilbarger Street, Vernon, Texas prior to the date this notice is published in the newspaper. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-99.303333,34.166666&level=18>

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. **Notice of the Application and Preliminary Decision will be published and mailed to those who are on the county-wide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.**

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. **Unless the application is directly referred for a contested case hearing, the response to comments, and the**

Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. **If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period. TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.**

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at <https://www14.tceq.texas.gov/epic/eComment/>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will

become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Solvay USA LLC at the address stated above or by calling Ms. Cheryl Smith at 940-553-2054.

Issuance Date: April 4, 2024

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



**NOTICE OF APPLICATION AND PRELIMINARY DECISION
FOR TPDES PERMIT FOR INDUSTRIAL WASTEWATER**

RENEWAL

PERMIT NO. WQ0002537000

APPLICATION AND PRELIMINARY DECISION. Syensqo USA LLC, 2564 U.S. Highway 1, Lawrence, New Jersey 08648, which operates Syensqo USA Vernon Plant, a guar bean processing plant, has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0002537000, which authorizes the discharge of treated process wastewater, utility wastewater, and first flush stormwater at a daily average flow not to exceed 1,300,000 gallons per day via Outfall 001; and stormwater on an intermittent and flow-variable basis via Outfall 002. TCEQ received this application on February 27, 2024.

The facility is located at 201 Harrison Street, in the City of Vernon, Wilbarger County, Texas 76384. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-99.303333,34.166666&level=18>

The effluent is discharged via Outfall 001 directly to the Pease River; and via Outfall 002 to man-made and natural ditches, thence to the Pease River in Segment No. 0230 of the Red River Basin. The unclassified receiving water uses are minimal aquatic life use for the man-made and natural ditches. The designated uses for Segment No. 0230 are primary contact recreation and intermediate aquatic life use.

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at Carnegie City-County Library, Front Desk, 2810 Wilbarger Street, Vernon, Texas. The application, including any updates, and associated notices are available electronically at the following webpage: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting about this application. The purpose of a public meeting is to provide the opportunity to submit written or oral comment or to ask questions about the application. Generally, the TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for public comments, the Executive Director will consider the comments and prepare a response to all relevant and material, or significant public comments. **The response to comments, along with the Executive Director's decision on the application, will be mailed to everyone who submitted public comments or who requested to be on a mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision.** A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. **If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period. TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.**

EXECUTIVE DIRECTOR ACTION. The Executive Director may issue final approval of the application unless a timely contested case hearing request or a timely request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and requests to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be added to: (1) the permanent list for a specific applicant name and permit number; and (2) the mailing list for a specific county. If you wish to be placed on the permanent and the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, TCEQ, P.O. Box 13087, Austin, TX 78711-3087 or electronically at <https://www.tceq.texas.gov/goto/comment/> within 30 days from the date of newspaper publication of this notice.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at <https://www.tceq.texas.gov/goto/cid/>. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. Public comments and requests must be submitted either electronically at <https://www.tceq.texas.gov/goto/comment/> or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address, and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, toll free, at 1-800-687-4040 or visit their website at <https://www.tceq.texas.gov/agency/decisions/participation/permitting-participation>. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Syensqo USA LLC at the address stated above or by calling Ms. Cheryl Smith, Quality Lead/Environmental, at 940-553-2054.

Issued: September 22, 2025



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. Box 13087
Austin, Texas 78711-3087

PERMIT TO DISCHARGE WASTES

under provisions of
Section 402 of the Clean Water Act
and Chapter 26 of the Texas Water Code

TPDES PERMIT NO.
WQ0002537000
*[For TCEQ office use only -
EPA I.D. No. TX0088751]*

This renewal replaces TPDES Permit
No. WQ0002537000, issued on
August 30, 2019.

Syensqo USA LLC

whose mailing address is

2564 U.S. Highway 1
Lawrence, New Jersey 08648

is authorized to treat and discharge wastes from Syensqo USA Vernon Plant, a guar bean processing plant (SIC 2899 and 0723)

located at 201 Harrison Street, in the City of Vernon, in Wilbarger County, Texas 76384

via Outfall 001 directly to the Pease River; and via Outfall 002 to man-made and natural ditches, thence to the Pease River in Segment No. 0230 of the Red River Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does not grant to the permittee the right to use private or public property for conveyance of wastewater along the discharge route described in this permit. This includes, but is not limited to, property belonging to any individual, partnership, corporation, or other entity. Neither does this permit authorize any invasion of personal rights nor any violation of federal, state, or local laws or regulations. It is the responsibility of the permittee to acquire property rights as may be necessary to use the discharge route.

This permit shall expire at midnight, five years from the date of permit issuance.

ISSUED DATE:

For the Commission

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

- During the period beginning upon the date of issuance and lasting through the date of expiration, the permittee is authorized to discharge treated process wastewater, utility wastewater, and first flush stormwater¹ subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 1.3 million gallons per day (MGD). The daily maximum flow shall not exceed 2.0 MGD.

Effluent Characteristics	Discharge Limitations				Minimum Self-Monitoring Requirements		
	Daily Average lbs/day	mg/L	Daily Maximum lbs/day	mg/L	Single Grab Report mg/L	Daily Average and Daily Maximum Measurement Frequency	Sample Type
Flow	1.3 MGD		2.0 MGD		N/A	Continuous	Record
Carbonaceous Biochemical Oxygen Demand (5-day) April-October	249	23	498	46	75	2/week	Composite
Carbonaceous Biochemical Oxygen Demand (5-day) November-February	455	42	910	84	125	2/week	Composite
Carbonaceous Biochemical Oxygen Demand (5-day) March	423	39	846	78	117	2/week	Composite
Total Suspended Solids	325	Report	650	Report	100	2/week	Composite
Total Organic Carbon	9,433	Report	16,480	Report	2,125	2/week	Composite
Ammonia Nitrogen	N/A	3.0	N/A	5.0	10	1/week	Composite
Minimum Dissolved Oxygen	N/A	5.0 (min)	N/A	N/A	5.0 (min)	2/week	Grab
Lethal Whole Effluent Toxicity (WET) limit 92% (Parameter 51714)							
<i>Pimephales promelas</i> (7-day chronic IC25²)	92%		92%		N/A	1/quarter	Composite
Sublethal Whole Effluent Toxicity (WET) limit 80% (Parameter 51714)							
<i>Pimephales promelas</i> (7-day chronic IC25²)	80%		80%		N/A	1/quarter	Composite

¹ See "Other Requirements" No. 5.

² The IC25 is defined the inhibition concentration of effluent that would cause a 25% reduction in the specified endpoint.

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS, continued

Outfall Number 001

2. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored 1/day by grab sample or by in-situ measurement.
3. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
4. Effluent monitoring samples shall be taken at the following location: At Outfall 001, at the flow-measuring device where treated effluent is discharged prior to entering the pipeline which conveys the wastewaters to the Pease River.

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTSOutfall Number 002

1. During the period beginning upon the date of issuance and lasting through the date of expiration, the permittee is authorized to discharge stormwater¹ subject to the following effluent limitations:

Volume: Intermittent and flow-variable.

Effluent Characteristics	Discharge Limitations			Minimum Self-Monitoring Requirements	
	Daily Average mg/L	Daily Maximum mg/L	Single Grab mg/L	Report Daily Average and Daily Maximum Measurement Frequency	Sample Type
Flow	Report (MGD)	Report (MGD)	N/A	1/day ²	Estimate
Chemical Oxygen Demand	N/A	500	500	1/week ²	Grab
Oil and Grease	N/A	15	15	1/week ²	Grab

¹ See "Other Requirements" No. 5.

² When discharge occurs. Samples shall be collected within 40 minutes of initiation of discharge.

2. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored 1/day, by grab sample, when discharge occurs. Samples shall be collected within 40 minutes of initiation of discharge.
3. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
4. Effluent monitoring samples shall be taken at the following location: At Outfall 002, at the outlet from the 0.5 million-gallon Storm Basin (SU-114).

DEFINITIONS AND STANDARD PERMIT CONDITIONS

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC §§305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in Texas Water Code §26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

1. Flow Measurements

- a. Annual average flow - the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder, and limited to major domestic wastewater discharge facilities with a one million gallons per day or greater permitted flow.
- b. Daily average flow - the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow - the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow - the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) - the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) - the highest 2-hour peak flow for any 24-hour period in a calendar month.

2. Concentration Measurements

- a. Daily average concentration - the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
 - i. For domestic wastewater treatment plants - When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.
 - ii. For all other wastewater treatment plants - When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration - the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration - the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge - the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the "daily discharge" is calculated as the total

mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the “daily discharge” is calculated as the average measurement of the pollutant over the sampling day.

The “daily discharge” determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the “daily discharge” determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.

- e. Bacteria concentration (Fecal coliform, *E. coli*, or Enterococci) – the number of colonies of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the n th root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substitute value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
- f. Daily average loading (lbs/day) - the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as $(\text{Flow, MGD} \times \text{Concentration, mg/L} \times 8.34)$.
- g. Daily maximum loading (lbs/day) - the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.

3. Sample Type

- a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC §319.9(a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC §319.9(c).
 - b. Grab sample - an individual sample collected in less than 15 minutes.
- 4. Treatment Facility (facility) - wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
 - 5. The term “sewage sludge” is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
 - 6. Bypass - the intentional diversion of a waste stream from any portion of a treatment facility.

MONITORING AND REPORTING REQUIREMENTS

1. Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Enforcement Division (MC 224), by the 20th day of the following month for each discharge that is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act; TWC Chapters 26, 27, and 28; and THSC Chapter 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§319.11 - 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

3. Records of Results

- a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.
- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR §264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:
 - i. date, time, and place of sample or measurement;
 - ii. identity of individual who collected the sample or made the measurement;
 - iii. date and time of analysis;
 - iv. identity of the individual and laboratory who performed the analysis;
 - v. the technique or method of analysis; and
 - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site or shall be readily available for review by a TCEQ representative for a period of three years.

6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the regional office and the Enforcement Division (MC 224).

7. Noncompliance Notification

- a. In accordance with 30 TAC §305.125(9) any noncompliance that may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Report of such information shall be provided orally or by facsimile transmission (FAX) to the regional office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the regional office and the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective September 1, 2020, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
 - b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
 - i. unauthorized discharges as defined in Permit Condition 2(g).
 - ii. any unanticipated bypass that exceeds any effluent limitation in the permit.
 - iii. violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
 - c. In addition to the above, any effluent violation that deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the regional office and the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
 - d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
8. In accordance with the procedures described in 30 TAC §§35.301 - 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.

9. Changes in Discharges of Toxic Substances

All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the regional office, orally or by facsimile transmission within 24 hours, and both the regional office and the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) that is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. one hundred micrograms per liter (100 µg/L);
 - ii. two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - iii. five (5) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. the level established by the TCEQ.

- b. That any activity has occurred or will occur that would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. five hundred micrograms per liter (500 µg/L);
 - ii. one milligram per liter (1 mg/L) for antimony;
 - iii. ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. the level established by the TCEQ.

10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC §305.128 (relating to Signatories to Reports).

11. All POTWs must provide adequate notice to the Executive Director of the following:

- a. any new introduction of pollutants into the POTW from an indirect discharger that would be subject to CWA §301 or §306 if it were directly discharging those pollutants;
- b. any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and
- c. for the purpose of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW; and
 - ii. any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

PERMIT CONDITIONS

1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
 - i. violation of any terms or conditions of this permit;
 - ii. obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
 - iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending, or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment,

revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.

- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.
- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance with 30 TAC §§305.62 and 305.66 and TWC §7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC §305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility that does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under Texas Water Code §§7.051 - 7.075 (relating to Administrative Penalties), 7.101 - 7.111 (relating to Civil Penalties), and 7.141 - 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA §402, or any requirement imposed in a pretreatment program approved under the CWA §§402(a)(3) or 402(b)(8).

3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC Chapter 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit, or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC §7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

4. Permit Amendment or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
 - i. the alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC §305.534 (relating to New Sources and New Dischargers); or
 - ii. the alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
 - iii. the alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes that are not described in the permit application or that would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC §26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA §307(a) for a toxic pollutant that is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA §307(a) for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC §305.64 (relating to Transfer of Permits) and 30 TAC §50.133 (relating to Executive Director Action on Application or WQMP update).

6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to Texas Water Code Chapter 11.

8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

11. Notice of Bankruptcy.

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
 - i. the permittee;
 - ii. an entity (as that term is defined in 11 USC, §101(15)) controlling the permittee or listing the permit or permittee as property of the estate; or
 - iii. an affiliate (as that term is defined in 11 USC, §101(2)) of the permittee.
- b. This notification must indicate:
 - i. the name of the permittee;
 - ii. the permit number(s);
 - iii. the bankruptcy court in which the petition for bankruptcy was filed; and
 - iv. the date of filing of the petition.

OPERATIONAL REQUIREMENTS

1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge use and disposal and 30 TAC §§319.21 - 319.29 concerning the discharge of certain hazardous metals.

3. Domestic wastewater treatment facilities shall comply with the following provisions:
 - a. The permittee shall notify the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
 - b. The permittee shall submit a closure plan for review and approval to the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment or other treatment unit regulated by this permit.
4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, or retention of inadequately treated wastewater.
5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.
6. The permittee shall remit an annual water quality fee to the Commission as required by 30 TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC §7.302(b)(6).
7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words "confidential business information" on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
 - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion or upgrading of the domestic wastewater treatment or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment or collection facilities. In the case of a domestic wastewater treatment facility that reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

- b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission, and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been secured.
 - c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
9. Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
11. Facilities that generate industrial solid waste as defined in 30 TAC §335.1 shall comply with these provisions:
- a. Any solid waste, as defined in 30 TAC §335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
 - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
 - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC §335.8(b)(1), to the Corrective Action Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
 - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Remediation Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC §335.5.
 - e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well, container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.
 - f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC Chapter 335 and must include the following, as it pertains to wastewater treatment and discharge:
 - i. volume of waste and date(s) generated from treatment process;
 - ii. volume of waste disposed of on-site or shipped off-site;
 - iii. date(s) of disposal;

- iv. identity of hauler or transporter;
- v. location of disposal site; and
- vi. method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC Chapter 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC Code Chapter 361.

TCEQ Revision 05/2021

OTHER REQUIREMENTS

1. Violations of daily maximum limitations for the following pollutants shall be reported orally or by facsimile to TCEQ Region 3 within 24 hours from the time the permittee becomes aware of the violation, followed by a written report within five working days to TCEQ Region 3 and Compliance Monitoring Team (MC 224): None.

2. **POND REQUIREMENTS**

A wastewater pond must comply with the following requirements. A wastewater pond (or lagoon) is an earthen structure used to evaporate, hold, store, or treat water that contains a *waste* or *pollutant* or that would cause *pollution* upon *discharge* as those terms are defined in Texas Water Code § 26.001, but does not include a pond that contains only stormwater.

- A. A wastewater pond **subject to 40 CFR Part 257, Subpart D** (related to coal combustion residuals) must comply with those requirements in lieu of the requirements in B through G of POND REQUIREMENTS.
- B. An **existing** wastewater pond must be maintained to meet or exceed the original approved design and liner requirements; or, in the absence of original approved requirements, must be maintained to prevent unauthorized discharges of wastewater into or adjacent to water in the state. The permittee shall maintain copies of all liner construction and testing documents at the facility or in a reasonably accessible location and make the information available to the executive director upon request.
- C. A **new** wastewater pond constructed after the issuance date of this permit must be lined in compliance with one of the following requirements if it will contain process wastewater as defined in 40 CFR § 122.2. The executive director will review ponds that will contain only non-process wastewater on a case-by-case basis to determine whether the pond must be lined. If a pond will contain only non-process wastewater, the owner shall notify the Industrial Permits Team (MC 148) to obtain a written determination at least 90 days before the pond is placed into service and copy the TCEQ Compliance Monitoring Team (MC 224) and regional office. The permittee must submit all information about the proposed pond contents that is reasonably necessary for the executive director to make a determination. If the executive director determines that a pond does not need to be lined, then the pond is exempt from C(1) through C(3) and D through G of POND REQUIREMENTS.

A wastewater pond that only contains domestic wastewater must comply with the design requirements in 30 TAC Chapter 217 and 30 TAC § 309.13(d) in lieu of items C(1) through C(3) of this subparagraph.

- (1) Soil liner: The soil liner must contain clay-rich soil material (at least 30% of the liner material passing through a #200 mesh sieve, liquid limit greater than or equal to 30, and plasticity index greater than or equal to 15) that completely covers the sides and bottom of the pond. The liner must be at least 3.0 feet thick. The liner material must be compacted in lifts of no more than 8 inches to 95% standard proctor density at the optimum moisture content in accordance with ASTM D698 to achieve a permeability less than or equal to 1×10^{-7} (≤ 0.0000001) cm/sec. For in-situ soil material that meets the permeability requirement, the material must be scarified at least 8 inches deep and then re-compacted to finished grade.
- (2) Synthetic membrane: The liner must be a synthetic membrane liner at least 40 mils in thickness that completely covers the sides and the bottom of the pond. The liner material used must be compatible with the wastewater and be resistant to degradation (e.g., from

ultraviolet light, chemical reactions, wave action, erosion, etc.). The liner material must be installed and maintained in accordance with the manufacturer's guidelines. A wastewater pond with a synthetic membrane liner must include an underdrain with a leak detection and collection system.

- (3) Alternate liner: The permittee shall submit plans signed and sealed by a Texas-licensed professional engineer for any other equivalently protective pond lining method to the TCEQ Industrial Permits Team (MC 148) and copy the regional office.

- D. For a pond that must be lined according to subparagraph C (including ponds with in-situ soil liners), the permittee shall provide certification, signed and sealed by a Texas-licensed professional engineer, stating that the completed pond lining and any required underdrain with leak detection and collection system for the pond meet the requirements in subparagraph C(1) – C(3) before using the pond. The certification shall include the following minimum details about the pond lining system: (1) pond liner type (in-situ soil, amended in-situ soil, imported soil, synthetic membrane, or alternative), (2) materials used, (3) thickness of materials, and (4) either permeability test results or a leak detection and collection system description, as applicable.

The certification must be provided to the TCEQ Water Quality Assessment Team (MC 150), Industrial Permits Team (MC 148), and regional office. A copy of the liner certification and construction details (i.e., as-built drawings, construction QA/QC documentation, and post construction testing) must be kept on-site or in a reasonably accessible location (in either hardcopy or digital format) until the pond is closed.

- E. Protection and maintenance requirements for a pond subject to subparagraph B or C (including ponds with in-situ soil liners).
- (1) The permittee shall maintain a liner to prevent the unauthorized discharge of wastewater into or adjacent to water in the state.
 - (2) A liner must be protected from damage caused by animals. Fences or other protective devices or measures may be used to satisfy this requirement.
 - (3) The permittee shall maintain the structural integrity of the liner and shall keep the liner and embankment free of woody vegetation, animal burrows, and excessive erosion.
 - (4) The permittee shall inspect each pond liner and each leak detection system at least once per month. Evidence of damage or unauthorized discharge must be evaluated by a Texas-licensed professional engineer or Texas-licensed professional geoscientist within 30 days. The permittee is not required to drain an operating pond or to inspect below the waterline during these routine inspections.
 - a. A Texas-licensed professional engineer or Texas-licensed professional geoscientist must evaluate damage to a pond liner, including evidence of an unauthorized discharge without visible damage.
 - b. Pond liner damage must be repaired at the recommendation of a Texas-licensed professional engineer or Texas-licensed professional geoscientist. If the damage is significant or could result in an unauthorized discharge, then the repair must be documented and certified by a Texas-licensed professional engineer. Within 60 days after a repair is completed, the liner certification must be provided to the TCEQ Water Quality Assessments Team (MC 150) and regional office. A copy of the liner certification must be maintained at the facility or in a reasonably accessible location and made available to the executive director upon request.

- c. A release determination and subsequent corrective action will be based on 40 CFR Part 257 or the Texas Risk Reduction Program (30 TAC Chapter 350), as applicable. If evidence indicates that an unauthorized discharge occurred, including evidence that the actual permeability exceeds the design permeability, the matter may also be referred to the TCEQ Enforcement Division to ensure the protection of the public and the environment.
- F. For a pond subject to subparagraph B or C (including ponds with in-situ soil liners), the permittee shall have a Texas-licensed professional engineer perform an evaluation of each pond that requires a liner at least once every five years. The evaluation must include: (1) a physical inspection of the pond liner to check for structural integrity, damage, and evidence of leaking; (2) a review of the liner documentation for the pond; and (3) a review of all documentation related to liner repair and maintenance performed since the last evaluation. For the purposes of this evaluation, evidence of leaking also includes evidence that the actual permeability exceeds the design permeability. The permittee is not required to drain an operating pond or to inspect below the waterline during the evaluation. A copy of the engineer's evaluation report must be maintained at the facility or in a reasonably accessible location and made available to the executive director upon request.
- G. For a pond subject to subparagraph B or C (including ponds with in-situ soil liners), the permittee shall maintain at least 2.0 feet of freeboard in the pond except when:
 - (1) the freeboard requirement temporarily cannot be maintained due to a large storm event that requires the additional retention capacity to be used for a limited period of time;
 - (2) the freeboard requirement temporarily cannot be maintained due to upset plant conditions that require the additional retention capacity to be used for treatment for a limited period of time; or
 - (3) the pond was not required to have at least 2.0 feet of freeboard according to the requirements at the time of construction.
- 3. The mixing zone for Outfall 001 is defined as 300 feet downstream and 100 feet upstream from the point where the discharge reaches the Pease River. Chronic toxic criteria apply at the edge of the chronic aquatic life mixing zone.
- 4. This permit does not authorize the discharge of domestic wastewater. All domestic wastewater must be disposed of in an approved manner, such as routing to an approved on-site septic tank and drainfield system or to an authorized third party for treatment and disposal.

5. STORMWATER CONTRIBUTING SOURCES

For the purpose of this permit, the term "stormwater" is inclusive of the following defined contributing sources.

- A. Stormwater and stormwater runoff is defined as rainfall runoff, snow melt runoff, and surface runoff and drainage.
- B. Stormwater associated with industrial activity is defined as the discharge from any conveyance that is used for collecting and conveying stormwater and that is directly related to manufacturing, processing, or raw materials storage areas at an industrial facility. For the purpose of this permit, the term includes, but is not limited to, stormwater discharges from industrial plant yards; immediate access roads and rail lines used by or traveled by carriers of raw materials, manufactured products, waste material, or by-products used or created by the

facility; material handling areas; refuse/waste disposal of process wastewaters; sites used for the storage and maintenance of material-handling equipment; sites used for residual treatment, storage, or disposal; shipping and disposal areas; sites used for receiving areas; manufacturing buildings; storage areas (including tank farms), intermediate products, and final products; similar areas where stormwater can contact pollutants related to industrial activity; and areas where industrial activity have taken place in the past and significant materials remain and are exposed to stormwater. For the purposes of this definition, materials handling areas include areas where storage, loading and unloading, transportation, or conveyance of any raw material, intermediate product, final product, by-product, or waste product occur. The term excludes areas located at industrial sites that are separate from the facility's industrial activities, such as office buildings and accompanying parking lots, as long as the drainage from the excluded areas is not mixed with stormwater drained from areas of a facility that are covered by this permit.

C. Miscellaneous non-stormwater flows include any of the non-stormwater waste streams that qualify for coverage under the Multi-Sector General Permit for Industrial Stormwater (TXR050000, Part II, Section A, Item 6) as follows:

- 1) discharges from emergency firefighting activities and uncontaminated fire hydrant flushings (excluding discharges of hyperchlorinated water, unless the water is first dechlorinated and discharges are not expected to adversely affect aquatic life);
- 2) potable water sources (excluding discharges of hyperchlorinated water, unless the water is first dechlorinated and discharges are not expected to adversely affect aquatic life);
- 3) lawn watering and similar irrigation drainage, provided that all pesticides, herbicides, and fertilizer have been applied in accordance with the approved labeling;
- 4) water from the routine external washing of buildings, conducted without the use of detergents or other chemicals;
- 5) water from the routine washing of pavement conducted without the use of detergents or other chemicals and where spills or leaks of toxic or hazardous materials have not occurred (unless all spilled material has been removed);
- 6) uncontaminated air conditioner condensate, compressor condensate, and steam condensate, and condensate from the outside storage of refrigerated gases or liquids;
- 7) water from foundation or footing drains where flows are not contaminated with pollutants (e.g., process materials, solvents, and other pollutants);
- 8) uncontaminated water used for dust suppression;
- 9) springs and other uncontaminated groundwater; and
- 10) incidental windblown mist from cooling towers that collects on rooftops or adjacent portions of the facility, but excluding intentional discharges from the cooling tower (e.g., "piped" cooling tower blowdown or drains).

6. COOLING WATER INTAKE STRUCTURE REQUIREMENTS

The permittee shall provide written notification to the TCEQ Industrial Permits Team (MC 148) and Region 3 Office of any changes in the method by which the facility obtains water for cooling purposes. This notification must be submitted 30 days prior to any such change and must include

a description of the planned changes. The TCEQ may, upon review of the notification, reopen the permit to include additional terms and conditions as necessary.

CHRONIC BIOMONITORING REQUIREMENTS: FRESHWATER

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

1. Scope, Frequency, and Methodology

- a. The permittee shall test the effluent for toxicity in accordance with the provisions below. Such testing will determine if an appropriately dilute effluent sample adversely affects the survival, reproduction, or growth of the test organisms.
- b. The permittee shall conduct the following toxicity tests using the test organisms, procedures and quality assurance requirements specified in this part of this permit and in accordance with "Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms," fourth edition (EPA-821-R-02-013) or its most recent update:
 - 1) Chronic static renewal 7-day larval survival and growth test using the fathead minnow (*Pimephales promelas*) (Method 1000.0). A minimum of five replicates with eight organisms per replicate shall be used in the control and in each dilution. This test shall be conducted once per quarter.

The permittee must perform and report a valid test for each test species during the prescribed reporting period. An invalid test must be repeated during the same reporting period. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. The permittee shall use five effluent dilution concentrations and a control in each toxicity test. These effluent dilution concentrations are 38%, 51%, 68%, 92%, and 100% effluent. The critical dilution, defined as 92% effluent, is the effluent concentration representative of the proportion of effluent in the receiving water during critical low flow or critical mixing conditions.
- d. The lethal IC₂₅ effluent limitations of not less than 92% and the sublethal IC₂₅ of 80% is effective for the test species (see the EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS section). The IC₂₅ is the inhibition concentration of effluent that would cause a 25% reduction in survival or reproduction/growth when compared to the control.
- e. If a test species fails to pass the lethal endpoint at the 92% effluent concentration or the sublethal endpoint at the 80% effluent concentration, the testing frequency will increase to monthly for that test species until such time compliance with the IC₂₅ effluent limitation is demonstrated for a period of three consecutive months, at which time the quarterly testing frequency may be resumed.

2. Required Toxicity Testing Conditions

- a. Test Acceptance - The permittee shall repeat any toxicity test, including the control and all effluent dilutions, which fail to meet the following criteria:
 - 1) a control mean survival of 80% or greater;
 - 2) a control mean dry weight of surviving fathead minnow larvae of 0.25 mg or

greater;

- 3) a control coefficient of variation percent (CV%) of 40 or less in between replicates for the growth and survival endpoints in the fathead minnow test;
- 4) a critical dilution CV% of 40 or less for the growth and survival endpoints for the fathead minnow test, unless statistically significant toxicity is demonstrated at the critical dilution, in which case the test shall be considered valid; and
- 5) a PMSD of 30 or less for fathead minnow growth, unless statistically significant sublethal toxicity is demonstrated at the critical dilution, in which case the test shall be considered valid.

b. Statistical Interpretation

- 1) For the fathead minnow larval survival and growth tests, the statistical analyses used to determine the IC₂₅ in survival or growth shall be as described in the methods manual referenced in Part 1.b.
- 2) The permittee is responsible for reviewing test concentration-response relationships to ensure that calculated test-results are interpreted and reported correctly. The document entitled "Method Guidance and Recommendation for Whole Effluent Toxicity (WET) Testing (40 CFR Part 136)" (EPA 821-B-00-004) provides guidance on determining the validity of test results.
- 3) Most point estimates are derived from a mathematical model that assumes a continuous dose-response relationship. For any test result that demonstrates a non-continuous (threshold) response, or a non-monotonic dose-response relationship, the IC₂₅ should be determined based on the method guidance manual referenced in Item 3.
- 4) Pursuant to the responsibility assigned to the permittee in Part 2.b.3), test results that demonstrate a non-monotonic dose-response relationship may be submitted, prior to the due date, for technical review of test validity and acceptability. The method guidance manual referenced in Item 3 will be used as the basis, along with best professional judgement, for making a determination of test validity and acceptability.

c. Dilution Water

- 1) Dilution water used in the toxicity tests shall be the receiving water collected at a point upstream of the discharge as close as possible to the discharge point but unaffected by the discharge. Where the toxicity tests are conducted on effluent discharges to receiving waters that are classified as intermittent streams, or where the toxicity tests are conducted on effluent discharges where no receiving water is available due to zero flow conditions, the permittee shall:
 - a) substitute a synthetic dilution water that has a pH, hardness, and alkalinity similar to that of the closest downstream perennial water unaffected by the discharge; or
 - b) use the closest downstream perennial water unaffected by the discharge.

- 2) Where the receiving water proves unsatisfactory as a result of pre-existing instream toxicity (i.e. fails to fulfill the test acceptance criteria of Part 2.a.), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
 - a) a synthetic lab water control was performed (in addition to the receiving water control) which fulfilled the test acceptance requirements of Part 2.a;
 - b) the test indicating receiving water toxicity was carried out to completion (i.e., 7 days);
 - c) the permittee submitted all test results indicating receiving water toxicity with the reports and information required in Part 3.
- 3) The synthetic dilution water shall consist of standard, moderately hard, reconstituted water. Upon approval, the permittee may substitute other appropriate dilution water with chemical and physical characteristics similar to that of the receiving water.

d. Samples and Composites

- 1) The permittee shall collect a minimum of three composite samples from Outfall 001. The second and third composite samples will be used for the renewal of the dilution concentrations for each toxicity test.
- 2) The permittee shall collect the composite samples such that the samples are representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged on an intermittent basis.
- 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the first composite sample. The holding time for any subsequent composite sample shall not exceed 72 hours. Samples shall be maintained at a temperature of 0-6 degrees Centigrade during collection, shipping, and storage.
- 4) If Outfall 001 ceases discharging during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions, and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume sufficient to complete the required toxicity tests with renewal of the effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report.

3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted in accordance with the manual referenced in Part 1.b. for every valid and invalid toxicity test initiated whether carried to completion or not.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 1 forms provided with this permit.
 - 1) Annual biomonitoring test results are due on or before January 20th for biomonitoring conducted during the previous 12-month period.
 - 2) Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.
 - 3) Quarterly biomonitoring test results are due on or before April 20th, July 20th, October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.
 - 4) Monthly biomonitoring test results are due on or before the 20th day of the month following sampling.
- c. Enter the following codes for the appropriate parameters for valid tests only:
 - 1) For the fathead minnow, Parameter T4P6C, enter a "1" if the IC25 for survival is less than the critical dilution; otherwise, enter a "0."
 - 2) For the fathead minnow, Parameter T6P6C, report the IC25 for survival.
 - 3) For the fathead minnow, Parameter T5P6C, enter a "1" if the IC25 for growth is less than the critical dilution; otherwise, enter a "0."
 - 4) For the fathead minnow, Parameter T7P6C, report the IC25 for growth.
- d. The permittee shall report the lethal and sublethal WET values for the 30-day average and the 7-day minimum under Parameter No. 51714 for the fathead minnow for the appropriate reporting period. If more than one valid test was performed during the reporting period, those IC25s will be averaged arithmetically and reported as the daily average IC25. The data submitted should reflect the lowest lethal and sublethal test results during the reporting period.

TABLE 1 (SHEET 1 OF 2)

BIOMONITORING REPORTING

FATHEAD MINNOW LARVAE GROWTH AND SURVIVAL

Dates and Times No. 1 FROM: _____ Date Time TO: _____ Date Time
 Composites
 Collected No. 2 FROM: _____ TO: _____
 No. 3 FROM: _____ TO: _____

Test initiated: _____ am/pm _____ date

Dilution water used: _____ Receiving water _____ Synthetic dilution water

FATHEAD MINNOW GROWTH DATA

Effluent Concentration	Average Dry Weight in replicate chambers					Mean Dry Weight	CV%*
	A	B	C	D	E		
0%							
38%							
51%							
80%							
92%							
100%							

* Coefficient of Variation = standard deviation x 100/mean

TABLE 1 (SHEET 2 OF 2)

BIOMONITORING REPORTING

FATHEAD MINNOW GROWTH AND SURVIVAL TEST

FATHEAD MINNOW SURVIVAL DATA

Effluent Concentration	Percent Survival in replicate chambers					Mean percent survival			CV%*
	A	B	C	D	E	24h	48h	7 day	
0%									
38%									
51%									
80%									
92%									
100%									

* Coefficient of Variation = standard deviation x 100/mean

1. Is the IC 25 for growth less than the critical dilution (92%)? _____ YES _____ NO
2. Is the IC 25 for survival less than the critical dilution (92%)? _____ YES _____ NO
3. Enter percent effluent corresponding to each IC25 below:

IC25 survival = _____%

IC25 reproduction = _____%

24-HOUR ACUTE BIOMONITORING REQUIREMENTS: FRESHWATER

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

1. Scope, Frequency, and Methodology

- a. The permittee shall test the effluent for lethality in accordance with the provisions in this section. Such testing will determine compliance with Texas Surface Water Quality Standard 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the appropriate test organisms in 100% effluent for a 24-hour period.
- b. The toxicity tests specified shall be conducted once per six months. The permittee shall conduct the following toxicity tests using the test organisms, procedures, and quality assurance requirements specified in this section of the permit and in accordance with “Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms,” fifth edition (EPA-821-R-02-012) or its most recent update:
 - 1) Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*). A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution.

The permittee must perform and report a valid test for each test species during the prescribed reporting period. An invalid test must be repeated during the same reporting period. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. In addition to an appropriate control, a 100% effluent concentration shall be used in the toxicity tests. Except as discussed in item 2.b., the control and dilution water shall consist of standard, synthetic, moderately hard, reconstituted water.
- d. This permit may be amended to require a WET limit, a Best Management Practice (BMP), Chemical-Specific (CS) limits, or other appropriate actions to address toxicity. The permittee may be required to conduct a Toxicity Reduction Evaluation after multiple toxic events.
- e. As the dilution series specified in the Chronic Biomonitoring Requirements includes a 100% effluent concentration, the results from those tests may fulfill the requirements of this Section; any tests performed in the proper time interval may be substituted. Compliance will be evaluated as specified in item a. The 50% survival in 100% effluent for a 24-hour period standard applies to all tests utilizing a 100% effluent dilution, regardless of whether the results are submitted to comply with the minimum testing frequency defined in item b.

2. Required Toxicity Testing Conditions

- a. Test Acceptance - The permittee shall repeat any toxicity test, including the control, if the control fails to meet a mean survival equal to or greater than 90%.
- b. Dilution Water - In accordance with item 1.c., the control and dilution water shall normally consist of standard, synthetic, moderately hard, reconstituted water. If the permittee utilizes the results of a chronic test to satisfy the requirements in item 1.e.,

the permittee may use the receiving water or dilution water that meets the requirements of item 2.a as the control and dilution water.

c. Samples and Composites

- 1) The permittee shall collect one composite sample from Outfall 001.
- 2) The permittee shall collect the composite samples such that the sample is representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged.
- 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the composite sample. The samples shall be maintained at a temperature of 0-6 degrees Centigrade during collection, shipping, and storage.
- 4) If Outfall 001 ceases discharging during the collection of the effluent composite sample, the requirements for the minimum number of effluent portions are waived. However, the permittee must have collected a composite sample volume sufficient for completion of the required test. The abbreviated sample collection, duration, and methodology must be documented in the full report.

3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this permit in accordance with the manual referenced in Part 1.b. for every valid and invalid toxicity test initiated.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 2 forms provided with this permit.
 - 1) Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.
 - 2) Quarterly biomonitoring test results are due on or before April 20th, July 20th, October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.
- c. Enter the following codes for the appropriate parameters for valid tests only:
 - 1) For the fathead minnow, Parameter TIE6C, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter "1."
- d. Enter the following codes for retests only:
 - 1) For retest number 1, Parameter 22415, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter "1."

- 2) For retest number 2, Parameter 22416, enter a “o” if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter “1.”

4. Persistent Mortality

The requirements of this part apply when a toxicity test demonstrates significant lethality, which is defined as a mean mortality of 50% or greater of organisms exposed to the 100% effluent concentration for 24 hours.

- a. The permittee shall conduct 2 additional tests (retests) for each species that demonstrates significant lethality. The two retests shall be conducted once per week for 2 weeks. Five effluent dilution concentrations in addition to an appropriate control shall be used in the retests. These effluent concentrations are 6%, 13%, 25%, 50% and 100% effluent. The first retest shall be conducted within 15 days of the laboratory determination of significant lethality. All test results shall be submitted within 20 days of test completion of the second retest. Test completion is defined as the 24th hour.
- b. If one or both of the two retests specified in Part 4.a. demonstrates significant lethality, the permittee shall initiate the TRE requirements as specified in Part 5.

5. Toxicity Reduction Evaluation

- a. Within 45 days of the retest that demonstrates significant lethality, the permittee shall submit a general outline for initiating a TRE. The outline shall include, but not be limited to, a description of project personnel, a schedule for obtaining consultants (if needed), a discussion of influent and effluent data available for review, a sampling and analytical schedule, and a proposed TRE initiation date.
- b. Within 90 days of the retest that demonstrates significant lethality, the permittee shall submit a TRE action plan and schedule for conducting a TRE. The plan shall specify the approach and methodology to be used in performing the TRE. A TRE is a step-wise investigation combining toxicity testing with physical and chemical analysis to determine actions necessary to eliminate or reduce effluent toxicity to a level not effecting significant lethality at the critical dilution. The TRE action plan shall lead to the successful elimination of significant lethality for both test species defined in Part 1.b. At a minimum, the TRE action plan shall include the following:
 - 1) Specific Activities - The TRE action plan shall specify the approach the permittee intends to utilize in conducting the TRE, including toxicity characterizations, identifications, confirmations, source evaluations, treatability studies, and alternative approaches. When conducting characterization analyses, the permittee shall perform multiple characterizations and follow the procedures specified in the document entitled “Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures” (EPA/600/6-91/003) or alternate procedures. The permittee shall perform multiple identifications and follow the methods specified in the documents entitled “Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity” (EPA/600/R-92/080) and “Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity” (EPA/600/R-92/081). All characterization, identification, and confirmation tests shall be conducted in an

- orderly and logical progression;
- 2) Sampling Plan - The TRE action plan should describe sampling locations, methods, holding times, chain of custody, and preservation techniques. The effluent sample volume collected for all tests shall be adequate to perform the toxicity characterization/identification/confirmation procedures, and chemical-specific analyses when the toxicity tests show significant lethality. Where the permittee has identified or suspects a specific pollutant and source of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical-specific analyses for the identified and suspected pollutant and source of effluent toxicity;
 - 3) Quality Assurance Plan - The TRE action plan should address record keeping and data evaluation, calibration and standardization, baseline tests, system blanks, controls, duplicates, spikes, toxicity persistence in the samples, randomization, reference toxicant control charts, and mechanisms to detect artifactual toxicity; and
 - 4) Project Organization - The TRE action plan should describe the project staff, manager, consulting engineering services (where applicable), consulting analytical and toxicological services, etc.
- c. Within 30 days of submittal of the TRE action plan and schedule, the permittee shall implement the TRE.
- d. The permittee shall submit quarterly TRE activities reports concerning the progress of the TRE. The quarterly TRE activities reports are due on or before April 20th, July 20th, October 20th, and January 20th. The report shall detail information regarding the TRE activities including:
- 1) results and interpretation of any chemical-specific analyses for the identified and suspected pollutant performed during the quarter;
 - 2) results and interpretation of any characterization, identification, and confirmation tests performed during the quarter;
 - 3) any data and substantiating documentation that identifies the pollutant and source of effluent toxicity;
 - 4) results of any studies/evaluations concerning the treatability of the facility's effluent toxicity;
 - 5) any data that identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to eliminate significant lethality; and
 - 6) any changes to the initial TRE plan and schedule that are believed necessary as a result of the TRE findings.
- e. During the TRE, the permittee shall perform, at a minimum, quarterly testing using the more sensitive species. Testing for the less sensitive species shall continue at the frequency specified in Part 1.b.
- f. If the effluent ceases to effect significant lethality, i.e., there is a cessation of lethality,

the permittee may end the TRE. A cessation of lethality is defined as no significant lethality for a period of 12 consecutive weeks with at least weekly testing. At the end of the 12 weeks, the permittee shall submit a statement of intent to cease the TRE and may then resume the testing frequency specified in Part 1.b.

This provision accommodates situations where operational errors and upsets, spills, or sampling errors triggered the TRE, in contrast to a situation where a single toxicant or group of toxicants cause lethality. This provision does not apply as a result of corrective actions taken by the permittee. Corrective actions are defined as proactive efforts that eliminate or reduce effluent toxicity. These include, but are not limited to, source reduction or elimination, improved housekeeping, changes in chemical usage, and modifications of influent streams and effluent treatment.

The permittee may only apply this cessation of lethality provision once. If the effluent again demonstrates persistent significant lethality to the same species, the permit will be amended to add a WET limit with a compliance period, if appropriate. However, prior to the effective date of the WET limit, the permittee may apply for a permit amendment removing and replacing the WET limit with an alternate toxicity control measure by identifying and confirming the toxicant and an appropriate control measure.

- g. The permittee shall complete the TRE and submit a final report on the TRE activities no later than 18 months from the last test day of the retest that demonstrates significant lethality. The permittee may petition the Executive Director (in writing) for an extension of the 18-month limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE. The report shall specify the control mechanism that will, when implemented, reduce effluent toxicity as specified in item 5.h. The report will also specify a corrective action schedule for implementing the selected control mechanism.
- h. Within 3 years of the last day of the test confirming toxicity, the permittee shall comply with 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the test organism in 100% effluent at the end of 24-hours. The permittee may petition the Executive Director (in writing) for an extension of the 3-year limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE.

The permittee may be exempted from complying with 30 TAC § 307.6(e)(2)(B) upon proving that toxicity is caused by an excess, imbalance, or deficiency of dissolved salts. This exemption excludes instances where individually toxic components (e.g., metals) form a salt compound. Following the exemption, this permit may be amended to include an ion-adjustment protocol, alternate species testing, or single species testing.

- i. Based upon the results of the TRE and proposed corrective actions, this permit may be amended to modify the biomonitoring requirements where necessary, require a compliance schedule for implementation of corrective actions, specify a WET limit, specify a best management practice, and specify a chemical-specific limit.
- j. Copies of any and all required TRE plans and reports shall also be submitted to the U.S. EPA Region 6 office, 6WQ-PO.

TABLE 1 (SHEET 1 OF 1)
FATHEAD MINNOW SURVIVAL

GENERAL INFORMATION

	Time	Date
Composite Sample Collected		
Test Initiated		

PERCENT SURVIVAL

Time	Rep	Percent effluent					
		0%	6%	13%	25%	50%	100%
24h	A						
	B						
	C						
	D						
	E						
	MEAN						

Enter percent effluent corresponding to the LC50 below:

24 hour LC50 = _____% effluent

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

For draft Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0002537000, U.S. Environmental Protection Agency (EPA) ID No. TX0088751, to discharge to water in the state

Issuing Office: Texas Commission on Environmental Quality (TCEQ)
P.O. Box 13087
Austin, Texas 78711-3087

Applicant: Syensqo USA LLC
2564 U.S. Highway 1
Lawrence, New Jersey 08648

Prepared By: Thomas E. Starr
Wastewater Permitting Section
Water Quality Division
(512) 239-4570

Date: April 29, 2025

Permit Action: Renewal without changes

I. EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit will expire at midnight, five years from the date of permit issuance according to the requirements of 30 Texas Administrative Code (TAC) §305.127(1)(C)(i).

II. APPLICANT ACTIVITY

The applicant currently operates Syensqo USA Vernon Plant, a guar bean processing plant.

III. DISCHARGE LOCATION

As described in the application, the facility is located at 201 Harrison Street, in the City of Vernon, Wilbarger County, Texas 76384. Discharge is via Outfall 001 directly to the Pease River; and via Outfall 002 to man-made and natural ditches, thence to the Pease River in Segment No. 0230 of the Red River Basin.

IV. RECEIVING STREAM USES

The unclassified receiving water uses are minimal aquatic life use for the manmade and natural ditches. The designated uses for Segment No. 0230 are primary contact recreation and intermediate aquatic life use.

V. STREAM STANDARDS

The general criteria and numerical criteria that make up the stream standards are provided in 30 TAC §§ 307.1 - 307.10.

VI. DISCHARGE DESCRIPTION

The following is a quantitative description of the discharge described in the monthly effluent report data for the period January 2020 through December 2024. The "average of daily average"

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

values presented in the following table are the average of all daily average values for the reporting period for each pollutant. The "maximum of daily maximum" values presented in the following table are the individual maximum values for the reporting period for each pollutant. Flows are expressed in million gallons per day (MGD). All pH values are expressed in standard units (SU).

A. Flow

Outfall	Frequency	Average of Daily Average, MGD	Maximum of Daily Maximum, MGD
001	Continuous	0.304	0.919
002	Intermittent	0.237	0.496

B. Effluent Characteristics

Outfall	Pollutant	Average of Daily Average		Maximum of Daily Maximum	
		lbs/day	mg/L	lbs/day	mg/L
001	Carbonaceous Biochemical Oxygen Demand, 5-day (CBOD ₅) (Apr-Oct)	29.65	9.19	59.19	25.4
	CBOD ₅ (Nov-Feb)	32.49	9.51	287.93	77.7
	CBOD ₅ (March)	27.71	9.022	73.33	26.5
	Total Suspended Solids (TSS)	54.58	17.09	728.6	197.0
	Total Organic Carbon (TOC)	1261	405.0	3661	1000
	Ammonia Nitrogen	N/A	0.255	N/A	2.78
	Dissolved Oxygen (DO)	5.04 minimum		N/A	N/A
	pH	6.67 SU, minimum		8.52 SU	

B. Effluent Characteristics

Outfall	Pollutant	Average of Daily Average,	Maximum of Daily Maximum,
		mg/L	mg/L
002	Chemical Oxygen Demand (COD)	N/A	439.0
	Oil & Grease	N/A	5.00
	pH	7.29 SU, minimum	8.70 SU

Effluent limit violations documented in the monthly effluent reports are summarized in the following table.

C. Effluent Limitation Violations

Outfall	Pollutant (units)	Month/Year	Daily Average		Daily Maximum	
			Limit	Reported	Limit	Reported
001	TSS	1/2019	-	-	650	728.59

The draft permit was not changed to address this effluent limit violation because of its infrequent nature.

VII. DRAFT EFFLUENT LIMITATIONS

Effluent limitations are established in the draft permit as shown in Appendix C.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

OUTFALL LOCATIONS

Outfall	Latitude	Longitude
001	34.176253 N	99.305579 W
002	34.165917 N	99.300334 W

VIII. SUMMARY OF CHANGES FROM APPLICATION

No changes were made from the application.

IX. SUMMARY OF CHANGES FROM EXISTING PERMIT

The following changes have been made to the draft permit:

1. Pages 3-13 were updated (May 2021 version).
2. The company name was changed from Syensqo USA Inc. to Syensqo USA LLC and Vernon Guar Plant to Syensqo USA Vernon Plant And the customer address has changed.
3. Other Requirement No. 3 was updated to reflect current mixing zones.
4. Other Requirement No. 6 was added to the draft permit to address cooling water intake structure requirements under CWA §316(b). Although CWA §316(b) does not currently apply to this facility, the applicant would be required to notify the TCEQ if there is a change in how the facility obtains cooling water.

X. DRAFT PERMIT RATIONALE

The following section sets forth the statutory and regulatory requirements considered in preparing the draft permit. Also set forth are any calculations or other necessary explanations of the derivation of specific effluent limitations and conditions, including a citation to the applicable effluent limitation guidelines and water quality standards.

A. REASON FOR PERMIT ISSUANCE

The applicant applied to the TCEQ for a renewal of TPDES Permit No. WQ0002537000, which authorizes the discharge of treated process wastewater, utility wastewater, and first flush stormwater at a daily average flow not to exceed 1,300,000 gallons per day via Outfall 001; and stormwater on an intermittent and flow-variable basis via Outfall 002.

B. WATER QUALITY SUMMARY**Discharge Routes**

The discharge routes are via Outfall 001 directly to the Pease River and via Outfall 002 to man-made and natural ditches, thence to the Pease River in Segment No. 0230 of the Red River Basin. The unclassified receiving water uses are minimal aquatic life use for the man-made and natural ditches. The designated uses for Segment No. 0230 are primary contact recreation and intermediate aquatic life use. Effluent limitations and conditions established in the draft permit comply with state water quality standards and the applicable water quality management plan. The effluent limits in the draft permit will maintain and protect the existing instream uses. Additional discussion of the water quality aspects of the draft permit can be found at Section X.D. of this fact sheet.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Endangered Species Review

The Whooping Crane (*Grus Americana*), an endangered aquatic dependent species has been determined to occur in Wilbarger County. However, the county is not located in a watershed of critical concern for the Whooping Crane. To make this determination for Texas Pollutant Discharge Elimination System (TPDES) permits, TCEQ and EPA only considered aquatic or aquatic dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the United States Fish and Wildlife Service's (USFWS) biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Impaired Water Bodies

Segment No. 0230 is not currently listed on the state's inventory of impaired and threatened waters, the 2022 Clean Water Act Section 303(d) list.

Completed Total Maximum Daily Loads (TMDLs)

There are no completed TMDLs for Segment No. 0230.

C. TECHNOLOGY-BASED EFFLUENT LIMITATIONS/CONDITIONS**1. GENERAL COMMENTS**

Regulations in Title 40 of the Code of Federal Regulations (40 CFR) require that technology-based limitations be placed in wastewater discharge permits based on effluent limitations guidelines, where applicable, or on best professional judgment (BPJ) in the absence of guidelines.

The draft permit authorizes the discharge of treated process wastewater, utility wastewater, and first flush stormwater at a daily average flow not to exceed 1,300,000 gallons per day via Outfall 001; and stormwater on an intermittent and flow-variable basis via Outfall 002.

The discharges via Outfalls 001 and 002 from this facility are not subject to federal effluent limitation guidelines and any technology-based effluent limitations are based on BPJ.

The wastewater system at this facility consists of industrial wastewater that is collected in an influent sump (SU-107) and sent to the wastewater treatment unit (WWTU) for treatment. The WWTU consists of an equalization basin (SU-103), a dissolved air flotation unit (CL-103) used as needed, an aerated bioreactor (SU-102), and an effluent clarifier (CL-102). The biologically treated wastewater is routed through a floc mix tank (T-103), where wastewater is mixed with liquid polymer prior to entering the effluent clarifier (CL-102). Clarified wastewater is sent to the effluent sump (SU-111) which then discharges to the Pease River via Outfall 001. Settled solids from the clarifier are recycled to either the aerated bioreactor or the sludge digester (SU-104). The sludge from the digester may be thickened when needed in the sludge thickener (CL-101) and returned to SU-104. The treated sludge is hauled to the landfarm for disposal. A 3.8-million-gallon surge basin (SU-110) is designed for temporary use during plant emergencies. The wastewater collected in the surge basin is treated in the WWTU before discharge via Outfall 001. Facility-wide stormwater is collected in the stormwater catch basin (SU-144). The collected stormwater is tested to meet the permit

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

requirements before discharge via Outfall 002 on an intermittent basis. Stormwater can be routed to SU-103, the equalization basin, for treatment as needed.

Domestic wastewater generated on site is routed to the City of Vernon's wastewater treatment plant for treatment and disposal.

2. CALCULATIONS

The wastewaters discharged via Outfalls 001 and 002 are not subject to EPA categorical guidelines. All technology-based limitations were originally based on BPJ and continued from the existing permit as required by EPA anti-backsliding regulations [40 CFR 122.44(l)].

See Appendix C for the technology-based effluent limitations proposed in the draft permit.

3. 316(B) COOLING WATER INTAKE STRUCTURES

a. SCREENING

The facility obtains water from a public water system (PWS No. 2440001), for cooling purposes. The use of water obtained from a public water system for cooling purposes does not constitute the use of a cooling water intake structure; therefore, the facility is not subject to Section 316(b) of the CWA or 40 CFR Part 125, Subpart J.

b. PERMIT ACTION

Other Requirement No. 6 has been added to the draft permit and requires the permittee to notify the TCEQ of any changes in the method by which cooling water is obtained. Upon receipt of such notification, the TCEQ may reopen the permit to include additional terms and conditions as necessary.

D. WATER QUALITY-BASED EFFLUENT LIMITATIONS/CONDITIONS

1. GENERAL COMMENTS

The *Texas Surface Water Quality Standards* found at 30 TAC Chapter 307 state that surface waters will not be toxic to man from ingestion of water, consumption of aquatic organisms, or contact with the skin, or to terrestrial or aquatic life. The methodology outlined in the TCEQ guidance document *Procedures to Implement the Texas Surface Water Quality Standards* (IPs) is designed to ensure compliance with 30 TAC Chapter 307. Specifically, the methodology is designed to ensure that no source will be allowed to discharge any wastewater that (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical state water quality standard; (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation that threatens human health. Calculated water quality-based effluent limits can be found in Appendix A of this fact sheet.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

TPDES permits contain technology-based effluent limits reflecting the best controls available. Where these technology-based permit limits do not protect water quality or the designated uses, additional water quality-based effluent limitations or conditions are included. State narrative and numerical water quality standards are used in conjunction with EPA criteria and other toxicity databases to determine the adequacy of technology-based permit limits and the need for additional water quality-based controls. A comparison of technology-based effluent limits and calculated water quality-based effluent limits can be found in Appendix C of this fact sheet.

2. AQUATIC LIFE CRITERIAa. SCREENING

Water quality-based effluent limitations for Outfall 001 are calculated from freshwater aquatic life criteria found in Table 1 of the *Texas Surface Water Quality Standards* (30 TAC Chapter 307).

Acute freshwater criteria are applied at the edge of the zone of initial dilution (ZID), and chronic freshwater criteria are applied at the edge of the aquatic life mixing zone. The ZID for this discharge is defined as 20 feet upstream and 60 feet downstream from the point where the discharge enters the Pease River. The aquatic life mixing zone for this discharge is defined as 100 feet upstream and 300 feet downstream from the point where the discharge enters the Pease River.

TCEQ uses the mass balance equation to estimate dilutions at the edges of the ZID and aquatic life mixing zone during critical conditions. The estimated dilution at the edge of the aquatic life mixing zone is calculated using the two-year maximum monthly average flow of 0.666 MGD and the seven-day, two-year low-flow (7Q2) of 0.1 cfs for the Pease River. The estimated dilution at the edge of the ZID is calculated using the two-year maximum monthly average flow of 0.666 MGD and 25% of the 7Q2. The following critical effluent percentages are being used:

Acute Effluent %	97.6%	Chronic Effluent %	91.1%
------------------	-------	--------------------	-------

General Screening Procedures

Wasteload allocations (WLAs) are calculated using the above estimated effluent percentages, criteria outlined in the *Texas Surface Water Quality Standards*, and partitioning coefficients for metals (when appropriate and designated in the implementation procedures). The WLA is the end-of-pipe effluent concentration that can be discharged when, after mixing in the receiving stream, the instream numerical criteria will not be exceeded.

From the WLA, a long-term average (LTA) is calculated using a lognormal probability distribution, a given coefficient of variation (0.6), and a 90th percentile confidence level. The LTA is the long-term average effluent concentration for which the WLA will never be exceeded using a selected percentile confidence level.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

The lower of the two LTAs (acute and chronic) is used to calculate a daily average and daily maximum effluent limitation for the protection of aquatic life using the same statistical considerations with the 99th percentile confidence level and a standard number of monthly effluent samples collected (12).

Assumptions used in deriving the effluent limitations include segment-specific values for TSS, pH, hardness, and chloride according to the *IPs*. The segment values are 8.6 mg/L for TSS, 7.5 standard units for pH, 1,779 mg/L for hardness (as calcium carbonate, CaCO₃), and 3,677 mg/L for chloride. For additional details on the calculation of water quality-based effluent limitations, refer to the *IPs*.

TCEQ practice for determining significant potential is to compare the reported analytical data against percentages of the calculated daily average water quality-based effluent limitation. Permit limitations are required when analytical data reported in the application equals or exceeds 85 percent of the calculated daily average water quality-based effluent limitation. Monitoring and reporting is required when analytical data reported in the application equals or exceeds 70 percent of the calculated daily average water quality-based effluent limitation.

b. PERMIT ACTION

Analytical data reported in the application was screened against calculated water quality-based effluent limitations for the protection of aquatic life. Reported analytical data does not exceed 70 percent of the calculated daily average water quality-based effluent limitation for aquatic life protection. No additional limits or monitoring and reporting requirements have been added to the draft permit.

3. WHOLE EFFLUENT TOXICITY (BIOMONITORING) CRITERIA (7-DAY CHRONIC)

a. SCREENING AND REASONABLE POTENTIAL ANALYSIS

The existing permit includes chronic freshwater biomonitoring requirements at Outfall 001.

In the past three years, the permittee has performed twelve chronic tests, with zero demonstrations of significant mortality (i.e. zero failures).

b. PERMIT ACTION

The provisions of this section apply to Outfall 001.

The lethal and sublethal WET limits of 92% and 80%, respectively, are retained. Therefore, no reasonable potential was performed.

Whole effluent toxicity testing (biomonitoring) is the most direct measure of potential toxicity, which incorporates the effects of synergism of effluent components and receiving stream water quality characteristics.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Biomonitoring of the effluent is, therefore, required as a condition of this permit to assess potential toxicity. The biomonitoring procedures stipulated as a condition of this permit are as follows:

Chronic static renewal 7-day larval survival and growth test using the fathead minnow (*Pimephales promelas*). The frequency of testing shall be once per quarter.

Toxicity tests shall be performed in accordance with protocols described in *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition (EPA-821-R-02-013) or the latest revision. The stipulated test species is appropriate to measure the toxicity of the effluent consistent with the requirements of the state water quality standards. The biomonitoring frequency has been established to reflect the likelihood of ambient toxicity and to provide data representative of the toxic potential of the facility's discharge.

c. DILUTION SERIES

The permit requires five (5) dilutions in addition to the control (0% effluent) to be used in the toxicity tests. These additional effluent concentrations shall be 38%, 51%, 68%, 92%, and 100%. The low-flow effluent concentration (critical dilution) is defined as 92% effluent.

The dilution series outlined above was calculated using a 0.75 factor applied to the critical dilution. The critical dilution is the estimated effluent dilution at the edge of the aquatic life mixing zone, which is discussed in Section X.D.2.a. of this fact sheet.

d. WHOLE EFFLUENT TOXICITY (WET) LIMITATIONS

The following whole effluent toxicity (WET) limits are proposed in the draft permit.

Outfall	Test/Species	Dly Avg	Dly Max
001	Lethal WET Limit (7-day chronic IC ₂₅ [*]) <i>Pimephales promelas</i>	92%	92%
	Sublethal WET Limit (7-day chronic IC ₂₅ ^a) <i>Pimephales promelas</i>	80%	80%

* The IC₂₅ is defined the inhibition concentration of effluent that would cause a 25% reduction in the specified endpoint.

4. AQUATIC ORGANISM TOXICITY CRITERIA (24-HOUR ACUTE)

a. SCREENING

The existing permit includes 24-hour acute freshwater biomonitoring requirements for the fathead minnow (*Pimephales promelas*) at Outfall 001.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

In the past three years, the permittee has performed six 24-hour acute tests, with zero demonstrations of significant mortality (i.e., zero failures).

b. PERMIT ACTION

Twenty-four-hour 100% acute biomonitoring tests are required at Outfall 001 at a frequency of once per six months for the life of the permit.

The biomonitoring procedures stipulated as a condition of this permit are as follows:

Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*). A minimum of five (5) replicates with eight (8) organisms per replicate shall be used for this test.

Toxicity tests shall be performed in accordance with protocols described in *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, Fifth Edition (EPA-821-R-02-012) or the latest revision.

5. AQUATIC ORGANISM BIOACCUMULATION CRITERIA

a. SCREENING

Water quality-based effluent limitations for the protection of human health are calculated using criteria for the consumption of fish tissue found in Table 2 of the *Texas Surface Water Quality Standards* (30 TAC Chapter 307).

Fish tissue bioaccumulation criteria are applied at the edge of the human health mixing zone. The human health mixing zone for this discharge is identical to the aquatic life mixing zone. TCEQ uses the mass balance equation to estimate dilution at the edge of the human health mixing zone during average flow conditions. The estimated dilution at the edge of the human health mixing zone is calculated using the two-year average monthly average flow of 0.357 MGD and the harmonic mean flow of 0.82 cfs for the Pease River. The following critical effluent percentage is being used:

Human Health Effluent %: 40.3%

Water quality-based effluent limitations for human health protection against the consumption of fish tissue are calculated using the same procedure as outlined for calculation of water quality-based effluent limitations for aquatic life protection. A 99th percentile confidence level in the long-term average calculation is used, with only one long-term average value being calculated.

Significant potential is again determined by comparing reported analytical data against 70 percent and 85 percent of the calculated daily average water quality-based effluent limitation.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

b. PERMIT ACTION

Analytical data reported in the application was screened against calculated water quality-based effluent limitations for the protection of human health. Reported analytical data does not exceed 70 percent of the calculated daily average water quality-based effluent limitation for human health protection. No additional limits or monitoring and reporting requirements have been added to the draft permit.

6. DRINKING WATER SUPPLY PROTECTIONa. SCREENING

Segment No. 0230, which receives the discharge from this facility, is not designated as a public water supply. Screening reported analytical data of the effluent against water quality-based effluent limitations calculated for the protection of a drinking water supply is not applicable.

b. PERMIT ACTION

None.

7. TOTAL DISSOLVED SOLIDS, CHLORIDE, AND SULFATE STANDARDS PROTECTIONa. SCREENING

Average concentrations of TDS, chloride, and sulfate reported in the application are all less than the respective criteria for Segment No. 0230; therefore, no further screening is necessary.

b. PERMIT ACTION

None.

8. PROTECTION OF pH STANDARDSa. SCREENING

A pH screening was calculated using the CO2SYS program (Lewis and Wallace, 1998) for Outfall 001. The screening determined that the existing effluent pH limits would meet segment criterion at the edge of the mixing zone. Calculations are presented in Appendix B.

The existing permit includes limits on pH of 6.0 – 9.0 standard units at Outfall 002, which discharges into an unclassified water body. Consistent with the procedures for pH screening that were submitted to EPA with a letter dated May 28, 2014, and approved by EPA in a letter dated June 2, 2014, requiring this discharge to unclassified water bodies to meet pH

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

limits of 6.0 – 9.0 standard units reasonably ensures instream compliance with Texas Surface Water Quality Standards pH criteria.

b. PERMIT ACTION

The existing effluent limits of 6.0 – 9.0 SU are adequate to ensure that the discharge will not violate the pH criteria in Pease River for Outfall 001.

The existing pH limits of 6.0 – 9.0 standard units are carried forward in the draft permit at Outfall 002.

9. DISSOLVED OXYGEN PROTECTION

a. SCREENING

A dissolved oxygen modeling analysis was previously performed for this permit on July 27, 2015, by Tom Y. Harrigan. Only Outfall 001 is expected to contain significant levels of oxygen demanding constituents. Applicable water body uses and criteria, proposed permitted flow conditions, and modeling analytical procedures pertaining to this discharge situation remain unchanged from the previous review. Therefore, the existing effluent sets for Outfall 001 of 23 mg/L CBOD₅ (April-October), 42 mg/L CBOD₅ (November-February) and 39 mg/L CBOD₅ (March), 3 mg/L NH₃-N and 5.0 mg/L DO are applicable to this permit. No additional modeling work was performed for the current permit action.

b. PERMIT ACTION

The existing limits above are carried forward in the draft permit at Outfall 001.

XI. PRETREATMENT REQUIREMENTS

This facility is not defined as a publicly owned treatment works. Pretreatment requirements are not proposed in the draft permit.

XII. VARIANCE REQUESTS

No variance requests have been received.

XIII. PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for reviewing and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ commissioners for their consideration at a scheduled commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the commission grants a contested case hearing as described above, the commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Thomas E. Starr at (512) 239-4570.

XIV. ADMINISTRATIVE RECORD

The following section is a list of the fact sheet citations to applicable statutory or regulatory provisions and appropriate supporting references.

A. PERMIT(S)

TPDES Permit No. WQ0002537000 issued on August 30, 2019.

B. APPLICATION

TPDES wastewater permit application received on February 27, 2024 and additional information received on March 21, 2024.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

C. LETTERS/MEMORANDA/RECORDS OF COMMUNICATION

Letter dated May 28, 2014, from L'Oreal W. Stepney, P.E., Deputy Director, Office of Water, TCEQ, to Bill Honker, Director, Water Quality Protection Division, EPA (TCEQ proposed development strategy for pH evaluation procedures).

Letter dated June 2, 2014, from William K. Honker, P.E., Director, Water Quality Protection Division, EPA, to L'Oreal W. Stepney, P.E., Deputy Director, Office of Water, TCEQ (Approval of TCEQ proposed development strategy for pH evaluation procedures).

Letter dated December 28, 2015, from L'Oreal Stepney, P.E., Deputy Director, Office of Water, TCEQ, to Bill Honker, Director, Water Quality Protection Division, EPA (TCEQ proposed development strategy for procedures to determine reasonable potential for whole effluent toxicity limitations).

Letter dated December 28, 2015, from William K. Honker, P.E., Director, Water Quality Protection Division, EPA, to L'Oreal W. Stepney, P.E., Deputy Director, Office of Water, TCEQ (Approval of TCEQ proposed development strategy for procedures to determine reasonable potential for whole effluent toxicity limitations).

TCEQ Interoffice Memorandum dated April 9, 2024, from Jeff Paull of the Standards Implementation Team, Water Quality Assessment Section, to the Industrial Permits Team, Wastewater Permitting Section (Standards Memo).

TCEQ Interoffice Memorandum dated April 11, 2024, from Brian Christman of the Water Quality Assessment Team, Water Quality Assessment Section, to the Industrial Permits Team, Wastewater Permitting Section (Critical Conditions Memo).

TCEQ Interoffice Memorandum dated April 23, 2025, from Orlando M. Vasquez, Jr., P.E. of the Water Quality Assessment Team, Water Quality Assessment Section, to the Industrial Permits Team, Wastewater Permitting Section (Modeling Memo).

TCEQ Interoffice Memorandum dated June 19, 2024, from Michael B. Pfeil of the Standards Implementation Team, Water Quality Assessment Section, to the Industrial Permits Team, Wastewater Permitting Section (Biomonitoring Memo).

D. MISCELLANEOUS

The State of Texas 2022 Integrated Report – Texas 303(d) List (Category 5), TCEQ, July 7, 2022.

Texas Surface Water Quality Standards, 30 TAC §§307.1 - 307.10, TCEQ, effective March 1, 2018, as approved by EPA Region 6.

Texas Surface Water Quality Standards, 30 TAC §§307.1 - 307.10, TCEQ, effective March 6, 2014, as approved by EPA Region 6, for portions of the 2018 standards not approved by EPA Region 6.

Texas Surface Water Quality Standards, 30 TAC §§307.1 - 307.10, TCEQ, effective July 22, 2010, as approved by EPA Region 6, for portions of the 2014 standards not yet approved by EPA Region 6.

Texas Surface Water Quality Standards, 30 TAC §§307.1 - 307.10, TCEQ, effective August 17, 2000, and Appendix E, effective February 27, 2002, for portions of the 2010 standards not yet approved by EPA Region 6.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition (EPA-821-R-02-013).

Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fifth Edition (EPA-821-R-02-012).

Procedures to Implement the Texas Surface Water Quality Standards, TCEQ, June 2010, as approved by EPA Region 6.

Procedures to Implement the Texas Surface Water Quality Standards, TCEQ, January 2003, for portions of the 2010 IPs not approved by EPA Region 6.

Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, TCEQ Document No. 98-001.000-OWR-WQ, May 1998.

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Appendix A Calculated Water Quality-Based Effluent Limits

TEXTOX MENU #3 - PERENNIAL STREAM OR RIVER				
The water quality-based effluent limitations developed below are calculated using:				
Table 1, 2014 Texas Surface Water Quality Standards (30 TAC 307) for Freshwater Aquatic Life				
Table 2, 2018 Texas Surface Water Quality Standards for Human Health				
"Procedures to Implement the Texas Surface Water Quality Standards," TCEQ, June 2010				
PERMIT INFORMATION				
Permittee Name:	Solvay USA LLC			
TPDES Permit No.:	WQ0002537000			
Outfall No.:	001			
Prepared by:	Thomas Starr			
Date:	May 1, 2025			
DISCHARGE INFORMATION				
Receiving Waterbody:	Pease River			
Segment No.:	0230			
TSS (mg/L):	8.6			
pH (Standard Units):	7.5			
Hardness (mg/L as CaCO ₃):	1779			
Chloride (mg/L):	3677			
Effluent Flow for Aquatic Life (MGD):	0.666			
Critical Low Flow [7Q2] (cfs):	0.1			
% Effluent for Chronic Aquatic Life (Mixing Zone):	91.15			
% Effluent for Acute Aquatic Life (ZID):	97.63			
Effluent Flow for Human Health (MGD):	0.357			
Harmonic Mean Flow (cfs):	0.82			
% Effluent for Human Health:	40.25			
Human Health Criterion (select: PWS, FISH, or INC)	FISH			

CALCULATE DISSOLVED FRACTION (AND ENTER WATER EFFECT RATIO IF APPLICABLE):							
Stream/River Metal	Intercept (b)	Slope (m)	Partition Coefficient (Kp)	Dissolved Fraction (Cd/Ct)	Source	Water Effect Ratio (WER)	Source
Aluminum	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Arsenic	5.68	-0.73	99498.41	0.539		1.00	Assumed
Cadmium	6.60	-1.13	349958.66	0.249		1.00	Assumed
Chromium (total)	6.52	-0.93	447627.17	0.206		1.00	Assumed
Chromium (trivalent)	6.52	-0.93	447627.17	0.206		1.00	Assumed
Chromium (hexavalent)	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Copper	6.02	-0.74	213044.90	0.353		1.00	Assumed
Lead	6.45	-0.80	503966.00	0.187		1.00	Assumed
Mercury	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Nickel	5.69	-0.57	143660.01	0.447		1.00	Assumed
Selenium	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Silver	6.38	-1.03	261496.93	0.308		1.00	Assumed
Zinc	6.10	-0.70	279158.65	0.294		1.00	Assumed

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

AQUATIC LIFE								
CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:								
Parameter	FW Acute Criterion (µg/L)	Chronic Criterion (µg/L)	WLAa (µg/L)	WLAc (µg/L)	LTAa (µg/L)	LTAc (µg/L)	Daily Avg. (µg/L)	Daily Max. (µg/L)
Aldrin	3.0	N/A	3.07	N/A	1.76	N/A	2.58	5.47
Aluminum	991	N/A	1015	N/A	582	N/A	854	1808
Arsenic	340	150	646	305	370	235	345	731
Cadmium	139.7	1.801	574	7.92	329	6.10	8.96	18.9
Carbaryl	2.0	N/A	2.05	N/A	1.17	N/A	1.72	3.65
Chlordane	2.4	0.004	2.46	0.00439	1.41	0.00338	0.00496	0.0105
Chlorpyrifos	0.083	0.041	0.0850	0.0450	0.0487	0.0346	0.0509	0.107
Chromium (trivalent)	6020	783	29902	4166	17134	3208	4715	9976
Chromium (hexavalent)	15.7	10.6	16.1	11.6	9.21	8.95	13.1	27.8
Copper	213.9	110.8	621	344	356	265	389	824
Cyanide (free)	45.8	10.7	46.9	11.7	26.9	9.04	13.2	28.1
4,4'-DDT	1.1	0.001	1.13	0.00110	0.646	0.000845	0.00124	0.00262
Demeton	N/A	0.1	N/A	0.110	N/A	0.0845	0.124	0.262
Diazinon	0.17	0.17	0.174	0.186	0.0998	0.144	0.146	0.310
Dicofol [Kelthane]	59.3	19.8	60.7	21.7	34.8	16.7	24.5	52.0
Dieldrin	0.24	0.002	0.246	0.00219	0.141	0.00169	0.00248	0.00525
Diuron	210	70	215	76.8	123	59.1	86.9	183
Endosulfan I (alpha)	0.22	0.056	0.225	0.0614	0.129	0.0473	0.0695	0.147
Endosulfan II (beta)	0.22	0.056	0.225	0.0614	0.129	0.0473	0.0695	0.147
Endosulfan sulfate	0.22	0.056	0.225	0.0614	0.129	0.0473	0.0695	0.147
Endrin	0.086	0.002	0.0881	0.00219	0.0505	0.00169	0.00248	0.00525
Guthion [Azinphos Methyl]	N/A	0.01	N/A	0.0110	N/A	0.00845	0.0124	0.0262
Heptachlor	0.52	0.004	0.533	0.00439	0.305	0.00338	0.00496	0.0105
Hexachlorocyclohexane (gamma) [Lindane]	1.126	0.08	1.15	0.0878	0.661	0.0676	0.0993	0.210
Lead	1184	46.15	6470	270	3707	208	305	646
Malathion	N/A	0.01	N/A	0.0110	N/A	0.00845	0.0124	0.0262
Mercury	2.4	1.3	2.46	1.43	1.41	1.10	1.61	3.41
Methoxychlor	N/A	0.03	N/A	0.0329	N/A	0.0253	0.0372	0.0788
Mirex	N/A	0.001	N/A	0.00110	N/A	0.000845	0.00124	0.00262
Nickel	5347	593.9	12243	1456	7015	1121	1648	3487
Nonylphenol	28	6.6	28.7	7.24	16.4	5.58	8.19	17.3
Parathion (ethyl)	0.065	0.013	0.0666	0.0143	0.0381	0.0110	0.0161	0.0341
Pentachlorophenol	14.4	11.1	14.8	12.1	8.46	9.34	12.4	26.3
Phenanthrene	30	30	30.7	32.9	17.6	25.3	25.8	54.7
Polychlorinated Biphenyls [PCBs]	2.0	0.014	2.05	0.0154	1.17	0.0118	0.0173	0.0367
Selenium	20	5	20.5	5.49	11.7	4.22	6.20	13.1
Silver	0.8	N/A	29.6	N/A	17.0	N/A	24.9	52.8
Toxaphene	0.78	0.0002	0.799	0.000219	0.458	0.000169	0.000248	0.000525
Tributyltin [TBT]	0.13	0.024	0.133	0.0263	0.0763	0.0203	0.0298	0.0630
2,4,5 Trichlorophenol	136	64	139	70.2	79.8	54.1	79.4	168
Zinc	1343	1354	4679	5052	2681	3890	3940	8337

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

HUMAN HEALTH							
CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:							
<i>Parameter</i>	<i>Water and Fish Criterion</i>	<i>Fish Only Criterion (µg/L)</i>	<i>Incidental Fish Criterion</i>	<i>WLAh (µg/L)</i>	<i>LTAh (µg/L)</i>	<i>Daily Avg. (µg/L)</i>	<i>Daily Max. (µg/L)</i>
Acrylonitrile	1.0	115	1150	286	266	390	826
Aldrin	1.146E-05	1.147E-05	1.147E-04	0.0000285	0.0000265	0.0000389	0.0000824
Anthracene	1109	1317	13170	3272	3043	4473	9464
Antimony	6	1071	10710	2661	2475	3637	7696
Arsenic	10	N/A	N/A	N/A	N/A	N/A	N/A
Barium	2000	N/A	N/A	N/A	N/A	N/A	N/A
Benzene	5	581	5810	1444	1342	1973	4175
Benzidine	0.0015	0.107	1.07	0.266	0.247	0.363	0.768
Benzo(a)anthracene	0.024	0.025	0.25	0.0621	0.0578	0.0849	0.179
Benzo(a)pyrene	0.0025	0.0025	0.025	0.00621	0.00578	0.00849	0.0179
Bis(chloromethyl)ether	0.0024	0.2745	2.745	0.682	0.634	0.932	1.97
Bis(2-chloroethyl)ether	0.60	42.83	428.3	106	99.0	145	307
Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phthalate]	6	7.55	75.5	18.8	17.4	25.6	54.2
Bromodichloromethane [Dichlorobromomethane]	10.2	275	2750	683	635	934	1976
Bromoform [Tribromomethane]	66.9	1060	10600	2634	2449	3600	7617
Cadmium	5	N/A	N/A	N/A	N/A	N/A	N/A
Carbon Tetrachloride	4.5	46	460	114	106	156	330
Chlordane	0.0025	0.0025	0.025	0.00621	0.00578	0.00849	0.0179
Chlorobenzene	100	2737	27370	6800	6324	9296	19668
Chlorodibromomethane [Dibromochloromethane]	7.5	183	1830	455	423	621	1315
Chloroform [Trichloromethane]	70	7697	76970	19124	17785	26143	55311
Chromium (hexavalent)	62	502	5020	1247	1160	1705	3607
Chrysene	2.45	2.52	25.2	6.26	5.82	8.55	18.1
Cresols [Methylphenols]	1041	9301	93010	23109	21491	31591	66837
Cyanide (free)	200	N/A	N/A	N/A	N/A	N/A	N/A
4,4'-DDD	0.002	0.002	0.02	0.00497	0.00462	0.00679	0.0143
4,4'-DDE	0.00013	0.00013	0.0013	0.000323	0.000300	0.000441	0.000934
4,4'-DDT	0.0004	0.0004	0.004	0.000994	0.000924	0.00135	0.00287
2,4'-D	70	N/A	N/A	N/A	N/A	N/A	N/A
Danitol [Fenpropathrin]	262	473	4730	1175	1093	1606	3399
1,2-Dibromoethane [Ethylene Dibromide]	0.17	4.24	42.4	10.5	9.80	14.4	30.4
<i>m</i> -Dichlorobenzene [1,3-Dichlorobenzene]	322	595	5950	1478	1375	2020	4275
<i>o</i> -Dichlorobenzene [1,2-Dichlorobenzene]	600	3299	32990	8197	7623	11205	23706
<i>p</i> -Dichlorobenzene [1,4-Dichlorobenzene]	75	N/A	N/A	N/A	N/A	N/A	N/A
3,3'-Dichlorobenzidine	0.79	2.24	22.4	5.57	5.18	7.60	16.0
1,2-Dichloroethane	5	364	3640	904	841	1236	2615
1,1-Dichloroethylene [1,1-Dichloroethene]	7	55114	551140	136933	127348	187201	396051
Dichloromethane [Methylene Chloride]	5	13333	133330	33126	30808	45287	95811
1,2-Dichloropropane	5	259	2590	643	598	879	1861
1,3-Dichloropropene [1,3-Dichloropropylene]	2.8	119	1190	296	275	404	855
Dicofol [Kelthane]	0.30	0.30	3	0.745	0.693	1.01	2.15
Dieldrin	2.0E-05	2.0E-05	2.0E-04	0.0000497	0.0000462	0.0000679	0.000143
2,4-Dimethylphenol	444	8436	84360	20960	19492	28653	60621
Di- <i>n</i> -Butyl Phthalate	88.9	92.4	924	230	214	313	663
Dioxins/Furans [TCDD Equivalents]	7.80E-08	7.97E-08	7.97E-07	1.98E-07	1.84E-07	2.70E-07	5.72E-07
Endrin	0.02	0.02	0.2	0.0497	0.0462	0.0679	0.143
Epichlorohydrin	53.5	2013	20130	5001	4651	6837	14465
Ethylbenzene	700	1867	18670	4639	4314	6341	13416
Ethylene Glycol	46744	1.68E+07	1.68E+08	41740348	38818524	57063230	120725609
Fluoride	4000	N/A	N/A	N/A	N/A	N/A	N/A
Heptachlor	8.0E-05	0.0001	0.001	0.000248	0.000231	0.000339	0.000718
Heptachlor Epoxide	0.00029	0.00029	0.0029	0.000721	0.000670	0.000985	0.00208
Hexachlorobenzene	0.00068	0.00068	0.0068	0.00169	0.00157	0.00230	0.00488
Hexachlorobutadiene	0.21	0.22	2.2	0.547	0.508	0.747	1.58

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

<i>Parameter</i>	<i>Water and Fish Criterion</i>	<i>Fish Only Criterion (µg/L)</i>	<i>Incidental Fish Criterion</i>	<i>WLAh (µg/L)</i>	<i>LTAh (µg/L)</i>	<i>Daily Avg. (µg/L)</i>	<i>Daily Max. (µg/L)</i>
Hexachlorocyclohexane (<i>alpha</i>)	0.0078	0.0084	0.084	0.0209	0.0194	0.0285	0.0603
Hexachlorocyclohexane (<i>beta</i>)	0.15	0.26	2.6	0.646	0.601	0.883	1.86
Hexachlorocyclohexane (<i>gamma</i>) [Lindane]	0.2	0.341	3.41	0.847	0.788	1.15	2.45
Hexachlorocyclopentadiene	10.7	11.6	116	28.8	26.8	39.4	83.3
Hexachloroethane	1.84	2.33	23.3	5.79	5.38	7.91	16.7
Hexachlorophene	2.05	2.90	29	7.21	6.70	9.85	20.8
4,4'-Isopropylidenediphenol	1092	15982	159820	39708	36928	54284	114847
Lead	1.15	3.83	38.3	50.8	47.2	69.3	146
Mercury	0.0122	0.0122	0.122	0.0303	0.0282	0.0414	0.0876
Methoxychlor	2.92	3.0	30	7.45	6.93	10.1	21.5
Methyl Ethyl Ketone	13865	9.92E+05	9.92E+06	2464668	2292141	3369447	7128559
Methyl <i>tert</i> -butyl ether [MTBE]	15	10482	104820	26043	24220	35603	75324
Nickel	332	1140	11400	6332	5888	8656	18313
Nitrate-Nitrogen (as Total Nitrogen)	10000	N/A	N/A	N/A	N/A	N/A	N/A
Nitrobenzene	45.7	1873	18730	4654	4328	6361	13459
N-Nitrosodiethylamine	0.0037	2.1	21	5.22	4.85	7.13	15.0
N-Nitroso-di- <i>n</i> -Butylamine	0.119	4.2	42	10.4	9.70	14.2	30.1
Pentachlorobenzene	0.348	0.355	3.55	0.882	0.820	1.20	2.55
Pentachlorophenol	0.22	0.29	2.9	0.721	0.670	0.985	2.08
Polychlorinated Biphenyls [PCBs]	6.4E-04	6.4E-04	6.40E-03	0.00159	0.00148	0.00217	0.00459
Pyridine	23	947	9470	2353	2188	3216	6805
Selenium	50	N/A	N/A	N/A	N/A	N/A	N/A
1,2,4,5-Tetrachlorobenzene	0.23	0.24	2.4	0.596	0.555	0.815	1.72
1,1,2,2-Tetrachloroethane	1.64	26.35	263.5	65.5	60.9	89.5	189
Tetrachloroethylene [Tetrachloroethylene]	5	280	2800	696	647	951	2012
Thallium	0.12	0.23	2.3	0.571	0.531	0.781	1.65
Toluene	1000	N/A	N/A	N/A	N/A	N/A	N/A
Toxaphene	0.011	0.011	0.11	0.0273	0.0254	0.0373	0.0790
2,4,5-TP [Silvex]	50	369	3690	917	853	1253	2651
1,1,1-Trichloroethane	200	784354	7843540	1948762	1812349	2664153	5636405
1,1,2-Trichloroethane	5	166	1660	412	384	563	1192
Trichloroethylene [Trichloroethene]	5	71.9	719	179	166	244	516
2,4,5-Trichlorophenol	1039	1867	18670	4639	4314	6341	13416
TTHM [Sum of Total Trihalomethanes]	80	N/A	N/A	N/A	N/A	N/A	N/A
Vinyl Chloride	0.23	16.5	165	41.0	38.1	56.0	118

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Aquatic Life	70% of	85% of
Parameter	Daily Avg.	Daily Avg.
	(µg/L)	(µg/L)
Aldrin	1.81	2.20
Aluminum	598	726
Arsenic	241	293
Cadmium	6.27	7.62
Carbaryl	1.20	1.46
Chlordane	0.00347	0.00422
Chlorpyrifos	0.0356	0.0432
Chromium (trivalent)	3300	4008
Chromium (hexavalent)	9.21	11.1
Copper	272	331
Cyanide (free)	9.30	11.2
4,4'-DDT	0.000869	0.00105
Demeton	0.0869	0.105
Diazinon	0.102	0.124
Dicofol [Kelthane]	17.2	20.8
Dieldrin	0.00173	0.00211
Diuron	60.8	73.8
Endosulfan I (<i>alpha</i>)	0.0486	0.0591
Endosulfan II (<i>beta</i>)	0.0486	0.0591
Endosulfan sulfate	0.0486	0.0591
Endrin	0.00173	0.00211
Guthion [Azinphos Methyl]	0.00869	0.0105
Heptachlor	0.00347	0.00422
Hexachlorocyclohexane (<i>gamma</i>) [Lindane]	0.0695	0.0844
Lead	213	259
Malathion	0.00869	0.0105
Mercury	1.12	1.37
Methoxychlor	0.0260	0.0316
Mirex	0.000869	0.00105
Nickel	1154	1401
Nonylphenol	5.73	6.96
Parathion (ethyl)	0.0112	0.0137
Pentachlorophenol	8.70	10.5
Phenanthrene	18.1	22.0
Polychlorinated Biphenyls [PCBs]	0.0121	0.0147
Selenium	4.34	5.27
Silver	17.4	21.2
Toxaphene	0.000173	0.000211
Tributyltin [TBT]	0.0208	0.0253
2,4,5 Trichlorophenol	55.6	67.5
Zinc	2758	3349

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Human Health	70% of Daily Avg.	85% of Daily Avg.
Parameter	(µg/L)	(µg/L)
Acrylonitrile	273	332
Aldrin	0.0000272	0.0000331
Anthracene	3131	3802
Antimony	2546	3092
Arsenic	N/A	N/A
Barium	N/A	N/A
Benzene	1381	1677
Benzidine	0.254	0.308
Benzo(a)anthracene	0.0594	0.0721
Benzo(a)pyrene	0.00594	0.00721
Bis(chloromethyl)ether	0.652	0.792
Bis(2-chloroethyl)ether	101	123
Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phthalate]	17.9	21.7
Bromodichloromethane [Dichlorobromomethane]	653	793
Bromoform [Tribromomethane]	2520	3060
Cadmium	N/A	N/A
Carbon Tetrachloride	109	132
Chlordane	0.00594	0.00721
Chlorobenzene	6507	7902
Chlorodibromomethane [Dibromochloromethane]	435	528
Chloroform [Trichloromethane]	18300	22222
Chromium (hexavalent)	1193	1449
Chrysene	5.99	7.27
Cresols [Methylphenols]	22114	26853
Cyanide (free)	N/A	N/A
4,4'-DDD	0.00475	0.00577
4,4'-DDE	0.000309	0.000375
4,4'-DDT	0.000951	0.00115
2,4'-D	N/A	N/A
Danitol [Fenpropathrin]	1124	1365
1,2-Dibromoethane [Ethylene Dibromide]	10.0	12.2
m-Dichlorobenzene [1,3-Dichlorobenzene]	1414	1717
o-Dichlorobenzene [1,2-Dichlorobenzene]	7843	9524
p-Dichlorobenzene [1,4-Dichlorobenzene]	N/A	N/A
3,3'-Dichlorobenzidine	5.32	6.46
1,2-Dichloroethane	865	1050
1,1-Dichloroethylene [1,1-Dichloroethene]	131040	159121
Dichloromethane [Methylene Chloride]	31701	38494
1,2-Dichloropropane	615	747
1,3-Dichloropropene [1,3-Dichloropropylene]	282	343
Dicofol [Kelthane]	0.713	0.866
Dieldrin	0.0000475	0.0000577
2,4-Dimethylphenol	20057	24355
Di-n-Butyl Phthalate	219	266
Dioxins/Furans [TCDD Equivalents]	1.89E-07	2.30E-07
Endrin	0.0475	0.0577
Epichlorohydrin	4786	5811
Ethylbenzene	4439	5390
Ethylene Glycol	39944261	48503745
Fluoride	N/A	N/A
Heptachlor	0.000237	0.000288
Heptachlor Epoxide	0.000689	0.000837
Hexachlorobenzene	0.00161	0.00196
Hexachlorobutadiene	0.523	0.635

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Human Health	70% of Daily Avg.	85% of Daily Avg.
Parameter	(µg/L)	(µg/L)
Hexachlorocyclohexane (<i>alpha</i>)	0.0199	0.0242
Hexachlorocyclohexane (<i>beta</i>)	0.618	0.750
Hexachlorocyclohexane (<i>gamma</i>) [Lindane]	0.810	0.984
Hexachlorocyclopentadiene	27.5	33.4
Hexachloroethane	5.53	6.72
Hexachlorophene	6.89	8.37
4,4'-Isopropylidenediphenol	37999	46142
Lead	48.5	58.9
Mercury	0.0290	0.0352
Methoxychlor	7.13	8.66
Methyl Ethyl Ketone	2358613	2864030
Methyl <i>tert</i> -butyl ether [MTBE]	24922	30262
Nickel	6059	7357
Nitrate-Nitrogen (as Total Nitrogen)	N/A	N/A
Nitrobenzene	4453	5407
N-Nitrosodiethylamine	4.99	6.06
N-Nitroso-di- <i>n</i> -Butylamine	9.98	12.1
Pentachlorobenzene	0.844	1.02
Pentachlorophenol	0.689	0.837
Polychlorinated Biphenyls [PCBs]	0.00152	0.00184
Pyridine	2251	2734
Selenium	N/A	N/A
1,2,4,5-Tetrachlorobenzene	0.570	0.692
1,1,2,2-Tetrachloroethane	62.6	76.0
Tetrachloroethylene [Tetrachloroethylene]	665	808
Thallium	0.546	0.664
Toluene	N/A	N/A
Toxaphene	0.0261	0.0317
2,4,5-TP [Silvex]	877	1065
1,1,1-Trichloroethane	1864907	2264530
1,1,2-Trichloroethane	394	479
Trichloroethylene [Trichloroethene]	170	207
2,4,5-Trichlorophenol	4439	5390
TTHM [Sum of Total Trihalomethanes]	N/A	N/A
Vinyl Chloride	39.2	47.6

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Appendix B pH Screening

Calculation of pH of a mixture of two flows. Based on the procedure in EPA's DESCON program (EPA, 1988. Technical Guidance on Supplementary Stream Design Conditions for Steady State Modeling. USEPA Office of Water, Washington D.C.)

INPUT		
1. DILUTION FACTOR AT MIXING ZONE BOUNDARY	1.099	1.099
RECEIVING WATER CHARACTERISTICS		
2. Temperature (deg C):	32.80	32.80
3. pH:	7.50	8.20
4. Alkalinity (mg CaCO ₃ /L):	1120.00	1120.00
EFFLUENT CHARACTERISTICS		
5. Temperature (deg C):	23.00	23.00
6. pH:	6.00	9.00
7. Alkalinity (mg CaCO ₃ /L):	20.00 *	1400.00
OUTPUT		
1. IONIZATION CONSTANTS		
Upstream/Background pKa:	6.31	6.31
Effluent pKa:	6.36	6.36
2. IONIZATION FRACTIONS		
Upstream/Background Ionization Fraction:	0.94	0.99
Effluent Ionization Fraction:	0.30	1.00
3. TOTAL INORGANIC CARBON		
Upstream/Background Total Inorganic Carbon (mg CaCO ₃ /L):	1192.66	1134.50
Effluent Total Inorganic Carbon (mg CaCO ₃ /L):	66.04	1403.22
4. CONDITIONS AT MIXING ZONE BOUNDARY		
Temperature (deg C):	23.88	23.88
Alkalinity (mg CaCO ₃ /L):	119.00	1374.78
Total Inorganic Carbon (mg CaCO ₃ /L):	167.43	1379.02
pKa:	6.36	6.36
pH at Mixing Zone Boundary:	6.75	8.87

* Assume minimal total alkalinity at low effluent pH based on carbonate equilibrium chemistry of natural and treated waters

FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

Appendix C

Comparison of Effluent Limits

The following table is a summary of technology-based effluent limitations calculated/assessed in the draft permit (Technology-Based), calculated/assessed water quality-based effluent limitations (Water Quality-Based), and effluent limitations in the existing permit (Existing Permit). Effluent limitations appearing in bold are the most stringent of the three and are included in the draft permit.

Outfall	Pollutant	Technology-Based				Water Quality-Based				Existing Permit			
		Daily Avg		Daily Max		Daily Avg		Daily Max		Daily Avg		Daily Max	
		lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L
001	Flow	-		-		-		-		1.3 MGD		2.0 MGD	
	CBOD ₅ (Apr-Oct)	-	-	-	-	-	23	-	-	249	23	498	46
	CBOD ₅ (Nov-Feb)	-	-	-	-	-	42	-	-	455	42	910	84
	CBOD ₅ (March)	-	-	-	-	-	39	-	-	423	39	846	78
	TSS	325	Report	650	Report	-	-	-	-	325	Report	650	Report
	TOC	9,433	Report	16,480	Report	-	-	-	-	9,433	Report	16,480	Report
	Ammonia Nitrogen	-	-	-	-	-	3.0	-	-	N/A	3.0	N/A	5.0
	DO	-	-	-	-	-	5.0, minimum	-	-	N/A	5.0, minimum	N/A	N/A
	pH	-		-		6.0 SU, minimum		9.0 SU		6.0 SU, minimum		9.0 SU	

Outfall	Pollutant	Technology-Based		Water Quality-Based		Existing Permit	
		Daily Avg	Daily Max	Daily Avg	Daily Max	Daily Avg	Daily Max
		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
002	Flow	Report, MGD	Report, MGD	-	-	Report, MGD	Report, MGD
	COD	N/A	500	-	-	N/A	500
	Oil and Grease	N/A	15	-	-	N/A	15
	pH	6.0 SU, minimum	9.0 SU	-	-	6.0 SU, minimum	9.0 SU