

This file contains the following documents:

- 1. Summary of application (in plain language)
- 2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
- 3. Second notice (NAPD-Notice of Preliminary Decision)
- 4. Application materials (**NOTE:** This application was declared Administratively Complete before June 1, 2024. Application materials are available for review at the Public Viewing Location provided in the NORI.)
- 5. Draft permit
- 6. Technical summary or fact sheet



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in <u>30 TAC Section 39.426</u>, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS INDUSTRIAL WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Wright City WSC (CN#600675284) operates Wright City WSC #1 (RN#101237063), a public water supply (facility). The facility is located at 18523 FM 2089 (approximate GPS coordinates 32.20154, -94.99400), in Overton, Smith County, Texas 75684. This is a request for a new industrial wastewater permit to discharge approximately 54,000 gallons per day of reject water. The discharge (reject water) will consist of untreated groundwater that has been processed through a nanofiltration system that removes larger molecules and ions from the water, such as organic matter, bacteria, calcium, and magnesium. This permit will not authorize a discharge of pollutants into water in the state.

The facility supports a public water supply system that filters groundwater for public use. Groundwater is collected and will go through a two-stage nanofiltration process where larger molecules and ions are stripped from the water prior to public use. The reject water that contains the larger molecules and ions will be discharged at the facility to a roadside ditch

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT

PROPOSED PERMIT NO. WQ0005459000

APPLICATION. Wright City Water Supply Corporation, 24065 Lyles Lane, Troup, Texas 75789, which own(s) a public water supply facility, has applied to the Texas Commission on Environmental Quality (TCEQ) for proposed Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0005459000 (EPA I.D. No. TX0145963) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 54,000 gallons per day. The facility will be located at 18523 Farm-to-Market Road 2089, in the city of Overton, in Smith County, Texas 75684. The discharge route will be from the plant site to a roadside ditch; thence to an unnamed tributary; thence to Wright Branch; thence to Bowles Creek; thence to Lake Striker; thence to Striker Creek; thence to Angelina River Above Sam Rayburn Reservoir. TCEQ received this application on April 26, 2024. The permit application will be available for viewing and copying at Wright City Water Supply Corporation Office, 24065 Lyles Lane, Troup, Texas prior to the date this notice is published in the newspaper. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application. https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.993888,32.201666&level=18

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. Notice of the Application and Preliminary Decision will be published and mailed to those who are on the countywide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. **Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who**

submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at https://www14.tceq.texas.gov/epic/eComment/, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll

Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Wright City Water Supply Corporation at the address stated above or by calling Mr. Charles Seale, President, at 903-859-1281.

Issuance Date: May 28, 2024

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



COMBINED

NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT AND NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR INDUSTRIAL WASTEWATER

NEW

Permit No. WQ0005459000

APPLICATION AND PRELIMINARY DECISION. Wright City Water Supply Corporation, 24065 Lyles Lane, Troup, Texas 75789, which proposes to operate Wright City Water Supply Corporation (WSC), a public water supply facility, has applied to the Texas Commission on Environmental Quality (TCEQ) for a new permit, Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0005459000, to authorize the discharge of water treatment wastes at a volume not to exceed a daily average flow of 54,000 gallons per day. The TCEQ received this application on April 26, 2024.

This combined notice is to correct the initial notice which listed the discharge of "treated wastewater" as the water treatment waste is not treated.

The facility is located at 18523 Farm-to-Market 2089, in the City of Overton, Smith County, Texas 75684. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application. https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.993888,32.201666&level=18

The effluent is discharged from the plant to an unnamed ditch; thence to an unnamed tributary; thence to Wright Branch; thence to Bowles Creek; thence to Striker Creek; thence to Lake Striker; thence to Striker Creek; thence to Angelina River Above Sam Rayburn Reservoir in Segment No. 0611 of the Neches River Basin. The unclassified receiving water uses are minimal aquatic life use for the unnamed ditch and Wright Branch, limited aquatic life use for the unnamed tributary, and high aquatic life use for Bowles Creek. The designated uses for Segment No. 0611 are primary contact recreation, public water supply, and high aquatic life use.

In accordance with Title 30 Texas Administrative Code Section 307.5 and TCEQ's *Procedures to Implement the Texas Surface Water Quality Standards* (June 2010), an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. A Tier 2 review has preliminarily determined that no significant degradation of water quality is expected in Bowles Creek, which has been identified as having high aquatic life use. Existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received.

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at Wright City Water Supply Corporation Office, 24065 Lyles Lane, Troup, Texas.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting about this application. The purpose of a public meeting is to provide the opportunity to submit written or oral comment or to ask questions about the application. Generally, the TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for public comments, the Executive Director will consider the comments and prepare a response to all relevant and material, or significant public comments. The response to comments, along with the Executive Director's decision on the application, will be mailed to everyone who submitted public comments or who requested to be on a mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision. A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

EXECUTIVE DIRECTOR ACTION. The Executive Director may issue final approval of the application unless a timely contested case hearing request or a timely request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and requests to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be added to: (1) the permanent list for a specific applicant name and permit number; and (2) the mailing list for a specific county. If you wish to be placed on the permanent and the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, TCEQ, P.O. Box 13087, Austin, TX 78711-3087 or electronically at https://www.tceq.texas.gov/goto/comment within 30 days from the date of newspaper publication of this notice.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at https://www.tceq.texas.gov/goto/cid/. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. Public comments and requests must be submitted either electronically at https://www.tceq.texas.gov/goto/comment, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address, and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, toll free, at 1-800-687-4040 or visit their website at https://www.tceq.texas.gov/agency/decisions/participation/permitting-participation. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Wright City Water Supply Corporation at the address stated above or by calling Mr. Charles Seale, President, at 903-859-1281.

Issued: October 24, 2025

RANGER ENVIRONMENTAL SERVICES, LLC P.O. BOX 201179 AUSTIN, TEXAS 78720

REPORT: INDUSTRIAL WASTEWATER PERMIT APPLICATION

WRIGHT CITY WSC #1

18523 FM 2089

Overton (Smith County), Texas

CN No.: 600675284 RN No.: 101237063

Attn: Applications Review and Processing Team Texas Commission on Environmental Quality Building F, Room 2101 12100 Park 35 Circle Austin, Texas 78711-30876439









April 22, 2024

Texas Commission on Environmental Quality Water Quality Division Applications Review and Processing Team, MC-148 P.O. Box 13087 Austin, Texas 78711-3087

Re:

Industrial Wastewater Permit Application

Wright City WSC 1 18523 FM 2089 Overton, Texas 75684

To Whom It May Concern:

Ranger Environmental Services, LLC (Ranger), on behalf of Wright City Water Supply Company, is pleased to submit the attached industrial wastewater permit application. Should you have any questions or need any additional information, please do not hesitate to contact me at 512/335-1785, ext. 128.

Sincerely,

RANGER ENVIRONMENTAL SERVICES, INC.

Max Cook, CAPM Project Manager

Attachments

cc: Mr. Charles Seale, Wright City Water Supply Company

INDUSTRIAL WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of industrial wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305 by checking the box next to the item. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until all items below are addressed.

are appire	artiful all ficins below are addressed.
(Requir	Pata Form (TCEQ Form No. 10400) red for all applications types. Must be completed in its entirety and signed. Form may be signed by applicant representative.)
⊠ Correct (TCEQ	t and Current Industrial Wastewater Permit Application Forms Form Nos. 10055 and 10411. Version dated 5/10/2019 or later.)
	Quality Permit Payment Submittal Form (Page 14) al payment sent to TCEQ Revenue Section. See instructions for mailing address.)
(Full-siz	aute USGS Quadrangle Topographic Map Attached se map if seeking "New" permit. 1 acceptable for Renewals and Amendments.)
⊠ N/A □	Current/Non-Expired, Executed Lease Agreement or Easement Attached
⊠ N/A □	Landowners Map (See instructions for landowner requirements.)
	 Things to Know: All the items shown on the map must be labeled. The applicant's complete property boundaries must be delineated which includes boundaries of contiguous property owned by the applicant. The applicant cannot be its own adjacent landowner. You must identify the landowners immediately adjacent to their property, regardless of how far they are from the actual facility. If the applicant's property is adjacent to a road, creek, or stream, the landowners on the opposite side must be identified. Although the properties are not adjacent to applicant's property boundary, they are considered potentially affected landowners. If the adjacent road is a divided highway as identified on the USGS topographic map, the applicant does not have to identify the landowners on the opposite side of the highway.
⊠ N/A □	Landowners Cross Reference List (See instructions for landowner requirements.)
⊠ N/A □	Landowners Labels or CD-RW attached (See instructions for landowner requirements.)

☑ Plain Language Summary

a copy of signature authority/delegation letter must be attached.)

(If signature page is not signed by an elected official or principle executive officer.

☑ Original signature per 30 TAC § 305.44 - Blue Ink Preferred

INDUSTRIAL WASTEWATER PERMIT APPLICATION

ADMINISTRATIVE REPORT

(TCEQ 10411)



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

INDUSTRIAL WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the industrial wastewater permit application.

APPLICANT NAME: Wright City WSC 1

PERMIT NUMBER (If new, leave blank): WQ00 Click to enter text.

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	\boxtimes		Worksheet 8.0	\boxtimes	
Administrative Report 1.1		75000 (1)	Worksheet 9.0	\boxtimes	
SPIF	\boxtimes		Worksheet 10.0	\boxtimes	Agencies and an artist of the second
Core Data Form	\boxtimes		Worksheet 11.0	\boxtimes	
Public Involvement Plan Form	\boxtimes		Worksheet 11.1	\boxtimes	
Plain Language Summary	\boxtimes	The state of the s	Worksheet 11.2	\boxtimes	
Technical Report 1.0	\boxtimes		Worksheet 11.3	\boxtimes	
Worksheet 1.0	\boxtimes		Original USGS Map	\boxtimes	
Worksheet 2.0	\boxtimes	and the same of th	Affected Landowners Map	\boxtimes	
Worksheet 3.0	\boxtimes		Landowner Disk or Labels		\boxtimes
Worksheet 3.1	\boxtimes	Total Control	Flow Diagram	\boxtimes	
Worksheet 3.2	\boxtimes		Site Drawing	\boxtimes	
Worksheet 3.3	\boxtimes		Original Photographs	\boxtimes	
Worksheet 4.0	\boxtimes	Colored Colored	Design Calculations		\boxtimes
Worksheet 4.1	\boxtimes	Section 1	Solids Management Plan		\boxtimes
Worksheet 5.0	\boxtimes		Water Balance		\boxtimes
Worksheet 6.0	\boxtimes				
Worksheet 7.0	\boxtimes				
For TCEQ Use Only					
Segment Number Expiration Date Permit Number	l	Region			

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

INDUSTRIAL WASTEWATER PERMIT APPLICATION **ADMINISTRATIVE REPORT 1.0**

This report is required for all applications for TPDES permits and TLAPs, except applications for oil and gas extraction operations subject to 40 CFR Part 435. Contact the Applications Review and Processing Team at 512-239-4671 with any questions about completing this report.

Applications for oil and gas extraction operations subject to 40 CFR Part 435 must use the Oil and Gas Exploration and Production Administrative Report (TCEO Form-20893 and 20893inst1).

It	em 1. Application Information and Fees (Instructions, Page 26)
a.	Complete each field with the requested information, if applicable.
	Applicant Name: Wright City WSC
	Permit No.: WQ000Click to enter text.
	EPA ID No.: TX0Click to enter text.
	Expiration Date: <u>Click to enter text.</u>
b.	Check the box next to the appropriate authorization type.
	☑ Industrial Wastewater (wastewater and stormwater)
	☐ Industrial Stormwater (stormwater only)
c.	Check the box next to the appropriate facility status.
	✓ Active ☐ Inactive
Ч	Check the box next to the appropriate permit type.
u.	☐ TPDES Permit ☐ TLAP ☐ TPDES with TLAP component
e.	Check the box next to the appropriate application type.
	⊠ New
	☐ Renewal with changes ☐ Renewal without changes
	☐ Major amendment with renewal ☐ Major amendment without renewal
	☐ Minor amendment without renewal
	☐ Minor modification without renewal
	If applying for an amendment or modification, describe the request: Click to enter text.
	TCEQ Use Only
eg	ment NumberCounty iration DateRegion
eri	mit Number

https://www.tceq.texas.gov/publications/search_forms.html TCEQ-10411 (01/08/2024) Industrial Wastewater Application Administrative Report

g. Application Fee

EPA Classification	New	Major Amend. (with or without renewal)	Renewal (with or without changes)	Minor Amend. / Minor Mod. (without renewal)
Minor facility not subject to EPA categorical effluent guidelines	⊠ \$350	□ \$350	□ \$315	□ \$150
(40 CFR Parts 400-471)				
Minor facility subject to EPA categorical effluent guidelines	□ \$1,250	□ \$1,250	□ \$1,215	□ \$150
(40 CFR Parts 400-471)				
Major facility	N/A ²	□ \$2,050	□ \$2,015	□ \$450

h. Payment Information

Mailed

Check or money order No.: <u>Click to enter text.</u> Check or money order amt.: Click to enter text.

Named printed on check or money order: Click to enter text.

Epay

Voucher number: <u>700274 & 700275</u> Copy of voucher attachment: <u>13</u>

Item 2. Applicant Information (Instructions, Pages 26)

a. Customer Number, if applicant is an existing customer: <u>CN600675284</u> **Note:** Locate the customer number using the <u>TCEO's Central Registry Customer Search</u>³.

b. Legal name of the entity (applicant) applying for this permit: Wright City WSC

Note: The owner of the facility must apply for the permit. The legal name must be spelled exactly as filed with the TX SOS, Texas Comptroller of Public Accounts, County, or in the legal documents forming the entity.

c. Name and title of the person signing the application. (**Note:** The person must be an executive official that meets signatory requirements in 30 TAC § 305.44.)

Prefix: Mr. Full Name (Last/First Name): Seale Charles

Title: <u>President</u> Credential: Click to enter text.

d. Will the applicant have overall financial responsibility for the facility?

⊠ Yes □ No

² All facilities are designated as minors until formally classified as a major by EPA.

³ https://www15.tceq.texas.gov/crpub/index.cfm?fuseaction=cust.CustSearch

Note: The entity with overall financial responsibility for the facility must apply as a coapplicant, if not the facility owner.

Item 3. Co-applicant Information (Instructions, Page 27)

☑ Check this box if there is no co-applicant.; otherwise, complete the below questions.

- a. Legal name of the entity (co-applicant) applying for this permit: <u>Click to enter text.</u>
 Note: The legal name must be spelled exactly as filed with the TX SOS, Texas Comptroller of Public Accounts, County, or in the legal documents forming the entity.
- b. Customer Number (if applicant is an existing customer): <u>CNClick to enter text.</u>
 Note: Locate the customer number using the TCEQ's Central Registry Customer Search.
- c. Name and title of the person signing the application. (**Note:** The person must be an executive official that meets signatory requirements in 30 TAC § 305.44.)

Prefix: Click to enter text.

Full Name (Last/First Name): Click to enter text.

Title: Click to enter text.

Credential: Click to enter text.

d. Will the co-applicant have overall financial responsibility for the facility?

☐ Yes ☐ No

Note: The entity with overall financial responsibility for the facility must apply as a coapplicant, if not the facility owner.

Item 4. Core Data Form (Instructions, Pages 27)

a. Complete one Core Data Form (TCEQ Form 10400) for each customer (applicant and coapplicant(s)) and include as an attachment. If the customer type selected on the Core Data Form is Individual, complete Attachment 1 of the Administrative Report. Attachment: 1

Item 5. Application Contact Information (Instructions, Page 27)

Provide names of two individuals who can be contact for additional information about this application. Indicate if the individual can be contact about administrative or technical information, or both.

a. ⊠ Administrative Contact . □ Technical Contact

Prefix: Ms Full Name (Last/First Name): Seale Linda

Title: Office Manager Credential: Click to enter text.

Organization Name: Wright City WSC

Mailing Address: 24065 Lyles Lane City/State/Zip: Troup, Texas 75789

Phone No: 903-859-1281 Email: wrightcitywsc@gmail.com

b. □ Administrative Contact ☑ Technical Contact

Prefix: Mr. Full Name (Last/First Name): Seale Charles

Title: <u>President</u> Credential: Click to enter text.

Organization Name: Wright City WSC

Mailing Address: 24065 Lyles Lane City/State/Zip: Troup, Texas 75789

Phone No: 903-859-1281 Email: cseale24113@gmail.com

Attachment: N/A

Item 6. Permit Contact Information (Instructions, Page 28)

Provide two names of individuals that can be contacted throughout the permit term.

a. Prefix: Mr. Full Name (Last/First Name): Seale Charles

Title: <u>President</u> Cr

Credential: Click to enter text.

Organization Name: Wright City WSC

Mailing Address: 24065 Lyles Lane

City/State/Zip: Troup, Texas 75789

Phone No: 903-859-1281 Email: cseale24113@gmail.com

b. Prefix: Mr. Full Name (Last/First Name): Sowell Chris

Title: <u>Project Manager</u> Credential: <u>Click to enter text.</u>

Organization Name: Ranger Environmental Services, LLC.

Mailing Address: <u>7215 Mcneil Drive</u> City/State/Zip: <u>Austin, Texas 78729</u>

Phone No: 512-826-3399 Email: chris@rangerenv.com

Attachment: Click to enter text.

Item 7. Billing Contact Information (Instructions, Page 28)

The permittee is responsible for paying the annual fee. The annual fee will be assessed for permits **in effect on September 1 of each year**. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (form TCEQ-20029).

Provide the complete mailing address where the annual fee invoice should be mailed and the name and phone number of the permittee's representative responsible for payment of the invoice.

Prefix: Mr. Full Name (Last/First Name): Seale Charles

Title: <u>President</u> Credential: Click to enter text.

Organization Name: Wright City WSC

Mailing Address: 24065 Lyles Lane City/State/Zip: Troup, Texas 75789

Phone No: 903-859-1281 Email: wrightcitywsc@gmail.com

Item 8. DMR/MER Contact Information (Instructions, Page 28)

Provide the name and mailing address of the person delegated to receive and submit DMRs or MERs. **Note:** DMR data must be submitted through the NetDMR system. An electronic reporting account can be established once the facility has obtained the permit number.

Prefix: Ms. Full Name (Last/First Name): Seale Linda

Title: Office Manager Credential: Click to enter text.

Organization Name: Wright City WSC

Mailing Address: 24065 Lyles Lane City/State/Zip: Troup, Texas 75789

Phone No: 903-859-1281 Email: wrightcitywsc@gmail.com

TCEQ-10411 (01/08/2024) Industrial Wastewater Application Administrative Report

Page 5 of 17

Item 9. Notice Information (Instructions, Pages 28)

a. Individual Publishing the Notices

Prefix: Ms. Full Name (Last/First Name): Seale Linda

Title: Office Manager Credential: Click to enter text.

Organization Name: Wright City WSC

Mailing Address: 24065 Lyles Lane City/State/Zip: Troup, Texas 75789

Phone No: 903-859-1281 Email: wrightcitywsc@gmail.com

- b. Method for Receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package (only for NORI, NAPD will be sent via regular mail)
 - ☑ E-mail: wrightcitywsc@gmail.com
 - ☐ Fax: Click to enter text.
 - ☐ Regular Mail (USPS)

Mailing Address: <u>Click to enter text.</u>

City/State/Zip Code: Click to enter text.

c. Contact in the Notice

Prefix: Mr. Full Name (Last/First Name): Seale Charles

Title: <u>President</u> Credential: <u>Click to enter text.</u>

Organization Name: Wright City WSC

Phone No: 903-859-1281 Email: wrightcitywsc@gmail.com

d. Public Viewing Location Information

Note: If the facility or outfall is located in more than one county, provide a public viewing place for each county.

Public building name: Wright City WSC - Office Location within the building: Wall Inside

Physical Address of Building: 24065 Lyles Lane

City: Troup County: Smith

e. Bilingual Notice Requirements

This information is required for new, major amendment, minor amendment or minor modification, and renewal applications.

This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.

Call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine if an alternative language notice(s) is required.

1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?

☐ Yes ☒ No

If no, publication of an alternative language notice is not required; skip to Item 8 (Regulated Entity and Permitted Site Information.)

	2.	Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?
		□ Yes □ No
	3.	Do the students at these schools attend a bilingual education program at another location?
		□ Yes □ No
	4.	Would the school be required to provide a bilingual education program, but the school has waived out of this requirement under 19 TAC §89.1205(g)?
		□ Yes □ No □ N/A
	5.	If the answer is yes to question 1, 2, 3, or 4, public notices in an alternative language are required. Which language is required by the bilingual program? <u>Click to enter text.</u>
f.	Pla 20	in Language Summary Template – Complete the Plain Language Summary (TCEQ Form 972) and include as an attachment. Attachment: <u>15</u>
g.		mplete one Public Involvement Plan (PIP) Form (TCEQ Form 20960) for each application a new permit or major amendment and include as an attachment. Attachment: $\underline{2}$
It	em	10. Regulated Entity and Permitted Site Information (Instructions
		Page 29)
a.	TC	EQ issued Regulated Entity Number (RN), if available: RN101237063
	No ma the	te: If your business site is part of a larger business site, a Regulated Entity Number (RN) y already be assigned for the larger site. Use the RN assigned for the larger site. Search TCEQ's Central Registry to determine the RN or to see if the larger site may already be istered as a Regulated Entity. If the site is found, provide the assigned RN.
b.	Nar WS	ne of project or site (the name known by the community where located): <u>Wright City</u> <u>C 1</u>
c.	Is t	he location address of the facility in the existing permit the same?
		Yes □ No ☒ N/A (new permit)
	Will	te: If the facility is located in Bexar, Comal, Hays, Kinney, Medina, Travis, Uvalde, or liamson County, additional information concerning protection of the Edwards Aquifer y be required.
d.	Ow	ner of treatment facility:
	Pref	fix: <u>Click to enter text.</u> Full Name (Last/First Name): <u>Click to enter text.</u>
	or C	Organization Name: Wright City WSC
	Mai	ling Address: 24065 Lyles Lane City/State/Zip: Troup, Texas 75789
	Pho	ne No: 903-859-1281 Email: wrightcitywsc@gmail.com
e.	Owr	nership of facility: $oxtimes$ Public $oxtimes$ Private $oxtimes$ Both $oxtimes$ Federal
f.	Owr	ner of land where treatment facility is or will be: Click to enter text.
	Pref	ix: <u>Click to enter text.</u> Full Name (Last/First Name): <u>Click to enter text.</u>
	or C	Organization Name: Wright City WSC

e.

f.

	Mailing Address: <u>24065 Lyles Lane</u>	City/State/Zip: Troup, Texas 78789
	Phone No: <u>903-859-1281</u> Email: <u>wrig</u>	htcitywsc@gmail.com
	Note: If not the same as the facility owne at least six years (In some cases, a lease reclick to enter text.	er, attach a long-term lease agreement in effect for may not suffice - see instructions). Attachment:
g.	Owner of effluent TLAP disposal site (if a	pplicable): <u>N/A</u>
	Prefix: <u>Click to enter text.</u> Full Name	(Last/First Name): Click to enter text.
	or Organization Name: Click to enter text	
	Mailing Address: Click to enter text.	City/State/Zip: Click to enter text.
	Phone No: Click to enter text. Email: Click	k to enter text.
	Note: If not the same as the facility owner at least six years. Attachment: <u>Click to en</u>	r, attach a long-term lease agreement in effect for text.
h.	Owner of sewage sludge disposal site (if a	applicable):
	Prefix: <u>Click to enter text.</u> Full Name (Last/First Name): <u>Click to enter text.</u>
	or Organization Name: Click to enter text.	
	Mailing Address: Click to enter text.	City/State/Zip: Click to enter text.
	Phone No: <u>Click to enter text.</u> Email: <u>Click</u>	to enter text.
	Note: If not the same as the facility owner at least six years. Attachment: <u>Click to entertainty</u>	c, attach a long-term lease agreement in effect for
	ut least six years. Attachment. enex to en	ter text.
Ite	em 11. TDPES Discharge/TLAP I	Disposal Information (Instructions,
Ite		
	em 11. TDPES Discharge/TLAP I	Disposal Information (Instructions,
a.	em 11. TDPES Discharge/TLAP I Page 31) Is the facility located on or does the treate ☐ Yes ☒ No Attach an original full size USGS Topograp	Disposal Information (Instructions, ed effluent cross Native American Land? Thic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to
a.	Page 31) Is the facility located on or does the treated In Yes In Note 1	Disposal Information (Instructions, ed effluent cross Native American Land? Thic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to
a.	Page 31) Is the facility located on or does the treated In the facility located on or does the treated In the Interest In the facility located on or does the treated In the Interest	Disposal Information (Instructions, ed effluent cross Native American Land? Thic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to cluded on the map.
a.	Page 31) Is the facility located on or does the treated an original full size USGS Topographenewal or amendment applications) with each item below to confirm it has been income. One-mile radius	Disposal Information (Instructions, ed effluent cross Native American Land? Thic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to cluded on the map. Three-miles downstream information
a.	Page 31) Is the facility located on or does the treated are Yes No Attach an original full size USGS Topographenewal or amendment applications) with each item below to confirm it has been income One-mile radius Applicant's property boundaries	Disposal Information (Instructions, ed effluent cross Native American Land? phic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to cluded on the map. Three-miles downstream information Treatment facility boundaries
a.	Page 31) Is the facility located on or does the treated I Yes I No Attach an original full size USGS Topographenewal or amendment applications) with each item below to confirm it has been inc I One-mile radius I Applicant's property boundaries I Labeled point(s) of discharge	Disposal Information (Instructions, ed effluent cross Native American Land? chic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to cluded on the map. ☐ Three-miles downstream information ☐ Treatment facility boundaries ☐ Highlighted discharge route(s)
a.	Page 31) Is the facility located on or does the treated I yes I No Attach an original full size USGS Topographenewal or amendment applications) with each item below to confirm it has been income I will one-mile radius I one-mile radius I Applicant's property boundaries I Labeled point(s) of discharge I Effluent disposal site boundaries	Disposal Information (Instructions, ed effluent cross Native American Land? chic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to cluded on the map. ☐ Three-miles downstream information ☐ Treatment facility boundaries ☐ Highlighted discharge route(s) ☐ All wastewater ponds
a. b.	Page 31) Is the facility located on or does the treated Yes No Attach an original full size USGS Topographenewal or amendment applications) with each item below to confirm it has been income One-mile radius Applicant's property boundaries Applicant's property boundaries Labeled point(s) of discharge Effluent disposal site boundaries Sewage sludge disposal site	Disposal Information (Instructions, ed effluent cross Native American Land? chic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to cluded on the map. ☐ Three-miles downstream information ☐ Treatment facility boundaries ☐ Highlighted discharge route(s) ☐ All wastewater ponds ☐ New and future construction
a. b.	Page 31) Is the facility located on or does the treated Yes ⋈ No Attach an original full size USGS Topographerenewal or amendment applications) with each item below to confirm it has been incomo item in the property boundaries ⋈ Applicant's property boundaries ⋈ Labeled point(s) of discharge ⋈ Effluent disposal site boundaries ⋈ Sewage sludge disposal site Attachment: 3 Is the location of the sewage sludge disposal site	Disposal Information (Instructions, ed effluent cross Native American Land? chic Map (or an 8.5"×11" reproduced portion for all required information. Check the box next to cluded on the map. ☐ Three-miles downstream information ☐ Treatment facility boundaries ☐ Highlighted discharge route(s) ☐ All wastewater ponds ☐ New and future construction sal site in the existing permit accurate?

	☐ Yes ☒ No or New Permit
	If no, or a new application, provide an accurate location description: 32.201457, -94.99415
e.	Are the discharge route(s) in the existing permit correct?
	☐ Yes ☒ No or New Permit
	If no, or a new permit, provide an accurate description of the discharge route: Roadside ditch along FM 2089, thence to an unnamed tributary, thence to Wright Branch, thence to Bowles Creek. (Segment # 0611V)
f.	City nearest the outfall(s): <u>Arp</u>
g.	County in which the outfalls(s) is/are located: Smith
h.	Is or will the treated wastewater discharge to a city, county, or state highway right-of-way or a flood control district drainage ditch?
	⊠ Yes □ No
	If yes, indicate by a check mark if: \square Authorization granted \boxtimes Authorization pending
	For new and amendment applications, attach copies of letters that show proof of contact and provide the approval letter upon receipt. Attachment: <u>Click to enter text.</u>
	For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: Click to enter text.
i.	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?
	☐ Yes No or New Permit ☐ <u>Click to enter text.</u>
	If no, or a new application, provide an accurate location description: <u>Click to enter text.</u>
j.	City nearest the disposal site: Click to enter text.
k.	County in which the disposal site is located: <u>Click to enter text.</u>
l.	For TLAPs, describe how effluent is/will be routed from the treatment facility to the disposal site: <u>Click to enter text.</u>
m.	For TLAPs, identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: <u>Click to enter text.</u>

Item 12. Miscellaneous Information (Instructions, Page 33)

a.	Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?
	□ Yes ⋈ No
	If yes, list each person: <u>Click to enter text.</u>
b.	Do you owe any fees to the TCEQ?
	□ Yes ⋈ No
	If yes, provide the following information:
	Account no.: Click to enter text.
	Total amount due: <u>Click to enter text.</u>
c.	Do you owe any penalties to the TCEQ?
	☐ Yes ☒ No
	If yes, provide the following information:
	Enforcement order no.: Click to enter text.
	Amount due: <u>Click to enter text.</u>

Item 13. Signature Page (Instructions, Page 33)

Permit No: <u>WQ000Click to enter text.</u>
Applicant Name: <u>Wright City WSC</u>

Certification: I, <u>Charles Seale</u>, certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code §305.44 to sign and submit this document and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): Charles Seale

Signatory title: President

Signature: Charles Seale	Date: 4-9-2024
(Use blue ink)	_ 1
Subscribed and Sworn to before me by the said	MAKICS STALE
on this day of	April , 20 24
My commission expires on the October 10 day of	October , 2027

Waler File Notary Public

[SEAL]



County, Texas

Note: If co-applicants are necessary, each entity must submit an original, separate signature page.

INDUSTRIAL WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.1

The following information is required for new and amendment applications.

Item 1. Affected Landowner Information (Instructions, Page 35)

a.	Attach a landowner map or drawing, with scale, as applicable. Check the box next to each item to confirm it has been provided.
	☑ The applicant's property boundaries.
	oxtimes The facility site boundaries within the applicant's property boundaries.
	☐ The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone.
	☑ The property boundaries of all landowners surrounding the applicant's property. (Note: if the application is a major amendment for a lignite mine, the map must include the property boundaries of all landowners adjacent to the new facility (ponds).)
	☑ The point(s) of discharge and highlighted discharge route(s) clearly shown for one mile downstream.
	☑ The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge.
	☐ The property boundaries of the landowners along the watercourse for a one-half mile radius from the point of discharge if the point of discharge is into a lake, bay, estuary, or affected by tides.
	☐ The boundaries of the effluent disposal site (e.g., irrigation area or subsurface drainfield site) and all evaporation/holding ponds within the applicant's property.
	☐ The property boundaries of all landowners surrounding the applicant's property boundaries where the effluent disposal site is located.
	☐ The boundaries of the sludge land application site (for land application of sewage sludge for beneficial use) and the property boundaries of landowners within one-quarter mile of the applicant's property boundaries where the sewage sludge land application site is located.
	☐ The property boundaries of landowners within one-half mile in all directions from the applicant's property boundaries where the sewage sludge disposal site (e.g., sludge surface disposal site or sludge monofil) is located.
	Attachment: <u>5</u>
).	Check the box next to the format of the landowners list:
	☐ Readable/Writeable CD ☐ Four sets of labels
	Attachment: Click to enter text.
	Provide the source of the landowners' names and mailing addresses:
	As required by Texas Water Code § 5.115, is any permanent school fund land affected by this application?
	□ Yes ⊠ No

b.

d.

e.

If yes, provide the location and foreseeable impacts and effects this application has on the land(s): <u>Click to enter text</u>.

Item 2. Original Photographs (Instructions, Page 37)

Provide original ground level photographs. Check the box next to each of the following items to indicate it is included.

- 🛮 At least one original photograph of the new or expanded treatment unit location.
- At least two photographs of the existing/proposed point of discharge and as much area downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is to an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.
- At least one photograph of the existing/proposed effluent disposal site.
- 🛮 A plot plan or map showing the location and direction of each photograph.

Attachment: 6

INDUSTRIAL WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: 14

WATER QUALITY PERMIT

PAYMENT SUBMITTAL FORM

Use this form to submit the Application Fee, if mailing the payment. (Instructions, Page 36-37)

- Complete items 1 through 5 below.
- Staple the check or money order in the space provided at the bottom of this document.
- Do not mail this form with the application form.
- Do not mail this form to the same address as the application.
- Do not submit a copy of the application with this form as it could cause duplicate permit entries.

Mail this form and the check or money order to:

BY REGULAR U.S. MAIL

Austin, Texas 78711-3088

BY OVERNIGHT/EXPRESS MAIL

Texas Commission on Environmental Quality Texas Commission on Environmental Quality Financial Administration Division Cashier's Office, MC-214 P.O. Box 13088

Financial Administration Division Cashier's Office, MC-214 12100 Park 35 Circle Austin, Texas 78753

Fee Code: WQP Permit No: WQ000Click to enter text.

- 1. Check or Money Order Number: Click to enter text.
- 2. Check or Money Order Amount: Click to enter text.
- 3. Date of Check or Money Order: Click to enter text.
- 4. Name on Check or Money Order: Click to enter text.
- 5. APPLICATION INFORMATION

Name of Project or Site: Click to enter text.

Physical Address of Project or Site: Click to enter text.

If the check is for more than one application, attach a list which includes the name of each Project or Site (RE) and Physical Address, exactly as provided on the application. Attachment: Click to enter text.

Staple Check or Money Order in This Space

ATTACHMENT 1

INDIVIDUAL INFORMATION

Item 1. Individual information (Instructions, Page 38)

Complete this attachment if the facility applicant or co-applicant is an individual. Make additional copies of this attachment if both are individuals.

Prefix (Mr., Ms., or Miss): Click to enter text.

Full legal name (first, middle, and last): Click to enter text.

Driver's License or State Identification Number: Click to enter text.

Date of Birth: Click to enter text.

Mailing Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone No.: Click to enter text.

Fax No.: Click to enter text.

E-mail Address: Click to enter text.

CN: Click to enter text.

INDUSTRIAL WASTEWATER PERMIT APPLICATION

TECHNICAL REPORT

(TCEQ 10055)

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



INDUSTRIAL WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

The following information **is required** for all applications for a TLAP or an individual TPDES discharge permit.

For **additional information** or clarification on the requested information, please refer to the <u>Instructions for Completing the Industrial Wastewater Permit Application</u>¹ available on the TCEQ website. Please contact the Industrial Permits Team at 512-239-4671 with any questions about this form.

If more than one outfall is included in the application, provide applicable information for each individual outfall. If an item does not apply to the facility, enter N/A to indicate that the item has been considered. Include separate reports or additional sheets as clearly cross-referenced attachments and provide the attachment number in the space provided for the item the attachment addresses.

NOTE: This application is for an industrial wastewater permit only. Additional authorizations from the TCEQ Waste Permits Division or the TCEQ Air Permits Division may be needed.

Item 1. Facility/Site Information (Instructions, Page 39)

a. Describe the general nature of the business and type(s) of industrial and commercial

SIC Code = 4941.	Provide drinking wate	r	
		115	

b. Describe all wastewater-generating processes at the facility.

The facility is public water supply that will utilize a two stage nanofiltration system to filter groundwater for public use. The nanofiltration system uses membranes with very small pores to remove unwanted larger molecules and ions (bacteria, calcium, magnesium, organic matter, etc.) from the groundwater. The feed water filtered through the system will be for public use, while the reject water that contains the unwanted molecules and ions will be reject water discharged at the facility. The system will generate as much as 54,000 gallons per day of reject groundwater per day. No chemicals are added to the reject water before discharge.

https://www.tceq.texas.gov/permitting/wastewater/industrial/TPDES_industrial_wastewater_steps.html

Raw Materials	Intermediate Products	Final Products
Raw Water		Drinking Water
	0	
*		
	SACK CONTRACTOR STOCK SACRAFTER	
Attachment: Click to en	nter text.	
. Attach a facility map (d	lrawn to scale) with the following i	nformation:
 Production areas, m and water intake str 	aintenance areas, materials-handli ructures.	ng areas, waste-disposal areas,
 The location of each sumps, impoundme outfall locations. 	unit of the WWTP including the long the long the long the long points, outfalls, and sampling points,	ocation of wastewater collection if significantly different from
Attachment: 10		
. Is this a new permit app	olication for an existing facility?	
⊠ Yes □ No		
If yes , provide backs	ground discussion: Click to enter t	ext.
Is/will the treatment fac-	cility/disposal site be located abov	e the 100-year frequency flood
⊠ Yes □ No)	
sound sound	etermine 100-year frequency flood	plain: Click to enter text
If no , provide the elevat protective measures are	ion of the 100-year frequency floo used/proposed to prevent flooding of the treatment facility and dispe	d plain and describe what ng (including tail water and
Attachment: 11	*	
For new or major amen	dment permit applications, will an	y construction operations resul
in a discharge of fill mat	terial into a water in the state?	

h.	If yes to Item 1.g, has the applicant applied for a USACE CWA Chapter 404 Dredge and Fill permit?
	□ Yes □ No
	If yes , provide the permit number: Click to enter text.
	If no , provide an approximate date of application submittal to the USACE: Click to enter text.
It	em 2. Treatment System (Instructions, Page 40)
a.	List any physical, chemical, or biological treatment process(es) used/proposed to treat wastewater at this facility. Include a description of each treatment process, starting with initial treatment and finishing with the outfall/point of disposal.
	The nanofiltration system uses membranes with very small pores to remove unwanted larger molecules and ions (bacteria, calcium, magnesium, organic matter, etc.) from the groundwater. The feed water filtered through the system will be for public use, while the reject water that contains the unwanted molecules and ions will be reject water discharged at the facility. The system will generate as much as 54,000 gallons per day of reject groundwater per day. No chemicals are added to the reject water before discharge.
	Attach a flow schematic with a water balance showing all sources of water and wastewater flow into the facility, wastewater flow into and from each treatment unit, and wastewater flow to each outfall/point of disposal.
	Attachment: 9
Ite	m 3. Impoundments (Instructions, Page 40)
Doe	s the facility use or plan to use any wastewater impoundments (e.g., lagoons or ponds?)
	□ Yes ⊠ No
3.e	o, proceed to Item 4. If yes , complete Item 3.a for existing impoundments and Items 3.a for new or proposed impoundments. NOTE: See instructions, Pages 40-42, for additional rmation on the attachments required by Items 3.a – 3.e.
a. (Complete the table with the following information for each existing, new, or proposed mpoundment. Attach additional copies of the Impoundment Information table, if needed.

Use Designation: Indicate the use designation for each impoundment as Treatment (T), Disposal (D), Containment (C), or Evaporation (E).

Associated Outfall Number: Provide an outfall number if a discharge occurs or will occur.

Liner Type: Indicate the liner type as Compacted clay liner (C), In-situ clay liner (I), Synthetic/plastic/rubber liner (S), or Alternate liner (A). **NOTE:** See instructions for further detail on liner specifications. If an alternate liner (A) is selected, include an attachment that provides a description of the alternate liner and any additional technical information necessary for an evaluation.

Leak Detection System: If any leak detection systems are in place/planned, enter **Y** for yes. Otherwise, enter **N** for no.

Groundwater Monitoring Wells and Data: If groundwater monitoring wells are in place/planned, enter Y for yes. Otherwise, enter N for no. Attach any existing groundwater monitoring data.

Dimensions: Provide the dimensions, freeboard, surface area, storage capacity of the impoundments, and the maximum depth (not including freeboard). For impoundments with irregular shapes, submit surface area instead of length and width.

Compliance with 40 CFR Part 257, Subpart D: If the impoundment is required to be in compliance with 40 CFR Part 257, Subpart D, enter Y for yes. Otherwise, enter N for no.

Date of Construction: Enter the date construction of the impoundment commenced (mm/dd/yy).

Impoundment Information

Parameter	Pond #	Pond #	Pond #	Pond #
Use Designation: (T) (D) (C) or (E)				
Associated Outfall Number				
Liner Type (C) (I) (S) or (A)				
Alt. Liner Attachment Reference	*			
Leak Detection System, Y/N				
Groundwater Monitoring Wells, Y/N			3	
Groundwater Monitoring Data Attachment				
Pond Bottom Located Above The Seasonal High-Water Table, Y/N				
Length (ft)				
Width (ft)				
Max Depth From Water Surface (ft), Not Including Freeboard				
Freeboard (ft)				
Surface Area (acres)				
Storage Capacity (gallons)				
40 CFR Part 257, Subpart D, Y/N				
Date of Construction				

Attachment: Click to enter text.

The following information (Items 3.b – 3.e) is required only for new or proposed impoundments.

D.	ite		If attach				ents, attach any available information on the following the appropriate box. Otherwise, check no or not yet
	1.	Lin	er data				
			Yes	\boxtimes	No		Not yet designed
	2.	Lea	k detecti	on sy	stem or	grou	ndwater monitoring data
			Yes	\boxtimes	No		Not yet designed
	3.	Gro	undwate	r imj	oacts		
			Yes	\boxtimes	No		Not yet designed
							he bottom of the pond is not above the seasonal high- vater-bearing zone.
			Appropriate Contraction of the C	-		and the same	

Attachment: Click to enter text.

For TLAP applications: Items 3.c - 3.e are not required, continue to Item 4.

c. Attach a USGS map or a color copy of original quality and scale which accurately locates and identifies all known water supply wells and monitor wells within ½-mile of the impoundments.

Attachment: Click to enter text.

d. Attach copies of State Water Well Reports (e.g., driller's logs, completion data, etc.), and data on depths to groundwater for all known water supply wells including a description of how the depths to groundwater were obtained.

Attachment: Click to enter text.

e. Attach information pertaining to the groundwater, soils, geology, pond liner, etc. used to assess the potential for migration of wastes from the impoundments or the potential for contamination of groundwater or surface water.

Attachment: Click to enter text.

Item 4. Outfall/Disposal Method Information (Instructions, Page 42)

Complete the following tables to describe the location and wastewater discharge or disposal operations for each outfall for discharge, and for each point of disposal for TLAP operations.

If there are more outfalls/points of disposal at the facility than the spaces provided, copies of pages 6 and/0r numbered accordingly (i.e., page 6a, 6b, etc.) may be used to provide information on the additional outfalls.

For TLAP applications: Indicate the disposal method and each individual irrigation area I, evaporation pond E, or subsurface drainage system S by providing the appropriate letter designation for the disposal method followed by a numerical designation for each disposal area in the space provided for Outfall number (e.g. E1 for evaporation pond 1, I2 for irrigation area No. 2, etc.).

Outfall Longitude and Latitude

Outfall No.	Latitude (Decimal Degrees)	Longitude (Decimal Degrees)
1.	32.2001360	-94.9944870

Outfall Location Description

Outfall No.	Location Description
1.	Roadside Ditch Along FM 2089

Description of Sampling Point(s) (if different from Outfall location)

Outfall No.	Description of sampling point
1.	Roadside Ditch Along FM 2089
-	

Outfall Flow Information - Permitted and Proposed

Outfall No.	Permitted Daily Avg Flow (MGD)	Permitted Daily Max Flow (MGD)	Proposed Daily Avg Flow (MGD)	Proposed Daily Max Flow (MGD)	Anticipated Discharge Date (mm/dd/yy)
1.			54,000 gpd	74	ASAP- 3/1/2025
ii					

Outfall Discharge - Method and Measurement

Outfall No.	Pumped Discharge? Y/N	Gravity Discharge? Y/N	Type of Flow Measurement Device Used
1	Y	N	Water Meter
4	0		

Outfall Discharge - Flow Characteristics

Outfall No.		Continuous Discharge? Y/N	Seasonal Discharge? Y/N	Discharge Duration (hrs/day)	Discharge Duration (days/mo)	Discharge Duration (mo/yr)
1	N	Y	N	24	28-31	12

Outfall Wastestream Contributions

Outfall No. Click to enter text.

Contributing Wastestream	Volume (MGD)	Percent (%) of Total Flow
Reject Water from Nano-filtration unit	54,000 gpd	100
	i i	2

Outfall No. Click to enter text.

Contributing Wastestream	Volume (MGD)	Percent (%) of Total Flow
×		
	8 11	
		P 58

Outfall No. Click to enter text.

Contributing Wastestream	Volume (MGD)	Percent (%) of Total Flow

Attachment: Click to enter text.

Item 5. Blowdown and Once-Through Cooling Water Discharges (Instructions, Page 43)

a. Indicate if the facility currently or proposes to:					
	88	Yes	\boxtimes	No	Use cooling towers that discharge blowdown or other wastestream
		Yes	\boxtimes	No	Use boilers that discharge blowdown or other wastestreams
		Yes	\boxtimes	No	Discharge once-through cooling water

NOTE: If the facility uses or plans to use cooling towers or once-through cooling water, Item 12 **is required**.

- b. If **yes** to any of the above, attach an SDS with the following information for each chemical additive.
 - Manufacturers Product Identification Number
 - Product use (e.g., biocide, fungicide, corrosion inhibitor, etc.)
 - Chemical composition including CASRN for each ingredient
 - Classify product as non-persistent, persistent, or bioaccumulative
 - Product or active ingredient half-life
 - Frequency of product use (e.g., 2 hours/day once every two weeks)
 - · Product toxicity data specific to fish and aquatic invertebrate organisms
 - Concentration of whole product or active ingredient, as appropriate, in wastestream.

In addition to each SDS, attach a summary of the above information for each specific wastestream and the associated chemical additives. Specify which outfalls are affected.

Attachment: Click to enter text.

c. Cooling Towers and Boilers

If the facility currently or proposes to use cooling towers or boilers that discharge blowdown or other wastestreams to the outfall(s), complete the following table.

Cooling Towers and Boilers

Type of Unit	Number of Units	Daily Avg Blowdown (gallons/day)	Daily Max Blowdown (gallons/day)
Cooling Towers	-	Y	
Boilers			

Item 6. Stormwater Management (Instructions, Page 44)

Will any existing/proposed outfalls discharge stormwater associated with industrial activities
as defined at 40 CFR § 122.26(b)(14), commingled with any other wastestream?

198	Yes	\boxtimes	No

If **yes**, briefly describe the industrial processes and activities that occur outdoors or in a manner which may result in exposure of the activities or materials to stormwater: Click to enter text.

Item 7. Domestic Sewage, Sewage Sludge, and Septage Management and Disposal (Instructions, Page 44)

Domestic Sewage - Waste and wastewater from humans or household operations that is discharged to a wastewater collection system or otherwise enters a treatment works.

d	 Check the box next to the appropriate method of do sludge treatment or disposal. Complete Worksheet 5 	mestic sewage and domestic sewage .0 or Item 7.b if directed to do so.					
	Domestic sewage is routed (i.e., connected to or tr receive domestic sewage for treatment, disposal, or	ransported to) to a WWTP permitted to or both. Complete Item 7.b.					
	☐ Domestic sewage disposed of by an on-site septic Item 7.b.	tank and drainfield system. Complete					
	☐ Domestic and industrial treatment sludge ARE con	nmingled prior to use or disposal.					
	☐ Industrial wastewater and domestic sewage are tre- sludge IS NOT commingled prior to sludge use or	☐ Industrial wastewater and domestic sewage are treated separately, and the respective sludge IS NOT commingled prior to sludge use or disposal. Complete Worksheet 5.0.					
	☐ Facility is a POTW. Complete Worksheet 5.0.						
	☑ Domestic sewage is not generated on-site.						
	☐ Other (e.g., portable toilets), specify and Complete	Item 7.b: Click to enter text.					
b.	Provide the name and TCEQ, NPDES, or TPDES Permit which receives the domestic sewage/septage. If haule name and TCEQ Registration No. of the hauler.						
Do	omestic Sewage Plant/Hauler Name						
	omestic Sewage Plant/Hauler Name Plant/Hauler Name	Permit/Registration No.					
		Permit/Registration No.					
		Permit/Registration No.					
P	Plant/Hauler Name						
P		/Enforcement					
It	em 8. Improvements or Compliance	/Enforcement age 45)					
It	Plant/Hauler Name Tem 8. Improvements or Compliance Requirements (Instructions, Page 1) Is the permittee currently required to meet any imple	/Enforcement age 45)					
It a.	Plant/Hauler Name Tem 8. Improvements or Compliance Requirements (Instructions, Paragraphics) Is the permittee currently required to meet any implesenforcement? Yes No	/Enforcement age 45) mentation schedule for compliance or					
It a.	Plant/Hauler Name Tem 8. Improvements or Compliance Requirements (Instructions, Parallel Sections) Is the permittee currently required to meet any imple enforcement?	/Enforcement age 45) mentation schedule for compliance or					

1	tem 9. Toxicity Testing (Instructions, Page 45)
	Have any biological tests for acute or chronic toxicity been made on any of the discharges or on a receiving water in relation to the discharge within the last three years?
	□ Yes ⊠ No
If	f yes, identify the tests and describe their purposes: Click to enter text.
A O	additionally, attach a copy of all tests performed which have not been submitted to the TCEQ or EPA. Attachment: Click to enter text.
I	tem 10. Off-Site/Third Party Wastes (Instructions, Page 45)
a.	. Does or will the facility receive wastes from off-site sources for treatment at the facility, disposal on-site via land application, or discharge via a permitted outfall?
	□ Yes ⊠ No
	If yes , provide responses to Items 10.b through 10.d below.
	If no , proceed to Item 11.
b.	Attach the following information to the application:
	• List of wastes received (including volumes, characterization, and capability with on-site wastes).
	 Identify the sources of wastes received (including the legal name and addresses of the generators).
	 Description of the relationship of waste source(s) with the facility's activities.
	Attachment: Click to enter text.
c.	Is or will wastewater from another TCEQ, NPDES, or TPDES permitted facility commingled with this facility's wastewater after final treatment and prior to discharge via the final outfall/point of disposal?
	□ Yes □ No
	If yes , provide the name, address, and TCEQ, NPDES, or TPDES permit number of the contributing facility and a copy of any agreements or contracts relating to this activity.
	Attachment: Click to enter text.
d.	Is this facility a POTW that accepts/will accept process wastewater from any SIU and has/is required to have an approved pretreatment program under the NPDES/TPDES program?
	□ Yes □ No
f y	yes, Worksheet 6.0 of this application is required.
[te	em 11. Radioactive Materials (Instructions, Page 46)
ı.	Are/will radioactive materials be mined, used, stored, or processed at this facility?
	☐ Yes ☒ No
	If yes , use the following table to provide the results of one analysis of the effluent for all radioactive materials that may be present. Provide results in pCi/L.

Radioactive Materials Mined, Used, S	stored, or Processed		
Radioactive Material Name		Concentration ()	pCi/L)
			7
 Does the applicant or anyone a radioactive materials may be pre- radioactive materials in the source. 	resent in the discharge	e, including natural	on to believe that ly occurring
□ Yes □ No			
If yes , use the following table to radioactive materials that may information provided in respon	be present. Provide res	of one analysis of t sults in pCi/L. Do r	he effluent for all not include
Radioactive Materials Present in the	Discharge		
Radioactive Material Name		Concentration (p	Ci/L)
			-
15	ı	2	o mi
Item 12. Cooling Water			
a. Does the facility use or propose	to use water for cooli	ng purposes?	
□ Yes ⊠ No			
If no , stop here. If yes , complete	e Items 12.b thru 12.f.		
o. Cooling water is/will be obtained	d from a groundwater	source (e.g., on-sit	e well).
□ Yes □ No			
If yes , stop here. If no , continue	S.		
. Cooling Water Supplier			
Provide the name of the own supply water for cooling purply.	er(s) and operator(s) for poses to the facility.	or the CWIS that su	ipplies or will
ooling Water Intake Structure(s) Owr	ner(s) and Operator(s)		
CWIS ID			
Owner			
Operator			

	2.	. Cooling w	vater is/v	vill be	e obtained from a Public Water Supplier (PWS)
			Yes		No
		If no , con enter text	tinue. If	yes, p	provide the PWS Registration No. and stop here: <u>PWS No.</u> Click to
	3.	Cooling w	ater is/v	vill be	e obtained from a reclaimed water source?
			Yes		No
		If no , con text.	tinue. If	yes, p	provide the Reuse Authorization No. and stop here: Click to ente
	4.	Cooling w	ater is/w	vill be	obtained from an Independent Supplier
			Yes		No
		If no , proc Supplier's Click to er	CWIS th	at is/	2.d. If yes, provide the actual intake flow of the Independent will be used to provide water for cooling purposes and proceed:
d.	31	6(b) Genera	al Criteri	a	
	1.	The CWIS(s) used t e design	o pro intak	vide water for cooling purposes to the facility has or will have a e flow of 2 MGD or greater.
			Yes		No
	2.	At least 25 exclusively	5% of the v for coo	total ling p	water withdrawn by the CWIS is/will be used at the facility ourposes on an annual average basis.
		20	Yes		No
	3.	The CWIS(surface was 122.2.	s) withdr ters that	aw(s) mee	/propose(s) to withdraw water for cooling purposes from the definition of Waters of the United States in 40 CFR §
			Yes		No
		If no , prov Waters of t	ide an ex the Unite	plana d Sta	ation of how the waterbody does not meet the definition of tes in 40 CFR § 122.2: Click to enter text.
If to	yes the	to all three full require	questior ments o	ns in I f Sect	tem 12.d, the facility meets the minimum criteria to be subject ion 316(b) of the CWA. Proceed to Item 12.f .
be	sub	ject to the	full requ	ireme	Item 12.d, the facility does not meet the minimum criteria to ents of Section 316(b) of the CWA; however, a determination is ed to Item 12.e .
e.	The of S	Section 316	es not m (b) and u No	ieet tł i ses /j	ne minimum requirements to be subject to the fill requirements proposes to use cooling towers.
	If y	es, stop he	re. If no ,	comp on ba	olete Worksheet 11.0, Items 1.a, 1.b.1-3 and 6, 2.b.1, and 3.a to sed upon BPJ.
f.	Oil	and Gas Ex	ploration	n and	Production
	1.	The facility	is subje	ct to 1	requirements at 40 CFR Part 435, Subparts A or D.

			Yes		No
	If	yes, co	ntinue.	If no ,	skip to Item 12.g.
2.	Th ex	ie facili isting f	ity is an facility a	existii s defii	ng facility as defined at 40 CFR § 125.92(k) or a new unit at an ned at 40 CFR § 125.92(u).
		IN THE SECOND	Yes		No
	If de	yes, co termin	mplete ation ba	Works sed up	heet 11.0, Items 1.a, 1.b.1-3 and 6, 2.b.1, and 3.a to allow for a pon BPJ. If no , skip to Item 12.g.3.
Co	mp	liance	Phase ar	nd Tra	ck Selection
1.	Ph	ase I -	New fac	ility su	ubject to 40 CFR Part 125, Subpart I
			Yes		No
	If y	y es , ch ormati	eck the on, and	box ne compl	ext to the compliance track selection, attach the requested lete Worksheet 11.0, Items 2 and 3, and Worksheet 11.2.
		Tracl	k I – AIF	greate	er than 2 MGD, but less than 10 MGD
		• A	ttach in	forma	tion required by 40 CFR §§ 125.86(b)(2)-(4).
		Track	c I – AIF	greate	er than 10 MGD
		• A	ttach in	forma	tion required by 40 CFR § 125.86(b).
		Track	C II		
		• A	ttach in	forma	tion required by 40 CFR § 125.86(c).
	Att	achme	nt: Clicl	to en	iter text.
2.	Pha	ise II -	Existing	facilit	ty subject to 40 CFR Part 125, Subpart J
		Name of Street, Street	Yes		No
	If y	es , cor	nplete V	Vorksh	neets 11.0 through 11.3, as applicable.
3.	Pha	se III -	New fac	cility s	subject to 40 CFR Part 125, Subpart N
			Yes		No
	If y info	es , che rmatic	ck the b	ox nez	xt to the compliance track selection and provide the requested
		Track	I - Fixed	d facili	ity
		• At	ttach inf l.0, Item	format is 2 an	tion required by 40 CFR § 125.136(b) and complete Worksheet d 3, and Worksheet 11.2.
		Track	I – Not a	a fixed	l facility
					ion required by 40 CFR § 125.136(b) and complete Worksheet cept CWIS latitude/longitude under Item 2.a).
		Track	II - Fixe	d facil	lity
			tach inf .0, Item		ion required by 40 CFR § 125.136(c) and complete Worksheet d 3.

Attachment: Click to enter text.

g.

Item 13. Permit Change Requests (Instructions, Page 48) This item is only applicable to existing permitted facilities. a. Is the facility requesting a **major amendment** of an existing permit? Yes \boxtimes No If **yes**, list each request individually and provide the following information: 1) detailed information regarding the scope of each request and 2) a justification for each request. Attach any supplemental information or additional data to support each request. Click to enter text. b. Is the facility requesting any minor amendments to the permit? Yes No If yes, list and describe each change individually. Click to enter text.

c. Is the facility requesting any **minor modifications** to the permit?

□ Yes □

⊠ No

If **yes**, list and describe each change individually.

Click to enter text.

Item 14. Laboratory Accreditation (Instructions, Page 49)

All laboratory tests performed must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - o periodically inspected by the TCEQ; or
 - o located in another state and is accredited or inspected by that state; or
 - o performing work for another company with a unit located in the same site; or
 - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the *Signature Page* section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Printed Name: Charles Seale

Title: President

Signature: VVOV

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 1.0: EPA CATEGORICAL EFFLUENT GUIDELINES

This worksheet **is required** for all applications for TPDES permits for discharges of wastewaters subject to EPA categorical effluent limitation guidelines (ELGs).

Item 1. Categorical Industries (Instructions, Page 53)

7 .7 . 0 .11 . 1 .			8/
Is this facility subject	ct to any 40 CFR categorie	cal ELGs outlined on pag	e 53 of the instructions?
□ Yes ⊠ No	0		
If no , this workshee	t is not required. If yes , p	provide the appropriate i	nformation below.
40 CFR Effluent Guide			
Industry	LIMC	10	CFR Part
muusu y		10	CFR Part
	V		
	u .		
		2	
Nº			
Item 2 Produ	ction/Process Da	ta (Instructions	Page 54)
NOTE: For all TPDES of oil and gas explora the state, falling under	permit applications requation and production was er the Oil and Gas Extrac	esting individual permit stewater (discharges into	coverage for discharges or adjacent to water in
Worksheet 12.0, Item	2 instead.		
a. Production Data			
Provide appropriate o	data for effluent guidelin	es with production-based	d effluent limitations.
Production Data	\$50.000 p. 50.000 p. 10.000 p.		
Subcategory	Actual Quantity/Day	Design Quantity/Day	Units
,	1100000	Design Quantity, Day	Units

b. Organic Chemicals, Plastics, and Synthetic Fibers Manufacturing Data (40 CFR Part 414) Provide each applicable subpart and the percent of total production. Provide data for metalbearing and cyanide-bearing wastestreams, as required by 40 CFR Part 414, Appendices A and В. Percentage of Total Production Percent of Total Appendix A and B -Appendix A -Subcategory Production Metals Cvanide c. Refineries (40 CFR Part 419) Provide the applicable subcategory and a brief justification. Click to enter text. Item 3. Process/Non-Process Wastewater Flows (Instructions, **Page 54)** Provide a breakdown of wastewater flow(s) generated by the facility, including both process and non-process wastewater flow(s). Specify which wastewater flows are to be authorized for discharge under this permit and the disposal practices for wastewater flows, excluding domestic, which are not to be authorized for discharge under this permit. A nano filtration plant will utilize groundwater and the system will need to backwash approximately 54,000gpd of water per day. Wastewater from this system will be placed onto ground. No chemicals are added before backwash process.

Item 4. New Source Determination (Instructions, Page 54)

Provide a list of all wastewater-generating processes subject to EPA categorical ELGs, identify the appropriate guideline Part and Subpart, and provide the date the process/construction commenced.

Wastewater Generating Processes Subject to Effluent Guidelines

Process	EPA Guideline Part	EPA Guideline Subpart	Date Process/ Construction Commenced
in g	19		
	4		V.
un			
и			2
	2		
*	i i	-	7

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: POLLUTANT ANALYSIS

Worksheet 2.0 **is required** for all applications submitted for a TPDES permit. Worksheet 2.0 is not required for applications for a permit to dispose of all wastewater by land disposal or for discharges solely of stormwater associated with industrial activities.

Item 1. General Testing Requirements (Instructions, Page 55)

- a. Provide the date range of all sampling events conducted to obtain the analytical data submitted with this application (e.g., 05/01/2018-05/30/2018): 01/04/2024
- b. \boxtimes Check the box to confirm all samples were collected no more than 12 months prior to the date of application submittal.
- c. Read the general testing requirements in the instructions for important information about sampling, test methods, and MALs. If a contact laboratory was used, attach a list which includes the name, contact information, and pollutants analyzed for each laboratory/firm. **Attachment:** 12

Item 2. Specific Testing Requirements (Instructions, Page 56)

Attach correspondence from TCEQ approving submittal of less than the required number of samples, if applicable. **Attachment**: <u>Click to enter text.</u>

TABLE 1 and TABLE 2 (Instructions, Page 58)

Completion of Tables 1 and 2 is required for all external outfalls for all TPDES permit applications.

Table 1 for Outfall No.: Click to enter text. Sam	oles are (check one): Composite	\boxtimes	Grab
---	----------------------------------	-------------	------

Pollutant	Sample 1 (mg/L)	Sample 2 (mg/L)	Sample 3 (mg/L)	Sample 4 (mg/L)
BOD (5-day)	<2.0			
CBOD (5-day)	<2.0			
Chemical oxygen demand	35.8			
Total organic carbon	1.7			
Dissolved oxygen	10.4			
Ammonia nitrogen	0.805			
Total suspended solids	19.3			
Nitrate nitrogen	<0.3			
Total organic nitrogen	1.395			
Total phosphorus	0.83			
Oil and grease	<5.0			
Total residual chlorine	<0.1			

Pollutant	Sample 1 (mg/L)	Sample 2 (mg/L)	Sample 3 (mg/L)	Sample 4 (mg/L)
Total dissolved solids	730			
Sulfate	44.7			
Chloride	170			
Fluoride	0.33			
Total alkalinity (mg/L as CaCO3)	340			
Temperature (°F)	-			
pH (standard units)	8.63			

Table 2 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☒ Grab

Pollutant	Sample 1 (µg/L)	Sample 2 (µg/L)	Sample 3 (µg/L)	Sample 4 (µg/L)	MAL (μg/L)
Aluminum, total	3130				2.5
Antimony, total	<2.0				5
Arsenic, total	<0.5				0.5
Barium, total	42.4				3
Beryllium, total	<0.5				0.5
Cadmium, total	<1.0			> 2 1/2	1
Chromium, total	2.06				3
Chromium, hexavalent	<3.0				3
Chromium, trivalent	<3.0				N/A
Copper, total	3.42				2
Cyanide, available	<5				2/10
Lead, total	0.663				0.5
Mercury, total	0.00096				0.005/0.0005
Nickel, total	<2.0				2
Selenium, total	<2.0				5
Silver, total	<0.5			1.	0.5
Thallium, total	<0.5				0.5
Zinc, total	7.92				5.0

TABLE 3 (Instructions, Page 58)

Completion of Table 3 **is required** for all **external outfalls** which discharge process wastewater.

Partial completion of Table 3 **is required** for all **external outfalls** which discharge non-process wastewater and stormwater associated with industrial activities commingled with other wastestreams (see instructions for additional guidance).

Pollutant	Sample 1	Sample 2	Sample 3	Sample 4	MAL
	(μg/L)*	(μg/L)*	(μg/L)*	(μg/L)*	(μg/L)*
Acrylonitrile	X				50
Anthracene			1.		10
Benzene	1				10
Benzidine					50
Benzo(a)anthracene					5
Benzo(a)pyrene					5
Bis(2-chloroethyl)ether					10
Bis(2-ethylhexyl)phthalate			2		10
Bromodichloromethane [Dichlorobromomethane]		_		<i>u</i>	10
Bromoform					10
Carbon tetrachloride					2
Chlorobenzene			1		10
Chlorodibromomethane [Dibromochloromethane]	= = 		85 A:		10
Chloroform			7		10
Chrysene					5
m-Cresol [3-Methylphenol]		4			10
o-Cresol [2-Methylphenol]					10
p-Cresol [4-Methylphenol]					10
1,2-Dibromoethane					10
m-Dichlorobenzene [1,3-Dichlorobenzene]					10
o-Dichlorobenzene 1,2-Dichlorobenzene]					10
o-Dichlorobenzene 1,4-Dichlorobenzene]					10
3,3'-Dichlorobenzidine					5
,2-Dichloroethane					10

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)*
1,1-Dichloroethene [1,1-Dichloroethylene]					10
Dichloromethane [Methylene chloride]					20
1,2-Dichloropropane					10
1,3-Dichloropropene [1,3-Dichloropropylene]					10
2,4-Dimethylphenol					10
Di-n-Butyl phthalate					10
Ethylbenzene					10
Fluoride					500
Hexachlorobenzene					5
Hexachlorobutadiene				v	10
Hexachlorocyclopentadiene					10
Hexachloroethane					20
Methyl ethyl ketone					50
Nitrobenzene					10
N-Nitrosodiethylamine		2			20
N-Nitroso-di-n-butylamine				F g 4	20
Nonylphenol		-			333
Pentachlorobenzene					20
Pentachlorophenol					5
Phenanthrene					10
Polychlorinated biphenyls (PCBs) (**)				14 2 3e =	0.2
Pyridine		F			20
1,2,4,5-Tetrachlorobenzene					20
1,1,2,2-Tetrachloroethane			7		10
Tetrachloroethene [Tetrachloroethylene]					10
Toluene					10
1,1,1-Trichloroethane					10
1,1,2-Trichloroethane					10
Trichloroethene					10
[Trichloroethylene]					

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)*
2,4,5-Trichlorophenol					50
TTHM (Total trihalomethanes)					10
Vinyl chloride					10

^(*) Indicate units if different from µg/L.

TABLE 4 (Instructions, Pages 58-59)

a.

tial completion of Table 4 is required for each external outfall based on the conditions ow.
Tributyltin
Is this facility an industrial/commercial facility which currently or proposes to directly dispose of wastewater from the types of operations listed below or a domestic facility which currently or proposes to receive wastewater from the types of industrial/commercial operations listed below?
□ Yes ⊠ No
If yes , check the box next to each of the following criteria which apply and provide the appropriate testing results in Table 4 below (check all that apply).
Manufacturers and formulators of tributyltin or related compounds.
Painting of ships, boats and marine structures.
Ship and boat building and repairing.
Ship and boat cleaning, salvage, wrecking and scaling.
Operation and maintenance of marine cargo handling facilities and marinas.
☐ Facilities engaged in wood preserving.
Any other industrial/commercial facility for which tributyltin is known to be present, or for which there is any reason to believe that tributyltin may be present in the effluent.
Enterococci (discharge to saltwater)

b.

This facility	discharge	s/proposes	to d	lischarge	directly	into	saltwater	receiving	waters and
									ty processes

		Yes	\boxtimes	No
Dor	nes	tic wastev	vater	is/will be discharged.
		Yes	\boxtimes	No

If yes to either question, provide the appropriate testing results in Table 4 below.

^(**) Total of detects for PCB-1242, PCB-1254, PCB-1221, PCB-1232, PCB-1248, PCB-1260, and PCB-1016. If all non-detects, enter the highest non-detect preceded by a "<".

C.	E.	coli	(discharge	to	freshwater)	Ì
----	----	------	------------	----	-------------	---

This facility discharges/proposes to discharge directly into freshwater receiving waters	and
E. coli bacteria are expected to be present in the discharge based on facility processes.	

□ Yes ⊠ No

Domestic wastewater is/will be discharged.

□ Yes ⊠ No

If yes to either question, provide the appropriate testing results in Table 4 below.

Table 4 for Outfall No.: Click to enter text.	Samples are (check one):	Composite	20	Grab
---	--------------------------	-----------	----	------

Pollutant	Sample 1	Sample 2	Sample 3	Sample 4	MAL
Tributyltin (μg/L)					0.010
Enterococci (cfu or MPN/100 mL)					N/A
E. coli (cfu or MPN/100 mL)			=		N/A

TABLE 5 (Instructions, Page 59)

Completion of Table 5 **is required** for all **external outfalls** which discharge process wastewater from a facility which manufactures or formulates pesticides or herbicides or other wastewaters which may contain pesticides or herbicides.

If this facility does not/will not manufacture or formulate pesticides or herbicides and does not/will not discharge other wastewaters that may contain pesticides or herbicides, check N/A.

⊠ N/A

Table 5 for Outfall No.: Click to enter text.	Samples are (check one): □	Composite		Grab
---	----------------------------	-----------	--	------

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)*
Aldrin				8	0.01
Carbaryl					5
Chlordane					0.2
Chlorpyrifos					0.05
4,4'-DDD					0.1
4,4'-DDE					0.1
4,4'-DDT				8	0.02
2,4-D					0.7
Danitol [Fenpropathrin]					_
Demeton					0.20
Diazinon					0.5/0.1
Dicofol [Kelthane]					1
Dieldrin					0.02
Diuron					0.090

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)*
Endosulfan I (<i>alpha</i>)					0.01
Endosulfan II (<i>beta</i>)					0.02
Endosulfan sulfate					0.1
Endrin					0.02
Guthion [Azinphos methyl]					0.1
Heptachlor					0.01
Heptachlor epoxide	1	V V			0.01
Hexachlorocyclohexane (alpha)					0.05
Hexachlorocyclohexane (<i>beta</i>)					0.05
Hexachlorocyclohexane (<i>gamma</i>) [Lindane]					0.05
Hexachlorophene					10
Malathion					0.1
Methoxychlor					2.0
Mirex					0.02
Parathion (ethyl)					0.1
Toxaphene					0.3
2,4,5-TP [Silvex]			=		0.3

^{*} Indicate units if different from µg/L.

TABLE 6 (Instructions, Page 59)

Completion of Table 6 is required for all external outfalls.

Table 6 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutants	Believed Present	Believed Absent	Sample 1 (mg/L)	Sample 2 (mg/L)	Sample 3 (mg/L)	Sample 4 (mg/L)	MAL (μg/L)*
		ANDSCITE	(IIIg/L)	(IIIg/L)	(IIIg/L)	(mg/L)	(µg/L)
Bromide						10	400
Color (PCU)						W 200	_
Nitrate-Nitrite (as N)							_
Sulfide (as S)			- N				-
Sulfite (as SO3)			12		6		_
Surfactants			* 10				- , -,
Boron, total					Н		20
Cobalt, total			α				0.3
Iron, total							7
Magnesium, total							20
Manganese, total							0.5
Molybdenum, total					£ 50		1
Tin, total			2 7				5
Titanium, total							30

TABLE 7 (Instructions, Page 60)

Check the box next to any of the industrial categories applicable to this facility. If no categories are applicable, check N/A. If GC/MS testing is required, check the box provided to confirm the testing results for the appropriate parameters are provided with the application.

⊠ N/A

Table 7 for Applicable Industrial Categories

In	dustrial Category	40 CFR Part		olatiles able 8		ids ble 9	Ne	ses/ eutrals able 10		sticides ble 11
8	Adhesives and Sealants			Yes		Yes		Yes	No	
	Aluminum Forming	467		Yes		Yes		Yes	No	
	Auto and Other Laundries			Yes		Yes	500	Yes	100	Yes
	Battery Manufacturing	461		Yes	No			Yes	No	
	Coal Mining	434	No		No)	No		No	
	Coil Coating	465		Yes		Yes		Yes	No	
	Copper Forming	468		Yes		Yes	To	Yes	No	
22	Electric and Electronic Components	469		Yes		Yes		Yes		Yes
	Electroplating	413		Yes		Yes		Yes	No	
92	Explosives Manufacturing	457	No			Yes		Yes	No	
	Foundries			Yes		Yes		Yes	No	
	Gum and Wood Chemicals - Subparts A,B,C,E	454		Yes		Yes	No		No	
	Gum and Wood Chemicals - Subparts D,F	454	18	Yes		Yes		Yes	No	
	Inorganic Chemicals Manufacturing	415		Yes		Yes		Yes	No	
	Iron and Steel Manufacturing	420		Yes		Yes		Yes	No	
	Leather Tanning and Finishing	425		Yes		Yes		Yes	No	
	Mechanical Products Manufacturing	1=0		Yes		Yes		Yes	No	
	Nonferrous Metals Manufacturing	421,471		Yes		Yes		Yes		Yes
	Oil and Gas Extraction - Subparts A, D, E, F, G, H	435		Yes		Yes		Yes	No	103
	Ore Mining - Subpart B	440	No			Yes	No		No	
6	Organic Chemicals Manufacturing	414		Yes		Yes		Yes		Yes
	Paint and Ink Formulation	446,447	16	Yes		Yes		Yes	No	1 00
	Pesticides	455		Yes		Yes		Yes		Yes
	Petroleum Refining	419		Yes	No	100	No	100	No	100
	Pharmaceutical Preparations	439		Yes		Yes		Yes	No	
	Photographic Equipment and Supplies	459		Yes		Yes	15	Yes	No	
	Plastic and Synthetic Materials Manufacturing	414		Yes		Yes		Yes		Yes
	Plastic Processing	463		Yes	No	100	No	1 00	No	103
	Porcelain Enameling	466	No	1 00	No		No		No	
	Printing and Publishing			Yes		Yes		Yes		Yes
	Pulp and Paperboard Mills - Subpart C	430		70		Yes		*		Yes
	Pulp and Paperboard Mills - Subparts F, K	430		zir		Yes		*		*
	Pulp and Paperboard Mills - Subparts A, B, D, G, H	430		Yes	i	Yes	ā	rk		n'e
	Pulp and Paperboard Mills - Subparts I, J, L	430		Yes		Yes		*		Yes
	Pulp and Paperboard Mills - Subpart E	430		Yes	15	Yes		Yes		*
	Rubber Processing	428		Yes		Yes		Yes	No	
	Soap and Detergent Manufacturing	417		Yes		Yes		Yes	No	
	Steam Electric Power Plants	423		Yes		Yes	No	1 03	No	
	Textile Mills (Not Subpart C)	410		Yes		Yes		Yes	No	
	Timber Products Processing	429		Yes		Yes		Yes		Yes
7-10-	st if believed present.	120		100		1 (3		1 (3		169

^{*} Test if believed present.

TABLES 8, 9, 10, and 11 (Instructions, Page 60)

Completion of Tables 8, 9, 10, and 11 **is required** as specified in Table 7 for all **external outfalls** that contain process wastewater.

Completion of Tables 8, 9, 10, and 11 may be required for types of industry not specified in Table 7 for specific parameters that are believed to be present in the wastewater.

Table 8 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)
Acrolein					50
Acrylonitrile					50
Benzene					10
Bromoform		- Fi			10
Carbon tetrachloride					2
Chlorobenzene					10
Chlorodibromomethane					10
Chloroethane					50
2-Chloroethylvinyl ether					10
Chloroform					10
Dichlorobromomethane [Bromodichloromethane]		F =			10
1,1-Dichloroethane		4		(4)	10
1,2-Dichloroethane					10
1,1-Dichloroethylene [1,1-Dichloroethene]		150			10
1,2-Dichloropropane		1			10
1,3-Dichloropropylene [1,3-Dichloropropene]					10
Ethylbenzene			11		10
Methyl bromide [Bromomethane]					50
Methyl chloride [Chloromethane]					50
Methylene chloride [Dichloromethane]					20
1,1,2,2-Tetrachloroethane					10
Tetrachloroethylene [Tetrachloroethene]					10
Toluene					10
1,2-Trans-dichloroethylene [1,2-Trans-dichloroethene]					10

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)
1,1,1-Trichloroethane					10
1,1,2-Trichloroethane					10
Trichloroethylene [Trichloroethene]					10
Vinyl chloride					10

^{*} Indicate units if different from µg/L.

Table 9 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)
2-Chlorophenol					10
2,4-Dichlorophenol					10
2,4-Dimethylphenol					10
4,6-Dinitro-o-cresol					50
2,4-Dinitrophenol	1.50				50
2-Nitrophenol					20
4-Nitrophenol					50
p-Chloro-m-cresol					10
Pentachlorophenol		-			5
Phenol					10
2,4,6-Trichlorophenol					10

^{*} Indicate units if different from µg/L.

Table 10 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (μg/L)*	MAL (μg/L)
Acenaphthene					10
Acenaphthylene					10
Anthracene		1			10
Benzidine					50
Benzo(a)anthracene					5
Benzo(a)pyrene					5
3,4-Benzofluoranthene [Benzo(b)fluoranthene]					10
Benzo(ghi)perylene					20
Benzo(k)fluoranthene					5
Bis(2-chloroethoxy)methane					10

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)
Bis(2-chloroethyl)ether					10
Bis(2-chloroisopropyl)ether					10
Bis(2-ethylhexyl)phthalate					10
4-Bromophenyl phenyl ether					10
Butylbenzyl phthalate					10
2-Chloronaphthalene					10
4-Chlorophenyl phenyl ether					10
Chrysene					5
Dibenzo(a,h)anthracene					5
1,2-Dichlorobenzene [o-Dichlorobenzene]			V		10
1,3-Dichlorobenzene [m-Dichlorobenzene]					10
1,4-Dichlorobenzene [p-Dichlorobenzene]					10
3,3'-Dichlorobenzidine					5
Diethyl phthalate					10
Dimethyl phthalate			1		10
Di-n-butyl phthalate					10
2,4-Dinitrotoluene					10
2,6-Dinitrotoluene					10
Di-n-octyl phthalate					10
1,2-Diphenylhydrazine (as Azobenzene)					20
Fluoranthene					10
Fluorene			- H		10
Hexachlorobenzene			n (5
Hexachlorobutadiene			=		10
Hexachlorocyclopentadiene					10
Hexachloroethane					20
Indeno(1,2,3-cd)pyrene					5
Isophorone					10
Naphthalene					10
Nitrobenzene					10
N-Nitrosodimethylamine					50

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)
N-Nitrosodi-n-propylamine					20
N-Nitrosodiphenylamine					20
Phenanthrene					10
Pyrene					10
1,2,4-Trichlorobenzene					10

^{*} Indicate units if different from µg/L.

Table 11 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)
Aldrin				, , ,	0.01
alpha-BHC [alpha-Hexachlorocyclohexane]				100	0.05
beta-BHC [beta-Hexachlorocyclohexane]					0.05
gamma-BHC [gamma-Hexachlorocyclohexane]					0.05
delta-BHC [delta-Hexachlorocyclohexane]		1 4		- E #	0.05
Chlordane		2 2			0.2
4,4'-DDT		n.		V 14	0.02
4,4'-DDE				Н	0.1
4,4'-DDD					0.1
Dieldrin					0.02
Endosulfan I (alpha)					0.01
Endosulfan II (beta)					0.02
Endosulfan sulfate					0.1
Endrin					0.02
Endrin aldehyde					0.1
Heptachlor					0.01
Heptachlor epoxide					0.01
PCB 1242					0.2
PCB 1254					0.2
PCB 1221					0.2
PCB 1232				11	0.2
PCB 1248					0.2

Pollutant	Sample 1 (µg/L)*	Sample 2 (µg/L)*	Sample 3 (µg/L)*	Sample 4 (µg/L)*	MAL (μg/L)
PCB 1260					0.2
PCB 1016					0.2
Toxaphene					0.3

^{*} Indicate units if different from µg/L.

Attachment: Click to enter text.

TABLE 12 (DIOXINS/FURAN COMPOUNDS)

Complete of Table 12 **is required** for **external outfalls**, as directed below. (Instructions, Pages 59-60)

Indicate which compound(s) are manufactured or used at the facility and provide a brief description of the conditions of its/their presence at the facility (check all that apply).

- □ 2,4,5-trichlorophenoxy acetic acid (2,4,5-T) CASRN 93-76-5
 □ 2-(2,4,5-trichlorophenoxy) propanoic acid (Silvex, 2,4,5-TP) CASRN 93-72-1
 □ 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate (Erbon) CASRN 136-25-4
 □ 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate (Ronnel) CASRN 299-84-3
 □ 2,4,5-trichlorophenol (TCP) CASRN 95-95-4
 □ hexachlorophene (HCP) CASRN 70-30-4
- ⊠ None of the above

Description: Click to enter text.

Does the applicant or anyone at the facility know or have any reason to believe that 2,3,7,8-tetrachlorodibenzo-p-dioxin (TCDD) or any congeners of TCDD may be present in the effluent proposed for discharge?

□ Yes ⊠ No

Description: Click to enter text.

If yes to either Items a or b, complete Table 12 as instructed.

Table 12 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Compound	Toxicity Equivalent Factors	Wastewater Concentration (ppq)	Wastewater Toxicity Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Toxicity Equivalents (ppt)	MAL (ppq)
2,3,7,8-TCDD	1					10
1,2,3,7,8- PeCDD	1.0					50
2,3,7,8- HxCDDs	0.1					50
1,2,3,4,6,7,8- HpCDD	0.01					50

Compound	Toxicity Equivalent Factors	Wastewater Concentration (ppq)	Wastewater Toxicity Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Toxicity Equivalents (ppt)	MAL (ppq)
2,3,7,8-TCDF	0.1					10
1,2,3,7,8- PeCDF	0.03		-			50
2,3,4,7,8- PeCDF	0.3					50
2,3,7,8- HxCDFs	0.1					50
2,3,4,7,8- HpCDFs	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					500
PCB 81	0.0003					500
PCB 126	0.1					500
PCB 169	0.03					500
Total				и и и =1		

TABLE 13 (HAZARDOUS SUBSTANCES)

Complete Table 13 **is required** for all **external outfalls** as directed below. (Instructions, Pages 60-61)

Are there any pollutants listed in the instructions (pages 55-62) believed present in the discharge?

□ Yes ⊠ No

Are there pollutants listed in Item 1.c. of Technical Report 1.0 which are believed present in the discharge and have not been analytically quantified elsewhere in this application?

□ Yes ⊠ No

If **yes** to either Items a **or** b, complete Table 13 as instructed.

Table 13 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	CASRN	Sample 1 (µg/L)	Sample 2 (µg/L)	Sample 3 (µg/L)	Sample 4 (µg/L)	Analytical Method

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 3.0: LAND APPLICATION OF EFFILIENT

This worksheet **is required** for all applications for a permit to disposal of wastewater by land application (i.e., TLAP)).

Item 1. Type of Disposal System (Instructions, Page 69)

Check the box next to the type of land disposal requested by this application:

Irrigation	Subsurface application
Evaporation	Subsurface soils absorption
Evapotranspiration beds	Surface application
Drip irrigation system	Other, specify: Click to enter text.

Item 2. Land Application Area (Instructions, Page 69)

Land Application Area Information

Effluent Application (gallons/day)	Irrigation Acreage (acres)	Describe land use & indicate type(s) of crop(s)	Public Access? (Y/N)
7			
- S			
A =		=	

Item 3. Annual Cropping Plan (Instructions, Page 69)

Attach the required cropping plan that includes each of the following:

- Cool and warm season plant species
- Breakdown of acreage and percent of total acreage for each crop
- · Crop growing season
- Harvesting method/number of harvests
- Minimum/maximum harvest height
- Crop yield goals
- Soils map
- Nitrogen requirements per crop
- Additional fertilizer requirements
- Supplemental watering requirements
- Crop salt tolerances
- Justification for not removing existing vegetation to be irrigated

Attachment:

Item 4. Well and Map Information (Instructions, Page 70)

a.		eck eac GS map		equired inform	nation is shown and lab	eled on the attached				
	The exact boundaries of the land application area									
		On-si	te buildings							
		□ Waste-disposal or treatment facilities								
		☐ Effluent storage and tailwater control facilities								
		Buffe	r zones							
		All su	rface waters in the sta	te onsite and	within 500 feet of the pr	operty boundaries				
	□ bou	All wa ındarie		e of the dispo	sal site, wastewater pone	ds, or property				
		All sp	rings and seeps onsite	and within 50	00 feet of the property b	oundaries				
	Atta	achmer	nt: Click to enter text.							
	was nece	tewate essary	ross reference all water r ponds, or property b to include all of the wo information Table	oundaries in t	l on or within 500 feet of the following table. Attac	f the disposal site, th additional pages as				
W	Well ID Well Use Producing? Open, cased, capped, Proposed Best									
			+	Y/N/U	or plugged?	Management Practice				
				Y/N/U						
				Y/N/U						
			>	Y/N/U						
				Y/N/U						
				Y/N/U						
				Y/N/U						
	achr	nent: (Click to enter text.	Y/N/U						
Att	Grou	ındwat	P	lysimeters ar		Management Practice				
Att	Grou	ındwat ication	er monitoring wells or site or wastewater po	lysimeters ar	or plugged?	Management Practice				
Att	Grou appl If ye site i	indwat ication Yes s, prov map at neters,	ter monitoring wells or site or wastewater po No Nowide the existing/proportached for Item 4.a. Ac	lysimeters arends.	or plugged?	Management Practice and the land or lysimeters on the depth of the wells or				
Att c.	Grou appl If ye site i lysin mod	indwat ication Yes s, prov map at neters, ificatio	ter monitoring wells or a site or wastewater po No No Vide the existing/proportached for Item 4.a. Ac sampling schedule, ar	lysimeters arends.	or plugged? re/will be installed aroun of the monitoring wells of the information on the	Management Practice and the land or lysimeters on the depth of the wells or				

Item 5. Soil Map and Soil Information (Instructions, Page 71)

Check each box to confirm that the following information is attached:

- a.

 USDA NRCS Soil Survey Map depicting the area to be used for land application with the locations identified by fields and crops.
- b.

 Breakdown of acreage and percent of total acreage for each soil type.
- c. \square Copies of laboratory soil analyses. Attachment: Click to enter text.

Item 6. Effluent Monitoring Data (Instructions, Page 72)

a. Completion of Table 14 **is required** for all **renewal** and **major amendment** applications. Complete the table with monitoring data for the previous two years for all parameters regulated in the current permit. An additional table has been provided with blank headers for parameters regulated in the current permit which are not listed in Table 14.

Table 14 for Outfall No.: Click to enter text. Samples are (check one): □ Composite ☐ Grab Date Daily Avg BOD5 TSS Nitrogen Conductivity **Hydraulic** Total Flow (gpd) (mo/yr) (mg/L)(mg/L)(mmhos/cm) (mg/L)acres **Application rate** irrigated (acre-feet/month)

Date (mo/yr)	Daily Avg Flow (gpd)	BOD5 (mg/L)	TSS (mg/L)	Nitrogen (mg/L)	Conductivity (mmhos/cm)	Total acres irrigated	Hydraulic Application rate (acre-feet/month)

b. Use this table to provide effluent analysis for parameters regulated in the current permit which are not listed in Table 14.

Additional Parameter Effluent Analysis

Date (mo/yr)	,			
	^			
	= 11	122	200	
	1	ū		
2	-			
			=	
9	1			
			ja j	
			 <	
·	19	2		

c. Attach an explanation of all persistent excursions to permitted parameters and corrective actions taken. **Attachment:** <u>Click to enter text.</u>

Item 7. Pollutant Analysis (Instructions, Page 72)

- a. Provide the date range of all sampling events conducted to obtain the analytical data submitted with this application (e.g., 05/01/2018-05/30/2018): Click to enter text.
- b. \square Check the box to confirm all samples were collected no more than 12 months prior to the date of application submittal.
- c. Complete Tables 15 and 16.

Table 15 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	Sample 1 (mg/L)	Sample 2 (mg/L)	Sample 3 (mg/L)	Sample 4 (mg/L)
BOD (5-day)			24	
CBOD (5-day)	7.5		P 2	
Chemical oxygen demand				
Total organic carbon	3,123			
Dissolved oxygen				
Ammonia nitrogen				
Total suspended solids			N	
Nitrate nitrogen				
Total organic nitrogen				
Total phosphorus				
Oil and grease			_	
Total residual chlorine				
Total dissolved solids			7,00	
Sulfate				
Chloride			100	
Fluoride				
Total alkalinity (mg/L as CaCO3)				
Temperature (°F)				
pH (standard units)	*		1	

Table 16 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	Sample 1 (µg/L)	Sample 2 (µg/L)	Sample 3 (µg/L)	Sample 4 (µg/L)	MAL (μg/L)
Aluminum, total					2.5
Antimony, total					5
Arsenic, total					0.5
Barium, total					3

Pollutant	Sample 1 (µg/L)	Sample 2 (µg/L)	Sample 3 (µg/L)	Sample 4 (µg/L)	MAL (μg/L)
Beryllium, total					0.5
Cadmium, total					1
Chromium, total					3
Chromium, hexavalent					3
Chromium, trivalent					N/A
Copper, total		1			2
Cyanide, available					2/10
Lead, total					0.5
Mercury, total					0.005/0.0005
Nickel, total					2
Selenium, total					5
Silver, total					0.5
Thallium, total	a				0.5
Zinc, total					5.0

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 3.1: SURFACE LAND APPLICATION AND APPLICATION

This worksheet **is required** for all applications for a permit to disposal of wastewater by surface land application or evaporation.

Item 1. Edwards Aquifer (Instructions, Page 73)

- a. Is the facility subject to 30 TAC Chapter 213, Edwards Aquifer Rules?

 ☐ Yes ☑ No

 If no, proceed to Item 2. If yes, complete Items 1.b and 1.c.
 b. Check the box next to the subchapter applicable to the facility.

 ☐ 30 TAC Chapter 213, Subchapter A

 ☐ 30 TAC Chapter 213, Subchapter B
- c. If *30 TAC Chapter 213, Subchapter A* applies, attach **either**: 1) a Geologic Assessment (if conducted in accordance with *30 TAC § 213.5*) **or** 2) a report that contains the following:
 - A description of the surface geological units within the proposed land application site and wastewater pond area.
 - The location and extent of any sensitive recharge features in the land application site and wastewater pond area
 - A list of any proposed BMPs to protect the recharge features.

Attachment: Click to enter text.

Item 2. Surface Spray/Irrigation (Instructions, Page 73)

a. Provide the following information on the irrigation operations:

Area under irrigation (acres): Click to enter text.

Design application rate (acre-ft/acre/yr): Click to enter text.

Design application frequency (hours/day): Click to enter text.

Design application frequency (days/week): Click to enter text.

Design total nitrogen loading rate (lbs nitrogen/acre/year): Click to enter text.

Average slope of the application area (percent): Click to enter text.

Maximum slope of the application area (percent): Click to enter text.

Irrigation efficiency (percent): Click to enter text.

Effluent conductivity (mmhos/cm): Click to enter text.

Soil conductivity (mmhos/cm): Click to enter text.

Curve number: Click to enter text.

Describe the application method and equipment: Click to enter text.

b. Attach a detailed engineering report which includes a water balance, storage volume calculations, and a nitrogen balance. **Attachment:** <u>Click to enter text.</u>

Item 3. Evaporation Ponds (Instructions, Page 74)

- a. Daily average effluent flow into ponds: Click to enter text. gallons per day
- b. Attach a separate engineering report of evaporation calculations for average long-term and worst-case critical conditions. **Attachment:** Click to enter text.

Item 4. Evapotranspiration Beds (Instructions, Page 74)

a. Provide the following information on the evapotranspiration beds:

Number of beds: Click to enter text.

Area of bed(s) (acres): <u>Click to enter text.</u> Depth of bed(s) (feet): <u>Click to enter text.</u>

Void ratio of soil in the beds: Click to enter text.

Storage volume within the beds (include units): Click to enter text.

Description of any lining to protect groundwater: Click to enter text.

- b. Attach a certification by a licensed Texas professional engineer that the liner meets TCEQ requirements. **Attachment:** Click to enter text.
- c. Attach a separate engineering report with water balance, storage volume calculations, and description of the liner. **Attachment**: <u>Click to enter text.</u>

Item 5. Overland Flow (Instructions, Page 74)

a. Provide the following information on the overland flow:

Area used for application (acres): Click to enter text.

Slopes for application area (percent): Click to enter text.

Design application rate (gpm/foot of slope width): Click to enter text.

Slope length (feet): Click to enter text.

Design BOD5 loading rate (lbs BOD5/acre/day): Click to enter text.

Design application frequency (hours/day): Click to enter text.

Design application frequency (days/week): Click to enter text.

b. Attach a separate engineering report with the method of application and design requirements according to *30 TAC § 217.212*. **Attachment:** Click to enter text.

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 3.2: SUBSURFACE IRRIGATION (NON-DRIP)

This worksheet **is required** for all applications for a permit to disposal of wastewater by subsurface land application.

Check the box to confirm the Class V Injection Well Inventory/Authorization Form (Worksheet 9.0) has been submitted to the TCEQ UIC Permits Team as directed.

Item 1. Edwards Aquifer (Instructions, Page 75)

a. The subsurface system is/will be located on the Edwards Aquifer Recharge Zone, as mapped by TCEQ?

□ Yes ⊠ No

b. The subsurface system is/will be located on the Edwards Aquifer Transition Zone, as mapped by TCEQ?

□ Yes ⊠ No

If **yes** to Item 1.a **or** 1.b, the subsurface system may be prohibited by *30 TAC § 213.8*. Contact the Water Quality Assessment Section at (512) 239-4671 for a preapplication meeting.

Item 2. Subsurface Application (Instructions, Page 75)

- a. Check the box next to the type of subsurface land disposal system requested:
 - ☐ Conventional drainfield, beds, or trenches

□ Low pressure dosing

 \Box Other: <u>Click to enter text.</u>

b. Provide the following information on the irrigation operations:

Application area (acres): Click to enter text.

Area of drainfield (square feet): Click to enter text.

Application rate (gal/square ft/day): Click to enter text.

Depth to groundwater (feet): Click to enter text.

Area of trench (square feet): Click to enter text.

Dosing duration per area (hours): Click to enter text.

Number of beds: Click to enter text.

Dosing amount per area (inches/day): Click to enter text.

Soil infiltration rate (inches/hour): Click to enter text.

Storage volume (gallons): <u>Click to enter text.</u>

Area of bed(s) (square feet): Click to enter text.

Soil classification: Click to enter text.

c. Attach a separate engineering report using 30 TAC § 309.20, Subchapter C, Land Disposal of Sewage Effluent as guidance, excluding items b(3)(A) and b(3)(B). Include a description of the schedule of dosing basin rotation. Attachment: Click to enter text.

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 3.3: SUBSURFACE AREA DRIP DISPERSAL SYSTEMS

	his worksheet is required for all applications for a permit to dispose of wastewater using a absurface area drip dispersal system (SADDS).
	Check the box to confirm the Class V Injection Well Inventory/Authorization Form (Worksheet 9.0) has been submitted to the TCEQ UIC Permits Team as directed.
It	tem 1. Edwards Aquifer (Instructions, Page 76)
a.	The subsurface system is/will be located on the Edwards Aquifer Recharge Zone, as mapped by TCEQ?
	□ Yes □ No
b.	The subsurface system is/will be located on the Edwards Aquifer Transition Zone, as mapped by TCEQ?
	□ Yes □ No
	yes to Item 1.a or 1.b, the subsurface system may be prohibited by <i>30 TAC § 213.8</i> . Contact e Water Quality Assessment Section at (512) 239-4671 for a preapplication meeting.
It	em 2. Administrative Information (Instructions, Page 76)
a.	Provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the treatment facility: <u>Click to enter text.</u>
b.	The owner of the land where the WWTF is/will be located is the same as the owner of the WWTF.
	□ Yes □ No
	If no , provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the land where the WWTF is/will be located: <u>Click to enter text</u> .
c.	Provide the legal name of the owner of the SADDS: Click to enter text.
d.	The owner of the SADDS is the same as the owner of the WWTF or the site where the WWTF is/will be located.
	□ Yes □ No
	If no , identify the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in Item 1.c: <u>Click to enter text.</u>
e.	Provide the legal name of the owner of the land where the SADDS is located: <u>Click to enter text.</u>

f.	f. The owner of the land where the SADDS is/will be located is the same as owner of the WWTF, the site where the WWTF is located, or the owner of the SADDS.					
	□ Yes □ No					
	If no , provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in item 1.e: <u>Click to enter text.</u>					
I	tem 3. SADDS (Instructions, Page 77)					
a.	Check the box next to the type SADDS requested by this application:					
	☐ Subsurface drip/trickle irrigation					
	□ Surface drip irrigation					
	□ Other: <u>Click to enter text.</u>					
b.	Attach a description of the SADDS proposed/used by the facility (see instructions for guidance). Attachment: <u>Click to enter text.</u>					
c.	Provide the following information on the SADDS:					
	Application area (acres): Click to enter text.					
	Soil infiltration rate (inches/hour): Click to enter text.					
	Average slope of the application area: Click to enter text.					
	Maximum slope of the application area: Click to enter text.					
	Storage volume (gallons): <u>Click to enter text.</u>					
	Major soil series: <u>Click to enter text.</u>					
	Depth to groundwater (feet): <u>Click to enter text.</u>					
	Effluent conductivity (mmhos/cm): Click to enter text.					
d.	d. The facility is/will be located west of the boundary shown in 30 TAC § 222.83 and using a vegetative cover of non-native grasses over seeded with cool-season grasses.					
	□ Yes □ No					
	If yes , the facility may propose a hydraulic application rate up to, but not to exceed, $0.1 \text{gal/ft}^2/\text{day}$.					
e.	The facility is/will be located east of the boundary shown in <i>30 TAC § 222.83</i> or is the facility proposing any crop other than non-native grasses.					
	□ Yes □ No					
	If yes , the facility must use the formula in <i>30 TAC § 222.83</i> to calculate the maximum hydraulic application rate.					
f.	The facility has or plans to submit an alternative method to calculate the hydraulic application rate for approval by the ED.					
	□ Yes □ No					

If **yes**, provide the following information on the hydraulic application rates: • Hydraulic application rate (gal/square foot/day): Click to enter text. Nitrogen application rate (gal/square foot/day): <u>Click to enter text.</u> g. Provide the following dosing information: Number of doses per day: Click to enter text. Dosing duration per area (hours): Click to enter text. Rest period between doses (hours): Click to enter text. Dosing amount per area (inches/day): Click to enter text. Number of zones: Click to enter text. h. The system is/will be a surface drip irrigation system using existing native vegetation as a crop? Yes No If **yes**, attach the following information: A vegetation survey by a certified arborist describing the percent canopy cover and relative percentage of major overstory and understory plant species. Attachment: Click to enter text. Attach a separate engineering report using 30 TAC § 309.20, Subchapter C, Land Disposal of Sewage Effluent as guidance, excluding items b(3)(A) and b(3)(B). Include a description of the schedule of dosing basin rotation. Attachment: Click to enter text. Item 4. Required Plans (Instructions, Page 78) a. Attach a Soil Evaluation with all information required in 30 TAC § 222.73. Attachment: Click to enter text. b. Attach a Site Preparation Plan with all information required in 30 TAC § 222.75. Attachment: Click to enter text. c. Attach a Recharge Feature Plan with all information required in 30 TAC § 222.79. Attachment: Click to enter text. d. Provide soil sampling and testing with all information required in 30 TAC § 222.157. Attachment: Click to enter text.

Item 5. Flood and Run-On Protection (Instructions, Page 79)

a.	Is the existing/proposed SADDS located within the 100-year frequency flood level?
	□ Yes □ No
	Source: Click to enter text.
	If ves , describe how the site will be protected from inundation: Click to enter text.

b. Is the existing/proposed SADDS within a designated floodway?						
□ Yes □ No						
If yes , attach either the FEMA flood map or alternate information used to make this determination. Attachment: Click to enter text.						
Item 6. Surface Waters in The State (Instructions, Page 79)						
a. Attach a buffer map which shows the appropriate buffers on surface waters in the state, water wells, and springs/seeps. Attachment: <u>Click to enter text.</u>						
b. The facility has or plans to request a buffer variance from water wells or waters in the state?						
□ Yes □ No						
If yes , attach the additional information required in <i>30 TAC § 222.81(c)</i> . Attachment: Click to enter text.						

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 4.0: RECEIVING WATERS

This worksheet is required for all TPDES permit applications.

Item 1. Domestic Drinking Water Supply (Instructions, Page 80)

 a. There is a surface water intake for domestic drinking water supply located within 5 (five) miles downstream from the point/proposed point of discharge.)				
□ Yes ⊠ No					
If no , stop here and proceed to Item 2. If yes , provide the following information:					
1. The legal name of the owner of the drinking water supply intake: <u>Click to enter text.</u>					
2. The distance and direction from the outfall to the drinking water supply intake: <u>Click enter text.</u>	to				
b. Locate and identify the intake on the USGS 7.5-minute topographic map provided for Administrative Report 1.0.					
Check this box to confirm the above requested information is provided.					
Item 2. Discharge Into Tidally Influenced Waters (Instructions Page 80)	s,				
If the discharge is to tidally influenced waters, complete this section. Otherwise, proceed to Item 3.					
a. Width of the receiving water at the outfall: Click to enter text. feet					
b. Are there oyster reefs in the vicinity of the discharge?					
□ Yes □ No					
If yes , provide the distance and direction from the outfall(s) to the oyster reefs: <u>Click to enter text.</u>					
c. Are there sea grasses within the vicinity of the point of discharge?					
□ Yes □ No					
If yes , provide the distance and direction from the outfall(s) to the grasses: <u>Click to enter text.</u>					
Item 3. Classified Segment (Instructions, Page 80)					
The discharge is/will be directly into (or within 300 feet of) a classified segment.					
□ Yes ⊠ No					
If yes , stop here and do not complete Items 4 and 5 of this worksheet or Worksheet 4.1.					
If no , complete Items 4 and 5 and Worksheet 4.1 may be required.					

Item 4. Description of Immediate Receiving Waters (Instructions, Page 80)

a	Name of the immediate receiving waters: <u>Unnamed Tributary</u>						
b	. Check the appropriate description of the immediate receiving waters:						
		□ Lake or Pond					
	• Surface area (acres): <u>Click to enter text.</u>						
	 Average depth of the entire water body (feet): <u>Click to enter text.</u> 						
		•	Average depth of water body within a 500-foot radius of the discharge point (feet): Click to enter text.				
	\boxtimes	N	Man-Made Channel or Ditch				
		S	tream or Creek				
		F	reshwater Swamp or Marsh				
		T	idal Stream, Bayou, or Marsh				
		O	pen Bay				
		O	ther, specify:				
If Ite	Man ms	- М а 4.с	ade Channel or Ditch or Stream or Creek were selected above, provide responses to – 4.g below:				
c.	For existing discharges , check the description below that best characterizes the area upstream of the discharge.						
	For new discharges , check the description below that best characterizes the area downstream of the discharge.						
		\boxtimes	Intermittent (dry for at least one week during most years)				
		□ 6	Intermittent with Perennial Pools (enduring pools containing habitat to maintain equatic life uses)				
			Perennial (normally flowing)				
	Check the source(s) of the information used to characterize the area upstream (existing discharge) or downstream (new discharge):						
	1		USGS flow records				
		\boxtimes	personal observation				
	į		historical observation by adjacent landowner(s)				
]	19	other, specify: Click to enter text.				
d.	List	mst	e names of all perennial streams that join the receiving water within three miles tream of the discharge point: Unnamed tributary, Wright Branch, Bowles Creek (Segment				

d.

е	(e.g., natural or man-made dams, ponds, reservoirs, etc.).						
		□ Yes ⊠ No					
	If	yes , describe how: <u>Click to ent</u>	er text.				
f.	<u>en</u>	General observations of the water body during normal dry weather conditions: <u>Click to enter text.</u>					
	Da	ite and time of observation: <u>Cli</u>	ick to enter text.				
g.	Th	e water body was influenced b	y stormwater rund	off during observations.			
		□ Yes □ No					
	If y	yes, describe how: <u>Click to ent</u>	er text.				
It	en	o 5. General Characto Page 81)	eristics of W	ater Body (Instructions,			
200							
a.	Is t inf	the receiving water upstream of luenced by any of the followin	of the existing discl g (check all that ap	harge or proposed discharge site oply):			
		oil field activities		urban runoff			
		agricultural runoff		septic tanks			
		upstream discharges		other, specify: Click to enter text.			
b.	Use	es of water body observed or e	vidence of such us	es (check all that apply):			
		livestock watering		industrial water supply			
		non-contact recreation		irrigation withdrawal			
		domestic water supply		navigation			
		contact recreation		picnic/park activities			
		fishing		other, specify: Click to enter text.			
C.	Description which best describes the aesthetics of the receiving water and the surroundir area (check only one):						
	☐ Wilderness: outstanding natural beauty; usually wooded or un-pastured area: water clarity exceptional						
	\boxtimes	Natural Area: trees or native fields, pastures, dwellings); w		n; some development evident (from ored			
		Common Setting: not offensive turbid	ve, developed but ı	incluttered; water may be colored or			
		Offensive: stream does not en areas; water discolored	nhance aesthetics;	cluttered; highly developed; dumping			

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 4.1: WATERBODY PHYSICAL CHARACTERISTICS

The following information **is required** for new applications, EPA-designated Major facilities, and major amendment applications requesting to add an outfall if the receiving waters are perennial or intermittent with perennial pools (including impoundments) for a TDPES permit.

Complete the transects downstream of the existing or proposed discharges.

Item 1. Data Collection (Instructions, Page 82	ctions. Page 82)	(Instructi	Collection	. Data	Item 1
--	------------------	------------	------------	--------	--------

a.	Date of study: Click to enter text. Time of study: Click to enter text.
	Waterbody name: Click to enter text.
	General location: <u>Click to enter text.</u>
b.	Type of stream upstream of an existing discharge or downstream of a proposed discharge (check only one):
	\square perennial \square intermittent with perennial pools \square impoundment
c.	No. of defined stream bends:
	Well: <u>Click to enter text.</u> Moderately: <u>Click to enter text.</u> Poorly: <u>Click to enter text.</u>
d.	No. of riffles: <u>Click to enter text.</u>
e.	Evidence of flow fluctuations (check one):
	□ Minor □ Moderate □ Severe
f.	Provide the observed stream uses and where there is evidence of channel obstructions/modifications: <u>Click to enter text.</u>
g.	Complete the following table with information regarding the transect measurements.

Stream Transect Data

Transect Location	Habitat Type*	Water Surface Width (ft)	Stream Depths (ft)**					3
1						2 0		11
						×		
7								

riffle, run, glide, or pool

^{**} channel bed to water surface

Item 2. Summarize Measurements (Instructions, Page 83)

Provide the following information regarding the transect measurements:

Streambed slope of entire reach (from USGS map in ft. /ft.): Click to enter text.

Approximate drainage area above the most downstream transect from USGS map or county highway map (square miles): <u>Click to enter text.</u>

Length of stream evaluated (ft): Click to enter text.

Number of lateral transects made: Click to enter text.

Average stream width (ft): Click to enter text.

Average stream depth (ft): Click to enter text.

Average stream velocity (ft/sec): Click to enter text.

Instantaneous stream flow (ft³/sec): Click to enter text.

Indicate flow measurement method (VERY IMPORTANT - type of meter, floating chip timed

over a fixed distance, etc.): Click to enter text.

Flow fluctuations (i.e., minor, moderate, or severe): Click to enter text.

Size of pools (i.e., large, small, moderate, or none): Click to enter text.

Maximum pool depth (ft): Click to enter text.

Total number of stream bends: Click to enter text.

Number well defined: Click to enter text.

Number moderately defined: Click to enter text.

Number poorly defined: Click to enter text.

Total number of riffles: Click to enter text.

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 5.0: SEWAGE SLUDGE MANAGEMENT AND DISPOSAL

The following information **is required** for all TPDES permit applications that meet the conditions as outlined in Technical Report 1.0, Item 7.

Item 1. Sewage Sludge Solids Management Plan (Instructions, Page 84)

a	. Is	this	a new pe	rmit	application or an amendment permit application?		
			Yes		No		
b	. Do	oes o	r will the	faci	lity discharge in the Lake Houston watershed?		
			Yes	259 259	No		
If te	yes ext.	to e	ither Iten	1 1.a	or 1.b, attach a solids management plan. Attachment: Click to enter		
I	em	ı 2.	Sewa Page		Sludge Management and Disposal (Instructions		
a.	Ch per	eck t rmit	the box n (check al	ext t l tha	o the sludge disposal method(s) authorized under the facility's existing t apply).		
		Per	mitted la	ındfi	11		
		Ma	rketing a	nd d	istribution by the permittee, attach Form TCEQ-00551		
		Reg	gistered l	and	application site, attach Form TCEQ-00565		
		Pro	cessed by	y the	permittee, attach Form TCEQ-00744		
		Sur	face disp	osal	site (sludge monofill), attach Form TCEQ-00744		
		Tra	nsported	to a	nother WWTP		
		Ben	eficial la	nd a	oplication, attach Form TCEQ-10451		
		Inci	ineration,	atta	ch Form TCEQ-00744		
	dire	ed or ected licat	l. Failure	ection to su	n(s) made above, complete and attach the required TCEQ forms as abmit the required TCEQ form will result in delays in processing the		
	Atta	achn	nent: Clic	k to	enter text.		
o.	. Provide the following information for each disposal site:						
					lick to enter text.		
	TCE	Q Pe	rmit/Reg	istra	tion Number: <u>Click to enter text.</u>		
	Cou	nty v	where dis	posa	l site is located: <u>Click to enter text.</u>		

c.	Method of sewage sludge transportation:							
	\Box truck \Box train \Box pipe \Box other: Click to enter text.							
	TCEQ Hauler Registration Number: Click to enter text.							
d.	Sludge is transported as a:							
	\square liquid \square semi-liquid \square semi-solid \square solid							
e.	Purpose of land application: \square reclamation \square soil conditioning \square N/A							
f.	If sewage sludge is transported to another WWTP for treatment, attach a written statement or copy of contractual agreements confirming that the WWTP identified above will accept and be responsible for the sludge from this facility for the life of the permit (at least 5 years).							
	Attachment: Click to enter text.							
Ito	em 3. Authorization for Sewage Sludge Disposal (Instructions, Page 85)							
slu	this is a new or major amendment application which requests authorization of a new sewag adge disposal method, check the new sewage disposal method(s) requested for authorization teck all that apply):							
	☐ Marketing and distribution by the permittee, attach Form TCEQ-00551							
	☐ Processed by the permittee, attach Form TCEQ-00744							
	☐ Surface disposal site (sludge monofill), attach Form TCEQ-00744							
	Beneficial land application, attach Form TCEQ-10451							
	☐ Incineration, attach Form TCEQ-00744							
dir	Based on the selection(s) made above, complete and attach any required TCEQ forms, as directed. Failure to submit the required TCEQ form will result in delays in processing the application.							
	Attachment: Click to enter text.							
n t for det	Attachment: Click to enter text. NOTE: New authorization for beneficial land application, incineration, processing, or disposal in the TPDES permit or TLAP requires a major amendment to the permit. New authorization for composting may require a major amendment to the permit. See the instructions to letermine if a major amendment is required or if authorization for composting can be added through the renewal process.							

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following information **is required** for all applications for publicly-owned treatment works (POTWs).

For an explanation of the terms used in this worksheet, refer to the General Definitions on pages 4-12 and the Definitions Relating to Pretreatment on pages 13-14 of the Instructions.

Item 1. All POTWs (Instructions, Page 86)

a. Complete the following table with the number of each type of industrial users (IUs) that discharge to the POTW and the daily average flows from each.

Type of Industrial User	Number of Industrial Users	Daily Average Flow (gallons per day)				
CIU		000 C000 BM 4				
SIU - Non-categorical		_				
Other IU						
b. In the past three years, has the POTW experienced treatment plant interference? Yes □ No If yes , identify the date(s), duration, nature of interference, and probable cause(s) and possible source(s) of each interference event. Include the names of the IU(s) that may have caused the interference: Click to enter text.						
In the past three years, has the POTW experienced pass-through? ☐ Yes ☐ No If yes , identify the date(s), duration, pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass-through event. Include the names of the IU(s) that may have caused the pass-through: Click to enter text.						
d. Does the POTW have, or is it required to develop, an approved pretreatment program? Yes No If yes, answer all questions in Item 2 and skip Item 3. If no, skip Item 2 and answer all questions in Item 3 for each SIU and CIU.						
Item 2. POTWs With Approved Pretreatment Programs or Those Required To Develop A Pretreatment Program (Instructions, Page 86)						

according to 40 CFR § 403.18?

56

No

Yes

a. Have there been any substantial modifications to the POTW's approved pretreatment program that have not been submitted to the Approval Authority (TCEQ) for approval

	If yes , include an attachment which identifies all substantial modifications that have not been submitted to the TCEQ and the purpose of the modifications.								
	Attachment: Click to enter								
ł	b. Have there been any non-substantial modifications to the POTW's approved pretreatment program that have not been submitted to the Approval Authority (TCEQ)?								
	□ Yes □ No								
	If yes , include an attachment which identifies all non-substantial modifications that have not been submitted to the TCEQ and the purpose of the modification.								
	Attachment: Click to enter	text.							
	. List all parameters measure last three years:		n the POTW	's effluent mor	nitoring during the				
	ffluent Parameters Measured A	# 1000 -	1						
	Pollutant	Concentration	MAL	Units	Date				
_									
-									
-									
-		2							
L									
L									
	Attachment: Click to enter	text.							
d.	Has any SIU, CIU, or other II interference or pass-through	J caused or contrib n) at the POTW in tl	uted to any ne past thre	other problem e years?	as (excluding				
	□ Yes □ No								
	If yes , provide a description problems, and probable poll may have caused or contribu	utants. Include the uted to any of the p	name(s) of croblems: <u>Cl</u>	the SIU(s)/CIU ick to enter te	(s)/other IU(s) that xt.				
It	em 3. Significant In User Informa	dustrial User tion (Instruc	and Ca	tegorical iges 88-87	Industrial ')				
PC fo	TWs that do not have an app llowing information for each !	roved pretreatmen SIU and CIU:	t program a	re required to	provide the				
a.	Mr. or Ms.: Click to enter tex	t. First/Last Name:	Click to ent	er text.					
	Organization Name: Click to	enter text. SIC	Code: <u>Click</u>	to enter text.					
	Phone number: Click to enter	r text. Ema	il address:	Click to enter t	text.				
	Physical Address: Click to en	MINISTER AND CONTRACTOR		Code: Click to					
Attachment: Click to enter text.									

b. Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (e.g., process and non-process wastewater): <u>Click to enter text.</u>

Effluent Type		Discharge Day (gallons per day)	Discharge (Continuou	Frequency is, batch, or intermitten
Process Waster	vater	300		
Non-process W	astewater	, , , , , , , , , , , , , , , , , , , ,		
e. Pretreatment	t Standards	<		
1. Is the SIU instruction	or CIU subject ons?	to technology-based l	ocal limits as defii	ned in the application
□ Yes	□ No			
2. Is the SIU	subject to cate	gorical pretreatment s	standards?	
□ Yes	□ No			
Categorical P	retreatment Sta		bcategories in the	SIUs Subject To
IUs Subject to Ca Category in	Subcategory i	atment Standards in Subcategory in	Subcategory in	Cubactagowy
40 CFR	40 CFR	40 CFR	40 CFR	Subcategory in 40 CFR
		9		
	-			
	19			
				1
Has the SIU or through, odor	r CIU caused or s, corrosion, bl	contributed to any pr ockages) at the POTW	oblem(s) (e.g., inte in the past three y	rferences, pass vears?
Has the SIU or through, odor	r CIU caused or rs, corrosion, bl	contributed to any pr ockages) at the POTW	oblem(s) (e.g., inte in the past three y	rferences, pass vears?

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 7.0: STORMWATER DISCHARGES ASSOCIATED WITH INDUSTRIAL ACTIVITIES

This worksheet **is required** for all TPDES permit applications requesting individual permit coverage for discharges consisting of **either**: 1) solely of stormwater discharges associated with industrial activities, as defined in $40 \ CFR \ \S \ 122.26(b)(14)(i-xi)$, **or** 2) stormwater discharges associated with industrial activities and any of the listed allowable non-stormwater discharges, as defined in the MSGP (TXR05000), Part II, Section A, Item 6.

Discharges of stormwater as defined in 40 CFR § 122.26 (b)(13) are not required to obtain authorization under a TPDES permit (see exceptions at 40 CFR §§ 122.26(a)(1) and (9)). Authorization for discharge may be required from a local municipal separate storm sewer system.

Item 1. Applicability (Instructions, Page 89)

Do discharges from any of the existing/proposed outfalls consist either 1) solely of stormwater discharges associated with industrial activities **or** 2) stormwater discharges associated with industrial activities and any of the allowable non-stormwater discharges?

□ Yes ⊠ No

If **no**, stop here. If **yes**, proceed as directed.

Item 2. Stormwater Coverage (Instructions, Page 89)

List each existing/proposed stormwater outfall at the facility and indicate which type of authorization covers or is proposed to cover discharges.

Authorization Coverage

Outfall	Authorization under MSGP	Authorized Under Individual Permit

If **all** existing/proposed outfalls which discharge stormwater associated with industrial activities (and any of the allowable non-stormwater discharges) are **authorized under the MSGP**, **stop** here.

If **seeking authorization** for any outfalls which discharge stormwater associated with industrial activities (and any of the allowable non-stormwater discharges) **under an individual permit**, **proceed**.

NOTE: The following information is required for each existing/proposed stormwater outfall for which the facility is seeking individual permit authorization under this application

Item 3. Site Map (Instructions, Page 90)

Attach a site map or maps (drawn to scale) of the entire facility with the following information.

- the location of each stormwater outfall to be covered by the permit
- an outline of the drainage area that is within the facility's boundary and that contributes stormwater to each outfall to be covered by the permit
- · connections or discharge points to municipal separate storm sewer systems
- locations of all structures (e.g. buildings, garages, storage tanks)
- structural control devices that are designed to reduce pollution in discharges of stormwater associated with industrial activities
- process wastewater treatment units (including ponds)
- bag house and other air treatment units exposed to stormwater (stormwater runoff, snow melt runoff, and surface runoff and drainage)
- landfills; scrapyards; surface water bodies (including wetlands)
- vehicle and equipment maintenance areas
- physical features of the site that may influence discharges of stormwater associated with industrial activities or contribute a dry weather flow
- locations where spills or leaks of reportable quality (as defined in 30 TAC § 327.4) have occurred during the three years before this application was submitted to obtain coverage under an individual permit
- processing areas, storage areas, material loading/unloading areas, and other locations
 where significant materials are exposed to stormwater (stormwater runoff, snow melt
 runoff, and surface runoff and drainage)

22	Check the box to confirm all above information was provided on the facility site map(s)
	Attachment: Click to enter text.

Item 4. Facility/Site Information (Instructions, Page 90)

a. Provide the area of impervious surface and the total area drained by each stormwater outfall requested for authorization by this permit application.

Impervious Surfaces

Outfall	Area of Impervious Surface (include units)	Total Area Drained (include units)	

b. Provide the following local area rainfall information and the source of the information.

Wettest month: Click to enter text.

Average rainfall for wettest month (total inches): Click to enter text.

25-year, 24-hour rainfall (inches): Click to enter text.

Source: Click to enter text.

- c. Attach an inventory, or list, of materials currently handled at the facility that may be exposed to precipitation. **Attachment:** <u>Click to enter text.</u>
- d. Attach narrative descriptions of the industrial processes and activities involving the materials in the above-listed inventory that occur outdoors or in some manner that may result in exposure of the materials to precipitation or runoff (see instructions for guidance). **Attachment:** Click to enter text.
- e. Describe any BMPs and controls the facility uses/proposes to prevent or effectively reduce pollution in stormwater discharges from the facility: <u>Click to enter text.</u>

Item 5. Pollutant Analysis (Instructions, Page 91)

- a. Provide the date range of all sampling events conducted to obtain the analytical data submitted with this application (e.g., 05/01/2018-05/30/2018): Click to enter text.
- b. \square Check the box to confirm all samples were collected no more than 12 months prior to the date of application submittal.
- c. Complete Table 17 as directed on page 92 of the Instructions.

Table 17 for Outfall No.: Click to enter text.

Pollutant	Grab Sample* Maximum (mg/L)	Composite Sample** Maximum (mg/L)	Grab Sample* Average (mg/L)	Composite Sample** Average (mg/L)	Number of Storm Events Sampled	MAL (mg/L)
pH (standard units)	(max)	_	(min)	-		s
Total suspended solids						_
Chemical oxygen demand					· ·	-
Total organic carbon		2				_
Oil and grease						= 1
Arsenic, total						0.0005
Barium, total						0.003
Cadmium, total						0.001
Chromium, total						0.003
Chromium, trivalent		2-11				_
Chromium, hexavalent						0.003
Copper, total						0.002

Pollutant	Grab Sample* Maximum (mg/L)	Composite Sample** Maximum (mg/L)	Grab Sample* Average (mg/L)	Composite Sample** Average (mg/L)	Number of Storm Events Sampled	MAL (mg/L)
Lead, total						0.0005
Mercury, total						0.000005
Nickel, total						0.002
Selenium, total						0.005
Silver, total						0.0005
Zinc, total						0.005

^{*} Taken during first 30 minutes of storm event

d. Complete Table 18 as directed on pages 92-94 of the Instructions.

Table 18 for Outfall No.: Click to enter text.

Grab Sample* Maximum (mg/L)	Composite Sample** Maximum (mg/L)	Grab Sample* Average (mg/L)	Composite Sample** Average (mg/L)	Number of Storm Events Sampled
		5		

		10		321
1				
12				÷a .
		-		
		-		
	Maximum	Sample* Sample** Maximum Maximum	Sample* Sample** Sample* Maximum Maximum Average	Maximum Maximum Average Average

^{*} Taken during first 30 minutes of storm event

Attachment: Click to enter text.

^{**} Flow-weighted composite sample

^{**} Flow-weighted composite sample

Item 6. Storm Event Data (Instructions, Page 93)

Provide the following data for the storm event(s) which resulted in the maximum values for the analytical data submitted:

Date of storm event: Click to enter text.

Duration of storm event (minutes): Click to enter text.

Total rainfall during storm event (inches): Click to enter text.

Number of hours the between beginning of the storm measured and the end of the previous measurable storm event (hours): Click to enter text.

Maximum flow rate during rain event (gallons/minute): Click to enter text.

Total stormwater flow from rain event (gallons): Click to enter text.

Provide a description of the method of flow measurement or estimate:

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 8.0: AQUACULTURE

This worksheet **is required** for all TPDES permit applications requesting individual permit coverage for discharges of aquaculture wastewater.

Item 1. Facility/Site Information (Instructions, Page 94)

a. Complete the following table with information regarding production ponds, raceways, and fabricated tanks at the facility.

Production Pond Descriptions

Number of Ponds	Dimensions (include units)	Area of Each Pond (include units)	Number of Ponds x Area of Ponds (include Units)
0			

Total surface area of all ponds: Click to enter text.

Raceway Descriptions

Number of Raceways	Dimensions (include units)
0	
	*

Fabricated Tank Descriptions

Dimensions (include units)
/

b.					
	□ Yes ⊠ N	lo .			
	If yes, attach a copy of	the approved plar	1.		
	Attachment: Click to e	nter text.			
c.	Does the facility have a	an aquatic plant tra	ensplant authoriza	tion?	
	□ Yes ⊠ N	lo			
	If yes, attach a copy of	the authorization	letter.		
	Attachment: Click to e	nter text.			
d.	Provide the number of enter text.	aquaculture faciliti	ies located within 2	25-miles of this fa	cility: <u>Click to</u>
Ite	em 2. Species Id	entification	(Instructions	s, Page 95)	
Co:	mplete the following tak the stock. Identify and a horize the species.	ole regarding each	species raised, sou	rce, origin, and di	sease status permits that
Sto	ck Species Information				
Sp	oecies	Source of Stock	Origin of Stock	Disease Status	Authorizations
				e e	
	-				
3	Attachment: Click to en	ter text.			
170-1710/02	CONTROL OF A STATE OF THE PARTY				

Item 3. Stock Management Plan (Instructions, Page 95)

Attach a detailed stock management plan: Click to enter text.

Item 4. Water Treatment and Discharge Description (Instructions, Page 96)

Attach a detailed description of the discharge practices and water treatment process(es): <u>Click</u> to enter text.

Item 5. Solid Waste Management (Instructions, Page 96)

Attach a description of the solid waste-disposal practices: Click to enter text.

Item 6. Site Assessment Report (Instructions, Page 96)

All new and expanding commercial shrimp facilities located/to be located within the coastal zone must attach a detailed site assessment report which identifies sensitive aquatic habitats within the coastal zone: Click to enter text.

WORKSHEET 9.0

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

CLASS V INJECTION WELL INVENTORY/AUTHORIZATION FORM

Submit the completed form to:

TCEQ

IUC Permits Team

Radioactive Materials Division

MC-233

PO Box 13087

Austin, Texas 78711-3087

512-239-6466

For TCEQ Use Only
Reg. No.____
Date Received____
Date Authorized____

Item 1. General Information (Instructions Page 99)

1. TCEQ Program Area

Program Area (PST, VCP, IHW, etc.): Click to enter text.

Program ID: Click to enter text.

Contact Name: Click to enter text.

Phone Number: Click to enter text.

2. Agent/Consultant Contact Information

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

3. Owner/Operator Contact Information

□ Owner □ Operator

Owner/Operator Name: Click to enter text.

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

4. Facility Contact Information

Facility Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Location description (if no address is available): Click to enter text.

Facility Contact Person: Click to enter text.

Phone Number: Click to enter text.

5.	Latitude and Longitude, in degrees-minutes-seconds							
	Latitu	de: <u>Clic</u>	k to enter te	xt.				
	Longit	ude: <u>Cl</u>	ick to enter	text.				
	Metho	d of de	termination	(GPS, TOPO, etc.): Click to enter	text.			
6.	Well I	nforma	tion					
	Type o	of Well (Construction	ı, select one:				
		□ Ve	rtical Injecti	on				
		□ Su	bsurface Flu	id Distribution System				
		□ Inf	iltration Gal	lery				
		□ Te	mporary Inj	ection Points				
		□ Ot	her, Specify:	Click to enter text.				
	Numbe	er of Inj	ection Wells	: Click to enter text.				
7.	Purpos	se						
			ription regar	ding purpose of Injection System	n:			
	Click	to ente	r text.					
			lap as Attac	hment B (Attach the Approved R	emediatio	n Plan, if		
j	approp	riate.)						
8.	Water 1	Well Dr	iller/Installe	er				
				r Name: <u>Click to enter text.</u>				
				Click to enter text.				
			: Click to en					
1	License Number: <u>Click to enter text.</u>							
Item	Item 2. Proposed Down Hole Design							
Attach a diagram signed and sealed by a licensed engineer as Attachment C.								
Down H	ole Des	ign Tab	le					
Name	of S	ize	Setting	Sacks Cement/Grout - Slurry	Hole	Weight (lbs/ft)		
String			Depth	Volume - Top of Center	Size	PVC/Steel		
Casing								
Tubing								
Dereell	8		I		l l			

Item 3. Proposed Trench System, Subsurface Fluid Distribution System, or Infiltration Gallery

Attach a diagram signed and sealed by a licensed engineer as Attachment D.

System(s) Dimensions: <u>Click to enter text.</u> System(s) Construction: <u>Click to enter text.</u>

Item 4. Site Hydrogeological and Injection Zone Data

- 1. Name of Contaminated Aquifer: Click to enter text.
- 2. Receiving Formation Name of Injection Zone: Click to enter text.
- 3. Well/Trench Total Depth: Click to enter text.
- 4. Surface Elevation: Click to enter text.
- 5. Depth to Ground Water: Click to enter text.
- 6. Injection Zone Depth: <u>Click to enter text.</u>
- 7. Injection Zone vertically isolated geologically? ☐ Yes ☐ No Impervious Strata between Injection Zone and nearest Underground Source of Drinking Water:

Name: <u>Click to enter text.</u>
Thickness: Click to enter text.

- 8. Attach a list of contaminants and the levels (ppm) in contaminated aquifer as Attachment E.
- 9. Attach the Horizontal and Vertical extent of contamination and injection plume as Attachment F.
- 10. Attach Formation (Injection Zone) Water Chemistry (Background levels) TDS, etc., as Attachment G.
- 11. Injection Fluid Chemistry in PPM at point of injection. Attach as Attachment H.
- 12. Lowest Known Depth of Ground Water with < 10,000 PPM TDS: Click to enter text.
- 13. Maximum injection Rate/Volume/Pressure: Click to enter text.
- 14. Water wells within 1/4 mile radius (attach map as Attachment I): Click to enter text.
- 15. Injection wells within 1/4 mile radius (attach map as Attachment J): Click to enter text.
- 16. Monitor wells within 1/4 mile radius (attach drillers logs and map as Attachment K): Click to enter text.
- 17. Sampling frequency: Click to enter text.
- 18. Known hazardous components in injection fluid: Click to enter text.

Item 5. Site History

- 1. Type of Facility: Click to enter text.
- 2. Contamination Dates: Click to enter text.
- 3. Original Contamination (VOCs, TPH, BTEX, etc.) and Concentrations. Attach as Attachment L.
- 4. Previous Remediation. Attach results of any previous remediation as Attachment M.

NOTE: Authorization Form should be completed in detail and authorization given by the TCEQ before construction, operation, and/or conversion can begin. Attach additional pages as necessary.

Item 6. CLASS V INJECTION WELL DESIGNATIONS

- 5A07 Heat Pump/AC return (IW used for groundwater to heat or cool buildings)
- 5A19 Industrial Cooling Water Return Flow (IW used to cool industrial process equipment)
- 5B22 Salt Water Intrusion Barrier (IW used to inject fluids to prevent the intrusion of salt water into an aquifer)
- 5D02 Stormwater Drainage (IW designed for the disposal of rain water)
- 5D04 Industrial Stormwater Drainage Wells (IW designed for the disposal of rain water associated with industrial facilities)
- 5F01 Agricultural Drainage (IW that receive agricultural runoff)
- 5R21 Aquifer Recharge (IW used to inject fluids to recharge an aquifer)
- 5S23 Subsidence Control Wells (IW used to control land subsidence caused by groundwater withdrawal)
- 5W09 Untreated Sewage
- 5W10 Large Capacity Cesspools (Cesspools that are designed for 5,000 gpd or greater)
- 5W11 Large Capacity Septic systems (Septic systems designed for 5,000 gpd or greater)
- 5W12 WTTP disposal
- 5W20 Industrial Process Waste-disposal Wells
- 5W31 Septic System (Well Disposal method)
- 5W32 Septic System Drainfield Disposal
- 5X13 Mine Backfill (IW used to control subsidence, dispose of mining byproducts, or fill sections of a mine)
- 5X25 Experimental Wells (Pilot Test) (IW used to test new technologies or tracer dye studies)
- 5X26 Aquifer Remediation (IW used to clean up, treat, or prevent contamination of a USDW)
- 5X27 Other Wells
- 5X28 Motor Vehicle Waste-disposal Wells (IW used to dispose of waste from a motor vehicle site These are currently banned)
- 5X29 Abandoned Drinking Water Wells (waste disposal)

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 10.0: QUARRIES IN THE JOHN GRAVES SCENIC RIVERWAY

This worksheet **is required** for all applications for individual permits for a municipal solid waste facility or mining facility located within a Water Quality Protection Area in the John Graves Scenic Riverway. **Note: Review 30 TAC §§ 311.71-311.82 thoroughly prior to completing any portion of this worksheet.**

I	tem	1.	Ex	clus	ions (l	nstruction	ons	,	Page 10())				
a.	. Is th	is a r	nuni	cipal s	solid waste	e facility?								
	ESS.	Yes		No										
b.	. Has mor	this o	quarı n 30	y bee: conse	n in opera cutive day	tion since Ja 's and under	nuar the	ry sa	1, 1994 with me ownersh	out ces ip?	satior	ı of ope	eration fo	or
		Yes		No										
c.	Is th	is a c	oal n	nine?										
		Yes		No										
d.	Is th	is fac	ility	minin	g clay and	or shale fo	r use	e ir	n manufactu	ring st	ructur	al clay	products	?
		Yes		No										
If ou	yes to	any l in 3	abov 0 TA	e que C§3	stion, sto r 11.72(c), a	here . The fit the facility	facili ⁄ to d	ty ler	is required t monstrate th	to mair e exclu	ıtain d ısion(s	locume s).	ntation, a	as
It	em	2. I	OCa	itioi	of the	Quarry	(Ir	18	struction	s, Pa	ge 1	01)		
Cł	neck tl	ne bo	x nex	t to t	he distanc	e between tl	ne qu	ıar	rry and the n	earest	naviga	able wa	ter body:	:
		< 200	feet		200 feet	- 1,500 feet		1	1,500 feet - 1	l mile		> 1 m	ile	
pr	ohibit	ed w	ithin	200 f	n or operat eet of any Riverway.	tion of any n water body	iew q locat	aua tec	arry or expar d within a Wa	nsion o ater Qu	f any (Iality F	existing Protecti	g quarry i on Area i	is in
It	em 3	3. A	dd	itioı	nal Reg	uiremer	nts	(I	nstruction	ons,	Page	e 101)	
the	e the e facili propri	ity ba	sed o	on dis	tance betv	o determine veen the qua	if ad irry a	ldi and	itional applic d the neares	cation r t water	equire way. A	ements Attach a	apply to	
a.	Attac	h a R	esto	ation	Plan: Clicl	k to enter te	xt.							
b.	Amou	int o	f Fina	ıncial	Assurance	e for Restora	ation:	: \$	Click to ent	er text				
	Mech	anisn	n: <u>Cli</u>	ck to	enter text.									
C.	Attac	h a T	echn	ical D	emonstrat	ion: <u>Click to</u>	ente	er	text.					
d.	Attac	h a R	eclar	nation	ı Plan: <u>Clic</u>	k to enter te	ext.							
e.	Amou	ınt ol	Fina	ncial	Assurance	for Reclam	ation	1: 5	\$ Click to en	ter text	<u>.</u>			
	Mech	anisn	n: Cli	ck to	enter text.									

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 11.0: COOLING WATER SYSTEM INFORMATION

This worksheet is required for all TPDES permit applications that meet the conditions outlined in Technical Report 1.0, Item 12.

Item 1. Cooling Water System Data (Instructions, Page 104)

a. Complete the following table with information regarding the cooling water system.

Cooling Water System Data

Parameter	Volume (include units)
Total DIF	
Total AIF	
Intake Flow Use(s) (%)	
Contact cooling	
Non-contact cooling	
Process Wastewater	
Other	

b. Attach the following information:

- 1. A narrative description of the design and annual operation of the facility's cooling water system and its relationship to the CWIS(s).
- 2. A scaled map depicting the location of each CWIS, impoundment, intake pipe, and canals, pipes, or waterways used to convey cooling water to, or within, the cooling water system. Provide the latitude and longitude for each CWIS and any intake pipe(s) on the map. Indicate the position of the intake pipe within the water column.
- 3. A description of water reuse activities, if applicable, reductions in total water withdrawals, if applicable, and the proportion of the source waterbody withdrawn (on a monthly basis).
- 4. Design and engineering calculations prepared by a qualified professional and data to support the information provided in above item a.
- 5. Previous year (a minimum of 12 months) of AIF data.
- 6. A narrative description of existing or proposed impingement and entrainment technologies or operation measures and a summary of their performance, including, but not limited to, reductions in impingement mortality and entrainment due to intake location and reductions in total water withdrawals and usage.

Attachment: Click to enter text.

Item 2. Cooling Water Intake Structure(s) Data (Instructions, Page 105)

a. Complete the following table with information regarding each cooling water intake structure (this includes primary and make-up CWIS(s)).

Cooling Water Intake Structure(s) Data

CWIS ID		-
DIF (include units)		
AIF (include units)		
Intake Flow Use(s) (%)		
Contact cooling		
Non-contact cooling		
Process Wastewater		
Other		-
Latitude (decimal degrees)		-
Longitude (decimal degrees)		

- b. Attach the following information regarding the CWIS(s):
 - 1. A narrative description of the configuration of each CWIS, annual and daily operation, including any seasonal changes, and where it is located in the water body and in the water column.
 - 2. Engineering calculations for each CWIS.

Attachment: Click to enter text.

Item 3. Source Water Physical Data (Instructions, Page 105)

a. Complete the following table with information regarding the CWIS(s) source waterbody (this includes primary and make-up CWIS(s)).

Source Waterbody Data

CWIS ID	
Source Waterbody	
Mean Annual Flow	
Source	~

- b. Attach the following information regarding the source waterbody.
 - 1. A narrative description of the source water for each CWIS, including areal dimensions, depths, salinity and temperature regimes, and other documentation that supports this determination of the water body type where each cooling water intake structure is located.

- 2. A narrative description of the source waterbody's hydrological and geomorphological features.
- 3. Scaled drawings showing the physical configuration of all source water bodies used by the facility, including the source waterbody's hydrological and geomorphological features. NOTE: The source waterbody's hydrological and geomorphological features may be included on the map submitted for item 1.b.ii of this worksheet.
- 4. A description of the methods used to conduct any physical studies to determine the intake's area of influence within the waterbody and the results of such studies.

Attachment: Click to enter text.

IT	er	n 4. Operational Status (Instructions, Page 106)
a.	Is	this application for a power production or steam generation facility? \Box Yes \Box No
	If	no , proceed to Item 4.b. If yes , provide the following information as an attachment:
	1.	Describe the operating status of each individual unit, including age, capacity utilization rate (or equivalent) for the previous five years (a minimum of 60 months), and any seasonal changes in operation.
	2.	Describe any extended or unusual outages or other factors which significantly affect current data for flow, impingement, entrainment.
	3.	Identify any operating unit with a capacity utilization rate of less than 8 percent averaged over a contiguous period of two years (a minimum of 24 months).
	4.	Describe any major upgrades completed within the last 15 years, including but not limited to boiler replacement, condenser replacement, turbine replacement, or changes of fuel type.
	At	tachment: Click to enter text.
b.	Pro	ocess Units
	1.	Is this application for a facility which has process units that use cooling water (other than for power production or steam generation)?
		□ Yes □ No
		If no , proceed to Item 4.c. If yes , continue.
	2.	Does the facility use or intend to use reductions in flow or changes in operations to meet the requirements of $40\ CFR\ \S\ 125.94(c)$?
		□ Yes □ No
		If no , proceed to Item 4.c. If yes , attach descriptions of the following information:
		Individual production processes and product lines
		• The operating status, including age of each line and seasonal operation
		 Any extended or unusual outages that significantly affect current data for flow, impingement, entrainment, or other factors

Attachment: Click to enter text. c. Is this an application for a nuclear power production facility? Yes No If no, proceed to Item 4.d. If yes, attach a description of completed, approved, or scheduled upgrades and the Nuclear Regulatory Commission relicensing status for each unit at the facility. Attachment: Click to enter text. d. Is this an application for a manufacturing facility? Yes No If no, proceed to Worksheet 11.1. If yes, attach descriptions of current and future production schedules and any plans or schedules for any new units planned within the next five years (a minimum of 60 mos) Attachment: Click to enter text.

product lines.

Any major upgrades completed within the last 15 years and plans or schedules for decommissioning or replacement of process units or production processes and

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 11.1: IMPINGEMENT MORTALITY

This worksheet **is required** for all TPDES permit applications **that meet the conditions outlined in Technical Report 1.0, Item 12.** Complete one copy of this worksheet for **each** individual CWIS the facility uses or proposes to use.

CWIS ID: Click to enter text.

Item 1. Impingement Compliance Technology Selection (Instructions, Page 107)

Ch se	lec	k the box next to the method of compliance for the Impingement Mortality Standard ted by the facility.	
	C	Closed-cycle recirculating system(CCRS) [$40\ CFR\ \S\ 125.94(c)(1)$] 0.5 ft/s Through-Screen Design Velocity [$40\ CFR\ \S\ 125.94(c)(2)$] - Proceed to Worksheet 11.2	
	E N S In D L 0.5	2.5 ft/s Through Screen Actual Velocity [40 CFR § 125.94(c)(3)] Existing offshore velocity cap [40 CFR § 125.94(c)(4)] – Proceed to Worksheet 11.2 Modified traveling screens [40 CFR § 125.94(c)(5)] ystem of technologies [40 CFR § 125.94(c)(6)] mpingement mortality performance standard [40 CFR § 125.94(c)(7)] De minimis rate of impingement [40 CFR § 125.94(c)(11)] ow capacity utilization power-generation facilities [40 CFR § 125.94(c)(12)] ft/s Through-Screen Design Velocity [40 CFR § 125.94(c)(2)] or existing offshore velocity [40 CFR § 125.94(c)(4)] was selected, proceed to Worksheet 11.2. Otherwise, continue to 2.	ty
Ite	en	1 2. Impingement Compliance Technology Information (Instructions, Page 107)	Charles Control
Coı	np	lete the following sections based on the selection made for item 1 above.	
a.	CC	RS [40 CFR § 125.94(c)(1)]	
		Check this box to confirm the CWS meets the definition of CCRS located at 40 CFR § $125.91(c)$ and provide a response to the following questions.	
	1.	Does the facility use or propose to use a CWIS to replenish water losses to the CWS? \Box Yes \Box No	
		If no , proceed to item a.2. If yes , provide the following information as an attachment and continue.	
		• CWIS ID	
		• 12 months of intake flow data for any CWIS used for make-up intake flows to replenish cooling water losses, excluding intakes for losses due to blowdown, drift,	

or evaporation.

• A narrative description of any physical or operational measures taken to minimize make-up withdraws.

Attachment: Click to enter text.

NOTE: Do not complete a separate Worksheet 11.1 for a make-up CWIS.

- 2. Does the facility use or propose to use cooling towers?
 - □ Yes □ No

If **no**, proceed to Worksheet 11.2. If **yes**, provide the following information and proceed to Worksheet 11.2.

• Average number of cycles of concentration (COCs) prior to blowdown:

Average COCs Prior to Blowdown

Cooling Tower ID			
COCs	ii ii		

- Attach COC monitoring data for each cooling tower from the previous year (a minimum of 12 months): Click to enter text.
- Maximum number of COCs each cooling tower can accomplish based on design of the system.

Calculated COCs Prior to Blowdown

Cooling Tower ID		4
COCs	 928	

- Describe conditions that may limit the number of COCs prior to blowdown, if any, including but not limited to permit conditions: <u>Click to enter text.</u>
- b. 0.5 ft/s Through Screen Actual Velocity [40 CFR § 125.94(c)(3)]

Provide daily intake flow measurement monitoring data from the previous year (a minimum of 12 months) as an attachment and proceed to Worksheet 11.2.

Attachment: Click to enter text.

c. Modified traveling screens [40 CFR § 125.94(c)(5)]

Provide the following information as an attachment and proceed to Worksheet 11.2.

- 1. A description of the modified traveling screens and associated equipment.
- 2. A site-specific impingement technology performance optimization study that includes a narrative description of the biological data collection methods.
- 3. Biological sampling data from the previous two years (a minimum of 24 months).

Attachment: Click to enter text.

d. System of technologies [$40 \ CFR \ \S \ 125.94(c)(6)$] or impingement mortality performance standard [$40 \ CFR \ \S \ 125.94(c)(7)$]

Provide the following information as an attachment and proceed to Worksheet 11.2.

1. A description of the system of technologies used or proposed for use by the facility to

achieve compliance with the impingement mortality standard.

- 2. A site-specific impingement technology performance optimization study that includes a narrative description of the biological data collection methods.
- 3. Biological sampling data from the previous two years (a minimum of 24 months).

Attachment: Click to enter text.

- e. De minimis rate of impingement [40 CFR § 125.94(c)(11)] Provide the following information and proceed to Worksheet 11.2.
 - 1. Attach monitoring data from the previous year (a minimum of 12 months) of intake flow measured at a frequency of 1/day on days of operation.

Attachment: Click to enter text.

2. If the rate of impingement caused by the CWIS is extremely low (at an organism or ageone equivalent count), attach supplemental information to Worksheet 11.0, item 1.b.6. to support this determination.

Attachment: Click to enter text.

f. Low capacity utilization power-generation facilities [40 CFR § 125.94(c)(12)] Attach monthly utilization data from the previous 2 years (a minimum of 24 months) for each operating unit and proceed to Worksheet 11.2.

Attachment: Click to enter text.

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 11.2: SOURCE WATER BIOLOGICAL DATA

This worksheet **is required** for all TPDES permit applications that **meet the conditions outlined in Technical Report 1.0, Item 12.** Complete one copy of this worksheet for **each** source waterbody of a CWIS for which a facility has selected an Impingement Mortality Technology Option described at $40 \ CFR \ \SS \ 125.94(c)(1)-(7)$.

Name of source waterbody: Click to enter text.

Item 1. Species Management (Instructions, Page 109)

a.	The facility has obtained an incidental take permit for its cooling water intake structure(s) from the USFWS or the NMFS.
	□ Yes □ No
	If yes, attach any information submitted in order to obtain that permit, which may be used to supplement the permit application information requirements of paragraph $40\ CFR\ \S$ $125.95(f)$.
	Attachment: Click to enter text.
b.	Is the facility requesting a waiver from application requirements at $40 \ CFR \ \S \ 122.21(r)(4)$ in accordance with $40 \ CFR \ \S \ 125.95$ for any CWIS(s) that withdraw from a man-made reservoir that is stocked and managed by a state or federal natural resources agency or the equivalent?
	□ Yes □ No
	If yes, attach a copy of the most recent managed fisheries report to TPWD, or equivalent.
	Attachment: Click to enter text.
c.	There are no federally listed threatened or endangered species or critical habitat designations within the source water body.
	□ True □ False
Ite	em 2. Source Water Biological Data (Instructions, Page 109)
	w Facilities (Phase I, Track I and II)
	 Provide responses to all items in this section and stop.
Exi	sting Facilities (Phase II)
	• If the answer to 1.b. above was no , provide responses to all items in this section and proceed to Worksheet 11.3.

If the answer to 1.b. was yes and 1.c. was true, do not complete any items in this

If the answer to **1.b.** was **yes** and **1.c.** was **false**, attach a response for any item in this section that is not contained within the most recent TPWD, or equivalent and proceed to

Attachment: Click to enter text.

Worksheet 11.3.

section and proceed to Worksheet 11.3.

- a. A list of the data requested at 40 CFR § 122.21(r)(4)(ii) through (vi) that are not available, and efforts made to identify sources of the data.
- b. Provide a list of species (or relevant taxa) in the vicinity of the CWIS and identify the following information regarding each species listed.
 - all life stages and their relative abundance,
 - identification of all species and life stages that would be most susceptible to impingement and entrainment,
 - forage base,
 - · significance to commercial fisheries,
 - · significance to recreational fisheries,
 - primary period of reproduction,
 - larval recruitment, and
 - period of peak abundance for relevant taxa.
- c. Data representative of the seasonal and daily activities (e.g., feeding and water column migration) of biological organisms in the vicinity of the CWIS(s).
- d. Identify all threatened, endangered, and other protected species that might be susceptible to impingement and entrainment at the CWIS(s).
- e. Documentation of any public participation or consultation with federal or state agencies undertaken.

The following is required for existing facilities only. Include the following information with the above listed attachment.

- f. Identify any protective measures and stabilization activities that have been implemented and provide a description of how these measures and activities affected the baseline water condition in the vicinity of the intake.
- g. A list of fragile species, as defined at 40 CFR § 125.92(m), at the facility. The applicant need only identify those species not already identified as fragile at 40 CFR § 125.92(m).

NOTE: New units at an existing facility are not required to resubmit this information if the cooling water withdrawals for the operation of the new unit are from an existing intake.

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 11.3: ENTRAINMENT

This worksheet **is required** for all TPDES permit applications that **meet the conditions outlined in Technical Report 1.0, Item 12**. Complete one copy of this worksheet for **each** individual CWIS the facility uses or proposes to use.

CWIS ID: Click to enter text.

Item 1. Applicability (Instructions, Page 111)

Is the AIF of the CWIS identified above greater than, or equal to, 125 MGD?

- □ Yes □ No
- If **no** or the facility has selected **CCRS** [40 CFR § 125.94(c)(1)] for the impingement mortality compliance method, complete Item 2 and stop here.
- If **yes** and the facility is **seeking a waiver** from application requirements in accordance with 40 CFR § 125.95 for any CWIS(s) that withdraw from a man-made reservoir that is stocked and managed by a state or federal natural resources agency or the equivalent, complete item 2 and stop.
- If **yes** and the facility is **not seeking a waiver** from application requirements in accordance *with 40 CFR § 125.95*, complete item 2 and provide any required and completed studies listed in item 3. For any required studies in item 3 that are not complete, provide a detailed explanation for the delay and an anticipated schedule for completion and submittal.

Item 2. Existing Entrainment Performance Studies (Instructions, Page 111)

Attach any previously conducted studies or studies obtained from other facilities addressing technology efficacy, through-facility entrainment survival, and other entrainment studies.

Attachment: Click to enter text.

Item 3. Facility Entrainment Performance Studies (Instructions, Page 111)

- a. Attach an entrainment characterization study, as described at 40 CFR § 122.21(r)(9): Click to enter text.
- b. Attach a comprehensive feasibility study, as described as 40 CFR § 122.21(r)(10): Click to enter text.
- c. Attach a benefits valuation study, as described as *40 CFR § 122.21(r)(11)*: Click to enter text.
- d. Attach a non-water quality environmental and other impacts study, as described as 40 CFR § 122.21(r)(12): Click to enter text.
- e. Attach a peer review analysis, as described as 40 CFR § 122.21(r)(13): Click to enter text.

INDUSTRIAL WASTEWATER PERMIT APPLICATION WORKSHEET 12.0: OIL AND GAS EXPLORATION, DEVELOPMENT, AND PRODUCTION WASTEWATER DISCHARGES

This worksheet **is required** for all TPDES permit applications that are subject to Effluent Limitation Guidelines in 40 CFR Part 435.

Item 1. Operational Information (Instructions, Page 112)

a.	Is the wastewater from an oil and gas exploration, development, or production facility located west of the 98th meridian?						
	□ Yes □ No						
	If yes, continue to the next Data.	t question. If no, skip to	Item 2 relating to Production/Process				
b.	 Provide justification for how the wastewater is/will be used for agriculture or wildlife propagation. 						
	Click to enter text.						
	1						
	*						
	T						
	em 2. Production/		structions, Page 112)				
	Click to enter text.	1					
	Describe if the permit being sought is for discharges from exploration, development, production, or for a combination of more than one of those activities.						
	Click to enter text.		э				

astestream	Reques to disc (Yes/N	sting authorization charge? Io)	Volume (MGD)	% of Total Flow
5.9				
Click to enter text.				
ø				
The state of the s				
Attachment: Click to e	nter text.			
Attachment: Click to expression on the control of t		arges.		

Attachment: Click to enter text.

f. List of chemicals that are in use, or will be used, downhole. Provide the category, concentration used/to be used, and purpose of using the chemical. Attach a safety data sheet for each chemical listed.

Chemicals List

Chemical Name	Concentration (include units)	Purpose
	Chemical Name	

Attachment: Click to enter text.

g. List of chemicals that are in use, or will be used, to treat the wastewater to be discharged under this authorization. Provide the concentration used/to be used and purpose of using the chemical. Attach a safety data sheet for each chemical listed.

Water Treatment Chemicals List

Category	Chemical Name	Concentration (include units)	Purpose
			V
7 0.5		12 12 12 12 12 12 12 12 12 12 12 12 12 1	
9			

Attachment: Click to enter text.

Item 3. Pollutant Analysis (Instructions, Page 113)

Tables 1, 2, 6, and 7 located in Worksheet 2.0 are required. In addition, Table 19 below is required and must be completed for each outfall and submitted with this application. The remaining tables in Worksheet 2.0, are required as applicable.

- a. Provide the date range of all sampling events conducted to obtain the analytical data submitted with this application (e.g., 05/01/2018-05/30/2018): Click to enter text.
- b. \Box Check the box to confirm all samples were collected no more than 12 months prior to the date of application submittal.
- c. Read the general testing requirements in the instructions for important information about sampling, test methods, and MALs. If a contact laboratory was used, attach a list which includes the name, contact information, and pollutants analyzed for each laboratory/firm. Attachment: Click to enter text.
- d. Attach correspondence from TCEQ approving submittal of less than the required number of samples, if applicable. **Attachment:** Click to enter text.

Table 19 for Outfall No.: Click to enter text. Samples are (check one): ☐ Composite ☐ Grab

Pollutant	Sample 1 (mg/L)*	Sample 2 (mg/L)*	Sample 3 (mg/L)*	Sample 4 (mg/L)*
Calcium				
Potassium				
Sodium			E . (0	

^{*}Indicate units if different from mg/L.

ATTACHMENT 1

CORE DATA FORM

(TCEQ 10400)

TCEQ Use Only



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

Renewal (Core Data Form should be submitted with the renewal form)				·m)		Other				
2. Customer F	Referen	ce Number (if issue	rd)	Control of the contro	is link to searc	-	Regulated Entity Reference Number (if issued)			
CN 6006752	CN 600675284				RN numbers i	-	101237063		P	
ECTION	N II:	Custome	r Infor	<u>matio</u>	<u>n</u>					
4. General Cu	stomer	Information	5. Effectiv	e Date for	Customer In	formatio	n Updates (mm/c	dd/yyyy)		
New Customer				nation	Cha	ange in Regulated I	Entity Owr	nership		
Change in Le	gal Nam	e (Verifiable with the	Texas Secretary	of State or T	Texas Comptro			Y (1996) Y (1996)	State Control (1994 € 10)	
The Customer	Name	submitted here mi	av he undated	automatic	ally hased o	n what is	current and acti	vo with t	he Texas Secretary of Stat	
		troller of Public Ac			uny suscu o	, while is	carrent and acti	ve with t	ne resus secretary of stat	
5. Customer L	egal Na	me (If an individual,	print last name j	first: eg: Doe	, John)		If new Custome	er, enter pr	evious Customer below:	
Vright City wate	er supply	company							Company of the second s	
. TX SOS/CPA	A Filing I	Number	8. TX State	Tax ID (11	digits)		9. Federal Tax	(ID	10. DUNS Number (if	
023244301			320271635	94		(9 digits)			applicable)	
1. Type of Cu	stomer	: 🛛 Corpo	ration			☐ Individ	lividual Partnership: ☐ General ☐ Limit			
overnment:	City 🔲	County Federal [Local 🗌 Stat	e 🗌 Other		☐ Sole P	roprietorship	□ Oth		
2. Number of							13. Independently Owned and Operated?			
₫ 0-20 □ 21			1-500 🗌 501	and higher			✓ Yes □ No			
4. Customer R	Role (Pro	oposed or Actual) – a	s it relates to the	Regulated E	Entity listed or	this form.	Please check one	of the follo	wing	
Owner Occupational I	Licensee	Operator Responsible F		wner & Oper VCP/BSA Ap			☐ Other	r:	Casal Constant of the	
	24065 Ly	rles Lane								
							-2			
5. Mailing	City	Trous		C4 :	TV	710	75056		717 4	
5. Mailing	City	Troup		State	TX	ZIP	75956		ZIP + 4	

19. Extension or Code

18. Telephone Number

20. Fax Number (if applicable)

	(903) 859-1281		() =	
ı		1	10		

SECTION III: Regulated Entity Information

Entity Inforr	nation (If 'New	Regulated Entity" is s	elected, a ne	w permit appl	ication is also required.)		
Update	to Regulated En	tity Name	ite to Regula	ted Entity Info	rmation		
ame submit	ted may be up	dated, in order to i	neet TCEQ	Core Data Si	tandards (removal of	organizatio	onal endings such
me (Enter na	me of the site w	here the regulated ac	tion is taking	place.)			
23. Street Address of the Regulated Entity: 18523 FM 2089							
City	Overton	State	тх	ZIP	75684	ZIP + 4	
Smith				I:			
	If no Str	eet Address is pro	vided, field	s 25-28 are r	equired.		
							-
					State	Nea	rest ZIP Code
			10 0 0 111		= **		3
					ards. (Geocoding of t	he Physical	Address may be
		provided or to gai					
April 14	32.201555		28.	Longitude (W) In Decimal:	-94.9939	87
Minutes		Seconds	Deg	rees	Minutes		Seconds
	12	5.5974		-94	59		38.3274
		Code			Jue	157.)	CS Code
123							
Business of t	his entity? (!	Do not repeat the SIC	or NAICS des	cription.)			
,					×		ii
24065 Lyle	s Lane						
					_		
City	Troup	State	TX	ZIP	75789	ZIP + 4	
wrig	htcity@gmail.co	om			1	8	
		37. Extension or	Code	38. F	ax Number (if applicab	ole)	
				() •		
	Update Jame submit Jame submit Jame (Enter na 18523 FM City Smith City Minutes 30. (4 d 24065 Lyle City	Update to Regulated Entername submitted may be updated Entername of the site with th	Update to Regulated Entity Name Update	Update to Regulated Entity Name Update to Regula Iame submitted may be updated, in order to meet TCEQ Iame (Enter name of the site where the regulated action is taking Iame (Enter name of the site where the regulated action is taking Iame (Enter name of the site where the regulated action is taking Iame (Enter name of the site where the regulated action is taking Iame (Enter name of the site where the regulated action is taking Iame (Enter name of the site where the regulated action is taking Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been provided or to gain accuracy) Iame (Iame submitted may be added/updated to meet TCEQ Core tes where none have been	Update to Regulated Entity Name Update to Regulated Entity Info Idame submitted may be updated, in order to meet TCEQ Core Data States are (Enter name of the site where the regulated action is taking place.) 18523 FM 2089	Update to Regulated Entity Name	Tame submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organization) are (Enter name of the site where the regulated action is taking place.) 18523 FM 2089

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

TCEQ-10400 (11/22) Page 2 of 3

Dam Safety		☐ Districts ☐ Edwards Aquifer			Emissions	Inventory Air	☐ Industrial Hazardous Waste
☐ Municipal Sc	lid Waste	New Source	OSSF		Petroleum	Storage Tank	⊠ pws
							2120027
Sludge		Storm Water	☐ Title V Air] Tires		Used Oil
☐ Voluntary Cle	anup	⊠ Wastewater	☐ Wastewater Agricu	lture [] Water Righ	nts	Other:
	IV: Pr	eparer Info	ormation		Maria de Caración		
40. Name:	hris Sowell			41. Title:	Project M	anager	
42. Telephone N	umber	43. Ext./Code	44. Fax Number	45. E-Mail	Address	733	
(512)335-1785			(512)335-0527	Chris@range	erenv.com	To the second second	
By my signature i	pelow, I certify	thorized Si v, to the best of my know entity specified in Secti	_	on provided in t	his form is to	rue and comple a ID numbers ic	ete, and that I have signature authority dentified in field 39.
Company:	Wright Cit	y WSC		Job Title:	President	t	-
Name (In Print):	Charles Se	ale				Phone:	(903) 859- 1281
ignature:	Cho	Mes Seo	ile			Date:	4-9-2024

ATTACHMENT 2 PUBLIC INVOLVEMENT PLAN

(TCEQ 20960)



Public Involvement Plan Form for Permit and Registration Applications

The Public Involvement Plan is intended to provide applicants and the agency with information about how public outreach will be accomplished for certain types of applications in certain geographical areas of the state. It is intended to apply to new activities; major changes at existing plants, facilities, and processes; and to activities which are likely to have significant interest from the public. This preliminary screening is designed to identify applications that will benefit from an initial assessment of the need for enhanced public outreach.

All applicable sections of this form should be completed and submitted with the permit or registration application. For instructions on how to complete this form, see TCEQ-20960-inst.

Section 1. Preliminary Screening
New Permit or Registration Application
New Activity - modification, registration, amendment, facility, etc. (see instructions)
If neither of the above boxes are checked, completion of the form is not required and does not need to be submitted.
Section 2. Secondary Screening
Requires public notice,
Considered to have significant public interest, <u>and</u>
Located within any of the following geographical locations:
 Austin Dallas Fort Worth Houston San Antonio West Texas Texas Panhandle Along the Texas/Mexico Border Other geographical locations should be decided on a case-by-case basis
If all the above boxes are not checked, a Public Involvement Plan is not necessary. Stop after Section 2 and submit the form.
Public Involvement Plan not applicable to this application. Provide brief explanation.
This discharge is geographically in a rural area with minimal residents and does not require a PIP.


TCEQ-20960 (02-09-2023) Page 1 of 4

Section 3. Application Information
Type of Application (check all that apply):
Air Initial Federal Amendment Standard Permit Title V
Waste Municipal Solid Waste Industrial and Hazardous Waste Scrap Tire Radioactive Material Licensing Underground Injection Control
Water Quality
Texas Pollutant Discharge Elimination System (TPDES)
Texas Land Application Permit (TLAP)
State Only Concentrated Animal Feeding Operation (CAFO)
Water Treatment Plant Residuals Disposal Permit
Class B Biosolids Land Application Permit
Domestic Septage Land Application Registration
Water Rights New Permit New Appropriation of Water New or existing reservoir
Amendment to an Existing Water Right
Add a New Appropriation of Water
Add a New or Existing Reservoir
Major Amendment that could affect other water rights or the environment
Section 4. Plain Language Summary
Provide a brief description of planned activities.

Section 5. Community and Demographic Information	
Community information can be found using EPA's EJ Screen, U.S. Census Bureau information, or generally available demographic tools.	
Information gathered in this section can assist with the determination of whether alternative	
language notice is necessary. Please provide the following information.	
(City)	
(County)	
(Census Tract)	
Please indicate which of these three is the level used for gathering the following information. City County Census Tract	
(a) Percent of people over 25 years of age who at least graduated from high school	
(a) research of people over 25 years of age who at least graduated from high school	
(b) Per capita income for population near the specified location	
(c) Percent of minority population and percent of population by race within the specified location	
(d) Percent of Linguistically Isolated Households by language within the specified location	
(d) referred of Enignistically isolated flouseholds by language within the specified location	
(e) Languages commonly spoken in area by percentage	
(f) Community and/or Stakeholder Groups	
g) Historic public interest or involvement	

Section 6. Planned Public Outreach Activities
(a) Is this application subject to the public participation requirements of Title 30 Texas Administrative Code (30 TAC) Chapter 39? Yes No
(b) If yes, do you intend at this time to provide public outreach other than what is required by rule? Yes No
If Yes, please describe.
If you answered "yes" that this application is subject to 30 TAC Chapter 39, answering the remaining questions in Section 6 is not required. (c) Will you provide notice of this application in alternative languages? Yes No Please refer to Section 5. If more than 5% of the population potentially affected by your
application is Limited English Proficient, then you are required to provide notice in the alternative language.
If yes, how will you provide notice in alternative languages?
Publish in alternative language newspaper
Posted on Commissioner's Integrated Database Website
Mailed by TCEQ's Office of the Chief Clerk
Other (specify)
(d) Is there an opportunity for some type of public meeting, including after notice?
Yes No
(e) If a public meeting is held, will a translator be provided if requested?
Yes No
(f) Hard copies of the application will be available at the following (check all that apply):
TCEQ Regional Office TCEQ Central Office
Public Place (specify)
Section 7. Voluntary Submittal
For applicants voluntarily providing this Public Involvement Plan, who are not subject to formal public participation requirements.
Will you provide notice of this application, including notice in alternative languages? Yes No What types of notice will be provided?
Publish in alternative language newspaper Posted on Commissioner's Integrated Database Website
Posted on Commissioner's Integrated Database Website Mailed by TCEQ's Office of the Chief Clerk
Other (specify)

ATTACHMENT 3 USGS TOPOGRAPHIC MAP




ATTACHMENT 4

TEXAS DEPARTMENT OF TRANSPORTATION APPROVAL


TX DOT APPROVAL


The Texas Department of Transportation has been notifie	ed regarding the discharge being in their right
of way and we are currently awaiting their approval.	

ATTACHMENT 5 AFFECTED LANDOWNER MAP




ATTACHMENT 6 DISCHARGE PHOTOGRAPHIC LOG






Photograph 1



Photograph 2



Photograph 3



Photograph 4



Photograph #5



Photograph #6




Photograph #7




Photograph #8

ATTACHMENT 7

TOPOGRAPHIC QUADRANGLE MAP



ATTACHMENT 8 DISCHARGE ROUTE MAP



ATTACHMENT 9

FLOW DIAGRAM



Projection Report

Date: 8/29/2022

Client: Simply Aquatics



Institutenweg 35 7521 PH Enschede The Netherlands +31 (0)850 479 900 info@nxfiltration.com www.nxfiltration.com

DISCLAIMER:

The use of the projection made available to you by NX Filtration B.V. (hereinafter 'NX') – and the use of all results arising thereof – is/are at the user's own risk and expense. NX makes no guarantees whatsoever regarding the contents of the projection and the results or reports generated by it. Product performance calculations are based on nominal module performance when operated on a feed water of acceptable quality. The results produced by this software are estimates of product performance only. Users of information set forth herein are responsible for determining suitability of the information and may not assume that the results are correct and reliable. No guarantee of product or system performance is expressed or implied whatsoever. NX expressly disclaims any and all liability as to any results obtained or arising from any use of the software or any reliance on such information. No warranty of fitness for any particular purpose, warranty of the merchantability or any other warranty, expressed or implied, is made concerning the software or the information provided herein, or the results arising thereof.

	PRO	JECT DETAILS	
Client:	Simply Aquatics	Feed Water Type:	Other
Project Name:	Wright City	Case:	dNF40T68FR75
Project Number:	And Market Males of	Select Design:	Feed & Bleed Design
Project Location:			Selected
Designer:	NX NKM		
Date:	8/29/2022		




7521 PH Enschede Institutenweg 35 The Netherlands

www.nxfiltration.com

info@nxfiltration.com +31 (0)850 479 900

PROCESS - PROPOSAL



		STAC	STAGE PARAMETER	METERS - PROPOSA				
Stage	•	2	3	4	5	u	Ü	
Modulos						,	onillillary	ary
modules per stage	10	10	0	0	0	0	Total	S
Doctor letter for free free free free free free fre	143							20
vecil calation flow (gpin)	489	489	0	0	0	c	Energy	,
Description of the second	1				18.	,	kWh/kgal	.
Liessure stage pump (psi)	7.4	7.4	0	0	0	c	Maria	,
Docotton nor office (8/1)	100					•	MIGAIIII	4.7
vecovery per stage (%)	37.9	59.7	0	0	0	0	Total	75
								2

Page 3/8

The content of this report is confidential and intended for the recipient specified in report only. It is strictly forbidden to share any part of this message with any third party, without a written consent of the sender. This report request does not imply entering into a legally binding contract.



Institutenweg 35 7521 PH Enschede The Netherlands +31 (0)850 479 900 info@nxfiltration.com www.nxfiltration.com

PROCESS PARAMETERS -	- PROPOSAL*
Process Properties	
Module Type	WRC200-dNF40-IRD
Number of Stages	2
Total Number of Modules	20
Membrane Age (years)	3
Average membrane flux (gfd)	14
Feed Settings	
Feed flow (gpm)	140
Feed pressure (psi)	73.4
Feed temperature (°F)	68
pH	7.5
Crossflow (ft/s)	1.6
Concentrate Settings	
Concentrate flow (gpm)	35
Concentrate pressure (psi)	66
Permeate Settings	
Permeate flow (gpm)	105
Permeate pressure (psi)	0
Pass Recovery Required (%)	75
Pass Recovery Achieved (%)	75
Forward Flush + Air Scour Set	tings
Flush flow (gpm)	488
Volume per flush (gal)	488
Flush min. pressure (psi)	25.6
Air Scour Flow	0
Air Scour pressure	29
Backwash Settings	
Backwash flow (gpm)	0
Volume per backwash (gal)	0
Backwash max. pressure (psi)	87

^{*}No piping or fitting pressure losses are calculated. The pressures indicated are assumed to be pressures at the receiving module interface or caused within the module based on the process conditions.



7521 PH Enschede Institutenweg 35 The Netherlands

+31 (0)850 479 900

info@nxfiltration.com www.nxfiltration.com

ENERGY CONSUMPTION	MPTION	
Inputs		
Pump Efficiency	80	%
Energy Unit Cost	0.1	\$/kWh
Results		
Filtration - Common Feed Pump	115	kWh/day
Filtration - Recirculation Pump Stage 1	46.3	kWh/day
Filtration - Recirculation Pump Stage 2	46.3	kWh/day
Filtration - Recirculation Pump Stage 3	0	kWh/day
Filtration - Recirculation Pump Stage 4	0	kWh/day
Hydraulic Clean - Flush	0.79	kWh/day
Hydraulic Clean - Backwash	0	kWh/day
Total Daily Energy Consumption	208	kWh/day
Total Specific Energy Consumption	1.4	kWh/kgal
Total Specific Energy Cost	0.14	\$/kgal
Total Yearly Energy Consumption	75.9	MWh

OPERATIONAL RESULTS	. RESULTS	
Grouping Volume	111	gal
Ave. Time In Filtration	23.6	hrs/day
Ave. Time In HC	0.1	hrs/day
Ave. Time In CEF	0.3	hrs/day
Filtration Availability	98.3	%
Permeate Consumption Per Day	63.6	pdb
Total Feed Per Day	201985	pd6
Net Permeate Per Day	148444	pd6
Total Waste Per Day	3968	pd6
Perm/Feed Recovery	73.5	%

		CLEA	CLEANING SETTINGS	NGS		
HC & CEF Grouping	max	10	modules	Hydraulic Clean every	c	bours
Base + NaOCI CEF	every	168	hours	Flush Crossflow Velocity	1.6	#/e
Base + NaOCI CEF	downtime	30	minutes	Flush Time	09	sproones
Permeate Used For Base + NaOCI CEF		YES	<= select	Air Scour Time	0	spacoos
Acid CEF	every	168	houre	Backwach Clive		seconds
Anid OEE				DECAMBBILLIAN	0	gfd
Acid CET	downtime	30	minutes	Backwash Time	0	seconds
Permeate Used For Acid CEF		YES	<= select	Drain + Vent Time	0	seconds

Page 5/8
The content of this report is confidential and intended for the recipient specified in report only, It is strictly forbidden to share any part of this message with any third party, without a written consent of the sender. This report request does not imply entering into a legally binding contract.



7521 PH Enschede Institutenweg 35 The Netherlands

되

H2SO4

Citric Acid 0 0

NaOH NaOCI

CEF

CHEMICAL CONSUMPTION

0 0 0 0

0 0 0 0 0

0

0

0 0 0 0 0 0 0

0 0 0 0 0 0 0

Final concentration (ppm) Stock concentration (%)

Ib chemical/CEF

gal stock/day

Ib stock/CEF

0 0 0

info@nxfiltration.com www.nxfiltration.com +31 (0)850 479 900

					SC,	ALIN	S IN	SCALING INDICES		
				Stage						
		Feed	Į.		=	≥	^	I	Conc.	Perm.
	BaF ₂	0	0	0	0	0	0	0	0	0
	BaSO4	< 0.1	0.1	0.3	0	0	0	0	0	0
	BaCOs	0	0	0	0	0	0	0	0	0
Saturation	CaF ₂	0	0	0	0	0	0	0	0	0
(Saturated at 1)	CaSO4	< 0.1	< 0.1	< 0.1	0	0	0	0	0	0
	SrF ₂	0	0	0	0	0	0	0	0	0
	SrSO4	0	0	0	0	0	0	0	0	0
	SrCO ₃	0	0	0	0	0	0	0	0	0
Langelier Saturation Index (Saturated at 0)	ration Index d at 0)	-0.9	-0.2	0.1	0	0	0	0	0	0

Scale prevention protocols not necessary!

11.3

0 0 0 0

0

3.3

2.6

67.1

587

7

0 0 0

0.413

0.774

Ib chemical/CIP

lb stock/CIP

gal stock/year

lb stock/year

17.1

12.1

172

134

410

0

150

Final concentration (ppm)

Stock concentration (%)

10

0

0 0

豆

H2SO4

NaOCI 12.5

NaOH

30 281

0

0

gal consumption stock/kgal permeate

Ib chemical/day

lb stock/day

0

0

0

0 0

0

0

0

0.001

54.6

58.7

0 0

0 0

21.5

40.2

< 0.001

< 0.001

gal consumption stock/kgal permeate

Ib chemical/year

Total Yearly chemicals consumption lb/year

The content of this report is confidential and intended for the recipient specified in report only. It is strictly forbidden to share any part of this message with any third party, without a written consent of the sender. This report request does not imply entering into a legally binding contract. Page **6/8**



Institutenweg 35 7521 PH Enschede The Netherlands +31 (0)850 479 900 info@nxfiltration.com www.nxfiltration.com

	WATER QUA	ALITY EXPE	CTATIONS -	GENERAL	
PARAMETER	UNIT	FEED	PERMEATE	CONCENTRATE	REJECTION (%)
Total Dissolved Solids	mg/l	977	737	1695	24.5
Colour	Hazen	50	2.7	192	94.6
Total Organic Carbon	mg/l	0.8	0.1	2.7	88.3
Total Hardness	mg/l CaCO3	3.7	2.1	8.6	43.4
Total Alkalinity	mg/l CaCO3	398	299	695	24.9



Institutenweg 35 7521 PH Enschede The Netherlands +31 (0)850 479 900 info@nxfiltration.com www.nxfiltration.com

	WATER QUALITY EXPECTATIONS - IONS									
PARAMETER	UNIT	FEED	PERMEATE	CONCENTRATE	REJECTION (%)					
Ca²+	mg/I	1.1	0.6	2.6	44					
Mg ^{z+}	mg/l	0.2	0.1	0.5	41.7					
Na ⁺	mg/l	300	229	513	23.7					
K⁺	mg/l	1.4	1.1	2.5	25.9					
Ba ²⁺	mg/l	< 0.1	< 0.1	0.1	45.9					
CI-	mg/l	189	145	321	23.2					
SO ₄ 2-	mg/l	4	< 0.1	15.9	99.7					
NO ₃ -	mg/l	0.1	< 0.1	0.1	24.9					
HCO₃⁻	mg/l	480	361	838	24.9					
F-	mg/l	1	0.6	2	35.6					

The data given in the tables above are estimated based on provided information and may differ slightly from reality.

Designer's comments:


No feed pH provided, assumed feed pH of 7.5.

ATTACHMENT 10

SITE DRAWING



ATTACHMENT 11 FEMA FLOOD PLAIN MAP



ATTACHMENT 12 LABORATORY REPORTS





REPORT

REPORT DATE RECEIVE DATE RECEIVE TIME WORK ORDER

02/15/2024	
01/05/2024	
1110	
N4A0514	

REPORT TO	
Simply Aquatics, Inc.	
Nancy Fountain	
PO Box 849	
Kirbyville, TX 75956	

REPORT FROM

Eastex Environmental Laboratory PO Box 631375 Nacogdoches, TX 75963 936-569-8879

PROJECT
Simply Aquatics Nano Waste

Enclosed are the results of analyses for samples received by the laboratory on 01/05/24 11:10, with Lab ID Number N4A0514. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Paul D. Hughes, Laboratory Director

LABORATORY ANALYTICAL REPORT

Project: Simply Aquatics Nano Waste

Sample Site: Outfall Nanc	Waste WC#	1	Sa	ample Nur	nber		Colle	ctor: Caleb Ro	ss
Sample Type: Grab			1	N4A0514-	-01		Samp	oled: 01/04/24	1200
Sample Matrix: Water								ived: 01/05/24	
Analyte	Result	Reporting Limit	Units	Nelac Status	Batch	Analyzed	Analyst	Method	Notes
Aluminum - Total	3130	2.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Antimony - Total	<2.00	2.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Arsenic, Total	<0.500	0.500	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Barium, Total	42.4	1.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	В
Beryllium, Total	< 0.500	0.500	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Boron, Total	116	8.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Bromide	0.882	0.100	mg/L	Α	B4A2387	01/15/24 1140	OCR	EPA 300.0	Cs
Cadmium, Total	<1.00	1.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Chromium, Total	2.06	1.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Cobalt, Total	< 0.600	0.600	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Copper, Total	3.42	1.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Iron, Total	235	37.0	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Lead, Total	0.663	0.500	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Magnesium, Total	350	17.0	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Manganese, Total	34.6	7.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Molybdenum, Total	<1.00	1.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Nickel, Total	<2.00	2.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Nitrate+Nitrite as N	< 0.02	0.02	mg/L	Α	B4A3008	01/23/24 1420	TRH	SM 4500 NO3 F	Cs
Selenium, Total	<2.00	2.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Silver, Total	< 0.500	0.500	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
Sulfide	< 0.05	0.05	mg/L	0	B4A2372	01/15/24 1445	NRJ	EPA 376.1	6, Cs
Γhallium, Total	< 0.500	0.500	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
lin, Total	<5.00	5.00	ug/L	Α	B4A2819	02/15/24 1603	KJH	EPA 200.8	
litanium, Total	13.5	1.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	
TOC .	1.7	1.0	mg/L	Α	B4A2877	01/18/24 1112	WLS	SM 5310 C	Cs
inc, Total	7.92	5.00	ug/L	Α	B4A2819	01/18/24 1211	KJH	EPA 200.8	54.00mm-1

Sample Site: Outfall Nano	Waste WC#	1	Sai	mple Nun	nber		Colle	ctor: Caleb Ro	ss
Sample Type: Grab				4A0514-			Samo	oled: 01/04/24	1200
Sample Matrix: Water							VIOC.201100411.	ived: 01/05/24	
Analyte	Result	Reporting Limit	Units	Nelac Status	Batch	Analyzed	Analyst	Method	Notes
Chlorine	<0.1	0.1	mg/L	N	N400176	01/05/24 1400	PDH	SM 4500 CI F	
DO	10.4		mg/L	N	N400176	01/05/24 1400	PDH	SM 4500 O G	
Alkalinity	340	20.0	mg CaCO3/L	Α	N400231	01/09/24 0930	ISR	SM 2320 B	
BOD 5	<2.0	2.0	mg/L	Α	N400244	01/05/24 1200	DBR	SM 5210 B	
CBOD 5	<2.0	2.0	mg/L	Α	N400243	01/05/24 0740	DBR	SM 5210 B	
Chloride	170	5	mg/L	Α	N400550	01/19/24 1540	KP	SM 4500 CI C	
Chromium, (VI)	<3	3	ug/L	Α	N400330	01/11/24 1030	RJD	SM 3500 Cr B	ZZ
Chromium, Trivalent	<3	3	ug/L	N	N400325	01/22/24 1610	RJD	X 2 X	
COD	35.8	20.0	mg/L	Α	N400248	01/10/24 1020	KP	EPA 410.4	
Color	20	5	Color Units	Α	N400178	01/05/24 1120	RJD	SM 2120 B	27
Fluoride	0.33	0.1	mg/L	0	N400214	01/08/24 1042	ISR	SM 4500 F D	
NH3N	0.805	0.1	mg/L	Α	N400333	01/11/24 1421	ISR	SM 4500 NH3 - D)
Nitrate - N	<0.3	0.3	mg/L	N	N400119	01/05/24 0900	KP	Hach 10206	
Nitrite as N	0.5825	0.05	mg/L	Α	N400594	01/23/24 1400	ISR	SM 4500 NO2 B	3, 4, 42
Oil Grease, HEM	<5.0	5.0	mg/L	Α	N400396	01/21/24 1000	DBR	EPA 1664A	
pH Lab	8.63		std unit	Α	N400203	01/05/24 1135	KP	SM 4500 H + B	3, 6
Sulfate	44.7	5.00	mg/L	Α	N400192	01/08/24 1230	ISR	ASTM D516-11	
TDS	730	10.0	mg/L	Α	N400223	01/08/24 1600	RWC	SM 2540 C	
TKN	2.2	2.0	mg/L	Α	N400835	02/01/24 1455	RJD	EPA 351.2	S
Total Nitrogen	3.08		mg/L	N	N400323	02/01/24 1515	RJD	**************************************	1
Total Organic Nitrogen	1.395	1	mg/L		N400588	02/01/24 1505	RJD		
Total Phosphorus as P	0.83	0.05	mg/L	Α	N400329	01/11/24 1000	KP	SM 4500 P B.5 E	
TSS	19.3	1.0	mg/L	Α	N400131	01/05/24 1740	RWC	SM 2540 D	

Hach 10206 - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch N400119 - No	Prep									
Blank (N400119-BLK1)						Pr	epared & A	Analyzed:	01/05/2
Nitrate - N	ND	0.3	mg/L							
LCS (N400119-BS1)						, , , , , , , , , , , , , , , , , , , ,	Pr	epared & A	nalyzed:	01/05/24
Nitrate - N	3.97		mg/L	4.26		93.2	90-110			
Matrix Spike (N400119)-MS1)		Sour	ce: N4A0230	-01		Pr	epared & A	nalyzed:	01/05/24
Nitrate - N	89.2	0.3	mg/L	50.0	37	104	80-120			
Matrix Spike Dup (N40	0119-MSD1)		Sour	ce: N4A0230	-01		Pro	epared & A	nalyzed:	01/05/24
Nitrate - N	88.2	0.3	mg/L	50.0	37	102	80-120	1.13	20	
Batch N400131 - No	Prep									
Blank (N400131-BLK1)				**********			Pre	pared & A	nalyzed: (01/05/24
TSS	ND	1.0	mg/L							
Duplicate (N400131-DL	JP1)		Sour	ce: N4A0156-	·01		Pre	pared & A	nalyzed: 0	1/05/24
TSS	49.0	1.0	mg/L		47.0	********		4.17	10	
Batch N400178 - No	Prep									
Blank (N400178-BLK1)				• • • • • • • • • • • • •			Pre	pared & A	nalyzed: 0	1/05/24
Color	ND	5	Color Units							27
Duplicate (N400178-DU	IP1)		Source	e: N4A0514-	01		Pre	pared & Aı	nalyzed: 0	1/05/24
Color	20	5	Color Units		20			0.00	20	27

ASTM D516-11 - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch N400192 - No Pre	р									
Blank (N400192-BLK1)							P:	repared & A	Analyzed:	01/08/2
Sulfate	ND	5.00	mg/L				· · · · · · · · · · · · · ·			
LCS (N400192-BS1)							Pı	repared & A	nalyzed:	01/08/24
Sulfate	95.4		mg/L	100		95.4	80-120			
Matrix Spike (N400192-MS1	1)		Sou	rce: N4A0046	-01		Pr	epared & A	nalyzed:	01/08/24
Sulfate	128	5.00	mg/L	60.0	61.3	112	80-120			
Matrix Spike Dup (N400192	-MSD1)		Sou	rce: N4A0046	-01		Pr	epared & A	nalyzed:	01/08/24
Sulfate	128	5.00	mg/L	60.0	61.3	111	80-120	0.158	20	
Batch N400203 - No Pre	р									
Duplicate (N400203-DUP1)	THE THE SINE SINE		Sour	rce: N4A0514	.01		Pr	epared & A	nalyzed: (01/05/24
pH Lab	8.61		std unit		8.63			0.232	20	3, 6
Batch N400214 - No Prep)									
Blank (N400214-BLK1)							Pro	epared & A	nalyzed: (1/08/24
Fluoride	ND	0.1	mg/L							
_CS (N400214-BS1)							Pre	epared & A	nalyzed: 0	1/08/24
Fluoride	1.09		mg/L	1.00		109	90-110			
MRL Check (N400214-MRL1)						Pre	epared & A	nalyzed: 0	1/08/24
luoride	0.13		mg/L	0.100		130	0-200			

SM 4500 F D - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch N400214 - No F	Prep									
Matrix Spike (N400214-I	WS1)			rce: N4A0514	I-01			repared & /	Analyzed:	01/08/2
Fluoride	1.34	0.1	mg/L	1.00	0.33	101	80-120			
Matrix Spike Dup (N400)	214-MSD1)	*************	Sou	rce: N4A0514	-01		F	repared & A	Analyzed:	01/08/2
Fluoride	1.26	0.1	mg/L	1.00	0.33	93.0	80-120	6.15	20	
Batch N400223 - No P	rep									
Blank (N400223-BLK1)								repared & A	nalyzed:	01/08/24
TDS	ND	10.0	mg/L							
LCS (N400223-BS1)							P	repared & A	nalyzed:	01/08/24
TDS	46.0		mg/L	50.0		92.0	90-110			
Duplicate (N400223-DUP	1)		Sour	ce: N4A0176	-01		Р	repared & A	nalyzed: (01/08/24
TDS	420	10.0	mg/L		428		ros con ros r	1.89	10	
Batch N400231 - No P	rep									
Blank (N400231-BLK1)							Pı	repared & A	nalyzed: (1/09/24
Alkalinity	ND	20.0	mg CaCO3/L							
CS (N400231-BS1)							Pı	epared & A	nalyzed: 0	1/09/24
Alkalinity	96.0		mg CaCO3/L	100		96.0	90-110			2000 EG 11
Ouplicate (N400231-DUP	1)		Source	ce: N4A0514-	01		Pr	epared & A	nalyzed: 0	1/09/24
lkalinity	336	20.0	mg CaCO3/L		340			1.18	20	

SM 5210 B - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch N400243 - No Pre	ep									
Blank (N400243-BLK1)			******				P	repared & A	nalyzed:	01/05/24
CBOD 5	ND	2.0	mg/L	5.512 5.82 5.612 5.612						
LCS (N400243-BS1)							P	repared & A	nalyzed:	01/05/24
CBOD 5	175		mg/L	198		88.4	84.59-115.4			
Duplicate (N400243-DUP1))		Sou	rce: N4A0207	-01		Pı	repared & A	nalyzed:	01/05/24
CBOD 5	ND	2.0	mg/L		ND				30	
Batch N400244 - No Pre	р									
Blank (N400244-BLK1)							Pr	epared & A	nalyzed: (01/05/24
BOD 5	ND	2.0	mg/L							
LCS (N400244-BS1)							Pr	epared & A	nalyzed: 0	1/05/24
BOD 5	186		mg/L	198		93.9	84.59-115.4			
Duplicate (N400244-DUP1)			Sour	ce: N4A0261	-01		Pr	epared & A	nalyzed: 0	1/05/24
3OD 5	2.60	2.0	mg/L		2.80			7.41	30	
Batch N400248 - No Pre	р									
Blank (N400248-BLK1)							Pro	epared & Ar	nalyzed: 0	1/10/24
COD	ND	20.0	mg/L		****************	E				
.CS (N400248-BS1)							Pre	epared & Ar	nalyzed: 0	1/10/24
COD	83.1		mg/L	82.4		101	80-120			

EPA 410.4 - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch N400248 - No P	rep								Little	
Matrix Spike (N400248-N	MS1)		Sou	rce: N4A0347	7-01		P	repared & A	nalyzed:	01/10/2
COD	212	20.0	mg/L	200	16.5	97.8	90-110			
Matrix Spike Dup (N4002	248-MSD1)		Sou	rce: N4A0347	7-01		Pı	epared & A	nalyzed:	01/10/2
COD	214	20.0	mg/L	200	16.5	98.8	90-110	0.985	20	
Batch N400329 - No P	rep									
Blank (N400329-BLK1)							Pr	epared & A	nalyzed:	01/11/24
Total Phosphorus as P	ND	0.05	mg/L					*********		
LCS (N400329-BS1)							Pr	epared & A	nalyzed: (01/11/24
Total Phosphorus as P	3.38		mg/L	3.33		102	90-110			
Matrix Spike (N400329-M	S1)		Sour	ce: N4A0045	-01		Pr	epared & A	nalyzed: (01/11/24
Total Phosphorus as P	0.28	0.05	mg/L	0.250	0.06	92.0	80-120			
Matrix Spike Dup (N40032	29-MSD1)		Sour	ce: N4A0045	-01		Pr	epared & A	nalyzed: 0	1/11/24
Total Phosphorus as P	0.30	0.05	mg/L	0.250	0.06	96.4	80-120	3.79	20	
Batch N400330 - No Pro	ер									
Blank (N400330-BLK1)							Pre	epared & Ai	nalyzed: 0	1/11/24
Chromium, (VI)	ND	3	ug/L							
.CS (N400330-BS1)							Pre	pared & Ar	nalyzed: 0	1/11/24
Chromium, (VI)	493		ug/L	511		96.5	95-105			

SM 3500 Cr B - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch N400330 - No	Prep									
MRL Check (N400330-	MRL1)						P	repared & A	Analyzed:	01/11/2
Chromium, (VI)	3.19		ug/L	3000		0.106	0-200			
Matrix Spike (N400330	-MS1)		Sou	rce: N4A0514	l-01		P	repared & A	nalyzed:	01/11/2
Chromium, (VI)	30	3	ug/L	27.4	2.3	101	80-120			
Matrix Spike Dup (N400	0330-MSD1)		Soul	rce: N4A0514	-01		Pı	repared & A	nalyzed:	01/11/24
Chromium, (VI)	30	3	ug/L	27.4	2.3	101	80-120	0.00	20	
Batch N400333 - No	Prep									
Blank (N400333-BLK1)	.,,,,,,,,,,,,,						Pr	epared & A	nalyzed: (01/11/24
NH3N	ND	0.1	mg/L							
LCS (N400333-BS1)							Pr	epared & A	nalyzed: (01/11/24
NH3N	4.8		mg/L	5.00		96.0	90-120			
Matrix Spike (N400333-	MS1)		Sour	ce: N4A0322-	·01		Pr	epared & A	nalyzed: 0	1/11/24
NH3N	4.62	0.1	mg/L	5.00	ND	92.4	80-120			
Matrix Spike Dup (N400	333-MSD1)		Sour	ce: N4A0322-	01		Pro	epared & A	nalyzed: 0	1/11/24
ИНЗИ	4.51	0.1	mg/L	5.00	ND	90.2	80-120	2.41	20	
Batch N400396 - No F	Prep									
Blank (N400396-BLK1)							Pre	pared & Ar	nalyzed: 0	1/21/24
Dil Grease, HEM	ND	5.0	mg/L		* * * * * * * * * * * * * * * * * * * *					eser eser e

EPA 1664A - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Note
Batch N400396 - No F	Prep									
Blank (N400396-BLK2)			*********				Pi	epared & A	Analyzed:	01/21/2
Oil Grease, HEM	ND	5.0	mg/L	*	***********		a sala sala sala si		* * * * * * * * *	
LCS (N400396-BS1)							Pr	epared & A	Analyzed:	01/21/2
Oil Grease, HEM	36.9		mg/L	40.0		92.2	78-114			
Matrix Spike (N400396-N	1 S1)		Sou	rce: N4A0342	-02	*******	Pr	epared & A	nalyzed:	01/21/2
Oil Grease, HEM	38.3	5.0	mg/L	40.0	ND	95.8	78-114			
Matrix Spike Dup (N4003	96-MSD1)		Sour	ce: N4A0342	-02		Pr	epared & A	nalyzed: (01/21/2
Oil Grease, HEM	35.0	5.0	mg/L	40.0	ND	87.5	78-114	9.00	18	
Batch N400550 - No P	rep	1		-						
Blank (N400550-BLK1)			,,,,,,,,,,,				Pro	epared & A	nalyzed: (01/19/24
Chloride	ND	5	mg/L							
_CS (N400550-BS1)					***********		Pre	pared & A	nalyzed: 0	1/19/24
Chloride	100		mg/L	100		100	90-110			
Matrix Spike (N400550-M	S1)		Sour	ce: N4A0046-	01		Pre	pared & A	nalyzed: 0	1/19/24
Chloride	220	5	mg/L	100	110	110	80-120			
Matrix Spike Dup (N4005	50-MSD1)		Sour	ce: N4A0046-	01		Pre	pared & Ar	nalyzed: 0	1/19/24
Chloride	220	5	mg/L	100	110	110	80-120	0.00	20	
Batch N400594 - No Pr	ер									
lank (N400594-BLK1)							Pre	pared & Ar	nalyzed: 0	1/23/24
itrite as N	ND ND	0.05	mg/L							

SM 4500 NO2 B - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch N400594 - I	No Prep									
LCS (N400594-BS1)				* * * * * * * * * * * * * *			Pr	epared & A	nalyzed:	01/23/24
Nitrite as N	0.31		mg/L	0.300	**********	103	90-110			
Matrix Spike (N4005	94-MS1)		Sou	rce: N4A0773	-01		Pro	epared & A	nalyzed:	01/23/24
Nitrite as N	0.263	0.05	mg/L	0.200	0.0501	106	80-120			
Matrix Spike Dup (N	400594-MSD1)		Sou	rce: N4A0773	-01		Pre	epared & A	nalyzed:	01/23/24
Nitrite as N	0.267	0.05	mg/L	0.200	0.0501	108	80-120	1.51	20	

EPA 300.0 - Quality Control

Eastex Environmental Laboratory - Coldspring

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B4A2387 - No	Prep									
Blank (B4A2387-BLK1)						P	repared & A	nalyzed:	01/15/2
Bromide	ND	0.100	mg/L							
LCS (B4A2387-BS1)							Pı	repared & A	nalyzed:	01/15/2
Bromide	0.514		mg/L	0.500		103	90-110			
Matrix Spike (B4A2387	-MS1)		Sour	rce: C4A3602	-01			epared & A	nalyzed:	
Bromide	2.66	0.100	mg/L	2.50	0.131	101	80-120			
Matrix Spike Dup (B4A		*	Sour	rce: C4A3602	-01			epared & A	nalyzed: (01/15/24
Bromide	2.64	0.100	mg/L	2.50	0.131	100	80-120	0.811	20	
Batch B4A2819 - EP	A 200.8									
Blank (B4A2819-BLK1)		**********					Prepared:	01/17/24 A	nalyzed: (01/18/24
Aluminum - Total	ND	2.50	ug/L							
Antimony - Total	ND	5.00	ug/L							
Arsenic, Total	ND	0.500	ug/L							
Barium, Total	ND	3.00	ug/L							В
Beryllium, Total	ND	0.500	ug/L							1000
Boron, Total	ND	8.00	ug/L							
Cadmium, Total	ND	1.00	ug/L							
Chromium, Total	ND	3.00	ug/L							
Cobalt, Total	ND	1.00	ug/L							
Copper, Total	ND	2.00	ug/L							
ron, Total	ND	100	ug/L							
ead, Total	ND	0.500	ug/L							
Magnesium, Total	ND	100	ug/L							
/langanese, Total	ND	7.00	ug/L							
folybdenum, Total	ND	1.00	ug/L							
lickel, Total	ND	2.00	ug/L							
elenium, Total	ND	5.00	ug/L							
ilver, Total	ND	0.500	ug/L							
hallium, Total	ND	0.500	ug/L							
in, Total	ND	1.00	ug/L							
itanium, Total	ND	1.00	ug/L							
inc, Total	ND	5.00	ug/L							

EPA 200.8 - Quality Control Eastex Environmental Laboratory - Coldspring

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B4A2819 - EPA	200.8									
LCS (B4A2819-BS1)							Prepared:	01/17/24 A	nalyzed:	01/18/2
Aluminum - Total	108	2.50	ug/L	100		108	85-115			
Antimony - Total	101	5.00	ug/L	100		101	85-115			
Arsenic, Total	101	0.500	ug/L	100		101	85-115			
Barium, Total	99.1	3.00	ug/L	100		99.1	85-115			В
Beryllium, Total	107	0.500	ug/L	100		107	85-115			ь
Boron, Total	113	8.00	ug/L	100		113	85-115			
Cadmium, Total	100	1.00	ug/L	100		100	85-115			
Chromium, Total	101	3.00	ug/L	100		101	85-115			
Cobalt, Total	102	1.00	ug/L	100		102	85-115			
Copper, Total	103	2.00	ug/L	100		103	85-115			
Iron, Total	10100	100	ug/L	10000		101	85-115			
Lead, Total	99.5	0.500	ug/L	100		99.5	85-115			
Magnesium, Total	10200	100	ug/L	10000		102	85-115			
Manganese, Total	99.8	7.00	ug/L	100		99.8	85-115			
Molybdenum, Total	101	1.00	ug/L	100		101	85-115			
Nickel, Total	101	2.00	ug/L	100		101	85-115			
Selenium, Total	96.4	5.00	ug/L	100		96.4	85-115			
Silver, Total	104	0.500	ug/L	100		104	85-115			
hallium, Total	103	0.500	ug/L	100		103	85-115			
īn, Total	97.1	1.00	ug/L	100		97.1	85-115			
ītanium, Total	102	1.00	ug/L	100		102	85-115			
linc, Total	99.2	5.00	ug/L	100		99.2	85-115			
/latrix Spike (B4A2819-M	S1)		Sou	rce: C4A3263	i-01		Prepared: 0	1/17/24 Ar	nalvzed: 0	1/18/24
Juminum - Total	166	2.50	ug/L	100	60.7	105	70-130			
ntimony - Total	107	5.00	ug/L	100	8.56	98.2	70-130			
rsenic, Total	102	0.500	ug/L	100	1.17	100	70-130			
arium, Total	151	3.00	ug/L	100	53.0	97.7	70-130			В
eryllium, Total	98.1	0.500	ug/L	100	ND	98.1	70-130			ь
oron, Total	468	8.00	ug/L	100	361	107	70-130			
admium, Total	95.5	1.00	ug/L	100	ND	95.5	70-130			
hromium, Total	97.7	3.00	ug/L	100	1.12	96.6	70-130			
obalt, Total	95.4	1.00	ug/L	100	0.399	95.0	70-130			
opper, Total	94.2	2.00	ug/L	100	0.933	93.3	70-130			
on, Total	9790	100	ug/L	10000	ND	97.9	70-130			- 1
ead, Total	98.2	0.500	ug/L	100	0.0690	98.2	70-130			
agnesium, Total	18200	100	ug/L	10000	8570	96.1	70-130			
anganese, Total	107	7.00	ug/L	100	7.85	99.4	70-130			
olybdenum, Total	104	1.00	ug/L	100	5.65	98.6	70-130			
ckel, Total	93.8	2.00	ug/L	100	ND	93.8	70-130			
elenium, Total	102	5.00	ug/L	100	ND	102	70-130			
ver, Total	92.4	0.500	ug/L	100	ND	92.4	70-130			
allium, Total	101	0.500	ug/L	100	0.0400	101	70-130			
n, Total	112	1.00	ug/L	100	18.9	93.3	70-130			
anium, Total	102	1.00	ug/L	100	0.626	101	70-130			
nc, Total	175	5.00	ug/L	100	77.3	97.8	70-130			

EPA 200.8 - Quality Control

Eastex Environmental Laboratory - Coldspring

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B4A2819 - EP	A 200.8									
Matrix Spike Dup (B4A	2819-MSD1)		Sou	rce: C4A326	3-01		Prepared	01/17/24	Analyzed:	01/18/2
Aluminum - Total	161	2.50	ug/L	100	60.7	100	70-130	3.29	20	
Antimony - Total	106	5.00	ug/L	100	8.56	97.8	70-130	0.374	20	
Arsenic, Total	102	0.500	ug/L	100	1.17	101	70-130	0.247	20	
Barium, Total	150	3.00	ug/L	100	53.0	96.8	70-130	0.573	20	В
Beryllium, Total	99.9	0.500	ug/L	100	ND	99.9	70-130	1.89	20	
Boron, Total	463	8.00	ug/L	100	361	102	70-130	1.12	20	
Cadmium, Total	94.9	1.00	ug/L	100	ND	94.9	70-130	0.569	20	
Chromium, Total	98.2	3.00	ug/L	100	1.12	97.1	70-130	0.486	20	
Cobalt, Total	96.7	1.00	ug/L	100	0.399	96.3	70-130	1.34	20	
Copper, Total	94.6	2.00	ug/L	100	0.933	93.6	70-130	0.399	20	
Iron, Total	9770	100	ug/L	10000	ND	97.7	70-130	0.178	20	
Lead, Total	99.0	0.500	ug/L	100	0.0690	99.0	70-130	0.830	20	
Magnesium, Total	18500	100	ug/L	10000	8570	99.6	70-130	1.89	20	
Manganese, Total	107	7.00	ug/L	100	7.85	98.8	70-130	0.507	20	
Molybdenum, Total	105	1.00	ug/L	100	5.65	98.9	70-130	0.339	20	
Nickel, Total	93.8	2.00	ug/L	100	ND	93.8	70-130	0.0352	20	
Selenium, Total	104	5.00	ug/L	100	ND	104	70-130	2.76	20	
Silver, Total	92.3	0.500	ug/L	100	ND	92.3	70-130	0.107	20	
hallium, Total	102	0.500	ug/L	100	0.0400	102	70-130	0.853	20	
în, Total	112	1.00	ug/L	100	18.9	92.6	70-130	0.603	20	
ītanium, Total	104	1.00	ug/L	100	0.626	104	70-130	2.60	20	
linc, Total	177	5.00	ug/L	100	77.3	99.2	70-130	0.783	20	
Batch B4A2877 - No F	Prep									
lank (B4A2877-BLK1)							Pre	nared &	Analyzed: (11/19/24
oc	ND	1.0	mg/L					pareu & /	analyzed: (

SM 5310 C - Quality Control

Eastex Environmental Laboratory - Coldspring

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B4A2877 - No	Prep									
LCS (B4A2877-BS1)							Pı	repared & A	nalyzed:	01/18/2
тос	10.4		mg/L	10.0		104	90-110			
LCS Dup (B4A2877-BS	D1)				**********		Pr	epared & A	nalyzed:	01/18/24
TOC	10.6		mg/L	10.0		106	90-110	1.62	20	
Matrix Spike (B4A2877	-MS1)	ini tanasa seesee	Sou		Pr	epared & A	nalyzed: (01/18/24		
тос	31.2	1.0	mg/L	10.0	19.5	117	80-120			
Batch B4A3008 - No	Prep									
Blank (B4A3008-BLK1)							Pr	epared & A	nalyzed: 0	01/23/24
Nitrate+Nitrite as N	ND	0.02	mg/L							
LCS (B4A3008-BS1)		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,					Pro	epared & A	nalyzed: 0	1/23/24
Nitrate+Nitrite as N	0.926		mg/L	1.00		92.6	90-110			
Matrix Spike (B4A3008-	MS1)		Sour	ce: C4A3012-	01		Pre	pared & Ar	nalyzed: 0	1/23/24
Nitrate+Nitrite as N	5.66	0.02	mg/L	1.00	3.70	196	80-120			23
Matrix Spike Dup (B4A3	008-MSD1)		Sour	ce: C4A3012-	01		Pre	pared & Ar	alyzed: 0	1/23/24
				• • • • • • • • • • • •						

Notes and Definitions

ZZ	Buffer added upon receipt to extend hold time to 28 days as per method.
S	Analysis performed by subcontract lab. Report available upon request.
Cs	Analyses performed at Coldspring Laboratory.
В	Analyte detected in Method Blank.
6	Sample not received within required holding time.
42	Laboratory Error
4	Not cooled to 0-6 degrees Celsius.
3	Sample analysis performed out of holding time.
27	Sample was pre-filtered as required by the method.
23	Spike recovery outside of acceptance limits due to matrix interference.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the reporting limit
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
	*All Metals Analyses performed at Coldspring Laboratory, unless otherwise indicated.

Chain of Custody REVISION 3: 03/01/17

EASTEX ENVIRONMENTAL LAB, INC. P.O. Box 1087 P.O. Box 631373 P.O. Box 631373 Nacogdoches, TX 75963-1373

	1405	01 05 m		7	J	1	120	2.9	2			
See back for instructions	Time	Date		S	1	rogger iii py	. 5	3 0		Date		Alternale Check In:
Received Iced: YES / NO	į				P.	l page d	5	Temp°C Therm ID		Acceptable	Sample Condition Acceptable: Yes / No	LAB USE ONLY
Received Iced: YES / NO	Time	Date			Received By and/or Checked in By:	Received By an		Time	Date			Relinquished By:
	Time	Date		,	y.	Received by:						
Received Iced VES NO		15.24	×	ンコス	1000	Donati	DAM	Time	Date			Relinquished By:
	Timo	Date		>	7	Received By:	Time	Tim	Date 5/2 u		aleb Ross	Relinquished By:
						1		-				
				1	+			-				
			-									
										\dagger		
		-					1	-				
		+										
							-					
				+			+	+				
					-			-		1		
			1 13.	+		1		-		-		
		type pres	1 /5	William din		Ø	1°0		Ţ	1/4/24	NANO WASTE 第	BUTFALL AN
	PA	· ·	±	Temp Matrix	Flow Te	CI2	DO pH	C or G	Time	Date		Sample ID
	ATT)		2					;	Name	Project Name		Froject Number
	s S			1	B	ature	Sampler's Signature	Sa		\$5	CALKEB ROSS	Sampler's Name (print)
	,									7	WEIGHT COTY	P.O. #
ANALYSIS REQUESTED	ANA											Fax#
						,	٠			9386	N	Phone#
					-0/	N440514 -01	NHA				CALEB ROSS	Attn:
		Jentification	Cample and Bottle Identification	Sample		-				ナメ	KIMBYVILE	Address:
			8949	AA (936) 569-	201 202-001 9		Remarks:	R		5.5	SIMPLY AGUATICS	::
			;	75963-1373	Nacogdoches, TX 75963-1373		Coldspring, TX 77329 (936) 653-3249 * (800) 525-0506	Colds 36) 653-3249	6			1

ANALYTICAL REPORT

PREPARED FOR

Attn: Justin Daniel Eastex Environmental Laboratory Inc. 1119 South University Drive (75961) PO BOX 631375

Nacogdoches, Texas 75963-1375

Generated 1/18/2024 5:12:56 PM

JOB DESCRIPTION

N4A0514 010924-G

JOB NUMBER

860-65281-1

Eurofins Houston 4145 Greenbriar Dr Stafford TX 77477

Eurofins Houston

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization

Generated 1/18/2024 5:12:56 PM

Authorized for release by Sylvia Garza, Project Manager Sylvia.Garza@et.eurofinsus.com (832)544-2004

234567

Client: Eastex Environmental Laboratory Inc. Project/Site: N4A0514

Laboratory Job ID: 860-65281-1

SDG: 010924-G

Table of Contents

Cover Page
Table of Contents
Definitions/Glossary
Case Narrative
Detection Summary 6
Client Sample Results
QC Sample Results
QC Association Summary
Lab Chronicle
Certification Summary
Method Summary
Sample Summary
Chain of Custody
Receipt Checklists

Definitions/Glossary

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Job ID: 860-65281-1 SDG: 010924-G

Qualifiers

Genera	I Ch	emi	stry
--------	------	-----	------

Qualifier	Qualifier Description
Н	Sample was prepped or analyzed beyond the specified holding time. This does not meet regulatory requirements.
НЗ	Sample was received and analyzed past holding time. This does not meet regulatory requirements.
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

DL

НЗ	Sample was received and analyzed past holding time. This does not meet regulatory requirements.
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
Glossary	
Abbreviation	These commonly used abbreviations may or may not be present in this report

	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid

Contains No Free Liquid DER Duplicate Error Ratio (normalized absolute difference)

Dil Fac Dilution Factor

Detection Limit (DoD/DOE) DL, RA, RE, IN Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample

DLC Decision Level Concentration (Radiochemistry) EDI Estimated Detection Limit (Dioxin) LOD Limit of Detection (DoD/DOE) LOQ Limit of Quantitation (DoD/DOE)

MCL EPA recommended "Maximum Contaminant Level" MDA Minimum Detectable Activity (Radiochemistry) Minimum Detectable Concentration (Radiochemistry) MDC

MDL Method Detection Limit ML Minimum Level (Dioxin) MPN Most Probable Number MQL Method Quantitation Limit NC Not Calculated

Not Detected at the reporting limit (or MDL or EDL if shown)

ND NEG Negative / Absent POS Positive / Present PQL Practical Quantitation Limit PRES Presumptive

QC Quality Control RER Relative Error Ratio (Radiochemistry) RL

Reporting Limit or Requested Limit (Radiochemistry)

RPD Relative Percent Difference, a measure of the relative difference between two points

TEF Toxicity Equivalent Factor (Dioxin) TEQ Toxicity Equivalent Quotient (Dioxin) TNTC Too Numerous To Count

Eurofins Houston

Case Narrative

Client: Eastex Environmental Laboratory Inc.

Project: N4A0514

Job ID: 860-65281-1

Job ID: 860-65281-1

Job Narrative 860-65281-1

Eurofins Houston

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The sample was received on 1/10/2024 10:17 AM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.2°C

The following sample was received outside of holding time: N4A0514-01 (860-65281-1). MBAS received out of hold

Metals

Method 1631E: The following sample was received with labels already on the vials: N4A0514-01 (860-65281-1)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

General Chemistry

Method 5540C: The following sample was received outside of holding time: N4A0514-01 (860-65281-1).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

3 4 5

Detection Summary

0.50

ng/L

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Mercury

Job ID: 860-65281-1

1631E

SDG: 010924-G

Total/NA

Client Sample ID: N4A0514-01

Lab Sample ID: 860-65281-1 Method Result Qualifier MDL Unit

0.96

Client Sample Results

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Sulfite (SM 4500 SO3 B)

Job ID: 860-65281-1

SDG: 010924-G

Client Sample ID: N4A0514-01

Date Collected: 01/04/24 12:00 Date Received: 01/10/24 10:17

Lab Sample ID: 860-65281-1

01/18/24 10:22

Matrix: Water

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.96		0.50		ng/L		01/16/24 15:11	01/17/24 11:54	
General Chemistry									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Total (EPA 335.4)	ND		0.0050		mg/L		01/15/24 17:41	01/16/24 13:16	1
Methylene Blue Active Substances (SM 5540C)	ND	н нз	0.10		mg/L			01/10/24 10:56	1
Analyte	Result	Qualifier	RL	RL	Unit	D	Prepared	Analyzed	Dil Fac

5.0

mg/L

ND HF

RL

0.50

MDL Unit

4.67

LCSD LCSD

4.75

Result Qualifier

ng/L

ng/L

Unit

ng/L

Job ID: 860-65281-1 SDG: 010924-G

Method:	1631E -	Mercury, L	ow Level	(CVAFS)

Lab Sample ID: MB 400-657878/3-A

Matrix: Water

Analysis Batch: 657941

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 657878

MB MB

ND

Analyte Qualifier Result

Prepared Analyzed Dil Fac 01/16/24 16:00 01/17/24 09:49

Lab Sample ID: LCS 400-657878/4-A

Matrix: Water

Mercury

Analysis Batch: 657941

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 657878

%Rec

79 - 121

Spike LCS LCS Analyte Added Result Qualifier Unit D %Rec Limits Mercury

5.00

Spike

Added

5.00

Lab Sample ID: LCSD 400-657878/5-A

Matrix: Water

Analyte

Mercury

Analysis Batch: 657941

Client Sample ID: Lab Control Sample Dup

Limits

79 - 121

93

%Rec

01/15/24 17:41

Prepared

01/15/24 17:41

95

%Rec

95

D

D

D

95

D

Prep Type: Total/NA

RPD

2

Prep Batch: 657878 RPD

Limit

20

Method: 335.4 - Cyanide, Total

Lab Sample ID: MB 860-140722/31-A

Matrix: Water

Analysis Batch: 140791

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 140722

мв мв

Analyte

MB MB

ND

Result Qualifier

ND

Result Qualifier

RL 0.0050

Spike

Added

0.100

Spike

Added

0.100

RL

0.0050

MDL Unit mg/L

mg/L

Unit

mg/L

Unit

mg/L

MDL Unit

LCS LCS

LCSD LCSD

Result Qualifier

0.0953

0.0953

Result Qualifier

Prepared Analyzed

Dil Fac

Dil Fac

Lab Sample ID: MB 860-140722/4-A

Matrix: Water

Cyanide, Total

Analysis Batch: 140791

Client Sample ID: Method Blank

Analyzed

01/16/24 12:59

01/16/24 13:42

Prep Type: Total/NA

Prep Batch: 140722

Lab Sample ID: LCS 860-140722/5-A

Matrix: Water

Cyanide, Total

Analyte

Analysis Batch: 140791

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 140722

%Rec %Rec Limits 90 - 110

Lab Sample ID: LCSD 860-140722/33-A

Matrix: Water

Analyte

Cyanide, Total

Cyanide, Total

Analysis Batch: 140791

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 140722

%Rec RPD

Limits RPD Limit

90 - 110 4 20

Eurofins Houston

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

SDG: 010924-G

Prep Type: Total/NA

Prep Batch: 140722

Method: 335.4 - Cyanide, Total (Continued)

Lab Sample ID: LLCS 860-140722/6-A Matrix: Water

Analysis Batch: 140791

Cyanide, Total

Spike LLCS LLCS Added

Result Qualifier 0.00350 J

Unit mg/L

%Rec 70

Method: SM 4500 SO3 B - Sulfite

Lab Sample ID: MB 860-141098/1

Matrix: Water

Analysis Batch: 141098

MR MR Analyte

Result Qualifier ND

Sample Sample

ND HF

Result Qualifier

MR MR Result

ND

Qualifier

RL 5.0

0.00500

Spike

Added

Spike

Added

10.0

10.0

Unit RL mg/L

LCS LCS

LCSD LCSD

DU DU

ND

Result Qualifier

MDL Unit

LCS LCS

Qualifier

Result

0.966

mg/L

Unit

mg/L

10.0

Result Qualifier

10.0

Result Qualifier

Unit

mg/L

Unit

mg/L

Unit

mg/L

Prepared

Analyzed 01/18/24 10:22

Dil Fac

RPD

Limit

Lab Sample ID: LCS 860-141098/2

Matrix: Water

Sulfite

Sulfite

Sulfite

Analysis Batch: 141098

Analyte

Lab Sample ID: LCSD 860-141098/3 Matrix: Water

Analysis Batch: 141098

Analyte

Lab Sample ID: 860-65281-1 DU

Matrix: Water Analysis Batch: 141098

Analyte

Sulfite Method: SM 5540C - Methylene Blue Active Substances (MBAS)

Lab Sample ID: MB 860-140279/3 Matrix: Water

Analysis Batch: 140279

Methylene Blue Active Substances

Lab Sample ID: LCS 860-140279/4

Matrix: Water Analysis Batch: 140279

Analyte Methylene Blue Active

Substances

Client Sample ID: Method Blank Prep Type: Total/NA

Client Sample ID: Lab Control Sample

Limits

50 - 150

Client Sample ID: Lab Control Sample

%Rec

Prep Type: Total/NA

%Rec Limits 100 80 - 120

%Rec

100

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA %Rec

Limits

80 - 120

Client Sample ID: N4A0514-01

Prep Type: Total/NA

RPD

0

RPD RPD Limit NC 20

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyzed Prepared Dil Fac 01/10/24 10:27

Client Sample ID: Lab Control Sample

%Rec

Prep Type: Total/NA

%Rec Limits 97 90 - 110

RL

0.10

Spike

Added

1.00

	QC As	sociation Summa	ry		
Client: Eastex Environm			•	150505	ID: 860-65281-1
Project/Site: N4A0514					SDG: 010924-G
Metals					
Prep Batch: 657878					
Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65281-1	N4A0514-01	Total/NA	Water	1631E	
MB 400-657878/3-A	Method Blank	Total/NA	Water	1631E	
LCS 400-657878/4-A	Lab Control Sample	Total/NA	Water	1631E	
LCSD 400-657878/5-A	Lab Control Sample Dup	Total/NA	Water	1631E	
Analysis Batch: 657941					
Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65281-1	N4A0514-01	Total/NA	Water	1631E	657878
MB 400-657878/3-A	Method Blank	Total/NA	Water	1631E	657878
LCS 400-657878/4-A	Lab Control Sample	Total/NA	Water	1631E	657878
LCSD 400-657878/5-A	Lab Control Sample Dup	Total/NA	Water	1631E	657878
General Chemistry					
Analysis Batch: 140279					
Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65281-1	N4A0514-01	Total/NA	Water	SM 5540C	
MB 860-140279/3	Method Blank	Total/NA	Water	SM 5540C	
LCS 860-140279/4	Lab Control Sample	Total/NA	Water	SM 5540C	
Prep Batch: 140722					
Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65281-1	N4A0514-01	Total/NA	Water	Distill/CN	
MB 860-140722/31-A	Method Blank	Total/NA	Water	Distill/CN	
MB 860-140722/4-A	Method Blank	Total/NA	Water	Distill/CN	

Analy	ysis Batc	h: 140791
-------	-----------	-----------

LCS 860-140722/5-A

LCSD 860-140722/33-A

LLCS 860-140722/6-A

Lab Control Sample

Lab Control Sample

Lab Control Sample Dup

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65281-1	N4A0514-01	Total/NA	Water	335.4	140722
MB 860-140722/31-A	Method Blank	Total/NA	Water	335.4	140722
MB 860-140722/4-A	Method Blank	Total/NA	Water	335.4	140722
LCS 860-140722/5-A	Lab Control Sample	Total/NA	Water	335.4	140722
LCSD 860-140722/33-A	Lab Control Sample Dup	Total/NA	Water	335.4	140722
LLCS 860-140722/6-A	Lab Control Sample	Total/NA	Water	335.4	140722

Total/NA

Total/NA

Total/NA

Water

Water

Water

Distill/CN

Distill/CN Distill/CN

Analysis Batch: 141098

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65281-1	N4A0514-01	Total/NA	Water	SM 4500 SO3 B	
MB 860-141098/1	Method Blank	Total/NA	Water	SM 4500 SO3 B	
LCS 860-141098/2	Lab Control Sample	Total/NA	Water	SM 4500 SO3 B	
LCSD 860-141098/3	Lab Control Sample Dup	Total/NA	Water	SM 4500 SO3 B	
860-65281-1 DU	N4A0514-01	Total/NA	Water	SM 4500 SO3 B	

Eurofins Houston

Lab Chronicle

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Job ID: 860-65281-1

SDG: 010924-G

Lab Sample ID: 860-65281-1

Matrix: Water

П

Client Sample ID: N4A0514-01

Date Collected: 01/04/24 12:00

Date Received: 01/10/24 10:17

D T	Batch	Batch	2 00.00	Dil	Initial	Final	Batch	Prepared	EX 020 000	120 12
Prep Type	Туре	Method	Run	Factor	Amount	Amount	Number	or Analyzed	Analyst	Lab
Total/NA	Prep	1631E			40 mL	40 mL	657878	01/16/24 15:11	VLC	EET PEN
		*					Completed:	01/17/24 09:20 1		
Total/NA	Analysis	1631E		1			657941	01/17/24 11:54	VLC	EET PEN
Total/NA	Prep	Distill/CN			6 mL	6 mL	140722	01/15/24 17:41	LD	EET HOL
Total/NA	Analysis	335.4		1			140791	01/16/24 13:16	LD	EET HOU
Total/NA	Analysis	SM 4500 SO3 B		1	50 mL	50 mL	141098	01/18/24 10:22	SCI	EET HOU
Total/NA	Analysis	SM 5540C		1	100 mL	100 mL	140279	01/10/24 10:56	JM	EET HOL

This procedure uses a method stipulated length of time for the process. Both start and end times are displayed.

Laboratory References:

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

EET PEN = Eurofins Pensacola, 3355 McLemore Drive, Pensacola, FL 32514, TEL (850)474-1001

Accreditation/Certification Summary

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Job ID: 860-65281-1 SDG: 010924-G

Laboratory: Eurofins Houston

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arkansas DEQ	State	88-00759	08-03-24
Florida	NELAP	E871002	06-30-24
Louisiana (All)	NELAP	03054	06-30-24
Oklahoma	NELAP	1306	08-31-24
Oklahoma	State	2023-139	08-31-24
Texas	NELAP	T104704215-23-53	06-30-24
Texas	TCEQ Water Supply	T104704215	12-28-25
USDA	US Federal Programs	525-23-79-79507	03-20-26

Laboratory: Eurofins Pensacola

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Alabama	State	40150	06-30-24
ANAB	ISO/IEC 17025	L2471	02-22-26
Arkansas DEQ	State	88-00689	08-01-24
California	State	2510	06-30-24
Florida	NELAP	E81010	06-30-24
Georgia	State	E81010(FL)	06-30-24
Illinois	NELAP	200041	10-09-24
Kansas	NELAP	E-10253	10-31-24
Kentucky (UST)	State	53	06-30-24
Louisiana (All)	NELAP	30976	06-30-24
Louisiana (DW)	State	LA017	12-31-24
North Carolina (WW/SW)	State	314	12-31-24
Oklahoma	NELAP	9810	08-31-24
Pennsylvania	NELAP	68-00467	01-31-24
South Carolina	State	96026	06-30-24
Tennessee	State	TN02907	06-30-24
Texas	NELAP	T104704286	09-30-24
JS Fish & Wildlife	US Federal Programs	A22340	06-30-24
JSDA	US Federal Programs	FLGNV23001	01-08-26
JSDA	US Federal Programs	P330-21-00056	05-17-24
/irginia	NELAP	460166	06-14-24
Vest Virginia DEP	State	136	03-31-24
West Virginia DEP	State	136	03-31-24

Method Summary

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Job ID: 860-65281-1 SDG: 010924-G

Method	Method Description	Protocol	Laboratory
1631E	Mercury, Low Level (CVAFS)	EPA	EET PEN
335.4	Cyanide, Total	EPA	EET HOU
SM 4500 SO3 B	Sulfite	SM	EET HOU
SM 5540C	Methylene Blue Active Substances (MBAS)	SM	EET HOU
1631E	Preparation, Mercury, Low Level	EPA	EET PEN
Distill/CN	Distillation, Cyanide	None	EET HOU

Protocol References:

EPA = US Environmental Protection Agency

None = None

SM = "Standard Methods For The Examination Of Water And Wastewater"

Laboratory References:

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200 EET PEN = Eurofins Pensacola, 3355 McLemore Drive, Pensacola, FL 32514, TEL (850)474-1001

Sample Summary

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Job ID: 860-65281-1 Sx G:8m m9c4LG

2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
860-65281-1	N4A0514-01	Water	01/04/24 12:00	01/10/24 10:17

3

4

5

6

0

q

10

11

12

13



Tel. 936 569 8879 Email, eelnac@sbcglobal.net Website eastexlabs com PO Box 631375 Nacogdoches Tx 75963



SUBCONTRACT ORDER

Subcontracted Laboratory:

Fax 713-690-5646 Phone, 713-690-4444 Stafford, XT , broffet? 4147 Greenbriar Dr. Eurofins Xenco LLC

sending Laboratory:

Fax, 936-569-8951 Phone 936-569-8879 Nacogdoches, TX 75961 1119 South University Drive Eastex Environmental Laboratory - Nacogdoches

Project Manager Paul Hughes

MOTK Order: N4A0514

Analysis to be Performed

Water Sampled, 01/04/2024 12,00 Sample ID N4A0514-01[none] Sample Date Matrix Sample 1D

P 500, Iced (X)

Outfall Nano Waste WC#1 Sample Site

0

:Od

P 1000, Iced (W)

01/18/2024

P 1000, Iced, NaOH (M)

01/18/2024 01/18/2024 01/18/2024

Due

P 1000, 1ced, HNO3 (L)

Containers Supplied. Surfactants (MBAS)


P 125, Iced, H2504 (3)

Sulfite

Mercury LL

Cyanide, Total

S MamaT bestoenoo 2 P qmeT 5 P



:STNBMMO:

Released By

500 Date & Time Received By Date & Time Released By

Received By

Date 8 Time Received By Date & Time

Date & Time

Released By

1

456

8

9

13

M961 00-S1 / \$202/6/1 BMIT/3TAO TURA

Date & Time

Eurofins Houston

4145 Greenbriar Dr Stafford, TX 77477 Phone: 281-240-4200	Chain of	Chain of Custody Record	cord		Seurofins Environment Tashing
Client Information (Sub Contract Lab)	Sampler:	Lab PM Garza	Lab PM: Garza, Sylvia	Carrier Tracking No(s):	COC No:
Crient Contact Shipping/Receiving	Phone:	E-Mail:	E-Mail:	State of Origin:	Page:
Company: Eurofins Environment Testing Southeast.		Sylvia	a. Carza@er.eurofinsus.com Accreditations Required (See note):	Texas	Page 1 of 1 Job #:
Address: 3355 Mr emore Drive	Due Date Requested:	2	NELAP - lexas		860-65281-1
City:	1/18/2024		Analysis	Analysis Requested	M - Hexane
Pensacola State, Zip: FL, 32514	A requested (days):				B - NaCht None C - Zn Acetite O AsnaO2 C - Zn Acetite O Nitric Acid O Ni
Phone: 850-474-1001(Tel) 850-478-2671(Fax)	PO#				E - NaHSO4 C - Na2S203 F - MeOH R - Na2S203 G - Amchlor S - H2SO4
Email:	WO#.				ъ
Project Name: N4A0514-01	Project #;				J - DI Water K - EDTA
Site:	SSOW#;		səy) C		Other:
		Т	ISW/		ו סף נ
Sample Identification - Client ID /I ah ID)	Sample		ə₁E∖₁eэ₁E¯		edmuM lad
		Preservation Code:	4		Special Instructions/Note:
N4A0514-01 (860-65281-1)	12:00				
	1/4/24 Central	Water	×		2
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is flowarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin fisted above for analysis/lasts/main/x being analyzed, the samples must be shipped back to the Eurofins Environment Testing South Central. LLC altention with a single South Central. LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central. LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central. LLC.	nt Testing South Central, LLC places the or bove for analysis/lests/matrix being analyzientral, LLC attention immediately. If all required.	wnership of method, analyte ed, the samples must be sh uested accreditations are cr	s & accreditation compliance upon our si ipped back to the Eurofins Environment irrent to date, return the signed Chain of	bcontract laboratories. This sample sh festing South Central, LLC laboratory o Custody attesting to said compliance to	pment is forwarded under chain-of-custody. If the r other instructions will be provided. Any changes to Eurofins Environment Testing South Central. L.L.C.
Possible Hazard Identification			Sample Disposal (A fee may	Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)	stained longer than 1 month)
Deliverable Requested: 1 III IV Other (consists)		Fi.	Retum To Client	Disposal By Lab	Archive For Months
(specify)	Primary Deliverable Rank: 2		Special Instructions/QC Requirements	ements:	
Empty Kit Relinquished by:	Date:		Time:	Method of Shipment:	
Commodified by	1 42,	Sas company	Received by:	Date/Time:	17 47 Company
relinquistred by:		Company	1	Date/Time:	9
	Date/Time:	Company	Received by.	Date/Time:	Сотралу
Custody Seals Intact: Custody Seal No.: Δ Yes Δ No			Cooler Temperature(s) °C and Other Remarks:	her Remarks:	

Login Sample Receipt Checklist

Client: Eastex Environmental Laboratory Inc.

Job Number: 860-65281-1

SDG Number: 010924-G

List Source: Eurofins Houston

Login Number: 65281 List Number: 1

Creator: Torrez, Lisandra

,			
Question	Answer	Comment	
Radioactivity wasn't checked or is = background as measured by a survey meter.</td <td>True</td> <td></td> <td></td>	True		
The cooler's custody seal, if present, is intact.	True		
Sample custody seals, if present, are intact.	N/A		
The cooler or samples do not appear to have been compromised or tampered with.	True		
Samples were received on ice.	True		
Cooler Temperature is acceptable.	True		
Cooler Temperature is recorded.	True		
COC is present.	True		
COC is filled out in ink and legible.	True		
COC is filled out with all pertinent information.	True		
Is the Field Sampler's name present on COC?	True		
There are no discrepancies between the containers received and the COC.	True		
Samples are received within Holding Time (excluding tests with immediate HTs)	False	Received out of hold MBAS	
Sample containers have legible labels.	True		
Containers are not broken or leaking.	True		
Sample collection date/times are provided.	True		
Appropriate sample containers are used.	True		
Sample bottles are completely filled.	True		
Sample Preservation Verified.	True		
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True		
Containers requiring zero headspace have no headspace or bubble is	True		

True

True

True

<6mm (1/4").

Multiphasic samples are not present.

Residual Chlorine Checked.

Samples do not require splitting or compositing.

Login Sample Receipt Checklist

Client: Eastex Environmental Laboratory Inc.

Login Number: 65281

Sample bottles are completely filled.

Multiphasic samples are not present.

Residual Chlorine Checked.

Samples do not require splitting or compositing.

There is sufficient vol. for all requested analyses, incl. any requested

Containers requiring zero headspace have no headspace or bubble is

Sample Preservation Verified.

MS/MSDs

<6mm (1/4").

List Number: 2

Job Number: 860-65281-1

SDG Number: 010924-G

List Source: Eurofins Pensacola List Creation: 01/13/24 11:58 AM

1	-	10
1	5	11
×	v,	11

			List Creation: 01/13/24 11:58 AM
Creator: Pardonner, Brett			
Question	Answer	Comment	
Radioactivity wasn't checked or is = background as measured by a survey meter.</td <td>N/A</td> <td></td> <td></td>	N/A		
The cooler's custody seal, if present, is intact.	N/A		
Sample custody seals, if present, are intact.	N/A		
The cooler or samples do not appear to have been compromised or tampered with.	True		
Samples were received on ice.	True		
Cooler Temperature is acceptable.	True		
Cooler Temperature is recorded.	True	0.2°C IR8	
COC is present.	True		
COC is filled out in ink and legible.	True		
COC is filled out with all pertinent information.	True		
Is the Field Sampler's name present on COC?	True		
There are no discrepancies between the containers received and the COC.	True		
Samples are received within Holding Time (excluding tests with immediate HTs)	True		
Sample containers have legible labels.	True		
Containers are not broken or leaking.	True		
Sample collection date/times are provided.	True		
Appropriate sample containers are used.	True		

True

N/A

True

N/A

True

True

N/A

PREPARED FOR

Attn: Justin Daniel Eastex Environmental Laboratory Inc. 1119 South University Drive (75961)

ANALYTICAL REPORT

PO BOX 631375

Nacogdoches, Texas 75963-1375 Generated 1/27/2024 11:25:22 PM

JOB DESCRIPTION

N4A0514

JOB NUMBER

860-65828-1

Eurofins Houston 4145 Greenbriar Dr Stafford TX 77477

EOL.

Eurofins Houston

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization

Generated 1/27/2024 11:25:22 PM

Authorized for release by Sylvia Garza, Project Manager Sylvia.Garza@et.eurofinsus.com (832)544-2004

Client: Eastex Environmental Laboratory Inc. Project/Site: N4A0514

Laboratory Job ID: 860-65828-1

Table of Contents

Cover Page	1
TILLICO	3
Definitions/Glossary	4
Case Narrative	5
D-4	6
Client Sample Results	7
00.0	8
QC Association Summary	9
Lab Chronicle	10
Certification Summary	11
Method Summary	12
Sample Summary	13
	14
Receipt Checklists	15

Definitions/Glossary

Client: Eastex Environmental Laboratory Inc. P6 jb2l/Sllb:eN4Aaxr4

Job ID: 860-65828-1

Qualifiers

General Chemistry

Qualifier

Qualifier Description

Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation These commonly used abbreviations may or may not be present in this report. Listed under the "D" column to designate that the result is reported on a dry weight basis %R Percent Recovery CFL Contains Free Liquid CFU Colony Forming Unit CNF Contains No Free Liquid

DER Duplicate Error Ratio (normalized absolute difference)

Dil Fac Dilution Factor

DL Detection Limit (DoD/DOE)

DL, RA, RE, IN Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample

DIC Decision Level Concentration (Radiochemistry)

EDL Estimated Detection Limit (Dioxin) LOD Limit of Detection (DoD/DOE) LOQ Limit of Quantitation (DoD/DOE)

MCI EPA recommended "Maximum Contaminant Level" MDA Minimum Detectable Activity (Radiochemistry) MDC Minimum Detectable Concentration (Radiochemistry)

MDL Method Detection Limit ML Minimum Level (Dioxin) MPN Most Probable Number MQL Method Quantitation Limit

NC Not Calculated

ND Not Detected at the reporting limit (or MDL or EDL if shown)

NEG Negative / Absent POS Positive / Present

POL Practical Quantitation Limit

PRES Presumptive QC **Quality Control**

RER Relative Error Ratio (Radiochemistry)

RI Reporting Limit or Requested Limit (Radiochemistry)

RPD Relative Percent Difference, a measure of the relative difference between two points

TEF Toxicity Equivalent Factor (Dioxin) TEQ Toxicity Equivalent Quotient (Dioxin)

TNTC Too Numerous To Count

Case Narrative

Client: Eastex Environmental Laboratory Inc.

Project: N4A0514

Job ID: 860-65828-1

Job ID: 860-65828-1

Eurofins Houston

Job Narrative 860-65828-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- · Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The sample was received on 1/18/2024 11:07 AM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.8°C

Receipt Exceptions

Only received TKN bottle. Per client, only TKN is needed

General Chemistry

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

1

2

3

5

0

1

10

12

13

Detection Summary

Client: Eastex Environmental Laboratory Inc.

P6 jb2/Slb:eN4Aaxr4

Job ID: 860-65828-1

2

Client	Sample	ID:	N4A0	514-01
--------	--------	-----	------	--------

Lab Sample ID: 860-65828-1

T										
ı	Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
L	Nitrogen, Kjeldahl	2.2		2.0		mg/L	1	_	351.2	Total/NA

4

5

6

7

8

10

11

12

13

Client Sample Results

Client: Eastex Environmental Laboratory Inc.

P6 jb2l/Sllb:eN4Aaxr4

Job ID: 860-65828-1

Client Sample ID: N4A0514-01

Date Collected: 01/04/24 12:00 Date Received: 01/18/24 11:07

Lab Sample ID: 860-65828-1

Matrix: Water

General Chemistry Analyte

Nitrogen, Kjeldahl (EPA 351.2)

Result Qualifier 2.2

RL 2.0 MDL Unit

D mg/L

Prepared 01/25/24 10:03

Analyzed Dil Fac 01/26/24 16:42

QC Sample Results

Client: Eastex Environmental Laboratory Inc. P6 jb2/Slb:eN4Aaxr4

Job ID: 860-65828-1

2

Method:	351.2 -	Nitrogen,	Total	Kjeldahl
---------	---------	-----------	--------------	----------

Lab Sample ID: MB 860-142129/4-A	Client Sample ID: Method Blank
Matrix: Water	Prep Type: Total/NA

Matrix: Water

Analysis Batch: 142453

MB MB

Prep Type: Total/NA

Prep Batch: 142129

 Analyte
 Result
 Qualifier
 RL
 MDL
 Unit
 D
 Prepared
 Analyzed
 DII Fac

 Nitrogen, Kjeldahl
 ND
 0.20
 mg/L
 01/25/24 10:03
 01/26/24 16:38
 1

Lab Sample ID: LCS 860-142129/6-A Client Sample ID: Lab Control Sample Matrix: Water Prep Type: Total/NA Analysis Batch: 142453 Prep Batch: 142129 Spike LCS LCS Analyte Added Result Qualifier Unit Limits %Rec Nitrogen, Kjeldahl 2.00 1.84 mg/L 92 90 - 110

Lab Sample ID: LCSD 860-142129/7-A

Client Sample ID: Lab Control Sample Dup
Matrix: Water

Prep Type: Total/NA
Analysis Batch: 142453

Prep Batch: 142129

Spike LCSD LCSD Analyte Added Result Qualifier Unit Limits %Rec RPD Limit Nitrogen, Kjeldahl 2.00 1.81 mg/L 90 - 110 2 20

Lab Sample ID: LLCS 860-142129/5-A

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 142453

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 142129

 Spike
 LLCS
 LLCS
 LLCS
 %Rec

 Analyte
 Added
 Result
 Qualifier
 Unit
 D
 %Rec
 Limits

 Nitrogen, Kjeldahl
 0.200
 0.194
 J
 mg/L
 97
 50 - 150

Eurofins Houston

QC Association Summary

Client: Eastex Environmental Laboratory Inc.

P6 jb2l/SILb:eN4Aaxr4

Job ID: 860-65828-1

General Chemistry

Prep Batch: 142129

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65828-1	N4A0514-01	Total/NA	Water	351.2	
MB 860-142129/4-A	Method Blank	Total/NA	Water	351.2	
LCS 860-142129/6-A	Lab Control Sample	Total/NA	Water	351.2	
LCSD 860-142129/7-A	Lab Control Sample Dup	Total/NA	Water	351.2	
LLCS 860-142129/5-A	Lab Control Sample	Total/NA	Water	351.2	

Analysis Batch: 142453

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-65828-1	N4A0514-01	Total/NA	Water	351,2	142129
MB 860-142129/4-A	Method Blank	Total/NA	Water	351.2	142129
LCS 860-142129/6-A	Lab Control Sample	Total/NA	Water	351.2	142129
LCSD 860-142129/7-A	Lab Control Sample Dup	Total/NA	Water	351.2	142129
LLCS 860-142129/5-A	Lab Control Sample	Total/NA	Water	351.2	142129

Lab Chronicle

Client: Eastex Environmental Laboratory Inc.

Client Sample ID: N4A0514-01

Date Collected: 01/04/24 12:00

Date Received: 01/18/24 11:07

Project/Site: N4A0514

Job ID: 860-65828-1

2

Lab Sample ID: 860-65828-1

Matrix: Water

	Batch	Batch		Dil	Initial	Final	Batch	Prepared		
Prep Type	Туре	Method	Run	Factor	Amount	Amount	Number	or Analyzed	Analyst	Lab
Total/NA	Prep	351.2			2 mL	20 mL	142129	01/25/24 10:03	LD	EET HOU
Total/NA	Analysis	351.2		1			142453	01/26/24 16:42	ΔΔ	EET HOU

5

Laboratory References:

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

7

8

40

11

12

13

Accreditation/Certification Summary

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Job ID: 860-65828-1

Laboratory: Eurofins Houston

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arkansas DEQ	State	88-00759	08-03-24
Florida	NELAP	E871002	06-30-24
Louisiana (All)	NELAP	03054	06-30-24
Oklahoma	NELAP	1306	08-31-24
Oklahoma	State	2023-139	08-31-24
Texas	NELAP	T104704215-23-53	06-30-24
Texas	TCEQ Water Supply	T104704215	12-28-25
USDA	US Federal Programs	525-23-79-79507	03-20-26

1

3

4

5

6

7

0

40

14

12

13

Method Summary

Client: Eastex Environmental Laboratory Inc. P6 jb2/Slb:eN4Aaxr4

Job ID: 860-65828-1

Ь	9	2	
6	í		

Method	Method Description	Protocol	Laboratory
351.2	Nitrogen, Total Kjeldahl	EPA	EET HOU
351.2	Nitrogen, Total Kjeldahl	EPA	EET HOU

1

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

5

6

7

8

40

14

12

13

Sample Summary

Client: Eastex Environmental Laboratory Inc.

Project/Site: N4A0514

Job ID: 860-65828-1

2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
860-65828-1	N4A0514-01	Water	01/04/24 12:00	01/18/24 11:07

3

4

5

_

0

9

10

13



PO Box 631375 Nacogdoches Tx 75963 Website eastexlabs com Email. eelnac@sbcglobal.net Tel 936 569 8879



SUBCONTRACT ORDER

Sending Laboratory:

Eastex Environmental Laboratory - Nacogdoches 1119 South University Drive Nacogdoches, TX 75961 Phone 936-569-8879 Fax 936-569-8951

Project Manager Paul Hughes

Subcontracted Laboratory:

Eurofins Xenco LLC 4147 Greenbriar Dr. Stafford, TX 77477 Phone, 713-690-4444

Fax 713-690-5646

Work Order: N4A0514

011624-6 PO:

Analysis to be Performed

Sample ID

Matrix

Sample Date

Sample ID. N4A0514-01[none]

Water Sampled 01/04/2024 12.00

Outfall Nano Waste WC#1

Cyanide, Total Mercury LL Sulfite Surfactants (MBAS) TKN as N

SHETAT 01/18/2024 01/18/2024 01/18/2024 01/18/2024 01/08/2024

Due

Sample Site

Containers Supplied P 125, Iced, H2SO4 (J)

P 500, Iced (X)

P 1000, Iced, HNO3 (L)

P 1000, Iced, NaOH (M)

P 250, Iced (Q)

P 1000, Iced (W)



IR ID-HOU-369 Temp:0 B C/F - 0.0 Corrected Temp. 0 8

COMMENTS:

Released By

Released By

Released By

Date & Time

Date & Time

Received By

ans

Received By

Received By

1/18/24 1107

Date & Time

PRINT DATE/TIME: 1/16/2024 / 11:00:06AM

Page 1 of 1

Login Sample Receipt Checklist

Client: Eastex Environmental Laboratory Inc.

Job Number: 860-65828-1

Login Number: 65828

List Source: Eurofins Houston

List Number: 1

Creator: Jimenez, Nicanor

Multiphasic samples are not present.

Residual Chlorine Checked.

Samples do not require splitting or compositing.

andari annonima internet			9
Question	Answer	Comment	
Radioactivity wasn't checked or is = background as measured by a survey meter.</td <td>True</td> <td></td> <td></td>	True		
The cooler's custody seal, if present, is intact.	N/A		
Sample custody seals, if present, are intact.	True		
The cooler or samples do not appear to have been compromised or tampered with.	True		
Samples were received on ice.	True		
Cooler Temperature is acceptable.	True		
Cooler Temperature is recorded.	True		
COC is present.	True		
COC is filled out in ink and legible.	True		
COC is filled out with all pertinent information.	True		
Is the Field Sampler's name present on COC?	True		
There are no discrepancies between the containers received and the COC.	True		
Samples are received within Holding Time (excluding tests with immediate HTs)	True		
Sample containers have legible labels.	True		
Containers are not broken or leaking.	True		
Sample collection date/times are provided.	True		
Appropriate sample containers are used.	False		
Sample bottles are completely filled.	True		
Sample Preservation Verified.	True		
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	False		
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True		

True

True

True

ATTACHMENT 13

EPAY VOUCHERS

Shopping Cart

Select Fee

Search Transactions

Sign Out

Print this voucher for your records. If you are sending the TCEQ hardcopy documents related to this payment, include a copy of this voucher.

Transaction Information

Voucher Number: 700274

Trace Number: 582EA000605405

Date: 04/05/2024 03:02 PM

Payment Method: CC - Authorization 000007529G

Voucher Amount: \$300.00

Fee Type: WW PERMIT - MINOR FACILITY NOT SUBJECT TO 40 CFR 400-471 - NEW

ePay Actor: ERNESTO MAXIMILLIAN COOK

Actor Email: max@rangerenv.com

IP: 67.79.4.106

Payment Contact Information

Name: ERNESTO MAXIMILLIAN COOK
Company: RANGER ENVIRONMENTAL

Address: 7215 MCNEIL DRIVE, AUSTIN, TX 78729

Phone: 512-335-1785

Site Information

Site Name: WRIGHT CITY WSC 1

Site Address: 18523 FM 2089, OVERTON, TX 75684

Site Location: LOCATION ON E SIDE OF FM 2089 NORTH OF HIGHWAY 64

Customer Information -

CN: CN600675284

Customer Name: WRIGHT CITY WSC

Customer Address: 24065 LYLES LANE, TROUP, TX 75789 5502

State Franchise Tax ID: 32027163594

Close

Site Help | Disclaimer | Web Policies | Accessibility | Our Compact with Texans | TCEQ Homeland Security | Contact Us Statewide Links: Texas.gov | Texas Homeland Security | TRAIL Statewide Archive | Texas Veterans Portal

Shopping Cart

Select Fee

Search Transactions

Sign Out

Print this voucher for your records. If you are sending the TCEQ hardcopy documents related to this payment, include a copy of this voucher.

Transaction Information

Voucher Number: 700275

Trace Number: 582EA000605405

Date: 04/05/2024 03:02 PM

Payment Method: CC - Authorization 000007529G

Voucher Amount: \$50.00

Fee Type: 30 TAC 305.53B WQ NOTIFICATION FEE

ePay Actor: ERNESTO MAXIMILLIAN COOK

Actor Email: max@rangerenv.com

IP: 67.79.4.106

Payment Contact Information

Name: ERNESTO MAXIMILLIAN COOK
Company: RANGER ENVIRONMENTAL

Address: 7215 MCNEIL DRIVE, AUSTIN, TX 78729

Phone: 512-335-1785

Close

Site Help | Disclaimer | Web Policies | Accessibility | Our Compact with Texans | TCEQ Homeland Security | Contact Us Statewide Links: Texas.gov | Texas Homeland Security | TRAIL Statewide Archive | Texas Veterans Portal

© 2002-2024 Texas Commission on Environmental Quality

ATTACHMENT 14

SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

(TCEQ 20971)

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

ı	
	TCEQ USE ONLY:
	Application type:RenewalMajor AmendmentMinor AmendmentNew
1	County: Segment Number:
ı	Admin Complete Date:
	Agency Receiving SPIF:
	Texas Historical Commission U.S. Fish and Wildlife
	Texas Parks and Wildlife Department U.S. Army Corps of Engineers
1	This form applies to TPDES permit applications only. (Instructions, Page 53)
i	Complete this form as a separate document. TCEQ will mail a copy to each agency as required by our agreement with EPA. If any of the items are not completely addressed or further information is needed, we will contact you to provide the information before issuing the permit. Address each item completely.
a	Do not refer to your response to any item in the permit application form. Provide each attachment for this form separately from the Administrative Report of the application. The application will not be declared administratively complete without this SPIF form being completed in its entirety including all attachments. Questions or comments concerning this form hay be directed to the Water Quality Division's Application Review and Processing Team by email at WQ-ARPTeam@tceq.texas.gov or by phone at (512) 239-4671.
I	The following applies to all applications:
l	. Permittee: Wright City WSC
	Permit No. WQ00 EPA ID No. TX
	Address of the project (or a location description that includes street/highway, city/vicinity, and county):
	18523 FM 2089, Overton, Texas 75684, Smith County
	·

		Disturbance of vegetation or wetlands
1.	or cave	oposed construction impact (surface acres to be impacted, depth of excavation, sealinges, or other karst features):
	N/A	
2.	Describ	be existing disturbances, vegetation, and land use: 1 consist of a 500 Pound propane tank, booster pump room, Generator with awning,
	pressi	are tanks, storage room with chlorinators, and water storage tanks. This equipment is native vegetation.
THI AM	E FOLLO	OWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR NTS TO TPDES PERMITS
3.	List con	struction dates of all buildings and structures on the property:
	treatm compa	28' x 10' cinder block building built to house the nanofiltration and current water ent chemicals. No architect was involved. Built by Kenneth Orr Construction ny out of Henderson, TX. They have another small building that houses their
	<u>chlorir</u>	nation equipment and booster pumps, we do not know when it was built but it has nere at least 20 years.
4.]	Provide	a brief history of the property, and name of the architect/builder, if known.
	Wright	City WSC has been public water supply since 1967, this property and water well een providing water since then.

ATTACHMENT 15

PLAIN LANGUAGE SUMMARY

(TCEQ 20972)



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by <u>Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H.</u> Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in <u>30 TAC Section 39.426</u>, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS INDUSTRIAL WASTEWATER/STORMWATER


The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Wright City WSC (CN#600675284) operates Wright City WSC #1 (RN#101237063), a public water supply (facility). The facility is located at 18523 FM 2089 (approximate GPS coordinates 32.20154, -94.99400), in Overton, Smith County, Texas 75684. This is a request for a new industrial wastewater permit to discharge approximately 54,000 gallons per day of reject water. The discharge (reject water) will consist of untreated groundwater that has been processed through a nanofiltration system that removes larger molecules and ions from the water, such as organic matter, bacteria, calcium, and magnesium. This permit will not authorize a discharge of pollutants into water in the state.

The facility supports a public water supply system that filters groundwater for public use. Groundwater is collected and will go through a two-stage nanofiltration process where larger molecules and ions are stripped from the water prior to public use. The reject water that contains the larger molecules and ions will be discharged at the facility to a roadside ditch

along FM 2089. The discharge will then flow to an unnamed tributary which flows to Wright Branch and then to Bowles Creek (Segment Number 0611V).

Discharges from the facility are expected to contain no chemicals of concern. The reject water will be discharged only after going through a two-stage nanofiltration process; there are no chemical additives to the reject water.



NUMBERS CORRESPOND TO AFFECTED LANDOWNER INFORMATION MAP PROPERTY IDENTIFICATION IDS

- 1) MICHAEL W HARDIN 18282 FM 2089 OVERTON TX 75648
- 2) DANNY PAUL STEPHENSON AND AMY INEZ 18871 FM 2089 OVERTON TX 75684-4493
- DANNY P STEPHENSON AND AMY L
 18871 FM 2089
 OVERTON TX 75684-4493
- 4) HEATHER R AND TRACY L EVANS 17756 FM 2089 OVERTON TX 75684-4443
- 5) HEATHER R AND TRACY L EVANS 17756 FM 2089 OVERTON TX 75684
- 6) DANNY P STEPHENSON AND AMY L 18871 FM 2089 OVERTON TX 75684
- 7) JACOB D AND KORTNI R KING 24670 STATE HIGHWAY 64 E TROUP TX 75789
- 8) CHARLES B WEITERMAN 23090 HWY 64E TROUP TX 75789
- 9) JOHN AND SANDRA PARNELL TODD 108 HILLVIEW DR HENDERSON TX 75652
- 10) JERRY MATHIS 25332 FM 15 TROUP TX 75789
- 11) ROY L KINGRY JR AND JULIA HWANG 8704 PALUXY DR TYLER TX 75703-5942

MICHAEL W HARDIN 18282 FM 2089 OVERTON TX 75648

DANNY P STEPHENSON AND AMY L 18871 FM 2089 OVERTON TX 75684-4493

HEATHER R AND TRACY L EVANS 17756 FM 2089 OVERTON TX 75684-4443


JACOB D AND KORTNI R KING 24670 STATE HIGHWAY 64 E TROUP TX 75789


CHARLES B WEITERMAN 23090 HWY 64E TROUP TX 75789

JOHN AND SANDRA PARNELL TODD 108 HILLVIEW DR HENDERSON TX 75652

JERRY MATHIS 25332 FM 15 TROUP TX 75789

ROY L KINGRY JR AND JULIA HWANG 8704 PALUXY DR TYLER TX 75703-5942







TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. Box 13087 Austin, Texas 78711-3087

PERMIT TO DISCHARGE WASTES

under provisions of Section 402 of the Clean Water Act and Chapter 26 of the Texas Water Code

Wright City Water Supply Corporation

whose mailing address is

24065 Lyles Lane Troup, Texas 75789

is authorized to treat and discharge wastes from Wright City Water Supply Corporation (WSC), public water supply facility (SIC 4941)

TPDES PERMIT NO. WQ0005459000

[For TCEQ office use only - EPA I.D. No. TX0145963]

located at 18523 Farm-to-Market 2089, in the City of Overton, Smith County, Texas 75684

from the plant to an unnamed ditch; thence to an unnamed tributary; thence to Wright Branch; thence to Bowles Creek; thence to Striker Creek; thence to Lake Striker; thence to Striker Creek; thence to Angelina River Above Sam Rayburn Reservoir in Segment No. 0611 of the Neches River Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does not grant to the permittee the right to use private or public property for conveyance of wastewater along the discharge route described in this permit. This includes, but is not limited to, property belonging to any individual, partnership, corporation, or other entity. Neither does this permit authorize any invasion of personal rights nor any violation of federal, state, or local laws or regulations. It is the responsibility of the permittee to acquire property rights as may be necessary to use the discharge route.

This permit shall expire at midnight, five years from the date of permit issuance.

ISSUED DATE:		
	For the Commission	

1. During the period beginning upon the date of permit issuance and lasting through the date of permit expiration, the permittee is authorized to discharge water treatment wastes ¹ subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.054 million gallons per day (MGD).

	Disc	charge Limitations	Minimum Self-Monitoring Requirements		
Effluent Characteristics	Daily Average	Daily Maximum	Single Grab	Report Daily Average and	Daily Maximum
	mg/L	mg/L	mg/L	Measurement Frequency	Sample Type
Flow	0.054 MGD	Report, MGD	N/A	Continuous	Record
Dissolved Aluminum ²	Report	Report	N/A	1/week	Grab
Total Aluminum ²	Report	Report	N/A	1/week	Grab
Total Dissolved Solids ²	N/A	Report	N/A	1/month	Grab
Chloride ²	N/A	Report	N/A	1/month	Grab
Sulfate ²	N/A	Report	N/A	1/month	Grab

- 2. The pH must not be less than 6.0 standard units nor greater than 9.0 standard units and must be monitored 1/week by grab sample.
- 3. There must be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 4. Effluent monitoring samples must be taken at the following location: At Outfall 001, at roadside ditch along Farm-to-Market 2089 Road.

Page 2 of TPDES Permit No. WQ0005459000

Wright City Water Supply Corporation

¹ See Other Requirement No. 3.

² This monitoring requirement begins upon the date of issuance of permit and expires 58 months after date of permit issuance..

DEFINITIONS AND STANDARD PERMIT CONDITIONS

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC §§305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in Texas Water Code §26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

1. Flow Measurements

- a. Annual average flow the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder, and limited to major domestic wastewater discharge facilities with a one million gallons per day or greater permitted flow.
- b. Daily average flow the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) the highest 2-hour peak flow for any 24-hour period in a calendar month.

2. Concentration Measurements

- a. Daily average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
 - i. For domestic wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.
 - ii. For all other wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the "daily discharge" is calculated as the total

mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the sampling day.

The "daily discharge" determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the "daily discharge" determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.

- e. Bacteria concentration (Fecal coliform, *E. coli*, or Enterococci) the number of colonies of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the nth root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substitute value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
- f. Daily average loading (lbs/day) the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD × Concentration, mg/L × 8.34).
- g. Daily maximum loading (lbs/day) the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.

3. Sample Type

- a. Composite sample For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC §319.9(a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC §319.9(c).
- b. Grab sample an individual sample collected in less than 15 minutes.
- 4. Treatment Facility (facility) wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
- 5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
- 6. Bypass the intentional diversion of a waste stream from any portion of a treatment facility.

MONITORING AND REPORTING REQUIREMENTS

1. Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Enforcement Division (MC 224), by the 20th day of the following month for each discharge that is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act; TWC Chapters 26, 27, and 28; and THSC Chapter 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or realistic to the complete of noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§319.11 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

3. Records of Results

- a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.
- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR §264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:

 - i. date, time, and place of sample or measurement;ii. identity of individual who collected the sample or made the measurement;
 - iii. date and time of analysis;
 - iv. identity of the individual and laboratory who performed the analysis;
 - v. the technique or method of analysis; and
 - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report

5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site or shall be readily available for review by a TCEQ representative for a period of three years.

6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the regional office and the Enforcement Division (MC

7. Noncompliance Notification

- a. In accordance with 30 TAC §305.125(9) any noncompliance that may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Report of such information shall be provided orally or by facsimile transmission (FAX) to the regional office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the regional office and the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective September 1, 2020, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
- b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:

i. unauthorized discharges as defined in Permit Condition 2(g).

- ii. any unanticipated bypass that exceeds any effluent limitation in the permit.
- iii. violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
- In addition to the above, any effluent violation that deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the regional office and the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
- d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
- 8. In accordance with the procedures described in 30 TAC §§35.301 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
- 9. Changes in Discharges of Toxic Substances

All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the regional office, orally or by facsimile transmission within 24 hours, and both the regional office and the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) that is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":

i. one hundred micrograms per liter (100 $\mu g/L$); ii. two hundred micrograms per liter (200 $\mu g/L$) for acrolein and acrylonitrile; five hundred micrograms per liter (500 $\mu g/L$) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;

iii. five (5) times the maximum concentration value reported for that pollutant in the permit application; or

iv. the level established by the TCEQ.

- b. That any activity has occurred or will occur that would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. five hundred micrograms per liter (500 μ g/L);

- ii. one milligram per liter (1 mg/L) for antimony; iii. ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
- iv. the level established by the TCEO.

10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC §305.128 (relating to Signatories to Reports).

- 11. All POTWs must provide adequate notice to the Executive Director of the following:
 - a. any new introduction of pollutants into the POTW from an indirect discharger that would be subject to CWA §301 or §306 if it were directly discharging those pollutants;
 - any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit;
 - c. for the purpose of this paragraph, adequate notice shall include information on:
 - i. the quality and quantity of effluent introduced into the POTW: and
 - any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

PERMIT CONDITIONS

1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:

 - i. violation of any terms or conditions of this permit;ii. obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
 - iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending, or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment,

- revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.
- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance with 30 TAC §§305.62 and 305.66 and TWC §7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC §305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility that does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under Texas Water Code §§7.051 7.075 (relating to Administrative Penalties), 7.101 7.111 (relating to Civil Penalties), and 7.141 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA §402, or any requirement imposed in a pretreatment program approved under the CWA §§402(a)(3) or 402(b)(8).

3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC Chapter 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit, or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC §7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

4. Permit Amendment or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
 - i. the alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC §305.534 (relating to New Sources and New Dischargers); or
 - ii. the alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
 - iii. the alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes that are not described in the permit application or that would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC §26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA §307(a) for a toxic pollutant that is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA §307(a) for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC §305.64 (relating to Transfer of Permits) and 30 TAC §50.133 (relating to Executive Director Action on Application or WQMP update).

6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to Texas Water Code Chapter 11.

8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

11. Notice of Bankruptcy.

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
 - i. the permittee;
 - ii. an entity (as that term is defined in 11 USC, §101(15)) controlling the permittee or listing the permit or permittee as property of the estate; or
 - iii. an affiliate (as that term is defined in 11 USC, §101(2)) of the permittee.

b. This notification must indicate:

- i. the name of the permittee;ii. the permit number(s);
- iii. the bankruptcy court in which the petition for bankruptcy was filed; and
- iv. the date of filing of the petition.

OPERATIONAL REQUIREMENTS

- The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
- 2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge use and disposal and 30 TAC §§319.21 319.29 concerning the discharge of certain hazardous metals.

- 3. Domestic wastewater treatment facilities shall comply with the following provisions:
 - a. The permittee shall notify the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
 - b. The permittee shall submit a closure plan for review and approval to the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment or other treatment unit regulated by this permit.
- 4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, or retention of inadequately treated wastewater.
- 5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.
- 6. The permittee shall remit an annual water quality fee to the Commission as required by 30 TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC §7.302(b)(6).

7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words "confidential business information" on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

- 8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
 - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion or upgrading of the domestic wastewater treatment or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment or collection facilities. In the case of a domestic wastewater treatment facility that reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

- b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission, and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been secured.
- c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
- 9. Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
- 10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
- 11. Facilities that generate industrial solid waste as defined in 30 TAC §335.1 shall comply with these provisions:
 - a. Any solid waste, as defined in 30 TAC §335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
 - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
 - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC §335.8(b)(1), to the Corrective Action Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
 - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Remediation Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC §335.5.
 - e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well, container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.
 - f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC Chapter 335 and must include the following, as it pertains to wastewater treatment and discharge:
 - i. volume of waste and date(s) generated from treatment process;
 - ii. volume of waste disposed of on-site or shipped off-site;
 - iii. date(s) of disposal;

- iv. identity of hauler or transporter;v. location of disposal site; andvi. method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC Chapter 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC Code Chapter 361.

TCEQ Revision 05/2021

OTHER REQUIREMENTS

1. Violations of daily maximum limitations for the following pollutants shall be reported orally or by facsimile to TCEQ Region 5 within 24 hours from the time the permittee becomes aware of the violation, followed by a written report within five working days to TCEQ Region 5 and Compliance Monitoring Team (MC 224): None.

Test methods used must be sensitive enough to demonstrate compliance with the permit effluent limitations. If an effluent limit for a pollutant is less than the MAL, then the test method for that pollutant must be sensitive enough to demonstrate compliance at the MAL. Permit compliance/noncompliance determinations will be based on the effluent limitations contained in this permit, with consideration given to the MAL for the pollutants specified above.

Pollutant	MAL ¹ (mg/L)
Aluminum (Total)	0.0025
Aluminum (Dissolved)	0.0025

When an analysis of an effluent sample for a pollutant listed above indicates no detectable levels above the MAL and the test method detection level is as sensitive as the specified MAL, a value of zero shall be used for that measurement when making calculations for the self-reporting form. This applies to determinations of daily maximum concentration, calculations of loading and daily averages, and other reportable results.

When a reported value is zero based on this MAL provision, the permittee shall submit the following statement with the self-reporting form either as a separate attachment to the form or as a statement in the comments section of the form:

"The reported value(s) of zero for <u>[list pollutant(s)]</u> on the self-reporting form for <u>[monitoring period date range]</u> is based on the following conditions: (1) the analytical method used had a method detection level as sensitive as the MAL specified in the permit, and (2) the analytical results contained no detectable levels above the specified MAL."

When an analysis of an effluent sample for a pollutant indicates no detectable levels and the test method detection level is not as sensitive as the MAL specified in the permit, or an MAL is not specified in the permit for that pollutant, the level of detection achieved shall be used for that measurement when making calculations for the self-reporting form. A zero may not be used.

- 2. This permit does not authorize the discharge of domestic wastewater. All domestic wastewater must be disposed of in an approved manner, such as routing to an approved on-site septic tank and drainfield system or to an authorized third party for treatment and disposal.
- 3. The term water treatment wastes includes, but is not limited to: cold lime water treatment wastes, demineralizer backwash, filter backwash, ion exchange water treatment system wastes, membrane regeneration wastes, and reverse osmosis reject water.
- 4. There is no mixing zone established for this discharge to an intermittent stream. Acute toxic criteria apply at the point of discharge.
- 5. Reporting requirements according to 30 TAC §§ 319.1-319.12 and any additional effluent reporting requirements contained in the permit are suspended from the effective date of the permit until plant startup or discharge, whichever occurs first, from the facility described by this permit. The permittee shall provide written notice to the TCEQ Region 5 Office, Applications Review and

¹ Minimum analytical level.

Processing Team (MC 148) of the Water Quality Division, and Compliance Monitoring Team (MC 224) at least forty-five days prior to plant startup or anticipated discharge, whichever occurs first, on Notification of Completion Form 20007.

- 6. Wastewater discharged via Outfall 001 must be sampled and analyzed as directed below for those parameters listed in Tables 1, 2, and 3 of Attachment A of this permit. Analytical testing for Outfall 001 must be completed within 60 days of initial discharge. Results of the analytical testing must be submitted within 90 days of initial discharge to the TCEQ Industrial Permits Team (MC 148) and Region 5 Office. Based on a technical review of the submitted analytical results, an amendment may be initiated by TCEQ staff to include additional effluent limitations, monitoring requirements, or both.
 - Table 1: Analysis is required for all pollutants in Table 1. Wastewater must be sampled and analyzed for those parameters listed in Table 1 for a minimum of four sampling events that are each at least one week apart.
 - Table 2: Analysis is required for all pollutants in Table 2. Wastewater must be sampled and analyzed for those parameters listed in Table 2 for a minimum of four sampling events that are each at least one week apart.
 - Table 3: For all pollutants listed in Table 3, the permittee shall indicate whether each pollutant is believed to be present or absent in the discharge. Sampling and analysis must be conducted for each pollutant believed present for a minimum of one sampling event.

The permittee shall report the flow at Outfall 001 in MGD in the attachment. The permittee shall indicate on each table whether the samples are composite (C) or grab (G) by checking the appropriate box.

7. SOURCE IDENTIFICATION AND REDUCTION STUDY PLAN

The permittee shall develop and submit a study plan to characterize the total and dissolved aluminum composition of the effluent and demonstrate that the discharge is not toxic to aquatic life with respect to total aluminum . The plan must be submitted to the TCEQ Water Quality Assessment Section (MC 150), Industrial Permits Team (MC 148), and Region 5 Office within 120 days after permit issuance. The TCEQ will review the work plan and may disapprove or modify the work plan within 60 days of receipt, with no response being equivalent to approval. The work plan to demonstrate the discharge is not toxic to aquatic life may include, but is not limited to or required to include, a partition coefficient study or a bioavailability study. The duration of the study shall be three years from the date of implementation and annual progress reports shall be submitted by Dec 31st of each year to the TCEQ Compliance Monitoring Team (MC 224).

Attachment A

Table 1

Outfall No.:		Effluent	Concentra	tion (mg/L)
Pollutant	Samp.	Samp.	Samp.	Samp.	Average
Flow (MGD)					
BOD (5-day)					
CBOD (5-day)					
Chemical Oxygen Demand					
Total Organic Carbon					
Dissolved Oxygen					
Ammonia Nitrogen					
Total Suspended Solids					
Nitrate Nitrogen					
Total Organic Nitrogen					
Total Phosphorus					
Oil and Grease					
Total Residual Chlorine					
Total Dissolved Solids					
Sulfate					
Chloride					
Fluoride					
Total Alkalinity (mg/L as CaCO ₃)					
Temperature (°F)					
pH (Standard Units; min/max)					

Table 2

Pollutant		Effluent Concentration (μg/L) ²						
Ponutant	Samp. 1	Samp. 2	Samp. 3	Samp. 4	Average	(µg/L)		
Aluminum, Total						2.5		
Antimony, Total						5		
Arsenic, Total						0.5		
Barium, Total						3		
Beryllium, Total						0.5		
Cadmium, Total						1		
Chromium, Total						3		
Chromium, Hexavalent						3		
Chromium, Trivalent						N/A		
Copper, Total						2		
Cyanide, Free						10		
Lead, Total						0.5		
Mercury, Total						0.005		
Nickel, Total						2		
Selenium, Total						5		
Silver, Total						0.5		
Thallium, Total						0.5		
Zinc, Total						5.0		

 $^{^{2}\,}$ Indicate units if different than $\mu g/L.$ $^{3}\,$ Minimum Analytical Level.

Table 3

Outfall No.	□C □G	Believed	Believed	Average	Maximum	No. of	MAL
Pollutant		Present	Absent	Conc.	Conc.	Samples	(mg/L)
				(mg/L)	(mg/L)		
Bromide							0.400
Color (PCU)							_
Nitrate-Nitrite (as N)							_
Sulfide (as S)							_
Sulfite (as SO ₃)							
Surfactants							_
Boron, total							0.020
Cobalt, total							0.0003
Iron, total							0.007
Magnesium, total							0.020
Manganese, total							0.0005
Molybdenum, total							0.001
Tin, total							0.005
Titanium, total	_						0.030

STATEMENT OF BASIS/TECHNICAL SUMMARY AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

DESCRIPTION OF APPLICATION

Applicant: Wright City Water Supply Corporation; Texas Pollutant Discharge Elimination

System (TPDES) Permit No. WQ0005459000 (EPA I.D. No. TX0145963)

Regulated activity: Industrial wastewater permit

Type of application: New permit

Request: New permit

Authority: Federal Clean Water Act (CWA) §402; Texas Water Code (TWC) §26.027;

30 Texas Administrative Code (TAC) Chapter 305, Subchapters C-F, and Chapters 307 and 319; commission policies; and Environmental Protection

Agency (EPA) guidelines

EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit will expire at midnight, five years from the date of permit issuance according to the requirements of 30 TAC §305.127(1)(C)(i).

REASON FOR PROJECT PROPOSED

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for a new permit.

PROJECT DESCRIPTION AND LOCATION

The applicant currently proposes to operate Wright City Water Supply Corporation (WSC), a public water supply facility.

The facility will utilize a two stage nanofiltration system to filter groundwater for public use. The nanofiltration system uses membranes with very small pores to remove unwanted larger molecules and ions (bacteria, calcium, magnesium, organic matter, etc.) from the groundwater. The feed water filtered through the system will be for public use, while the reject water that contains the unwanted molecules and ions will be reject water discharged at the facility. The system will generate as much as 54,000 gallons per day of reject groundwater per day. No chemicals are added to the reject water before discharge. Domestic wastewater is not generated on site.

The facility is located at 18523 Farm-to-Market 2089, in the City of Overton, Smith County, Texas 75684.

Discharge Route and Designated Uses

The effluent is discharged from the plant to an unnamed ditch; thence to an unnamed tributary; thence to Wright Branch; thence to Bowles Creek; thence to Striker Creek; thence to Lake Striker; thence to Striker Creek; thence to Angelina River Above Sam Rayburn Reservoir in Segment No. 0611 of the Neches River Basin. The unclassified receiving water uses are minimal aquatic life use for the unnamed ditch and Wright Branch, limited aquatic life use for the unnamed tributary, and high aquatic life use for Bowles Creek. The designated uses for Segment No. 0611 are primary contact recreation, public water supply, and high aquatic life use. The effluent limits in the draft permit will maintain and protect the existing instream uses. All determinations are preliminary and subject to additional review and revisions.

Antidegradation Review

In accordance with 30 TAC §307.5 and TCEQ's *Procedures to Implement the Texas Surface Water Quality Standards* (June 2010), an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. A Tier 2 review has preliminarily determined that no significant degradation of water quality is expected in Bowles Creek, which has been identified as having high aquatic life use. Existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received.

Endangered Species Review

The discharge from this permit is not expected to have an effect on any federal endangered or threatened aquatic or aquatic-dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS) biological opinion on the State of Texas authorization of the TPDES (September 14, 1998; October 21, 1998 update). To make this determination for TPDES permits, TCEQ and the EPA only considered aquatic or aquatic-dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS's biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Impaired Water Bodies

Segment No. 0611 is currently listed on the state's inventory of impaired and threatened waters, the 2022 CWA §303(d) list. The listing is for bacteria from the aqueduct crossing upstream to the confluence with Old River Channel in Nacogdoches County about 2.8 km downstream of County Hwy 2625 at NHD RC 12020004000039 (AU 0611_01) and from a point immediately upstream of the confluence with Mud Creek (0611C) upstream to the confluence with Barnhardt and Mill Creeks (AUs 0611_03 and 0611_04). The facility is not authorized to discharge domestic wastewater nor is bacteria anticipated to be present in the discharge from this facility based on facility processes.

Completed Total Maximum Daily Loads (TMDLs)

There are no completed TMDLs for Segment No. 0611.

Dissolved Oxygen

Due to the low levels of oxygen-demanding constituents expected from this type of waste stream, no significant dissolved oxygen depletion is anticipated in the receiving waters as a result of this discharge.

SUMMARY OF EFFLUENT DATA

Self-reporting data is not available because the facility has not been constructed.

DRAFT PERMIT CONDITIONS

The draft permit authorizes the discharge of water treatment waste at a daily average flow not to exceed 0.054 million gallons per day (MGD) via Outfall 001.

Effluent limitations are established in the draft permit as follows:

Outfall	Pollutant	Daily Average mg/L	Daily Maximum mg/L
001	Flow	0.0540 MGD	Report, MGD

Outfall	Pollutant	Daily Average	Daily Maximum
Outian	Tonutant	mg/L	mg/L
001	Dissolved Aluminum 1	Report	Report
	Total Aluminum ¹	Report	Report
	Total Dissolved Solids (TDS) ¹	N/A	Report
	Chloride ¹	N/A	Report
	Sulfate ¹	N/A	Report
	рН	6.0 SU, minimum	9.0 SU

¹ This monitoring requirement begins upon the date of issuance of permit and expires 58 months after date of permit issuance

OUTFALL LOCATIONS

Outfall	Latitude	Longitude
001	32.200136 N	94.994487 W

Technology-Based Effluent Limitations

Regulations in Title 40 of the Code of Federal Regulations (40 CFR) require that technology-based limitations be placed in wastewater discharge permits based on effluent limitations guidelines, where applicable, or on best professional judgment (BPJ) in the absence of guidelines. Discharge of water treatment wastes is not subject to any federal effluent limitations guidelines. pH limits are based on BPJ and are typical of limits included in wastewater permits.

Water Quality-Based Effluent Limitations

Calculations of water quality-based effluent limitations for the protection of aquatic life and human health are presented in Appendix B. Aquatic life criteria established in Table 1 and human health criteria established in Table 2 of 30 TAC Chapter 307 are incorporated into the calculations, as are recommendations in the Water Quality Assessment Team's memorandum dated July 12, 2024. TCEQ practice for determining significant potential is to compare the reported analytical data from the facility against percentages of the calculated daily average water quality-based effluent limitation. Permit limitations are required when analytical data reported in the application exceeds 85 percent of the calculated daily average water quality-based effluent limitation. Monitoring and reporting is required when analytical data reported in the application exceeds 70 percent of the calculated daily average water quality-based effluent limitation.

Data reported in the application was from a single sample of a like plant and screened against the calculated water quality-based effluent limitations and Other Requirement No. 6 is added to the draft permit to require a total of four samples to be tested. Self-expiring monitoring requirements for dissolved aluminum and total aluminum are placed in the draft permit. In addition, Other Requirement No. 7 is added to the draft permit to require a study to demonstrate that the effluent is not toxic to aquatic life with respect to total aluminum.

Total Dissolved Solids (TDS), Chloride, and Sulfate Screening

Concentrations of TDS, chloride, and sulfate reported in the application from the one sample are all greater than the respective criteria for Segment No. 0611; therefore, further screening is necessary. See Appendix B. Other Requirement No. 6 is added to the draft permit to require a total of four samples to be tested for reevaluation purposes. Self-expiring monitoring requirements for TDS, chloride, and sulfate are placed in the draft permit to obtain more comprehensive effluent data during the permit term.

pH Screening

The draft permit includes pH limits of 6.0-9.0 SU at Outfall 001, which discharges into an unclassified water body. Consistent with the procedures for pH screening that were submitted to EPA with a letter dated May 28, 2014, and approved by EPA in a letter dated June 2, 2014, requiring a discharge to an unclassified water body to meet pH limits of 6.0-9.0 standard units reasonably ensures instream compliance with *Texas Surface Water Quality Standards* pH criteria. These limits have been carried forward in the draft permit.

Whole Effluent Toxicity Testing (Biomonitoring)

Biomonitoring requirements are not included in the draft permit. The discharges authorized by this permit do not meet the threshold established in the *Procedures to Implement the Texas Surface Water Quality Standards* (RG-194) to impose biomonitoring requirements.

SUMMARY OF CHANGES FROM APPLICATION

No changes were made from the application.

BASIS FOR DRAFT PERMIT

The following items were considered in developing the draft permit:

- 1. Application received on April 26, 2024, and additional information received on May 24, 2024.
- 2. TCEO Rules.
- 3. *Texas Surface Water Quality Standards* 30 TAC §§307.1-307.10, effective March 1, 2018, as approved by EPA Region 6.
- 4. *Texas Surface Water Quality Standards* 30 TAC §§307.1-307.10, effective March 6, 2014, as approved by EPA Region 6, for portions of the 2018 standards not approved by EPA Region 6.
- 5. *Texas Surface Water Quality Standards* 30 TAC §§307.1-307.10, effective July 22, 2010, as approved by EPA Region 6, for portions of the 2014 standards not approved by EPA Region 6.
- 6. *Texas Surface Water Quality Standards* 30 TAC §§307.1-307.10, effective August 17, 2000, and Appendix E, effective February 27, 2002, for portions of the 2010 standards not approved by EPA Region 6.
- 7. Procedures to Implement the Texas Surface Water Quality Standards (IPs), Texas Commission on Environmental Quality, June 2010, as approved by EPA Region 6.
- 8. Procedures to Implement the Texas Surface Water Quality Standards, Texas Commission on Environmental Quality, January 2003, for portions of the 2010 IPs not approved by EPA Region 6.
- 9. Memos from the Standards Implementation Team and Water Quality Assessment Team of the Water Quality Assessment Section of the TCEQ.
- 10. Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, TCEQ Document No. 98-001.000-OWR-WQ, May 1998.
- 11. EPA Effluent Guidelines: N/A.
- 12. Consistency with the Coastal Management Plan: N/A
- 13. Letter dated May 28, 2014, from L'Oreal W. Stepney, P.E., Deputy Director, Office of Water, TCEQ, to Bill Honker, Director, Water Quality Protection Division, EPA (TCEQ proposed development strategy for pH evaluation procedures).
- 14. Letter dated June 2, 2014, from William K. Honker, P.E., Director, Water Quality Protection Division, EPA, to L'Oreal W. Stepney, P.E., Deputy Director, Office of Water, TCEQ (Approval of TCEQ proposed development strategy for pH evaluation procedures).
- 15. Guidance Industrial Permits: Uncontaminated Stormwater Runoff, EPA, January 1997.

PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the chief clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for reviewing and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent to the Chief Clerk, along with the Executive Director's preliminary decision contained in the technical summary or fact sheet. At that time, the Combined Notice of Receipt of Application and Intent to obtain water quality permit and the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment and is not a contested case hearing.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ commissioners for their consideration at a scheduled commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the commission grants a contested case hearing as described above, the commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Thomas E. Starr at (512) 239-4570.

Thomas E. Starr
Thomas E. Starr, P.E.

September 3, 2025

Date

Appendix A Calculated Water Quality-Based Effluent Limits

TEXTOX MENU #7 - INTERMITTENT STREAM WITH PERENNIAL POOLS

The water quality-based effluent limitations developed below are calculated using:

Table 1, 2014 Texas Surface Water Quality Standards (30 TAC 307) for Freshwater Aquatic Life Table 2, 2018 Texas Surface Water Quality Standards for Human Health, Incidental Fishery "Procedures to Implement the Texas Surface Water Quality Standards," TCEQ, June 2010

PERMIT INFORMATION

Permittee Name:	Wright Water Supply Corporation
TPDES Permit No.:	WQ0005459000
Outfall No.:	001
Prepared by:	Thomas Starr
Date:	September 3, 2025

DISCHARGE INFORMATION

2.00		
Intermittent Receiving Waterbody:	unnamed trib	utary
Segment No.:	0611	
TSS (mg/L):	8	
pH (Standard Units):	6.5	
Hardness (mg/L as CaCO₃):	38	
Chloride (mg/L):	19	
Effluent Flow for Aquatic Life (MGD):	0.054	
Critical Low Flow [7Q2] (cfs):	0	
% Effluent for Chronic Aquatic Life:	100	
% Effluent for Acute Aquatic Life:	100	
Effluent Flow for Human Health (MGD):	0.054	
Harmonic Mean Flow (cfs):	0.1	
% Effluent for Human Health:	45.519	

CALCULATE DISSOLVED FRACTION (AND ENTER WATER EFFECT RATIO IF APPLICABLE):

			Partition	Dissolved		Water	
	Intercept	Slope	Coefficient	Fraction		Effect	
Stream/River Metal	(b)	(m)	(Kp)	(Cd/Ct)	Source	Ratio	Source
Aluminum	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Arsenic	5.68	-0.73	104892.47	0.544		1.00	Assumed
Cadmium	6.60	-1.13	379759.21	0.248		1.00	Assumed
Chromium (total)	6.52	-0.93	478769.32	0.207		1.00	Assumed
Chromium (trivalent)	6.52	-0.93	478769.32	0.207		1.00	Assumed
Chromium (hexavalent)	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Copper	6.02	-0.74	224757.09	0.357		1.00	Assumed
Lead	6.45	-0.80	533983.71	0.190		1.00	Assumed
Mercury	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Nickel	5.69	-0.57	149705.83	0.455		1.00	Assumed
Selenium	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Silver	6.38	-1.03	281719.76	0.307		1.00	Assumed
Zinc	6.10	-0.70	293654.74	0.299		1.00	Assumed

AQUATIC LIFE CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:

	FW Acute	FW Chronic						Daily
	Criterion	Criterion	WLAa	WLAc	LTAa	LTAc	Daily Avg.	Max.
Parameter	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)
Aldrin	3.0	N/A	3.00	N/A	1.72	N/A	2.52	5.34
Aluminum	991	N/A	991	N/A	568	N/A	834	1765
Arsenic	340	150	625	276	358	212	312	660
Cadmium	3.3	0.125	13.5	0.507	7.74	0.390	0.573	1.21
Carbaryl	2.0	N/A	2.00	N/A	1.15	N/A	1.68	3.56
Chlordane	2.4	0.004	2.40	0.00400	1.38	0.00308	0.00452	0.00957
Chlorpyrifos	0.083	0.041	0.0830	0.0410	0.0476	0.0316	0.0464	0.0981
Chromium (+3)	258	34	1246	162	714	125	183	388
Chromium (+6)	15.7	10.6	15.7	10.6	9.00	8.16	11.9	25.3
Copper	5.7	4.1	16.0	11.6	9.15	8.92	13.1	27.7
Cyanide (free)	45.8	10.7	45.8	10.7	26.2	8.24	12.1	25.6
4,4'-DDT	1.1	0.001	1.10	0.00100	0.630	0.000770	0.00113	0.00239
Demeton	N/A	0.1	N/A	0.100	N/A	0.0770	0.113	0.239
Diazinon	0.17	0.17	0.170	0.170	0.0974	0.131	0.143	0.302
Dicofol	59.3	19.8	59.3	19.8	34.0	15.2	22.4	47.4
Dieldrin	0.24	0.002	0.240	0.00200	0.138	0.00154	0.00226	0.00478
Diuron	210	70	210	70.0	120	53.9	79.2	167
Endosulfan I (alpha)	0.22	0.056	0.220	0.0560	0.126	0.0431	0.0633	0.134
Endosulfan II (beta)	0.22	0.056	0.220	0.0560	0.126	0.0431	0.0633	0.134
Endosulfan sulfate	0.22	0.056	0.220	0.0560	0.126	0.0431	0.0633	0.134
Endrin	0.086	0.002	0.0860	0.00200	0.0493	0.00154	0.00226	0.00478
Guthion	N/A	0.01	N/A	0.0100	N/A	0.00770	0.0113	0.0239
Heptachlor	0.52	0.004	0.520	0.00400	0.298	0.00308	0.00452	0.00957
Hexachlorocyclohexane (Lindane)	1.126	0.08	1.13	0.0800	0.645	0.0616	0.0905	0.191
Lead	22	0.87	117	4.56	67.1	3.51	5.16	10.9
Malathion	N/A	0.01	N/A	0.0100	N/A	0.00770	0.0113	0.0239
Mercury	2.4	1.3	2.40	1.30	1.38	1.00	1.47	3.11
Methoxychlor	N/A	0.03	N/A	0.0300	N/A	0.0231	0.0339	0.0718
Mirex	N/A	0.001	N/A	0.00100	N/A	0.000770	0.00113	0.00239
Nickel	207	22.9	454	50.4	260	38.8	57.0	120
Nonylphenol	28	6.6	28.0	6.60	16.0	5.08	7.47	15.8
Parathion (ethyl)	0.065	0.013	0.0650	0.0130	0.0372	0.0100	0.0147	0.0311
Pentachlorophenol	5.3	4.0	5.28	4.05	3.02	3.12	4.44	9.40
Phenanthrene	30	30	30.0	30.0	17.2	23.1	25.2	53.4
Polychlorinated Biphenyls (PCBs)	2.0	0.014	2.00	0.0140	1.15	0.0108	0.0158	0.0335
Selenium	20	5	20.0	5.00	11.5	3.85	5.65	11.9
Silver	0.8	N/A	5.45	N/A	3.12	N/A	4.59	9.71
Toxaphene	0.78	0.0002	0.780	0.000200	0.447	0.000154	0.000226	0.000478
Tributyltin (TBT)	0.13	0.024	0.130	0.0240	0.0745	0.0185	0.0271	0.0574
2,4,5 Trichlorophenol	136	64	136	64.0	77.9	49.3	72.4	153
Zinc	52	52	173	174	99.1	134	145	308

HUMAN HEALTH (APPLIES FOR INCIDENTAL FRESHWATER FISH TISSUE) CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:

	Fish				
	Criterion	WLAh	LTAh	Daily Avg.	Daily Max.
Parameter	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)
Acrylonitrile	1150	2526	2350	3453	7307
Aldrin	1.147E-04	0.000252	0.000234	0.000344	0.000728
Anthracene	13170	28933	26908	39554	83682
Antimony	10710	23529	21882	32166	68052
Arsenic	N/A	N/A	N/A	N/A	N/A
Barium	N/A	N/A	N/A	N/A	N/A
Benzene	5810	12764	11870	17449	36917
Benzidine	1.07	2.35	2.19	3.21	6.79
Benzo(a)anthracene	0.25	0.549	0.511	0.750	1.58
Benzo(a)pyrene	0.025	0.0549	0.0511	0.0750	0.158
Bis(chloromethyl)ether	2.745	6.03	5.61	8.24	17.4
Bis(2-chloroethyl)ether	428.3	941	875	1286	2721
Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phtha	75.5	166	154	226	479
Bromodichloromethane [Dichlorobromomethane]	2750	6041	5619	8259	17473
Bromoform [Tribromomethane]	10600	23287	21657	31835	67353
Cadmium	N/A	N/A	N/A	N/A	N/A
Carbon Tetrachloride	460	1011	940	1381	2922
Chlordane	0.025	0.0549	0.0511	0.0750	0.158
Chlorobenzene	27370	60129	55920	82202	173910
Chlorodibromomethane [Dibromochloromethane]	1830	4020	3739	5496	11627
Chloroform [Trichloromethane]	76970	169095	157258	231169	489072
Chromium (hexavalent)	5020	11028	10256	15076	31897
Chrysene	25.2	55.4	51.5	75.6	160
Cresols [Methylphenols]	93010	204333	190029	279343	590991
	93010 N/A	N/A	190029 N/A	N/A	N/A
Cyanide (free)	-	-			
4,4'-DDD 4,4'-DDE	0.02	0.0439	0.0409	0.0600	0.127
		0.00286	0.00266	0.00390	0.00826
4,4'-DDT	0.004	0.00879	0.00817	0.0120	0.0254
2,4'-D	N/A	N/A	N/A	N/A	N/A
Danitol [Fenpropathrin]	4730	10391	9664	14205	30054
1,2-Dibromoethane [Ethylene Dibromide]	42.4	93.1	86.6	127	269
m -Dichlorobenzene [1,3-Dichlorobenzene]	5950	13071	12156	17870	37806
o -Dichlorobenzene [1,2-Dichlorobenzene]	32990	72475	67402	99081	209620
p -Dichlorobenzene [1,4-Dichlorobenzene]	N/A	N/A	N/A	N/A	N/A
3,3'-Dichlorobenzidine	22.4	49.2	45.8	67.2	142
1,2-Dichloroethane	3640	7997	7437	10932	23128
1,1-Dichloroethylene [1,1-Dichloroethene]	551140	1210793	1126038	1655275	3501977
Dichloromethane [Methylene Chloride]	133330	292911	272407	400438	847187
1,2-Dichloropropane	2590	5690	5292	7778	16457
1,3-Dichloropropene [1,3-Dichloropropylene]	1190	2614	2431	3574	7561
Dicofol [Kelthane]	3	6.59	6.13	9.01	19.0
Dieldrin	2.0E-04	0.000439	0.000409	0.000600	0.00127
2,4-Dimethylphenol	84360	185330	172356	253364	536028
Di-n -Butyl Phthalate	924	2030	1888	2775	5871
Dioxins/Furans [TCDD Equivalents]	7.97E-07	0.0000018	0.0000016	0.0000024	0.0000051
Endrin	0.2	0.439	0.409	0.600	1.27
Epichlorohydrin	20130	44223	41128	60457	127907
Ethylbenzene	18670	41016	38145	56072	118630
Ethylene Glycol	1.68E+08	369077333	343241920	504565622	1067482371
Fluoride	N/A	N/A	N/A	N/A	N/A
Heptachlor	0.001	0.00220	0.00204	0.00300	0.00635
			0.00593	0.00870	0.0184
Heptachlor Epoxide	0.0029	0.00637	0.00555	0.00070	0.0104
Heptachlor Epoxide Hexachlorobenzene	0.0029	0.00637	0.00393	0.0204	0.0134

	Fish				
	Criterion	WLAh	LTAh	Daily Avg.	Daily Max.
Parameter	(μg/L)	(μg/L)	(μg/L)	(μg/L)	(μg/L)
Hexachlorocyclohexane (alpha)	0.084	0.185	0.172	0.252	0.533
Hexachlorocyclohexane (beta)	2.6	5.71	5.31	7.80	16.5
Hexachlorocyclohexane (gamma) [Lindane]	3.41	7.49	6.97	10.2	21.6
Hexachlorocyclopentadiene	116	255	237	348	737
Hexachloroethane	23.3	51.2	47.6	69.9	148
Hexachlorophene	29	63.7	59.3	87.0	184
4,4'-Isopropylidenediphenol [Bisphenol A]	159820	351107	326529	479998	1015506
Lead	38.3	444	413	606	1282
Mercury	0.122	0.268	0.249	0.366	0.775
Methoxychlor	30	65.9	61.3	90.1	190
Methyl Ethyl Ketone	9.92E+06	21793138	20267618	29793398	63032292
Methyl tert -butyl ether [MTBE]	104820	230278	214158	314812	666032
Nickel	11400	55039	51186	75243	159189
Nitrate-Nitrogen (as Total Nitrogen)	N/A	N/A	N/A	N/A	N/A
Nitrobenzene	18730	41148	38267	56253	119011
N-Nitrosodiethylamine	21	46.1	42.9	63.0	133
N-Nitroso-di-n -Butylamine	42	92.3	85.8	126	266
Pentachlorobenzene	3.55	7.80	7.25	10.6	22.5
Pentachlorophenol	2.9	6.37	5.93	8.70	18.4
Polychlorinated Biphenyls [PCBs]	6.40E-03	0.0141	0.0131	0.0192	0.0406
Pyridine	9470	20805	19348	28441	60172
Selenium	N/A	N/A	N/A	N/A	N/A
1,2,4,5-Tetrachlorobenzene	2.4	5.27	4.90	7.20	15.2
1,1,2,2-Tetrachloroethane	263.5	579	538	791	1674
Tetrachloroethylene [Tetrachloroethylene]	2800	6151	5721	8409	17791
Thallium	2.3	5.05	4.70	6.90	14.6
Toluene	N/A	N/A	N/A	N/A	N/A
Toxaphene	0.11	0.242	0.225	0.330	0.698
2,4,5-TP [Silvex]	3690	8107	7539	11082	23446
1,1,1-Trichloroethane	7843540	17231386	16025189	23557027	49838337
1,1,2-Trichloroethane	1660	3647	3392	4985	10547
Trichloroethylene [Trichloroethene]	719	1580	1469	2159	4568
2,4,5-Trichlorophenol	18670	41016	38145	56072	118630
TTHM [Sum of Total Trihalomethanes]	N/A	N/A	N/A	N/A	N/A
Vinyl Chloride	165	362	337	495	1048

	70% of	85% of
Aquatic Life	Daily Avg.	Daily Avg.
Parameter	(μg/L)	(μg/L)
Aldrin	1.76	2.14
Aluminum	584	709
Arsenic	218	265
Cadmium	0.401	0.487
Carbaryl	1.17	1.43
Chlordane	0.00316	0.00384
Chlorpyrifos	0.0324	0.0394
Chromium (+3)	128	155
Chromium (+6)	8.39	10.1
Copper	9.18	11.1
Cyanide (free)	8.47	10.2
4,4'-DDT	0.000792	0.000962
Demeton	0.0792	0.0962
Diazinon	0.100	0.121
Dicofol	15.6	19.0
Dieldrin	0.00158	0.00192
Diuron	55.4	67.3
Endosulfan (alpha)	0.0443	0.0538
Endosulfan (beta)	0.0443	0.0538
Endosulfan sulfate	0.0443	0.0538
Endrin	0.00158	0.00192
Guthion	0.00792	0.00962
Heptachlor	0.00316	0.00384
Hexachlorocyclohexane (Lindane)	0.0633	0.0769
Lead	3.61	4.38
Malathion	0.00792	0.00962
Mercury	1.03	1.25
Methoxychlor	0.0237	0.0288
Mirex	0.000792	0.000962
Nickel	39.9	48.4
Nonylphenol	5.22	6.34
Parathion (ethyl)	0.0103	0.0125
Pentachlorophenol	3.11	3.77
Phenanthrene	17.6	21.4
Polychlorinated Biphenyls (PCBs)	0.0110	0.0134
Selenium	3.96	4.81
Silver	3.21	3.90
Toxaphene	0.000158	0.000192
Tributyltin (TBT)	0.0190	0.0230
2,4,5 Trichlorophenol	50.7	61.5
Zinc	101	123

	70% of	85% of
Human Health	Daily Avg.	Daily Avg.
Parameter	(μg/L)	(μg/L)
Acrylonitrile	2417	2935
Aldrin	0.000241	0.000292
Anthracene	27688	33621
Antimony	22516	27341
Arsenic	N/A	N/A
Barium	N/A	N/A
Benzene	12214	14832
Benzidine	2.24	2.73
Benzo(a)anthracene	0.525	0.638
Benzo(a)pyrene	0.0525	0.0638
Bis(chloromethyl)ether	5.77	7.00
Bis(2-chloroethyl)ether	900	1093
Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phtha	158	192
Bromodichloromethane [Dichlorobromomethane]	5781	7020
Bromoform [Tribromomethane]	22284	27060
Cadmium	N/A	N/A
Carbon Tetrachloride	967	1174
Chlordane	0.0525	0.0638
Chlorobenzene	57541	69871
Chlorodibromomethane [Dibromochloromethane]	3847	4671
Chloroform [Trichloromethane]	161818	196493
Chromium (hexavalent)	10553	12815
Chrysene	52.9	64.3
Cresols [Methylphenols]	195540	237441
Cyanide (free)	N/A	N/A
4,4'-DDD	0.0420	0.0510
4,4'-DDE	0.00273	0.00331
4,4'-DDT	0.00840	0.0102
2,4'-D	N/A	N/A
Danitol [Fenpropathrin]	9944	12075
1,2-Dibromoethane [Ethylene Dibromide]	89.1	108
m -Dichlorobenzene [1,3-Dichlorobenzene]	12509	15189
o -Dichlorobenzene [1,2-Dichlorobenzene]	69356	84218
p -Dichlorobenzene [1,4-Dichlorobenzene]	N/A	N/A
3,3'-Dichlorobenzidine	47.0	57.1
1,2-Dichloroethane	7652	9292
1,1-Dichloroethylene [1,1-Dichloroethene]	1158692	1406984
Dichloromethane [Methylene Chloride]	280307	340373
1,2-Dichloropropane	5445	6611
1,3-Dichloropropene [1,3-Dichloropropylene]	2501	3037
Dicofol [Kelthane]	6.30	7.65
Dieldrin	0.000420	0.000510
2,4-Dimethylphenol	177354	215359
Di-n -Butyl Phthalate	1942	2358
Dioxins/Furans [TCDD Equivalents]	0.0000017	0.0000020
Endrin	0.420	
Epichlorohydrin	42320	0.510 51389
Ethylbenzene	39251	47661
•		
Ethylene Glycol	353195935 N/A	428880779 N/A
Fluoride	N/A	N/A
Heptachlor	0.00210	0.00255
Heptachlor Epoxide	0.00609	0.00740
Hexachlorobenzene	0.0142	0.0173
Hexachlorobutadiene	4.62	5.61

	70% of	85% of
Human Health	Daily Avg.	Daily Avg.
Parameter	(μg/L)	(μg/L)
Hexachlorocyclohexane (alpha)	0.176	0.214
Hexachlorocyclohexane (beta)	5.46	6.63
Hexachlorocyclohexane (gamma) [Lindane]	7.16	8.70
Hexachlorocyclopentadiene	243	296
Hexachloroethane	48.9	59.4
Hexachlorophene	60.9	74.0
4,4'-Isopropylidenediphenol [Bisphenol A]	335998	407998
Lead	424	515
Mercury	0.256	0.311
Methoxychlor	63.0	76.5
Methyl Ethyl Ketone	20855379	25324388
Methyl tert -butyl ether [MTBE]	220369	267590
Nickel	52670	63957
Nitrate-Nitrogen (as Total Nitrogen)	N/A	N/A
Nitrobenzene	39377	47815
N-Nitrosodiethylamine	44.1	53.6
N-Nitroso-di- <i>n</i> -Butylamine	88.2	107
Pentachlorobenzene	7.46	9.06
Pentachlorophenol	6.09	7.40
Polychlorinated Biphenyls [PCBs]	0.0134	0.0163
Pyridine	19909	24175
Selenium	N/A	N/A
1,2,4,5-Tetrachlorobenzene	5.04	6.12
1,1,2,2-Tetrachloroethane	553	672
Tetrachloroethylene [Tetrachloroethylene]	5886	7148
Thallium	4.83	5.87
Toluene	N/A	N/A
Toxaphene	0.231	0.280
2,4,5-TP [Silvex]	7757	9420
1,1,1-Trichloroethane	16489919	20023473
1,1,2-Trichloroethane	3489	4237
Trichloroethylene [Trichloroethene]	1511	1835
2,4,5-Trichlorophenol	39251	47661
TTHM [Sum of Total Trihalomethanes]	N/A	N/A
Vinyl Chloride	346	421

TEXTOX MENU #3 - PERENNIAL STREAM OR RIVER

The water quality-based effluent limitations developed below are calculated using:

Table 1, 2014 Texas Surface Water Quality Standards (30 TAC 307) for Freshwater Aquatic Life Table 2, 2018 Texas Surface Water Quality Standards for Human Health
"Procedures to Implement the Texas Surface Water Quality Standards," TCEQ, June 2010

PERMIT INFORMATION

Permittee Name: Wright City Water Supply Corporation
TPDES Permit No.: WQ0005459000
Outfall No.: 001
Prepared by: Thomas Starr
Date: September 3, 2025

DISCHARGE INFORMATION

Receiving Waterbody:	Bowles Creek
Segment No.:	0611
TSS (mg/L):	8
pH (Standard Units):	6.5
Hardness (mg/L as CaCO₃):	38
Chloride (mg/L):	19
Effluent Flow for Aquatic Life (MGD):	N/A
Critical Low Flow [7Q2] (cfs):	0
% Effluent for Chronic Aquatic Life (Mixing Zone):	N/A
% Effluent for Acute Aquatic Life (ZID):	N/A
Effluent Flow for Human Health (MGD):	0.054
Harmonic Mean Flow (cfs):	0.2
% Effluent for Human Health:	29.47
Human Health Criterion (select: PWS, FISH, or INC)	FISH

CALCULATE DISSOLVED FRACTION (AND ENTER WATER EFFECT RATIO IF APPLICABLE):

			Partition	Dissolved		Water	
	Intercept	Slope	Coefficient	Fraction		Effect Ratio	
Stream/River Metal	(b)	(m)	(Kp)	(Cd/Ct)	Source	(WER)	Source
Aluminum	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Arsenic	5.68	-0.73	104892.47	0.544		1.00	Assumed
Cadmium	6.60	-1.13	379759.21	0.248		1.00	Assumed
Chromium (total)	6.52	-0.93	478769.32	0.207		1.00	Assumed
Chromium (trivalent)	6.52	-0.93	478769.32	0.207		1.00	Assumed
Chromium (hexavalent)	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Copper	6.02	-0.74	224757.09	0.357		1.00	Assumed
Lead	6.45	-0.80	533983.71	0.190		1.00	Assumed
Mercury	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Nickel	5.69	-0.57	149705.83	0.455		1.00	Assumed
Selenium	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Silver	6.38	-1.03	281719.76	0.307	•	1.00	Assumed
Zinc	6.10	-0.70	293654.74	0.299		1.00	Assumed

HUMAN HEALTH CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:

	Water and	Fish Only	Incidental				
	Fish	Criterion	Fish	WLAh	LTAh	Daily Avg.	Daily Max.
Parameter	Criterion	(μg/L)	Criterion	(μg/L)	(μg/L)	(μg/L)	(μg/L)
Acrylonitrile	1.0	115	1150	390	363	533	1128
Aldrin	1.146E-05	1.147E-05	1.147E-04	0.0000389	0.0000362	0.0000532	0.000112
Anthracene	1109	1317	13170	4470	4157	6110	12927
Antimony	6	1071	10710	3635	3380	4969	10512
Arsenic	10	N/A	N/A	N/A	N/A	N/A	N/A
Barium	2000	N/A	N/A	N/A	N/A	N/A	N/A
Benzene	5	581	5810	1972	1834	2695	5702
Benzidine	0.0015	0.107	1.07	0.363	0.338	0.496	1.05
Benzo(a)anthracene	0.024	0.025	0.25	0.0848	0.0789	0.115	0.245
Benzo(a)pyrene	0.0025	0.0025	0.025	0.00848	0.00789	0.0115	0.0245
Bis(chloromethyl)ether	0.0024	0.2745	2.745	0.932	0.866	1.27	2.69
Bis(2-chloroethyl)ether	0.60	42.83	428.3	145	135	198	420
Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phthalate]	6	7.55	75.5	25.6	23.8	35.0	74.1
Bromodichloromethane [Dichlorobromomethane]	10.2	275	2750	933	868	1275	2699
Bromoform [Tribromomethane]	66.9	1060	10600	3597	3346	4918	10404
Cadmium	5	N/A	N/A	N/A	N/A	N/A	N/A
Carbon Tetrachloride	4.5	46	460	156	145	213	451
Chlordane	0.0025	0.0025	0.025	0.00848	0.00789	0.0115	0.0245
Chlorobenzene	100	2737	27370	9289	8639	12698	26865
Chloroform [Trichloromethane]	7.5	183	1830	621	578	849	1796
Chloroform [Trichloromethane]	70 62	7697	76970	26122	24293	35711	75552
Chromium (hexavalent) Chrysene	2.45	2.52	5020 25.2	1704 8.55	7.95	2329	4927 24.7
Cresols [Methylphenols]	1041	9301	93010	31566	29356	43153	91296
Cyanide (free)	200	N/A	93010 N/A	N/A	29330 N/A	43133 N/A	91290 N/A
4,4'-DDD	0.002	0.002	0.02	0.00679	0.00631	0.00927	0.0196
4,4'-DDE	0.00013	0.00013	0.0013	0.000441	0.00031	0.000603	0.00127
4,4'-DDT	0.00013	0.00013	0.0013	0.00136	0.00126	0.00005	0.00392
2,4'-D	70	N/A	N/A	N/A	N/A	N/A	N/A
Danitol [Fenpropathrin]	262	473	4730	1605	1493	2194	4642
1,2-Dibromoethane [Ethylene Dibromide]	0.17	4.24	42.4	14.4	13.4	19.6	41.6
m -Dichlorobenzene [1,3-Dichlorobenzene]	322	595	5950	2019	1878	2760	5840
o -Dichlorobenzene [1,2-Dichlorobenzene]	600	3299	32990	11196	10412	15306	32382
p -Dichlorobenzene [1,4-Dichlorobenzene]	75	N/A	N/A	N/A	N/A	N/A	N/A
3,3'-Dichlorobenzidine	0.79	2.24	22.4	7.60	7.07	10.3	21.9
1,2-Dichloroethane	5	364	3640	1235	1149	1688	3572
1,1-Dichloroethylene [1,1-Dichloroethene]	7	55114	551140	187045	173952	255708	540989
Dichloromethane [Methylene Chloride]	5	13333	133330	45249	42082	61860	130874
1,2-Dichloropropane	5	259	2590	879	817	1201	2542
1,3-Dichloropropene [1,3-Dichloropropylene]	2.8	119	1190	404	376	552	1168
Dicofol [Kelthane]	0.30	0.30	3	1.02	0.947	1.39	2.94
Dieldrin	2.0E-05	2.0E-05	2.0E-04	0.0000679	0.0000631	0.0000927	0.000196
2,4-Dimethylphenol	444	8436	84360	28630	26626	39139	82806
Di-n -Butyl Phthalate	88.9	92.4	924	314	292	428	906
Dioxins/Furans [TCDD Equivalents]	7.80E-08	7.97E-08	7.97E-07	2.70E-07	2.52E-07	3.69E-07	7.82E-07
Endrin	0.02	0.02	0.2	0.0679	0.0631	0.0927	0.196
Epichlorohydrin	53.5	2013	20130	6832	6353	9339	19759
Ethylbenzene	700	1867	18670	6336	5893	8662	18326
Ethylene Glycol	46744	1.68E+07	1.68E+08	57015467	53024384	77945844	164905834
Fluoride	4000	N/A	N/A	N/A	N/A	N/A	N/A
Heptachlor	8.0E-05	0.0001	0.001	0.000339	0.000316	0.000463	0.000981
Heptachlor Epoxide	0.00029	0.00029	0.0029	0.000984	0.000915	0.00134	0.00284
Hexachlorobenzene	0.00068	0.00068	0.0068	0.00231	0.00215	0.00315	0.00667
Hexachlorobutadiene	0.21	0.22	2.2	0.747	0.694	1.02	2.15

	Water and	Fish Only	Incidental				
	Fish	Criterion	Fish	WLAh	LTAh	Daily Avg.	Daily Max.
Parameter	Criterion	(μg/L)	Criterion	(μg/L)	(μg/L)	(μg/L)	(μg/L)
Hexachlorocyclohexane (alpha)	0.0078	0.0084	0.084	0.0285	0.0265	0.0389	0.0824
Hexachlorocyclohexane (beta)	0.15	0.26	2.6	0.882	0.821	1.20	2.55
Hexachlorocyclohexane (gamma) [Lindane]	0.2	0.341	3.41	1.16	1.08	1.58	3.34
Hexachlorocyclopentadiene	10.7	11.6	116	39.4	36.6	53.8	113
Hexachloroethane	1.84	2.33	23.3	7.91	7.35	10.8	22.8
Hexachlorophene	2.05	2.90	29	9.84	9.15	13.4	28.4
4,4'-Isopropylidenediphenol	1092	15982	159820	54239	50443	74150	156876
Lead	1.15	3.83	38.3	68.5	63.7	93.6	198
Mercury	0.0122	0.0122	0.122	0.0414	0.0385	0.0566	0.119
Methoxychlor	2.92	3.0	30	10.2	9.47	13.9	29.4
Methyl Ethyl Ketone	13865	9.92E+05	9.92E+06	3366628	3130964	4602516	9737296
Methyl tert -butyl ether [MTBE]	15	10482	104820	35574	33083	48632	102889
Nickel	332	1140	11400	8502	7907	11623	24591
Nitrate-Nitrogen (as Total Nitrogen)	10000	N/A	N/A	N/A	N/A	N/A	N/A
Nitrobenzene	45.7	1873	18730	6357	5912	8690	18385
N-Nitrosodiethylamine	0.0037	2.1	21	7.13	6.63	9.74	20.6
N-Nitroso-di- <i>n</i> -Butylamine	0.119	4.2	42	14.3	13.3	19.4	41.2
Pentachlorobenzene	0.348	0.355	3.55	1.20	1.12	1.64	3.48
Pentachlorophenol	0.22	0.29	2.9	0.984	0.915	1.34	2.84
Polychlorinated Biphenyls [PCBs]	6.4E-04	6.4E-04	6.40E-03	0.00217	0.00202	0.00296	0.00628
Pyridine	23	947	9470	3214	2989	4393	9295
Selenium	50	N/A	N/A	N/A	N/A	N/A	N/A
1,2,4,5-Tetrachlorobenzene	0.23	0.24	2.4	0.815	0.757	1.11	2.35
1,1,2,2-Tetrachloroethane	1.64	26.35	263.5	89.4	83.2	122	258
Tetrachloroethylene [Tetrachloroethylene]	5	280	2800	950	884	1299	2748
Thallium	0.12	0.23	2.3	0.781	0.726	1.06	2.25
Toluene	1000	N/A	N/A	N/A	N/A	N/A	N/A
Toxaphene	0.011	0.011	0.11	0.0373	0.0347	0.0510	0.107
2,4,5-TP [Silvex]	50	369	3690	1252	1165	1712	3622
1,1,1-Trichloroethane	200	784354	7843540	2661923	2475589	3639115	7699080
1,1,2-Trichloroethane	5	166	1660	563	524	770	1629
Trichloroethylene [Trichloroethene]	5	71.9	719	244	227	333	705
2,4,5-Trichlorophenol	1039	1867	18670	6336	5893	8662	18326
TTHM [Sum of Total Trihalomethanes]	80	N/A	N/A	N/A	N/A	N/A	N/A
Vinyl Chloride	0.23	16.5	165	56.0	52.1	76.5	161

Human Health Daily Avg. Daily Avg. Parameter (µg/L) (µg/L) Acrylonitrile 373 453 Aldrin 0.0000372 0.0000452 Anthracene 4277 5193 Antimony 3478 4223 Arsenic N/A N/A Barium N/A N/A Benzene 1886 2291 Benzidine 0.347 0.421 Benzo(a) anthracene 0.0811 0.0985 Bis(chloromethyl)ether 0.891 1.08 Bis(2-ehloroethyl)ether 139 168 Bis(2-ehtylhexyl) phthalate [Di(2-ethylhexyl) phthalate) 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 383 1084 Bromoform [Tribromomethane [Dichlorobromomethane] 3842 4180 Cadmium N/A N/A Carbon Tetrachloride 149 181 Chlorodane 0.0081 0.0085 Chloroform [Trichloromethane] 2499 30354 Chloroform [T		70% of	85% of
Parameter (μρ/L) (μη/L) Acrylonitrile 373 453 Aldrin 0.000452 0.0000452 Anthracene 4277 5193 Antimony 3478 4223 Arsenic N/A N/A Barium N/A N/A Benzide 1886 2.291 Benzidine 0.0811 0.0985 Benzola juhrinacene 0.0811 0.0985 Benzola juhrinacene 0.0811 0.0985 Bis(chloromethyllether 0.891 1.08 Bis(2c-letrothyllether 139 1.68 Bis(2c-thylnexyll) phthalate [Di(2-ethylhexyll) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1.08 Bis(2c-thylnexyll) phthalate [Di(2-ethylhexyll) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1.08 Bis(2c-thylnexyll) phthalate [Di(2-ethylhexyll) phthalate] 24.5 29.7 Bromoform [Triboloromethane] 3034 4.818 0.00 <	Human Health	-	-
Actylonitrile 373 453 Aldrin 0.000372 0.0000452 Anthracene 4277 5193 Antimony 3478 4223 Arsenic N/A N/A Berace 1886 2291 Benzidine 0.0811 0.0985 Benzidine 0.0811 0.0985 Benzo(a) Janthracene 0.0811 0.0985 Benzo(a) Janthracene 0.0811 0.0985 Bis(2-chloroethyl)ether 0.0811 0.0985 Bis(2-chloroethyl)ether 139 168 Bis(2-ethylhexyl) phthalate [Dic(2-ethylhexyl) phthalate] 24.5 29.7 Bromodichloromethane [Dichorobromomethane] 893 1084 Bromodichloromethane [Dichorobromethane] 893 1084 Carbon Tetrachloride 149 181 Chlorodane 0.00811 0.0085 Chlorodibromomethane [Dibromochloromethane] 2497 30354 Chlorodibromomethane [Dibromochloromethane] 2497 30354 Chlorofori [Trichloromethane] 24	Parameter	(μg/L)	
Anthracene 4277 5193 Antimony 3478 4223 Arsenic N/A N/A Barium N/A N/A Benzene 1886 2291 Benzidine 0.0811 0.0985 Benzo(a) phracene 0.0811 0.0985 Bis(chloromethyllether 0.0811 0.0985 Bis(2-chloroethyllether 139 168 Bis(2-chloromethyllether 139 168 Bis(2-chloroethyllether) 139 168 Bis(2-chloroethyllether) 342 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromodichloromethane [Dichlorobromomethane] 393 1084 Bromodichloromethane [Dichlorobromomethane] 489 1093 Carbin Terrachloride 149 181 Chlorodane 0.0081 0.0085 Chlorodbenzene 889 10793 Chlorodbenzene 889 10793 Chlorodbenzene [Allethylene] 1630 1979 Chlorof	Acrylonitrile		
Antimony 3478 4223 Arsenic N/A N/A Barium N/A N/A Bernzene 1886 2291 Benzidine 0.0347 0.421 Benzo(a) janthracene 0.0811 0.00985 Benzo(a) pyrene 0.0811 0.00985 Bis(2-chloroethyl)ether 1.39 1.68 Bis(2-chlylexyl) phthalate [Di(2-ethylhexyl) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 38.3 1.08 Bromofich [Tirbromomethane] 3442 418.0 Carbon Tetrachloride 149 181 Chlorobenzene 8889 10793 Chlorodibromomethane [Dibromochloromethane] 594 721 Chlorofom [Trichloromethane] 594 721 Chloroform [Trichloromethane] 594 721 Chloroform [Trichloromethane] 594 721 Chloroform [Trichloromethane] 594 721 Chloroform [Trichloromethane] 1594 721 Chloroform [Trichloromethane] <t< td=""><td>Aldrin</td><td>0.0000372</td><td>0.0000452</td></t<>	Aldrin	0.0000372	0.0000452
Arsenic N/A N/A Barium N/A N/A Benzene 1886 2291 Benzidine 0.347 0.421 Benzo(a) pyrene 0.00811 0.00985 Bis(schloroethyl)ether 0.891 1.08 Bis(2-ethylhexyl) phthalate [Diclo-ethylhexyl) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoforn [Tribromomethane] 342 4180 Cadmium N/A N/A Carbon Tetrachloride 149 181 Chlorodane 0.00811 0.00985 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 2497 30354 Chloroform [Trichloromethane] 594 721 Chloroform [Trichloromethane] 30207 36680 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide [free) N/A N/A 4,4-bDD 0.00422 0.00512	Anthracene	4277	5193
Barium N/A N/A Benzene 1886 2291 Benzidine 0.341 0.421 Benzo(a) phyrene 0.0811 0.0985 Bis(chloromethyllether 0.0811 0.00851 Bis(2-ethylhexyl) phthalate [Dic2-ethylhexyl) phthalate [24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoform [Tribromomethane] 3442 4180 Cadmium N/A N/A Carbon Tetrachloride 149 181 Chlorobenzene 8889 10793 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroforfi [Trichloromethane] 24997 30354 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chloroform [Trichloromethane] 3000 36600 Cyanide (free) N/A N/A Chloroform [Trichloromethane] 1000 0.0014 Chysene 8.18 </td <td>Antimony</td> <td>3478</td> <td>4223</td>	Antimony	3478	4223
Benzene 1886 2291 Benzidine 0.347 0.421 Benzo(a) pyrene 0.0811 0.0985 Bis(chloromethyllether 0.891 1.08 Bis(2-chloroethyllether 139 168 Bis(2-chtylhexyl) phthalate [Di(2-ethylhexyl) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoform [Tribromomethane] 3442 4180 Carbon Tetrachloride 149 181 Chlorodane 0.00811 0.00985 Chlorodibromomethane [Dibromochloromethane] 594 721 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4*-DDD 0.00422 0.000512 4,4*-DDT 0.00123 0.00157 2,4*-D N/A N/A Danitol [Fenpropathrin] 153	Arsenic	N/A	N/A
Benzidine 0.347 0.421 Benzo(a) phyrene 0.0811 0.0985 Benzo(a) phyrene 0.0811 0.0985 Bis(schloromethyl)ether 0.891 1.08 Bis(2-chloroethyl)ether 139 168 Bis(2-chloroethyl)phthalate [Di(2-ethylhexyl)phthalate) 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 393 1084 Bromoform [Tribromomethane] 3442 4180 Cadmium N/A N/A Carbon Tetrachloride 149 181 Chlorodane 0.0811 0.00985 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 594 721 Chloroform [Trichloromethane] 1630 1979 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Chrysene 9.0 70.0 70.0 Chrysene 9.0 70.0 70.0 Chrysene	Barium	N/A	N/A
Benzo(a) pyrene 0.0811 0.0985 Benzo(a) pyrene 0.09811 0.00985 Bis (chloromethyl) ether 0.891 1.08 Bis (2-chloroethyl)ether 139 168 Bis (2-chloroethyl) phthalate [Di(2-ethylhexyl) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoform [Tribromomethane] 3442 4180 Cardini Tetrachloride 149 181 Chlordane 0.00811 0.00985 Chlorodibromomethane [Dibromochloromethane] 594 721 Chlorodibromomethane [Dibromochloromethane] 594 721 Chlorofim [Trichloromethane] 4979 30354 Chromium (hexavalent) 163 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 3680 Cyanide (free) N/A N/A 4,4-DDT 0.00642 0.00124 Quantial (free) 0.0042 0.00124 4,4-DDT 0.0012 0.00154 A,2-Dirichlorobe	Benzene	1886	2291
Benzo(a) pyrene 0.00811 0.00881 Bis (chloromethyl)ether 0.891 1.08 Bis (2-chloroethyl)ether 139 168 Bis (2-chloroethyl)ether 139 1084 Bis (2-chlyhlbexyl) phthalate [Di(2-ethylhexyl) phthalate] 245 29.7 Bromodichloromethane [Dichlorobromomethane] 393 1084 Bromoform [Trichromomethane] 3442 4180 Cadmium N/A N/A Chlorodane 149 181 Chlorodhezene 8889 10793 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 2497 30354 Chromium (hexavalent) 163 1973 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A 1/A 4,4*DDT 0.00649 0.00788 4,4*DDT 0.00649 0.00788 4,4*DDT 130 107 2,4*D 10 0.002	Benzidine	0.347	0.421
Bis(chloromethyl)ether 0.891 1.08 Bis(2-chloroethyl)ether 139 168 Bis(2-chlylmexyl) phthalate [Di(2-ethylhexyl) phthalate) 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoform [Tribromomethane] 3442 4180 Cadmium N/A N/A Chloroba ene 3889 10793 Chlorodane 0.00811 0.00985 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 2497 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.3 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4-DDD 0.00649 0.00788 4,4-DDT 0.00429 0.00512 2,4-D N/A N/A Al-Dichlorobenzene [1,3-Dichlorobenzene] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 19.3 2.3 1,2-Dichlorobenzene [1,4-Dichlorobenze	Benzo(a)anthracene	0.0811	0.0985
Bis(2-chloroethyl)ether 139 168 Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoform [Tribromomethane] 3442 4180 Cadmium N/A M/A Chlorodane 0.00811 0.00985 Chlorodibromomethane [Dibromochloromethane] 8889 10793 Chlorodibromomethane [Dibromochloromethane] 24997 30354 Chloroform [Trichloromethane] 24997 30354 Chloroform [Trichloromethane] 24997 30354 Chloroform [Trichloromethane] 32027 36680 Chloroform [Trichloromethane] 30207 36680 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A 4/A 4,4-DDE 0.00649 0.00849 4,4-DDE 0.00649 0.00129 4,4-DDT 0.00129 0.00157 2,4-D N/A N/A Anitoli [Fenpropa	Benzo(a)pyrene	0.00811	0.00985
Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phthalate] 24.5 29.7 Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoform [Tribromomethane] 3442 4180 Cadmium N/A N/A Carbon Tetrachloride 149 181 Chlorodane 0.00811 0.00985 Chlorodibromethane [Dibromochloromethane] 594 721 Chlorodibromomethane [Dibromochloromethane] 2497 30354 Chloroform [Trichloromethane] 2497 30354 Chlorofium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4*-DDD 0.00429 0.00548 4,4*-DDT 0.00129 0.00157 2,4*-D N/A N/A Ay-Danitol [Fenpropathrin] 1536 1865 1,2*-Dichlorobenzene [1,3*-Dichlorobenzene] 1937 2346 0*-Dichlorobenzene [1,4*-Dichlorobenzene] 1974 1301 <	Bis(chloromethyl)ether	0.891	1.08
Bromodichloromethane [Dichlorobromomethane] 893 1084 Bromoform [Tribromomethane] 3442 4180 Cadmium N/A N/A Carbon Tetrachloride 181 0.00811 0.00851 Chlorodene 8889 10793 1093 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4-DDD 0.00649 0.00788 4,4'-DDT 0.00129 0.00152 2,4'-D N/A N/A A,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] </td <td>Bis(2-chloroethyl)ether</td> <td>139</td> <td>168</td>	Bis(2-chloroethyl)ether	139	168
Bromoform [Tribromomethane] 3442 4180 Cadmium N/A N/A Carbon Tetrachloride 149 181 Chlorodne 8889 10793 Chlorodbenzene 889 10793 Chloroform [Trichloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4-DDE 0.00649 0.00848 4,4-DDE 0.00129 0.00152 4,4-DDT 0.00129 0.00157 2,4-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,2-Dichlorobenzene] 1974 1301 p-Dichlorobenzene [1,4-Dichlorobenzene] 1789 21735 <	Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phthalate]	24.5	29.7
Cadmium N/A N/A Carbon Tetrachloride 149 181 Chlordane 0.00811 0.00985 Chlorobenzene 8889 10793 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4°-DDD 0.00649 0.00788 4,4°-DDT 0.00129 0.00152 4,4°-DDT 0.00129 0.00157 2,4°-D N/A N/A 4,4°-DDT 0.00129 0.00157 2,4°-D N/A N/A Ay-10 (September (Ethylene Dibromide) 133 1865 1,2-Dibromoethane [Ethylene Dibromide] 133 1865 1,2-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 0-Dichlorobenzene [1,4-Dichlorobenzene] 10.7 8.83	Bromodichloromethane [Dichlorobromomethane]	893	1084
Carbon Tetrachloride 149 181 Chlordane 0.00811 0.00985 Chlorobenzene 8889 10793 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.00129 0.00129 4,4'-DDT 0.00129 0.00129 2,4'-D N/A N/A A,4'-DDE 0.00129 0.00129 4,4'-DDT 0.00129 0.00129 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Diblomocethane [Ethylene Dibromide] 137 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3	Bromoform [Tribromomethane]	3442	4180
Chlorodane 0.00811 0.00985 Chlorobenzene 8889 10793 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.00129 0.00122 4,4'-DDT 0.00129 0.00152 2,4'-D N/A N/A A,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A A,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzene [1,4-Dichlorobenzene] 182 1435 <t< td=""><td>Cadmium</td><td>N/A</td><td>N/A</td></t<>	Cadmium	N/A	N/A
Chlorobenzene 8889 10793 Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.00129 0.00157 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzene [1,4-Dichlorobenzene] 17896 217352 Dichlorobenzene [Methylene Chloride] 43302 52581 1,2-Dichloropenpane 841 1021 1,3-D	Carbon Tetrachloride	149	181
Chlorodibromomethane [Dibromochloromethane] 594 721 Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00782 4,4'-DDE 0.00129 0.00157 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 17896 217352 Dichloromethane [Methylene Chloride] 386 469 Dico	Chlordane	0.00811	0.00985
Chloroform [Trichloromethane] 24997 30354 Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.00122 0.00157 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichloroethane 1.2 1.83 1,2-Dichloroethylene [1,1-Dichloroethene] 17896 217352 1,2-Dichloropropane 841 1021 1,3-Dichloropropane 841 1021 1,3-Dichloropropane 841 1021 1,0-Dichloropropane 841	Chlorobenzene	8889	10793
Chromium (hexavalent) 1630 1979 Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.00129 0.001512 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,2-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,2-Dichlorobethane 1182 1435 1,2-Dichloropenpane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Diedrin	Chlorodibromomethane [Dibromochloromethane]	594	721
Chrysene 8.18 9.93 Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.00129 0.00152 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 0-Dichlorobenzene [1,4-Dichlorobenzene] 19714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichlorobenzidine 7.27 8.83 1,2-Dichlorobenzidine 7.27 8.83 1,2-Dichlorobenzidine 7.27 8.83 1,2-Dichloropethylene [1,1-Dichloroethene] 178996 217352 Dichloropropane 841 1021 1,3-Dichloropropane 841 1021 1,3-Dichloropropane 841	Chloroform [Trichloromethane]	24997	30354
Cresols [Methylphenols] 30207 36680 Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.000422 0.000512 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,2-Dichloroethylene [1,1-Dichloroethene] 17896 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropane [1,3-Dichloropropylene] 386 469 Diciofol [Kelthane] 0.974 1.18 Dieldrin 0.000649 0.000788 2,4-	Chromium (hexavalent)	1630	1979
Cyanide (free) N/A N/A 4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.000422 0.000512 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,4-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,2-Dichloroethane 1182 1435 1,1-Dichloroptoplene [1,1-Dichloroethene] 17896 217352 Dichloroptropane 841 1021 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [kelthane] 0.000449 0.000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate <td>Chrysene</td> <td>8.18</td> <td>9.93</td>	Chrysene	8.18	9.93
4,4'-DDD 0.00649 0.00788 4,4'-DDE 0.000422 0.000512 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.000649 0.000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dio	Cresols [Methylphenols]	30207	36680
4,4'-DDE 0.000422 0.000159 4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropane [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 </td <td>Cyanide (free)</td> <td>N/A</td> <td>N/A</td>	Cyanide (free)	N/A	N/A
4,4'-DDT 0.00129 0.00157 2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 17896 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropane [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788	4,4'-DDD	0.00649	0.00788
2,4'-D N/A N/A Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o -Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 p -Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicoldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylene Glycol 54562091 66253967	4,4'-DDE	0.000422	0.000512
Danitol [Fenpropathrin] 1536 1865 1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o-Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 17896 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylene Glycol 54562091 662539	4,4'-DDT	0.00129	0.00157
1,2-Dibromoethane [Ethylene Dibromide] 13.7 16.7 m-Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 ο -Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 ρ -Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 <t< td=""><td>2,4'-D</td><td>N/A</td><td>N/A</td></t<>	2,4'-D	N/A	N/A
m - Dichlorobenzene [1,3-Dichlorobenzene] 1932 2346 o - Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 p - Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394	Danitol [Fenpropathrin]	1536	1865
o -Dichlorobenzene [1,2-Dichlorobenzene] 10714 13010 p -Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000220 0.00268	1,2-Dibromoethane [Ethylene Dibromide]	13.7	16.7
p-Dichlorobenzene [1,4-Dichlorobenzene] N/A N/A 3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000220 0.00220	<i>m</i> -Dichlorobenzene [1,3-Dichlorobenzene]	1932	2346
3,3'-Dichlorobenzidine 7.27 8.83 1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000220 0.00268	o -Dichlorobenzene [1,2-Dichlorobenzene]	10714	13010
1,2-Dichloroethane 1182 1435 1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000240 0.0014 Hexachlorobenzene 0.00220 0.00268	p -Dichlorobenzene [1,4-Dichlorobenzene]	N/A	N/A
1,1-Dichloroethylene [1,1-Dichloroethene] 178996 217352 Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.00020 0.00268	3,3'-Dichlorobenzidine	7.27	8.83
Dichloromethane [Methylene Chloride] 43302 52581 1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.00020 0.0014 Hexachlorobenzene 0.00220 0.00268	1,2-Dichloroethane	1182	1435
1,2-Dichloropropane 841 1021 1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000220 0.00268	1,1-Dichloroethylene [1,1-Dichloroethene]	178996	217352
1,3-Dichloropropene [1,3-Dichloropropylene] 386 469 Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n -Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Dichloromethane [Methylene Chloride]	43302	52581
Dicofol [Kelthane] 0.974 1.18 Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	1,2-Dichloropropane	841	1021
Dieldrin 0.0000649 0.0000788 2,4-Dimethylphenol 27397 33268 Di-n -Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000240 0.00114 Hexachlorobenzene 0.00220 0.00268	1,3-Dichloropropene [1,3-Dichloropropylene]	386	469
2,4-Dimethylphenol 27397 33268 Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.00020 0.00268	Dicofol [Kelthane]	0.974	1.18
Di-n-Butyl Phthalate 300 364 Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Dieldrin	0.0000649	0.0000788
Dioxins/Furans [TCDD Equivalents] 2.58E-07 3.14E-07 Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	2,4-Dimethylphenol	27397	33268
Endrin 0.0649 0.0788 Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Di-n -Butyl Phthalate	300	364
Epichlorohydrin 6537 7938 Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Dioxins/Furans [TCDD Equivalents]	2.58E-07	3.14E-07
Ethylbenzene 6063 7362 Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Endrin	0.0649	
Ethylene Glycol 54562091 66253967 Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Epichlorohydrin	6537	7938
Fluoride N/A N/A Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Ethylbenzene	6063	7362
Heptachlor 0.000324 0.000394 Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Ethylene Glycol	54562091	66253967
Heptachlor Epoxide 0.000941 0.00114 Hexachlorobenzene 0.00220 0.00268	Fluoride	N/A	N/A
Hexachlorobenzene 0.00220 0.00268	Heptachlor	0.000324	0.000394
	Heptachlor Epoxide	0.000941	0.00114
Hexachlorobutadiene 0.714 0.867	Hexachlorobenzene	0.00220	0.00268
	Hexachlorobutadiene	0.714	0.867

	70% of	85% of
Human Health	Daily Avg.	Daily Avg.
Parameter	(μg/L)	(μg/L)
Hexachlorocyclohexane (alpha)	0.0272	0.0331
Hexachlorocyclohexane (beta)	0.844	1.02
Hexachlorocyclohexane (gamma) [Lindane]	1.10	1.34
Hexachlorocyclopentadiene	37.6	45.7
Hexachloroethane	7.56	9.18
Hexachlorophene	9.41	11.4
4,4'-Isopropylidenediphenol	51905	63028
Lead	65.5	79.6
Mercury	0.0396	0.0481
Methoxychlor	9.74	11.8
Methyl Ethyl Ketone	3221761	3912139
Methyl tert -butyl ether [MTBE]	34042	41337
Nickel	8136	9880
Nitrate-Nitrogen (as Total Nitrogen)	N/A	N/A
Nitrobenzene	6083	7386
N-Nitrosodiethylamine	6.82	8.28
N-Nitroso-di-n -Butylamine	13.6	16.5
Pentachlorobenzene	1.15	1.40
Pentachlorophenol	0.941	1.14
Polychlorinated Biphenyls [PCBs]	0.00207	0.00252
Pyridine	3075	3734
Selenium	N/A	N/A
1,2,4,5-Tetrachlorobenzene	0.779	0.946
1,1,2,2-Tetrachloroethane	85.5	103
Tetrachloroethylene [Tetrachloroethylene]	909	1104
Thallium	0.746	0.907
Toluene	N/A	N/A
Toxaphene	0.0357	0.0433
2,4,5-TP [Silvex]	1198	1455
1,1,1-Trichloroethane	2547380	3093247
1,1,2-Trichloroethane	539	654
Trichloroethylene [Trichloroethene]	233	283
2,4,5-Trichlorophenol	6063	7362
TTHM [Sum of Total Trihalomethanes]	N/A	N/A
Vinyl Chloride	53.5	65.0

Appendix B TDS, Chloride, and Sulfate Screening Calculations

Screening Calculations for Total Dissolved Solids, Chloride, and Sulfate Menu 7 - Discharge to an Intermittent Stream with Perennial Pools

Screen the Perennial Pool Characteristics of the Stream

Applicant Name: Wright City Water Supply Co.

Permit Number, Outfall: 05459-000, 001

Segment Number: 0611

Enter values needed for screening:		Data Source (edit if different)
QE - Average effluent flow	0.054 MGD	
QS - Stream harmonic mean flow	0.10 cfs	Critical conditions memo
QE - Average effluent flow	0.0836 cfs	Calculated
CA - TDS - ambient segment concentration	134 mg/L	2010 IP, Appendix D
CA - chloride - ambient segment concentration	19 mg/L	2010 IP, Appendix D
CA - sulfate - ambient segment concentration	22 mg/L	2010 IP, Appendix D
CC - TDS - segment criterion	250 mg/L	Latest EPA approved TSWQS, Appendix A
CC - chloride - segment criterion	125 mg/L	Latest EPA approved TSWQS, Appendix A
CC - sulfate - segment criterion	50 mg/L	Latest EPA approved TSWQS, Appendix A
CE - TDS - average effluent concentration	730 mg/L	Permit application
CE - chloride - average effluent concentration	170 mg/L	Permit application
CE - sulfate - average effluent concentration	44.7 mg/L	Permit application

Screening Equation

 $CC \ge [(QS)(CA) + (QE)(CE)]/[QE + QS]$

Permit Limit Calculations

TDS

. 2 3					
Calculate the WLA	WLA= [CC(QE+QS) - (QS)(CA)]/QE			388.84	
Calculate the LTA	LTA = WLA * 0.93			361.62	
Calculate the daily average	Daily Avg. = LTA * 1.47			531.58	
Calculate the daily maximum	Daily Max. = LTA * 3.11			1124.64	
Calculate 70% of the daily average	70% of Daily Avg. =			372.11	
Calculate 85% of the daily average	85% of Daily Avg. =		451.84		
No permit limitations needed if:	730	≤	372.11		
Reporting needed if:	730	>	372.11	but ≤	451.84
Permit limits may be needed if:	730	>	451.84		

Permit limits may be needed for TDS

Chloride

Calculate the WLA	WLA=[CC(QE+QS) - (QS)(CA)]/QE			251.87	
Calculate the LTA	LTA = WLA * 0.93			234.24	
Calculate the daily average	Daily Avg. = LTA * 1.47			344.33	
Calculate the daily maximum	Daily Max. = LTA * 3.11			728.48	
Calculate 70% of the daily average	70% of Daily Avg. =			241.03	
Calculate 85% of the daily average	85% of Daily Avg. =			292.68	
	470	4	244 02		
No permit limitations needed if:	170	≤	241.03		
Reporting needed if:	170	>	241.03	but≤	292.68
Permit limits may be needed if:	170	>	292.68		

No permit limitations needed for chloride

Sulfate

Juliate					
Calculate the WLA	WLA = [CC(QE+QS) - (QS)(CA)]/QE			83.51	
Calculate the LTA	LTA = WLA * 0.93			77.67	
Calculate the daily average	Daily Avg. = LTA * 1.47			114.17	
Calculate the daily maximum	Daily Max. = LTA * 3.11			241.54	
Calculate 70% of the daily average	70% of Daily Avg. =			79.92	
Calculate 85% of the daily average	85% of Daily Avg. =			97.04	
No permit limitations needed if:	44.7	≤	79.92		
Reporting needed if:	44.7	>	79.92	but≤	97.04
Permit limits may be needed if:	44.7	>	97.04		

No permit limitations needed for sulfate

Appendix C Comparison of Effluent Limits

The following table is a summary of technology-based effluent limitations calculated/assessed in the draft permit (Technology-Based) and calculated/assessed water quality-based effluent limitations (Water Quality-Based. Effluent limitations appearing in bold are the most stringent of the three and are included in the draft permit.

		Technolog	gy-Based	Water Quality-Based	
Outfall	Pollutant	Daily Avg	Daily Max	Daily Avg	Daily Max
		mg/L	mg/L	mg/L	mg/L
001	Flow, MGD	0.0540 MGD	Report, MGD	-	-
	Dissolved Aluminum 1	-	-	Report	Report
	Total Aluminum ¹	-	-	Report	Report
	TDS ¹	N/A	Report	-	-
	Chloride ¹	N/A	Report	-	-
	Sulfate ¹	N/A	Report	-	-
	рН	6.0 SU, minimum	9.0 SU	-	-

¹ This monitoring requirement begins upon the date of issuance of permit and expires 58 months after date of permit issuance.