

# This file contains the following documents:

- 1. Summary of application (in plain language)
- 2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
- 3. Second notice (NAPD-Notice of Preliminary Decision)
- 4. Application materials
- 5. Draft permit
- 6. Technical summary or fact sheet

# ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

CITY OF LAMESA (CN600632400) operates CITY OF LAMESA WWTP RN101918977. an ACTIVATED SLUDGE PLANT. The facility is located approximately 2,600 feet east-northeast of the intersection of CR 20 and SH 137.

Discharges from the facility are expected to contain TSS, 5 DAY CBOD, AMMONIA NITROGEN, ESCHERICHIA E COLI ... TREATED EFFLUENT is treated by *ACTIVATED SLUDGE PROCESS PLANT. WHICH INCLUDES A PLANT SCREEN, ARIATION BASIN, FINAL CLARAFIERS, BELT FILTER PRESS, UV SYSTEM, AND CASCADE* 

# **TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**



# NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT RENEWAL.

#### PERMIT NO. WQ0010107001

**APPLICATION.** City of Lamesa, 601 South 1st Street, Lamesa, Texas 79331, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010107001 (EPA I.D. No. TX0129011) to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 2,000,000 gallons per day. The domestic wastewater treatment facility is located approximately 2,600 feet east-northeast of the intersection of County Road 20 and State Highway 137, near the city of Lamesa, in Dawson County, Texas 79331. The discharge route is from the plant site via pipe to Sulphur Springs Draw; thence to Natural Dam Lake; thence to Sulphur Springs Draw; thence to Beals Creek; thence to the Colorado River Below Lake J.B. Thomas. TCEQ received this application on June 3, 2024. The permit application will be available for viewing and copying at Lamesa City Hall, 601 South 1st Street, Lamesa, in Dawson County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: https://www.tceq.texas.gov/permitting/wastewater/pendingpermits/tpdes-applications. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-101.946111,32.711944&level=18

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. Notice of the Application and Preliminary Decision will be published and mailed to those who are on the countywide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.

**PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application.** The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at <a href="https://www.tceq.texas.gov/goto/cid">www.tceq.texas.gov/goto/cid</a>. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at <a href="https://www14.tceq.texas.gov/epic/eComment/">https://www14.tceq.texas.gov/epic/eComment/</a>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at <a href="www.tceq.texas.gov/goto/pep">www.tceq.texas.gov/goto/pep</a>. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from City of Lamesa at the address stated above or by calling Mr. Ernest Ojeda, Utility Director, at 806-201-0243.

Issuance Date: June 26, 2024

#### **Texas Commission on Environmental Quality**



# NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR MUNICIPAL WASTEWATER

#### **RENEWAL**

#### **PERMIT NO. WQ0010107001**

**APPLICATION AND PRELIMINARY DECISION.** City of Lamesa, 601 South 1st Street, Lamesa, Texas 79331, has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010107001, which authorizes the discharge of treated domestic wastewater at an annual average flow not to exceed 2,000,000 gallons per day. TCEQ received this application on June 3, 2024.

The facility is located approximately 2,600 feet east-northeast of the intersection of County Road 20 and State Highway 137, in Dawson County, Texas 79331. The treated effluent is discharged via pipe to Sulphur Springs Draw, thence to Natural Dam Lake, thence to Sulphur Springs Draw, thence to Beals Creek, thence to the Colorado River Below Lake J.B. Thomas in Segment No. 1412 of the Colorado River Basin. The unclassified receiving water use is minimal aquatic life use for Sulphur Springs Draw. The designated uses for Segment No. 1412 are primary contact recreation and high aquatic life use. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-101.946111,32.711944&level=18

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at Lamesa City Hall, 601 South 1st Street, Lamesa, in Dawson County, Texas. The application, including any updates, and associated notices are available electronically at the following webpage: <a href="https://www.tceq.texas.gov/permitting/wastewater/tpdes-applications">https://www.tceq.texas.gov/permitting/wastewater/tpdes-applications</a>.

**PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting about this application.** The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ holds a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision. A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period. TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

**EXECUTIVE DIRECTOR ACTION.** The Executive Director may issue final approval of the application unless a timely contested case hearing request or request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

**MAILING LIST.** If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, Texas Commission on Environmental Quality, P.O. Box 13087, Austin, TX 78711-3087 or electronically at <a href="https://www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a> within 30 days from the date of newspaper publication of this notice.

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at <a href="https://www.tceq.texas.gov/goto/cid">www.tceq.texas.gov/goto/cid</a>. Search the database using the permit number for this application, which is provided at the top of this notice.

**AGENCY CONTACTS AND INFORMATION.** Public comments and requests must be submitted either electronically at <a href="www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC 105, P.O. Box 13087, Austin, Texas 78711-3087. Any personal information you submit to the TCEQ will become part of the agency's record; this includes email addresses. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at <a href="www.tceq.texas.gov/goto/pep">www.tceq.texas.gov/goto/pep</a>. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from City of Lamesa at the address stated above or by calling Mr. Ernest Ojeda, Utility Director, at 806-201-0243.

Issuance Date: October 14, 2025

# THE TONMENTAL OUR LEVEL OF THE TON THE

### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

APPLICANT NAME:	City of Lamesa
-----------------	----------------

PERMIT NUMBER (If new, leave blank): WQ00 10107001

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	$\boxtimes$		Original USGS Map	$\boxtimes$	
Administrative Report 1.1		$\boxtimes$	Affected Landowners Map		$\boxtimes$
SPIF	$\boxtimes$		Landowner Disk or Labels		$\boxtimes$
Core Data Form	$\boxtimes$		Buffer Zone Map		$\boxtimes$
Public Involvement Plan Form		$\boxtimes$	Flow Diagram	$\boxtimes$	
Technical Report 1.0	$\boxtimes$		Site Drawing	$\boxtimes$	
Technical Report 1.1			Original Photographs		$\boxtimes$
Worksheet 2.0	$\boxtimes$		Design Calculations		$\boxtimes$
Worksheet 2.1			Solids Management Plan		$\boxtimes$
Worksheet 3.0		$\boxtimes$	Water Balance		$\boxtimes$
Worksheet 3.1		$\boxtimes$			
Worksheet 3.2					
Worksheet 3.3					
Worksheet 4.0	$\boxtimes$				
Worksheet 5.0	$\boxtimes$				
Worksheet 6.0	$\boxtimes$				
Worksheet 7.0		$\boxtimes$			

For TCEQ Use Only	
Segment Number	County
Expiration Date	Region
Permit Number	

# THE TONMENTAL OUR LEVEL OF THE TON THE

#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

## **Section 1.** Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
<0.05 MGD	\$350.00 □	\$315.00 □
≥0.05 but <0.10 MGD	\$550.00 □	\$515.00 □
≥0.10 but <0.25 MGD	\$850.00 □	\$815.00 □
≥0.25 but <0.50 MGD	\$1,250.00 □	\$1,215.00
≥0.50 but <1.0 MGD	\$1,650.00 □	\$1,615.00
≥1.0 MGD	\$2,050.00 □	\$2,015.00

Minor Amendment (for any flow) \$150.00 □

Payment	Informa	tion
---------	---------	------

Mailed	Check/Money Order Number: Click to enter text.
	Check/Money Order Amount: Click to enter text.
	Name Printed on Check: Click to enter text.
EPAY	Voucher Number: Click to enter text.
Copy of Payr	nent Voucher enclosed? Yes □

# Section 2. Type of Application (Instructions Page 26)

a.	Che	ck the box next to the appropriate authorization type
	$\boxtimes$	Publicly-Owned Domestic Wastewater
		Privately-Owned Domestic Wastewater
		Conventional Wastewater Treatment
b.	Che	ck the box next to the appropriate facility status.
	$\boxtimes$	Active   Inactive

c.	Che	eck the box next to the appropriate permit typ	e.	
	$\boxtimes$	TPDES Permit		
		TLAP		
		TPDES Permit with TLAP component		
		Subsurface Area Drip Dispersal System (SAD	DS)	
d.	Che	eck the box next to the appropriate application	ı typ	e
		New	-71	
		Major Amendment <i>with</i> Renewal		Minor Amendment <i>with</i> Renewal
		Major Amendment <i>without</i> Renewal		Minor Amendment <i>without</i> Renewal
	$\boxtimes$	Renewal without changes		Minor Modification of permit
Δ	For	amendments or modifications, describe the p	ronc	read changes: Click to enter text
		•	торс	oscu changes. enex to enter text.
f.		existing permits:		
		mit Number: WQ00 <u>10107001</u>		
	EPA	A I.D. (TPDES only): TX <u>0129011</u>		
	Exp	oiration Date: <u>12/06/2024</u>		
Se	ectio	on 3. Facility Owner (Applicant) a	nd	Co-Applicant Information
		(Instructions Page 26)		
A.	The	e owner of the facility must apply for the per	mit.	
	Wha	at is the Legal Name of the entity (applicant) a	pply	ing for this permit?
	<u>City</u>	<u>v of Lamesa</u>		
		e legal name must be spelled exactly as filed w legal documents forming the entity.)	ith th	he Texas Secretary of State, County, or in
		ne applicant is currently a customer with the T n may search for your CN on the TCEQ website		
		CN: <u>600632400</u>		
		at is the name and title of the person signing t		

Prefix: Mr. Last Name, First Name: Stevens, Josh

Title: Mayor Credential: Click to enter text.

**B. Co-applicant information.** Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

N/A

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the legal documents forming the entity.)

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: <a href="http://www15.tceq.texas.gov/crpub/">http://www15.tceq.texas.gov/crpub/</a>

CN: Click to enter text.

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in *30 TAC § 305.44*.

Prefix: Click to enter text. Last Name, First Name: Click to enter text.

Title: Click to enter text. Credential: Click to enter text.

Provide a brief description of the need for a co-permittee: Click to enter text.

#### C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. <u>Appendix A</u>

## Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Mr. Last Name, First Name: Ojeda, Ernest

Title: <u>Utility Director</u> Credential: Click to enter text.

Organization Name: City of Lamesa

Mailing Address: 601 S. 1st Street City, State, Zip Code: Lamesa, TX 79331

Phone No.: 806.201.0243 E-mail Address: directorofutilities@ci.lamesa.tx.us

Check one or both: 

Administrative Contact

Technical Contact

B. Prefix: Mr. Last Name, First Name: Krueger, Paul

Title: <u>Civil Engineer</u> Credential: <u>P.E.</u>

Organization Name: Parkhill

Mailing Address: 4222 85th Street City, State, Zip Code: <u>Lubbock, TX, 79423</u>

Phone No.: <u>806.473.2200</u> E-mail Address: <u>pkrueger@parkhill.com</u>

Check one or both: oxdot Administrative Contact oxdot Technical Contact

# Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Mr. Last Name, First Name: Ojeda, Ernest

Title: <u>Utilities Director</u> Credential: Click to enter text.

Organization Name: City of Lamesa

Mailing Address: 601 S. 1st Street City, State, Zip Code: Lamesa, TX, 79331

Phone No.: 806.201.0243 E-mail Address: directorofutilities@ci.lamesa.tx.us

**B.** Prefix: Mr. Last Name, First Name: Krueger, Paul

Title: <u>Civil Engineer</u> Credential: <u>P.E.</u>

Organization Name: Parkhill

Mailing Address: 4222 85th Street City, State, Zip Code: <u>Lubbock, TX, 79423</u>

Phone No.: 806.473.2200 E-mail Address: pkrueger@parkhill.com

# Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Mr. Last Name, First Name: Hines, Joe

Title: <u>City Manager</u> Credential: Click to enter text.

Organization Name: City of Lamesa

Mailing Address: 601 1st Street City, State, Zip Code: Lamesa, TX, 79331

Phone No.: 806.872.2124 E-mail Address: jhines@ci.lamesa.tx.us

## Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Mr. Last Name, First Name: Ojeda, Ernest

Title: <u>Utilities Director</u> Credential: Click to enter text.

Organization Name: City of Lamesa

Mailing Address: 601 S. 1st Street City, State, Zip Code: Lamesa, TX, 79331

Phone No.: 806.201.0243 E-mail Address: directorofutilities@ci.lamesa.tx.us

# Section 8. Public Notice Information (Instructions Page 27)

#### A. Individual Publishing the Notices

Prefix: Mr. Last Name, First Name: Krueger, Paul

Title: <u>Civil Engineer</u> Credential: <u>P.E.</u>

Organization Name: Parkhill

Mailing Address: 4222 85th Street City, State, Zip Code: <u>Lubbock, TX, 79423</u>

Phone No.: 806.473.2200 E-mail Address: pkrueger@parkhill.com

В.		thod for Receiving Notice of ckage	Receipt and Intent to Obtain a Water Quality Permit
	Ind	licate by a check mark the pre	ferred method for receiving the first notice and instructions:
	$\boxtimes$	E-mail Address	
		Fax	
	$\boxtimes$	Regular Mail	
C.	Co	ntact permit to be listed in th	ne Notices
	Pre	fix: <u>Mr.</u>	Last Name, First Name: <u>Ojeda, Ernest</u>
	Tit	le: <u>Utilities Director</u>	Credential: Click to enter text.
	Org	ganization Name: <u>City of Lames</u>	<u>a</u>
	Ma	iling Address: <u>601 S. 1st Street</u>	City, State, Zip Code: Lamesa, TX, 79331
	Pho	one No.: <u>806.201.0243</u>	E-mail Address: directorofutilities@ci.lamesa.tx.us
D.	Pul	blic Viewing Information	
	•	he facility or outfall is located inty must be provided.	in more than one county, a public viewing place for each
	Pul	olic building name: <u>City Hall</u>	
	Loc	cation within the building: <u>City</u>	Managers Office
	Phy	vsical Address of Building: <u>601</u>	S. 1st Street
	Cit	y: <u>Lamesa</u>	County: <u>Dawson</u>
	Co	ntact (Last Name, First Name):	<u>Joe Hines</u>
	Pho	one No.: <u>806.872.2124</u> Ext.: Clic	k to enter text.
E.	Bili	ingual Notice Requirements	
		is information <b>is required</b> for o <b>dification, and renewal</b> appli	new, major amendment, minor amendment or minor cations.
	be		only used to determine if alternative language notices will s on publishing the alternative language notices will be in
	obt		dinator at the nearest elementary and middle schools and to determine whether an alternative language notices are
	1.		am required by the Texas Education Code at the elementary ne facility or proposed facility?
		□ Yes ⊠ No	
		If <b>no</b> , publication of an altern below.	ative language notice is not required; <b>skip to</b> Section 9
	2.	Are the students who attend a bilingual education program	either the elementary school or the middle school enrolled in at that school?
		□ Yes □ No	

	3.	Do the locatio	students at n?	these	schoo	ls attend	a bilingua	l educa	tion prog	ram at	another
			Yes		No						
	4.		the school out of this							gram b	out the school has
			Yes		No						
	5.		nswer is <b>ye</b> ed. Which la								tive language are enter text.
F.	Pla	ain Lang	guage Sumn	nary T	empla	te					
	Co	mplete	the Plain La	nguage	e Sumi	mary (TC	EQ Form 2	0972) a	and includ	de as a	n attachment.
	At	tachme	nt: <u>Appendix</u>	<u>x B</u>							
G	Pıı	hlic Inv	olvement F	Plan Fo	rm						
<b>.</b>						Plan Form	(TCEO Fo	rm 209	(60) for e	ach an	plication for a
		-	it or major								-
	At	tachme	<b>nt:</b> <u>N/A - Re</u> :	<u>newal</u>							
Se	cti	ion 9.	Regula Page 29		ntity	and Pe	ermitted	l Site	Inform	ation	(Instructions
Α.				regula	ited by	TCEQ, p	rovide the	Regula	ted Entity	y Num	ber (RN) issued to
			e TCEQ's Cer currently re				<u>//www15.1</u>	ceq.tex	as.gov/cı	<u>pub/</u> 1	to determine if
B.	Na	me of p	roject or sit	te (the	name	known by	the comr	nunity	where loc	ated):	
	<u>Cit</u>	y of Lam	iesa Wastewa	ater Tre	atment	t Plant					
C.	Ov	vner of	treatment fa	acility:	City of	Lamesa					
	Ov	vnership	of Facility:		Public		Private		Both		Federal
D.	Ov	vner of l	land where	treatm	ent fac	cility is o	will be:				
	Pre	efix: <u>N/</u>	<u>4</u>		I	ast Nam	e, First Na	me: Clic	ck to ente	er text.	
	Tit	tle: Click	k to enter te	ext.	(	Credentia	l: Click to	enter to	ext.		
	Or	ganizati	ion Name: <u>C</u>	City of L	<u>amesa</u>						
	Ma	ailing Ac	ldress: <u>601 \$</u>	S 1st Str	<u>reet</u>		City, State	e, Zip C	ode: <u>Lam</u> e	esa, TX	<u>, 79331</u>
	Ph	one No.	: 806.872.21	<u>24</u>		E-mail A	ddress: <u>jhi</u>	nes@ci.]	lamesa.tx.	<u>us</u>	
			lowner is no t or deed re		_		-		or co-ap	plicant	t, attach a lease
		Attach	ment: <u>N/A</u>								

	Prefix: <u>N/A</u>	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ent	er text.
	Mailing Address: Click to enter t	ext. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded eas	e person as the facility owner or co-applicant, attach a lease ement. See instructions.
	Attachment: Click to enter to	ext.
F.	Owner sewage sludge disposal s property owned or controlled by	ite (if authorization is requested for sludge disposal on the applicant)::
	Prefix: <u>N/A</u>	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ent	er text.
	Mailing Address: Click to enter t	ext. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded eas	e person as the facility owner or co-applicant, attach a lease ement. See instructions.
	Attachment: Click to enter to	ext.
_		
Se	ection 10. TPDES Dischar	ge Information (Instructions Page 31)
		ge Information (Instructions Page 31) lity location in the existing permit accurate?
	Is the wastewater treatment facion    Yes  No  If no, or a new permit application	
	Is the wastewater treatment faci	lity location in the existing permit accurate?
A.	Is the wastewater treatment facions in the wastewater treatment facions in the second	lity location in the existing permit accurate?  on, please give an accurate description:
A.	Is the wastewater treatment facions in the wastewater treatment facions in the second	lity location in the existing permit accurate?
A.	Is the wastewater treatment facion  ✓ Yes □ No  If no, or a new permit application  N/A  Are the point(s) of discharge and  ✓ Yes □ No	on, please give an accurate description:  d the discharge route(s) in the existing permit correct?
A.	Is the wastewater treatment facing  ✓ Yes ☐ No  If no, or a new permit application in the point (s) of discharge and in the waste of discharge and the disc	lity location in the existing permit accurate?  on, please give an accurate description:
A.	Is the wastewater treatment facing  ✓ Yes □ No  If no, or a new permit application of the point (s) of discharge and waste or an endment proport of discharge and the dischar	lity location in the existing permit accurate?  on, please give an accurate description:  d the discharge route(s) in the existing permit correct?  permit application, provide an accurate description of the
A.	Is the wastewater treatment facion    ✓ Yes	lity location in the existing permit accurate?  on, please give an accurate description:  d the discharge route(s) in the existing permit correct?  permit application, provide an accurate description of the large route to the nearest classified segment as defined in 30
A.	Is the wastewater treatment facing Yes □ No  If no, or a new permit application N/A  Are the point(s) of discharge and waste and the discharge and the disc	lity location in the existing permit accurate?  on, please give an accurate description:  d the discharge route(s) in the existing permit correct?  permit application, provide an accurate description of the large route to the nearest classified segment as defined in 30
A.B.	Is the wastewater treatment facing Yes No  If no, or a new permit application N/A  Are the point(s) of discharge and Yes No  If no, or a new or amendment property of discharge and the discharg	lity location in the existing permit accurate?  on, please give an accurate description:  d the discharge route(s) in the existing permit correct?  permit application, provide an accurate description of the targe route to the nearest classified segment as defined in 30 as s/are located: <a href="Dawson">Dawson</a>
A.B.	Is the wastewater treatment facing Yes No  If no, or a new permit application N/A  Are the point(s) of discharge and Yes No  If no, or a new or amendment property of discharge and the discharg	lity location in the existing permit accurate?  on, please give an accurate description:  d the discharge route(s) in the existing permit correct?  permit application, provide an accurate description of the targe route to the nearest classified segment as defined in 30 as s/are located: Dawson  discharge to a city, county, or state highway right-of-way, or

**E.** Owner of effluent disposal site:

	If <b>yes</b> , indicate by a check mark if:
	$\square$ Authorization granted $\square$ Authorization pending
	For <b>new and amendment</b> applications, provide copies of letters that show proof of contact and the approval letter upon receipt.
	Attachment: N/A
D.	For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: $\underline{\text{N/A}}$
Se	ection 11. TLAP Disposal Information (Instructions Page 32)
A.	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?
	□ Yes □ No
	If <b>no, or a new or amendment permit application</b> , provide an accurate description of the disposal site location:
	N/A
B.	,
	County in which the disposal site is located: Click to enter text.
D.	For <b>TLAPs</b> , describe the routing of effluent from the treatment facility to the disposal site:
E.	For <b>TLAPs</b> , please identify the nearest watercourse to the disposal site to which rainfall
	runoff might flow if not contained: Click to enter text.
Se	ection 12. Miscellaneous Information (Instructions Page 32)
	Is the facility located on or does the treated effluent cross American Indian Land?
7 1	☐ Yes ☑ No
В.	If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?
	□ Yes □ No ⊠ Not Applicable
	If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.
	N/A

C.	Did any person service regardi		nerly employed by the TCEQ represent your co is application?	ompany and get paid for
	□ Yes		No	
			on formerly employed by the TCEQ who repre regarding the application: Click to enter text.	
D.	Do you owe an	y fees	to the TCEQ?	
	□ Yes		No	
	If <b>yes</b> , provide	the fo	ollowing information:	
	Account nu	ımber:	Click to enter text.	
	Amount pa	st due	c: Click to enter text.	
E.	Do you owe an	ıy pena	alties to the TCEQ?	
	□ Yes	$\boxtimes$	No	
	If <b>yes</b> , please p	orovid	e the following information:	
	Enforcemen	nt orde	er number: Click to enter text.	
	Amount pa	st due	e: Click to enter text.	
Se	ection 13. A	ttach	nments (Instructions Page 33)	
			nments (Instructions Page 33)  ents are included with the Administrative Rep	oort. Check all that apply:
	dicate which att Lease agreem	achme		he treatment facility is
Inc	dicate which att Lease agreem located or th	achme ent or e efflu	ents are included with the Administrative Rep	he treatment facility is cant or co-applicant.
Inc	dicate which att  Lease agreem located or th  Original full-	ent or e efflu size US nt's pr ent fac point nted di sewage d dispo d futur adius	ents are included with the Administrative Repeted deed recorded easement, if the land where the lent disposal site are not owned by the applications of the secondary of discharge for each discharge point (TPDES ischarge route for each discharge point (TPDES e sludge disposal site (if applicable)	ne treatment facility is cant or co-applicant. rmation:
Inc	dicate which att  Lease agreem located or th  Original full-	ent or e efflusize US nt's prent factorist disposite dis	ents are included with the Administrative Repeted deed recorded easement, if the land where the lent disposal site are not owned by the applications of the summary of discharge for each discharge point (TPDES ischarge route for each discharge point (TPDES is sludge disposal site (if applicable) osal site boundaries (TLAP only)  Seconstruction (if applicable) information	ne treatment facility is rant or co-applicant. rmation: S only) ES only)

### Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0010107001

Applicant: City of Lamesa

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): <u>Jo</u>	<u>sh Stevens</u>	
Signatory title: <u>Lamesa</u>		
Signature:	Date	٠ <u>٠</u>
(Use blue ink)		
Subscribed and Sworn to before me b	y the said	
on thisda		
My commission expires on the	day of	, 20
Notary Public		[SEAL]
County, Texas		

# DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

N/A - Renewal

The following information is required for new and amendment applications.

A.

B.

C.

D.

E.

# Section 1. Affected Landowner Information (Instructions Page 36)

Indicate by a check mark that the landowners map of following information, as applicable:	or drawing, with scale, includes the
☐ The applicant's property boundaries	
☐ The facility site boundaries within the applicant	s's property boundaries
☐ The distance the buffer zone falls into adjacent of the landowners located within the buffer zone	
The property boundaries of all landowners surrest the application is a major amendment for a light property boundaries of all landowners adjacent	nite mine, the map must include the
☐ The point(s) of discharge and highlighted discharge downstream	arge route(s) clearly shown for one mile
The property boundaries of the landowners location for one full stream mile downstream of the point	
The property boundaries of the landowners alor radius from the point of discharge if the point or affected by tides	
☐ The boundaries of the effluent disposal site (for drainfield site) and all evaporation/holding por	• , ,
☐ The property boundaries of all landowners surr	ounding the effluent disposal site
The boundaries of the sludge land application s for beneficial use) and the property boundaries applicant's property boundaries where the sew	of landowners surrounding the
The property boundaries of landowners within applicant's property boundaries where the sew sludge surface disposal site or sludge monofill.	age sludge disposal site (for example,
☐ Indicate by a check mark that a separate list wit addresses cross-referenced to the landowner's map	· ·
Indicate by a check mark in which format the landow	wners list is submitted:
$\square$ USB Drive $\square$ Four sets of labels	
Provide the source of the landowners' names and ma	ailing addresses: Click to enter text.
As required by <i>Texas Water Code § 5.115</i> , is any pethis application?	rmanent school fund land affected by
□ Yes □ No	

	-	<b>res</b> , provide the location and foreseeable impacts and effects this application has on the d(s):
	Cli	ick to enter text.
Se	ctio	on 2. Original Photographs (Instructions Page 38)
Pro	ovide	e original ground level photographs. Indicate with checkmarks that the following nation is provided.
		At least one original photograph of the new or expanded treatment unit location
		At least two photographs of the existing/proposed point of discharge and as much area downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is to an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.
		At least one photograph of the existing/proposed effluent disposal site
		A plot plan or map showing the location and direction of each photograph
Se	ctio	on 3. Buffer Zone Map (Instructions Page 38)
A.	info	If the zone map. Provide a buffer zone map on $8.5 \times 11$ -inch paper with all of the following ormation. The applicant's property line and the buffer zone line may be distinguished by $1.0 \times 10^{-5}$ mg dashes or symbols and appropriate labels.
		<ul> <li>The applicant's property boundary;</li> <li>The required buffer zone; and</li> <li>Each treatment unit; and</li> <li>The distance from each treatment unit to the property boundaries.</li> </ul>
В.		ffer zone compliance method. Indicate how the buffer zone requirements will be met. eck all that apply.
		<ul> <li>□ Ownership</li> <li>□ Restrictive easement</li> <li>□ Nuisance odor control</li> <li>□ Variance</li> </ul>
C.	uns	suitable site characteristics. Does the facility comply with the requirements regarding suitable site characteristic found in 30 TAC § 309.13(a) through (d)?  Yes  No

# DOMESTIC WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: Appendix D: SPIF Form

# WATER QUALITY PERMIT

#### PAYMENT SUBMITTAL FORM

Use this form to submit the Application Fee, if the mailing the payment.

- Complete items 1 through 5 below.
- Staple the check or money order in the space provided at the bottom of this document.
- Do Not mail this form with the application form.
- Do not mail this form to the same address as the application.
- Do not submit a copy of the application with this form as it could cause duplicate permit entries.

#### Mail this form and the check or money order to:

BY REGULAR U.S. MAIL

BY OVERNIGHT/EXPRESS MAIL

Texas Commission on Environmental Quality Texas Commission on Environmental Quality

Financial Administration Division Financial Administration Division

Cashier's Office, MC-214
P.O. Box 13088
Cashier's Office, MC-214
12100 Park 35 Circle

Austin, Texas 78711-3088 Austin, Texas 78753

Fee Code: WQP Waste Permit No: WQ0010107001

1. Check or Money Order Number: Click to enter text.

2. Check or Money Order Amount: Click to enter text.

3. Date of Check or Money Order: Click to enter text.

4. Name on Check or Money Order: Click to enter text.

5. APPLICATION INFORMATION

Name of Project or Site: City of Lamesa Wastewater Treatment Plant

Physical Address of Project or Site: <u>The treatment plant is located 1.3 miles southeast of the intersection of State Hwy 137 and Sulphur Springs Draw, southeast of Lamesa in Dawson County.</u>

If the check is for more than one application, attach a list which includes the name of each Project or Site (RE) and Physical Address, exactly as provided on the application.

#### Staple Check or Money Order in This Space

#### **ATTACHMENT 1**

#### INDIVIDUAL INFORMATION

### Section 1. Individual Information (Instructions Page 41)

Complete this attachment if the facility applicant or co-applicant is an individual. Make additional copies of this attachment if both are individuals.

Prefix (Mr., Ms., Miss): Click to enter text.

Full legal name (Last Name, First Name, Middle Initial): Click to enter text.

Driver's License or State Identification Number: Click to enter text.

Date of Birth: Click to enter text.

Mailing Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text. Fax Number: Click to enter text.

E-mail Address: Click to enter text.

CN: Click to enter text.

#### For Commission Use Only:

**Customer Number:** 

**Regulated Entity Number:** 

Permit Number:

# DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

application until the items below have been addressed.				
Core Data Form (TCEQ Form No. 10400) (Required for all application types. Must be completed in its entirety Note: Form may be signed by applicant representative.)	and s	igned.		Yes
Correct and Current Industrial Wastewater Permit Application Forn (TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018 or lat			$\boxtimes$	Yes
Water Quality Permit Payment Submittal Form (Page 19) (Original payment sent to TCEQ Revenue Section. See instructions fo	r mai	iling ad	⊠ dress	Yes
7.5 Minute USGS Quadrangle Topographic Map Attached (Full-size map if seeking "New" permit. 8½ x 11 acceptable for Renewals and Amendments)				Yes
Current/Non-Expired, Executed Lease Agreement or Easement	$\boxtimes$	N/A		Yes
Landowners Map (See instructions for landowner requirements)	$\boxtimes$	N/A		Yes
<ul> <li>Things to Know:</li> <li>All the items shown on the map must be labeled.</li> <li>The applicant's complete property boundaries must be deboundaries of contiguous property owned by the applicant.</li> <li>The applicant cannot be its own adjacent landowner. You landowners immediately adjacent to their property, regard from the actual facility.</li> <li>If the applicant's property is adjacent to a road, creek, or on the opposite side must be identified. Although the propaplicant's property boundary, they are considered poter of the adjacent road is a divided highway as identified on map, the applicant does not have to identify the landown the highway.</li> </ul>	nt. mus dless strea perti itially the U	t identi s of how um, the les are i affecto JSGS to	fy the lande land and land and land and land pogra	e they are owners djacent to idowners. aphic
Landowners Cross Reference List (See instructions for landowner requirements)		N/A		Yes
Landowners Labels or USB Drive attached (See instructions for landowner requirements)	$\boxtimes$	N/A		Yes
Original signature per 30 TAC § 305.44 - Blue Ink Preferred			$\boxtimes$	Yes

a copy of signature authority/delegation letter must be attached)

Plain Language Summary

(If signature page is not signed by an elected official or principle executive officer,

Yes

# PARTIE ON THE PROPERTY OF THE

#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

## Section 1. Permitted or Proposed Flows (Instructions Page 43)

#### A. Existing/Interim I Phase

Design Flow (MGD): Click to enter text.

2-Hr Peak Flow (MGD): Click to enter text.

Estimated construction start date: Click to enter text.

Estimated waste disposal start date: Click to enter text.

#### **B.** Interim II Phase

Design Flow (MGD): Click to enter text.

2-Hr Peak Flow (MGD): Click to enter text.

Estimated construction start date: Click to enter text.

Estimated waste disposal start date: Click to enter text.

#### C. Final Phase

Design Flow (MGD): 2.0

2-Hr Peak Flow (MGD): 5.5

Estimated construction start date: Click to enter text.

Estimated waste disposal start date: Click to enter text.

#### D. Current Operating Phase

Provide the startup date of the facility: 01/01/2009

## Section 2. Treatment Process (Instructions Page 43)

#### A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. **If more than one phase exists or is proposed, a description of** *each phase* **must be provided**.

The City of Lamesa Wastewater Treatment Facility is currently operating in its final phase and is an extended aeration WWTP. The plant consists of headworks with fine screening, vortex grit removal, an extended aeration basin, final clarification, UV disinfection and a belt filter for solids disposal.

#### **B.** Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

#### **Table 1.0(1) - Treatment Units**

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Screen(3mm)	1	16' x 3'
Vortex Grit Removal	1	10' x 12' Tall
Carrousel Aeration Basin (2MG)	1	180' x 115' x 16'
Final Clarifiers	2	60' x 14'
UV Disinfection	1	2' Channel, 32' Long

#### C. Process Flow Diagram

Provide flow diagrams for the existing facilities and **each** proposed phase of construction.

Attachment: Appendix E: Flow Diagram

# Section 3. Site Information and Drawing (Instructions Page 44)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

• Latitude: <u>32.713573</u>

• Longitude: <u>-101.943213</u>

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

• Latitude: <u>N/A</u>

• Longitude: N/A

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment: Appendix F: Site Map

Provide the name <b>and</b> a des	cription of the area	served by the treatmen	t facility.
City of Lamesa			
Collection System Informati			
each <b>uniquely owned</b> collection systems.			
examples.			•
<b>Collection System Informatio</b>	n		
<b>Collection System Name</b>	Owner Name	Owner Type	Population Served
Lamesa Collection System	City of Lamesa	Publicly Owned	8,500
Section 4. Unbuilt P	Phases (Instruct	ions Page 45)	
Is the application for a rene	wal of a permit that	contains an unbuilt ph	ase or phases?
□ Yes ⊠ No			
If yes, does the existing per years of being authorized b	_	that has not been cons	structed <b>within five</b>
□ Yes □ No			
If yes, provide a detailed di	scussion regarding t	the continued need for	the unbuilt phase.
Failure to provide sufficier recommending denial of the	,		e Director
N/A	le unbunt phase of	рназез.	
N/A			
	-		
Section 5. Closure I	Plans (Instruction	ons Page 45)	
Have any treatment units be out of service in the next five		vice permanently, or wi	ll any units be taken
□ Yes ⊠ No			
If yes, was a closure plan su	abmitted to the TCE	Q?	
□ Yes □ No			
If yes, provide a brief descr	iption of the closure	e and the date of plan a	pproval.

NI	//A
11	T/A
Se	ection 6. Permit Specific Requirements (Instructions Page 45)
	r applicants with an existing permit, check the Other Requirements or Special ovisions of the permit.
A.	Summary transmittal
	Have plans and specifications been approved for the existing facilities and each proposed phase?
	⊠ Yes □ No
	If yes, provide the date(s) of approval for each phase: <u>July 2006</u>
	Provide information, including dates, on any actions taken to meet a <i>requirement or provision</i> pertaining to the submission of a summary transmittal letter. <b>Provide a copy of an approval letter from the TCEQ, if applicable</b> .
	N/A
В.	Buffer zones
	Have the buffer zone requirements been met?
	⊠ Yes □ No
	Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.
	N/A

#### C. Other actions required by the current permit

Does the *Other Requirements* or *Special Provisions* section in the existing permit require submission of any other information or other required actions? Examples include Notification of Completion, progress reports, soil monitoring data, etc.

		□ Yes ⊠ No
		yes, provide information below on the status of any actions taken to meet the nditions of an <i>Other Requirement</i> or <i>Special Provision</i> .
	N	/A
D.	Gr	it and grease treatment
	1.	Acceptance of grit and grease waste
		Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?
		□ Yes ⊠ No
		If No, stop here and continue with Subsection E. Stormwater Management.
	2.	Grit and grease processing
		Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.
		Click to enter text.
	3.	Grit disposal
		Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?
		□ Yes □ No
		<b>If No</b> , contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.
		Describe the method of grit disposal.

		Click to enter text.
	4.	Grease and decanted liquid disposal
		Note: A registration or permit is required for grease disposal. Grease shall not be
		combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.
		Describe how the decant and grease are treated and disposed of after grit separation.
		Click to enter text.
E.	Sto	ormwater management
	1.	Applicability
		Does the facility have a design flow of 1.0 MGD or greater in any phase?
		⊠ Yes □ No
		Does the facility have an approved pretreatment program, under 40 CFR Part 403?
		□ Yes ⊠ No
		If no to both of the above, then skip to Subsection F, Other Wastes Received.
	2.	MSGP coverage
		Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?
		□ Yes ⊠ No
		<b>If yes</b> , please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:
		TXR05 Click to enter text. or TXRNE Click to enter text.
		If no, do you intend to seek coverage under TXR050000?
		⊠ Yes □ No
	<i>3.</i>	Conditional exclusion
		Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?
		□ Yes ⊠ No
		If yes, please explain below then proceed to Subsection F, Other Wastes Received:

	N/A
<b>1.</b>	Existing coverage in individual permit
	Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?
	□ Yes ⊠ No
	<b>If yes</b> , provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.
	N/A
5.	Zero stormwater discharge
	Do you intend to have no discharge of stormwater via use of evaporation or other means?
	□ Yes ⊠ No
	If yes, explain below then skip to Subsection F. Other Wastes Received.
	N/A
	Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.
<b>5.</b>	Request for coverage in individual permit
	Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?
	□ Yes ⊠ No

**If yes**, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you

		intend to divert stormwater to the treatment plant headworks and indirectly discharge it to water in the state.
		N/A
		Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.
F.	Di	scharges to the Lake Houston Watershed
	Do	es the facility discharge in the Lake Houston watershed?
		□ Yes ⊠ No
	If y <u>N/</u>	ves, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions. $\underline{\mathbf{A}}$
G.	Ot	her wastes received including sludge from other WWTPs and septic waste
	1.	Acceptance of sludge from other WWTPs
		Does or will the facility accept sludge from other treatment plants at the facility site?
		□ Yes ⊠ No
		If yes, attach sewage sludge solids management plan. See Example 5 of instructions.
		In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an
		estimate of the $BOD_5$ concentration of the sludge, and the design $BOD_5$ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
		N/A
		Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	2.	Acceptance of septic waste
		Is the facility accepting or will it accept septic waste?
		□ Yes ⊠ No
		If yes, does the facility have a Type V processing unit?
		□ Yes □ No
		If yes, does the unit have a Municipal Solid Waste permit?
		□ Yes □ No

millions of gallons), an estimate of the BOD <sub>5</sub> concentration of the septic waste, and the design BOD <sub>5</sub> concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.							
N/A							
Note: Permits that accept sludge from other wastewater treatment placed required to have influent flow and organic loading monitoring.	ants may be						
3. Acceptance of other wastes (not including septic, grease, grit, or Roas discharged by IUs listed in Worksheet 6)	CRA, CERCLA or						
Is or will the facility accept wastes that are not domestic in nature ex categories listed above?	cluding the						
□ Yes ⊠ No							
If yes, provide the date that the plant started accepting the waste, and much waste is accepted on a monthly basis (gallons or millions of galdescription of the entities generating the waste, and any distinguishing other physical characteristic of the waste. Also note if this information changed since the last permit action.	llons), a ng chemical or						
N/A							
Section 7. Pollutant Analysis of Treated Effluent (Instru50)	ctions Page						
Is the facility in operation?							
If no, this section is not applicable. Proceed to Section 8.							

If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or

If yes, provide effluent analysis data for the listed pollutants. *Wastewater treatment facilities* complete Table 1.0(2). *Water treatment facilities* discharging filter backwash water, complete Table 1.0(3). Provide copies of the laboratory results sheets. **These tables are not applicable for a minor amendment without renewal.** See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD <sub>5</sub> , mg/l	2.14	2.14	1	GRAB	7/18/23 @ 9:30
Total Suspended Solids, mg/l	8	8	1	GRAB	7/18/23 @ 9:30
Ammonia Nitrogen, mg/l	.0345	.0345	1	GRAB	7/18/23 @ 9:30
Nitrate Nitrogen, mg/l	.0293	.0293	1	GRAB	7/18/23 @ 9:30
Total Kjeldahl Nitrogen, mg/l	.632	.632	1	GRAB	7/18/23 @ 9:30
Sulfate, mg/l	197	197	1	GRAB	7/18/23 @ 9:30
Chloride, mg/l	391	391	1	GRAB	7/18/23 @ 9:30
Total Phosphorus, mg/l	2.97	2.97	1	GRAB	7/18/23 @ 9:30
pH, standard units	7.8	7.8	1	GRAB	7/18/23 @ 9:30
Dissolved Oxygen*, mg/l	9.65	9.65	1	GRAB	7/18/23 @ 9:30
Chlorine Residual, mg/l	.05	.05	1	GRAB	7/18/23 @ 9:30
E.coli (CFU/100ml) freshwater	1	1	1	GRAB	7/18/23 @ 9:30
Entercocci (CFU/100ml) saltwater	N/A	N/A	N/A	N/A	N/A
Total Dissolved Solids, mg/l	1170	1170	1	GRAB	7/18/23 @ 9:30
Electrical Conductivity, µmohs/cm, †	N/A	N/A	N/A	N/A	N/A
Oil & Grease, mg/l	1.57	1.57	1	GRAB	7/18/23 @ 9:30
Alkalinity (CaCO <sub>3</sub> )*, mg/l	1360	1360	1	GRAB	7/18/23 @ 9:30

<sup>\*</sup>TPDES permits only †TLAP permits only

Table 1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l	N/A				
Total Dissolved Solids, mg/l					
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO <sub>3</sub> ), mg/l					

# Section 8. Facility Operator (Instructions Page 50)

Facility Operator Name: Dionicio Garza Jr.; Joe Hines; Manuel Vasquez

Facility Operator's License Classification and Level: <u>B;B;C</u>

Facility Operator's License Number: <u>WW0071134;WW0035602;WW0071148</u>

# Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 51)

# A. WWTP's Biosolids Management Facility Type Check all that apply. See instructions for guidance Design flow>= 1 MGD Serves >= 10,000 people Class I Sludge Management Facility (per 40 CFR § 503.9) Biosolids generator Biosolids end user – land application (onsite) Biosolids end user - surface disposal (onsite) Biosolids end user - incinerator (onsite) B. WWTP's Biosolids Treatment Process Check all that apply. See instructions for guidance. $\boxtimes$ Aerobic Digestion Air Drying (or sludge drying beds) **Lower Temperature Composting** Lime Stabilization **Higher Temperature Composting Heat Drying** Thermophilic Aerobic Digestion **Beta Ray Irradiation** Gamma Ray Irradiation **Pasteurization** Preliminary Operation (e.g. grinding, de-gritting, blending) $\boxtimes$ Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter) Sludge Lagoon Temporary Storage (< 2 years) Long Term Storage (>= 2 years) Methane or Biogas Recovery Other Treatment Process: Click to enter text.

# C. Biosolids Management

Provide information on the *intended* biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the permit will authorize

all biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

### **Biosolids Management**

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Disposal in Landfill	On-Site Owner or Operator	Bulk		Class B: PSRP Equivalency	Option 5: Aerobic process for 14 days at >40C

If "Other" is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP):  $\underline{N/A}$ 

# D. Disposal site

Disposal site name: <u>City of Lamesa MSW Landfill</u>
TCEQ permit or registration number: <u>RN105147581</u>
County where disposal site is located: Dawson

# E. Transportation method

Method of transportation (truck, train, pipe, other): Truck

Name of the hauler: City of Lamesa

Hauler registration number: N/A – Doesn't leave City owned land

Sludge is transported as a:

Liquid  $\square$  semi-liquid  $\square$  semi-solid  $\square$  solid  $\boxtimes$ 

# Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 53)

### A. Beneficial use authorization

Does the existing	ng permit include authorization for land application of sewage sludge for
beneficial use?	
□ Yes ⊠	No

**If yes**, are you requesting to continue this authorization to land apply sewage sludge for beneficial use?

□ Yes □ No

If yes, is the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451) attached to this permit application (see the instructions for details)?

□ Yes □ No

# B. Sludge processing authorization

	xisting permit include authorization f disposal options?	for any	y of the	follow	ring sludge processing,
Sludge	Composting		Yes		No
Marketi	ng and Distribution of sludge		Yes	$\boxtimes$	No
Sludge	Surface Disposal or Sludge Monofill		Yes	$\boxtimes$	No
Tempo	ary storage in sludge lagoons		Yes		No
authorizat	ny of the above sludge options and the completed <b>Domestic Waste Report (TCEQ Form No. 10056)</b> attac	ewate	r Permi	t Appl	ication: Sewage Sludge
□ Yes	s □ No				
Section 11.	Sewage Sludge Lagoons (In	stru	ctions	Page	2 53)
Does this facil	ity include sewage sludge lagoons?				
□ Yes [	⊠ No				
If yes, comple	te the remainder of this section. If no	, proc	eed to S	Section	12.
A. Location in	nformation				
	ing maps are required to be submitte e Attachment Number.	d as p	art of t	he app	lication. For each map,
• Orig	inal General Highway (County) Map:				
Atta	chment: Click to enter text.				
• USD	A Natural Resources Conservation Se	rvice S	Soil Ma <sub>l</sub>	<b>)</b> :	
Atta	chment: Click to enter text.				
• Fede	eral Emergency Management Map:				
Atta	chment: Click to enter text.				
• Site	map:				
Atta	chment: Click to enter text.				
Discuss in apply.	a description if any of the following $\epsilon$	exist w	ithin th	ne lago	on area. Check all that
□ Ov	erlap a designated 100-year frequency	y floo	d plain		
□ Soi	ls with flooding classification				
□ Ov	erlap an unstable area				
□ We	tlands				
□ Loc	cated less than 60 meters from a faul	t			
□ No	ne of the above				
Attachı	nent: Click to enter text.				
If a portion	of the lagoon(s) is located within the	2 100-	year fre	quency	y flood plain, provide

the protective measures to be utilized including type and size of protective structures:

Click to enter text.
Chek to enter text.
Temporary storage information
Provide the results for the pollutant screening of sludge lagoons. These results are in
addition to pollutant results in Section 7 of Technical Report 1.0.
Nitrate Nitrogen, mg/kg: Click to enter text.
Total Kjeldahl Nitrogen, mg/kg: Click to enter text.
Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: Click to enter text.
Phosphorus, mg/kg: Click to enter text.
Potassium, mg/kg: Click to enter text.
pH, standard units: <u>Click to enter text.</u>
Ammonia Nitrogen mg/kg: Click to enter text.
Arsenic: Click to enter text.
Cadmium: Click to enter text.
Chromium: Click to enter text.
Copper: Click to enter text.
Lead: Click to enter text.
Mercury: Click to enter text.
Molybdenum: Click to enter text.
Nickel: Click to enter text.
Selenium: Click to enter text.
Zinc: Click to enter text.
Total PCBs: Click to enter text.
Provide the following information:
Volume and frequency of sludge to the lagoon(s): Click to enter text.
Total dry tons stored in the lagoons(s) per 365-day period: Click to enter text.
Total dry tons stored in the lagoons(s) over the life of the unit: <u>Click to enter text.</u>
Liner information
Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of $1x10^{-7}$ cm/sec?
□ Yes □ No

B.

C.

	If yes	, describe the liner below. Please note that a liner is required.
	Click	to enter text.
D.	Site d	evelopment plan
	Provid	le a detailed description of the methods used to deposit sludge in the lagoon(s):
	Click	to enter text.
	Attacl	n the following documents to the application.
	•	Plan view and cross-section of the sludge lagoon(s)
		Attachment: Click to enter text.
	•	Copy of the closure plan
		Attachment: Click to enter text.
	•	Copy of deed recordation for the site
		Attachment: Click to enter text.
	•	Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons
		Attachment: Click to enter text.
	•	Description of the method of controlling infiltration of groundwater and surface water from entering the site
		Attachment: Click to enter text.
	•	Procedures to prevent the occurrence of nuisance conditions
		Attachment: Click to enter text.
E.	Groui	ndwater monitoring
	groun	undwater monitoring currently conducted at this site, or are any wells available for dwater monitoring, or are groundwater monitoring data otherwise available for the e lagoon(s)?
		Yes □ No
	types	undwater monitoring data are available, provide a copy. Provide a profile of soil encountered down to the groundwater table and the depth to the shallowest dwater as a separate attachment.
	At	tachment: Click to enter text.

# Section 12. Authorizations/Compliance/Enforcement (Instructions

4.	Additional authorizations	
	Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?	
	⊠ Yes □ No	
	If yes, provide the TCEQ authorization number and description of the authorization:	
	10107001. Authorization for reclaimed water; type II reclaimed water is authorized to be sed in accordance with 30TAC 210.32	
3.	Permittee enforcement status	
	Is the permittee currently under enforcement for this facility?	
	□ Yes ⊠ No	
	Is the permittee required to meet an implementation schedule for compliance or enforcement?	
	□ Yes ⊠ No	
	<b>If yes</b> to either question, provide a brief summary of the enforcement, the implement schedule, and the current status:	tation
N	T/A	
Se	ection 13. RCRA/CERCLA Wastes (Instructions Page 55)	

# A. RCRA hazardous wastes

Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

Yes	$\boxtimes$	No

# B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

□ Yes ⊠ No

# C. Details about wastes received

**If yes** to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: Click to enter text.

# Section 14. Laboratory Accreditation (Instructions Page 56)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25*, *Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
  - o periodically inspected by the TCEQ; or
  - o located in another state and is accredited or inspected by that state; or
  - o performing work for another company with a unit located in the same site; or
  - o performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

### **CERTIFICATION:**

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Title: <u>Mayor</u>	
Signature:	
Date:	

Printed Name: Josh Stevens

# DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.1 N/A - Renewal

The following information is required for new and amendment major applications.

# Section 1. Justification for Permit (Instructions Page 57)

<b>A.</b> .	Justificatio	on of p	ermit n	eed
-------------	--------------	---------	---------	-----

B.

Provide a detailed discussion regarding the need for any phase(s) not currently permitted
Failure to provide sufficient justification may result in the Executive Director
recommending denial of the proposed phase(s) or permit.

C	Click to enter text.
L Re	gionalization of facilities
	r additional guidance, please review <u>TCEQ's Regionalization Policy for Wastewater</u> eatment¹.
	ovide the following information concerning the potential for regionalization of domestic stewater treatment facilities:
1.	Municipally incorporated areas
	If the applicant is a city, then Item 1 is not applicable. Proceed to Item 2 Utility CCN areas.
	Is any portion of the proposed service area located in an incorporated city?
	□ Yes □ No □ Not Applicable
	If yes, within the city limits of: <u>Click to enter text.</u>
	If yes, attach correspondence from the city.
	Attachment: Click to enter text.
	If consent to provide service is available from the city, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the city versus the cost of the proposed facility or expansion attached.
	Attachment: Click to enter text.
2.	Utility CCN areas
	Is any portion of the proposed service area located inside another utility's CCN area?
	□ Yes □ No

<sup>&</sup>lt;sup>1</sup> https://www.tceq.texas.gov/permitting/wastewater/tceq-regionalization-for-wastewater

If yes, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the CCN facilities versus the cost of the proposed facility or expansion.
Attachment: Click to enter text.
3. Nearby WWTPs or collection systems
Are there any domestic permitted wastewater treatment facilities or collection systems located within a three-mile radius of the proposed facility?
□ Yes □ No
If yes, attach a list of these facilities and collection systems that includes each permittee's name and permit number, and an area map showing the location of these facilities and collection systems.
Attachment: Click to enter text.
If yes, attach proof of mailing a request for service to each facility and collection system, the letters requesting service, and correspondence from each facility and collection system.
Attachment: Click to enter text.
If the facility or collection system agrees to provide service, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the facility or collection system versus the cost of the proposed facility or expansion.
Attachment: Click to enter text.
Section 2. Proposed Organic Loading (Instructions Page 59)
Is this facility in operation?
□ Yes □ No
If no, proceed to Item B, Proposed Organic Loading.
If yes, provide organic loading information in Item A, Current Organic Loading
A. Current organic loading
Facility Design Flow (flow being requested in application): Click to enter text.
Average Influent Organic Strength or BOD <sub>5</sub> Concentration in mg/l: Click to enter text.
Average Influent Loading (lbs/day = total average flow X average BOD <sub>5</sub> conc. X 8.34): $\underline{\text{Click}}$ to enter text.
Provide the source of the average organic strength or BOD <sub>5</sub> concentration.
Click to enter text

# B. Proposed organic loading

This table must be completed if this application is for a facility that is not in operation or if this application is to request an increased flow that will impact organic loading.

Table 1.1(1) - Design Organic Loading

Source	Total Average Flow (MGD)	Influent BOD5 Concentration (mg/l)
Municipality		
Subdivision		
Trailer park - transient		
Mobile home park		
School with cafeteria and showers		
School with cafeteria, no showers		
Recreational park, overnight use		
Recreational park, day use		
Office building or factory		
Motel		
Restaurant		
Hospital		
Nursing home		
Other		
TOTAL FLOW from all sources		
AVERAGE BOD <sub>5</sub> from all sources		

# Section 3. Proposed Effluent Quality and Disinfection (Instructions Page 59)

# A. Existing/Interim I Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.

Total Suspended Solids, mg/l: Click to enter text.

Ammonia Nitrogen, mg/l: Click to enter text.

Total Phosphorus, mg/l: Click to enter text.

Dissolved Oxygen, mg/l: Click to enter text.

Other: Click to enter text.

В.	interim ii Phase Design Efficient Quanty
	Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.
	Total Suspended Solids, mg/l: Click to enter text.
	Ammonia Nitrogen, mg/l: Click to enter text.
	Total Phosphorus, mg/l: Click to enter text.
	Dissolved Oxygen, mg/l: Click to enter text.
	Other: Click to enter text.
C.	Final Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.
	Total Suspended Solids, mg/l: Click to enter text.
	Ammonia Nitrogen, mg/l: Click to enter text.
	Total Phosphorus, mg/l: <u>Click to enter text.</u>
	Dissolved Oxygen, mg/l: Click to enter text.
	Other: Click to enter text.
D.	Disinfection Method
	Identify the proposed method of disinfection.
	Chlorine: Click to enter text. mg/l after Click to enter text. minutes detention time at peak flow
	Dechlorination process: <u>Click to enter text.</u>
	□ Ultraviolet Light: <u>Click to enter text.</u> seconds contact time at peak flow
	□ Other: Click to enter text.
Ca	etion 4. Decima Calculations (Instruction Bores 50)
	ection 4. Design Calculations (Instructions Page 59)
	tach design calculations and plant features for each proposed phase. Example 4 of the structions includes sample design calculations and plant features.
1110	Attachment: Click to enter text.
	Actuellisent: Check to their texts
Se	ection 5. Facility Site (Instructions Page 60)
Α.	100-year floodplain
	Will the proposed facilities be located <u>above</u> the 100-year frequency flood level?
	□ Yes □ No
	If no, describe measures used to protect the facility during a flood event. Include a site map showing the location of the treatment plant within the 100-year frequency flood level. If applicable, provide the size and types of protective structures.
	Click to enter text.

	Provide the source(s) used to determine 100-year frequency flood plain.
	Click to enter text.
	For a new or expansion of a facility, will a wetland or part of a wetland be filled?
	□ Yes □ No
	<b>If yes</b> , has the applicant applied for a US Corps of Engineers 404 Dredge and Fill Permit?
	□ Yes □ No
	If yes, provide the permit number: <u>Click to enter text.</u>
	<b>If no,</b> provide the approximate date you anticipate submitting your application to the Corps: Click to enter text.
B.	Wind rose
	Attach a wind rose: Click to enter text.
Se	ection 6. Permit Authorization for Sewage Sludge Disposal
	(Instructions Page 60)
A.	Beneficial use authorization
	Are you requesting to include authorization to land apply sewage sludge for beneficial use on property located adjacent to the wastewater treatment facility under the wastewater permit?
	□ Yes □ No
	If yes, attach the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451): Click to enter text.
B.	Sludge processing authorization
	Identify the sludge processing, storage or disposal options that will be conducted at the wastewater treatment facility:
	□ Sludge Composting
	☐ Marketing and Distribution of sludge
	□ Sludge Surface Disposal or Sludge Monofill
	If any of the above, sludge options are selected, attach the completed <b>Domestic</b> Wastewater Permit Application: Sewage Sludge Technical Report (TCEQ Form No. 10056): Click to enter text.
Se	ection 7. Sewage Sludge Solids Management Plan (Instructions Page 61)

Attach a solids management plan to the application.

Attachment: Click to enter text.

The sewage sludge solids management plan must contain the following information:

Treatment units and processes dimensions and capacities

- Solids generated at 100, 75, 50, and 25 percent of design flow
- Mixed liquor suspended solids operating range at design and projected actual flow
- Quantity of solids to be removed and a schedule for solids removal
- Identification and ownership of the ultimate sludge disposal site
- For facultative lagoons, design life calculations, monitoring well locations and depths, and the ultimate disposal method for the sludge from the facultative lagoon

An example of a sewage sludge solids management plan has been included as Example 5 of the instructions.

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

Section 1. Domestic Drinking Water Supply (Instructions Page 64)
Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?
□ Yes ⊠ No
If <b>no</b> , proceed it Section 2. <b>If yes</b> , provide the following:
Owner of the drinking water supply: <u>Click to enter text.</u>
Distance and direction to the intake: Click to enter text.
Attach a USGS map that identifies the location of the intake.
Attachment: Click to enter text.
Section 2. Discharge into Tidally Affected Waters (Instructions Page 64)
Does the facility discharge into tidally affected waters?
□ Yes ⊠ No
If <b>no</b> , proceed to Section 3. <b>If yes</b> , complete the remainder of this section. If no, proceed to Section 3.
A. Receiving water outfall
Width of the receiving water at the outfall, in feet: Click to enter text.
B. Oyster waters
Are there oyster waters in the vicinity of the discharge?
□ Yes □ No
If yes, provide the distance and direction from outfall(s).
Click to enter text.
C. Sea grasses
Are there any sea grasses within the vicinity of the point of discharge?
□ Yes □ No
If yes, provide the distance and direction from the outfall(s).
Click to enter text.

# Section 3. **Classified Segments (Instructions Page 64)** Is the discharge directly into (or within 300 feet of) a classified segment? Yes ⊠ No If yes, this Worksheet is complete. **If no**, complete Sections 4 and 5 of this Worksheet. Section 4. **Description of Immediate Receiving Waters (Instructions Page 65)** Name of the immediate receiving waters: Sulphur Springs Draw A. Receiving water type Identify the appropriate description of the receiving waters. $\boxtimes$ Stream Freshwater Swamp or Marsh Lake or Pond Surface area, in acres: Click to enter text. Average depth of the entire water body, in feet: Click to enter text. Average depth of water body within a 500-foot radius of discharge point, in feet: Click to enter text. Man-made Channel or Ditch Open Bay Tidal Stream, Bayou, or Marsh Other, specify: Click to enter text. **B.** Flow characteristics If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area upstream of the discharge. For new discharges, characterize the area *downstream* of the discharge (check one). Intermittent - dry for at least one week during most years Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses Perennial - normally flowing Check the method used to characterize the area upstream (or downstream for new dischargers). USGS flow records Historical observation by adjacent landowners $\boxtimes$ Personal observation Other, specify: Click to enter text.

		e names of all perennial streams that tream of the discharge point.	at joii	n the receiving water within three miles
	N/A			
D.	Downs	stream characteristics		
		receiving water characteristics charge (e.g., natural or man-made dams	_	rithin three miles downstream of the ads, reservoirs, etc.)?
		discuss how.		
	N/A			
E.	Provide	l dry weather characteristics e general observations of the water n remains dry and only flows during we		during normal dry weather conditions.
	Date a	nd time of observation: <u>07/18/2023</u>		
		e water body influenced by stormw Yes ⊠ No	ater 1	runoff during observations?
Se	ection	5. General Characteristic Page 66)	s of	the Waterbody (Instructions
A.	Upstre	am influences		
		mmediate receiving water upstream iced by any of the following? Check		ne discharge or proposed discharge site nat apply.
		Oil field activities	$\boxtimes$	Urban runoff
		Upstream discharges	$\boxtimes$	Agricultural runoff
		Septic tanks		Other(s), specify: Click to enter text.

C. Downstream perennial confluences

### **B.** Waterbody uses Observed or evidences of the following uses. Check all that apply. Livestock watering Contact recreation Irrigation withdrawal Non-contact recreation **Fishing Navigation** Domestic water supply Industrial water supply Park activities $\boxtimes$ Other(s), specify: N/A C. Waterbody aesthetics Check one of the following that best describes the aesthetics of the receiving water and the surrounding area. Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored Common Setting: not offensive; developed but uncluttered; water may be colored or turbid

Offensive: stream does not enhance aesthetics; cluttered; highly developed;

dumping areas; water discolored

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.1: STREAM PHYSICAL CHARACTERISTICS

Required for new applications, major facilities, and applications adding an outfall.

N/A - Renewal

Worksheet 2.1 is not required for discharges to intermittent streams or discharges directly to (or within 300 feet of) a classified segment.

Section 1. General Information (Instructions Page 66)
Date of study: Click to enter text. Time of study: Click to enter text.
Stream name: Click to enter text.
Location: Click to enter text.
Type of stream upstream of existing discharge or downstream of proposed discharge (check one).
□ Perennial □ Intermittent with perennial pools
Section 2. Data Collection (Instructions Page 66)
Number of stream bends that are well defined: Click to enter text.
Number of stream bends that are moderately defined: Click to enter text.
Number of stream bends that are poorly defined: <u>Click to enter text.</u>
Number of riffles: Click to enter text.
Evidence of flow fluctuations (check one):
□ Minor □ moderate □ severe
Indicate the observed stream uses and if there is evidence of flow fluctuations or channel obstruction/modification.
Click to enter text.

### Stream transects

In the table below, provide the following information for each transect downstream of the existing or proposed discharges. Use a separate row for each transect.

Table 2.1(1) - Stream Transect Records

Stream type at transect	Transect location	Water surface	Stream depths (ft) at 4 to 10 points along each		
Select riffle, run, glide, or pool. See Instructions, Definitions section.		width (ft)	transect from the channel bed to the water surface. Separate the measurements with commas.		
Choose an item.			Will Committee		
Choose an item.					
Choose an item.					
Choose an item.					
Choose an item.					
Choose an item.					
Choose an item.					
Choose an item.					
Choose an item.					
Choose an item.					

# Section 3. Summarize Measurements (Instructions Page 66)

Streambed slope of entire reach, from USGS map in feet/feet: Click to enter text.

Approximate drainage area above the most downstream transect (from USGS map or county highway map, in square miles): <u>Click to enter text.</u>

Length of stream evaluated, in feet: Click to enter text.

Number of lateral transects made: <u>Click to enter text.</u>

Average stream width, in feet: Click to enter text.

Average stream depth, in feet: <u>Click to enter text.</u>

Average stream velocity, in feet/second: Click to enter text.

Instantaneous stream flow, in cubic feet/second: Click to enter text.

Indicate flow measurement method (type of meter, floating chip timed over a fixed distance, etc.): Click to enter text.

Size of pools (large, small, moderate, none): Click to enter text.

Maximum pool depth, in feet: Click to enter text.

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.0: LAND DISPOSAL OF EFFLUENT

The following is required for renewal, new, and amendment permit applications.

N/A - TPDES

Section 1.	Type of Disposal System (Instructions Page 68)	
T-1	sthood of land diamonals	

Identif	y the method of land disposal:		
	Surface application		Subsurface application
	Irrigation		Subsurface soils absorption
	Drip irrigation system		Subsurface area drip dispersal system
	Evaporation		Evapotranspiration beds
	Other (describe in detail): Click	to er	nter text.
	All applicants without authoriza complete and submit Worksheet		or proposing new/amended subsurface disposal

# Section 2. Land Application Site(s) (Instructions Page 68)

For existing authorizations, provide Registration Number: Click to enter text.

In table 3.0(1), provide the requested information for the land application sites. Include the agricultural or cover crop type (wheat, cotton, alfalfa, bermuda grass, native grasses, etc.), land use (golf course, hayland, pastureland, park, row crop, etc.), irrigation area, amount of effluent applied, and whether or not the public has access to the area. Specify the amount of land area and the amount of effluent that will be allotted to each agricultural or cover crop, if more than one crop will be used.

### Table 3.0(1) - Land Application Site Crops

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N

# Section 3. Storage and Evaporation Lagoons/Ponds (Instructions Page 68)

# Table 3.0(2) – Storage and Evaporation Ponds

Pond Number	Surface Area (acres)	Storage Volume (acre-feet)	Dimensions	Liner Type

Attach a copy of a liner certification that was prepared, signed, and sealed by a Texas licensed professional engineer for each pond.
Attachment: Click to enter text.
Section 4. Flood and Runoff Protection (Instructions Page 68)
Is the land application site <u>within</u> the 100-year frequency flood level?
□ Yes □ No
If yes, describe how the site will be protected from inundation.
Click to enter text.
Provide the source used to determine the 100-year frequency flood level:
Click to enter text.
Provide a description of tailwater controls and rainfall run-on controls used for the land
application site.
Click to enter text.

# Section 5. Annual Cropping Plan (Instructions Page 68)

Attach an Annual Cropping Plan which includes a discussion of each of the following items. If not applicable, provide a detailed explanation indicating why. **Attachment**: Click to enter text.

- Soils map with crops
- Cool and warm season plant species
- Crop yield goals
- Crop growing season
- Crop nutrient requirements
- Additional fertilizer requirements
- Minimum/maximum harvest height (for grass crops)
- Supplemental watering requirements
- Crop salt tolerances
- Harvesting method/number of harvests
- Justification for not removing existing vegetation to be irrigated

# Section 6. Well and Map Information (Instructions Page 69)

Attach a USGS map with the following information shown and labeled. If not applicable, provide a detailed explanation indicating why. **Attachment**: <u>Click to enter text.</u>

- The boundaries of the land application site(s)
- Waste disposal or treatment facility site(s)
- On-site buildings
- Buffer zones
- Effluent storage and tailwater control facilities
- All water wells within 1-mile radius of the disposal site or property boundaries
- All springs and seeps onsite and within 500 feet of the property boundaries
- All surface waters in the state onsite and within 500 feet of the property boundaries
- All faults and sinkholes onsite and within 500 feet of the property

List and cross reference all water wells located within a half-mile radius of the disposal site or property boundaries shown on the USGS map in the following table. Attach additional pages as necessary to include all of the wells.

Table 3.0(3) - Water Well Data

Well ID	Well Use	Producing? Y/N	Open, cased, capped, or plugged?	Proposed Best Management Practice
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	

If water quality data or well log information is available please include the information in an attachment listed by Well ID.

Attachment: Click to enter text.

# Section 7. Groundwater Quality (Instructions Page 69)

Attach a Groundwater Quality Technical Report which assesses the impact of the wastewater disposal system on groundwater. This report shall include an evaluation of the water wells (including the information in the well table provided in Item 6. above), the wastewater application rate, and pond liners. Indicate by a check mark that this report is provided.

Attachment: Click to enter text.
Are groundwater monitoring wells available onsite?   Yes  No
Do you plan to install ground water monitoring wells or lysimeters around the land application site? $\Box$ Yes $\Box$ No
If yes, provide the proposed location of the monitoring wells or lysimeters on a site map.
Attachment: Click to enter text.

# Section 8. Soil Map and Soil Analyses (Instructions Page 70)

### A. Soil map

Attach a USDA Soil Survey map that shows the area to be used for effluent disposal.

Attachment: Click to enter text.

# B. Soil analyses

Attach the laboratory results sheets from the soil analyses. **Note**: for renewal applications, the current annual soil analyses required by the permit are acceptable as long as the test date is less than one year prior to the submission of the application.

**Attachment**: Click to enter text.

List all USDA designated soil series on the proposed land application site. Attach additional pages as necessary.

### Table 3.0(4) - Soil Data

Soil Series	Depth from Surface	Permeability	Available Water Capacity	Curve Number

# **Section 9.** Effluent Monitoring Data (Instructions Page 71) Is the facility in operation? Yes □ No **If no**, this section is not applicable and the worksheet is complete. If yes, provide the effluent monitoring data for the parameters regulated in the existing permit. If a parameter is not regulated in the existing permit, enter N/A. Table 3.0(5) – Effluent Monitoring Data Chlorine **Date** 30 Day Avg BOD5 TSS рН Acres Flow MGD mg/l Residual mg/l irrigated mg/l

corrective actions taken.		
Click to enter text.		

Provide a discussion of all persistent excursions above the permitted limits and any

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.1: SURFACE LAND DISPOSAL OF EFFLUENT

The following is required for new and major amendment permit applications. Renewal and minor amendment permit applications may be asked for this worksheet on a case by case basis.

N/A - Renewal

# Section 1. Surface Disposal (Instructions Page 72)

Complete the item that applies for the method of disposal being used.

# A. Irrigation

Area under irrigation, in acres: Click to enter text.

Design application frequency:

hours/day Click to enter text. And days/week Click to enter text.

Land grade (slope):

average percent (%): Click to enter text.

maximum percent (%): Click to enter text.

Design application rate in acre-feet/acre/year: Click to enter text.

Design total nitrogen loading rate, in lbs N/acre/year: Click to enter text.

Soil conductivity (mmhos/cm): Click to enter text.

Method of application: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations, method of application, irrigation efficiency, and nitrogen balance.

**Attachment:** Click to enter text.

# **B.** Evaporation ponds

Daily average effluent flow into ponds, in gallons per day: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations.

**Attachment:** Click to enter text.

### C. Evapotranspiration beds

Number of beds: Click to enter text.

Area of bed(s), in acres: <u>Click to enter text.</u>

Depth of bed(s), in feet: Click to enter text.

Void ratio of soil in the beds: Click to enter text.

Storage volume within the beds, in acre-feet: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations, and a description of the lining.

Attachment: Click to enter text.

# Area used for application, in acres: Click to enter text. Slopes for application area, percent (%): Click to enter text. Design application rate, in gpm/foot of slope width: Click to enter text. Slope length, in feet: Click to enter text. Design BOD<sub>5</sub> loading rate, in lbs BOD<sub>5</sub>/acre/day: Click to enter text. Design application frequency: hours/day: Click to enter text. And days/week: Click to enter text. Attach a separate engineering report with the method of application and design requirements according to 30 TAC Chapter 217. Attachment: Click to enter text.

# **Section 2.** Edwards Aquifer (Instructions Page 73)

-
Is the facility subject to 30 TAC Chapter 213, Edwards Aquifer Rules?
□ Yes □ No
If <b>yes</b> , is the facility located on the Edwards Aquifer Recharge Zone?
□ Yes □ No
If yes, attach a geological report addressing potential recharge features
Attachment: Click to enter text.

N/A - Renewal

# DOMESTIC WASTEWATER PERMIT APPLICATION **WORKSHEET 3.2: SURFACE LAND DISPOSAL OF EFFLUENT**

The following is required for new and major amendment permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **does not meet** the definition of a subsurface area drip dispersal system as defined in 30 TAC Chapter 222, Subsurface Area Drip Dispersal System.

Section 1. Subsurface Application (Instructions Page 74)
Identify the type of system:
□ Conventional Gravity Drainfield, Beds, or Trenches (new systems must be less than 5,000 GPD)
□ Low Pressure Dosing
☐ Other, specify: <u>Click to enter text.</u>
Application area, in acres: Click to enter text.
Area of drainfield, in square feet: Click to enter text.
Application rate, in gal/square foot/day: Click to enter text.
Depth to groundwater, in feet: Click to enter text.
Area of trench, in square feet: Click to enter text.
Dosing duration per area, in hours: <u>Click to enter text.</u>
Number of beds: Click to enter text.
Dosing amount per area, in inches/day: Click to enter text.
Infiltration rate, in inches/hour: Click to enter text.
Storage volume, in gallons: <u>Click to enter text.</u>
Area of bed(s), in square feet: Click to enter text.
Soil Classification: <u>Click to enter text.</u>
Attach a separate engineering report with the information required in $30\ TAC\ \S\ 309.20$ , excluding the requirements of $\S\ 309.20\ b(3)(A)$ and (B) design analysis which may be asked for on a case by case basis. Include a description of the schedule of dosing basin rotation.
Attachment: Click to enter text.
Section 2. Edwards Aquifer (Instructions Page 74)
Is the subsurface system over the Edwards Aquifer Recharge Zone as mapped by TCEQ?
□ Yes □ No
Is the subsurface system over the Edwards Aquifer Transition Zone as mapped by TCEQ?
□ Yes □ No
<b>If yes to either question</b> , the subsurface system may be prohibited by <i>30 TAC §213.8</i> . Please call the Municipal Permits Team, at 512-239-4671, to schedule a pre-application meeting.

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.3: SUBSURFACE AREA DRIP DISPERSAL (SADDS) LAND DISPOSAL OF EFFLUENT N/A - R

N/A - Renewal

The following **is required** for **new and major amendment** subsurface area drip dispersal system permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **meets** the definition of a subsurface area drip dispersal system as defined in *30 TAC Chapter 222*, *Subsurface Area Drip Dispersal System*.

Se	ction 1. Administrative Information (Instructions Page 75)
Α.	Provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the treatment facility:
В.	<u>Click to enter text.</u> Is the owner of the land where the treatment facility is located the same as the owner of the treatment facility?
	□ Yes □ No
	If <b>no</b> , provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the land where the treatment facility is located.
	Click to enter text.
C.	Owner of the subsurface area drip dispersal system: <u>Click to enter text.</u>
D.	Is the owner of the subsurface area drip dispersal system the same as the owner of the wastewater treatment facility or the site where the wastewater treatment facility is located?
	□ Yes □ No
	If ${f no}$ , identify the names of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in Item 1.C.
	Click to enter text.
Е.	Owner of the land where the subsurface area drip dispersal system is located: <u>Click to enter text.</u>
F.	Is the owner of the land where the subsurface area drip dispersal system is located the same as owner of the wastewater treatment facility, the site where the wastewater treatment facility is located, or the owner of the subsurface area drip dispersal system?  □ Yes □ No
	If <b>no</b> , identify the name of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in item 1.E.
	Click to enter text.

# Section 2. Subsurface Area Drip Dispersal System (Instructions Page

A.	Type of system
	□ Subsurface Drip Irrigation
	□ Surface Drip Irrigation
	□ Other, specify: <u>Click to enter text.</u>
B.	Irrigation operations
	Application area, in acres: Click to enter text.
	Infiltration Rate, in inches/hour: Click to enter text.
	Average slope of the application area, percent (%): Click to enter text.
	Maximum slope of the application area, percent (%): Click to enter text.
	Storage volume, in gallons: <u>Click to enter text.</u>
	Major soil series: Click to enter text.
	Depth to groundwater, in feet: <u>Click to enter text.</u>
C.	Application rate
	Is the facility located <b>west</b> of the boundary shown in <i>30 TAC § 222.83</i> <b>and</b> also using a vegetative cover of non-native grasses over seeded with cool season grasses during the winter months (October-March)?
	□ Yes □ No
	If yes, then the facility may propose a hydraulic application rate not to exceed 0.1 gal/square foot/day.
	Is the facility located <b>east</b> of the boundary shown in <i>30 TAC § 222.83</i> <b>or</b> in any part of the state when the vegetative cover is any crop other than non-native grasses?
	□ Yes □ No
	If <b>yes</b> , the facility must use the formula in <i>30 TAC §222.83</i> to calculate the maximum hydraulic application rate.
	Do you plan to submit an alternative method to calculate the hydraulic application rate for approval by the executive director?
	□ Yes □ No
	Hydraulic application rate, in gal/square foot/day: Click to enter text.
	Nitrogen application rate, in lbs/gal/day: <u>Click to enter text.</u>
D.	Dosing information
	Number of doses per day: Click to enter text.
	Dosing duration per area, in hours: <u>Click to enter text.</u>

Rest period between doses, in hours: Click to enter text.

Dosing amount per area, in inches/day: Click to enter text.

	Number of zones: Click to enter text.
	Does the proposed subsurface drip irrigation system use tree vegetative cover as a crop?
	□ Yes □ No
	If <b>yes</b> , provide a vegetation survey by a certified arborist. Please call the Water Quality Assessment Team at (512) 239-4671 to schedule a pre-application meeting.
	Attachment: Click to enter text.
Se	ction 3. Required Plans (Instructions Page 75)
Α.	Recharge feature plan
	Attach a Recharge Feature Plan with all information required in 30 TAC §222.79.
	Attachment: Click to enter text.
B.	Soil evaluation
	Attach a Soil Evaluation with all information required in 30 TAC §222.73.
	Attachment: Click to enter text.
C.	Site preparation plan
	Attach a Site Preparation Plan with all information required in 30 TAC §222.75.
	Attachment: Click to enter text.
D.	Soil sampling/testing
	Attach soil sampling and testing that includes all information required in <i>30 TAC §222.157</i> .
	Attachment: Click to enter text.
Sa	ction 4. Floodway Designation (Instructions Page 76)
Α.	Site location
	Is the existing/proposed land application site within a designated floodway?
	□ Yes □ No
B.	Flood map
	Attach either the FEMA flood map or alternate information used to determine the floodway.
	Attachment: Click to enter text.
Ç <sub>o</sub>	ction 5. Surface Waters in the State (Instructions Page 76)
JC	ection 5. Surface waters in the state (instructions rage 70)

# A. Buffer Map

Attach a map showing appropriate buffers on surface waters in the state, water wells, and springs/seeps.

Attachment: Click to enter text.

Do you plan to request a buffer variance from water wells or waters in the state?
□ Yes □ No
If yes, then attach the additional information required in 30 TAC § 222.81(c).
Attachment: Click to enter text.
Section 6. Edwards Aquifer (Instructions Page 76)
Section 6. Edwards Aquiler (instructions rage 76)
<b>A.</b> Is the SADDS located over the Edwards Aquifer Recharge Zone as mapped by TCEQ?
□ Yes □ No
<b>B.</b> Is the SADDS located over the Edwards Aquifer Transition Zone as mapped by TCEQ?
□ Yes □ No
<b>If yes to either question</b> , then the SADDS may be prohibited by <i>30 TAC §213.8</i> . Please call the Municipal Permits Team at 512-239-4671 to schedule a pre-application meeting.

**B.** Buffer variance request

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 4.0: POLLUTANT ANALYSIS REQUIREMENTS

The following **is required** for facilities with a permitted or proposed flow of **1.0 MGD or greater**, facilities with an approved **pretreatment** program, or facilities classified as a **major** facility. See instructions for further details.

This worksheet is not required minor amendments without renewal.

See Appendix G

# Section 1. Toxic Pollutants (Instructions Page 78)

For pollutants identified in Table 4.0(1), indicate the type of sample.

Grab ⊠

Composite □

Date and time sample(s) collected: <u>07/18/2023@9:30</u>

# Table 4.0(1) - Toxics Analysis

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acrylonitrile	14.3	14.3	1	50
Aldrin	.00113	.00113	1	0.01
Aluminum	.0842	.0842	1	2.5
Anthracene	1.5	1.5	1	10
Antimony	1.05	1.05	1	5
Arsenic	5.2	5.2	1	0.5
Barium	93	93	1	3
Benzene	.46	.46	1	10
Benzidine	4.8	4.8	1	50
Benzo(a)anthracene	.173	.173	1	5
Benzo(a)pyrene	.364	.364	1	5
Bis(2-chloroethyl)ether	2.16	2.16	1	10
Bis(2-ethylhexyl)phthalate	.277	.277	1	10
Bromodichloromethane	.552	.552	1	10
Bromoform	.633	.633	1	10
Cadmium	.085	.085	1	1
Carbon Tetrachloride	.896	.896	1	2
Carbaryl	1.85	1.85	1	5
Chlordane*	.103	.103	1	0.2
Chlorobenzene	.530	.530	1	10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Chlorodibromomethane	.547	.547	1	10
Chloroform	.643	.643	1	10
Chlorpyrifos	N/A	N/A	N/A	0.05
Chromium (Total)	.392	.392	1	3
Chromium (Tri) (*1)	<2	<2	1	N/A
Chromium (Hex)	2	2	1	3
Copper	5.47	5.47	1	2
Chrysene	.222	.222	1	5
p-Chloro-m-Cresol	1.57	1.57	1	10
4,6-Dinitro-o-Cresol	1.44	1.44	1	50
p-Cresol	2.62	2.62	1	10
Cyanide (*2)	2.13	2.13	1	10
4,4'- DDD	.000814	.000814	1	0.1
4,4'- DDE	.00109	.00109	1	0.1
4,4'- DDT	.00379	.00379	1	0.02
2,4-D	.0541	.0541	1	0.7
Demeton (O and S)	N/A	N/A	N/A	0.20
Diazinon	N/A	N/A	N/A	0.5/0.1
1,2-Dibromoethane	.999	.999	1	10
m-Dichlorobenzene	.513	.513	1	10
o-Dichlorobenzene	.509	.509	1	10
p-Dichlorobenzene	.513	.513	1	10
3,3'-Dichlorobenzidine	.341	.341	1	5
1,2-Dichloroethane	.59	.59	1	10
1,1-Dichloroethylene	.738	.738	1	10
Dichloromethane	1.73	1.73	1	20
1,2-Dichloropropane	.667	.667	1	10
1,3-Dichloropropene	1.27	1.27	1	10
Dicofol	.05	.05	1	1
Dieldrin	.000953	.000953	1	0.02
2,4-Dimethylphenol	.649	.649	1	10
Di-n-Butyl Phthalate	.252	.252	1	10
Diuron	.166	.166	1	0.09

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Endosulfan I (alpha)	.00107	.00107	1	0.01
Endosulfan II (beta)	.00122	.00122	1	0.02
Endosulfan Sulfate	.00112	.00112	1	0.1
Endrin	.00156	.00156	1	0.02
Ethylbenzene	.411	.411	1	10
Fluoride	93.1	93.1	1	500
Guthion	N/A	N/A	N/A	0.1
Heptachlor	.00446	.00446	1	0.01
Heptachlor Epoxide	.00134	.00134	1	0.01
Hexachlorobenzene	.307	.307	1	5
Hexachlorobutadiene	1.26	1.26	1	10
Hexachlorocyclohexane (alpha)	.00142	.00142	1	0.05
Hexachlorocyclohexane (beta)	.00245	.00245	1	0.05
gamma-Hexachlorocyclohexane	.00299	.00299	1	0.05
(Lindane)				
Hexachlorocyclopentadiene	4.58	4.58	1	10
Hexachloroethane	.526	.526	1	20
Hexachlorophene	10	10	1	10
Lead	.537	.537	1	0.5
Malathion	N/A	N/A	N/A	0.1
Mercury	.0525	.0525	1	0.005
Methoxychlor	.0039	.0039	1	2
Methyl Ethyl Ketone	8.28	8.28	1	50
Mirex	.02	.02	1	0.02
Nickel	1.7	1.7	1	2
Nitrate-Nitrogen	20.8	20.8	1	100
Nitrobenzene	1.66	1.66	1	10
N-Nitrosodiethylamine	2.02	2.02	1	20
N-Nitroso-di-n-Butylamine	1.49	1.49	1	20
Nonylphenol	N/A	N/A	N/A	333
Parathion (ethyl)	N/A	N/A	N/A	0.1
Pentachlorobenzene	1.07	1.07	1	20
Pentachlorophenol	.234	.234	1	5

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Phenanthrene	1.42	1.42	1	10
Polychlorinated Biphenyls (PCB's) (*3)	.1	.1	1	0.2
Pyridine	2.64	2.64	1	20
Selenium	.685	.685	1	5
Silver	.118	.118	1	0.5
1,2,4,5-Tetrachlorobenzene	1.32	1.32	1	20
1,1,2,2-Tetrachloroethane	.47	.47	1	10
Tetrachloroethylene	.801	.801	1	10
Thallium	.096	.096	1	0.5
Toluene	.475	.475	1	10
Toxaphene	.0769	.0769	1	0.3
2,4,5-TP (Silvex)	.0424	.0424	1	0.3
Tributyltin (see instructions for explanation)	N/A	N/A	N/A	0.01
1,1,1-Trichloroethane	1.69	1.69	1	10
1,1,2-Trichloroethane	.511	.511	1	10
Trichloroethylene	.791	.791	1	10
2,4,5-Trichlorophenol	2	2	1	50
TTHM (Total Trihalomethanes)	.643	.643	1	10
Vinyl Chloride	.638	.638	1	10
Zinc	68.3	68.3	1	5

<sup>(\*1)</sup> Determined by subtracting hexavalent Cr from total Cr.

<sup>(\*2)</sup> Cyanide, amenable to chlorination or weak-acid dissociable.

<sup>(\*3)</sup> The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

### **Section 2.** Priority Pollutants

For pollutants identified in Tables 4.0(2)A-E, indicate type of sample.

Grab □ Composite □

Date and time sample(s) collected: <u>07/18/2023 9:30</u>

Table 4.0(2)A - Metals, Cyanide, and Phenols

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Antimony	1.05	1.05	1	5
Arsenic	5.2	5.2	1	0.5
Beryllium	.148	.148	1	0.5
Cadmium	.0850	.0850	1	1
Chromium (Total)	.392	.392	1	3
Chromium (Hex)	.2	.2	1	3
Chromium (Tri) (*1)	<2	<2	1	N/A
Copper	5.47	5.47	1	2
Lead	5.37	5.37	1	0.5
Mercury	.0525	.0525	1	0.005
Nickel	1.7	1.7	1	2
Selenium	.685	.685	1	5
Silver	.118	.118	1	0.5
Thallium	.096	.096	1	0.5
Zinc	68.3	68.3	1	5
Cyanide (*2)	2.13	2.13	1	10
Phenols, Total	N/A	N/A	1	10

<sup>(\*1)</sup> Determined by subtracting hexavalent Cr from total Cr.

<sup>(\*2)</sup> Cyanide, amenable to chlorination or weak-acid dissociable

Table 4.0(2)B - Volatile Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acrolein	11.1	11.1	1	50
Acrylonitrile	14.3	14.3	1	50
Benzene	.460	.460	1	10
Bromoform	.633	.633	1	10
Carbon Tetrachloride	.896	.896	1	2
Chlorobenzene	.530	.530	1	10
Chlorodibromomethane	.547	.547	1	10
Chloroethane	1.98	1.98	1	50
2-Chloroethylvinyl Ether	2.52	2.52	1	10
Chloroform	.643	.643	1	10
Dichlorobromomethane [Bromodichloromethane]	1.42	1.42	1	10
1,1-Dichloroethane	.635	.635	1	10
1,2-Dichloroethane	.590	.590	1	10
1,1-Dichloroethylene	.738	.738	1	10
1,2-Dichloropropane	.667	.667	1	10
1,3-Dichloropropylene	1.27	1.27	1	10
[1,3-Dichloropropene]				
1,2-Trans-Dichloroethylene	.945	.945	1	10
Ethylbenzene	.411	.411	1	10
Methyl Bromide	1.42	1.42	1	50
Methyl Chloride	2.04	2.04	1	50
Methylene Chloride	1.73	1.73	1	20
1,1,2,2-Tetrachloroethane	.47	.47	1	10
Tetrachloroethylene	.801	.801	1	10
Toluene	.475	.475	1	10
1,1,1-Trichloroethane	1.69	1.69	1	10
1,1,2-Trichloroethane	.511	.511	1	10
Trichloroethylene	.791	.791	1	10
Vinyl Chloride	.638	.638	1	10

Table 4.0(2)C - Acid Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2-Chlorophenol	.649	.649	1	10
2,4-Dichlorophenol	.314	.314	1	10
2,4-Dimethylphenol	N/A	N/A	N/A	10
4,6-Dinitro-o-Cresol	1.44	1.44	1	50
2,4-Dinitrophenol	.499	.499	1	50
2-Nitrophenol	1.67	1.67	1	20
4-Nitrophenol	4.91	4.91	1	50
P-Chloro-m-Cresol	1.57	1.57	1	10
Pentalchlorophenol	.234	.234	1	5
Phenol	.423	.423	1	10
2,4,6-Trichlorophenol	1.42	1.42	1	10

### Table 4.0(2)D - Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acenaphthene	1.39	1.39	1	10
Acenaphthylene	1.41	1.41	1	10
Anthracene	1.5	1.5	1	10
Benzidine	4.8	4.8	1	50
Benzo(a)Anthracene	.173	.173	1	5
Benzo(a)Pyrene	.364	.364	1	5
3,4-Benzofluoranthene	2.04	2.04	1	10
Benzo(ghi)Perylene	2.68	2.68	1	20
Benzo(k)Fluoranthene	.375	.376	1	5
Bis(2-Chloroethoxy)Methane	1.76	1.76	1	10
Bis(2-Chloroethyl)Ether	2.16	2.16	1	10
Bis(2-Chloroisopropyl)Ether	N/A	N/A	N/A	10
Bis(2-Ethylhexyl)Phthalate	.277	.277	1	10
4-Bromophenyl Phenyl Ether	.256	.256	1	10
Butyl benzyl Phthalate	.337	.337	1	10
2-Chloronaphthalene	.462	.462	1	10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
4-Chlorophenyl phenyl ether	1.28	1.28	1	10
Chrysene	.222	.222	1	5
Dibenzo(a,h)Anthracene	.246	.246	1	5
1,2-(o)Dichlorobenzene	.509	.509	1	10
1,3-(m)Dichlorobenzene	.513	.513	1	10
1,4-(p)Dichlorobenzene	.513	.513	1	10
3,3-Dichlorobenzidine	.341	.341	1	5
Diethyl Phthalate	1.59	1.59	1	10
Dimethyl Phthalate	.229	.229	1	10
Di-n-Butyl Phthalate	N/A	N/A	N/A	10
2,4-Dinitrotoluene	1.31	1.31	1	10
2,6-Dinitrotoluene	1.61	1.61	1	10
Di-n-Octyl Phthalate	.373	.373	1	10
1,2-Diphenylhydrazine (as Azobenzene)	1.49	1.49	1	20
Fluoranthene	1.59	1.59	1	10
Fluorene	1.63	1.63	1	10
Hexachlorobenzene	.307	.307	1	5
Hexachlorobutadiene	.238	.238	1	10
Hexachlorocyclo-pentadiene	4.58	4.58	1	10
Hexachloroethane	.526	.526	1	20
Indeno(1,2,3-cd)pyrene	2.29	2.29	1	5
Isophorone	1.64	1.64	1	10
Naphthalene	.542	.542	1	10
Nitrobenzene	1.66	1.66	1	10
N-Nitrosodimethylamine	2.02	2.02	1	50
N-Nitrosodi-n-Propylamine	2.88	2.88	1	20
N-Nitrosodiphenylamine	1.81	1.81	1	20
Phenanthrene	1.42	1.42	1	10
Pyrene	.178	.178	1	10
1,2,4-Trichlorobenzene	.161	.161	1	10

Table 4.0(2)E - Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Aldrin	.00113	.00113	1	0.01
alpha-BHC (Hexachlorocyclohexane)	.00142	.00142	1	0.05
beta-BHC (Hexachlorocyclohexane)	.00389	.00389	1	0.05
gamma-BHC (Hexachlorocyclohexane)	.00299	.00299	1	0.05
delta-BHC (Hexachlorocyclohexane)	.00245	.00245	1	0.05
Chlordane	1.03	1.03	1	0.2
4,4-DDT	.00379	.00379	1	0.02
4,4-DDE	.00109	.00109	1	0.1
4,4,-DDD	.000814	.000518	1	0.1
Dieldrin	.000953	.000953	1	0.02
Endosulfan I (alpha)	.00107	.00107	1	0.01
Endosulfan II (beta)	.00122	.00122	1	0.02
Endosulfan Sulfate	.00112	.00112	1	0.1
Endrin	.00156	.00156	1	0.02
Endrin Aldehyde	.00117	.00117	1	0.1
Heptachlor	.00446	.00446	1	0.01
Heptachlor Epoxide	.00134	.00134	1	0.01
PCB-1242	.0125	.0125	1	0.2
PCB-1254	.0078	.0078	1	0.2
PCB-1221	.0125	.0125	1	0.2
PCB-1232	.0125	.0125	1	0.2
PCB-1248	.0125	.0125	1	0.2
PCB-1260	.0078	.0078	1	0.2
PCB-1016	.0125	.0125	1	0.2
Toxaphene	.0769	.0769	1	0.3

<sup>\*</sup> For PCBS, if all are non-detects, enter the highest non-detect preceded by a "<".

### Section 3. Dioxin/Furan Compounds

Α.	. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user. Check all that apply.								
		2,4,5-trichlorophenoxy acetic acid							
		Common Name 2,4,5-T, CASRN 93-76-5							
		2-(2,4,5-trichlorophenoxy) propanoic acid							
		Common Name Silvex or 2,4,5-TP, CASRN 93-72-1							
		2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate							
		Common Name Erbon, CASRN 136-25-4							
		0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate							
		Common Name Ronnel, CASRN 299-84-3							
		2,4,5-trichlorophenol							
		Common Name TCP, CASRN 95-95-4							
		hexachlorophene							
		Common Name HCP, CASRN 70-30-4							
		ch compound identified, provide a brief description of the conditions of its/their nce at the facility.							
	$N/\underline{A}$								
	IV/A								
	N/A								
	N/ <u>A</u>								
	IN/A								
В.	Do yo	u know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin O) or any congeners of TCDD may be present in your effluent?							
В.	Do yo (TCDI	O) or any congeners of TCDD may be present in your effluent?  Yes ☑ No							
В.	Do yo (TCDI	o) or any congeners of TCDD may be present in your effluent?							
В.	Do yo (TCDI	O) or any congeners of TCDD may be present in your effluent?  Yes ⊠ No							
В.	Do yo (TCDI	O) or any congeners of TCDD may be present in your effluent?  Yes ⊠ No							
В.	Do yo (TCDI	O) or any congeners of TCDD may be present in your effluent?  Yes ⊠ No							

C.	If any of the compounds in Subsection A ${f or}$ B are present, complete Table 4.0(2)F.
	For pollutants identified in Table 4.0(2)F, indicate the type of sample.

Grab □ Composite □

Date and time sample(s) collected: Click to enter text.

### Table 4.0(2)F - Dioxin/Furan Compounds

Compound	Toxic Equivalenc y Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
2,3,7,8 TCDD	1					10
1,2,3,7,8 PeCDD	0.5					50
2,3,7,8 HxCDDs	0.1					50
1,2,3,4,6,7,8 HpCDD	0.01					50
2,3,7,8 TCDF	0.1					10
1,2,3,7,8 PeCDF	0.05					50
2,3,4,7,8 PeCDF	0.5					50
2,3,7,8 HxCDFs	0.1					50
2,3,4,7,8 HpCDFs	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					0.5
PCB 81	0.0003					0.5
PCB 126	0.1					0.5
PCB 169	0.03					0.5
Total						

### DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 5.0: TOXICITY TESTING REQUIREMENTS

The following **is required** for facilities with a current operating design flow of **1.0 MGD or greater**, with an EPA-approved **pretreatment** program (or those required to have one under 40 CFR Part 403), or are required to perform Whole Effluent Toxicity testing. See instructions for further details.

This worksheet is not required minor amendments without renewal.

### Section 1. Required Tests (Instructions Page 88)

Indicate the number of 7-day chronic or 48-hour acute Whole Effluent Toxicity (WET) tests performed in the four and one-half years prior to submission of the application.

7-day Chronic: <u>Click to enter text.</u>

48-hour Acute: <u>20</u>

### **Section 2.** Toxicity Reduction Evaluations (TREs)

Has this facility	completed a	ı TRE in th	e past fo	ır and	a half	years?	Or is	the facilit	y currently
performing a TI	RE?								

□ Yes ⊠ No

If yes, describe the progress to date, if applicable, in identifying and confirming the toxicant.

N/A		

### **Section 3. Summary of WET Tests**

If the required biomonitoring test information has not been previously submitted via both the Discharge Monitoring Reports (DMRs) and the Table 1 (as found in the permit), provide a summary of the testing results for all valid and invalid tests performed over the past four and one-half years. Make additional copies of this table as needed.

Table 5.0(1) Summary of WET Tests

Test Date Test Species		NOEC Survival	NOEC Sub-lethal
2/19/2019	Daphnia pulex	100	
	Pimephales promelas		
5/21/2019	Daphnia pulex	100	
	Pimephales promelas		
8/20/2019	Daphnia pulex	100	
	Pimephales promelas		
11/19/2019	Daphnia pulex	100	
	Pimephales promelas		
2/18/2020	Daphnia pulex	100	
	Pimephales promelas		
5/19/2020	Daphnia pulex	100	
	Pimephales promelas		
8/18/2020	Daphnia pulex	100	
	Pimephales promelas		
11/17/2020	Daphnia pulex	100	
	Pimephales promelas		
3/30/2021	Daphnia pulex	100	
	Pimephales promelas		
5/18/2021	Daphnia pulex	100	
	Pimephales promelas		
8/17/2021	Daphnia pulex	100	
	Pimephales promelas		
11/23/2021	Daphnia pulex	100	
	Pimephales promelas		
2/15/2022	Daphnia pulex	100	

Test Date	Test Species	NOEC Survival	NOEC Sub-lethal	
	Pimephales promelas			
5/18/2022	Daphnia pulex	100		
	Pimephales promelas			
8/17/2022	Daphnia pulex	100		
	Pimephales promelas			
11/16/2022	Daphnia pulex	100		
	Pimephales promelas			
2/15/2023	Daphnia pulex	100		
	Pimephales promelas			
5/10/2023	Daphnia pulex	100		
	Pimephales promelas			

### DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following is required for all publicly owned treatment works.

### Section 1. All POTWs (Instructions Page 89)

#### A. Industrial users (IUs)

Provide the number of each of the following types of industrial users (IUs) that discharge to your POTW and the daily flows from each user. See the Instructions for definitions of Categorical IUs, Significant IUs – non-categorical, and Other IUs.

### If there are no users, enter 0 (zero).

Categorical IUs:

Number of IUs: o

Average Daily Flows, in MGD: N/A

Significant IUs - non-categorical:

Number of IUs: o

Average Daily Flows, in MGD: N/A

Other IUs:

Number of IUs: o

Average Daily Flows, in MGD: N/A

#### B. Treatment plant interference

In the past three years, has your POTW experienced treatment plant interference (see instructions)?

□ Yes ⊠ No

**If yes**, identify the dates, duration, description of interference, and probable cause(s) and possible source(s) of each interference event. Include the names of the IUs that may have caused the interference.

N/A

	in the past three years, has your POTW experienced pass through (see instructions)?
	□ Yes ⊠ No
	If yes, identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.
	N/A
D	Pretreatment program
D.	Does your POTW have an approved pretreatment program?
	☐ Yes ☑ No
	If yes, complete Section 2 only of this Worksheet.
	Is your POTW required to develop an approved pretreatment program?
	□ Yes ⊠ No
	If yes, complete Section 2.c. and 2.d. only, and skip Section 3.
	If no to either question above, skip Section 2 and complete Section 3 for each significant
	industrial user and categorical industrial user.
Se	ection 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)
	ection 2. POTWs with Approved Programs or Those Required to
	ection 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)
	ection 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)  Substantial modifications  Have there been any substantial modifications to the approved pretreatment program
	Ection 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)  Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?
	POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)  Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?  Yes No  If yes, identify the modifications that have not been submitted to TCEQ, including the
	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?  Yes No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?  Yes No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?  Yes No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?  Yes No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.

C. Treatment plant pass through

Have there been any <b>non-substantial modifications</b> to the approved pretreatment program that have not been submitted to TCEQ for review and acceptance?							
□ Yes □ No							
If yes, identify all non-substantial modifications that have not been submitted to TCEQ, including the purpose of the modification.							
N/A							
C. Effluent param	eters above the MAL						
	list all parameters me						
monitoring dur	ing the last three year	rs. Submit an atta	achment if nec	essary.			
Table 6.0(1) – Parai	meters Above the MAL						
Pollutant	Concentration	MAL	Units	Date			
N/A							
D. Industrial user	interruptions						
Has any SIU, CI	U, or other IU caused pass throughs) at yo						
□ Yes □	No						
	<b>If yes</b> , identify the industry, describe each episode, including dates, duration, description of the problems, and probable pollutants.						
N/A							

**B.** Non-substantial modifications

### Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 90)

A. General information

	Company Name: <u>N/A – No Industrial Users</u>
	SIC Code: Click to enter text.
	Contact name: Click to enter text.
	Address: Click to enter text.
	City, State, and Zip Code: <u>Click to enter text.</u>
	Telephone number: <u>Click to enter text.</u>
	Email address: <u>Click to enter text.</u>
B.	Process information
	Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).
	N/A
C.	Product and service information
C.	Product and service information  Provide a description of the principal product(s) or services performed.
C.	Provide a description of the principal product(s) or services performed.
C.	
C.	Provide a description of the principal product(s) or services performed.
C.	Provide a description of the principal product(s) or services performed.
C.	Provide a description of the principal product(s) or services performed.
C.	Provide a description of the principal product(s) or services performed.
	Provide a description of the principal product(s) or services performed.  N/A
	Provide a description of the principal product(s) or services performed.  N/A  Flow rate information
	Provide a description of the principal product(s) or services performed.  N/A  Flow rate information  See the Instructions for definitions of "process" and "non-process wastewater."
	Provide a description of the principal product(s) or services performed.  N/A  Flow rate information  See the Instructions for definitions of "process" and "non-process wastewater."  Process Wastewater:
	Provide a description of the principal product(s) or services performed.  N/A  Flow rate information  See the Instructions for definitions of "process" and "non-process wastewater."  Process Wastewater:  Discharge, in gallons/day: N/A
	Provide a description of the principal product(s) or services performed.  N/A  Flow rate information  See the Instructions for definitions of "process" and "non-process wastewater."  Process Wastewater:  Discharge, in gallons/day: N/A  Discharge Type:  Continuous  Batch  Intermittent
	Provide a description of the principal product(s) or services performed.  N/A  Flow rate information  See the Instructions for definitions of "process" and "non-process wastewater."  Process Wastewater:  Discharge, in gallons/day: N/A  Discharge Type:  Continuous  Batch  Intermittent  Non-Process Wastewater:
	Provide a description of the principal product(s) or services performed.  N/A  Flow rate information  See the Instructions for definitions of "process" and "non-process wastewater."  Process Wastewater:  Discharge, in gallons/day: N/A  Discharge Type:  Continuous  Batch  Intermittent

E.	Pretreatment standards
	Is the SIU or CIU subject to technically based local limits as defined in the <i>i</i> nstructions?
	□ Yes □ No
	Is the SIU or CIU subject to categorical pretreatment standards found in $40$ CFR Parts $405$ - $471$ ?
	□ Yes □ No
	<b>If subject to categorical pretreatment standards</b> , indicate the applicable category and subcategory for each categorical process.
	Category: Subcategories: <u>N/A</u>
	Click or tap here to enter text. Click to enter text.
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
F.	Industrial user interruptions
	Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?
	□ Yes □ No
	<b>If yes</b> , identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.
	N/A

### **WORKSHEET 7.0**

#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

#### CLASS V INJECTION WELL INVENTORY/AUTHORIZATION FORM

Submit the completed form to:

TCEQ IUC Permits Team Radioactive Materials Division MC-233 PO Box 13087 Austin, Texas 78711-3087 512-239-6466

For TCEQ Use Only
Reg. No
Date Received
Date Authorized

N/A - TPDES

### Section 1. General Information (Instructions Page 92)

1	TCEO	Drogram	Amon
1.	ICEU	<b>Program</b>	Area

Program Area (PST, VCP, IHW, etc.): Click to enter text.

Program ID: Click to enter text.

Contact Name: <u>Click to enter text.</u> Phone Number: <u>Click to enter text.</u>

#### 2. Agent/Consultant Contact Information

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

#### 3. Owner/Operator Contact Information

□ Owner □ Operator

Owner/Operator Name: Click to enter text.

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

#### 4. Facility Contact Information

Facility Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Location description (if no address is available): Click to enter text.

Facility Contact Person: Click to enter text.

Phone Number: Click to enter text.

5.	Latitude and Longitude, in degrees-minutes-seconds
	Latitude: Click to enter text.
	Longitude: Click to enter text.
	Method of determination (GPS, TOPO, etc.): Click to enter text.
	Attach topographic quadrangle map as attachment A.
6.	Well Information
	Type of Well Construction, select one:
	□ Vertical Injection
	□ Subsurface Fluid Distribution System
	□ Infiltration Gallery
	□ Temporary Injection Points
	□ Other, Specify: <u>Click to enter text.</u>
	Number of Injection Wells: <u>Click to enter text.</u>
7.	Purpose
	Detailed Description regarding purpose of Injection System:
	Click to enter text.
	Attach a Site Map as Attachment B (Attach the Approved Remediation Plan, if appropriate.)
8.	Water Well Driller/Installer
	Water Well Driller/Installer Name: <u>Click to enter text.</u>
	City, State, and Zip Code: <u>Click to enter text.</u>
	Phone Number: <u>Click to enter text.</u>
	License Number: <u>Click to enter text.</u>
Section	2. Proposed Down Hole Design
Attach a	diagram signed and sealed by a licensed engineer as Attachment C.
Table 7.0(	(1) – Down Hole Design Table

Name of String	Size	Setting Depth	Sacks Cement/Grout - Slurry Volume - Top of Cement	Hole Size	Weight (lbs/ft) PVC/Steel
Casing					
Tubing					
Screen					

### Section 3. Proposed Trench System, Subsurface Fluid Distribution System, or Infiltration Gallery

Attach a diagram signed and sealed by a licensed engineer as Attachment D.

System(s) Dimensions: <u>Click to enter text.</u> System(s) Construction: Click to enter text.

Section 4.	Site Hydr	ogeologica	l and Ini	ection 7	one Data
occuon 1.	DICC II y CII	OECOIOEICA	T GIIG III	CCLIOII Z	Dire Data

- 1. Name of Contaminated Aquifer: Click to enter text.
- 2. Receiving Formation Name of Injection Zone: Click to enter text.
- **3.** Well/Trench Total Depth: Click to enter text.
- **4.** Surface Elevation: <u>Click to enter text.</u>
- **5.** Depth to Ground Water: <u>Click to enter text.</u>
- **6.** Injection Zone Depth: Click to enter text.
- 7. Injection Zone vertically isolated geologically? 

  Yes 

  No

  Impervious Strata between Injection Zone and nearest Underground Source of Drinking Water:

Name: Click to enter text.

Thickness: Click to enter text.

- **8.** Provide a list of contaminants and the levels (ppm) in contaminated aquifer Attach as Attachment E.
- **9.** Horizontal and Vertical extent of contamination and injection plume Attach as Attachment F.
- **10.** Formation (Injection Zone) Water Chemistry (Background levels) TDS, etc. Attach as Attachment G.
- **11.** Injection Fluid Chemistry in PPM at point of injection Attach as Attachment H.
- 12. Lowest Known Depth of Ground Water with < 10,000 PPM TDS: Click to enter text.
- **13.** Maximum injection Rate/Volume/Pressure: Click to enter text.
- 14. Water wells within 1/4 mile radius (attach map as Attachment I): Click to enter text.
- 15. Injection wells within 1/4 mile radius (attach map as Attachment J): <u>Click to enter text.</u>
- 16. Monitor wells within 1/4 mile radius (attach drillers logs and map as Attachment K): Click to enter text.
- **17.** Sampling frequency: Click to enter text.
- **18.** Known hazardous components in injection fluid: Click to enter text.

### Section 5. Site History

- **1.** Type of Facility: Click to enter text.
- **2.** Contamination Dates: Click to enter text.
- 3. Original Contamination (VOCs, TPH, BTEX, etc.) and Concentrations (attach as Attachment L): <u>Click to enter text.</u>
- **4.** Previous Remediation (attach results of any previous remediation as attachment M): Click to enter text.

NOTE: Authorization Form should be completed in detail and authorization given by the TCEQ before construction, operation, and/or conversion can begin. Attach additional pages as necessary.

#### Class V Injection Well Designations

- 5A07 Heat Pump/AC return (IW used for groundwater to heat and/or cool buildings)
- 5A19 Industrial Cooling Water Return Flow (IW used to cool industrial process equipment)
- 5B22 Salt Water Intrusion Barrier (IW used to inject fluids to prevent the intrusion of salt water into an aquifer)
- 5D02 Storm Water Drainage (IW designed for the disposal of rain water)
- 5D04 Industrial Stormwater Drainage Wells (IW designed for the disposal of rain water associated with industrial facilities)
- 5F01 Agricultural Drainage (IW that receive agricultural runoff)
- 5R21 Aquifer Recharge (IW used to inject fluids to recharge an aquifer)
- 5S23 Subsidence Control Wells (IW used to control land subsidence caused by ground water withdrawal)
- 5W09 Untreated Sewage
- 5W10 Large Capacity Cesspools (Cesspools that are designed for 5,000 gpd or greater)
- 5W11 Large Capacity Septic systems (Septic systems designed for 5,000 gpd or greater)
- 5W12 WTTP disposal
- 5W20 Industrial Process Waste Disposal Wells
- 5W31 Septic System (Well Disposal method)
- 5W32 Septic System Drainfield Disposal
- 5X13 Mine Backfill (IW used to control subsidence, dispose of mining byproducts, and/or fill sections of a mine)
- 5X25 Experimental Wells (Pilot Test) (IW used to test new technologies or tracer dye studies)
- 5X26 Aguifer Remediation (IW used to clean up, treat, or prevent contamination of a USDW)
- 5X27 Other Wells
- 5X28 Motor Vehicle Waste Disposal Wells (IW used to dispose of waste from a motor vehicle site These are currently banned)
- 5X29 Abandoned Drinking Water Wells (waste disposal)

Appendix A

Core Data Form



### **TCEQ Core Data Form**

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

### **SECTION I: General Information**

1. Reason for Submission (If other is checked please describe in space provided.)

☐ New Pern	nit, Registra	ation or Authorization (	Core Data Form	should be s	submitted v	vith the prog	gram application.)				
Renewal (Core Data Form should be submitted with the renewal form)						☐ Other					
2. Customer Reference Number (if issued) CN 600632400				or CN or RN	ink to searc	in	Regulated Entity Reference Number (if issued) N 101918977				
<u>SECTIOI</u>	N II:	Customer	<u>Inform</u>	ation	<u>l</u>						
4. General Customer Information 5. Effective				ve Date for Customer Information Updates (mm/dd/yyyy)							
☐ New Custor ☐ Change in Lo		U <sub>I</sub> (Verifiable with the Tex	odate to Custom as Secretary of S				nge in Regulated Er c Accounts)	ntity Own	ership		
		bmitted here may b oller of Public Accou	-	tomaticali	ly based o	on what is o	current and active	e with th	ne Texas Sec	retary of State	
6. Customer	Legal Nam	ne (If an individual, prir	nt last name first	: eg: Doe, J	lohn)		If new Customer,	, enter pre	evious Custom	ner below:	
City of Lamesa											
7. TX SOS/CPA Filing Number 8. TX			8. TX State Ta	tate Tax ID (11 digits)			9. Federal Tax ID (9 digits)		10. DUNS Number (if applicable)		
11. Type of Customer: Corporation						☐ Indivi	☐ Individual Partnership:			neral 🗌 Limited	
Government: ⊠ City ☐ County ☐ Federal ☐ Local ☐ State ☐ Other						☐ Sole F	Sole Proprietorship Other:				
12. Number o	21-100	☑ 101-250   ☐ 251-					13. Independe	⊠ No		erated?	
Owner		posed or Actual) – as it  Operator  Responsible Par	⊠ Own	er & Opera CP/BSA App	ator	on this form.	Please check one o		owing		
15. Mailing	601 S. 1 <sup>st</sup>	Street									
Address:	City	Lamesa		State	TX	ZIP	79331		ZIP + 4		
16. Country N	Mailing Inf	formation (if outside	USA)		1	7. E-Mail A	ddress (if applicab	ole)			
					di	irectorofutili	ties@ci.lamesa.tx.u	IS			

TCEQ-10400 (11/22) Page 1 of 3

806 ) 872-2124	( ) -

### **SECTION III: Regulated Entity Information**

tity Informa	tion (If 'New Reg	ulated Entity" is select	ted, a new pe	rmit applicat	ion is also	required.)							
☐ New Regulated Entity ☐ Update to Regulated Entity Name ☐ Update to Regulated Entity Information													
The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).													
22. Regulated Entity Name (Enter name of the site where the regulated action is taking place.)													
City of Lamesa Wastewater Treatment Plant													
City		State		ZIP		ZIP		+ 4					
24. County Dawson			I					I					
If no Street Address is provided, fields 25-28 are required.													
25. Description to  Located approximately 1.3 miles southeast of the intersection of State Highway 137 and Sulphur Springs Draw southeast of Lamesa													
Physical Location:													
26. Nearest City			State				Nearest ZIP Code						
				TX			79331						
Latitude/Longitude are required and may be added/updated to meet TCEQ Core Data Standards. (Geocoding of the Physical Address may be used to supply coordinates where none have been provided or to gain accuracy).													
al:	32.7119			<b>28. Longitude (W) In Decimal:</b> -101.94611									
Minutes		Seconds		Degrees		Minutes		Seconds					
	42	43		-101		56		46					
30.	Secondary SIC (	Code or a		NAICS Cada 32. Sect		undary NAICS Code							
			(5 or 6 digits)										
4952		221320											
33. What is the Primary Business of this entity? (Do not repeat the SIC or NAICS description.)													
usiness of t	ins entity: (Do	Thou repeat the Sic of		,			Wastewater Treatment for the City of Lamesa						
		Thou repeat the Sic of		,									
	esa	not repeat the Sic of		,									
e City of Lame	esa	not repeat the Sic of		,									
e City of Lame	esa	State	тх	ZIP	79331		ZIP + 4						
e City of Lame	esa	State			79331		ZIP + 4						
e City of Lame	treet	State	тх	ZIP		e <b>r</b> (if applicab							
	City Dawson  Located app in Dawson C  cquired and as where not al:  Minutes  30. (4 di	Update to Regulated Entity  ne submitted may be update  e (Enter name of the site where  reatment Plant  City  Dawson  If no Street  Located approximately 1.3 min in Dawson County  equired and may be added, as where none have been positive where	Update to Regulated Entity Name Update to the submitted may be updated, in order to meet the regulated action of the site where the reg	Update to Regulated Entity Name Update to Regulated Enter submitted may be updated, in order to meet TCEQ Core  e (Enter name of the site where the regulated action is taking place  reatment Plant  City State  Dawson  If no Street Address is provided, fields 2:  Located approximately 1.3 miles southeast of the intersection of in Dawson County  equired and may be added/updated to meet TCEQ Core Dies where none have been provided or to gain accuracy).  al: 32.7119 28. Located approximately 43  30. Secondary SIC Code 31. Primary (5 or 6 digit)  (4 digits) 221320	Update to Regulated Entity Name Update to Regulated Entity Informative submitted may be updated, in order to meet TCEQ Core Data Standard Entity Informative (Enter name of the site where the regulated action is taking place.)  Treatment Plant  State ZIP  Dawson  If no Street Address is provided, fields 25-28 are recular action of State Highway in Dawson County  Equired and may be added/updated to meet TCEQ Core Data Standards as where none have been provided or to gain accuracy).  Seconds Degrees  42 43 -101  30. Secondary SIC Code (4 digits)  221320	Update to Regulated Entity Name Update to Regulated Entity Information  The submitted may be updated, in order to meet TCEQ Core Data Standards (researched in the site where the regulated action is taking place.)  The etament Plant  The Street Address is provided, fields 25-28 are required.  Located approximately 1.3 miles southeast of the intersection of State Highway 137 and in Dawson County  State  TX  Equired and may be added/updated to meet TCEQ Core Data Standards. (Geodess where none have been provided or to gain accuracy).  Al: 32.7119  28. Longitude (W) In Decir Minutes  Degrees  Minutes  Seconds  Degrees  Minutes  13. Primary NAICS Code (5 or 6 digits)	e (Enter name of the site where the regulated action is taking place.)  reatment Plant  City State ZIP  Dawson  If no Street Address is provided, fields 25-28 are required.  Located approximately 1.3 miles southeast of the intersection of State Highway 137 and Sulphur Spring in Dawson County  State  TX  required and may be added/updated to meet TCEQ Core Data Standards. (Geocoding of the swhere none have been provided or to gain accuracy).  al: 32.7119  Z8. Longitude (W) In Decimal:  Minutes  Seconds  Degrees  Minutes  42  43  -101  56  30. Secondary SIC Code (4 digits)  (5 or 6 digits)  (5 or 6 digits)	Update to Regulated Entity Name Update to Regulated Entity Information  The submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organization are (Enter name of the site where the regulated action is taking place.)  The state State In St					

TCEQ-10400 (11/22) Page 2 of 3

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance. ☐ Dam Safety Districts Edwards Aquifer ☐ Emissions Inventory Air ☐ Industrial Hazardous Waste ☐ New Source OSSF ☐ Petroleum Storage Tank ☐ PWS Review Air Sludge Storm Water ☐ Title V Air ☐ Tires Used Oil ☐ Voluntary Cleanup ■ Wastewater Agriculture ■ Water Rights Other: WQ0010107001 **SECTION IV: Preparer Information** 40. Name: Paul Krueger, P.E. 41. Title: Civil Engineer 42. Telephone Number 43. Ext./Code 44. Fax Number 45. E-Mail Address (806) 473-2200 pkrueger@parkhill.com **SECTION V: Authorized Signature** 46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39. Company: Job Title: Utilities Director City of Lamesa Name (In Print): Ernest Ojeda Phone: (806)872-2124 Signature: Date:

TCEQ-10400 (11/22) Page 3 of 3

Appendix B
Plain Language Summary

# TCEQ

### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

### PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

# Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter 'INDUSTRIAL' or 'DOMESTIC' here WASTEWATER/STORMWATER


The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

City of Lamesa (CN600632400) operates City of Levelland Wastewater Treatment Plant (RN101948977), an activated sludge treatment process using the extended aeration mode. The facility is located at 1.3 miles southeast of the intersection of State Hwy 137 and Sulphur Springs Draw, in Lamesa, Dawson County, Texas 79331. A permit renewal to discharge 2.0 million gallons a day of treated domestic wastewater.

Discharges from the facility are expected to contain Carbonaceous Biochemical Oxygen Demand, Total Suspended Solids, and Ammonia Nitrogen. Domestic wastewater is treated by activated sludge treatment process using the extended aeration mode. Treatment units include a screen, vortex grit removal, carrousel aeration basin, 2 final clarifiers, and UV disinfection.

Appendix C

**USGS Map** 



## **City of Lamesa Wastewater Treatment Plant**

City of Lamesa 601 S. 1st Street Lamesa, TX, 79331



Parkhill.com

### Appendix C USGS Map

Issue: Permit Renewal
Date: 05/17/2024
Project No: 41362.23
Sheet: 1 of 1

Appendix D

**SPIF Form** 

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

### FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:
Application type:RenewalMajor AmendmentMinor AmendmentNew
County: Segment Number:
Admin Complete Date:
Agency Receiving SPIF:
Texas Historical Commission U.S. Fish and Wildlife
Texas Parks and Wildlife Department U.S. Army Corps of Engineers
This form applies to TPDES permit applications only. (Instructions, Page 53)
Complete this form as a separate document. TCEQ will mail a copy to each agency as required by our agreement with EPA. If any of the items are not completely addressed or further information is needed, we will contact you to provide the information before issuing the permit. Address each item completely.
Do not refer to your response to any item in the permit application form. Provide each attachment for this form separately from the Administrative Report of the application. The application will not be declared administratively complete without this SPIF form being completed in its entirety including all attachments. Questions or comments concerning this form may be directed to the Water Quality Division's Application Review and Processing Team by email at

answer specific questions about the property.
Prefix (Mr., Ms., Miss): Mr.
First and Last Name: <u>Ernest Ojeda</u>
Credential (P.E, P.G., Ph.D., etc.):
Title: <u>Director of Utilities</u>
Mailing Address: <u>601 S. 1st Street</u>
City, State, Zip Code: <u>Lamesa, TX, 79331</u>
Phone No.: <u>806.201.0243</u> Ext.: Fax No.:
E-mail Address: <u>directorofutilites@ci.lamesa.tx.us</u>
List the county in which the facility is located: <u>Dawson</u>
If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.
City of Lamesa
Provide a description of the effluent discharge route. The discharge route must follow the flow of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.
The treated effluent is discharged through a 24" out fall pipe to Sulphur Springs Draw, then
to Mustang Draw, then to Beals Creek, then to Colorado River. The nearest classified stream segrent is Segrent 1412, described as the Colorado river below lake J.B. Thomas.
Segrene is Segrene 1112, described as the colorado fiver below lake j.b. Thomas.
Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries
plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report).
Provide original photographs of any structures 50 years or older on the property.
Does your project involve any of the following? Check all that apply.
□ Proposed access roads, utility lines, construction easements
□ Visual effects that could damage or detract from a historic property's integrity
□ Vibration effects during construction or as a result of project design
☐ Additional phases of development that are planned for the future
☐ Sealing caves, fractures, sinkholes, other karst features

Provide the name, address, phone and fax number of an individual that can be contacted to


2.3.

4.

5.

1.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	N/A
2.	Describe existing disturbances, vegetation, and land use:
	$\frac{N/A}{}$
тц	E FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR
	ENDMENTS TO TPDES PERMITS
3.	List construction dates of all buildings and structures on the property:
	N/A
4.	Provide a brief history of the property, and name of the architect/builder, if known.
	N/A

Disturbance of vegetation or wetlands



### Lamesa Wastewater Treatment Plant

City of Lamesa 601 S. 1st Street Lamesa, TX, 79331



Parkhill.com

### Appendix D SPIF Map

 Issue:
 Permit Renewal


 Date:
 04/17/2024

 Project No:
 41362.23

 Sheet:
 1 of 1

Appendix E

Flow Diagram



### City of Lamesa Wastewater **Treatment Plant**

**City of Lamesa** 601 S. 1st Street Lamesa, TX, 79331



Parkhill.com

### Appendix E **Flow Diagram**

Issue: Date: Project No: Permit Renewal 05/17/2023 41362.23

Sheet: 1 of 1

Appendix F
Site Map



# **City of Lamesa Wastewater Treatment Plant**

City of Lamesa 601 S. 1st Street Lamesa, TX, 79331

# Parkhill.com

### Appendix F Site Map

 Issue:
 Permit Renewal

 Date:
 05/17/2024

 Project No:
 41362.23

 Sheet:
 1 of 1

Appendix G

Pollutant Analysis

# **ANALYTICAL REPORT**

### PREPARED FOR

Attn: Jessica Richey Parkhill Smith & Cooper Inc. 4222 85th Street Lubbock, Texas 79423

Generated 7/31/2023 1:28:59 PM

### **JOB DESCRIPTION**

**TPDES Permit Application Renewal** 

## **JOB NUMBER**

820-9303-1

Eurofins Lubbock 6701 Aberdeen Ave. Suite 8 Lubbock TX 79424



# **Eurofins Lubbock**

#### **Job Notes**

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All guestions should be directed to the Eurofins Environment Testing South Central, LLC Project Manager.

### **Authorization**

Generated 7/31/2023 1:28:59 PM

Authorized for release by John Builes, Project Manager John.Builes@et.eurofinsus.com (561)558-4549

# **Table of Contents**

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	6
Client Sample Results	8
Surrogate Summary	14
QC Sample Results	16
QC Association Summary	41
Lab Chronicle	48
Certification Summary	50
Method Summary	51
Sample Summary	53
Chain of Custody	54
	58

3

4

0

Q

9

11

12

12

### **Definitions/Glossary**

Client: Parkhill Smith & Cooper Inc. Job ID: 820-9303-1

Project/Site: TPDES Permit Application Renewal

**Qualifier Description** 

#### **Qualifiers**

#### **GC/MS VOA**

Qualifier **Qualifier Description** 

Indicates the analyte was analyzed for but not detected.

#### GC/MS Semi VOA

Qualifier	Qualifier Description
*_	LCS and/or LCSD is outside acceptance limits, low biased.
*1	LCS/LCSD RPD exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
S1-	Surrogate recovery exceeds control limits, low biased.
U	Indicates the analyte was analyzed for but not detected.
GC Semi VC	DA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
S1+	Surrogate recovery exceeds control limits, high biased.
U	Indicates the analyte was analyzed for but not detected.

#### HPLC/IC

Qualifier

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
U	Indicates the analyte was analyzed for but not detected.
Metals	

	J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.				
	U	Indicates the analyte was analyzed for but not detected.				
General Chemistry						

#### Generai Chemistry

Qualifier	Qualifier Description
4	MS, MSD: The analyte present in the original sample is greater than 4 times the matrix spike concentration; therefore, control limits are not
	applicable.
HF	Field parameter with a holding time of 15 minutes. Test performed by laboratory at client's request.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
U	Indicates the analyte was analyzed for but not detected.

#### **Glossary**

Abbreviation	These commonly used abbreviations may or may not be present in this report.
n	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit

**Eurofins Lubbock** 

Page 4 of 59 7/31/2023

### **Definitions/Glossary**

Client: Parkhill Smith & Cooper Inc.

Job ID: 820-9303-1

Project/Site: TPDES Permit Application Renewal

### **Glossary (Continued)**

Too Numerous To Count

TNTC

Abbreviation	These commonly used abbreviations may or may not be present in this report.
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)

3

Α

5

6

\_

9

10

13

14

#### Case Narrative

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

**Laboratory: Eurofins Lubbock** 

Narrative

Job Narrative 820-9303-1

#### Receipt

The sample was received on 7/18/2023 11:50 AM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 5.0°C

#### GC/MS VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

#### GC/MS Semi VOA

Method 625.1: The surrogate recovery for the laboratory control sample and laboratory control sample duplicate associated with preparation batch 860-113963 and analytical batch 860-114044 was outside the control limit.

Method 625.1: Six surrogates are used for this analysis. The laboratory's SOP allows one acid and one base of these surrogates to be outside acceptance criteria without performing re-extraction/re-analysis. The following sample contained an allowable number of surrogate compounds outside limits: 4136223 Permit (820-9303-1). These results have been reported and qualified.

Method 625.1: The laboratory control sample (LCS) for preparation batch 860-114275 and analytical batch 860-114367 recovered outside control limits for the following analyte: Benzidine. Benzidine has been identified as a poor performing analyte when analyzed using this method; therefore, re-extraction/re-analysis was not performed. These results have been reported and qualified.

Method 625.1: The RPD of the laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) for preparation batch 860-114275 and analytical batch 860-114367 recovered outside control limits for the following analytes: Benzidine and Pyridine.

Method 625.1: Six surrogates are used for this analysis. The laboratory's SOP allows one acid and one base of these surrogates to be outside acceptance criteria without performing re-extraction/re-analysis. The following sample contained an allowable number of surrogate compounds outside limits: 4136223 Permit (820-9303-1). These results have been reported and qualified.

Method 625.1: The following sample was re-prepared outside of preparation holding time due to QC failed on first extracted: 4136223 Permit (820-9303-1).

Method 625.1: The laboratory control sample and laboratory control sample duplicate (LCS/LCSD) for preparation batch 860-113963 and analytical batch 860-114044 recovered outside control limits for multiple analytes. The associated sample was re-prepared and re-analyzed outside holding time. Both sets of data have been reported.

Method 625.1: The surrogate recovery for the laboratory control sample and laboratory control sample duplicate associated with preparation batch 860-114275 and analytical batch 860-114367 was outside the control limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

#### GC Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

#### Pesticides

Method 608.3 Pest: Surrogate recovery for the following sample was outside the upper control limit: 4136223 Permit (820-9303-1). This sample did not contain any target analytes; therefore, re-extraction and/or re-analysis was not performed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Job ID: 820-9303-1

#### **Case Narrative**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### Job ID: 820-9303-1 (Continued)

#### **Laboratory: Eurofins Lubbock (Continued)**

#### HPLC/IC

Method 300\_ORGFMS: The following sample was diluted to bring the concentration of target analytes within the calibration range: 4136223 Permit (820-9303-1). Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

#### Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

#### **General Chemistry**

Method 2540D: Elevated reporting limits are provided for the following sample(s) due to insufficient sample provided for analysis: 1000mL.

Method 365.1: The matrix spike / matrix spike duplicate (MS/MSD) recoveries for preparation batch 860-113846 and analytical batch 860-114071 were outside control limits for one or more analytes. See QC Sample Results for detail. Sample matrix interference and/or non-homogeneity are suspected because the associated laboratory control sample (LCS) recovery is within acceptance limits.

Method SM5210B\_Calc: The method blank result associated with batch 860-113787 was higher than the method-required limit of 0.2 mg/L.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

#### **Biology**

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

-

4

**5** 

7

8

10

12

13

114

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Method: EPA 624.1 - Volatile Organic Compounds (GC/MS)

Client Sample ID: 4136223 Permit

Date Collected: 07/18/23 09:30 Date Received: 07/18/23 11:50

Lab Sample ID: 820-9303-1

**Matrix: Water** 

Job ID: 820-9303-1

_		 5	

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acrolein	<0.0111	U	0.0500	0.0111	Ü			07/19/23 19:37	1
Acrylonitrile	<0.0143	U	0.0500	0.0143	mg/L			07/19/23 19:37	1
Benzene	<0.000460	U	0.00100	0.000460	mg/L			07/19/23 19:37	1
Bromodichloromethane	<0.000552	U	0.00100	0.000552	mg/L			07/19/23 19:37	1
Bromoform	<0.000633	U	0.00500	0.000633	mg/L			07/19/23 19:37	1
Bromomethane	< 0.00142	U	0.00500	0.00142	mg/L			07/19/23 19:37	1
Carbon tetrachloride	<0.000896	U	0.00500	0.000896	mg/L			07/19/23 19:37	1
Chlorobenzene	<0.000530	U	0.00100	0.000530	mg/L			07/19/23 19:37	1
Chlorodibromomethane	< 0.000547	U	0.00500	0.000547	mg/L			07/19/23 19:37	1
Chloroethane	<0.00198	U	0.0100	0.00198	mg/L			07/19/23 19:37	1
2-Chloroethyl vinyl ether	<0.00252	U	0.00500	0.00252	mg/L			07/19/23 19:37	1
Chloroform	< 0.000643	U	0.00100	0.000643	mg/L			07/19/23 19:37	1
Chloromethane	<0.00204	U	0.0100	0.00204	mg/L			07/19/23 19:37	1
cis-1,3-Dichloropropene	< 0.00107	U	0.00500	0.00107	mg/L			07/19/23 19:37	1
1,2-Dibromoethane	< 0.000999	U	0.00500	0.000999	mg/L			07/19/23 19:37	1
1,1-Dichloroethane	<0.000635	U	0.00100	0.000635	mg/L			07/19/23 19:37	1
1,2-Dichloroethane	<0.000590	U	0.00100	0.000590	mg/L			07/19/23 19:37	1
1,1-Dichloroethene	<0.000738	U	0.00100	0.000738	mg/L			07/19/23 19:37	1
Methylene Chloride	<0.00173	U	0.00500	0.00173	mg/L			07/19/23 19:37	1
1,2-Dichloropropane	< 0.000667	U	0.00500	0.000667	mg/L			07/19/23 19:37	1
1,3-Dichloropropene, Total	<0.00127	U	0.00500	0.00127				07/19/23 19:37	1
Ethylbenzene	<0.000411	U	0.00100	0.000411				07/19/23 19:37	1
Hexachlorobutadiene	<0.00126	U	0.00500	0.00126	_			07/19/23 19:37	1
m-Dichlorobenzene	<0.000513		0.00100	0.000513				07/19/23 19:37	1
Methyl ethyl ketone (MEK)	<0.00828	U	0.0500		mg/L			07/19/23 19:37	1
Naphthalene	<0.00135	U	0.0100	0.00135	_			07/19/23 19:37	1
o-Dichlorobenzene	< 0.000509		0.00100	0.000509				07/19/23 19:37	1
p-Dichlorobenzene	<0.000513	U	0.00100	0.000513				07/19/23 19:37	1
1,1,2,2-Tetrachloroethane	< 0.000470		0.00100	0.000470				07/19/23 19:37	1
Tetrachloroethylene	<0.000801		0.00100	0.000801				07/19/23 19:37	1
Toluene	<0.000475		0.00100	0.000475				07/19/23 19:37	1
trans-1,2-Dichloroethene	< 0.000945		0.00100	0.000945				07/19/23 19:37	1
1,2,4-Trichlorobenzene	<0.00175		0.00500	0.00175				07/19/23 19:37	1
1,1,1-Trichloroethane	<0.00169		0.00500	0.00169				07/19/23 19:37	·
1,1,2-Trichloroethane	<0.000511		0.00100	0.000511				07/19/23 19:37	1
Trichloroethene	<0.000791		0.00500	0.000791	mg/L			07/19/23 19:37	1
Trihalomethanes, Total	<0.000643		0.00500	0.000643				07/19/23 19:37	·
Vinyl chloride	<0.000638		0.00200	0.000638	_			07/19/23 19:37	1
trans-1,3-Dichloropropene	<0.00127		0.00500	0.00127	_			07/19/23 19:37	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		63 - 144			-		07/19/23 19:37	1
4-Bromofluorobenzene (Surr)	103		74 - 124					07/19/23 19:37	1
Dibromofluoromethane (Surr)	101		75 <sub>-</sub> 131					07/19/23 19:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	100		63 - 144	 	07/19/23 19:37	1
4-Bromofluorobenzene (Surr)	103		74 - 124		07/19/23 19:37	1
Dibromofluoromethane (Surr)	101		75 - 131		07/19/23 19:37	1
Toluene-d8 (Surr)	101		80 - 120		07/19/23 19:37	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)										
	Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Acenaphthene	<0.00139	U *-	0.00570	0.00139	mg/L		07/25/23 10:28	07/26/23 00:36	1
	Acenaphthylene	<0.00141	U *-	0.0100	0.00141	mg/L		07/25/23 10:28	07/26/23 00:36	1

**Eurofins Lubbock** 

Page 8 of 59

7/31/2023

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Client Sample ID: 4136223 Permit

Date Collected: 07/18/23 09:30 Date Received: 07/18/23 11:50 Lab Sample ID: 820-9303-1

Matrix: Water

Job ID: 820-9303-1

Analyte	ivesuit	Qualifier	RL	MDL	J	D	Prepared	Analyzed	Dil Fac
Anthracene	<0.00150	U	0.00570	0.00150	mg/L		07/25/23 10:28	07/26/23 00:36	1
Benzidine	<0.00480	U *1	0.0200	0.00480	mg/L		07/25/23 10:28	07/26/23 00:36	1
Benzo[a]anthracene	<0.000173	U	0.00500	0.000173	mg/L		07/25/23 10:28	07/26/23 00:36	1
Benzo[a]pyrene	< 0.000364	U	0.00500	0.000364	mg/L		07/25/23 10:28	07/26/23 00:36	1
3,4-Benzofluoranthene	<0.00204	U	0.0100	0.00204	mg/L		07/25/23 10:28	07/26/23 00:36	1
Benzo[g,h,i]perylene	<0.00268	U	0.0100	0.00268	mg/L		07/25/23 10:28	07/26/23 00:36	1
Benzo[k]fluoranthene	<0.000375	U	0.00500	0.000375	mg/L		07/25/23 10:28	07/26/23 00:36	1
Bis(2-chloroethoxy)methane	<0.00176	U *-	0.0100	0.00176	mg/L		07/25/23 10:28	07/26/23 00:36	1
Bis(2-chloroethyl)ether	<0.00216	U *-	0.0100	0.00216	mg/L		07/25/23 10:28	07/26/23 00:36	1
Bis(2-ethylhexyl) phthalate	<0.000277	U	0.00500	0.000277	mg/L		07/25/23 10:28	07/26/23 00:36	1
4-Bromophenyl phenyl ether	<0.000256	U *-	0.00500	0.000256	mg/L		07/25/23 10:28	07/26/23 00:36	1
Butyl benzyl phthalate	< 0.000337	U	0.00500	0.000337	mg/L		07/25/23 10:28	07/26/23 00:36	1
4-Chloro-3-methylphenol	< 0.00157	U	0.00500	0.00157	mg/L		07/25/23 10:28	07/26/23 00:36	1
2-Chloronaphthalene	<0.000462	U *-	0.00500	0.000462	mg/L		07/25/23 10:28	07/26/23 00:36	1
2-Chlorophenol	< 0.000649	U	0.00500	0.000649	mg/L		07/25/23 10:28	07/26/23 00:36	1
4-Chlorophenyl phenyl ether	<0.00128	U	0.0100	0.00128	mg/L		07/25/23 10:28	07/26/23 00:36	1
Chrysene	<0.000222	U	0.00500	0.000222	mg/L		07/25/23 10:28	07/26/23 00:36	1
Dibenz(a,h)anthracene	<0.000246	U	0.00500	0.000246	mg/L		07/25/23 10:28	07/26/23 00:36	1
3,3'-Dichlorobenzidine	<0.000341	U	0.00500	0.000341	mg/L		07/25/23 10:28	07/26/23 00:36	1
2,4-Dichlorophenol	<0.000314	U *-	0.00500	0.000314			07/25/23 10:28	07/26/23 00:36	1
Diethyl phthalate	< 0.00159	U	0.00500	0.00159	mg/L		07/25/23 10:28	07/26/23 00:36	1
2,4-Dimethylphenol	< 0.000649	U *-	0.00500	0.000649	•		07/25/23 10:28	07/26/23 00:36	1
Dimethyl phthalate	<0.000299	U	0.00250	0.000299			07/25/23 10:28	07/26/23 00:36	
Di-n-butyl phthalate	<0.000252		0.00500	0.000252	•		07/25/23 10:28	07/26/23 00:36	1
4,6-Dinitro-o-cresol	<0.00144		0.0100	0.00144			07/25/23 10:28	07/26/23 00:36	1
2,4-Dinitrophenol	<0.000499	U *1	0.0100	0.000499	mg/L		07/25/23 10:28	07/26/23 00:36	1
2,4-Dinitrotoluene	<0.00131	U	0.0100	0.00131	_		07/25/23 10:28	07/26/23 00:36	1
2,6-Dinitrotoluene	<0.00161	U *-	0.00500	0.00161			07/25/23 10:28	07/26/23 00:36	1
Di-n-octyl phthalate	<0.000373	U	0.00500	0.000373	mg/L		07/25/23 10:28	07/26/23 00:36	
1,2-Diphenylhydrazine	<0.00149		0.0100	0.00149	mg/L		07/25/23 10:28	07/26/23 00:36	1
Fluoranthene	<0.00159		0.00500	0.00159	mg/L		07/25/23 10:28	07/26/23 00:36	1
Fluorene	<0.00163		0.00500	0.00163			07/25/23 10:28	07/26/23 00:36	1
Hexachlorobenzene	<0.000307		0.00500	0.000307	•		07/25/23 10:28	07/26/23 00:36	1
Hexachlorobutadiene	<0.000238		0.00100	0.000238	mg/L		07/25/23 10:28	07/26/23 00:36	1
Hexachlorocyclopentadiene	<0.00458		0.0100	0.00458			07/25/23 10:28	07/26/23 00:36	·
Hexachloroethane	<0.000526		0.00480	0.000526	J		07/25/23 10:28	07/26/23 00:36	1
Indeno[1,2,3-cd]pyrene	<0.00229		0.0100	0.00229	•		07/25/23 10:28	07/26/23 00:36	1
Isophorone	<0.00164		0.00500	0.00164			07/25/23 10:28	07/26/23 00:36	·
m+p-Cresol	<0.00262		0.0100	0.00262	_		07/25/23 10:28	07/26/23 00:36	1
Naphthalene	< 0.000542		0.00250	0.000542	_		07/25/23 10:28	07/26/23 00:36	1
Nitrobenzene	<0.00166		0.00500	0.00166			07/25/23 10:28	07/26/23 00:36	·
4-Nitrophenol	<0.00491		0.00720	0.00491			07/25/23 10:28	07/26/23 00:36	1
2-Nitrophenol	<0.00167		0.0100	0.00167	•		07/25/23 10:28	07/26/23 00:36	1
N-Nitrosodimethylamine	<0.00107		0.0100	0.00202			07/25/23 10:28	07/26/23 00:36	
N-Nitrosodi-n-propylamine	<0.00288		0.0100	0.00202	_		07/25/23 10:28	07/26/23 00:36	1
N-Nitrosodiphenylamine	<0.00288		0.0100	0.00288	•		07/25/23 10:28	07/26/23 00:36	1
o-Cresol	<0.00161		0.0100	0.00161			07/25/23 10:28	07/26/23 00:36	
					_				
2,2'-oxybis[1-chloropropane]	<0.00179		0.0100	0.00179	-		07/25/23 10:28	07/26/23 00:36	1
Pentachlorophenol	<0.000234	U ^-	0.0100	0.000234	mg/L		07/25/23 10:28	07/26/23 00:36	1

Eurofins Lubbock

Page 9 of 59

2

3

5

9

11

12

1 4

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Client Sample ID: 4136223 Permit

Date Collected: 07/18/23 09:30 Date Received: 07/18/23 11:50 Lab Sample ID: 820-9303-1

Matrix: Water

Job ID: 820-9303-1

atrix: Water

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Phenanthrene	<0.00142	U *-	0.0100	0.00142	mg/L		07/25/23 10:28	07/26/23 00:36	1
Phenol	<0.000423	U *-	0.00450	0.000423	mg/L		07/25/23 10:28	07/26/23 00:36	1
Pyrene	<0.000178	U	0.00500	0.000178	mg/L		07/25/23 10:28	07/26/23 00:36	1
1,2,4,5-Tetrachlorobenzene	<0.00132	U	0.0100	0.00132	mg/L		07/25/23 10:28	07/26/23 00:36	1
1,2,4-Trichlorobenzene	<0.00161	U *-	0.00500	0.00161	mg/L		07/25/23 10:28	07/26/23 00:36	1
2,4,6-Trichlorophenol	< 0.00142	U *-	0.00500	0.00142	mg/L		07/25/23 10:28	07/26/23 00:36	1
2,4,5-Trichlorophenol	<0.00200	U	0.0100	0.00200	mg/L		07/25/23 10:28	07/26/23 00:36	1
Pyridine	<0.00264	U	0.0100	0.00264	mg/L		07/25/23 10:28	07/26/23 00:36	1
Pentachlorobenzene	< 0.00107	U	0.0100	0.00107	mg/L		07/25/23 10:28	07/26/23 00:36	1
Hexachlorophene	<0.0100	U	0.100	0.0100	mg/L		07/25/23 10:28	07/26/23 00:36	1
N-Nitrosodi-n-butylamine	<0.00149	U	0.0100	0.00149	mg/L		07/25/23 10:28	07/26/23 00:36	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2-Fluorobiphenyl (Surr)	51		29 - 112				07/25/23 10:28	07/26/23 00:36	1
2-Fluorophenol (Surr)	21	S1-	28 - 114				07/25/23 10:28	07/26/23 00:36	1
Nitrobenzene-d5 (Surr)	43		15 - 314				07/25/23 10:28	07/26/23 00:36	1
Phenol-d5 (Surr)	13		8 - 424				07/25/23 10:28	07/26/23 00:36	1
p-Terphenyl-d14 (Surr)	67		20 - 141				07/25/23 10:28	07/26/23 00:36	1
2,4,6-Tribromophenol (Surr)	43		31 - 132				07/25/23 10:28	07/26/23 00:36	1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Aldrin	<0.00000113	U	0.0000100	0.00000113	mg/L		07/20/23 07:48	07/20/23 15:28	1
alpha-BHC	<0.0000142	U	0.0000090	0.0000014	mg/L		07/20/23 07:48	07/20/23 15:28	1
			0	2					
beta-BHC	<0.00000389	U	0.0000180	0.0000038	mg/L		07/20/23 07:48	07/20/23 15:28	1
delta-BHC	<0.00000245	U	0.000250	0.0000024	mg/L		07/20/23 07:48	07/20/23 15:28	1
				5					
gamma-BHC (Lindane)	<0.00000299	U	0.0000100	0.0000029	mg/L		07/20/23 07:48	07/20/23 15:28	1
4,4'-DDD	<0.0000081	U	0.0000100	9 0.0000008	ma/l		07/20/23 07:48	07/20/23 15:28	1
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	4	·	0.0000.00	14	9/ =		01/20/20 01110	0.720720 .0.20	
4,4'-DDE	<0.00000109	U	0.0000100	0.0000010	mg/L		07/20/23 07:48	07/20/23 15:28	1
				9					
4,4'-DDT	<0.00000379	U	0.0000200	0.0000037	mg/L		07/20/23 07:48	07/20/23 15:28	1
Dieldrin	<0.0000095	U	0.0000100	0.0000009	mg/L		07/20/23 07:48	07/20/23 15:28	1
	3			53					
Endosulfan I	<0.00000107	U	0.0000100	0.0000010	mg/L		07/20/23 07:48	07/20/23 15:28	1
				7	_				
Endosulfan II	<0.00000122	U	0.0000100	0.0000012	mg/L		07/20/23 07:48	07/20/23 15:28	1
Endosulfan sulfate	<0.00000112	U	0.0000100	0.00000112	mg/L		07/20/23 07:48	07/20/23 15:28	1
Endrin	<0.0000156	U	0.0000100	0.0000015	mg/L		07/20/23 07:48	07/20/23 15:28	1
				6					
Endrin aldehyde	<0.00000118	U	0.0000100	0.00000118	mg/L		07/20/23 07:48	07/20/23 15:28	1
Heptachlor	<0.00000446	U	0.0000090	0.0000044	mg/L		07/20/23 07:48	07/20/23 15:28	1
			0	6	<u>.</u>				
Heptachlor epoxide	<0.00000134	U	0.0000100	0.0000013	mg/L		07/20/23 07:48	07/20/23 15:28	1
Toxaphene	<0.0000769	U	0.000200	0.0000769	mg/L		07/20/23 07:48	07/20/23 15:28	1
Chlordane	<0.000103	U	0.000250	0.000103	mg/L		07/20/23 07:48	07/20/23 15:28	1

Eurofins Lubbock

3

5

0

10

11

13

14

c . . . . .

Job ID: 820-9303-1

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Client Sample ID: 4136223 Permit

Date Collected: 07/18/23 09:30 Date Received: 07/18/23 11:50

Lab Sample ID: 820-9303-1

**Matrix: Water** 

	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fa
DCB Decachlorobiphenyl (Surr)	164	S1+	15 - 136				07/20/23 07:48	07/20/23 15:28	
Tetrachloro-m-xylene (Surr)	107		18 - 126				07/20/23 07:48	07/20/23 15:28	
Method: EPA 608.3 - Polychlor	inated Biphenyls	(PCBs) (GC)							
Analyte		Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fa
PCB-1016	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:59	
PCB-1221	< 0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:59	
PCB-1232	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:59	
PCB-1242	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:59	
PCB-1248	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:59	
PCB-1254	<0.00000780	U	0.000100	0.0000078	mg/L		07/20/23 07:48	07/20/23 13:59	
PCB-1260	<0.0000780	U	0.000100	0.0000078	mg/L		07/20/23 07:48	07/20/23 13:59	
Polychlorinated biphenyls, Total	<0.000100	U	0.000100	0.000100	mg/L		07/20/23 07:48	07/20/23 13:59	
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fa
Tetrachloro-m-xylene (Surr)	87		18 - 126				07/20/23 07:48	07/20/23 13:59	
DCB Decachlorobiphenyl (Surr)	107		15 - 136				07/20/23 07:48	07/20/23 13:59	
Method: EPA-01 615 - Herbicid	• •								
Analyte		Qualifier	RL	MDL		D	Prepared	Analyzed	Dil Fa
Hexachlorophene	<0.000811		0.00502	0.000811	mg/L		07/23/23 19:55	07/27/23 19:12	
Silvex (2,4,5-TP)	<0.0000424	U	0.000201	0.0000424	mg/L		07/23/23 19:55	07/26/23 19:41	
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fa
2,4-Dichlorophenylacetic acid	119		45 - 150				07/23/23 19:55	07/26/23 19:41	
2,4-Dichlorophenylacetic acid	125		45 - 150				07/23/23 19:55	07/27/23 19:12	
Method: EPA 300.0 - Anions, Ic Analyte	• •	•	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fa
Analyte	Result	Qualifier	RL 0.500		Unit mg/L	<u>D</u>	Prepared	<b>Analyzed</b> 07/19/23 19:25	
Analyte Chloride	Result 391	•	0.500	0.250	mg/L	<u>D</u>	Prepared	Analyzed 07/19/23 19:25 07/19/23 19:25	
Analyte Chloride Fluoride	Result 391 0.931	Qualifier	0.500 0.500	0.250 0.100	mg/L mg/L	<u>D</u>	Prepared	07/19/23 19:25 07/19/23 19:25	
Analyte Chloride	Result 391	Qualifier	0.500	0.250 0.100 0.0293	mg/L	<u>D</u>	Prepared	07/19/23 19:25	
Analyte Chloride Fluoride Nitrite as N	Result 391 0.931 <0.0293	Qualifier	0.500 0.500 0.100	0.250 0.100 0.0293	mg/L mg/L mg/L	<u>D</u>	Prepared	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate	Result	Qualifier	0.500 0.500 0.100	0.250 0.100 0.0293	mg/L mg/L mg/L mg/L	<u>D</u>	Prepared Prepared	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25	
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Ic	Result	Qualifier  U  Chy - DL	0.500 0.500 0.100 0.500	0.250 0.100 0.0293 0.200	mg/L mg/L mg/L mg/L			07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Io Analyte	Result	Qualifier  U  Chy - DL	0.500 0.500 0.100 0.500	0.250 0.100 0.0293 0.200	mg/L mg/L mg/L mg/L  mg/L			07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 Analyzed	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Io Analyte Nitrate as N	Result 391 0.931 <0.0293 197 on Chromatograp Result 20.8 20.8	Qualifier  U  hy - DL  Qualifier	0.500 0.500 0.100 0.500 RL 1.00	0.250 0.100 0.0293 0.200 MDL 0.391	mg/L mg/L mg/L mg/L  mg/L			07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 Analyzed 07/19/23 19:33	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Io Analyte Nitrate as N Nitrate Nitrite as N	Result 391 0.931 <0.0293 197 on Chromatograp Result 20.8 20.8 ate and Urea Pes	Qualifier  U  hy - DL  Qualifier	0.500 0.500 0.100 0.500 RL 1.00	0.250 0.100 0.0293 0.200 MDL 0.391 0.391	mg/L mg/L mg/L mg/L  mg/L			07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 Analyzed 07/19/23 19:33	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Ic Analyte Nitrate as N Nitrate Nitrite as N Method: EPA-01 632 - Carbama Analyte	Result 391 0.931 <0.0293 197 on Chromatograp Result 20.8 20.8 ate and Urea Pes	Qualifier  U  hy - DL  Qualifier  ticides (HPLC)  Qualifier	0.500 0.500 0.100 0.500 RL 1.00 1.00	0.250 0.100 0.0293 0.200 MDL 0.391 0.391	mg/L mg/L mg/L mg/L  Unit mg/L mg/L	<u>D</u>	Prepared	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 Analyzed 07/19/23 19:33 07/19/23 19:33	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Ic Analyte Nitrate as N Nitrate Nitrite as N Method: EPA-01 632 - Carbama	Result	Qualifier  U  hy - DL  Qualifier  ticides (HPLC)  Qualifier	0.500 0.500 0.100 0.500 RL 1.00 1.00	0.250 0.100 0.0293 0.200 MDL 0.391 0.391	mg/L mg/L mg/L mg/L  Unit mg/L mg/L  Unit ug/L	<u>D</u>	Prepared	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 Analyzed 07/19/23 19:33 07/19/23 19:33	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Io Analyte Nitrate as N Nitrate Nitrite as N Method: EPA-01 632 - Carbama Analyte Carbaryl Diuron Method: EPA 200.8 - Metals (IC	Result	Qualifier  U  Chy - DL  Qualifier  ticides (HPLC  Qualifier  U  coverable	0.500 0.500 0.100 0.500  RL 1.00 1.00  \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$	0.250 0.100 0.0293 0.200 MDL 0.391 0.391 MDL 1.85 0.0514	mg/L mg/L mg/L  Unit mg/L mg/L  Unit ug/L  ug/L	D_	Prepared  Prepared  07/22/23 06:44	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25  Analyzed 07/19/23 19:33 07/19/23 19:33  Analyzed 07/26/23 08:09 07/26/23 08:09	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Ic Analyte Nitrate as N Nitrate Nitrite as N Method: EPA-01 632 - Carbama Analyte Carbaryl Diuron	Result	Qualifier  U  Ohy - DL  Qualifier  ticides (HPLC  Qualifier  U	0.500 0.500 0.100 0.500  RL 1.00 1.00  5.00 0.0900	0.250 0.100 0.0293 0.200  MDL 0.391 0.391  MDL 1.85 0.0514	mg/L mg/L mg/L  Unit mg/L  Unit ug/L  Unit	<u>D</u>	Prepared  07/22/23 06:44 07/22/23 06:44  Prepared	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25  Analyzed 07/19/23 19:33 07/19/23 19:33  Analyzed 07/26/23 08:09 07/26/23 08:09  Analyzed	Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Io Analyte Nitrate as N Nitrate Nitrite as N Method: EPA-01 632 - Carbama Analyte Carbaryl Diuron Method: EPA 200.8 - Metals (IC	Result	Qualifier  U  Chy - DL  Qualifier  ticides (HPLC  Qualifier  U  coverable	0.500 0.500 0.100 0.500  RL 1.00 1.00  \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$\$	0.250 0.100 0.0293 0.200  MDL 0.391 0.391  MDL 1.85 0.0514  MDL 0.00301	mg/L mg/L mg/L  Unit mg/L  Unit ug/L  Unit ug/L  Unit ug/L	D_	Prepared  07/22/23 06:44 07/22/23 06:44	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25  Analyzed 07/19/23 19:33 07/19/23 19:33  Analyzed 07/26/23 08:09 07/26/23 08:09	Dil Fa  Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate Method: EPA 300.0 - Anions, Ic Analyte Nitrate as N Nitrate Nitrite as N Method: EPA-01 632 - Carbama Analyte Carbaryl Diuron Method: EPA 200.8 - Metals (IC Analyte	Result	Qualifier  U  Chy - DL  Qualifier  ticides (HPLC  Qualifier  U  Coverable  Qualifier	0.500 0.500 0.100 0.500  RL 1.00 1.00  5.00 0.0900	0.250 0.100 0.0293 0.200  MDL 0.391 0.391  MDL 1.85 0.0514  MDL 0.00301 0.00105	mg/L mg/L mg/L  Unit mg/L mg/L  Unit ug/L  Unit ug/L  Unit ug/L	D_	Prepared  07/22/23 06:44 07/22/23 06:44  Prepared	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25  Analyzed 07/19/23 19:33 07/19/23 19:33  Analyzed 07/26/23 08:09 07/26/23 08:09  Analyzed	Dil Fa  1  Dil Fa  Dil Fa
Analyte Chloride Fluoride Nitrite as N Sulfate  Method: EPA 300.0 - Anions, Ic Analyte Nitrate as N Nitrate Nitrite as N  Method: EPA-01 632 - Carbama Analyte Carbaryl Diuron  Method: EPA 200.8 - Metals (IC Analyte Aluminum	Result	Qualifier  U  Chy - DL  Qualifier  ticides (HPLC  Qualifier  U  Coverable  Qualifier	0.500 0.500 0.100 0.500  RL 1.00 1.00  St. 5.00 0.0900  RL 0.0200	0.250 0.100 0.0293 0.200  MDL 0.391 0.391  MDL 1.85 0.0514  MDL 0.00301	mg/L mg/L mg/L  Unit mg/L mg/L  Unit ug/L  Unit ug/L  Unit ug/L	D_	Prepared  07/22/23 06:44  07/22/23 06:44  Prepared  07/21/23 20:53	07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25 07/19/23 19:25  Analyzed 07/19/23 19:33 07/19/23 19:33  Analyzed 07/26/23 08:09 07/26/23 08:09  Analyzed 07/22/23 23:57	Dil Fa  Dil Fa

Eurofins Lubbock

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Client Sample ID: 4136223 Permit

Date Collected: 07/18/23 09:30

Date Received: 07/18/23 11:50

Lab Sample ID: 820-9303-1

**Matrix: Water** 

Job ID: 820-9303-1

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Beryllium	<0.000148	U	0.00200	0.000148	mg/L		07/21/23 20:53	07/22/23 23:57	1
Cadmium	<0.0000850	U	0.00200	0.0000850	mg/L		07/21/23 20:53	07/22/23 23:57	1
Chromium	0.000392	J	0.00400	0.000325	mg/L		07/21/23 20:53	07/22/23 23:57	1
Copper	0.00547		0.00400	0.000690	mg/L		07/21/23 20:53	07/22/23 23:57	1
Lead	0.000537	J	0.00200	0.000140	mg/L		07/21/23 20:53	07/22/23 23:57	1
Nickel	0.00170	J	0.00200	0.000486	mg/L		07/21/23 20:53	07/22/23 23:57	1
Selenium	<0.000685	U	0.00200	0.000685	mg/L		07/21/23 20:53	07/22/23 23:57	1
Silver	<0.000118	U	0.00200	0.000118	mg/L		07/21/23 20:53	07/22/23 23:57	1
Thallium	<0.0000960	U	0.00200	0.0000960	mg/L		07/21/23 20:53	07/22/23 23:57	1
Zinc	0.0683		0.00400	0.000885	mg/L		07/21/23 20:53	07/22/23 23:57	1

Welliou. LFA 243.1 - Welculy (CVA	<b>~</b> )								
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.0000525	U	0.000200	0.0000525	mg/L		07/24/23 20:20	07/25/23 16:30	•

							•	•	
Mercury	<0.0000525	U	0.000200	0.0000525	mg/L		07/24/23 20:20	07/25/23 16:30	1
General Chemistry									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HEM (Oil & Grease) (1664B)	<1.57	U	5.00	1.57	mg/L			07/24/23 09:53	1
Cyanide, Total (EPA 335.4)	0.00213	J	0.00500	0.00200	mg/L		07/21/23 11:49	07/21/23 20:22	1
Ammonia (EPA 350.1)	< 0.0345	U	0.100	0.0345	mg/L			07/19/23 23:41	1
Nitrogen, Kjeldahl (EPA 351.2)	0.632		0.200	0.0890	mg/L		07/24/23 16:54	07/25/23 15:28	1
Oxygen, Dissolved (EPA 360.1)	9.65	HF	1.00	1.00	mg/L			07/25/23 10:59	1
Total Phosphorus as P (EPA 365.1)	2.97		0.0612	0.0293	mg/L		07/24/23 18:08	07/25/23 16:13	3.06
Total Phosphorus as PO4 (EPA	9.11		0.188	0.0900	mg/L		07/24/23 18:08	07/25/23 16:13	3.06
365.1)									
Chemical Oxygen Demand (Hach 8000)	27.0		20.0	3.36	mg/L			07/25/23 10:00	1
Nitrogen, Organic (EPA Nitrogen,Org)	0.632		0.200	0.0614	mg/L			07/26/23 10:27	1
Alkalinity (SM 2320B)	1360		4.00	4.00	mg/L			07/20/23 12:24	1
Bicarbonate Alkalinity as CaCO3 (SM 2320B)	<4.00	U	4.00	4.00	mg/L			07/20/23 12:24	1
Carbonate Alkalinity as CaCO3 (SM 2320B)	822		4.00	4.00	mg/L			07/20/23 12:24	1
Specific Conductance (SM 2510B)	2080		10.0	10.0	umho/cm @ 25C			07/21/23 12:01	1
Total Dissolved Solids (SM 2540C)	1170		20.0	20.0	mg/L			07/23/23 09:45	1
Total Suspended Solids (SM 2540D)	<8.00	U	8.00	8.00	mg/L			07/25/23 10:18	1
Cr (III) (SM 3500 CR B)	<0.00200	U	0.0100	0.00200	mg/L			07/25/23 15:38	1
Chlorine, Total Residual (SM 4500 Cl G)	<0.0500	U HF	0.0500	0.0500	mg/L			07/24/23 13:42	1
pH (SM 4500 H+ B)	7.8	HF			SU			07/20/23 17:46	1
Temperature (SM 4500 H+ B)	22.2	HF			Degrees C			07/20/23 17:46	1
Sulfide (SM 4500 S2 D)	<0.0400	U	0.100	0.0400	mg/L			07/25/23 15:32	1
Biochemical Oxygen Demand (SM 5210B)	<2.14	U	2.14	2.14	mg/L		07/19/23 13:00	07/19/23 15:23	1
Total Organic Carbon (SM 5310C)	1.35		1.00	0.500	mg/L			07/24/23 12:20	1
Chromium, hexavalent (SM3500 CR B)	<0.00200	U	0.0100	0.00200	mg/L			07/19/23 13:37	1
Carbonaceous Biochemical Oxygen	<2.14	U	2.14	2.14	mg/L		07/19/23 16:08	07/19/23 18:22	1
Demand (SM5210B CBOD)									
Nitrogen, Total (EPA Total Nitrogen)	21.4		0.200	0.0614	mg/L			07/30/23 15:28	1

Eurofins Lubbock

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Lab Sample ID: 820-9303-1

Matrix: Water

Job ID: 820-9303-1

Client Sample ID: 4136223 Permit Date Collected: 07/18/23 09:30

Date Received: 07/18/23 11:50

Method: SM 9223B - Coliforms, To	otal, and E.Co	II (Colilert - Q	uanti Tray)						
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Coliform, Total	11		1.0	1.0	MPN/100mL			07/18/23 16:14	1
Escherichia coli	1.0		1.0	1.0	MPN/100mL			07/18/23 16:14	1

Method: 624.1 - Volatile Organic Compounds (GC/MS)

Matrix: Water Prep Type: Total/NA

				Percent Su	rrogate Rec
		DCA	BFB	DBFM	TOL
Lab Sample ID	Client Sample ID	(63-144)	(74-124)	(75-131)	(80-120)
820-9303-1	4136223 Permit	100	103	101	101
LCS 860-112934/14	Lab Control Sample	96	99	101	100
LCSD 860-112934/15	Lab Control Sample Dup	98	102	100	101
MB 860-112934/21	Method Blank	101	103	103	100

**Surrogate Legend** 

DCA = 1,2-Dichloroethane-d4 (Surr)

BFB = 4-Bromofluorobenzene (Surr)

DBFM = Dibromofluoromethane (Surr)

TOL = Toluene-d8 (Surr)

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water Prep Type: Total/NA

_				Percent Sur	rogate Reco	very (Accepta	ance Limits)
		FBP	2FP	NBZ	PHL	TPHd14	TBP
Lab Sample ID	Client Sample ID	(29-112)	(28-114)	(15-314)	(8-424)	(20-141)	(31-132)
820-9303-1	4136223 Permit	51	21 S1-	43	13	67	43
LCS 860-113963/2-A	Lab Control Sample	51	19 S1-	46	12	75	58
LCSD 860-113963/3-A	Lab Control Sample Dup	53	19 S1-	47	13	83	67
MB 860-113963/1-A	Method Blank	74	30	68	17	79	49

#### **Surrogate Legend**

FBP = 2-Fluorobiphenyl (Surr)

2FP = 2-Fluorophenol (Surr)

NBZ = Nitrobenzene-d5 (Surr)

PHL = Phenol-d5 (Surr)

TPHd14 = p-Terphenyl-d14 (Surr)

TBP = 2,4,6-Tribromophenol (Surr)

Method: 608.3 - Organochlorine Pesticides in Water

**Matrix: Water** Prep Type: Total/NA

				Percent Surrogate Recovery (Acceptance Limits)
		DCB1	TCX1	
Lab Sample ID	Client Sample ID	(15-136)	(18-126)	
820-9303-1	4136223 Permit	164 S1+	107	
LCS 860-113167/2-A	Lab Control Sample	131	101	
LCSD 860-113167/3-A	Lab Control Sample Dup	121	94	
MB 860-113167/1-A	Method Blank	128	98	

Surrogate Legend

DCB = DCB Decachlorobiphenyl (Surr)

TCX = Tetrachloro-m-xylene (Surr)

Method: 608.3 - Polychlorinated Biphenyls (PCBs) (GC)

**Matrix: Water** Prep Type: Total/NA

				Percent Surrogate Recovery (Acceptance Limits)
		TCX1	DCB1	
Lab Sample ID	Client Sample ID	(18-126)	(15-136)	
820-9303-1	4136223 Permit	87	107	

**Eurofins Lubbock** 

Page 14 of 59

7/31/2023

### **Surrogate Summary**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Method: 608.3 - Polychlorinated Biphenyls (PCBs) (GC) (Continued)

Matrix: Water Prep Type: Total/NA

				Percent Surrogate Recovery (Acceptance Limits)
		TCX1	DCB1	
_ab Sample ID	Client Sample ID	(18-126)	(15-136)	
LCS 860-113167/4-A	Lab Control Sample	84	125	
LCSD 860-113167/5-A	Lab Control Sample Dup	82	115	
MB 860-113167/1-A	Method Blank	80	121	

TCX = Tetrachloro-m-xylene (Surr)

DCB = DCB Decachlorobiphenyl (Surr)

Method: 615 - Herbicides (GC)

**Matrix: Water** Prep Type: Total/NA

		DCPAA1	
Lab Sample ID	Client Sample ID	(45-150)	
820-9303-1	4136223 Permit	119	
820-9303-1	4136223 Permit	125	
LCS 860-113651/2-A	Lab Control Sample	130	
LCS 860-113651/4-A	Lab Control Sample	128	
LCSD 860-113651/3-A	Lab Control Sample Dup	111	
LCSD 860-113651/5-A	Lab Control Sample Dup	112	
MB 860-113651/1-A	Method Blank	118	

Surrogate Legend

DCPAA = 2,4-Dichlorophenylacetic acid

Job ID: 820-9303-1

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

### Method: 624.1 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 860-112934/21

**Matrix: Water** 

Analysis Batch: 112934

**Client Sample ID: Method Blank** 

**Prep Type: Total/NA** 

	MB	MB							
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acrolein	<0.0111	U	0.0500	0.0111	mg/L			07/19/23 14:08	1
Acrylonitrile	<0.0143	U	0.0500	0.0143	mg/L			07/19/23 14:08	1
Benzene	<0.000460	U	0.00100	0.000460	mg/L			07/19/23 14:08	1
Bromodichloromethane	<0.000552	U	0.00100	0.000552	mg/L			07/19/23 14:08	1
Bromoform	<0.000633	U	0.00500	0.000633	mg/L			07/19/23 14:08	1
Bromomethane	<0.00142	U	0.00500	0.00142	mg/L			07/19/23 14:08	1
Carbon tetrachloride	<0.000896	U	0.00500	0.000896	mg/L			07/19/23 14:08	1
Chlorobenzene	<0.000530	U	0.00100	0.000530	mg/L			07/19/23 14:08	1
Chlorodibromomethane	<0.000547	U	0.00500	0.000547	mg/L			07/19/23 14:08	1
Chloroethane	<0.00198	U	0.0100	0.00198	mg/L			07/19/23 14:08	1
2-Chloroethyl vinyl ether	<0.00252	U	0.00500	0.00252	mg/L			07/19/23 14:08	1
Chloroform	< 0.000643	U	0.00100	0.000643	mg/L			07/19/23 14:08	1
Chloromethane	<0.00204	U	0.0100	0.00204	mg/L			07/19/23 14:08	1
cis-1,3-Dichloropropene	<0.00107	U	0.00500	0.00107	mg/L			07/19/23 14:08	1
1,2-Dibromoethane	<0.000999	U	0.00500	0.000999	mg/L			07/19/23 14:08	1
1,1-Dichloroethane	<0.000635	U	0.00100	0.000635	mg/L			07/19/23 14:08	1
1,2-Dichloroethane	< 0.000590	U	0.00100	0.000590	mg/L			07/19/23 14:08	1
1,1-Dichloroethene	<0.000738	U	0.00100	0.000738	mg/L			07/19/23 14:08	1
Methylene Chloride	<0.00173	U	0.00500	0.00173	mg/L			07/19/23 14:08	1
1,2-Dichloropropane	< 0.000667	U	0.00500	0.000667	mg/L			07/19/23 14:08	1
1,3-Dichloropropene, Total	< 0.00127	U	0.00500	0.00127	mg/L			07/19/23 14:08	1
Ethylbenzene	<0.000411	U	0.00100	0.000411	mg/L			07/19/23 14:08	1
Hexachlorobutadiene	<0.00126	U	0.00500	0.00126	mg/L			07/19/23 14:08	1
m-Dichlorobenzene	< 0.000513	U	0.00100	0.000513	mg/L			07/19/23 14:08	1
Methyl ethyl ketone (MEK)	<0.00828	U	0.0500	0.00828	mg/L			07/19/23 14:08	1
Naphthalene	< 0.00135	U	0.0100	0.00135	mg/L			07/19/23 14:08	1
o-Dichlorobenzene	< 0.000509	U	0.00100	0.000509	mg/L			07/19/23 14:08	1
p-Dichlorobenzene	<0.000513	U	0.00100	0.000513	mg/L			07/19/23 14:08	1
1,1,2,2-Tetrachloroethane	<0.000470	U	0.00100	0.000470	mg/L			07/19/23 14:08	1
Tetrachloroethylene	<0.000801	U	0.00100	0.000801	mg/L			07/19/23 14:08	1
Toluene	<0.000475	U	0.00100	0.000475	mg/L			07/19/23 14:08	1
trans-1,2-Dichloroethene	< 0.000945	U	0.00100	0.000945	mg/L			07/19/23 14:08	1
1,2,4-Trichlorobenzene	<0.00175	U	0.00500	0.00175	mg/L			07/19/23 14:08	1
1,1,1-Trichloroethane	<0.00169	U	0.00500	0.00169	mg/L			07/19/23 14:08	1
1,1,2-Trichloroethane	<0.000511	U	0.00100	0.000511	mg/L			07/19/23 14:08	1
Trichloroethene	<0.000791	U	0.00500	0.000791	mg/L			07/19/23 14:08	1
Trihalomethanes, Total	<0.000643	U	0.00500	0.000643	mg/L			07/19/23 14:08	1
Vinyl chloride	<0.000638	U	0.00200	0.000638	mg/L			07/19/23 14:08	1
trans-1,3-Dichloropropene	< 0.00127	U	0.00500	0.00127	ma/l			07/19/23 14:08	1

ИΒ	MΒ

Surrogate	%Recovery	Qualifier	Limits	Prepare	ed Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		63 - 144		07/19/23 14:08	1
4-Bromofluorobenzene (Surr)	103		74 - 124		07/19/23 14:08	1
Dibromofluoromethane (Surr)	103		75 - 131		07/19/23 14:08	1
Toluene-d8 (Surr)	100		80 - 120		07/19/23 14:08	1

**Eurofins Lubbock** 

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

### Method: 624.1 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-112934/14

**Matrix: Water** 

Analysis Batch: 112934

**Client Sample ID: Lab Control Sample** 

**Prep Type: Total/NA** 

	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Acrolein	0.250	0.2751		mg/L		110	60 - 140	
Acrylonitrile	0.500	0.5030		mg/L		101	60 - 140	
Benzene	0.0500	0.05599		mg/L		112	75 - 125	
Bromodichloromethane	0.0500	0.05661		mg/L		113	75 - 125	
Bromoform	0.0500	0.05774		mg/L		115	70 - 130	
Bromomethane	0.0500	0.05168		mg/L		103	60 - 140	
Carbon tetrachloride	0.0500	0.05448		mg/L		109	70 - 130	
Chlorobenzene	0.0500	0.05614		mg/L		112	65 - 135	
Chlorodibromomethane	0.0500	0.05731		mg/L		115	73 - 125	
Chloroethane	0.0500	0.06200		mg/L		124	60 - 140	
2-Chloroethyl vinyl ether	0.0500	0.05912		mg/L		118	50 - 150	
Chloroform	0.0500	0.05916		mg/L		118	70 - 121	
Chloromethane	0.0500	0.04988		mg/L		100	60 - 140	
cis-1,3-Dichloropropene	0.0500	0.05750		mg/L		115	74 - 125	
1,2-Dibromoethane	0.0500	0.05796		mg/L		116	73 - 125	
1,1-Dichloroethane	0.0500	0.05775		mg/L		115	70 - 130	
1,2-Dichloroethane	0.0500	0.05685		mg/L		114	72 - 130	
1,1-Dichloroethene	0.0500	0.05422		mg/L		108	50 - 150	
Methylene Chloride	0.0500	0.04168		mg/L		83	71 - 125	
1,2-Dichloropropane	0.0500	0.05751		mg/L		115	74 - 125	
Ethylbenzene	0.0500	0.05613		mg/L		112	75 - 125	
Hexachlorobutadiene	0.0500	0.05508		mg/L		110	75 - 125	
m-Dichlorobenzene	0.0500	0.05532		mg/L		111	75 - 125	
Methyl ethyl ketone (MEK)	0.250	0.2872		mg/L		115	60 - 140	
Naphthalene	0.0500	0.05804		mg/L		116	70 - 130	
o-Dichlorobenzene	0.0500	0.05565		mg/L		111	75 - 125	
p-Dichlorobenzene	0.0500	0.05539		mg/L		111	75 - 125	
1,1,2,2-Tetrachloroethane	0.0500	0.05442		mg/L		109	74 - 125	
Tetrachloroethylene	0.0500	0.04857		mg/L		97	71 <sub>-</sub> 125	
Toluene	0.0500	0.05592		mg/L		112	70 - 130	
trans-1,2-Dichloroethene	0.0500	0.04781		mg/L		96	75 _ 125	
1,2,4-Trichlorobenzene	0.0500	0.05745		mg/L		115	75 - 135	
1,1,1-Trichloroethane	0.0500	0.05736		mg/L		115	70 - 130	
1,1,2-Trichloroethane	0.0500	0.05644		mg/L		113	70 - 130	
Trichloroethene	0.0500	0.05559		mg/L		111	75 _ 135	
Vinyl chloride	0.0500	0.05667		mg/L		113	60 - 140	

;
;

Surrogate	%Recovery	Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	96		63 - 144
4-Bromofluorobenzene (Surr)	99		74 - 124
Dibromofluoromethane (Surr)	101		75 - 131
Toluene-d8 (Surr)	100		80 - 120

**Eurofins Lubbock** 

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

### Method: 624.1 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 860-112934/15

**Matrix: Water** 

Analysis Batch: 112934

Client Sample ID: Lab Control Sample Dup

**Prep Type: Total/NA** 

	Spike	LCSD	LCSD	CSD			%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Acrolein	0.250	0.2271		mg/L		91	60 - 140	19	25
Acrylonitrile	0.500	0.4597		mg/L		92	60 - 140	9	25
Benzene	0.0500	0.04972		mg/L		99	75 - 125	12	25
Bromodichloromethane	0.0500	0.05011		mg/L		100	75 - 125	12	25
Bromoform	0.0500	0.05230		mg/L		105	70 - 130	10	25
Bromomethane	0.0500	0.04491		mg/L		90	60 - 140	14	25
Carbon tetrachloride	0.0500	0.04789		mg/L		96	70 - 130	13	25
Chlorobenzene	0.0500	0.04945		mg/L		99	65 - 135	13	25
Chlorodibromomethane	0.0500	0.05106		mg/L		102	73 - 125	12	25
Chloroethane	0.0500	0.04979		mg/L		100	60 - 140	22	25
2-Chloroethyl vinyl ether	0.0500	0.05342		mg/L		107	50 - 150	10	25
Chloroform	0.0500	0.05157		mg/L		103	70 - 121	14	25
Chloromethane	0.0500	0.05329		mg/L		107	60 - 140	7	25
cis-1,3-Dichloropropene	0.0500	0.05081		mg/L		102	74 - 125	12	25
1,2-Dibromoethane	0.0500	0.05263		mg/L		105	73 - 125	10	25
1,1-Dichloroethane	0.0500	0.05205		mg/L		104	70 - 130	10	25
1,2-Dichloroethane	0.0500	0.05099		mg/L		102	72 - 130	11	25
1,1-Dichloroethene	0.0500	0.04238		mg/L		85	50 - 150	25	25
Methylene Chloride	0.0500	0.04016		mg/L		80	71 - 125	4	25
1,2-Dichloropropane	0.0500	0.05043		mg/L		101	74 - 125	13	25
Ethylbenzene	0.0500	0.04929		mg/L		99	75 - 125	13	25
Hexachlorobutadiene	0.0500	0.05100		mg/L		102	75 - 125	8	25
m-Dichlorobenzene	0.0500	0.05076		mg/L		102	75 - 125	9	25
Methyl ethyl ketone (MEK)	0.250	0.2621		mg/L		105	60 - 140	9	25
Naphthalene	0.0500	0.05437		mg/L		109	70 - 130	7	25
o-Dichlorobenzene	0.0500	0.05075		mg/L		101	75 - 125	9	25
p-Dichlorobenzene	0.0500	0.05061		mg/L		101	75 - 125	9	25
1,1,2,2-Tetrachloroethane	0.0500	0.05122		mg/L		102	74 - 125	6	25
Tetrachloroethylene	0.0500	0.04283		mg/L		86	71 - 125	13	25
Toluene	0.0500	0.04893		mg/L		98	70 - 130	13	25
trans-1,2-Dichloroethene	0.0500	0.04194		mg/L		84	75 - 125	13	25
1,2,4-Trichlorobenzene	0.0500	0.05280		mg/L		106	75 - 135	8	25
1,1,1-Trichloroethane	0.0500	0.04977		mg/L		100	70 - 130	14	25
1,1,2-Trichloroethane	0.0500	0.05104		mg/L		102	70 - 130	10	25
Trichloroethene	0.0500	0.04916		mg/L		98	75 - 135	12	25
Vinyl chloride	0.0500	0.05143		mg/L		103	60 - 140	10	25
trans-1,3-Dichloropropene	0.0500	0.05207		mg/L		104	66 - 125	11	25

Surrogate	%Recovery	Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	98		63 - 144
4-Bromofluorobenzene (Surr)	102		74 - 124
Dibromofluoromethane (Surr)	100		75 - 131
Toluene-d8 (Surr)	101		80 - 120

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

### Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 860-113963/1-A

**Matrix: Water** 

Analysis Batch: 114044

Client Sample ID: Method Blank

Prep Type: Total/NA

**Prep Batch: 113963** 

Analysis Batch: 114044	МВ	МВ						Prep Batch:	
Analyte		Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fa
Acenaphthene	<0.00139	U	0.00570	0.00139	mg/L		07/25/23 10:28	07/26/23 00:12	
Acenaphthylene	<0.00141	U	0.0100	0.00141	mg/L		07/25/23 10:28	07/26/23 00:12	
Anthracene	<0.00150	U	0.00570	0.00150	mg/L		07/25/23 10:28	07/26/23 00:12	
Benzidine	<0.00480	U	0.0200	0.00480			07/25/23 10:28	07/26/23 00:12	
Benzo[a]anthracene	<0.000173	U	0.00500	0.000173	mg/L		07/25/23 10:28	07/26/23 00:12	
Benzo[a]pyrene	< 0.000364	U	0.00500	0.000364			07/25/23 10:28	07/26/23 00:12	
3,4-Benzofluoranthene	<0.00204	U	0.0100	0.00204			07/25/23 10:28	07/26/23 00:12	
Benzo[g,h,i]perylene	<0.00268	U	0.0100	0.00268	mg/L		07/25/23 10:28	07/26/23 00:12	
Benzo[k]fluoranthene	< 0.000375	U	0.00500	0.000375	mg/L		07/25/23 10:28	07/26/23 00:12	
Bis(2-chloroethoxy)methane	<0.00176	U	0.0100	0.00176	mg/L		07/25/23 10:28	07/26/23 00:12	
Bis(2-chloroethyl)ether	<0.00216	U	0.0100	0.00216	mg/L		07/25/23 10:28	07/26/23 00:12	
Bis(2-ethylhexyl) phthalate	<0.000277	U	0.00500	0.000277	mg/L		07/25/23 10:28	07/26/23 00:12	
4-Bromophenyl phenyl ether	<0.000256	U	0.00500	0.000256	mg/L		07/25/23 10:28	07/26/23 00:12	
Butyl benzyl phthalate	<0.000337	U	0.00500	0.000337	mg/L		07/25/23 10:28	07/26/23 00:12	
4-Chloro-3-methylphenol	<0.00157	U	0.00500	0.00157			07/25/23 10:28	07/26/23 00:12	
2-Chloronaphthalene	<0.000462	U	0.00500	0.000462	mg/L		07/25/23 10:28	07/26/23 00:12	
2-Chlorophenol	< 0.000649	U	0.00500	0.000649	mg/L		07/25/23 10:28	07/26/23 00:12	
4-Chlorophenyl phenyl ether	<0.00128	U	0.0100	0.00128	mg/L		07/25/23 10:28	07/26/23 00:12	
Chrysene	<0.000222	U	0.00500	0.000222	mg/L		07/25/23 10:28	07/26/23 00:12	
Dibenz(a,h)anthracene	<0.000246	U	0.00500	0.000246	mg/L		07/25/23 10:28	07/26/23 00:12	
3,3'-Dichlorobenzidine	< 0.000341	U	0.00500	0.000341	mg/L		07/25/23 10:28	07/26/23 00:12	
2,4-Dichlorophenol	<0.000314	U	0.00500	0.000314	mg/L		07/25/23 10:28	07/26/23 00:12	
Diethyl phthalate	< 0.00159	U	0.00500	0.00159	mg/L		07/25/23 10:28	07/26/23 00:12	
2,4-Dimethylphenol	< 0.000649	U	0.00500	0.000649	mg/L		07/25/23 10:28	07/26/23 00:12	
Dimethyl phthalate	<0.000299	U	0.00250	0.000299	mg/L		07/25/23 10:28	07/26/23 00:12	
Di-n-butyl phthalate	<0.000252	U	0.00500	0.000252	mg/L		07/25/23 10:28	07/26/23 00:12	
4,6-Dinitro-o-cresol	<0.00144	U	0.0100	0.00144	mg/L		07/25/23 10:28	07/26/23 00:12	
2,4-Dinitrophenol	<0.000499	U	0.0100	0.000499	mg/L		07/25/23 10:28	07/26/23 00:12	
2,4-Dinitrotoluene	<0.00131	U	0.0100	0.00131	mg/L		07/25/23 10:28	07/26/23 00:12	
2,6-Dinitrotoluene	< 0.00161	U	0.00500	0.00161	mg/L		07/25/23 10:28	07/26/23 00:12	
Di-n-octyl phthalate	<0.000373	U	0.00500	0.000373	mg/L		07/25/23 10:28	07/26/23 00:12	
1,2-Diphenylhydrazine	< 0.00149	U	0.0100	0.00149	mg/L		07/25/23 10:28	07/26/23 00:12	
Fluoranthene	<0.00159	U	0.00500	0.00159	mg/L		07/25/23 10:28	07/26/23 00:12	
Fluorene	<0.00163	U	0.00500	0.00163	mg/L		07/25/23 10:28	07/26/23 00:12	
Hexachlorobenzene	< 0.000307	U	0.00500	0.000307	mg/L		07/25/23 10:28	07/26/23 00:12	
Hexachlorobutadiene	<0.000238	U	0.00100	0.000238	mg/L		07/25/23 10:28	07/26/23 00:12	
Hexachlorocyclopentadiene	<0.00458	U	0.0100	0.00458	mg/L		07/25/23 10:28	07/26/23 00:12	
Hexachloroethane	< 0.000526	U	0.00480	0.000526	mg/L		07/25/23 10:28	07/26/23 00:12	
Indeno[1,2,3-cd]pyrene	<0.00229	U	0.0100	0.00229	mg/L		07/25/23 10:28	07/26/23 00:12	
Isophorone	<0.00164	U	0.00500	0.00164	mg/L		07/25/23 10:28	07/26/23 00:12	
m+p-Cresol	<0.00262	U	0.0100	0.00262	mg/L		07/25/23 10:28	07/26/23 00:12	
Naphthalene	<0.000542	U	0.00250	0.000542	mg/L		07/25/23 10:28	07/26/23 00:12	
Nitrobenzene	<0.00166	U	0.00500	0.00166	mg/L		07/25/23 10:28	07/26/23 00:12	
4-Nitrophenol	<0.00491	U	0.00720	0.00491	mg/L		07/25/23 10:28	07/26/23 00:12	
2-Nitrophenol	<0.00167	U	0.0100	0.00167	mg/L		07/25/23 10:28	07/26/23 00:12	
N-Nitrosodimethylamine	<0.00202	U	0.0100	0.00202	mg/L		07/25/23 10:28	07/26/23 00:12	
N-Nitrosodi-n-propylamine	<0.00288	U	0.0100	0.00288	mg/L		07/25/23 10:28	07/26/23 00:12	
N-Nitrosodiphenylamine	<0.00181	U	0.0100	0.00181	mg/L		07/25/23 10:28	07/26/23 00:12	

**Eurofins Lubbock** 

Page 19 of 59

7/31/2023

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

MB MB

Lab Sample ID: MB 860-113963/1-A

**Matrix: Water** 

Analysis Batch: 114044

Client Sample ID: Method Blank

**Prep Type: Total/NA** 

**Prep Batch: 113963** 

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
o-Cresol	<0.00162	U	0.0100	0.00162	mg/L		07/25/23 10:28	07/26/23 00:12	1
2,2'-oxybis[1-chloropropane]	<0.00179	U	0.0100	0.00179	mg/L		07/25/23 10:28	07/26/23 00:12	1
Pentachlorophenol	<0.000234	U	0.0100	0.000234	mg/L		07/25/23 10:28	07/26/23 00:12	1
Phenanthrene	<0.00142	U	0.0100	0.00142	mg/L		07/25/23 10:28	07/26/23 00:12	1
Phenol	<0.000423	U	0.00450	0.000423	mg/L		07/25/23 10:28	07/26/23 00:12	1
Pyrene	<0.000178	U	0.00500	0.000178	mg/L		07/25/23 10:28	07/26/23 00:12	1
1,2,4,5-Tetrachlorobenzene	<0.00132	U	0.0100	0.00132	mg/L		07/25/23 10:28	07/26/23 00:12	1
1,2,4-Trichlorobenzene	< 0.00161	U	0.00500	0.00161	mg/L		07/25/23 10:28	07/26/23 00:12	1
2,4,6-Trichlorophenol	< 0.00142	U	0.00500	0.00142	mg/L		07/25/23 10:28	07/26/23 00:12	1
2,4,5-Trichlorophenol	<0.00200	U	0.0100	0.00200	mg/L		07/25/23 10:28	07/26/23 00:12	1
Pyridine	< 0.00264	U	0.0100	0.00264	mg/L		07/25/23 10:28	07/26/23 00:12	1
Pentachlorobenzene	< 0.00107	U	0.0100	0.00107	mg/L		07/25/23 10:28	07/26/23 00:12	1
Hexachlorophene	<0.0100	U	0.100	0.0100	mg/L		07/25/23 10:28	07/26/23 00:12	1
N-Nitrosodi-n-butylamine	< 0.00149	U	0.0100	0.00149	mg/L		07/25/23 10:28	07/26/23 00:12	1

	III D	1110				
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorobiphenyl (Surr)	74		29 - 112	07/25/23 10:28	07/26/23 00:12	1
2-Fluorophenol (Surr)	30		28 - 114	07/25/23 10:28	07/26/23 00:12	1
Nitrobenzene-d5 (Surr)	68		15 - 314	07/25/23 10:28	07/26/23 00:12	1
Phenol-d5 (Surr)	17		8 - 424	07/25/23 10:28	07/26/23 00:12	1
p-Terphenyl-d14 (Surr)	79		20 - 141	07/25/23 10:28	07/26/23 00:12	1
2,4,6-Tribromophenol (Surr)	49		31 - 132	07/25/23 10:28	07/26/23 00:12	1

Lab Sample ID: LCS 860-113963/2-A

**Matrix: Water** 

Analysis Batch: 114044

**Client Sample ID: Lab Control Sample** 

**Prep Type: Total/NA** 

Prep Batch: 113963

Analysis Batch: 114044							Prep Batc	n: 113963
	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Acenaphthene	0.0400	0.01867	*-	mg/L		47	60 - 132	
Acenaphthylene	0.0400	0.02015	*-	mg/L		50	54 - 126	
Anthracene	0.0400	0.02463		mg/L		62	43 - 120	
Benzidine	0.0400	0.01109	J	mg/L		28	25 _ 125	
Benzo[a]anthracene	0.0400	0.02748		mg/L		69	42 - 133	
Benzo[a]pyrene	0.0400	0.02508		mg/L		63	32 - 148	
3,4-Benzofluoranthene	0.0400	0.02749		mg/L		69	42 - 140	
Benzo[g,h,i]perylene	0.0400	0.02741		mg/L		69	13 _ 195	
Benzo[k]fluoranthene	0.0400	0.02784		mg/L		70	25 - 146	
Bis(2-chloroethoxy)methane	0.0400	0.01875	*_	mg/L		47	49 - 165	
Bis(2-chloroethyl)ether	0.0400	0.01653	*_	mg/L		41	43 - 126	
Bis(2-ethylhexyl) phthalate	0.0400	0.02510		mg/L		63	29 - 137	
4-Bromophenyl phenyl ether	0.0400	0.02259	*_	mg/L		56	65 - 120	
Butyl benzyl phthalate	0.0400	0.02531		mg/L		63	12 - 140	
4-Chloro-3-methylphenol	0.0400	0.01770		mg/L		44	41 - 128	
2-Chloronaphthalene	0.0400	0.01856	*_	mg/L		46	65 - 120	
2-Chlorophenol	0.0400	0.01471		mg/L		37	36 - 120	
4-Chlorophenyl phenyl ether	0.0400	0.02043		mg/L		51	38 - 145	
Chrysene	0.0400	0.02660		mg/L		67	44 - 140	
Dibenz(a,h)anthracene	0.0400	0.02676		mg/L		67	16 - 200	

**Eurofins Lubbock** 

Page 20 of 59

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-113963/2-A

**Matrix: Water** 

Analysis Batch: 114044

**Client Sample ID: Lab Control Sample** 

**Prep Type: Total/NA** 

**Prep Batch: 113963** 

Analysis Batch. 114044	Spike	LCS	LCS				%Rec	ten. 1159
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
3,3'-Dichlorobenzidine	0.0400	0.02767		mg/L		69	18 - 213	
2,4-Dichlorophenol	0.0400	0.01902	*_	mg/L		48	52 - 122	
Diethyl phthalate	0.0400	0.02424		mg/L		61	17 - 120	
2,4-Dimethylphenol	0.0400	0.01634	*_	mg/L		41	42 - 120	
Dimethyl phthalate	0.0400	0.02255		mg/L		56	25 _ 120	
Di-n-butyl phthalate	0.0400	0.02479		mg/L		62	8 - 120	
4,6-Dinitro-o-cresol	0.0400	0.02064	*_	mg/L		52	53 - 130	
2,4-Dinitrophenol	0.0400	0.01205		mg/L		30	12 - 173	
2,4-Dinitrotoluene	0.0400	0.02350		mg/L		59	48 - 127	
2,6-Dinitrotoluene	0.0400	0.02180	*-	mg/L		54	68 - 137	
Di-n-octyl phthalate	0.0400	0.02512		mg/L		63	19 - 132	
1,2-Diphenylhydrazine	0.0400	0.02059		mg/L		51	28 - 136	
Fluoranthene	0.0400	0.02806		mg/L		70	43 - 121	
Fluorene	0.0400	0.02052	*_	mg/L		51	70 - 120	
Hexachlorobenzene	0.0400	0.02370		mg/L		59	8 - 142	
Hexachlorobutadiene	0.0400	0.01607		mg/L		40	38 - 120	
Hexachlorocyclopentadiene	0.0400	0.01404	*_	mg/L		35	41 - 125	
Hexachloroethane	0.0400	0.01350	*-	mg/L		34	55 - 120	
Indeno[1,2,3-cd]pyrene	0.0400	0.02649		mg/L		66	13 _ 151	
Isophorone	0.0400	0.01889		mg/L		47	47 - 180	
m+p-Cresol	0.0400	0.01067		mg/L		27	14 - 176	
Naphthalene	0.0400	0.01752		mg/L		44	36 - 120	
Nitrobenzene	0.0400	0.01805	*_	mg/L		45	54 - 158	
4-Nitrophenol	0.0400	0.006527	J	mg/L		16	13 _ 129	
2-Nitrophenol	0.0400	0.01822		mg/L		46	45 - 167	
N-Nitrosodimethylamine	0.0400	0.007145	J *-	mg/L		18	20 - 125	
N-Nitrosodi-n-propylamine	0.0400	0.01767		mg/L		44	14 - 198	
N-Nitrosodiphenylamine	0.0400	0.02359		mg/L		59	2 _ 196	
o-Cresol	0.0400	0.01203		mg/L		30	14 - 176	
2,2'-oxybis[1-chloropropane]	0.0400	0.01600	*-	mg/L		40	63 _ 139	
Pentachlorophenol	0.0400	0.01478	*-	mg/L		37	38 - 152	
Phenanthrene	0.0400	0.02333	*_	mg/L		58	65 - 120	
Phenol	0.0400	0.004743	*-	mg/L		12	17 - 120	
Pyrene	0.0400	0.02791		mg/L		70	70 - 120	
1,2,4,5-Tetrachlorobenzene	0.0400	0.01802		mg/L		45	41 - 125	
1,2,4-Trichlorobenzene	0.0400	0.01683	*-	mg/L		42	57 - 130	
2,4,6-Trichlorophenol	0.0400	0.01943	*-	mg/L		49	52 - 129	
2,4,5-Trichlorophenol	0.0400	0.02037		mg/L		51	35 _ 111	
Pyridine	0.0400	0.004087	J	mg/L		10	5 - 94	
Pentachlorobenzene	0.0400	0.02000		mg/L		50	25 _ 131	
N-Nitrosodi-n-butylamine	0.0400	0.01640		mg/L		41	33 - 141	

LCS LCS

Surrogate	%Recovery	Qualifier	Limits
2-Fluorobiphenyl (Surr)	51		29 - 112
2-Fluorophenol (Surr)	19	S1-	28 - 114
Nitrobenzene-d5 (Surr)	46		15 - 314
Phenol-d5 (Surr)	12		8 - 424
p-Terphenyl-d14 (Surr)	75		20 - 141

**Eurofins Lubbock** 

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

#### Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-113963/2-A

**Matrix: Water** 

Analysis Batch: 114044

**Client Sample ID: Lab Control Sample** 

**Prep Type: Total/NA** 

**Prep Batch: 113963** 

Job ID: 820-9303-1

LCS LCS

Surrogate %Recovery Qualifier Limits 2,4,6-Tribromophenol (Surr) 58 31 - 132

Lab Sample ID: LCSD 860-113963/3-A

**Matrix: Water** 

**Client Sample ID: Lab Control Sample Dup** 

**Prep Type: Total/NA** 

Matrix: Water								Detek 1	
Analysis Batch: 114044	Spike	I CSD	LCSD				%Rec	Batch: 1	RPD
Analyte	Added		Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Acenaphthene		0.02025		mg/L		51	60 <sub>-</sub> 132	8	29
Acenaphthylene	0.0400	0.02023	-	mg/L		54	54 - 126	8	30
Anthracene	0.0400	0.02178		_		70	43 - 120	13	30
			1 *4	mg/L					
Benzidine	0.0400	0.01785	JI	mg/L		45	25 - 125	47	30
Benzo[a]anthracene	0.0400	0.03046		mg/L		76 70	42 - 133	10	30
Benzo[a]pyrene	0.0400	0.02806		mg/L		70	32 - 148	11	30
3,4-Benzofluoranthene	0.0400	0.03180		mg/L		80	42 - 140	15	30
Benzo[g,h,i]perylene	0.0400	0.02974		mg/L		74	13 - 195	8	30
Benzo[k]fluoranthene	0.0400	0.02819		mg/L		70	25 - 146	1	
Bis(2-chloroethoxy)methane	0.0400	0.01896		mg/L		47	49 - 165	1	30
Bis(2-chloroethyl)ether	0.0400	0.01600	*-	mg/L		40	43 - 126	3	30
Bis(2-ethylhexyl) phthalate	0.0400	0.02848		mg/L		71	29 - 137	13	30
4-Bromophenyl phenyl ether	0.0400	0.02509	*-	mg/L		63	65 - 120	10	26
Butyl benzyl phthalate	0.0400	0.02875		mg/L		72	12 - 140	13	30
4-Chloro-3-methylphenol	0.0400	0.02034		mg/L		51	41 - 128	14	30
2-Chloronaphthalene	0.0400	0.01887	*-	mg/L		47	65 - 120	2	15
2-Chlorophenol	0.0400	0.01494		mg/L		37	36 - 120	2	30
4-Chlorophenyl phenyl ether	0.0400	0.02255		mg/L		56	38 - 145	10	30
Chrysene	0.0400	0.02930		mg/L		73	44 - 140	10	30
Dibenz(a,h)anthracene	0.0400	0.02936		mg/L		73	16 - 200	9	30
3,3'-Dichlorobenzidine	0.0400	0.03142		mg/L		79	18 - 213	13	30
2,4-Dichlorophenol	0.0400	0.01987	*_	mg/L		50	52 - 122	4	30
Diethyl phthalate	0.0400	0.02724		mg/L		68	17 - 120	12	30
2,4-Dimethylphenol	0.0400	0.01729		mg/L		43	42 - 120	6	30
Dimethyl phthalate	0.0400	0.02494		mg/L		62	25 - 120	10	30
Di-n-butyl phthalate	0.0400	0.02843		mg/L		71	8 - 120	14	28
4,6-Dinitro-o-cresol	0.0400	0.02608		mg/L		65	53 - 130	23	30
2,4-Dinitrophenol	0.0400	0.01795	*1	mg/L		45	12 - 173	39	30
2,4-Dinitrotoluene	0.0400	0.02704		mg/L		68	48 - 127	14	25
2,6-Dinitrotoluene	0.0400	0.02479	*_	mg/L		62	68 - 137	13	29
Di-n-octyl phthalate	0.0400	0.02978		mg/L		74	19 - 132	17	30
1,2-Diphenylhydrazine	0.0400	0.02281		mg/L		57	28 - 136	10	30
Fluoranthene	0.0400	0.03217		mg/L		80	43 - 121	14	30
Fluorene	0.0400	0.02250	*_	mg/L		56	70 - 120	9	23
Hexachlorobenzene	0.0400	0.02648		mg/L		66	8 - 142	11	30
Hexachlorobutadiene	0.0400	0.02048		mg/L		38	38 - 120	5	30
Hexachlorocyclopentadiene	0.0400	0.01329	*_	mg/L		37	41 - 125		30
Hexachloroethane	0.0400	0.01475		_		3 <i>1</i>	41 - 125 55 - 120		
			-	mg/L				4	30
Indeno[1,2,3-cd]pyrene	0.0400	0.02880		mg/L		72	13 - 151	8	30
Isophorone	0.0400	0.01959		mg/L		49	47 - 180	4	30
m+p-Cresol	0.0400	0.01126		mg/L		28	14 - 176	5	30

**Eurofins Lubbock** 

Page 22 of 59

Snike

LCSD LCSD

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

### Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 860-113963/3-A

**Matrix: Water** 

Analysis Batch: 114044

Client Sample ID: Lab Control Sample Dup

**Prep Type: Total/NA Prep Batch: 113963** 

	<b>Spike</b>	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Naphthalene	0.0400	0.01730		mg/L		43	36 - 120	1	30
Nitrobenzene	0.0400	0.01827	*_	mg/L		46	54 - 158	1	30
4-Nitrophenol	0.0400	0.008061		mg/L		20	13 - 129	21	30
2-Nitrophenol	0.0400	0.01969		mg/L		49	45 - 167	8	30
N-Nitrosodimethylamine	0.0400	0.007143	J *-	mg/L		18	20 - 125	0	30
N-Nitrosodi-n-propylamine	0.0400	0.01829		mg/L		46	14 - 198	3	30
N-Nitrosodiphenylamine	0.0400	0.02629		mg/L		66	2 - 196	11	30
o-Cresol	0.0400	0.01268		mg/L		32	14 - 176	5	30
2,2'-oxybis[1-chloropropane]	0.0400	0.01603	*-	mg/L		40	63 - 139	0	30
Pentachlorophenol	0.0400	0.01933		mg/L		48	38 - 152	27	30
Phenanthrene	0.0400	0.02610		mg/L		65	65 - 120	11	30
Phenol	0.0400	0.005130	*-	mg/L		13	17 - 120	8	30
Pyrene	0.0400	0.03052		mg/L		76	70 - 120	9	30
1,2,4,5-Tetrachlorobenzene	0.0400	0.01800		mg/L		45	41 - 125	0	30
1,2,4-Trichlorobenzene	0.0400	0.01643	*-	mg/L		41	57 - 130	2	30
2,4,6-Trichlorophenol	0.0400	0.02233		mg/L		56	52 - 129	14	30
2,4,5-Trichlorophenol	0.0400	0.02368		mg/L		59	35 - 111	15	30
Pyridine	0.0400	0.004986	J	mg/L		12	5 - 94	20	30
Pentachlorobenzene	0.0400	0.02133		mg/L		53	25 - 131	6	30
N-Nitrosodi-n-butylamine	0.0400	0.01807		mg/L		45	33 - 141	10	30

LCSD LCSD

Surrogate	%Recovery	Qualifier	Limits
2-Fluorobiphenyl (Surr)	53		29 - 112
2-Fluorophenol (Surr)	19	S1-	28 - 114
Nitrobenzene-d5 (Surr)	47		15 - 314
Phenol-d5 (Surr)	13		8 - 424
p-Terphenyl-d14 (Surr)	83		20 - 141
2,4,6-Tribromophenol (Surr)	67		31 - 132

#### Method: 608.3 - Organochlorine Pesticides in Water

Lab Sample ID: MB 860-113167/1-A

**Matrix: Water** 

Analysis Batch: 113174

**Client Sample ID: Method Blank** Prep Type: Total/NA

**Prep Batch: 113167** 

	MB	MB							
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Aldrin	<0.00000113	U	0.0000100	0.00000113	mg/L		07/20/23 07:48	07/20/23 12:18	1
alpha-BHC	<0.00000142	U	0.0000090	0.0000014	mg/L		07/20/23 07:48	07/20/23 12:18	1
			0	2					
beta-BHC	<0.00000389	U	0.0000180	0.0000038	mg/L		07/20/23 07:48	07/20/23 12:18	1
				9					
delta-BHC	<0.00000245	U	0.000250	0.0000024	mg/L		07/20/23 07:48	07/20/23 12:18	1
				5					
gamma-BHC (Lindane)	<0.00000299	U	0.0000100	0.0000029	mg/L		07/20/23 07:48	07/20/23 12:18	1
				9					
4,4'-DDD	<0.00000081	U	0.0000100	0.0000008	mg/L		07/20/23 07:48	07/20/23 12:18	1
	4			14					
4,4'-DDE	<0.00000109	U	0.0000100	0.0000010	mg/L		07/20/23 07:48	07/20/23 12:18	1
				a					

Page 23 of 59

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### Method: 608.3 - Organochlorine Pesticides in Water (Continued)

128

98

Lab Sample ID: MB 860-113167/1-A

**Matrix: Water** 

**Analysis Batch: 113174** 

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 113167

	MB	MB							
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4,4'-DDT	<0.00000379	U	0.0000200	0.0000037	mg/L		07/20/23 07:48	07/20/23 12:18	1
				9					
Dieldrin	<0.00000095	U	0.0000100	0.0000009	mg/L		07/20/23 07:48	07/20/23 12:18	1
	3			53					
Endosulfan I	<0.00000107	U	0.0000100	0.0000010	mg/L		07/20/23 07:48	07/20/23 12:18	1
				7					
Endosulfan II	<0.00000122	U	0.0000100	0.0000012	mg/L		07/20/23 07:48	07/20/23 12:18	1
				2					
Endosulfan sulfate	<0.00000112	U	0.0000100	0.00000112	mg/L		07/20/23 07:48	07/20/23 12:18	1
Endrin	<0.00000156	U	0.0000100	0.0000015	mg/L		07/20/23 07:48	07/20/23 12:18	1
				6					
Endrin aldehyde	<0.00000118	U	0.0000100	0.00000118	mg/L		07/20/23 07:48	07/20/23 12:18	1
Heptachlor	<0.00000446	U	0.0000090	0.0000044	mg/L		07/20/23 07:48	07/20/23 12:18	1
			0	6					
Heptachlor epoxide	<0.00000134	U	0.0000100	0.0000013	mg/L		07/20/23 07:48	07/20/23 12:18	1
				4					
Toxaphene	<0.0000769	U	0.000200	0.0000769	mg/L		07/20/23 07:48	07/20/23 12:18	1
Chlordane	<0.000103	U	0.000250	0.000103	mg/L		07/20/23 07:48	07/20/23 12:18	1
	МВ	MB							
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac

15 - 136

18 - 126

Lab Sample ID: LCS 860-113167/2-A

**Matrix: Water** 

Analysis Batch: 113174

DCB Decachlorobiphenyl (Surr)

Tetrachloro-m-xylene (Surr)

Client Sample ID: Lab Control Sample Prep Type: Total/NA

07/20/23 12:18

07/20/23 12:18

07/20/23 07:48

07/20/23 07:48

Prep Batch: 113167

	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Aldrin	0.000100	0.0001153		mg/L		115	42 - 140	_
alpha-BHC	0.000100	0.0001115		mg/L		111	37 - 140	
beta-BHC	0.000100	0.0001384		mg/L		138	17 - 147	
delta-BHC	0.000100	0.00009904	J	mg/L		99	19 - 140	
gamma-BHC (Lindane)	0.000100	0.0001148		mg/L		115	34 - 140	
4,4'-DDD	0.000100	0.0001344		mg/L		134	31 - 141	
4,4'-DDE	0.000100	0.0001226		mg/L		123	30 - 145	
4,4'-DDT	0.000100	0.0001347		mg/L		135	25 - 160	
Dieldrin	0.000100	0.0001233		mg/L		123	36 - 146	
Endosulfan I	0.000100	0.0001252		mg/L		125	45 - 153	
Endosulfan II	0.000100	0.0001287		mg/L		129	22 - 171	
Endosulfan sulfate	0.000100	0.0001245		mg/L		125	26 - 144	
Endrin	0.000100	0.0001267		mg/L		127	30 - 147	
Endrin aldehyde	0.000100	0.0001171		mg/L		117	60 - 130	
Heptachlor	0.000100	0.0001149		mg/L		115	34 - 140	
Heptachlor epoxide	0.000100	0.0001189		mg/L		119	37 - 142	

	LCS	LCS	
Surrogate	%Recovery	Qualifier	Limits
DCB Decachlorobiphenyl (Surr)	131		15 - 136
Tetrachloro-m-xylene (Surr)	101		18 - 126

Eurofins Lubbock

2

4

6

-

46

11

13

14

Client: Parkhill Smith & Cooper Inc. Job ID: 820-9303-1

Project/Site: TPDES Permit Application Renewal

#### Method: 608.3 - Organochlorine Pesticides in Water (Continued)

Lab Sample ID: LCSD 860-113167/3-A

Analysis Batch: 113174

**Matrix: Water** 

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

**Prep Batch: 113167** 

	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Aldrin	0.000100	0.0001141		mg/L		114	42 - 140	1	30
alpha-BHC	0.000100	0.0001136		mg/L		114	37 - 140	2	30
beta-BHC	0.000100	0.0001342		mg/L		134	17 - 147	3	30
delta-BHC	0.000100	0.00009733	J	mg/L		97	19 - 140	2	30
gamma-BHC (Lindane)	0.000100	0.0001160		mg/L		116	34 - 140	1	30
4,4'-DDD	0.000100	0.0001296		mg/L		130	31 - 141	4	30
4,4'-DDE	0.000100	0.0001171		mg/L		117	30 - 145	5	30
4,4'-DDT	0.000100	0.0001300		mg/L		130	25 - 160	4	30
Dieldrin	0.000100	0.0001212		mg/L		121	36 - 146	2	30
Endosulfan I	0.000100	0.0001264		mg/L		126	45 - 153	1	30
Endosulfan II	0.000100	0.0001252		mg/L		125	22 - 171	3	30
Endosulfan sulfate	0.000100	0.0001206		mg/L		121	26 - 144	3	30
Endrin	0.000100	0.0001231		mg/L		123	30 - 147	3	30
Endrin aldehyde	0.000100	0.0001145		mg/L		115	60 - 130	2	30
Heptachlor	0.000100	0.0001160		mg/L		116	34 - 140	1	30
Heptachlor epoxide	0.000100	0.0001179		mg/L		118	37 - 142	1	30

LCSD LCSD

Surrogate	%Recovery	Qualifier	Limits
DCB Decachlorobiphenyl (Surr)	121		15 - 136
Tetrachloro-m-xylene (Surr)	94		18 - 126

#### Method: 608.3 - Polychlorinated Biphenyls (PCBs) (GC)

Lab Sample ID: MB 860-113167/1-A

**Matrix: Water** 

Analysis Batch: 113186

Client Sample ID: Method Blank

Prep Type: Total/NA

**Prep Batch: 113167** 

	MB	MB						-	
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
PCB-1016	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:25	1
PCB-1221	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:25	1
PCB-1232	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:25	1
PCB-1242	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:25	1
PCB-1248	<0.0000125	U	0.000100	0.0000125	mg/L		07/20/23 07:48	07/20/23 13:25	1
PCB-1254	<0.00000780	U	0.000100	0.0000078	mg/L		07/20/23 07:48	07/20/23 13:25	1
				0					
PCB-1260	<0.00000780	U	0.000100	0.0000078	mg/L		07/20/23 07:48	07/20/23 13:25	1
				0					
Polychlorinated biphenyls, Total	<0.000100	U	0.000100	0.000100	mg/L		07/20/23 07:48	07/20/23 13:25	1
	MR	MR							

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Tetrachloro-m-xylene (Surr)	80		18 - 126	07/20/23 07:48	07/20/23 13:25	1
DCB Decachlorobiphenyl (Surr)	121		15 - 136	07/20/23 07:48	07/20/23 13:25	1

Lab Sample ID: LCS 860-113167/4-A

**Matrix: Water** 

Analysis Batch: 113186

Client Sample ID: Lab Control Sample Prep Type: Total/NA

**Prep Batch: 113167** 

Spike LCS LCS %Rec Analyte Added Result Qualifier Unit %Rec Limits PCB-1016 0.00100 0.0007608 mg/L 76 61 - 103

**Eurofins Lubbock** 

Page 25 of 59

Client: Parkhill Smith & Cooper Inc. Job ID: 820-9303-1

Project/Site: TPDES Permit Application Renewal

Method: 608.3 - Polychlorinated Biphenyls (PCBs) (GC) (Continued)

Lab Sample ID: LCS 860-113167/4-A **Matrix: Water** 

Analysis Batch: 113186							Prep	Batch: 113167
	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
PCB-1260	0.00100	0.0008231		mg/L		82	37 - 130	

	LCS	LCS	
Surrogate	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene (Surr)	84		18 - 126
DCB Decachlorobiphenyl (Surr)	125		15 - 136

Lab Sample ID: LCSD 860-113167/5-A

**Matrix: Water** 

Analysis Batch: 113186							Prep I	Batch: 1	13167
	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
PCB-1016	0.00100	0.0007988		mg/L		80	61 - 103	5	24
PCB-1260	0.00100	0.0008625		mg/L		86	37 - 130	5	28

	LCSD	LCSD	
Surrogate	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene (Surr)	82		18 - 126
DCB Decachlorobiphenyl (Surr)	115		15 - 136

Method: 615 - Herbicides (GC)

Lab Sample ID: MB 860-113651/1-A

Matrix: Water Analysis Batch: 114272				Prep Type: Total/NA Prep Batch: 113651
	MB MB			

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hexachlorophene	<0.000811	U	0.00502	0.000811	mg/L		07/23/23 19:55	07/26/23 17:23	1
Silvex (2,4,5-TP)	<0.0000424	U	0.000201	0.0000424	mg/L		07/23/23 19:55	07/26/23 17:23	1
	МВ	MB							
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2,4-Dichlorophenylacetic acid	118		45 _ 150				07/23/23 19:55	07/26/23 17:23	1

2,4-Dichlorophenylacetic acid Lab Sample ID: LCS 860-113651/2-A **Client Sample ID: Lab Control Sample** 

**Matrix: Water** 

Analysis Batch: 114272

Alialysis Datcii. 114212							FIE
	Spike	LCS	LCS				%Rec
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits
Silvex (2,4,5-TP)	0.00201	0.001916		mg/L		95	55 - 140

	LCS	LCS	
Surrogate	%Recovery	Qualifier	Limits
2.4-Dichlorophenylacetic acid	130		45 _ 150

Lab Sample ID: LCS 860-113651/4-A

**Matrix: Water** 

Analysis Batch: 11/1272

Analysis Batch: 114272							Prep	Battin: 1	13051
	Spike	LCS	LCS				%Rec		
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits		
Hexachlorophene	0.00803	0.007690		mg/L		96	60 - 135		

Eurofins Lubbock

Client Sample ID: Lab Control Sample

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Type: Total/NA

Client Sample ID: Method Blank

Prep Type: Total/NA

**Prep Batch: 113651** 

Prep Batch: 113651

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### Method: 615 - Herbicides (GC) (Continued)

Lab Sample ID: LCS 860-113651/4-A

Lab Sample ID: LCSD 860-113651/3-A

Lab Sample ID: LCSD 860-113651/5-A

**Matrix: Water** 

**Matrix: Water** 

**Matrix: Water** 

Analysis Batch: 114272

Analysis Batch: 114272

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

**Prep Batch: 113651** 

LCS LCS

Surrogate %Recovery Qualifier Limits 2,4-Dichlorophenylacetic acid 128 45 - 150

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

**Prep Batch: 113651** 

Analysis Batch: 114272 LCSD LCSD Spike %Rec RPD Analyte Added Result Qualifier Unit %Rec Limits RPD Limit Silvex (2,4,5-TP) 0.00202 0.001681 mg/L 83 55 - 140 25

LCSD LCSD

Surrogate %Recovery Qualifier Limits 2,4-Dichlorophenylacetic acid 111 45 - 150

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

**Prep Batch: 113651** 

Spike LCSD LCSD %Rec RPD Added Result Qualifier RPD Limit Analyte Unit D %Rec Limits Hexachlorophene 0.00802 0.006777 mg/L 85 60 - 135 13

LCSD LCSD

MB MB

Limits Surrogate %Recovery Qualifier 2,4-Dichlorophenylacetic acid 112 45 - 150

#### Method: 300.0 - Anions, Ion Chromatography

Lab Sample ID: MB 860-112992/49

**Matrix: Water** 

Analysis Batch: 112992

Client Sample ID: Method Blank

Prep Type: Total/NA

Result Qualifier MDL Unit Dil Fac Analyte RL Prepared Analyzed Chloride <0.250 U 0.500 0.250 07/19/23 17:02 mg/L Fluoride <0.100 U 0.500 0.100 mg/L 07/19/23 17:02 Sulfate <0.200 U 0.500 07/19/23 17:02 0.200 mg/L

**Client Sample ID: Lab Control Sample** 

Analysis Batch: 112992

Lab Sample ID: LCS 860-112992/50 **Matrix: Water** Prep Type: Total/NA

LCS LCS Spike %Rec Qualifier %Rec Analyte Added Result Unit Limits 99 90 - 110 Chloride 10.0 9.911 mg/L Fluoride 10.0 10.30 mg/L 103 90 - 110 Sulfate 10.0 9.487 95 90 - 110 mg/L

Lab Sample ID: LCSD 860-112992/51 Client Sample ID: Lab Control Sample Dup

**Matrix: Water** 

Analysis Batch: 112992

	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Chloride	10.0	9.955		mg/L		100	90 - 110	0	20
Fluoride	10.0	10.31		mg/L		103	90 - 110	0	20

**Eurofins Lubbock** 

Prep Type: Total/NA

Page 27 of 59

7/31/2023

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

Method: 300.0 - Anions, Ion Chromatography (Continued)

Lab Sample ID: LCSD 860-112992/51

**Matrix: Water** 

Analysis Batch: 112992

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Spike LCSD LCSD %Rec RPD Analyte Added Result Qualifier Unit %Rec Limits **RPD** Limit D Sulfate 10.0 9.516 95 90 - 110 mg/L

Lab Sample ID: LLCS 860-112992/52 **Client Sample ID: Lab Control Sample** 

**Matrix: Water** 

Prep Type: Total/NA

Analysis Batch: 112992

Spike LLCS LLCS %Rec Added Result Qualifier Analyte Unit Limits %Rec Chloride 0.500 0.4730 J mg/L 95 50 - 150 Fluoride 0.500 72 0.3615 J mg/L 50 - 150 0.500 Sulfate 0.4962 J mg/L 99 50 - 150

Lab Sample ID: MB 860-112993/3 Client Sample ID: Method Blank

**Matrix: Water** Prep Type: Total/NA

Analysis Batch: 112993

MB MB

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Nitrate as N	<0.0391	U	0.100	0.0391	mg/L			07/19/23 11:05	1
Nitrite as N	<0.0293	U	0.100	0.0293	mg/L			07/19/23 11:05	1
Nitrate Nitrite as N	< 0.0391	U	0.100	0.0391	mg/L			07/19/23 11:05	1

Lab Sample ID: MB 860-112993/49 Client Sample ID: Method Blank Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 112993

мв мв

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Nitrate as N	<0.0391	U	0.100	0.0391	mg/L			07/19/23 17:02	1
Nitrite as N	<0.0293	U	0.100	0.0293	mg/L			07/19/23 17:02	1
Nitrate Nitrite as N	< 0.0391	U	0.100	0.0391	mg/L			07/19/23 17:02	1

Lab Sample ID: LCS 860-112993/50 Client Sample ID: Lab Control Sample Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 112993

7 mm, 610 = 410 m 11=000							
	Spike	LCS	LCS				%Rec
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits
Nitrate as N	10.0	10.11		mg/L		101	80 - 120
Nitrite as N	10.0	9.646		mg/L		96	80 - 120

Lab Sample ID: LCSD 860-112993/51 Client Sample ID: Lab Control Sample Dup

**Matrix: Water** 

Analysis Batch: 112993

7 maryolo Batom 112000										
	Spike	LCSD	LCSD				%Rec		RPD	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit	
Nitrate as N	10.0	10.13		mg/L		101	80 - 120	0	20	
Nitrite as N	10.0	9.714		mg/L		97	80 - 120	1	20	

**Eurofins Lubbock** 

7/31/2023

Prep Type: Total/NA

LICE LICE

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### Method: 300.0 - Anions, Ion Chromatography (Continued)

Lab Sample ID: LLCS 860-112993/6

**Matrix: Water** 

Client Sample ID: Lab Control Sample Prep Type: Total/NA

0/ Doo

Analysis Batch: 112993

	<b>Бріке</b>	LLCS	LLCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Nitrate as N	0.100	0.06606	J	mg/L		66	50 - 150	
Nitrite as N	0.100	0.06965	J	mg/L		70	50 - 150	

Cnika

#### Method: 632 - Carbamate and Urea Pesticides (HPLC)

Lab Sample ID: MB 860-113552/1-A

**Matrix: Water** 

Analysis Batch: 114338

Client Sample ID: Method Blank Prep Type: Total/NA

**Prep Batch: 113552** 

	МВ	MB							
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Carbaryl	<1.85	U	5.00	1.85	ug/L		07/22/23 06:44	07/26/23 05:24	1
Diuron	<0.0514	U	0.0900	0.0514	ug/L		07/22/23 06:44	07/26/23 05:24	1

Lab Sample ID: LCS 860-113552/2-A

**Matrix: Water** 

Analysis Batch: 114338

**Client Sample ID: Lab Control Sample** 

Prep Type: Total/NA

**Prep Batch: 113552** 

	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Carbaryl	 100	113.8		ug/L		114	70 - 130	
Diuron	2.00	2.591		ug/L		130	70 - 130	

Lab Sample ID: LCSD 860-113552/3-A

**Matrix: Water** 

Analysis Batch: 114338

**Client Sample ID: Lab Control Sample Dup** 

Prep Type: Total/NA

**Prep Batch: 113552** 

	Spike	LCSD	LCSD			%Rec		RPD	
Analyte	Added	Result	Qualifier Unit	D	%Rec	Limits	RPD	Limit	
Carbaryl	100	113.7	ug/L		114	70 - 130	0	20	
Diuron	2.00	2.556	ug/L		128	70 - 130	1	20	

#### Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 860-113539/1-A

**Matrix: Water** 

Analysis Batch: 113641

Client Sample ID: Method Blank **Prep Type: Total Recoverable** 

**Prep Batch: 113539** 

Tananyono Batom Trooti									
	MB	MB							
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Aluminum	<0.00301	U	0.0200	0.00301	mg/L		07/21/23 20:53	07/22/23 22:59	1
Antimony	<0.00105	U	0.00200	0.00105	mg/L		07/21/23 20:53	07/22/23 22:59	1
Arsenic	<0.000341	U	0.00400	0.000341	mg/L		07/21/23 20:53	07/22/23 22:59	1
Barium	<0.000289	U	0.00400	0.000289	mg/L		07/21/23 20:53	07/22/23 22:59	1
Beryllium	<0.000148	U	0.00200	0.000148	mg/L		07/21/23 20:53	07/22/23 22:59	1
Cadmium	<0.0000850	U	0.00200	0.0000850	mg/L		07/21/23 20:53	07/22/23 22:59	1
Chromium	<0.000325	U	0.00400	0.000325	mg/L		07/21/23 20:53	07/22/23 22:59	1
Copper	<0.000690	U	0.00400	0.000690	mg/L		07/21/23 20:53	07/22/23 22:59	1
Lead	<0.000140	U	0.00200	0.000140	mg/L		07/21/23 20:53	07/22/23 22:59	1
Nickel	<0.000486	U	0.00200	0.000486	mg/L		07/21/23 20:53	07/22/23 22:59	1
Selenium	<0.000685	U	0.00200	0.000685	mg/L		07/21/23 20:53	07/22/23 22:59	1
Silver	<0.000118	U	0.00200	0.000118	mg/L		07/21/23 20:53	07/22/23 22:59	1
Thallium	<0.0000960	U	0.00200	0.0000960	mg/L		07/21/23 20:53	07/22/23 22:59	1
Zinc	<0.000885	U	0.00400	0.000885	mg/L		07/21/23 20:53	07/22/23 22:59	1

**Eurofins Lubbock** 

Page 29 of 59

Project/Site: TPDES Permit Application Renewal

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: LCS 860-113539/2-A

Analysis Batch: 113641

**Matrix: Water** 

**Client Sample ID: Lab Control Sample Prep Type: Total Recoverable** 

**Prep Batch: 113539** 

Job ID: 820-9303-1

	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Aluminum	0.500	0.4639		mg/L		93	85 - 115	
Antimony	0.100	0.08663		mg/L		87	85 _ 115	
Arsenic	0.100	0.09080		mg/L		91	85 <sub>-</sub> 115	
Barium	0.100	0.09239		mg/L		92	85 - 115	
Beryllium	0.100	0.08892		mg/L		89	85 <sub>-</sub> 115	
Cadmium	0.100	0.09030		mg/L		90	85 - 115	
Chromium	0.100	0.08940		mg/L		89	85 - 115	
Copper	0.100	0.08903		mg/L		89	85 <sub>-</sub> 115	
Lead	0.100	0.09067		mg/L		91	85 _ 115	
Nickel	0.100	0.08997		mg/L		90	85 - 115	
Selenium	0.100	0.08990		mg/L		90	85 - 115	
Silver	0.0500	0.04707		mg/L		94	85 _ 115	
Thallium	0.100	0.09046		mg/L		90	85 - 115	
Zinc	0.100	0.09075		mg/L		91	85 - 115	

Lab Sample ID: LCSD 860-113539/3-A

**Matrix: Water** 

**Client Sample ID: Lab Control Sample Dup Prep Type: Total Recoverable** 

Analysis Batch: 113641							Prep	Batch: 1	13539
	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Aluminum	0.500	0.4668		mg/L		93	85 - 115	1	20
Antimony	0.100	0.08848		mg/L		88	85 - 115	2	20
Arsenic	0.100	0.09045		mg/L		90	85 - 115	0	20
Barium	0.100	0.09221		mg/L		92	85 - 115	0	20
Beryllium	0.100	0.08999		mg/L		90	85 - 115	1	20
Cadmium	0.100	0.09051		mg/L		91	85 - 115	0	20
Chromium	0.100	0.08896		mg/L		89	85 - 115	0	20
Copper	0.100	0.08889		mg/L		89	85 - 115	0	20
Lead	0.100	0.09083		mg/L		91	85 - 115	0	20
Nickel	0.100	0.08976		mg/L		90	85 - 115	0	20
Selenium	0.100	0.09009		mg/L		90	85 - 115	0	20
Silver	0.0500	0.04692		mg/L		94	85 - 115	0	20
Thallium	0.100	0.09006		mg/L		90	85 - 115	0	20
Zinc	0.100	0.09085		mg/L		91	85 - 115	0	20

Lab Sample ID: LLCS 860-113539/4-A

**Matrix: Water** 

**Analysis Batch: 113641** 

Client Sample ID: Lab Control Sample **Prep Type: Total Recoverable** 

**Prep Batch: 113539** 

	Spike	LLCS	LLCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Aluminum	0.0200	0.01542	J	mg/L		77	50 - 150	
Antimony	0.00200	0.002278		mg/L		114	50 - 150	
Arsenic	0.00400	0.003612	J	mg/L		90	50 - 150	
Barium	0.00400	0.003627	J	mg/L		91	50 - 150	
Beryllium	0.00200	0.001714	J	mg/L		86	50 - 150	
Cadmium	0.00200	0.001775	J	mg/L		89	50 - 150	
Chromium	0.00400	0.003911	J	mg/L		98	50 - 150	
Copper	0.00400	0.003629	J	mg/L		91	50 - 150	
Lead	0.00200	0.001761	J	mg/L		88	50 - 150	

**Eurofins Lubbock** 

Page 30 of 59

Project/Site: TPDES Permit Application Renewal

Method: 200.8 - Metals (ICP/MS) (Continued)

Lab Sample ID: LLCS 860-113539/4-A

**Matrix: Water** 

Analysis Batch: 113641

**Client Sample ID: Lab Control Sample** 

**Prep Type: Total Recoverable** 

**Prep Batch: 113539** 

Job ID: 820-9303-1

	Spike	LLCS	LLCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Nickel	0.00200	0.001767	J	mg/L		88	50 - 150	
Selenium	0.00200	0.002157		mg/L		108	50 - 150	
Silver	0.00200	0.001845	J	mg/L		92	50 - 150	
Thallium	0.00200	0.001790	J	mg/L		90	50 - 150	
Zinc	0.00400	0.003507	J	mg/L		88	50 - 150	

Method: 245.1 - Mercury (CVAA)

Lab Sample ID: MB 860-113872/10-A

**Matrix: Water** 

Analyte

Mercury

Mercury

Analyte

Analyte

Analysis Batch: 114081

MR MR

Result Qualifier <0.0000525 U

0.000200

Spike

Added

Spike

Added

Spike

Added

0.000200

0.00200

0.00200

MDL Unit 0.0000525 mg/L

LCS LCS

0.001939

0.001924

0.0002280

RL

5.00

Result Qualifier

LCSD LCSD

LLCS LLCS

Result Qualifier

Result Qualifier

Unit

mg/L

Unit

mg/L

Unit

mg/L

07/24/23 20:19

%Rec

%Rec

%Rec

114

07/25/23 16:06

**Client Sample ID: Lab Control Sample** 

%Rec

Limits

85 - 115

Client Sample ID: Method Blank

Analyzed

Prep Type: Total/NA

**Prep Batch: 113872** 

Prep Type: Total/NA **Prep Batch: 113872** 

Lab Sample ID: LCS 860-113872/11-A

**Matrix: Water** 

Analysis Batch: 114081

Analyte

Mercury

Lab Sample ID: LCSD 860-113872/12-A **Matrix: Water** 

Analysis Batch: 114081

Analyte

Lab Sample ID: LLCS 860-113872/13-A **Matrix: Water** 

**Analysis Batch: 114081** 

Mercury

Method: 1664B - HEM and SGT-HEM

**Matrix: Water** 

Analysis Batch: 113695

мв мв

HEM (Oil & Grease)

Lab Sample ID: MB 860-113695/1

Lab Sample ID: LCS 860-113695/2 **Matrix: Water** 

Analysis Batch: 113695

Spike Added HEM (Oil & Grease) 40.0 35.50

Result Qualifier

<1.57 U

LCS LCS Result Qualifier

MDL Unit

1.57 mg/L

> Unit mg/L

%Rec

Prepared

78 - 114

Page 31 of 59

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA **Prep Batch: 113872** 

RPD

RPD Limit Limits 85 - 115 20

Client Sample ID: Lab Control Sample

Prep Type: Total/NA Prep Batch: 113872

%Rec Limits

50 - 150

%Rec

Limits

Prep Type: Total/NA

Analyzed Dil Fac 07/24/23 09:53

Job ID: 820-9303-1

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Method: 1664B - HEM and SGT-HEM

Lab Sample ID: LCSD 860-113695/3

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analysis Batch: 113695

**Matrix: Water** 

	Spike	LCSD	LCSD				%Rec		RPD	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit	
HEM (Oil & Grease)	40.0	36.80		mg/L		92	78 - 114	4	18	

Method: 335.4 - Cyanide, Total

Lab Sample ID: MB 860-113429/30-A Client Sample ID: Method Blank

**Matrix: Water** Prep Type: Total/NA Analysis Batch: 113542 **Prep Batch: 113429** 

MB MB

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Total	<0.0231	U	0.0577	0.0231	mg/L		07/21/23 14:28	07/21/23 20:29	1

Lab Sample ID: MB 860-113429/47-A Client Sample ID: Method Blank

**Matrix: Water** Prep Type: Total/NA **Prep Batch: 113429** Analysis Batch: 113542 MB MB

Analyte Result Qualifier RL MDL Unit D Prepared Analyzed Dil Fac Cyanide, Total <0.00200 U 0.00500 0.00200 mg/L 07/21/23 14:39 07/21/23 21:00

Lab Sample ID: MB 860-113429/4-A Client Sample ID: Method Blank

**Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113542 Prep Batch: 113429 мв мв

Analyte Result Qualifier RL MDL Unit Prepared Analyzed Dil Fac Cyanide, Total <0.00200 U 0.00500 0.00200 07/21/23 11:49 07/21/23 19:47 mg/L

Lab Sample ID: LCS 860-113429/48-A **Client Sample ID: Lab Control Sample Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113542 Prep Batch: 113429 Spike LCS LCS %Rec

Added Analyte Result Qualifier Unit Limits Cyanide, Total 0.100 0.09726 90 - 110 mg/L

Lab Sample ID: LCS 860-113429/5-A Client Sample ID: Lab Control Sample **Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113542 Prep Batch: 113429 LCS LCS Spike %Rec Added Result Qualifier Limits Analyte Unit D %Rec

0.100 0.09719 Cyanide, Total mg/L 90 - 110

Lab Sample ID: LCSD 860-113429/32-A Client Sample ID: Lab Control Sample Dup **Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113542 Prep Batch: 113429 Spike LCSD LCSD %Rec **RPD** Analyte Added Result Qualifier Unit D %Rec Limits RPD Limit Cyanide, Total 1.15 1.140 mg/L 90 \_ 110

**Eurofins Lubbock** 

Job ID: 820-9303-1

Prep Type: Total/NA

Prep Type: Total/NA

Project/Site: TPDES Permit Application Renewal

Method: 335.4 - Cyanide, Total (Continued)

Lab Sample ID: LCSD 860-113429/49-A Client Sample ID: Lab Control Sample Dup

**Matrix: Water** 

Client: Parkhill Smith & Cooper Inc.

Prep Type: Total/NA Analysis Batch: 113542 Prep Batch: 113429 Spike LCSD LCSD RPD

Analyte babbA Result Qualifier %Rec Limits RPD Limit Unit Cyanide, Total 0.100 0.09590 mg/L 96 90 - 110 20

Lab Sample ID: LLCS 860-113429/6-A Client Sample ID: Lab Control Sample **Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113542

**Prep Batch: 113429** Spike LLCS LLCS %Rec

Analyte Added Result Qualifier Unit D %Rec Limits Cyanide, Total 0.00500 0.004437 J mg/L 89 50 - 150

Method: 350.1 - Nitrogen, Ammonia

Lab Sample ID: MB 860-113251/134 Client Sample ID: Method Blank

**Matrix: Water** 

Analysis Batch: 113251

MB MB Analyte Result Qualifier RL MDL Unit D Prepared Analyzed Dil Fac Ammonia <0.0345 U 0.100 0.0345 mg/L 07/19/23 23:15

Lab Sample ID: LCS 860-113251/135 **Client Sample ID: Lab Control Sample** 

**Matrix: Water** 

Analysis Batch: 113251

Spike LCS LCS %Rec Analyte Added Qualifier Unit %Rec Limits Result 1.086 Ammonia 1.00 mg/L 90 - 110

Lab Sample ID: LCSD 860-113251/136 Client Sample ID: Lab Control Sample Dup Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113251

Spike LCSD LCSD %Rec RPD Qualifier Analyte Added Result Unit %Rec Limits Limit 1.00 1.094 109 90 - 110 Ammonia mg/L 20

Method: 351.2 - Nitrogen, Total Kjeldahl

Lab Sample ID: MB 860-113822/4-A Client Sample ID: Method Blank **Matrix: Water** Prep Type: Total/NA

Analysis Batch: 114070

MR MR Analyte Result Qualifier RL MDL Unit Prepared Analyzed Dil Fac Nitrogen, Kjeldahl <0.0890 0.200 0.0890 mg/L 07/24/23 16:54 07/25/23 15:22

Lab Sample ID: LCS 860-113822/6-A Client Sample ID: Lab Control Sample

**Matrix: Water** Analysis Batch: 114070

Prep Batch: 113822 Spike LCS LCS %Rec

Added Result Qualifier Limits Analyte Unit %Rec Nitrogen, Kjeldahl 2.00 1.994 100 ma/L 90 - 110

**Eurofins Lubbock** 

Prep Batch: 113822

Prep Type: Total/NA

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### Method: 351.2 - Nitrogen, Total Kjeldahl (Continued)

Lab Sample ID: LCSD 860-113822/7-A Client Sample ID: Lab Control Sample Dup **Matrix: Water** Prep Type: Total/NA Analysis Batch: 114070 **Prep Batch: 113822** LCSD LCSD RPD Spike Added Result Qualifier %Rec Limits RPD Limit Analyte Unit D Nitrogen, Kjeldahl 2.00 1.989 mg/L 99 90 - 110 0 20

Lab Sample ID: LLCS 860-113822/5-A Client Sample ID: Lab Control Sample **Matrix: Water** Prep Type: Total/NA **Analysis Batch: 114070 Prep Batch: 113822** Spike LLCS LLCS %Rec

Analyte Added Result Qualifier Unit D %Rec Limits Nitrogen, Kjeldahl 0.200 0.2109 mg/L 105 50 - 150

#### Method: 365.1 - Phosphorus, Total

Total Phosphorus as PO4

Lab Sample ID: MB 860-113846/31-A Client Sample ID: Method Blank

**Matrix: Water** Prep Type: Total/NA **Analysis Batch: 114071** Prep Batch: 113846

MB MB Analyte Result Qualifier RΙ MDL Unit D Prepared Analyzed Dil Fac Total Phosphorus as P <0.00959 U 0.0200 0.00959 mg/L 07/24/23 18:08 07/25/23 15:46 Total Phosphorus as PO4 <0.0294 U 0.0613 0.0294 mg/L 07/24/23 18:08 07/25/23 15:46

Lab Sample ID: LCS 860-113846/32-A Client Sample ID: Lab Control Sample **Matrix: Water** Prep Type: Total/NA Analysis Batch: 114071 Prep Batch: 113846

Spike LCS LCS %Rec Added Result Analyte Qualifier Unit D %Rec Limits Total Phosphorus as P 0.250 0.2486 mg/L 99 90 - 110Total Phosphorus as PO4 0.766 0.7622 mg/L 99 90 - 120

Lab Sample ID: LCSD 860-113846/33-A Client Sample ID: Lab Control Sample Dup **Matrix: Water** Prep Type: Total/NA

Analysis Batch: 114071 Prep Batch: 113846 LCSD LCSD Spike %Rec RPD Added Result Qualifier Unit %Rec Limits RPD Limit Analyte Total Phosphorus as P 0.250 0.2492 100 90 - 110 20 mg/L 0 0.766 0.7640

Lab Sample ID: 820-9303-1 MS Client Sample ID: 4136223 Permit

**Matrix: Water** Prep Type: Total/NA **Analysis Batch: 114071** Prep Batch: 113846

mg/L

100

90 - 120

Sample Sample Spike MS MS Result Qualifier Added Result Qualifier Limits Analyte Unit D %Rec Total Phosphorus as P 2.97 0.250 3.124 4 90 - 110 mg/L 62 0.766 9.578 4 62 90 - 120 Total Phosphorus as PO4 9 11 mg/L

Lab Sample ID: 820-9303-1 MSD Client Sample ID: 4136223 Permit

**Matrix: Water** Prep Type: Total/NA Analysis Batch: 114071 Prep Batch: 113846

MSD MSD Sample Sample Spike %Rec RPD Result Qualifier Added Result Qualifier %Rec RPD Limit Analyte Unit D Limits Total Phosphorus as P 2 97 0.250 20 3.117 4 59 0 mg/L 90 - 110 Total Phosphorus as PO4 0.766 9.557 59 9 11 mg/L 90 - 12020

**Eurofins Lubbock** 

20

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

Method: 8000 - COD

Lab Sample ID: MB 860-113943/3

Lab Sample ID: LCS 860-113943/4

**Matrix: Water** 

Client Sample ID: Method Blank

Prep Type: Total/NA

Analysis Batch: 113943

мв мв

Analyte Result Qualifier RL MDL Unit Prepared Analyzed Dil Fac Chemical Oxygen Demand <3.36 U 20.0 3.36 mg/L 07/25/23 09:54

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analysis Batch: 113943

**Matrix: Water** 

	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Chemical Oxygen Demand	100	104.0		mg/L		104	90 - 110	 

Method: SM 2320B - Alkalinity

Lab Sample ID: MB 860-113305/3 Client Sample ID: Method Blank

Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113305

MB MB

<10.0 U

	Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Alkalinity	<4.00	U	4.00	4.00	mg/L			07/20/23 11:33	1
	Bicarbonate Alkalinity as CaCO3	<4.00	U	4.00	4.00	mg/L			07/20/23 11:33	1
l	Carbonate Alkalinity as CaCO3	<4.00	U	4.00	4.00	mg/L			07/20/23 11:33	1

Lab Sample ID: LCS 860-113305/4 **Client Sample ID: Lab Control Sample Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113305

	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Alkalinity	250	251.3		mg/L	_	101	85 - 115	 

Lab Sample ID: LCSD 860-113305/5 Client Sample ID: Lab Control Sample Dup Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113305

	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Alkalinity	250	253.6		mg/L		101	85 - 115	1	20

Method: SM 2510B - Conductivity, Specific Conductance

Lab Sample ID: MB 860-113430/2 Client Sample ID: Method Blank Prep Type: Total/NA

**Matrix: Water** 

Specific Conductance

Analyte

Analysis Batch: 113430

мв мв Result Qualifier MDL Unit Dil Fac Prepared Analyzed

> umho/cm @ 25C

10.0

Lab Sample ID: LCS 860-113430/3 **Client Sample ID: Lab Control Sample** 

10.0

**Matrix: Water** 

Analysis Batch: 113430

Analysis Baton: 110-100							
	Spike	LCS	LCS				%Rec
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits
Specific Conductance	1410	1422		umho/cm		101	85 - 115
				@ 25C			

**Eurofins Lubbock** 

Prep Type: Total/NA

07/21/23 12:01

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Client Sample ID: 4136223 Permit

Prep Type: Total/NA

Prep Type: Total/NA

Method: SM 2510B - Conductivity, Specific Conductance

Lab Sample ID: LCSD 860-113430/4

Analysis Batch: 113430

Client Sample ID: Lab Control Sample Dup **Matrix: Water** Prep Type: Total/NA

Spike LCSD LCSD %Rec RPD Analyte babbA Result Qualifier Unit %Rec Limits RPD Limit Specific Conductance 1410 1424 umho/cm 101 85 - 115 @ 25C

Lab Sample ID: 820-9303-1 DU

**Matrix: Water** 

Analysis Batch: 113430

	Sample	Sample	DU	DU				RPD
Analyte	Result	Qualifier	Result	Qualifier	Unit	D	RPD	Limit
Specific Conductance	2080		2082		umho/cm	_	0.1	20
					@ 25C			

Method: SM 2540C - Solids, Total Dissolved (TDS)

Lab Sample ID: MB 860-113611/1 Client Sample ID: Method Blank

**Matrix: Water** 

Analysis Batch: 113611

MB MB Result Qualifier RL MDL Unit Dil Fac Analyte Analyzed Prepared 5.00 Total Dissolved Solids <5.00 U 07/23/23 09:45 5.00 mg/L

Lab Sample ID: LCS 860-113611/2 **Client Sample ID: Lab Control Sample Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113611

		<b>Бріке</b>	LCS	LCS				%Rec	
Analyte		Added	Result	Qualifier	Unit	D	%Rec	Limits	
Total Dissolved Solids	 	1000	1007		ma/L		101	80 - 120	

Lab Sample ID: LCSD 860-113611/3 Client Sample ID: Lab Control Sample Dup Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113611

	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Total Dissolved Solids	 1000	1007		mg/L		101	80 - 120	0	10

Lab Sample ID: LLCS 860-113611/4 **Client Sample ID: Lab Control Sample** Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113611

	Spike	LLCS	LLCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Total Dissolved Solids	5.00	<5.00	U	mg/L		90	50 - 150	

Lab Sample ID: 820-9303-1 DU Client Sample ID: 4136223 Permit

**Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113611

DU DU RPD Sample Sample Result Qualifier Result Qualifier Analyte Unit **RPD** Limit Total Dissolved Solids 1170 1196 10 mg/L

Prep Type: Total/NA

Prep Type: Total/NA

Project/Site: TPDES Permit Application Renewal

Client: Parkhill Smith & Cooper Inc.

Method: SM 2540D - Solids, Total Suspended (TSS)

Lab Sample ID: MB 860-113947/1 Client Sample ID: Method Blank

**Matrix: Water** 

Analysis Batch: 113947

мв мв

Analyte Result Qualifier RLMDL Unit D Prepared Analyzed Dil Fac Total Suspended Solids <4.00 U 4.00 4.00 mg/L 07/25/23 10:18

Lab Sample ID: LCS 860-113947/2 Client Sample ID: Lab Control Sample **Matrix: Water** Prep Type: Total/NA

**Analysis Batch: 113947** 

Spike LCS LCS %Rec Added Result Qualifier Unit D %Rec Limits Total Suspended Solids 100 106.0 mg/L 106 80 - 120

Lab Sample ID: LCSD 860-113947/3 Client Sample ID: Lab Control Sample Dup Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113947

LCSD LCSD %Rec RPD Spike Analyte Added Result Qualifier Unit %Rec Limits RPD Limit 107.0 Total Suspended Solids 100 mg/L 107 80 - 120 10

Method: SM 4500 CI G - Chlorine, Residual

Lab Sample ID: MB 860-113790/3 Client Sample ID: Method Blank

**Matrix: Water** 

Analysis Batch: 113790

мв мв

Analyte Result Qualifier MDL Unit Dil Fac Prepared Analyzed Chlorine, Total Residual <0.0500 U 0.0500 07/24/23 13:42 0.0500 mg/L

Lab Sample ID: LCS 860-113790/4 **Client Sample ID: Lab Control Sample** Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113790

Spike LCS LCS %Rec Added Analyte Result Qualifier Unit %Rec Limits Chlorine, Total Residual 0.250 0.2591 104 85 - 115 mg/L

Lab Sample ID: LCSD 860-113790/5 Client Sample ID: Lab Control Sample Dup Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113790

LCSD LCSD Spike %Rec RPD Added Result Qualifier RPD Limit Analyte Unit D %Rec Limits 0.250 Chlorine, Total Residual 20 0.2670 mg/L 107 85 - 115

Lab Sample ID: 820-9303-1 MS Client Sample ID: 4136223 Permit Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113790

Sample Sample Spike MS MS %Rec Analyte Result Qualifier babbA Result Qualifier Unit %Rec Limits Chlorine, Total Residual < 0.0500 U HF 0.250 0.2591 mg/L 104 90 - 110

Prep Type: Total/NA

Prep Type: Total/NA

Prep Type: Total/NA

Prep Type: Total/NA

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Method: SM 4500 CI G - Chlorine, Residual (Continued)

Lab Sample ID: 820-9303-1 MSD Client Sample ID: 4136223 Permit

**Matrix: Water** Prep Type: Total/NA Analysis Batch: 113790

Sample Sample MSD MSD RPD Spike %Rec Analyte Result Qualifier Added Result Qualifier %Rec Limits RPD Limit Unit Chlorine, Total Residual <0.0500 UHF 0.250 0.2591 mg/L 104 90 - 110 0 20

Method: SM 4500 S2 D - Sulfide, Total

Lab Sample ID: MB 860-114017/3 Client Sample ID: Method Blank

**Matrix: Water** 

Analysis Batch: 114017

MB MB

Result Qualifier RL MDL Unit Dil Fac Analyte D Prepared Analyzed 0.100 Sulfide <0.0400 U 07/25/23 15:32 0.0400 mg/L

Lab Sample ID: LCS 860-114017/4 Client Sample ID: Lab Control Sample Prep Type: Total/NA

**Matrix: Water** 

**Analysis Batch: 114017** 

Spike LCS LCS %Rec Analyte Added Result Qualifier Unit D %Rec Limits Sulfide 1.00 0.9684 mg/L 97 90 - 110

Lab Sample ID: LCSD 860-114017/5 Client Sample ID: Lab Control Sample Dup Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 114017

Spike LCSD LCSD %Rec RPD Analyte Added Qualifier Unit %Rec **RPD** Limit Result Limits Sulfide 1.00 0.9699 mg/L 90 - 110 20

Method: SM 5210B - BOD, 5-Day

Lab Sample ID: SCB 860-113787/2 Client Sample ID: Method Blank

**Matrix: Water** 

Analysis Batch: 113787

SCB SCB Analyte Result Qualifier RL MDL Unit D Prepared Analyzed Dil Fac Biochemical Oxygen Demand 0.7740 0.0000020 0.0000020 mg/L 07/19/23 13:41

0

0

Lab Sample ID: USB 860-113787/1 Client Sample ID: Method Blank

**Matrix: Water** 

**Analysis Batch: 113787** 

USB USB

RL MDL D Analyte Result Qualifier Unit Prepared Analyzed Dil Fac 07/19/23 13:40 Biochemical Oxygen Demand 0.2650 0.0000020 0.0000020 mg/L 0 0

Lab Sample ID: LCS 860-113787/3 Client Sample ID: Lab Control Sample

**Matrix: Water** 

Analysis Batch: 113787

Spike LCS LCS %Rec Added Result Qualifier Unit %Rec Limits Biochemical Oxygen Demand 198 207.6 105 85 - 115 mg/L

Prep Type: Total/NA

Client Sample ID: Method Blank

Client Sample ID: Lab Control Sample

Client Sample ID: Lab Control Sample Dup

**Client Sample ID: Lab Control Sample** 

Client Sample ID: Method Blank

**Client Sample ID: Lab Control Sample** 

Client Sample ID: Lab Control Sample Dup

Method: SM 5310C - TOC

Lab Sample ID: MB 860-113874/3

**Matrix: Water** 

Analysis Batch: 113874

MR	MB	

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Organic Carbon	<0.500	U	1.00	0.500	mg/L			07/24/23 11:34	1

Lab Sample ID: LCS 860-113874/4

**Matrix: Water** 

Analysis Batch: 113874

	Spike	LCS	LCS				%Rec
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits
Total Organic Carbon	5.00	5.232		mg/L		105	90 - 110

Lab Sample ID: LCSD 860-113874/5

**Matrix: Water** 

Analysis Batch: 113874

	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Total Organic Carbon	5.00	5.235		mg/L		105	90 - 110	0	20

Lab Sample ID: LLCS 860-113887/16

**Matrix: Water** 

Analysis Batch: 113887

		Spike	LLCS	LLCS				%Rec	
Analyte		Added	Result	Qualifier Uni	t	D	%Rec	Limits	
Total Organic Carbon		1.00	1.212	mg.	'L		121	50 - 150	

Method: SM3500 CR B - Chromium, Hexavalent

Lab Sample ID: MB 860-113065/3

**Matrix: Water** 

Analysis Batch: 113065

MB MB

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chromium, hexavalent	< 0.00200	U	0.0100	0.00200	ma/L			07/19/23 13:37	1

Lab Sample ID: LCS 860-113065/4

**Matrix: Water** 

Analysis Batch: 113065

	Spike	LCS	LCS			%Rec	
Analyte	Added	Result	Qualifier	Unit I	D %Rec	Limits	
Chromium, hexavalent	0.200	0.2022		ma/L	101	80 - 120	

Lab Sample ID: LCSD 860-113065/5

**Matrix: Water** 

Analysis Batch: 113065									
	Spike	LCSD	LCSD				%Rec		RPD
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Chromium, hexavalent	0.200	0.2035		mg/L		102	80 - 120	1	20

#### **QC Sample Results**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

Prep Type: Total/NA

Method: SM3500 CR B - Chromium, Hexavalent (Continued)

Lab Sample ID: 820-9303-1 MS Client Sample ID: 4136223 Permit

**Matrix: Water** 

Analysis Batch: 113065

	Sample	Sample	Spike	MS	MS				%Rec	
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Chromium, hexavalent	<0.00200	U	0.200	0.1848		mg/L		92	80 - 120	 

Lab Sample ID: 820-9303-1 MSD Client Sample ID: 4136223 Permit **Matrix: Water** 

Prep Type: Total/NA

Prep Type: Total/NA

Analysis Batch: 113065

	Sample	Sample	Spike	MSD	MSD				%Rec		RPD
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Chromium, hexavalent	<0.00200	U	0.200	0.1861		mg/L		93	80 - 120	1	20

Method: SM5210B CBOD - Carbonaceous BOD, 5 Day

Lab Sample ID: SCB 860-113823/2 Client Sample ID: Method Blank

**Matrix: Water** Prep Type: Total/NA

Analysis Batch: 113823

SCB SCB Analyte Result Qualifier RL MDL Unit D Prepared Analyzed Dil Fac Carbonaceous Biochemical Oxygen 0.9600 0.0000020 0.0000020 mg/L 07/19/23 17:53

Lab Sample ID: USB 860-113823/1 Client Sample ID: Method Blank

**Matrix: Water** 

**Analysis Batch: 113823** USB USB

	000 000						
Analyte	Result Qualifier	RL	MDL Unit	D	Prepared	Analyzed	Dil Fac
Carbonaceous Biochemical Oxygen	0.1700	0.0000020	0.0000020 mg/L			07/19/23 17:51	1
Demand		0	0				

Lab Sample ID: LCS 860-113823/3 **Client Sample ID: Lab Control Sample** Prep Type: Total/NA

**Matrix: Water** 

Analysis Batch: 113823

		Spike	LCS	LCS				%Rec	
Analyte		Added	Result	Qualifier	Unit	D	%Rec	Limits	
Carbonaceous Biochemical		198	206.7		mg/L		104	85 - 115	
Oxygen Demand									

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

GC/MS VOA

Analysis Batch: 112934

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	624.1	
MB 860-112934/21	Method Blank	Total/NA	Water	624.1	
LCS 860-112934/14	Lab Control Sample	Total/NA	Water	624.1	
LCSD 860-112934/15	Lab Control Sample Dup	Total/NA	Water	624.1	

GC/MS Semi VOA

**Prep Batch: 113963** 

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	625	
MB 860-113963/1-A	Method Blank	Total/NA	Water	625	
LCS 860-113963/2-A	Lab Control Sample	Total/NA	Water	625	
LCSD 860-113963/3-A	Lab Control Sample Dup	Total/NA	Water	625	

Analysis Batch: 114044

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	625.1	113963
MB 860-113963/1-A	Method Blank	Total/NA	Water	625.1	113963
LCS 860-113963/2-A	Lab Control Sample	Total/NA	Water	625.1	113963
LCSD 860-113963/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	113963

**Prep Batch: 114275** 

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1 - RE	4136223 Permit	Total/NA	Water	625	
MB 860-114275/1-A	Method Blank	Total/NA	Water	625	
LCS 860-114275/2-A	Lab Control Sample	Total/NA	Water	625	
LCSD 860-114275/3-A	Lab Control Sample Dup	Total/NA	Water	625	

Analysis Batch: 114367

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1 - RE	4136223 Permit	Total/NA	Water	625.1	114275
MB 860-114275/1-A	Method Blank	Total/NA	Water	625.1	114275
LCS 860-114275/2-A	Lab Control Sample	Total/NA	Water	625.1	114275
LCSD 860-114275/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	114275

**GC Semi VOA** 

**Prep Batch: 113167** 

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batcl
820-9303-1	4136223 Permit	Total/NA	Water	608	
MB 860-113167/1-A	Method Blank	Total/NA	Water	608	
LCS 860-113167/2-A	Lab Control Sample	Total/NA	Water	608	
LCS 860-113167/4-A	Lab Control Sample	Total/NA	Water	608	
LCSD 860-113167/3-A	Lab Control Sample Dup	Total/NA	Water	608	
LCSD 860-113167/5-A	Lab Control Sample Dup	Total/NA	Water	608	

Analysis Batch: 113174

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	608.3	113167
MB 860-113167/1-A	Method Blank	Total/NA	Water	608.3	113167
LCS 860-113167/2-A	Lab Control Sample	Total/NA	Water	608.3	113167
LCSD 860-113167/3-A	Lab Control Sample Dup	Total/NA	Water	608.3	113167

Eurofins Lubbock

Job ID: 820-9303-1

7/31/2023

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### GC Semi VOA

#### Analysis Batch: 113186

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	608.3	113167
MB 860-113167/1-A	Method Blank	Total/NA	Water	608.3	113167
LCS 860-113167/4-A	Lab Control Sample	Total/NA	Water	608.3	113167
LCSD 860-113167/5-A	Lab Control Sample Dup	Total/NA	Water	608.3	113167

#### **Prep Batch: 113651**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	3511	
MB 860-113651/1-A	Method Blank	Total/NA	Water	3511	
LCS 860-113651/2-A	Lab Control Sample	Total/NA	Water	3511	
LCS 860-113651/4-A	Lab Control Sample	Total/NA	Water	3511	
LCSD 860-113651/3-A	Lab Control Sample Dup	Total/NA	Water	3511	
LCSD 860-113651/5-A	Lab Control Sample Dup	Total/NA	Water	3511	

#### **Analysis Batch: 114272**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	615	113651
MB 860-113651/1-A	Method Blank	Total/NA	Water	615	113651
LCS 860-113651/2-A	Lab Control Sample	Total/NA	Water	615	113651
LCS 860-113651/4-A	Lab Control Sample	Total/NA	Water	615	113651
LCSD 860-113651/3-A	Lab Control Sample Dup	Total/NA	Water	615	113651
LCSD 860-113651/5-A	Lab Control Sample Dup	Total/NA	Water	615	113651

#### **Analysis Batch: 114462**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	615	113651

#### **HPLC/IC**

#### Analysis Batch: 112992

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	300.0	
MB 860-112992/49	Method Blank	Total/NA	Water	300.0	
LCS 860-112992/50	Lab Control Sample	Total/NA	Water	300.0	
LCSD 860-112992/51	Lab Control Sample Dup	Total/NA	Water	300.0	
LLCS 860-112992/52	Lab Control Sample	Total/NA	Water	300.0	

#### Analysis Batch: 112993

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	300.0	
820-9303-1 - DL	4136223 Permit	Total/NA	Water	300.0	
MB 860-112993/3	Method Blank	Total/NA	Water	300.0	
MB 860-112993/49	Method Blank	Total/NA	Water	300.0	
LCS 860-112993/50	Lab Control Sample	Total/NA	Water	300.0	
LCSD 860-112993/51	Lab Control Sample Dup	Total/NA	Water	300.0	
LLCS 860-112993/6	Lab Control Sample	Total/NA	Water	300.0	

#### **Prep Batch: 113552**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	CWA_Prep	
MB 860-113552/1-A	Method Blank	Total/NA	Water	CWA_Prep	

**Eurofins Lubbock** 

Page 42 of 59

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

HPLC/IC (Continued)

_			
Prep	Batch:	113552	(Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method P	rep Batch
LCS 860-113552/2-A	Lab Control Sample	Total/NA	Water	CWA_Prep	
LCSD 860-113552/3-A	Lab Control Sample Dup	Total/NA	Water	CWA_Prep	

#### **Analysis Batch: 114338**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	632	113552
MB 860-113552/1-A	Method Blank	Total/NA	Water	632	113552
LCS 860-113552/2-A	Lab Control Sample	Total/NA	Water	632	113552
LCSD 860-113552/3-A	Lab Control Sample Dup	Total/NA	Water	632	113552

#### Metals

#### **Prep Batch: 113539**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batc
820-9303-1	4136223 Permit	Total Recoverable	Water	200.8	
MB 860-113539/1-A	Method Blank	Total Recoverable	Water	200.8	
LCS 860-113539/2-A	Lab Control Sample	Total Recoverable	Water	200.8	
LCSD 860-113539/3-A	Lab Control Sample Dup	Total Recoverable	Water	200.8	
LLCS 860-113539/4-A	Lab Control Sample	Total Recoverable	Water	200.8	

#### Analysis Batch: 113641

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total Recoverable	Water	200.8	113539
MB 860-113539/1-A	Method Blank	Total Recoverable	Water	200.8	113539
LCS 860-113539/2-A	Lab Control Sample	Total Recoverable	Water	200.8	113539
LCSD 860-113539/3-A	Lab Control Sample Dup	Total Recoverable	Water	200.8	113539
LLCS 860-113539/4-A	Lab Control Sample	Total Recoverable	Water	200.8	113539

#### **Prep Batch: 113872**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batc
820-9303-1	4136223 Permit	Total/NA	Water	245.1	<u> </u>
MB 860-113872/10-A	Method Blank	Total/NA	Water	245.1	
LCS 860-113872/11-A	Lab Control Sample	Total/NA	Water	245.1	
LCSD 860-113872/12-A	Lab Control Sample Dup	Total/NA	Water	245.1	
LLCS 860-113872/13-A	Lab Control Sample	Total/NA	Water	245.1	

#### Analysis Batch: 114081

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	245.1	113872
MB 860-113872/10-A	Method Blank	Total/NA	Water	245.1	113872
LCS 860-113872/11-A	Lab Control Sample	Total/NA	Water	245.1	113872
LCSD 860-113872/12-A	Lab Control Sample Dup	Total/NA	Water	245.1	113872
LLCS 860-113872/13-A	Lab Control Sample	Total/NA	Water	245.1	113872

#### **General Chemistry**

#### Analysis Batch: 113065

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM3500 CR B	
MB 860-113065/3	Method Blank	Total/NA	Water	SM3500 CR B	
LCS 860-113065/4	Lab Control Sample	Total/NA	Water	SM3500 CR B	
LCSD 860-113065/5	Lab Control Sample Dup	Total/NA	Water	SM3500 CR B	

**Eurofins Lubbock** 

7/31/2023

Page 43 of 59

Job ID: 820-9303-1

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### **General Chemistry (Continued)**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1 MS	4136223 Permit	Total/NA	Water	SM3500 CR B	
820-9303-1 MSD	4136223 Permit	Total/NA	Water	SM3500 CR B	

#### **Prep Batch: 113078**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	BOD Prep	

#### **Prep Batch: 113123**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	BOD Prep	

#### Analysis Batch: 113251

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	350.1	
MB 860-113251/134	Method Blank	Total/NA	Water	350.1	
LCS 860-113251/135	Lab Control Sample	Total/NA	Water	350.1	
LCSD 860-113251/136	Lab Control Sample Dup	Total/NA	Water	350.1	

#### Analysis Batch: 113305

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 2320B	
MB 860-113305/3	Method Blank	Total/NA	Water	SM 2320B	
LCS 860-113305/4	Lab Control Sample	Total/NA	Water	SM 2320B	
LCSD 860-113305/5	Lab Control Sample Dup	Total/NA	Water	SM 2320B	

#### Analysis Batch: 113328

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 4500 H+ B	

#### **Prep Batch: 113429**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	Distill/CN	_
MB 860-113429/30-A	Method Blank	Total/NA	Water	Distill/CN	
MB 860-113429/47-A	Method Blank	Total/NA	Water	Distill/CN	
MB 860-113429/4-A	Method Blank	Total/NA	Water	Distill/CN	
LCS 860-113429/48-A	Lab Control Sample	Total/NA	Water	Distill/CN	
LCS 860-113429/5-A	Lab Control Sample	Total/NA	Water	Distill/CN	
LCSD 860-113429/32-A	Lab Control Sample Dup	Total/NA	Water	Distill/CN	
LCSD 860-113429/49-A	Lab Control Sample Dup	Total/NA	Water	Distill/CN	
LLCS 860-113429/6-A	Lab Control Sample	Total/NA	Water	Distill/CN	

#### Analysis Batch: 113430

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 2510B	
MB 860-113430/2	Method Blank	Total/NA	Water	SM 2510B	
LCS 860-113430/3	Lab Control Sample	Total/NA	Water	SM 2510B	
LCSD 860-113430/4	Lab Control Sample Dup	Total/NA	Water	SM 2510B	
820-9303-1 DU	4136223 Permit	Total/NA	Water	SM 2510B	

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

**General Chemistry** 

Analysis Batch: 113542

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	335.4	113429
MB 860-113429/30-A	Method Blank	Total/NA	Water	335.4	113429
MB 860-113429/47-A	Method Blank	Total/NA	Water	335.4	113429
MB 860-113429/4-A	Method Blank	Total/NA	Water	335.4	113429
LCS 860-113429/48-A	Lab Control Sample	Total/NA	Water	335.4	113429
LCS 860-113429/5-A	Lab Control Sample	Total/NA	Water	335.4	113429
LCSD 860-113429/32-A	Lab Control Sample Dup	Total/NA	Water	335.4	113429
LCSD 860-113429/49-A	Lab Control Sample Dup	Total/NA	Water	335.4	113429
LLCS 860-113429/6-A	Lab Control Sample	Total/NA	Water	335.4	113429

Analysis Batch: 113611

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 2540C	
MB 860-113611/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 860-113611/2	Lab Control Sample	Total/NA	Water	SM 2540C	
LCSD 860-113611/3	Lab Control Sample Dup	Total/NA	Water	SM 2540C	
LLCS 860-113611/4	Lab Control Sample	Total/NA	Water	SM 2540C	
820-9303-1 DU	4136223 Permit	Total/NA	Water	SM 2540C	

Analysis Batch: 113695

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	1664B
MB 860-113695/1	Method Blank	Total/NA	Water	1664B
LCS 860-113695/2	Lab Control Sample	Total/NA	Water	1664B
LCSD 860-113695/3	Lab Control Sample Dup	Total/NA	Water	1664B

Analysis Batch: 113787

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 5210B	113078
SCB 860-113787/2	Method Blank	Total/NA	Water	SM 5210B	
USB 860-113787/1	Method Blank	Total/NA	Water	SM 5210B	
LCS 860-113787/3	Lab Control Sample	Total/NA	Water	SM 5210B	

Analysis Batch: 113790

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 4500 CI G	
MB 860-113790/3	Method Blank	Total/NA	Water	SM 4500 CI G	
LCS 860-113790/4	Lab Control Sample	Total/NA	Water	SM 4500 CI G	
LCSD 860-113790/5	Lab Control Sample Dup	Total/NA	Water	SM 4500 CI G	
820-9303-1 MS	4136223 Permit	Total/NA	Water	SM 4500 CI G	
820-9303-1 MSD	4136223 Permit	Total/NA	Water	SM 4500 CI G	

Prep Batch: 113822

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	351.2	
MB 860-113822/4-A	Method Blank	Total/NA	Water	351.2	
LCS 860-113822/6-A	Lab Control Sample	Total/NA	Water	351.2	
LCSD 860-113822/7-A	Lab Control Sample Dup	Total/NA	Water	351.2	
LLCS 860-113822/5-A	Lab Control Sample	Total/NA	Water	351.2	

Page 45 of 59

Job ID: 820-9303-1

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### **General Chemistry**

#### Analysis Batch: 113823

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM5210B CBOD	113123
SCB 860-113823/2	Method Blank	Total/NA	Water	SM5210B CBOD	
USB 860-113823/1	Method Blank	Total/NA	Water	SM5210B CBOD	
LCS 860-113823/3	Lab Control Sample	Total/NA	Water	SM5210B CBOD	

#### **Prep Batch: 113846**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	365.2/365.3/365	
MB 860-113846/31-A	Method Blank	Total/NA	Water	365.2/365.3/365	
LCS 860-113846/32-A	Lab Control Sample	Total/NA	Water	365.2/365.3/365	
LCSD 860-113846/33-A	Lab Control Sample Dup	Total/NA	Water	365.2/365.3/365	
820-9303-1 MS	4136223 Permit	Total/NA	Water	365.2/365.3/365	
820-9303-1 MSD	4136223 Permit	Total/NA	Water	365.2/365.3/365	

#### Analysis Batch: 113874

Lab Sample ID 820-9303-1	Client Sample ID 4136223 Permit	Prep Type Total/NA	Matrix Water	Method SM 5310C	Prep Batch
MB 860-113874/3	Method Blank	Total/NA	Water	SM 5310C	
LCS 860-113874/4	Lab Control Sample	Total/NA	Water	SM 5310C	
LCSD 860-113874/5	Lab Control Sample Dup	Total/NA	Water	SM 5310C	

#### Analysis Batch: 113887

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LLCS 860-113887/16	Lab Control Sample	Total/NA	Water	SM 5310C	

#### Analysis Batch: 113943

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	8000	
MB 860-113943/3	Method Blank	Total/NA	Water	8000	
LCS 860-113943/4	Lab Control Sample	Total/NA	Water	8000	

#### Analysis Batch: 113947

Lab Sample ID 820-9303-1	Client Sample ID 4136223 Permit	Prep Type Total/NA	Matrix Water	Method SM 2540D	Prep Batch
MB 860-113947/1	Method Blank	Total/NA	Water	SM 2540D	
LCS 860-113947/2	Lab Control Sample	Total/NA	Water	SM 2540D	
LCSD 860-113947/3	Lab Control Sample Dup	Total/NA	Water	SM 2540D	

#### Analysis Batch: 113972

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	360.1	

#### Analysis Batch: 114017

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 4500 S2 D	
MB 860-114017/3	Method Blank	Total/NA	Water	SM 4500 S2 D	
LCS 860-114017/4	Lab Control Sample	Total/NA	Water	SM 4500 S2 D	
LCSD 860-114017/5	Lab Control Sample Dup	Total/NA	Water	SM 4500 S2 D	

**Eurofins Lubbock** 

Page 46 of 59

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### **General Chemistry**

Analysis Batch: 114059
------------------------

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	SM 3500 CR B	

#### Analysis Batch: 114070

<b>Lab Sample ID</b> 820-9303-1	Client Sample ID 4136223 Permit	Prep Type Total/NA	Matrix Water	Method 351.2	Prep Batch 113822
MB 860-113822/4-A	Method Blank	Total/NA	Water	351.2	113822
LCS 860-113822/6-A	Lab Control Sample	Total/NA	Water	351.2	113822
LCSD 860-113822/7-A	Lab Control Sample Dup	Total/NA	Water	351.2	113822
LLCS 860-113822/5-A	Lab Control Sample	Total/NA	Water	351.2	113822

#### Analysis Batch: 114071

<b>Lab Sample ID</b> 820-9303-1	Client Sample ID 4136223 Permit	Prep Type Total/NA	Matrix Water	Method 365.1	Prep Batch 113846
MB 860-113846/31-A	Method Blank	Total/NA	Water	365.1	113846
LCS 860-113846/32-A	Lab Control Sample	Total/NA	Water	365.1	113846
LCSD 860-113846/33-A	Lab Control Sample Dup	Total/NA	Water	365.1	113846
820-9303-1 MS	4136223 Permit	Total/NA	Water	365.1	113846
820-9303-1 MSD	4136223 Permit	Total/NA	Water	365.1	113846

#### Analysis Batch: 114179

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	Nitrogen.Org	

#### Analysis Batch: 114830

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-9303-1	4136223 Permit	Total/NA	Water	Total Nitrogen	

#### **Biology**

#### **Analysis Batch: 1840**

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
820-0303-1	4136223 Dormit	Total/NIA	Water	0223B	

Eurofins Lubbock

7/31/2023

#### **Lab Chronicle**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Client Sample ID: 4136223 Permit

Date Collected: 07/18/23 09:30 Date Received: 07/18/23 11:50

Lab Sample ID: 820-9303-1

Matrix: Water

Job ID: 820-9303-1

	Batch	Batch		Dil	Initial	Final	Batch	Prepared		
Prep Type	Type	Method	Run	Factor	Amount	Amount	Number	or Analyzed	Analyst	Lab
Total/NA	Analysis	624.1		1	5 mL	5 mL	112934	07/19/23 19:37	TTD	EET HOU
Total/NA	Prep	625			1000 mL	1.00 mL	113963	07/25/23 10:28	DR	EET HOU
Total/NA	Analysis	625.1		1	1 mL	1 mL	114044	07/26/23 00:36	PXS	EET HOU
Total/NA	Prep	625	RE		1000 mL	1.00 mL	114275	07/26/23 14:35	DR	EET HOU
Total/NA	Analysis	625.1	RE	1	1 mL	1 mL	114367	07/27/23 14:51	LPL	EET HOU
Total/NA	Prep	608			1000 mL	1.00 mL	113167	07/20/23 07:48	DR	EET HOU
Total/NA	Analysis	608.3		1			113186	07/20/23 13:59	WP	EET HOU

	Batch	Batch		Dil	Initial	Final	Batch	Prepared		
Prep Type	Type	Method	Run	Factor	Amount	Amount	Number	or Analyzed	Analyst	Lab
Total/NA	Analysis	624.1		1	5 mL	5 mL	112934	07/19/23 19:37	TTD	EET HOU
Total/NA	Prep	625			1000 mL	1.00 mL	113963	07/25/23 10:28	DR	EET HOU
Total/NA	Analysis	625.1		1	1 mL	1 mL	114044	07/26/23 00:36	PXS	EET HOU
Total/NA	Prep	625	RE		1000 mL	1.00 mL	114275	07/26/23 14:35	DR	EET HOU
Total/NA	Analysis	625.1	RE	1	1 mL	1 mL	114367	07/27/23 14:51	LPL	EET HOU
Total/NA	Prep	608			1000 mL	1.00 mL	113167	07/20/23 07:48	DR	EET HOU
Total/NA	Analysis	608.3		1			113186	07/20/23 13:59	WP	EET HOU
Total/NA	Prep	608			1000 mL	1.00 mL	113167	07/20/23 07:48	DR	EET HOU
Total/NA	Analysis	608.3		1			113174	07/20/23 15:28	WP	EET HOU
Total/NA	Prep	3511			49.8 mL	4 mL	113651	07/23/23 19:55	JN	EET HOU
Total/NA	Analysis	615		1			114272	07/26/23 19:41	WP	EET HOU
Total/NA	Prep	3511			49.8 mL	4 mL	113651	07/23/23 19:55	JN	EET HOU
Total/NA	Analysis	615		1			114462	07/27/23 19:12	WP	EET HOU
Total/NA	Analysis	300.0		1			112992	07/19/23 19:25	WP	EET HOU
Total/NA	Analysis	300.0		1			112993	07/19/23 19:25	WP	EET HOU
Total/NA	Analysis	300.0	DL	10			112993	07/19/23 19:33	WP	EET HOU
Total/NA	Prep	CWA_Prep			1000 mL	10 mL	113552	07/22/23 06:44	DR	EET HOU
Total/NA	Analysis	632		1			114338	07/26/23 08:09	AA	EET HOU
Total Recovera	able Prep	200.8			50 mL	50 mL	113539	07/21/23 20:53	AGR	EET HOU
Total Recovera	able Analysis	200.8		1			113641	07/22/23 23:57	DP	EET HOU
Total/NA	Prep	245.1			50 mL	50 mL	113872	07/24/23 20:20	AGR	EET HOU
Total/NA	Analysis	245.1		1			114081	07/25/23 16:30	SHZ	EET HOU
Total/NA	Analysis	1664B		1	1000 mL	1000 mL	113695	07/24/23 09:53	JCM	EET HOU
Total/NA	Prep	Distill/CN			6 mL	6 mL	113429	07/21/23 11:49	CL	EET HOU
Total/NA	Analysis	335.4		1			113542	07/21/23 20:22	CL	EET HOU
Total/NA	Analysis	350.1		1	10 mL	10 mL	113251	07/19/23 23:41	ADL	EET HOU
Total/NA	Prep	351.2			20 mL	20 mL	113822	07/24/23 16:54	LD	EET HOU
Total/NA	Analysis	351.2		1			114070	07/25/23 15:28	AA	EET HOU
Total/NA	Analysis	360.1		1			113972	07/25/23 10:59	HN	EET HOU
Total/NA	Prep	365.2/365.3/365			10 mL	10 mL	113846	07/24/23 18:08	LD	EET HOU
Total/NA	Analysis	365.1		3.06			114071	07/25/23 16:13	AA	EET HOU
Total/NA	Analysis	8000		1	2 mL	2 mL	113943	07/25/23 10:00	HN	EET HOU
Total/NA	Analysis	Nitrogen,Org		1			114179	07/26/23 10:27	MC	EET HOU
Total/NA	Analysis	SM 2320B		1			113305	07/20/23 12:24	TL	EET HOU
Total/NA	Analysis	SM 2510B		1			113430	07/21/23 12:01	TL	EET HOU
Total/NA	Analysis	SM 2540C		1	50 mL	200 mL	113611	07/23/23 09:45	ОН	EET HOU
Total/NA	Analysis	SM 2540D		1	500 mL	1000 mL	113947	07/25/23 10:18	ОН	EET HOU
Total/NA	Analysis	SM 3500 CR B		1			114059	07/25/23 15:38	MC	EET HOU
Total/NA	Analysis	SM 4500 CI G		1	10 mL	10 mL	113790	07/24/23 13:42	SCI	EET HOU
Total/NA	Analysis	SM 4500 H+ B		1			113328	07/20/23 17:46	TL	EET HOU
Total/NA	Analysis	SM 4500 S2 D		1	7.5 mL	7.5 mL	114017	07/25/23 15:32	SCI	EET HOU
IOIAI/IVA	Allalysis	31VI 430U 32 D		ı	I.J IIIL	I.J IIIL	114017	01120120 10.02	301	LL1 HUU

#### **Lab Chronicle**

Initial

Amount

280 mL

40 mL

25 mL

280 mL

100 mL

Dil

1

1

Factor

Run

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Batch

Туре

Prep

Analysis

Analysis

Analysis

Analysis

Analysis

Analysis

Prep

Client Sample ID: 4136223 Permit

Date Collected: 07/18/23 09:30 Date Received: 07/18/23 11:50

Prep Type

Total/NA

Total/NA

Total/NA

Total/NA

Total/NA

Total/NA

Total/NA

Total/NA

Lab Sample ID: 820-9303-1

Matrix: Water

EET HOU

EET LUB

Job ID: 820-9303-1

Final	Batch	Prepared			
Amount	Number	or Analyzed	Analyst	Lab	
	113078	07/19/23 13:00	ALL	EET HOU	
300 mL	113787	07/19/23 15:23	HN	EET HOU	
40 mL	113874	07/24/23 12:20	YG	EET HOU	
25 mL	113065	07/19/23 13:37	TL	EET HOU	
	113123	07/19/23 16:08	ALL	EET HOU	
300 mL	113823	07/19/23 18:22	HN	EET HOU	

MC

LT

07/30/23 15:28

07/18/23 16:14

114830

1840

100 mL

Laboratory References:

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

Batch

Method

BOD Prep

SM 5210B

SM 5310C

**BOD Prep** 

9223B

SM3500 CR B

SM5210B CBOD

Total Nitrogen

EET LUB = Eurofins Lubbock, 6701 Aberdeen Ave., Suite 8, Lubbock, TX 79424, TEL (806)794-1296

5

5

7

9

10

13

14

#### **Accreditation/Certification Summary**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

#### **Laboratory: Eurofins Lubbock**

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Pr	ogram	Identification Number	Expiration Date
Texas	NE	ELAP	T104704219-23-29	03-03-24
The following analytes	are included in this report, bu	ut the laboratory is not certif	ied by the governing authority. This list ma	ay include analytes f
The following analytes the agency does not of	• •	ut the laboratory is not certif	ied by the governing authority. This list ma	ay include analytes fo
0 ,	• •	ut the laboratory is not certif Matrix	ied by the governing authority. This list ma Analyte	ay include analytes f

#### **Laboratory: Eurofins Houston**

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Texas	NELAP	T104704215-23-50	06-30-24

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
365.1	365.2/365.3/365	Water	Total Phosphorus as PO4
608.3	608	Water	Polychlorinated biphenyls, Total
615	3511	Water	Hexachlorophene
624.1		Water	1,2,4-Trichlorobenzene
624.1		Water	1,3-Dichloropropene, Total
624.1		Water	Hexachlorobutadiene
624.1		Water	Naphthalene
624.1		Water	Trihalomethanes, Total
625.1	625	Water	Hexachlorophene
625.1	625	Water	m+p-Cresol
632	CWA_Prep	Water	Diuron
Nitrogen,Org		Water	Nitrogen, Organic
SM 2320B		Water	Bicarbonate Alkalinity as CaCO3
SM 2320B		Water	Carbonate Alkalinity as CaCO3
SM 3500 CR B		Water	Cr (III)
SM 4500 H+ B		Water	Temperature
Total Nitrogen		Water	Nitrogen, Total

5

6

8

10

4.6

13

14

#### **Method Summary**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Method	Method Description	Protocol	Laboratory
624.1	Volatile Organic Compounds (GC/MS)	EPA	EET HOU
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET HOU
608.3	Organochlorine Pesticides in Water	EPA	EET HOU
608.3	Polychlorinated Biphenyls (PCBs) (GC)	EPA	EET HOU
615	Herbicides (GC)	EPA-01	EET HOU
300.0	Anions, Ion Chromatography	EPA	EET HOU
632	Carbamate and Urea Pesticides (HPLC)	EPA-01	EET HOU
200.8	Metals (ICP/MS)	EPA	EET HOU
245.1	Mercury (CVAA)	EPA	EET HOU
1664B	HEM and SGT-HEM	1664B	EET HOU
335.4	Cyanide, Total	EPA	EET HOU
350.1	Nitrogen, Ammonia	EPA	EET HOU
351.2	Nitrogen, Total Kjeldahl	EPA	EET HOU
360.1	Oxygen, Dissolved	EPA	EET HOU
365.1	Phosphorus, Total	EPA	EET HOU
8000	COD	Hach	EET HOU
Nitrogen,Org	Nitrogen, Organic	EPA	EET HOU
SM 2320B	Alkalinity	SM	EET HOU
SM 2510B	Conductivity, Specific Conductance	SM	EET HOU
SM 2540C	Solids, Total Dissolved (TDS)	SM	EET HOU
SM 2540D	Solids, Total Suspended (TSS)	SM	EET HOU
SM 3500 CR B	Chromium, Trivalent	SM	EET HOU
SM 4500 CI G	Chlorine, Residual	SM	EET HOU
SM 4500 H+ B	pH	SM	EET HOU
SM 4500 S2 D	Sulfide, Total	SM	EET HOU
SM 5210B	BOD, 5-Day	SM	EET HOU
SM 5310C	TOC	SM	EET HOU
SM3500 CR B	Chromium, Hexavalent	SM	EET HOU
SM5210B CBOD	Carbonaceous BOD, 5 Day	SM	EET HOU
Total Nitrogen	Nitrogen, Total	EPA	EET HOU
9223B	Coliforms, Total, and E.Coll (Colilert - Quanti Tray)	SM	EET LUB
200.8	Preparation, Total Recoverable Metals	EPA	EET HOU
245.1	Preparation, Mercury	EPA	EET HOU
351.2	Nitrogen, Total Kjeldahl	EPA	EET HOU
3511	Microextraction of Organic Compounds	SW846	EET HOU
365.2/365.3/365	Phosphorus, Total	EPA	EET HOU
608	Liquid-Liquid Extraction (Separatory Funnel)	EPA	EET HOU
625	Liquid-Liquid Extraction	EPA	EET HOU
BOD Prep	Preparation, BOD	SM	EET HOU
CWA_Prep	Liquid-Liquid Extraction (Separatory Funnel)	EPA	EET HOU
Distill/CN	Distillation, Cyanide	None	EET HOU

#### **Protocol References:**

1664B = EPA-821-98-002

EPA = US Environmental Protection Agency

EPA-01 = "Methods For The Determination Of Nonconventional Pesticides In Municipal And Industrial Wastewater", EPA/821/R/92/002, April 1992.

Hach = Hach Company

None = None

SM = "Standard Methods For The Examination Of Water And Wastewater"

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

**Eurofins Lubbock** 

Job ID: 820-9303-1

#### **Method Summary**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

Job ID: 820-9303-1

 Method
 Method Description
 Protocol
 Laboratory

Laboratory References:

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

EET LUB = Eurofins Lubbock, 6701 Aberdeen Ave., Suite 8, Lubbock, TX 79424, TEL (806)794-1296

4

7

8

9

11

10

13

114

#### **Sample Summary**

Client: Parkhill Smith & Cooper Inc.

Project/Site: TPDES Permit Application Renewal

 Lab Sample ID
 Client Sample ID
 Matrix
 Collected
 Received

 820-9303-1
 4136223 Permit
 Water
 07/18/23 09:30
 07/18/23 11:50

Job ID: 820-9303-1

3

4

5

7

8

10

11

16

14

Chain of Custody

Midland, TX (432) 704-5440, San Antonio, TX (210) \$09-3334 EL Paso, TX (915) 585,3443, Lubbock, TX (806) 794-1296 Hobbs, NM (575) 392-7550, Carlsbad, NM (575) 988-3199 Houston, TX (281) 240-4200, Dallas, TX (214) 902-0300

Environment Testing Xenco

Fins

Loc: 820

320-9303 Chain of Custody	_
3 Chain of Custod	
3 Chain of 0	Sustod
3 Che	ain of O
	မို

Daniel Manager	Kneek		Bill to: Of different	1		Work Order Comments	Comments
			Company Name		8	Program: UST/PST   PRP   Br	Brownfields RRC Superfund
	85 th GF		Address:		Str	olect:	1
e ZIP:	4,428	79472	City, State ZIP:		Re	Reporting: Level      Level	PŚT/UST ☐ TRRP ☐ LevelIV ☐
		Email:			0	Deliverables: EDD 🗌 AD	ADaPT ☐ Other:
Project Name:	enerue	Turn A	Around		ANALYSIS REQUEST		Preservative Codes
Ser:	23	Routine	Rush	Pres. Code			None: NO DI Water: H <sub>2</sub> O
	Trees	Due Date:					Cool: Cool MeOH: Me
er's Name:	1 Belcher	TAT starts the	TAT starts the day received by	Y			
PO #:		the lab, if rec	erved by 4:50pm				H <sub>2</sub> SC 4: H <sub>2</sub> NaOH: Na
SAMPLE RECEIPT Temp Blank:	Blank: Yes (N)	Wet Ice:	© No	ietei Sol			H <sub>3</sub> PO <sub>4</sub> : HP
Samples Received Intact: (Fe) No	No Thermometer ID:	er ID:	18-4				NaHSO 4: NABIS
Cooler Custody Seals: Yes No	Correction Factor:	Factor:	-0.1	₹ V			Na2S2O3: NaSO 3
Sample Custody Seals: Yes No	Temperature Reading:	re Reading:	5.1	•			Zn Acetate+NaOH: Zn
Total Containers:	_	Corrected Temperature:	5.0	60			NaOH+Ascorbic Acid: SAPC
Sample Identification	Matrix Sampled	Time	Depth Grab/	\$ jo#			Sample Comments
0127772 2000	Ť	0700	dipo				
11) port) (seiner w		76-1					
Total 200.7 / 6010 200.8 / 6020:		RCRA 13PP TCLP/S	8RCRA 13PPM Texas 11 A TCLP / SPLP 6010 : 8RC	A Sb As Ba Be B Cd C	A 13PPM Texas 11 Al'Sb As Ba Be B Cd Ca Cr Co Cu Fe Pb Mg Mn Mo Ni K TCLP/SPLP6010 : 8RCRA Sb As Ba Be Cd Cr Co Cu Pb Mn Mo Ni Se Ag Tl U	Zi K Se	Ag SiO <sub>3</sub> Na Sr 11 Sn U V Zn Hg:1631/245.1/2476 / 7471
In the Comment and relinquishment of samples constitutes a valid purchase order from client company to Eurofins Xenco, its affiliates and subcontractors. It assigns standard terms and conditions of any responsibility for any losses or expenses incurred by the client if such losses are due to circumstances beyond the control of any responsibility for any losses or expenses incurred by the client if such losses are due to circumstances beyond the control of the control	nent of samples constitutes a e cost of samples and shall no ill be applied to each project	valid purchase ord t assume any respo and a charge of \$5	er from client company nsibility for any losses o for each sample submit	to Eurofins Xenco, its affiliates and expenses incurred by the dient if ed to Eurofins Xenco, but not anal	subcontractors. It assigns standard terms and such losses are due to circumstances beyond thyzed. These terms will be enforced unless previous	conditions e control ously negotiated.	
Relinquished by: (Signature)	Received	Received by: (Signature)	(0	Date/Time	Relinquished by: (Signature)	Received by (Signature)	ret Detection
tankered Pallem	alla)	11	" TIME	04/1808/1/2	2		
	/		1. 1.1		4		
				*	9		

## 🔅 eurofins

Environment Testing

# **Chain of Custody Record**

Eurofins Lubbock		4952C	!
6701 Aberdeen Ave. Suite 8	Chain of Custody Boostd	11 PE	euro Seuro
Lubbock, TX 79424	oliani oi castoay Necota		3
Phone: 806-794-1296			
	Sampler, Lab PM:	Camer Tracking No(s).	COC No.

Client Information (Sub Contract Lab)	Sampler		Builes	Lab PM: Builes, John				Š	Jamer Tracking No(s);	ng No(s):		<u>3 8</u>	COC No: 820-7396.1	
Client Contact: Shtipping/Receiving	Phone:		E-Mail: John.I	3uiles@et.	eurofinsu	IS.COM		State	State of Origin: Texas		[	Page: Page	Page: Page 1 of 3	
Campany. Eurofins Ervironment Testing South Centr			8.2	Accreditations Required (See note): NELAP Texas	Required ( xas	See note)	   					1.00 # 820-9	Job #: 820-9303-1	
Address: 4145 Greenbriar Dr	Due Date Requested: 7/20/2023		   			Ana	Analysis Requested	edues	te	ļ		P. P.	Preservation Codes:	Hexana
City. Stafford	TAT Requested (days):			100 T	├			_	-		-	A B C		None AsNaO2
State, Zp: TX, 77477	·												пαп	Na2O4S Na2SO3
Phone: 281-240-4200(Tel)	PO#:											r O I		H2SO4 TSP Dodecahydrate
Email:	#OM			°. ((4)	_					_			lce V	
Project Name: TPDES Permit Application Renewal	Project #: 82000843			lita().			borite					मंग्री(म् ४ न		
Site:	SSOW#;			(Ų) (ų[::			M lesc						<b>L</b>	
Sample Identification - Client ID (Lab ID)	Sample Date Time	Sample Type (C=comp,	Matrix (Wewater Steald, Owwateloff, STETEL	TREASE NP/ (MOI	4200°CF°G	SM4500_52_D	3330B\ (WOD) FO	2540C_Calcd	935.4/Dietifi_CN	/ Vitrogen, Total	IN \grO,nego11IN qe19_236\f,286	भव <b>ाक्षणप्रा</b> क्षिक	Special Instructions/Note:	rctions/Note:
4136223 Permit (820-9303-1)	7/18/23 09:30		Water	×	×	×	×	×	×	×	×	1 (8)	Filtered(0.45um) &	Filtered(0.45um) &
					ļ			L	-		-		O VIOLIDO PARA DE	Dalles Cook letter
					-						-			
				_			-	-	<u> </u>	ļ				
												San T		
			_		-		_							
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratory or other instructions will be provided. Any changes to laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/lests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing South Central, LLC altertion in the State of Origin listed above for analysis/lests/matrix being analyzed, the samples be surrent to date, return the signed Chain of Custody attesting South Central, LLC altertion immediately, if all requested accreditations are current to date, return the signed Chain of Custody attesting South Central, LLC altertion immediately, if all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central, LLC altertion immediately.	t Testing South Central, LLC pla ove for analysis/tests/matrix beil rtral, LLC attention immediately.	ces the ownership or analyzed, the sar If all requested acc	of method, analyt mples must be st creditations are c	e & accredita ripped back to urrent to date	ion compliant the Eurof.	ance upol ins Enviro signed C	nour subco nment Tes hain of Cu	nthact lat ting Sout stody atte	oratories 1 Central, sting to s	. This se LLC lab	mple ship pratory or fiance to	pment is for other instri Eurofins Er	warded under chain⊸ uctions will be provide ivironment Testing Sc	of-custody. If the cd. Any changes to buth Central, LLC.
Possible Hazard Identification				Sample	Disposa	I (A fee	з тау Бе	asses	sed if s	ample	s are re	stained k	Sample Disposal ( A fee may be assessed if samples are retained longer than 1 month)	nth)
Uncontinued Deliverable Requested: I II III, IV Other (specify)	Primary Deliverable Rank: 2	K: 2		Special Instructions/QC Requirements:	Return To Client pecial Instructions/QC	Client ns/QC	Requiren	Dispo ents:	Disposal By Lab ents:	ge	]	Archive For		Months
The Paint is to be a second to the second to			ľ		l	1	•		i i	į	إ	ł		
	Date:		٦	i me					Memod	in Singing II	į į			
i Tayler	7/18/23	002/	Company	Yece Yece	Received by:	ŭ	FedEX			Date/Time:	:e: E:		8	Сотрапу
FedEX	Date/Ime:		Company	Recei	Received by:	2	erca			Date/Time:	īme: 7/1	7/19/2023 10:13		Company EX
	Date/Time:		Company	Recei	Received by:	,	1)			Date/Time		Temp:	IR ID	Company HOLL338
Custody Seals Intact: Custody Seal No.				Coole	Tempera	၁ <u>. (</u> s)arr	Cooler Temperature(s) C and Other Remarks.	Remarks			პ გ 	C/F -0.3 \ \Corrected Tem	2	
											1	1	ارا الا	

Preserved(2.5mlCR+6Buffer\_00001&4.0ml None
AsnaO2
Na2O4S
Na2SO3
Na2SO3
H2SO4
TSP Dodecahydrate
Acetone tote. Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratory or other instructions will be provided. Any changes to aboratory does not currently maintain accreditation in the State of Origin isled above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofine Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to atte, return the signed Chain of Custody attesting to Eurofins Environment Testing South Central, LLC. Months Sample Disposal ( A fee may be assessed if samples are retained longer than 1 month)

Return To Client Disposal By Lab Archive For Won
Special Instructions/QC Requirements: 820-9303-1 Preservation Codes Page 2 of 3 COC No: 820-7396.2 2 DI Water EDTA EDA Amchior HCL NaOH 2 by t × 3500\_CR\_B\_Pres Date/Time: 808 OTT qe14\_808\zeq\_£.808 × Method of Shipment × B\_680\_0028 State of Origin: Texas × efetoT gnibuloni eB39 B39\_qerq\_808iB39\_6.808 Analysis Requested × 625.1/625\_Prep (MOD) Priority Pollutant List Cooler Temperature(s) °C and Other Remarks × 624.1/624\_Prop\_3D (MOD) Priority Poliulant Lief (with × × YnoteM gerg\_f.8651f.865 Lab PW. Builes, John E-Mail: John. Builes@et.eurofinsus.com × Accrediations Required (See note): NELAP Texas 200.8/200.8 P TR (MOD) Custom Liet × N as ethil (MOD) Nitrate and Nitrite as N × 300\_ORGFM\_28D/ (MOD) Custom List Received by: × einommA \f.086 (६/५) (०) (४) (०) मुस्सिताल का ह Matrix Water Company Company Type (C=comp, G=grab) Sample 2 Primary Deliverable Rank: 2 Sample 09:30 Central Date: Due Date Requested: 7/20/2023 TAT Requested (days): Date/JRIE 7/(8/23 Sample Date 7/18/23 Project #: 82000843 SSOW#: Date/Time: Client Information (Sub Contract Lab) eliverable Requested: I, II III, IV Other (specify) Custody Seal No. Eurofins Environment Testing South Centr ample Identification - Client ID (Lab ID) Poject Name: PDES Permit Application Renewal ossible Hazard Identification 1136223 Permit (820-9303-1) Empty Kit Relinquished by: Custody Seals Intact.

Δ Yes. Δ No Shipping/Receiving 4145 Greenbriar Dr 281-240-4200(Tel) inquished by: Inconfirmed State, Zip: TX, 77477 Stafford

**Environment Testing** 

🔅 eurofins

Chain of Custody Record

6701 Aberdeen Ave. Suite 8 **Eurofins Lubbock** 

Phone: 806-794-1296 Lubbock. TX 79424

arrier Tracking No(s)

None
ANNaCO4
ANNaCO45
Na2SO3
Na2S2O3
Na2S2O4
TSP Dodecahydrate
Acetane
MCAA Preserved(2.5mlCR+6Buffer\_0000184.0m Note: Since laboratory accerditations are subject to change, Eurofine Environment Testing South Central, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract aboratoris or channels. Eurofine Environment Testing South Central, LLC laboratory or other instructions will be provided. Any changes to accreditation to the Eurofine Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chein of Custoory attesting to said compliance to Eurofine Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chein of Custoory attesting to said compliance to Eurofine Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chein of Custoory attesting to said compliance to Eurofine Environment Testing South Central, LLC. Special Instructions/Note IR ID:HOU-338 Months Sample Disposal ( A fee may be assessed if samples are retained longer than 1 month)

Return To Client Disposal By Lab Archive For Mon Preservation Codes Filtered(0.45um) & Corrected Temp. 1 2 HCL NaOH Zn Acetate Nitric Acid NaHSO4 MeOH Amchlor Ascorbic Acid 21.01 Page: Page 3 of 3 Job#: COC NO: 820-7396.3 CF-03 6 820-9303-1 Ol Water EDTA EDA <u>∢ ⊞ ∪ ⊡ ш 止 ∪ т</u> ะ นับเดิมข้ององกับเยมสมาชิก Jate/Time. Method of Shipment Camer Tracking No(s): State of Origin Analysis Requested Cooler Temperature(s) °C and Other Remarks: Special Instructions/QC Requirements × 615\_MOD/3511\_Herb\_Prep (MOD) Entended List John. Builes@et.eurofinsus.com Accreditations Required (See note): NELAP Texas × × SMS210B CBODC#//BOD bisb CBOD Received by: × SM5210B\_CalciBOD\_Prep BOD, 5-Day Lab PM: Builes, John E-Mail: ्रिया कर १४% विश्वयक्त स्थापना । इ.स.च्या १४% विश्वयक्त स्थापना । Tme: Water (C=comp, G=grab) Sample Type 1700 Primary Deliverable Rank: 2 Sample Central Time Date: AT Requested (days) Due Date Requested: 7/20/2023 Sample Date Date/Time: 7//8/23 Date/Time: 7/18/23 Project #: 82000843 SSOW#: Date/Time: hane: #O% Deliverable Requested: I, II III, IV Other (specify) (Sub Contract Lab) Custody Seal No. Eurofins Environment Testing South Centr Sample Identification - Client ID (Lab ID) Project Name: TPDES Permit Application Renewal Possible Hazard Identification 1136223 Permit (820-9303-1) Empty Kit Relinquished by: Custody Seals Intact: Client Information Δ Yes Δ No Shipping/Receiving 4145 Greenbriar Dr 281-240-4200(Tel) elinquished by: Inconfirmed State, Zip: TX, 77477 Stafford

**Environment Testing** 

💸 eurofins

Chain of Custody Record

6701 Aberdeen Ave. Suite 8 **Eurofins Lubbock** 

Phone: 806-794-1296 Lubbock, TX 79424

#### **Login Sample Receipt Checklist**

Client: Parkhill Smith & Cooper Inc.

Job Number: 820-9303-1

Login Number: 9303 List Source: Eurofins Lubbock

List Number: 1 Creator: Triplett, Colby

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or ampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
s the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is 6mm (1/4").	True	

3

4

6

1

9

10

12

Le

12

#### **Login Sample Receipt Checklist**

Client: Parkhill Smith & Cooper Inc.

Job Number: 820-9303-1

Login Number: 9303 List Source: Eurofins Houston
List Number: 2 List Creation: 07/19/23 12:50 PM

Creator: Pena, Jesiel

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
s the Field Sampler's name present on COC?	N/A	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	

2

6

8

10

12

13

14

#### **Candice Calhoun**

From: Paul Krueger < PKrueger@Parkhill.com>
Sent: Wednesday, June 19, 2024 5:11 PM

To: Candice Calhoun; directorofutilities@ci.lamesa.tx.us

**Cc:** jhines@ci.lamesa.tx.us; Marshall Belcher

Subject:RE: Application to Renew Permit No. WQ0010107001; City of LamesaAttachments:Lamesa WWTP\_NOD1 Response.pdf; WQ0010107001\_PLS.docx

Follow Up Flag: Follow up Flag Status: Flagged

Good Afternoon Ms. Calhoun,

Please find our attached response to your NOD letter. As requested, a Microsoft Word version of the Plain Language Summary is also attached to this email. Thank you for your assistance with this renewal application and please feel free to contact me if you have any questions or need additional information.

Thank you,

#### Paul Krueger, PE

Civil Engineer

#### **Parkhill**

806.473.3715 | Parkhill.com

From: Candice Calhoun < Candice. Calhoun@tceq.texas.gov>

**Sent:** Thursday, June 6, 2024 5:19 PM **To:** directorofutilities@ci.lamesa.tx.us **Cc:** Paul Krueger < PKrueger@Parkhill.com>

Subject: Application to Renew Permit No. WQ0010107001; City of Lamesa

Importance: High

Good afternoon, Mr. Ojeda,

The attached Notice of Deficiency (NOD) letter dated June 6, 2024, requests additional information needed to declare the application administratively complete. Please send complete response by June 21, 2024.

Please let me know if you have any questions.

Regards,



#### Candice Calhoun

Texas Commission on Environmental Quality Water Quality Division 512-239-4312 candice.calhoun@tceq.texas.gov

#### **Candice Calhoun**

From: Joe Hines <jhines@ci.lamesa.tx.us>
Sent: Wednesday, June 19, 2024 4:27 PM

**To:** Candice Calhoun; Paul Krueger; Ernest Ogeda

**Subject:** RE: Application to Renew Permit No. WQ0010107001; City of Lamesa

**Attachments:** Section 14 signed and notorized 6-19-24.pdf

Follow Up Flag: Follow up Flag Status: Flagged

Will this work?

Thank you,

Joe Hines City Manager City of Lamesa, Tx 806-872-4321 Office

From: Candice Calhoun < Candice. Calhoun@tceq.texas.gov>

Sent: Wednesday, June 19, 2024 8:51 AM

To: Joe Hines <jhines@ci.lamesa.tx.us>; Paul Krueger <PKrueger@Parkhill.com>; Ernest Ogeda

<directorofutilities@ci.lamesa.tx.us>

Subject: RE: Application to Renew Permit No. WQ0010107001; City of Lamesa

Importance: High

#### Good morning,

I was able to locate the signature page, in the original, hard copy, of the application. However, the signature page was not notarized. Please provide a signed and notarized signature page for the application. The person who signs the signature page will need to match the individual listed in Section 3, item A, of the Administrative Report 1.0. The signature page does not need to be mailed in, you can send it via email, to me.

The signature page, that we received, has been attached to this email.

Regards,



#### **Candice Calhoun**

Texas Commission on Environmental Quality Water Quality Division 512-239-4312 candice.calhoun@tceq.texas.gov

#### **Candice Calhoun**

From: Ernest Ogeda <directorofutilities@ci.lamesa.tx.us>

**Sent:** Monday, June 17, 2024 5:17 PM

To: Candice Calhoun Cc: Dionicio Garza, Jr.

**Subject:** Application to Renew Permit No. WQ0010107001; City of Lamesa

**Attachments:** Municipal TPDES and TLAP PLS Form.docx

Follow Up Flag: Follow up Flag Status: Completed





Ms. Candice Calhoun Texas Commission of Environmental Quality Applications Review and Processing Team (MC-148) Water Quality Division P.O. Box 13087 Austin, TX 78711-3087

Re: Application to Renew Permit No.: WQ0010107001 (EPA I.D. No. TX0129011)

Applicant Name: City of Lamesa (CN600632400) Site Name: City of Lamesa WWTP (RN101918977)

Type of Application: Renewal

Dear Ms. Calhoun

We have received the Notice of Deficiency letter on the above referenced application in your e-mail dated June 6, 2024. Our response is provided below.

1. <u>Comment:</u> Administrative Report, 1.0 Section 14 – The signature page was inadvertently left blank. Please provide an e-copy of the signed, dated, and notarized signature page.

Response: An e-copy has been attached to this response under Attachment 1.

2. <u>Comment</u>: Core Data Form, Section III, item 25-28 – The description to the physical location provided differs from the description listed in the current permit. Please provide an updated core data form to show the correct description to the physical location. The description must include the distance in feet or miles from road intersections.

Response: An updated Core Data Form has been attached to this response under Attachment 2.

3. <u>Comment</u>: Core Data Form, Section V – The signature and date for the Authorized Signature was inadvertently left blank. Please provide an updated core data form with a signature and date for the Authorized Signature.

Response: An updated Core Data Form has been attached to this response under Attachment 2.

4. <u>Comment</u>: Plain Language Summary (PLS) – The Site Name and the RN number provided on the English plain language summary (PLS) was inadvertently incorrect. The facility location will also need to be updated, per item 2 of this letter. Please provide an updated PLS by using the Plain Language Summary (PLS) Template attached to this letter. Please provide the PLS in a Microsoft Word Document.

Response: An updated PLS has been provided in Attachment 3. A Microsoft Word Document version will also be sent via email.

5. <u>Comment:</u> The following is a portion of the NORI which contains information relevant to your application. Please read it carefully and indicate if it contains any errors or omissions. The complete notice will be sent to you once the application is declared administratively complete.

APPLICATION. City of Lamesa, 601 South 1st Street, Lamesa, Texas 79331, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge

A:\2023\41362.23\03\_DSGN\03\_REPT\00\_CLERICAL\Lamesa Permit Renewal\41362.23 Lamesa WWTP Permit Renewal Letter.docx

Elimination System (TPDES) Permit No. WQ0010107001 (EPA I.D. No. TX0129011) to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 2,000,000 gallons per day. The domestic wastewater treatment facility is located **approximately 2,600 feet east-northeast of the intersection of County Road 20 and State Highway 137**, near the City of Lamesa, in Dawson County, Texas 79331. The discharge route is from the plant site via pipe to Sulphur Springs Draw; thence following the route, in specified order, Natural Dam Lake, Sulphur Springs Draw, Beals Creek, and Colorado River below Lake J.B. Thomas. TCEQ received this application on June 3, 2024. The permit application will be available for viewing and copying at Lamesa City Hall, 601 South 1st Street, Lamesa, Dawson County, Texas. Prior to the date, this notice was published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: https://www.tceq.texas.gov/permitting/wastewater/pendingpermits/tpdes-applications.

This link to an electronic map of the site, or facility's general location, is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application at <a href="https://gisweb.tceq.texas.gov/LocationMapper/?marker=-101.946111,32.711944&level=18">https://gisweb.tceq.texas.gov/LocationMapper/?marker=-101.946111,32.711944&level=18</a>.

Response: All information above is correct and the updated facility location has been provided.

Thank you for reviewing the submitted application. If you have any questions or would like to discuss further, please feel free to call me at 806.473.3715

Sincerely,

**PARKHILL** 

Paul Krueger, PE Civil Engineer

PSK/mb/pp Enclosures

> Section 14 Signature Page Core Data Form Plain Language Summary (PLS)

**Attachment 1** 

Signature Page

#### Section 14. Signature Page (Instructions Page 39)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0010107001

Applicant: City of Lamesa

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): <u>Josh Stever</u> Signatory title: <u>Mayor</u>	<u>1S</u>
Signature: (Use blue ink)	Date: 6/19/2024
Subscribed and Sworn to before me by the sai	d Josh Stevens (Mayor) June, 2024. For Juneary, 2026.
Motary Public Notary Public	[SEAL]
	BEATRIZ CONDE

Notary Public, State of Texas Notary ID# 13140246-3 My Commission Expires 01-11-2026

### Attachment 2 Updated Core Data Form

TCEQ Use Only



#### **TCEQ Core Data Form**

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

#### **SECTION I: General Information**

1. Reason for Submission (If other is checked please describe in space provided.)

Renewal (Core Data Form should be subm		Other								
2. Customer Reference Number (if issued) CN 600632400	for CN or RN numbers in					3. Regulated Entity Reference Number (if issued)  RN 101918977				
ECTION II: Customer	<u>Information</u>									
4. General Customer Information	5. Effective Date for Cu	stomer Info	rmation	Updates (mm/dd/	'γγγγ)					
☐ New Customer ☐☐ Change in Legal Name (Verifiable with the To	J Jpdate to Customer Informati xas Secretary of State or Texa		_	ige in Regulated Ent Accounts)	tity Owners	hip				
The Customer Name submitted here may (SOS) or Texas Comptroller of Public Acco		y based on	what is c	urrent and active	with the	Texas Secretary of Si				
6. Customer Legal Name (If an individual, p.	int last name first: eg: Doe, Jo	ohn)		If new Customer,	enter previ	ous Customer below:				
City of Lamesa										
7. TX SOS/CPA Filing Number	8. TX State Tax ID (11 di	TX State Tax ID (11 digits)				10. DUNS Number (if applicable)				
11. Type of Customer: Corpor	ation		☐ Individ	dual	Partners	hip: 🔲 General 🔲 Lim				
Government: 🛛 City 🔲 County 🔲 Federal 🗌	Local State Other		Sole P	le Proprietorship 🔲 Other:						
12. Number of Employees		13. Independently Owned and Operated?								
□ 0-20 □ 21-100 ☑ 101-250 □ 251-500 □ 501 and higher □ Yes ☑ No										
14. Customer Role (Proposed or Actual) – as	it relates to the Regulated En	ntity listed on	this form.	Please check one o	f the follow	ing				
Owner Operator  Occupational Licensee Responsible F	Owner & Opera  OVCP/BSA App			Other	:					
15. Mailing 601 S. 1st Street										
				T		710 . 4				
Address: City Lamesa	State	TX	ZIP	79331		ZIP + 4				

TCEQ-10400 (11/22) Page 1 of 3

directorofutilities@ci.lamesa.tx.us

18. Telephone Number	19. Extension or Code	20. Fax Number (if applicable)				
( 806 ) 872-2124		( ) 🗟				

#### **SECTION III: Regulated Entity Information**

21. General Regulated En	tity Informa	tion (If 'New Regi	ulated Entity" is selec	ted, a r	new per	mit applica	tion is als	so required.)		
		Regulated Entity N								
The Regulated Entity Nar as Inc, LP, or LLC).	ne submitte	d may be updat	ed, in order to mee	et TCE(	Q Core	Data Star	ndards (	removal of org	ganization	al endings such
22. Regulated Entity Nam	ne (Enter nam	e of the site where	the regulated action	ı is taki	ng place	e.)				
City of Lamesa Wastewater 1	reatment Plar	nt								
23. Street Address of the Regulated Entity:										
(No PO Boxes)	City		State			ZIP			ZIP + 4	
24. County	Dawson									
		If no Stree	et Address is provid	ded, fi	elds 25	-28 are re	quired.			
25. Description to Physical Location:	Located app Texas.	roximately 2600 f	t east-northeast of th	ne inter	section	of County I	Road 20 a	and State Highw	ay 137, in D	awson County,
26. Nearest City							State		Nea	rest ZIP Code
Lamesa							TX		7933	
Latitude/Longitude are rused to supply coordinat						ita Stando	ards. (G	eocoding of th	e Physical	Address may be
27. Latitude (N) In Decim	ıal:	32.7119			28. Lo	ngitude (\	W) In De	ecimal:	-101.946	11
Degrees	Minutes		Seconds		Degree			Minutes		Seconds
32		42	43		-101 56			46		
29. Primary SIC Code	30.	Secondary SIC	Code			NAICS C	ode	32. Seco	ndary NAI	CS Code
(4 digits)	(4 d	ligits)		(5 or	6 digits	5) 		(5 or 6 dig	gits)	
4952				2213						
33. What is the Primary	Business of 1	this entity? (De	o not repeat the SIC o	r NAIC.	S descri <sub>l</sub>	ption.)				
Wastewater Treatment for t	he City of Lam									
34. Mailing	601 S. 1st !	Street								
Address:	City	Lamesa	State	тх		ZIP	7933	1	ZIP + 4	
35. E-Mail Address:	dire	ectorofutilities@c	i.lamesa.tx.us				1			
36. Telephone Number			37. Extension or	Code		38.	Fax Nur	nber (if applica	ble)	
( 806 ) 872-4327						( 80	6 ) 872-4	338		
						1				

form. See the Core Data Form instructions for additional guidance. ☐ Industrial Hazardous Waste ☐ Edwards Aquifer Emissions Inventory Air ☐ Districts Dam Safety New Source □ PWS Petroleum Storage Tank OSSF ■ Municipal Solid Waste Review Air Used Oil Tires Sludge Storm Water ☐ Title V Air Other: ☐ Wastewater Agriculture ☐ Water Rights ☐ Voluntary Cleanup WQ0010107001 **SECTION IV: Preparer Information** 41. Title: Civil Engineer 40. Name: Paul Krueger, P.E. 43. Ext./Code 44. Fax Number 45. E-Mail Address 42. Telephone Number pkrueger@parkhill.com (806) 473-2200 ) = **SECTION V: Authorized Signature** 46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39. Utilities Director Job Title: Company: City of Lamesa Ernest Ojeda Phone: (806) 872-2124 Name (In Print): Date: 06/10/2024 Signature:

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this

TCEQ-10400 (11/22) Page 3 of 3

**Attachment 3** 

**Updated PLS** 

# TCEQ

### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

## PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

# Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

City of Lamesa (CN600632400) operates City of Lamesa Wastewater Treatment Plant (RN101918977), an activated sludge treatment process using the extended aeration mode. The facility is located at approximately 2,600 feet east-northeast of the intersection of County Road 20 and State Highway 137, in Lamesa, Dawson County, Texas 79331. Application is being submitted for a standard renewal without changes. << For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain CBOD, TSS, and Ammonia Nitrogen. Domestic wastewater is treated by activated sludge process using the extended aeration mode. Treatment units include a screen, vortex grit removal, carrousel aeration basin, 2 final clarifiers, and UV disinfection.



TPDES PERMIT NO.
WQ0010107001
[For TCEQ office use only - EPA I.D.
No. TX0129011]

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY P.O. Box 13087 Austin, Texas 78711-3087

This is a renewal that replaces TPDES Permit No. WQ0010107001 issued on April 13, 2015.

### PERMIT TO DISCHARGE WASTES

under provisions of Section 402 of the Clean Water Act and Chapter 26 of the Texas Water Code

City of Lamesa

whose mailing address is

601 South 1st Street Lamesa, Texas 79331

is authorized to treat and discharge wastes from the City of Lamesa Wastewater Treatment Plant, SIC Code 4952

located approximately 2,600 feet east-northeast of the intersection of County Road 20 and State Highway 137, in Dawson County, Texas 79331

via pipe to Sulphur Springs Draw, thence to Natural Dam Lake, thence to Sulphur Springs Draw, thence to Beals Creek, thence to the Colorado River Below Lake J.B. Thomas in Segment No. 1412 of the Colorado River Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does not grant to the permittee the right to use private or public property for conveyance of wastewater along the discharge route described in this permit. This includes, but is not limited to, property belonging to any individual, partnership, corporation, or other entity. Neither does this permit authorize any invasion of personal rights nor any violation of federal, state, or local laws or regulations. It is the responsibility of the permittee to acquire property rights as may be necessary to use the discharge route.

This permit shall expire at midnight, five years from the date of issuance.

ISSUED DATE: December 6, 2019

For the Commission

# EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

# Outfall Number 001

1. During the period beginning upon the date of issuance and lasting through the date of expiration, the permittee is authorized to discharge subject to the following effluent limitations:

The annual average flow of effluent shall not exceed 2.0 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 3,819 gallons per minute.

Effluent Characteristic		Discharge Limitations	imitations		Min. Self-Monitoring Requirements	Sequirements
	Daily Avg	7-day Avg	7-day Avg Daily Max	Single Grab	Report Daily Avg. & Daily Max.	Daily Max.
	mg/l (lbs/day)	mg/l	mg/l	mg/l	Measurement Frequency	Sample Type
Flow, MGD	Report	N/A	Report	N/A	Continuous	Totalizing Meter
Carbonaceous Biochemical Oxygen Demand (5-day)	10 (167)	15	25	35	Two/week	Composite
Total Suspended Solids	15 (250)	25	40	09	Two/week	Composite
Ammonia Nitrogen	3 (50)	9	10	15	Two/week	Composite
Total Aluminum	Report (Report)	N/A	Report	N/A	One/week	Composite
E. coli, CFU or MPN per 100 ml	126	N/A	399	N/A	Daily	Grab

- 2. The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
  - 3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per week by grab sample. 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
    - - 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 4.0 mg/l and shall be monitored twice per week by grab sample.
- The annual average flow and maximum 2-hour peak flow shall be reported monthly.

### **DEFINITIONS AND STANDARD PERMIT CONDITIONS**

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC § 305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§ 5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§ 361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in TWC § 26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

### 1. Flow Measurements

- a. Annual average flow the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder and limited to major domestic wastewater discharge facilities with one million gallons per day or greater permitted flow.
- b. Daily average flow the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) the highest 2-hour peak flow for any 24-hour period in a calendar month.

### 2. Concentration Measurements

- a. Daily average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
  - i. For domestic wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.

- ii. For all other wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day.
  - The daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the daily discharge determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.
- e. Bacteria concentration (*E. coli* or Enterococci) Colony Forming Units (CFU) or Most Probable Number (MPN) of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the nth root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or, computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substituted value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
- f. Daily average loading (lbs/day) the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD x Concentration, mg/l x 8.34).
- g. Daily maximum loading (lbs/day) the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.

### 3. Sample Type

a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (b).

- b. Grab sample an individual sample collected in less than 15 minutes.
- 4. Treatment Facility (facility) wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation and/or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
- 5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
- 6. Bypass the intentional diversion of a waste stream from any portion of a treatment facility.

### MONITORING AND REPORTING REQUIREMENTS

### Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§ 319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Compliance Monitoring Team of the Enforcement Division (MC 224), by the 20th day of the following month for each discharge which is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act (CWA); TWC §§ 26, 27, and 28; and THSC § 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

### 2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§ 319.11 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC § 25, Environmental Testing Laboratory Accreditation and Certification.

### 3. Records of Results

- a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.
- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period

of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR § 264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.

- c. Records of monitoring activities shall include the following:
  - i. date, time and place of sample or measurement;
  - ii. identity of individual who collected the sample or made the measurement.
  - iii. date and time of analysis;
  - iv. identity of the individual and laboratory who performed the analysis;
  - v. the technique or method of analysis; and
  - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

### 4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

### 5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site and/or shall be readily available for review by a TCEQ representative for a period of three years.

### 6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224).

### 7. Noncompliance Notification

- a. In accordance with 30 TAC § 305.125(9) any noncompliance which may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Except as allowed by 30 TAC § 305.132, report of such information shall be provided orally or by facsimile transmission (FAX) to the Regional Office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective September 1, 2020, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
- b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
  - i. Unauthorized discharges as defined in Permit Condition 2(g).
  - ii. Any unanticipated bypass that exceeds any effluent limitation in the permit.
  - iii. Violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
- c. In addition to the above, any effluent violation which deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
- d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Compliance Monitoring Team of the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
- 8. In accordance with the procedures described in 30 TAC §§ 35.301 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
- 9. Changes in Discharges of Toxic Substances

All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the Regional Office, orally or by facsimile transmission within 24 hours, and both the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - i. One hundred micrograms per liter (100 μg/L);
  - ii. Two hundred micrograms per liter (200  $\mu$ g/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500  $\mu$ g/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - i. Five hundred micrograms per liter (500 µg/L);
  - ii. One milligram per liter (1 mg/L) for antimony;
  - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.

### 10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC § 305.128 (relating to Signatories to Reports).

- 11. All POTWs must provide adequate notice to the Executive Director of the following:
  - a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to CWA § 301 or § 306 if it were directly discharging those pollutants;
  - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and
  - c. For the purpose of this paragraph, adequate notice shall include information on:
    - i. The quality and quantity of effluent introduced into the POTW; and
    - ii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

### PERMIT CONDITIONS

### 1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
  - i. Violation of any terms or conditions of this permit;
  - Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
  - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

### 2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment, revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.

- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance with 30 TAC §§ 305.62 and 305.66 and TWC§ 7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC § 305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility which does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under TWC §§ 7.051 7.075 (relating to Administrative Penalties), 7.101 7.111 (relating to Civil Penalties), and 7.141 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§ 301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA § 402, or any requirement imposed in a pretreatment program approved under the CWA §§ 402 (a)(3) or 402 (b)(8).

### 3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC § 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC § 7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

### 4. Permit Amendment and/or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
  - The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC § 305.534 (relating to New Sources and New Dischargers); or
  - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
  - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes which are not described in the permit application or which would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC § 26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA § 307(a) for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or

prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA § 307(a) for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

### 5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC § 305.64 (relating to Transfer of Permits) and 30 TAC § 50.133 (relating to Executive Director Action on Application or WQMP update).

### 6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

### 7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to TWC Chapter 11.

### 8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

### 9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

### 10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

### 11. Notice of Bankruptcy

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
  - i. the permittee;
  - ii. an entity (as that term is defined in 11 USC, § 101(14)) controlling the permittee or listing the permit or permittee as property of the estate; or

- iii. an affiliate (as that term is defined in 11 USC, § 101(2)) of the permittee.
- b. This notification must indicate:
  - i. the name of the permittee and the permit number(s);
  - ii. the bankruptcy court in which the petition for bankruptcy was filed; and
  - iii. the date of filing of the petition.

### **OPERATIONAL REQUIREMENTS**

- 1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
- 2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge use and disposal and 30 TAC §§ 319.21 319.29 concerning the discharge of certain hazardous metals.
- 3. Domestic wastewater treatment facilities shall comply with the following provisions:
  - a. The permittee shall notify the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
  - b. The permittee shall submit a closure plan for review and approval to the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment and/or other treatment unit regulated by this permit.
- 4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, and/or retention of inadequately treated wastewater.
- 5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.

6. The permittee shall remit an annual water quality fee to the Commission as required by 30 TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC § 7.302(b)(6).

### 7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §§ 1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words confidential business information on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

- 8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
  - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion and/or upgrading of the domestic wastewater treatment and/or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment and/or collection facilities. In the case of a domestic wastewater treatment facility which reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been secured.

- c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
- Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
- 10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
- 11. Facilities that generate industrial solid waste as defined in 30 TAC § 335.1 shall comply with these provisions:
  - a. Any solid waste, as defined in 30 TAC § 335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
  - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
  - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC § 335.8(b)(1), to the Corrective Action Section (MC 221) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
  - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC § 335.5.
  - e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well,

- container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.
- f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC § 335 and must include the following, as it pertains to wastewater treatment and discharge:
  - i. Volume of waste and date(s) generated from treatment process;
  - ii. Volume of waste disposed of on-site or shipped off-site;
  - iii. Date(s) of disposal;
  - iv. Identity of hauler or transporter;
  - v. Location of disposal site; and
  - vi. Method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC § 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC § 361.

TCEQ Revision 08/2008

### SLUDGE PROVISIONS

The permittee is authorized to dispose of sludge only at a Texas Commission on Environmental Quality (TCEQ) authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge. The disposal of sludge by land application on property owned, leased or under the direct control of the permittee is a violation of the permit unless the site is authorized with the TCEQ. This provision does not authorize Distribution and Marketing of Class A or Class AB Sewage Sludge. This provision does not authorize the permittee to land apply sludge on property owned, leased or under the direct control of the permittee.

### SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE LAND APPLICATION

### A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge in accordance with 30 TAC § 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
- 2. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
- 3. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge disposal practice.

### **B.** Testing Requirements

Sewage sludge shall be tested annually in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other method that receives the prior approval of the TCEQ for the contaminants listed in 40 CFR Part 261.24, Table 1. Sewage sludge failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal. Following failure of any TCLP test, the management or disposal of sewage sludge at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 7) within seven (7) days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P.O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 7) and the Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30<sup>th</sup> of each year. Effective September 1, 2020, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

2. Sewage sludge shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Section I.C. of this permit.

TABLE 1

<u>Pollutant</u>	Ceiling Concentration
	(Milligrams per kilogram)*
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

<sup>\*</sup> Dry weight basis

### 3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site must be treated by one of the following methods to ensure that the sludge meets either the Class A, Class AB or Class B pathogen requirements.

a. For sewage sludge to be classified as Class A with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 most probable number (MPN) per gram of total solids (dry weight basis), or the density of Salmonella sp. bacteria in the sewage sludge must be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

Alternative 1 - The temperature of the sewage sludge that is used or disposed shall be maintained at or above a specific value for a period of time. See 30 TAC § 312.82(a)(2)(A) for specific information;

Alternative 5 (PFRP) - Sewage sludge that is used or disposed of must be treated in one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR Part 503, Appendix B. PFRP include composting, heat drying, heat treatment, and thermophilic aerobic digestion; or

Alternative 6 (PFRP Equivalent) - Sewage sludge that is used or disposed of must be treated in a process that has been approved by the U. S. Environmental Protection Agency as being equivalent to those in Alternative 5.

b. For sewage sludge to be classified as Class AB with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 MPN per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 2</u> - The pH of the sewage sludge that is used or disposed shall be raised to above 12 std. units and shall remain above 12 std. units for 72 hours.

The temperature of the sewage sludge shall be above 52° Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12 std. units.

At the end of the 72-hour period during which the pH of the sewage sludge is above 12 std. units, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50%; or

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is less than one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(i-iii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(iv-vi) for specific information; or

Alternative 4 - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed.

- c. Sewage sludge that meets the requirements of Class AB sewage sludge may be classified a Class A sewage sludge if a variance request is submitted in writing that is supported by substantial documentation demonstrating equivalent methods for reducing odors and written approval is granted by the executive director. The executive director may deny the variance request or revoke that approved variance if it is determined that the variance may potentially endanger human health or the environment, or create nuisance odor conditions.
- d. Three alternatives are available to demonstrate compliance with Class B criteria for sewage sludge.

### Alternative 1

- A minimum of seven random samples of the sewage sludge shall be collected within 48 hours of the time the sewage sludge is used or disposed of during each monitoring episode for the sewage sludge.
- ii. The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

<u>Alternative 2</u> - Sewage sludge that is used or disposed of shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR Part 503, Appendix B, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. An independent Texas Licensed Professional Engineer must make a certification to the generator of a sewage sludge that the wastewater treatment facility generating the sewage sludge is designed to achieve one of the PSRP at the permitted design loading of the facility. The certification need only be repeated if the design loading of the facility is increased. The certification shall include a statement indicating the design meets all the applicable standards specified in Appendix B of 40 CFR Part 503;
- iii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iv. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review; and
- v. If the sewage sludge is generated from a mixture of sources, resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the PSRP, and shall meet the certification, operation, and record keeping requirements of this paragraph.

<u>Alternative 3</u> - Sewage sludge shall be treated in an equivalent process that has been approved by the U.S. Environmental Protection Agency, so long as all of the following requirements are met by the generator of the sewage sludge.

i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;

- ii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iii. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review;
- iv. The Executive Director will accept from the U.S. Environmental Protection Agency a finding of equivalency to the defined PSRP; and
- v. If the sewage sludge is generated from a mixture of sources resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the Processes to Significantly Reduce Pathogens, and shall meet the certification, operation, and record keeping requirements of this paragraph.

In addition to the Alternatives 1-3, the following site restrictions must be met if Class B sludge is land applied:

- i. Food crops with harvested parts that touch the sewage sludge/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of sewage sludge.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of sewage sludge when the sewage sludge remains on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of sewage sludge when the sewage sludge remains on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of sewage sludge.
- v. Animals shall not be allowed to graze on the land for 30 days after application of sewage sludge.
- vi. Turf grown on land where sewage sludge is applied shall not be harvested for 1 year after application of the sewage sludge when the harvested turf is placed on either land with a high potential for public exposure or a lawn.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of sewage sludge.

- viii. Public access to land with a low potential for public exposure shall be restricted for 30 days after application of sewage sludge.
- ix. Land application of sludge shall be in accordance with the buffer zone requirements found in 30 TAC § 312.44.

### 4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following Alternatives 1 through 10 for vector attraction reduction.

- Alternative 1 The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38%.
- Alternative 2 If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30° and 37° Celsius. Volatile solids must be reduced by less than 17% to demonstrate compliance.
- Alternative 3 If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20° Celsius. Volatile solids must be reduced by less than 15% to demonstrate compliance.
- Alternative 4 The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20° Celsius.
- Alternative 5 Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40° Celsius and the average temperature of the sewage sludge shall be higher than 45° Celsius.
- Alternative 6 The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali shall remain at 12 or higher for two hours and then remain at a pH of 11.5 or higher for an additional 22 hours at the time the sewage sludge is prepared for sale or given away in a bag or other container.
- Alternative 7 The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75% based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

### Alternative 8 -

The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90% based on the moisture content and total solids prior to mixing with other materials at the time the sludge is used. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

### Alternative 9 -

- i. Sewage sludge shall be injected below the surface of the land.
- ii. No significant amount of the sewage sludge shall be present on the land surface within one hour after the sewage sludge is injected.
- iii. When sewage sludge that is injected below the surface of the land is Class A or Class AB with respect to pathogens, the sewage sludge shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.

### Alternative 10-

- Sewage sludge applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
- ii. When sewage sludge that is incorporated into the soil is Class A or Class AB with respect to pathogens, the sewage sludge shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

### C. Monitoring Requirements

Toxicity Characteristic Leaching Procedure - annually (TCLP) Test
PCBs - annually

All metal constituents and fecal coliform or *Salmonella* sp. bacteria shall be monitored at the appropriate frequency shown below, pursuant to 30 TAC § 312.46(a)(1):

Amount of sewage sludge (*) metric tons per 365-day period	Monitoring Frequency
o to less than 290	Once/Year
290 to less than 1,500	Once/Quarter
1,500 to less than 15,000	Once/Two Months
15,000 or greater	Once/Month

(\*) The amount of bulk sewage sludge applied to the land (dry wt. basis).

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 30 TAC  $\S$  312.7

Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.

Identify in the following categories (as applicable) the sewage sludge treatment process or processes at the facility: preliminary operations (e.g., sludge grinding and de-gritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.

Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge for disposal at a mono-fill) and whether the material is ultimately conveyed off-site in bulk or in bags.

### SECTION II.

REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE FOR APPLICATION TO THE LAND MEETING CLASS A, CLASS AB or CLASS B PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A, Class AB or Class B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below listed in Table 3, the following conditions apply:

### A. Pollutant Limits

### Table 2

	Cumulative Pollutant Loading Rate
Pollutant	(pounds per acre)*
Arsenic	36
Cadmium	35
Chromium	2677
Copper	1339
Lead	268
Mercury	15
Molybdenum	Report Only
Nickel	375
Selenium	89
Zinc	2500

### Table 3

	Monthly Average	
	Concentration	
<b>Pollutant</b>	(milligrams per kilogram)	*
Arsenic	41	
Cadmium	39	
Chromium	1200	
Copper	1500	
Lead	300	
Mercury	17	
Molybdenum	Report Only	
Nickel	420	
Selenium	36	
Zinc	2800	
	*Dry weight basis	

### **B.** Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, shall be treated by either Class A, Class AB or Class B pathogen reduction requirements as defined above in Section I.B.3.

### C. Management Practices

- 1. Bulk sewage sludge shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk sewage sludge enters a wetland or other waters in the State.
- 2. Bulk sewage sludge not meeting Class A requirements shall be land applied in a manner which complies with Applicability in accordance with 30 TAC §312.41 and the Management Requirements in accordance with 30 TAC § 312.44.
- 3. Bulk sewage sludge shall be applied at or below the agronomic rate of the cover crop.
- 4. An information sheet shall be provided to the person who receives bulk sewage sludge sold or given away. The information sheet shall contain the following information:
  - a. The name and address of the person who prepared the sewage sludge that is sold or given away in a bag or other container for application to the land.
  - b. A statement that application of the sewage sludge to the land is prohibited except in accordance with the instruction on the label or information sheet.
  - c. The annual whole sludge application rate for the sewage sludge application rate for the sewage sludge that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Section II above are met.

### D. Notification Requirements

- 1. If bulk sewage sludge is applied to land in a State other than Texas, written notice shall be provided prior to the initial land application to the permitting authority for the State in which the bulk sewage sludge is proposed to be applied. The notice shall include:
  - a. The location, by street address, and specific latitude and longitude, of each land application site.
  - b. The approximate time period bulk sewage sludge will be applied to the site.
  - c. The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk sewage sludge.
- 2. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge disposal practice.

### E. Record keeping Requirements

The sludge documents will be retained at the facility site and/or shall be readily available for review by a TCEQ representative. The person who prepares bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information at

the facility site and/or shall be readily available for review by a TCEQ representative for a period of <u>five years</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply.

- 1. The concentration (mg/kg) in the sludge of each pollutant listed in Table 3 above and the applicable pollutant concentration criteria (mg/kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (lbs/ac) listed in Table 2 above.
- 2. A description of how the pathogen reduction requirements are met (including site restrictions for Class AB and Class B sludge, if applicable).
- 3. A description of how the vector attraction reduction requirements are met.
- 4. A description of how the management practices listed above in Section II.C are being met.
- 5. The following certification statement:
  - "I certify, under penalty of law, that the applicable pathogen requirements in 30 TAC § 312.82(a) or (b) and the vector attraction reduction requirements in 30 TAC § 312.83(b) have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."
- 6. The recommended agronomic loading rate from the references listed in Section II.C.3. above, as well as the actual agronomic loading rate shall be retained. The person who applies bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative <u>indefinitely</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply:
  - a. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii), as applicable, and to the permittee's specific sludge treatment activities.
  - b. The location, by street address, and specific latitude and longitude, of each site on which sludge is applied.
  - c. The number of acres in each site on which bulk sludge is applied.
  - d. The date and time sludge is applied to each site.

- e. The cumulative amount of each pollutant in pounds/acre listed in Table 2 applied to each site.
- f. The total amount of sludge applied to each site in dry tons.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

### F. Reporting Requirements

The permittee shall report annually to the TCEQ Regional Office (MC Region 7) and Compliance Monitoring Team (MC 224) of the Enforcement Division, by September 30<sup>th</sup> of each year the following information. Effective September 1, 2020, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

- Identify in the following categories (as applicable) the sewage sludge treatment process
  or processes at the facility: preliminary operations (e.g., sludge grinding and de-gritting),
  thickening (concentration), stabilization, anaerobic digestion, aerobic digestion,
  composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation,
  pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons),
  heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge for disposal at a mono-fill) and whether the material is ultimately conveyed off-site in bulk or in bags.
- 3. Results of tests performed for pollutants found in either Table 2 or 3 as appropriate for the permittee's land application practices.
- 4. The frequency of monitoring listed in Section I.C. that applies to the permittee.
- 5. Toxicity Characteristic Leaching Procedure (TCLP) results.
- PCB concentration in sludge in mg/kg.
- 7. Identity of hauler(s) and TCEQ transporter number.
- 8. Date(s) of transport.
- 9. Texas Commission on Environmental Quality registration number, if applicable.
- 10. Amount of sludge disposal dry weight (lbs/acre) at each disposal site.
- 11. The concentration (mg/kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/kg) listed in Table 3 above, or the applicable pollutant loading rate limit (lbs/acre) listed in Table 2 above if it exceeds 90% of the limit.
- 12. Level of pathogen reduction achieved (Class A, Class AB or Class B).
- 13. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B sludge, include information on how site restrictions were met.

- 14. Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.
- 15. Vector attraction reduction alternative used as listed in Section I.B.4.
- 16. Amount of sludge transported in dry tons/year.
- 17. The certification statement listed in either 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii) as applicable to the permittee's sludge treatment activities, shall be attached to the annual reporting form.
- 18. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the annual reporting form.
  - a. The location, by street address, and specific latitude and longitude.
  - b. The number of acres in each site on which bulk sewage sludge is applied.
  - c. The date and time bulk sewage sludge is applied to each site.
  - d. The cumulative amount of each pollutant (i.e., pounds/acre) listed in Table 2 in the bulk sewage sludge applied to each site.
  - e. The amount of sewage sludge (i.e., dry tons) applied to each site.

The above records shall be maintained on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

### SECTION III. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL

- A. The permittee shall handle and dispose of sewage sludge in accordance with 30 TAC § 330 and all other applicable state and federal regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge meets the requirements in 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- B. If the permittee generates sewage sludge and supplies that sewage sludge to the owner or operator of a municipal solid waste landfill (MSWLF) for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
- C. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge disposal practice.
- D. Sewage sludge shall be tested annually in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I (Toxicity Characteristic Leaching Procedure) or other method, which receives the prior approval of the TCEQ for contaminants listed in Table 1 of 40 CFR § 261.24. Sewage sludge failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal.

Following failure of any TCLP test, the management or disposal of sewage sludge at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 7) of the appropriate TCEQ field office within 7 days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P. O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 7) and the Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30 of each year.

- E. Sewage sludge shall be tested as needed, in accordance with the requirements of 30 TAC Chapter 330.
- F. Record keeping Requirements

The permittee shall develop the following information and shall retain the information for five years.

- 1. The description (including procedures followed and the results) of all liquid Paint Filter Tests performed.
- 2. The description (including procedures followed and results) of all TCLP tests performed.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

### G. Reporting Requirements

The permittee shall report annually to the TCEQ Regional Office (MC Region 7) and Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30<sup>th</sup> of each year the following information. Effective September 1, 2020, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

- Identify in the following categories (as applicable) the sewage sludge treatment process
  or processes at the facility: preliminary operations (e.g., sludge grinding and de-gritting),
  thickening (concentration), stabilization, anaerobic digestion, aerobic digestion,
  composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation,
  pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons),
  heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Toxicity Characteristic Leaching Procedure (TCLP) results.
- Annual sludge production in dry tons/year.
- 4. Amount of sludge disposed in a municipal solid waste landfill in dry tons/year.
- 5. Amount of sludge transported interstate in dry tons/year.
- 6. A certification that the sewage sludge meets the requirements of 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- 7. Identity of hauler(s) and transporter registration number.
- 8. Owner of disposal site(s).
- Location of disposal site(s).
- 10. Date(s) of disposal.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

### SECTION IV. REQUIREMENTS APPLYING TO SLUDGE TRANSPORTED TO ANOTHER FACILITY FOR FURTHER PROCESSING

These provisions apply to sludge that is transported to another wastewater treatment facility or facility that further processes sludge. These provisions are intended to allow transport of sludge to facilities that have been authorized to accept sludge. These provisions do not limit the ability of the receiving facility to determine whether to accept the sludge, nor do they limit the ability of the receiving facility to request additional testing or documentation.

### A. General Requirements

- The permittee shall handle and dispose of sewage sludge in accordance with 30 TAC Chapter 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
- 2. Sludge may only be transported using a registered transporter or using an approved pipeline.

### **B.** Record Keeping Requirements

- 1. For sludge transported by an approved pipeline, the permittee must maintain records of the following:
  - a. the amount of sludge transported;
  - the date of transport;
  - c. the name and TCEQ permit number of the receiving facility or facilities;
  - d. the location of the receiving facility or facilities;
  - e. the name and TCEQ permit number of the facility that generated the waste; and
  - f. copy of the written agreement between the permittee and the receiving facility to accept sludge.
- 2. For sludge transported by a registered transporter, the permittee must maintain records of the completed trip tickets in accordance with 30 TAC § 312.145(a)(1)-(7) and amount of sludge transported.
- The above records shall be maintained on-site on a monthly basis and shall be made available to the TCEQ upon request. These records shall be retained for at least five years.

### C. Reporting Requirements

The permittee shall report the following information annually to the TCEQ Regional Office (MC Region 7) and Compliance Monitoring Team (MC 224) of the Enforcement Division, by September 30<sup>th</sup> of each year. Effective September 1, 2020, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

- 1. Identify in the following categories (as applicable) the sewage sludge treatment process or processes at the facility: preliminary operations (e.g., sludge grinding and de-gritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. the annual sludge production;
- the amount of sludge transported;
- 4. the owner of each receiving facility;
- 5. the location of each receiving facility; and
- 6. the date(s) of disposal at each receiving facility.

TCEQ Revision 01/2016

### OTHER REQUIREMENTS

The permittee shall employ or contract with one or more licensed wastewater treatment
facility operators or wastewater system operations companies holding a valid license or
registration according to the requirements of 30 TAC Chapter 30, Occupational Licenses and
Registrations, and in particular 30 TAC Chapter 30, Subchapter J, Wastewater Operators
and Operations Companies.

This Category B facility must be operated by a chief operator or an operator holding a Category B license or higher. The facility must be operated a minimum of five days per week by the licensed chief operator or an operator holding the required level of license or higher. The licensed chief operator or operator holding the required level of license or higher must be available by telephone or pager seven days per week. Where shift operation of the wastewater treatment facility is necessary, each shift that does not have the on-site supervision of the licensed chief operator must be supervised by an operator in charge who is licensed not less than one level below the category for the facility.

- 2. The facility is not located in the Coastal Management Program boundary.
- 3. There is no mixing zone established for this discharge to an intermittent stream. Acute toxic criteria apply at the point of discharge.
- 4. The permittee shall comply with the requirements of 30 TAC § 309.13 (a) through (d). In addition, by ownership of the required buffer zone area, the permittee shall comply with the requirements of 30 TAC § 309.13(e).
- 5. In accordance with 30 TAC § 319.9, a permittee that has at least twelve months of uninterrupted compliance with its bacteria limit may notify the commission in writing of its compliance and request a less frequent measurement schedule. To request a less frequent schedule, the permittee shall submit a written request to the TCEQ Wastewater Permitting Section (MC 148) for each phase that includes a different monitoring frequency. The request must contain all of the reported bacteria values (Daily Avg. and Daily Max/Single Grab) for the twelve consecutive months immediately prior to the request. If the Executive Director finds that a less frequent measurement schedule is protective of human health and the environment, the permittee may be given a less frequent measurement schedule. For this permit, daily may be reduced to 5/week. A violation of any bacteria limit by a facility that has been granted a less frequent measurement schedule will require the permittee to return to the standard frequency schedule and submit written notice to the TCEO Wastewater Permitting Section (MC 148). The permittee may not apply for another reduction in measurement frequency for at least 24 months from the date of the last violation. The Executive Director may establish a more frequent measurement schedule, if necessary, to protect human health or the environment.

## CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

- 1. The following pollutants may not be introduced into the treatment facility:
  - a. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed-cup flash point of less than 140° Fahrenheit (60° Celsius) using the test methods specified in 40 CFR § 261.21;
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case shall there be discharges with a pH lower than 5.0 standard units, unless the works are specifically designed to accommodate such discharges;
  - c. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference;
  - d. Any pollutant, including oxygen-demanding pollutants (e.g., biochemical oxygen demand), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW;
  - e. Heat in amounts which will inhibit biological activity in the POTW, resulting in Interference, but in no case shall there be heat in such quantities that the temperature at the POTW treatment plant exceeds 104° Fahrenheit (40° Celsius) unless the Executive Director, upon request of the POTW, approves alternate temperature limits;
  - f. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through;
  - g. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and
  - h. Any trucked or hauled pollutants except at discharge points designated by the POTW.
- 2. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Clean Water Act, including any requirements established under 40 CFR Part 403 [rev. Federal Register/Vol. 70/No. 198/Friday, October 14, 2005/Rules and Regulations, pages 60134-60798].
- 3. The permittee shall provide adequate notification to the Executive Director, care of the Wastewater Permitting Section (MC 148) of the Water Quality Division, within 30 days subsequent to the permittee's knowledge of either of the following:
  - Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Clean Water Act if it were directly discharging those pollutants; and
  - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Any notice shall include information on the quality and quantity of effluent to be introduced into the treatment works and any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

Revised July 2007

## BIOMONITORING REQUIREMENTS

## 48-HOUR ACUTE BIOMONITORING REQUIREMENTS: FRESHWATER

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

- 1. Scope, Frequency, and Methodology
  - a. The permittee shall test the effluent for toxicity in accordance with the provisions below. Such testing will determine if an appropriately dilute effluent sample adversely affects the survival of the test organisms.
  - b. The permittee shall conduct the following toxicity tests using the test organisms, procedures, and quality assurance requirements specified in this part of this permit and in accordance with "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms," fifth edition (EPA-821-R-02-012) or its most recent update:
    - 1) Acute static renewal 48-hour definitive toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*). A minimum of five replicates with eight organisms per replicate shall be used in the control and in each dilution. This test shall be conducted once per quarter.
    - 2) Acute static renewal 48-hour definitive toxicity test using the fathead minnow (*Pimephales promelas*). A minimum of five replicates with eight organisms per replicate shall be used in the control and in each dilution. This test shall be conducted once per quarter.

The permittee must perform and submit a valid test for each test species during the required reporting period for that species. A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution. A repeat test shall include the control and all effluent dilutions and use the appropriate number of organisms and replicates, as specified above. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. The permittee shall use five effluent dilution concentrations and a control in each toxicity test. These effluent dilution concentrations are 32%, 42%, 56%, 75%, and 100% effluent. The critical dilution, defined as 100% effluent, is the effluent concentration representative of the proportion of effluent in the receiving water during critical low flow or critical mixing conditions.
- d. This permit may be amended to require a WET limit, a chemical-specific limit, a best management practice, or other appropriate actions to address toxicity. The permittee may be required to conduct a toxicity reduction evaluation (TRE) after multiple toxic events.

## e. Testing Frequency Reduction

- If none of the first four consecutive quarterly tests demonstrates significant lethal effects, the permittee may submit this information in writing and, upon approval, reduce the testing frequency to once per six months for the invertebrate test species and once per year for the vertebrate test species.
- 2) If one or more of the first four consecutive quarterly tests demonstrates significant lethal effects, the permittee shall continue quarterly testing for that species until this permit is reissued. If a testing frequency reduction had been previously granted and a subsequent test demonstrates significant lethal effects, the permittee shall resume a quarterly testing frequency for that species until this permit is reissued.

## 2. <u>Required Toxicity Testing Conditions</u>

- a. Test Acceptance The permittee shall repeat any toxicity test, including the control and all effluent dilutions, which fails to meet any of the following criteria:
  - 1) a control mean survival of 90% or greater; and
  - a coefficient of variation percent (CV%) of 40 or less for both the control and critical dilution. However, if significant lethality is demonstrated, a CV% greater than 40 shall not invalidate the test. The CV% requirement does not apply when significant lethality occurs.

## b. Statistical Interpretation

- 1) For the water flea and fathead minnow tests, the statistical analyses used to determine if there is a significant difference between the control and an effluent dilution shall be in accordance with the manual referenced in Part 1.b.
- The permittee is responsible for reviewing test concentration-response relationships to ensure that calculated test results are interpreted and reported correctly. The document entitled "Method Guidance and Recommendation for Whole Effluent Toxicity (WET) Testing (40 CFR Part 136)" (EPA 821-B-00-004) provides guidance on determining the validity of test results.
- 3) If significant lethality is demonstrated (that is, there is a statistically significant difference in survival at the critical dilution when compared to the survival in the control), the conditions of test acceptability are met, and the survival of the test organisms are equal to or greater than 90% in the critical dilution and all dilutions below that, then the permittee shall report a survival No Observed Effect Concentration (NOEC) of not less than the critical dilution for the reporting requirements.
- 4) The NOEC is defined as the greatest effluent dilution at which no significant lethality is demonstrated. The Lowest Observed Effect

Concentration (LOEC) is defined as the lowest effluent dilution at which significant lethality is demonstrated. Significant lethality is defined as a statistically significant difference the survival of the test organism in a specified effluent dilution when compared to the survival of the test organism in the control.

- 5) The use of NOECs and LOECs assumes either a monotonic (continuous) concentration-response relationship or a threshold model of the concentration-response relationship. For any test result that demonstrates a non-monotonic (non-continuous) response, the NOEC should be determined based on the guidance manual referenced in Item 2.
- 6) Pursuant to the responsibility assigned to the permittee in Part 2.b.2), test results that demonstrate a non-monotonic (non-continuous) concentration-response relationship may be submitted, prior to the due date, for technical review. The guidance manual referenced in Item 2 will be used when making a determination of test acceptability.
- 7) TCEQ staff will review test results for consistency with rules, procedures, and permit requirements.

#### c. Dilution Water

- Dilution water used in the toxicity tests must be the receiving water collected at a point upstream of the discharge point as close as possible to the discharge point but unaffected by the discharge. Where the toxicity tests are conducted on effluent discharges to receiving waters that are classified as intermittent streams, or where the toxicity tests are conducted on effluent discharges where no receiving water is available due to zero flow conditions, the permittee shall:
  - substitute a synthetic dilution water that has a pH, hardness, and alkalinity similar to that of the closest downstream perennial water unaffected by the discharge; or
  - b) use the closest downstream perennial water unaffected by the discharge.
- 2) Where the receiving water proves unsatisfactory as a result of preexisting instream toxicity (i.e. fails to fulfill the test acceptance criteria Part 2.a.), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
  - a) a synthetic lab water control was performed (in addition to the receiving water control) which fulfilled the test acceptance requirements of Part 2.a;
  - b) the test indicating receiving water toxicity was carried out to completion; and

- c) the permittee submitted all test results indicating receiving water toxicity with the reports and information required in Part 3.
- 3) The synthetic dilution water shall consist of standard, moderately hard, reconstituted water. Upon approval, the permittee may substitute other appropriate dilution water with chemical and physical characteristics similar to that of the receiving water.

## d. Samples and Composites

- The permittee shall collect a minimum of two composite samples from Outfall 001. The second composite sample will be used for the renewal of the dilution concentrations for each toxicity test.
- 2) The permittee shall collect the composite samples such that the samples are representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged on an intermittent basis.
- 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the first composite sample. The holding time for the subsequent composite sample shall not exceed 72 hours. Samples shall be maintained at a temperature of o-6 degrees Centigrade during collection, shipping, and storage.
- 4) If Outfall 001 ceases discharging during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions, and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume sufficient to complete the required toxicity tests with renewal of the effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report.
- 5) The effluent sample shall not be dechlorinated after sample collection.

## 3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted in accordance with the manual referenced in Part 1.b for every valid and invalid toxicity test initiated, whether carried to completion or not.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 1 forms provided with this permit.

- 1) Annual biomonitoring test results are due on or before January 20th for biomonitoring conducted during the previous 12-month period.
- 2) Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.
- Quarterly biomonitoring test results are due on or before April 20th, July 20th, October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.
- 4) Monthly biomonitoring test results are due on or before the 20th day of the month following sampling.
- c. Enter the following codes for the appropriate parameters for valid tests only:
  - 1) For the water flea, Parameter TEM3D, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 2) For the water flea, Parameter TOM3D, report the NOEC for survival.
  - 3) For the water flea, Parameter TXM3D, report the LOEC for survival.
  - 4) For the fathead minnow, Parameter TEM6C, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 5) For the fathead minnow, Parameter TOM6C, report the NOEC for survival.
  - 6) For the fathead minnow, Parameter TXM6C, report the LOEC for survival.
- d. Enter the following codes for retests only:
  - 1) For retest number 1, Parameter 22415, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 2) For retest number 2, Parameter 22416, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "o."

## 4. Persistent Toxicity

The requirements of this part apply only when a toxicity test demonstrates significant lethality. Significant lethality was defined in Part 2.b.

a. The permittee shall conduct a total of 2 additional tests (retests) for any species that demonstrates significant lethality. The two retests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two retests in lieu of routine toxicity testing. All reports shall be submitted within 20 days of test completion. Test completion is defined as the last day of the test.

- b. If one or both of the two retests specified in Part 4.a. demonstrates significant lethality, the permittee shall initiate the TRE requirements as specified in Part 5.
- c. The provisions of Part 4.a. are suspended upon completion of the two retests and submittal of the TRE action plan and schedule defined in Part 5.

## 5. <u>Toxicity Reduction Evaluation</u>

- a. Within 45 days of the retest that demonstrates significant lethality, the permittee shall submit a general outline for initiating a TRE. The outline shall include, but not be limited to, a description of project personnel, a schedule for obtaining consultants (if needed), a discussion of influent and effluent data available for review, a sampling and analytical schedule, and a proposed TRE initiation date.
- b. Within 90 days of the retest that demonstrates significant lethality, the permittee shall submit a TRE action plan and schedule for conducting a TRE. The plan shall specify the approach and methodology to be used in performing the TRE. A TRE is a step-wise investigation combining toxicity testing with physical and chemical analyses to determine actions necessary to eliminate or reduce effluent toxicity to a level not effecting significant lethality at the critical dilution. The TRE action plan shall describe an approach for the reduction or elimination of lethality for both test species defined in Part 1.b. At a minimum, the TRE action plan shall include the following:
  - 1) Specific Activities - The TRE action plan shall specify the approach the permittee intends to utilize in conducting the TRE, including toxicity characterizations, identifications, confirmations, source evaluations, treatability studies, and alternative approaches. When conducting characterization analyses, the permittee shall perform multiple characterizations and follow the procedures specified in the document entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA/600/6-91/003) or alternate procedures. The permittee shall perform multiple identifications and follow the methods specified in the documents entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081). All characterization, identification, and confirmation tests shall be conducted in an orderly and logical progression;
  - Sampling Plan The TRE action plan should describe sampling locations, methods, holding times, chain of custody, and preservation techniques. The effluent sample volume collected for all tests shall be adequate to perform the toxicity characterization/identification/confirmation procedures and chemical-specific analyses when the toxicity tests show significant lethality. Where the permittee has identified or suspects a specific pollutant and source of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical-specific analyses for the identified and suspected pollutant and source of effluent toxicity;

- Quality Assurance Plan The TRE action plan should address record keeping and data evaluation, calibration and standardization, baseline tests, system blanks, controls, duplicates, spikes, toxicity persistence in the samples, randomization, reference toxicant control charts, and mechanisms to detect artifactual toxicity; and
- 4) Project Organization The TRE action plan should describe the project staff, project manager, consulting engineering services (where applicable), consulting analytical and toxicological services, etc.
- c. Within 30 days of submittal of the TRE action plan and schedule, the permittee shall implement the TRE.
- d. The permittee shall submit quarterly TRE activities reports concerning the progress of the TRE. The quarterly reports are due on or before April 20th, July 20th, October 20th, and January 20th. The report shall detail information regarding the TRE activities including:
  - 1) results and interpretation of any chemical specific analyses for the identified and suspected pollutant performed during the quarter;
  - 2) results and interpretation of any characterization, identification, and confirmation tests performed during the quarter;
  - any data and substantiating documentation which identifies the pollutant(s) and source of effluent toxicity;
  - 4) results of any studies/evaluations concerning the treatability of the facility's effluent toxicity;
  - any data that identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution; and
  - 6) any changes to the initial TRE plan and schedule that are believed necessary as a result of the TRE findings.
- e. During the TRE, the permittee shall perform, at a minimum, quarterly testing using the more sensitive species. Testing for the less sensitive species shall continue at the frequency specified in Part 1.b.
- f. If the effluent ceases to effect significant lethality, i.e., there is a cessation of lethality, the permittee may end the TRE. A cessation of lethality is defined as no significant lethality for a period of 12 consecutive months with at least monthly testing. At the end of the 12 months, the permittee shall submit a statement of intent to cease the TRE and may then resume the testing frequency specified in Part 1.b.

This provision accommodates situations where operational errors and upsets, spills, or sampling errors triggered the TRE, in contrast to a situation where a single toxicant or group of toxicants cause lethality. This provision does not apply

as a result of corrective actions taken by the permittee. Corrective actions are defined as proactive efforts that eliminate or reduce effluent toxicity. These include, but are not limited to, source reduction or elimination, improved housekeeping, changes in chemical usage, and modifications of influent streams and effluent treatment.

The permittee may only apply this cessation of lethality provision once. If the effluent again demonstrates significant lethality to the same species, the permit will be amended to add a WET limit with a compliance period, if appropriate. However, prior to the effective date of the WET limit, the permittee may apply for a permit amendment removing and replacing the WET limit with an alternate toxicity control measure by identifying and confirming the toxicant and an appropriate control measure.

- g. The permittee shall complete the TRE and submit a final report on the TRE activities no later than 28 months from the last test day of the retest that confirmed significant lethal effects at the critical dilution. The permittee may petition the Executive Director (in writing) for an extension of the 28-month limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification/TRE. The report shall provide information pertaining to the specific control mechanism selected that will, when implemented, result in the reduction of effluent toxicity to no significant lethality at the critical dilution. The report shall also provide a specific corrective action schedule for implementing the selected control mechanism.
- h. Based on the results of the TRE and proposed corrective actions, this permit may be amended to modify the biomonitoring requirements, where necessary, require a compliance schedule for implementation of corrective actions, specify a WET limit, specify a best management practice, and specify a chemical-specific limit.
- i. Copies of any and all required TRE plans and reports shall also be submitted to the U.S. EPA Region 6 office, 6WQ-PO.

# TABLE 1 (SHEET 1 OF 2)

## WATER FLEA SURVIVAL

Dates and	Times	No 1 EPO		e Time			ime
composite	es						
ollected		No. 2 FRC	M:		_ TO:		
est initia	ted: vater used: _			_am/pm			dat
ilution w	ater used: _	Re	ceiving wate	r	Synthetic D	ilution wate	r
			PERCENT	SURVIVAL			
Time	Rep			Percent	effluent		
Time	Кер	0%	32%	42%	56%	75%	100%
	A						
	В	S.					e e
24h	С						
	D						
	Е						
	A						
	В						
48h	С		80				
	D						
	Е						
Mean a	at test end						
C	V%*	1					
							IL
*C	oefficient of	Variation = S	tandard Dev	riation x 100	/mean		
unnett's	Procedure or	Steel's Many	-One Rank	Test as appro	opriate:		
the mea	n survival at	48 hours sig	nificantly les	s than the co	ontrol surviv	al?	
	CRITICAL	DILUTION (	100%):	YES	1	10	
nter perc	ent effluent o						
•		survival = _					
		survival = _					

# TABLE 1 (SHEET 2 OF 2)

## FATHEAD MINNOW SURVIVAL

			Dat	e Time	I	Date Tim	e
		No. 1 FRO	M:		TO:		
Composites Collected		No. 2 FROM:		TO:	2		
Test initiat	ed:			_am/pm _			date
D	ilution wat	er used:	Recei	ving water	Sy	nthetic Dilu	tion water
			PERCENT	SURVIVAL	ř		
					t effluent		
Time	Rep	0%	32%	42%	56%	75%	100%
	A		-				
	В						
24h	C						
	D	10					
	E						
	A						
	В						
48h	C						
	D						
	E	ly si					
Mean a	t test end						
STATE OF BUILDING	V%*						
* C	pefficient of	f Variation = s	standard dev	iation x 100	o/mean		
Dunnett's I	Procedure o	r Steel's Many	y-One Rank	Test as appi	ropriate:		
Is the mear	survival at	48 hours sign	nificantly les	s than the c	ontrol surviv	al?	
	CRITICAL	DILUTION (	100%):	YES		NO	
Enter perce	ent effluent	correspondin	g to the NOI	EC below:			
	1) NOE	C survival = _	9	% effluent			
	2) LOE(	C survival = _	9	6 effluent			

## 24-HOUR ACUTE BIOMONITORING REQUIREMENTS: FRESHWATER

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

## Scope, Frequency, and Methodology

- a. The permittee shall test the effluent for lethality in accordance with the provisions in this section. Such testing will determine compliance with Texas Surface Water Quality Standard 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the appropriate test organisms in 100% effluent for a 24-hour period.
- b. The toxicity tests specified shall be conducted once per six months. The permittee shall conduct the following toxicity tests using the test organisms, procedures, and quality assurance requirements specified in this section of the permit and in accordance with "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms," fifth edition (EPA-821-R-02-012) or its most recent update:
  - 1) Acute 24-hour static toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*). A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution.
  - 2) Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*). A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution.

The permittee must perform and report a valid test for each test species during the prescribed reporting period. An invalid test must be repeated during the same reporting period. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. In addition to an appropriate control, a 100% effluent concentration shall be used in the toxicity tests. The control and dilution water shall consist of standard, synthetic, moderately hard, reconstituted water.
- d. This permit may be amended to require a WET limit, a best management practice, a chemical-specific limit, or other appropriate actions to address toxicity. The permittee may be required to conduct a toxicity reduction evaluation (TRE) after multiple toxic events.
- e. As the dilution series specified in the 48-Hour Acute Biomonitoring Requirements includes a 100% effluent concentration, the results from those tests may fulfill the requirements of this section; any tests performed in the proper time interval may be substituted. Compliance will be evaluated as specified in Part 1.a. The 50% survival in 100% effluent for a 24-hour period standard applies to all tests utilizing a 100% effluent dilution, regardless of whether the results are submitted to comply with the minimum testing frequency.

## 2. Required Toxicity Testing Conditions

- a. Test Acceptance The permittee shall repeat any toxicity test, including the control, if the control fails to meet a mean survival equal to or greater than 90%.
- b. Dilution Water In accordance with Part 1.c., the control and dilution water shall consist of standard, synthetic, moderately hard, reconstituted water.
- c. Samples and Composites
  - 1) The permittee shall collect one composite sample from Outfall 001.
  - 2) The permittee shall collect the composite sample such that the sample is representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged on an intermittent basis.
  - 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the composite sample. The sample shall be maintained at a temperature of o-6 degrees Centigrade during collection, shipping, and storage.
  - 4) If Outfall 001 ceases discharging during the collection of the effluent composite sample, the requirements for the minimum number of effluent portions are waived. However, the permittee must have collected a composite sample volume sufficient for completion of the required test. The abbreviated sample collection, duration, and methodology must be documented in the full report.
  - 5) The effluent sample shall not be dechlorinated after sample collection.

## 3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this permit in accordance with the manual referenced in Part 1.b. for every valid and invalid toxicity test initiated.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 2 forms provided with this permit.
  - Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.
  - Quarterly biomonitoring test results are due on or before April 20th, July 20th, and October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.

- c. Enter the following codes for the appropriate parameters for valid tests only:
  - 1) For the water flea, Parameter TIE3D, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter "1."
  - 2) For the fathead minnow, Parameter TIE6C, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter "1."
- d. Enter the following codes for retests only:
  - 1) For retest number 1, Parameter 22415, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter "1."
  - 2) For retest number 2, Parameter 22416, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter "1."

## 4. Persistent Mortality

The requirements of this part apply when a toxicity test demonstrates significant lethality, which is defined as a mean mortality of 50% or greater of organisms exposed to the 100% effluent concentration for 24 hours.

- a. The permittee shall conduct 2 additional tests (retests) for each species that demonstrates significant lethality. The two retests shall be conducted once per week for 2 weeks. Five effluent dilution concentrations in addition to an appropriate control shall be used in the retests. These effluent concentrations are 6%, 13%, 25%, 50%, and 100% effluent. The first retest shall be conducted within 15 days of the laboratory determination of significant lethality. All test results shall be submitted within 20 days of test completion of the second retest. Test completion is defined as the 24th hour.
- b. If one or both of the two retests specified in Part 4.a. demonstrates significant lethality, the permittee shall initiate the TRE requirements as specified in Part 5.

## 5. <u>Toxicity Reduction Evaluation</u>

- a. Within 45 days of the retest that demonstrates significant lethality, the permittee shall submit a general outline for initiating a TRE. The outline shall include, but not be limited to, a description of project personnel, a schedule for obtaining consultants (if needed), a discussion of influent and effluent data available for review, a sampling and analytical schedule, and a proposed TRE initiation date.
- b. Within 90 days of the retest that demonstrates significant lethality, the permittee shall submit a TRE action plan and schedule for conducting a TRE. The plan shall specify the approach and methodology to be used in performing the TRE. A TRE is a step-wise investigation combining toxicity testing with physical and chemical analyses to determine actions necessary to eliminate or reduce effluent toxicity to

a level not effecting significant lethality at the critical dilution. The TRE action plan shall lead to the successful elimination of significant lethality for both test species defined in Part 1.b. At a minimum, the TRE action plan shall include the following:

- 1) Specific Activities - The TRE action plan shall specify the approach the permittee intends to utilize in conducting the TRE, including toxicity characterizations, identifications, confirmations, source evaluations, treatability studies, and alternative approaches. When conducting characterization analyses, the permittee shall perform multiple characterizations and follow the procedures specified in the document entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA/600/6-91/003) or alternate procedures. The permittee shall perform multiple identifications and follow the methods specified in the documents entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081). All characterization, identification, and confirmation tests shall be conducted in an orderly and logical progression;
- Sampling Plan The TRE action plan should describe sampling locations, methods, holding times, chain of custody, and preservation techniques. The effluent sample volume collected for all tests shall be adequate to perform the toxicity characterization/identification/confirmation procedures, and chemical-specific analyses when the toxicity tests show significant lethality. Where the permittee has identified or suspects a specific pollutant and source of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical-specific analyses for the identified and suspected pollutant and source of effluent toxicity;
- Quality Assurance Plan The TRE action plan should address record keeping and data evaluation, calibration and standardization, baseline tests, system blanks, controls, duplicates, spikes, toxicity persistence in the samples, randomization, reference toxicant control charts, and mechanisms to detect artifactual toxicity; and
- 4) Project Organization The TRE Action Plan should describe the project staff, manager, consulting engineering services (where applicable), consulting analytical and toxicological services, etc.
- c. Within 30 days of submittal of the TRE action plan and schedule, the permittee shall implement the TRE.
- d. The permittee shall submit quarterly TRE activities reports concerning the progress of the TRE. The quarterly TRE Activities Reports are due on or before April 20th, July 20th, October 20th, and January 20th. The report shall detail information regarding the TRE activities including:

- results and interpretation of any chemical-specific analyses for the identified and suspected pollutant performed during the quarter;
- 2) results and interpretation of any characterization, identification, and confirmation tests performed during the quarter;
- any data and substantiating documentation that identifies the pollutant and source of effluent toxicity;
- 4) results of any studies/evaluations concerning the treatability of the facility's effluent toxicity;
- 5) any data that identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to eliminate significant lethality; and
- 6) any changes to the initial TRE plan and schedule that are believed necessary as a result of the TRE findings.
- e. During the TRE, the permittee shall perform, at a minimum, quarterly testing using the more sensitive species. Ttesting for the less sensitive species shall continue at the frequency specified in Part 1.b.
- f. If the effluent ceases to effect significant lethality, i.e., there is a cessation of lethality, the permittee may end the TRE. A cessation of lethality is defined as no significant lethality for a period of 12 consecutive weeks with at least weekly testing. At the end of the 12 weeks, the permittee shall submit a statement of intent to cease the TRE and may then resume the testing frequency specified in Part 1.b.

This provision accommodates situations where operational errors and upsets, spills, or sampling errors triggered the TRE, in contrast to a situation where a single toxicant or group of toxicants cause lethality. This provision does not apply as a result of corrective actions taken by the permittee. Corrective actions are defined as proactive efforts that eliminate or reduce effluent toxicity. These include, but are not limited to, source reduction or elimination, improved housekeeping, changes in chemical usage, and modifications of influent streams and effluent treatment.

The permittee may only apply this cessation of lethality provision once. If the effluent again demonstrates significant lethality to the same species, the permit will be amended to add a WET limit with a compliance period, if appropriate. However, prior to the effective date of the WET limit, the permittee may apply for a permit amendment removing and replacing the WET limit with an alternate toxicity control measure by identifying and confirming the toxicant and an appropriate control measure.

g. The permittee shall complete the TRE and submit a final report on the TRE activities no later than 18 months from the last test day of the retest that demonstrates significant lethality. The permittee may petition the Executive Director (in writing) for an extension of the 18-month limit. However, to warrant

an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE. The report shall specify the control mechanism that will, when implemented, reduce effluent toxicity as specified in Part 5.h. The report shall also specify a corrective action schedule for implementing the selected control mechanism.

h. Within 3 years of the last day of the test confirming toxicity, the permittee shall comply with 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the test organism in 100% effluent at the end of 24-hours. The permittee may petition the Executive Director (in writing) for an extension of the 3-year limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE.

The permittee may be exempted from complying with 30 TAC § 307.6(e)(2)(B) upon proving that toxicity is caused by an excess, imbalance, or deficiency of dissolved salts. This exemption excludes instances where individually toxic components (e.g., metals) form a salt compound. Following the exemption, this permit may be amended to include an ion-adjustment protocol, alternate species testing, or single species testing.

- i. Based upon the results of the TRE and proposed corrective actions, this permit may be amended to modify the biomonitoring requirements where necessary, require a compliance schedule for implementing corrective actions, specify a WET limit, specify a best management practice, and specify a chemical-specific limit.
- j. Copies of any and all required TRE plans and reports shall also be submitted to the U.S. EPA Region 6 office, 6WQ-PO.

# TABLE 2 (SHEET 1 OF 2)

## WATER FLEA SURVIVAL

## GENERAL INFORMATION

	Time	Date
Composite Sample Collected		
Test Initiated	d.	

## PERCENT SURVIVAL

	35	Percent effluent					
Time	Rep	0%	6%	13%	25%	50%	100%
	A		A SUCCESSION OF THE SUCCESSION				
	В						
	С			15,6		250	
24h	D			70		The second	
	E						
	MEAN*						

Enter	percent	effluent	corresi	ponding	to th	ne LC	50 be	elow:
LILLOI	POLCOIL	CITICOLLE	COLLOD	POHIGHIA		TO DO.	,00	10 11 .

24-hour LC50 = \_\_\_\_\_% effluent

## TABLE 2 (SHEET 2 OF 2)

# FATHEAD MINNOW SURVIVAL

## GENERAL INFORMATION

4	Time	Date
Composite Sample Collected		
Test Initiated		

## PERCENT SURVIVAL

Times	Don.	Percent effluent						
Time	Rep	0%	6%	13%	25%	50%	100%	
9/2	A					AL THE		
	В							
o .h	С							
24h	D						=	
	Е						2	
	MEAN							

T .	· CCI ·	7	11 TO-	1 1
Enter	percent effluent co	orresponding to	the LC50	below:

24-hour LC50 = \_\_\_\_\_% effluent

## FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

For draft Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010107001, EPA I.D. No. TX0129011, to discharge to water in the state.

Issuing Office: Texas Commission on Environmental Quality

P.O. Box 13087

Austin, Texas 78711-3087

Applicant: City of Lamesa

601 South 1st Street Lamesa, Texas 79331

Prepared By: Sonia Bhuiya

Municipal Permits Team

Wastewater Permitting Section (MC 148)

Water Quality Division

(512) 239-1205

Date: June 16, 2025

Permit Action: Renewal

## 1. EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **five years from the date of issuance**.

## 2. APPLICANT ACTIVITY

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of the existing permit that authorizes the discharge of treated domestic wastewater at an annual average flow not to exceed 2.0 million gallons per day (MGD). The existing wastewater treatment facility serves the City of Lamesa.

## 3. FACILITY AND DISCHARGE LOCATION

The plant site is located approximately 2,600 feet east-northeast of the intersection of County Road 20 and State Highway 137, in Dawson County, Texas 79331.

## Outfall Location:

Outfall Number	Latitude	Longitude	
001	32.713573 N	101.943213 W	

The treated effluent is discharged via pipe to Sulphur Springs Draw, thence to Natural Dam Lake, thence to Sulphur Springs Draw, thence to Beals Creek, thence to the Colorado River Below Lake J.B. Thomas in Segment No. 1412 of the Colorado River Basin. The unclassified receiving water use is minimal aquatic life use for Sulphur Springs Draw. The designated uses for Segment No. 1412 are primary contact recreation

and high aquatic life use.

## 4. TREATMENT PROCESS DESCRIPTION AND SEWAGE SLUDGE DISPOSAL

The City of Lamesa Wastewater Treatment Facility (WWTF) is an activated sludge process plant operated in the extended aeration mode. Treatment units include a barscreen, a fine screen, a vortex removal unit, a carousel aeration basin, a final clarifier, a belt filter press, and an ultraviolet light (UV) disinfection chamber. The facility is in operation.

Sludge generated from the treatment facility is hauled by a registered transporter and disposed of at a TCEQ-permitted landfill, City of Lamesa Landfill, Permit No. 517A, in Dawson County. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

## 5. INDUSTRIAL WASTE CONTRIBUTION

The draft permit includes pretreatment requirements that are appropriate for a facility of this size and complexity. The City of Lamesa WWTF does not appear to receive significant industrial wastewater contributions.

## 6. SUMMARY OF SELF-REPORTED EFFLUENT ANALYSES

The following is a summary of the applicant's effluent monitoring data for the period May 2019 through May 2025. The average of Daily Average value is computed by the averaging of all 30-day average values for the reporting period for each parameter: flow, five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), and total Aluminum. The average of Daily Average value for *Escherichia coli* (*E. coli*) in colony-forming units (CFU) or most probable number (MPN) per 100 ml is calculated via geometric mean.

<u>Parameter</u>	Average of Daily Avg
Flow, MGD	1.24
CBOD <sub>5</sub> , mg/l	3.81
TSS, mg/l	4.0
NH <sub>3</sub> -N, mg/l	0.18
E. coli, CFU or MPN per 100 ml	1
Total Aluminum, mg/l	0.14

## 7. DRAFT PERMIT CONDITIONS AND MONITORING REQUIREMENTS

The effluent limitations and monitoring requirements for those parameters that are limited in the draft permit are as follows:

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The annual average flow of effluent shall not exceed 2.0 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 3,819 gallons per minute.

<u>Parameter</u>	30-Day Average		<u>7-Day</u>	<u>Daily</u>
			<u>Average</u>	<u>Maximum</u>
	<u>mg/l</u>	<u>lbs/day</u>	<u>mg/l</u>	<u>mg/l</u>
$CBOD_5$	10	167	15	25
TSS	15	250	25	40
$NH_3$ - $N$	3	50	6	10
Total Aluminum	Report	Report	N/A	Report
DO (minimum)	4.0	N/A	N/A	N/A
E. coli, CFU or MPN/100 ml	126	N/A	N/A	399

The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per week by grab sample. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.

The permittee shall utilize a UV system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.

<u>Parameter</u>	Monitoring Requirement
Flow, MGD	Continuous
$CBOD_5$	Two/week
TSS	Two/week
$NH_3$ -N	Two/week
Total Aluminum	One/week
DO	Two/week
E. coli	Daily

## B. SEWAGE SLUDGE REQUIREMENTS

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal, and Transportation. Sludge generated from the treatment facility is hauled by a registered transporter and disposed of at a TCEQ-permitted landfill, City of Lamesa Landfill, Permit No. 517A, in Dawson County. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

## C. PRETREATMENT REQUIREMENTS

Permit requirements for pretreatment are based on TPDES regulations contained in 30 TAC Chapter 305, which references 40 Code of Federal Regulations (CFR) Part 403, "General Pretreatment Regulations for Existing and New Sources of Pollution" [rev. Federal Register/ Vol. 70/ No. 198/ Friday, October 14, 2005/ Rules and Regulations, pages 60134-60798]. The permit includes specific requirements that establish responsibilities of local government, industry, and the public to implement the standards to control pollutants which pass through or interfere with treatment processes in publicly owned treatment works or which may contaminate the sewage sludge. This permit has appropriate pretreatment language for a facility of this size and complexity.

## D. WHOLE EFFLUENT TOXICITY (BIOMONITORING) REQUIREMENTS

- (1) The draft permit includes 48-hour acute freshwater biomonitoring requirements as follows. The permit requires five dilutions in addition to the control (0% effluent) to be used in the toxicity tests. These additional effluent concentrations shall be 32%, 42%, 56%, 75%, and 100%. The low-flow effluent concentration (critical dilution) is defined as 100% effluent. The critical dilution is in accordance with the "Aquatic Life Criteria" section of the "Water Quality Based Effluent Limitations/Conditions" section.
  - (a) Acute static renewal 48-hour definitive toxicity tests using the water flea (*Daphnia pulex*) or (*Ceriodaphnia dubia*). The frequency of the testing is once per quarter for at least the first year of testing, after which the permittee may apply for a testing frequency reduction.
  - (b) Acute static renewal 48-hour definitive toxicity test using the fathead minnow (*Pimephales promelas*). The frequency of the testing is once per quarter for at least the first year of testing, after which the permittee may apply for a testing frequency reduction.
- (2) The draft permit includes the following minimum 24-hour acute freshwater biomonitoring requirements at a frequency of once per six months:
  - (a) Acute 24-hour static toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*).
  - (b) Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*).

#### E. SUMMARY OF CHANGES FROM APPLICATION

None.

#### F. SUMMARY OF CHANGES FROM EXISTING PERMIT

The Standard Permit Conditions, Sludge Provisions, Other Requirements, and Biomonitoring sections of the draft permit have been updated.

For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

Certain accidental discharges or spills of treated or untreated wastewater from wastewater treatment facilities or collection systems owned or operated by a local government may be reported on a monthly basis in accordance with 30 TAC §

305.132.

The draft permit includes all updates based on the 30 TAC § 312 rule change effective April 23, 2020.

## 8. DRAFT PERMIT RATIONALE

## A. TECHNOLOGY-BASED EFFLUENT LIMITATIONS/CONDITIONS

Regulations promulgated in Title 40 of the CFR require that technology-based limitations be placed in wastewater discharge permits based on effluent limitations guidelines, where applicable, or on best professional judgment (BPJ) in the absence of guidelines.

Effluent limitations for maximum and minimum pH are in accordance with 40 CFR § 133.102(c) and 30 TAC § 309.1(b).

## B. WATER QUALITY SUMMARY AND COASTAL MANAGEMENT PLAN

## (1) WATER QUALITY SUMMARY

The treated effluent is discharged to via pipe to Sulphur Springs Draw, thence to Natural Dam Lake, thence to Sulphur Springs Draw, thence to Beals Creek, thence to the Colorado River Below Lake J.B. Thomas in Segment No. 1412 of the Colorado River Basin. The unclassified receiving water use is minimal aquatic life use for Sulphur Springs Draw. The designated uses for Segment No. 1412 are primary contact recreation and high aquatic life use. The effluent limitations in the draft permit will maintain and protect the existing instream uses. All determinations are preliminary and subject to additional review and/or revisions.

The discharge from this permit action is not expected to have an effect on any federal endangered or threatened aquatic or aquatic-dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS's) biological opinion on the State of Texas authorization of the TPDES (September 14, 1998; October 21, 1998, update). To make this determination for TPDES permits, TCEQ and EPA only considered aquatic or aquatic-dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Segment 1412 is currently listed on the State's inventory of impaired and threatened waters (2022 CWA § 303(d) list). The listing is specifically for elevated bacteria levels from the confluence of Beals Creek upstream to the dam below Barber Reservoir pump station (Assessment Unit [AU] 1412\_02). Beals Creek is also listed on the 2022 303(d) list for elevated bacteria levels from the confluence of Gutherie Draw upstream to the

confluence of Mustang Draw and Sulphur Springs Draw (AU 1412B\_03). This facility is designed to provide adequate disinfection and, when operated properly, should not add to the bacterial impairment of the segment. To ensure that the proposed discharge meets the stream bacterial standard, an effluent limitation of 126 CFU or MPN of *E. coli* per 100 ml has been continued in the draft permit.

The pollutant analysis of treated effluent provided by the permittee in the application indicated 1170 mg/l total dissolved solids (TDS), 197 mg/l sulfate, and 391 mg/l chloride present in the effluent. The segment criteria for Segment No. 1412 are 9210 mg/l for TDS, 1570 mg/l for sulfate, and 4,740 mg/l for chlorides. Based on dissolved solids screening, no additional limits or monitoring requirements are needed for total dissolved solids, chloride, or sulfate. See Attachment A of this Fact Sheet.

One finalized Total Maximum Daily Load (TMDL) Project is applicable to Segment 1412: Two Total Maximum Daily Loads for Total Dissolved Solids and Sulfate in E.V. Spence Reservoir for Segment 1411 (Project No. 4). However, this discharge is located outside the scope of the TMDL project.

On June 14, 2002, the report Two Total Maximum Daily Loads for Total Dissolved Solids and Sulfate in E.V. Spence Reservoir was adopted with revisions by the TNRC, predecessor to the TCEQ. The Environmental Protection EPA) approved the TMDL on May 9, 2003. Wastewater treatment plants were not determined to be significant contributors of TDS or sulfate to the reservoir. The need for effluent limits or monitoring of these constituents is assessed using routine procedures. Effluent data provided in the application for sulfate, TDS, and chloride was screened in accordance with the *Procedures to Implement the Texas Surface Water Quality Standards*, June 2010. The draft permit does not include effluent limits or monitoring requirements for sulfate, TDS, or chloride based on this screening.

The effluent limitations and conditions in the draft permit comply with EPA-approved portions of the 2018 Texas Surface Water Quality Standards (TSWQS), 30 TAC §§ 307.1 - 307.10, effective March 1, 2018; 2014 TSWQS, effective March 6, 2014; 2010 TSWQS, effective July 22, 2010; and 2000 TSWQS, effective July 26, 2000.

## (2) CONVENTIONAL PARAMETERS

Effluent limitations for the conventional effluent parameters (i.e., Five-Day Biochemical Oxygen Demand or Five-Day Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water quality-limited streams as established in the TSWQS and the State of Texas Water Quality Management Plan (WQMP).

The existing effluent limits have been reviewed for consistency with the State of Texas Water Quality Management Plan (WQMP). The existing

limits are consistent with the approved WQMP.

The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Effluent Limitations.

## (3) COASTAL MANAGEMENT PLAN

The facility is not located in the Coastal Management Program boundary.

## C. WATER QUALITY-BASED EFFLUENT LIMITATIONS/CONDITIONS

## (1) GENERAL COMMENTS

The Texas Surface Water Quality Standards (30 TAC Chapter 307) state that surface waters will not be toxic to man, or to terrestrial or aquatic life. The methodology outlined in the *Procedures to Implement the Texas Surface Water Quality Standards*, (IP) (June 2010) is designed to ensure compliance with 30 TAC Chapter 307. Specifically, the methodology is designed to ensure that no source will be allowed to discharge any wastewater that: (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical state water quality standard; (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation that threatens human health.

## (2) AQUATIC LIFE CRITERIA

## (a) SCREENING

Water quality-based effluent limitations are calculated from freshwater aquatic life criteria found in Table 1 of the Texas Surface Water Quality Standards (30 TAC Chapter 307).

There is no mixing zone or zone of initial dilution for this discharge directly to an intermittent stream; acute freshwater criteria apply at the end of pipe. Chronic freshwater criteria do not apply to discharges to intermittent streams where there is no perennial waterbody within three miles downstream from the point of discharge. The following critical effluent percentage is being used:

Acute Effluent %: 100%

Waste load allocations (WLAs) are calculated using the above estimated effluent percentages, criteria outlined in the Texas Surface Water Quality Standards, and partitioning coefficients for metals (when appropriate and designated in the implementation procedures). The WLA is the end-of-pipe effluent concentration that can be discharged when, after mixing in the receiving stream, instream numerical criteria will not be exceeded.

From the WLA, a long-term average (LTA) is calculated using a log normal probability distribution, a given coefficient of variation (0.6), and

a 90<sup>th</sup> percentile confidence level. The LTA is the long-term average effluent concentration for which the WLA will never be exceeded using a selected percentile confidence level. The lower of the two LTAs (acute and chronic) is used to calculate a daily average and daily maximum effluent limitation for the protection of aquatic life using the same statistical considerations with the 99<sup>th</sup> percentile confidence level and a standard number of monthly effluent samples collected (12).

Assumptions used in deriving the effluent limitations include segment values for hardness, chlorides, pH, and TSS according to the segment-specific values contained in the TCEQ guidance document *Procedures to Implement the Texas Surface Water Quality Standards*. The segment values are 514 mg/l for hardness (as calcium carbonate), 1700 mg/l chlorides, 7.6 standard units for pH, and 14 mg/l for TSS. For additional details on the calculation of water quality-based effluent limitations, refer to the TCEQ guidance document.

TCEQ practice for determining significant potential is to compare the reported analytical data against percentages of the calculated daily average water quality-based effluent limitation. Permit limitations are required when analytical data reported in the application exceeds 85% of the calculated daily average water quality-based effluent limitation. Monitoring and reporting is required when analytical data reported in the application exceeds 70% of the calculated daily average water quality-based effluent limitation. See Attachment B of this Fact Sheet.

## (b) PERMIT ACTION

Analytical data reported in the application was screened against calculated water quality-based effluent limitations for the protection of aquatic life. Reported analytical data does not exceed 70% of the calculated daily average water quality-based effluent limitations for aquatic life protection.

## (3) AQUATIC ORGANISM BIOACCUMULATION CRITERIA

#### (a) SCREENING

The discharge point is located at a distance greater than three miles upstream of perennial waters. Human health screening is not applicable because of the distance between the discharge point and perennial waters that support fisheries.

## (b) PERMIT ACTION

None.

#### (4) DRINKING WATER SUPPLY PROTECTION

## (a) SCREENING

Water Quality Segment No. 1412, which receives the discharge from this facility, is not designated as a public water supply. Screening reported analytical data of the effluent against water quality-based effluent limitations calculated for the protection of a drinking water supply is not applicable.

## (b) PERMIT ACTION

None.

## (5) WHOLE EFFLUENT TOXICITY (BIOMONITORING) CRITERIA

## (a) SCREENING

TCEQ has determined that there may be pollutants present in the effluent that may have the potential to cause toxic conditions in the receiving stream. Whole effluent biomonitoring is the most direct measure of potential toxicity that incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. Biomonitoring of the effluent is, therefore, required as a condition of this permit to assess potential toxicity.

The existing permit includes 48-hour acute freshwater biomonitoring requirements. A summary of the biomonitoring testing for the facility indicates that in the past three years, the permittee has performed twenty-two 48-hour acute tests, with zero demonstrations of significant toxicity (i.e., zero failures).

A reasonable potential (RP) determination was performed in accordance with 40 CFR § 122.44(d)(1)(ii) to determine whether the discharge will reasonably be expected to cause or contribute to an exceedance of a state water quality standard or criterion within that standard. Each test species is evaluated separately. The RP determination is based on representative data from the previous three years of 48-hour acute WET testing. This determination was performed in accordance with the methodology outlined in the TCEQ letter to the EPA dated December 28, 2015, and approved by the EPA in a letter dated December 28, 2015.

With zero failures, a determination of no RP was made, and WET limits are not required. Both test species are eligible for the testing frequency reduction.

## (b) PERMIT ACTION

The test species are appropriate to measure the toxicity of the effluent consistent with the requirements of the State water quality standards. The biomonitoring frequency has been established to reflect the likelihood of ambient toxicity and to provide data representative of the toxic potential of the facility's discharge. This permit may be reopened to require effluent limits, additional testing, and/or other appropriate actions to address toxicity if biomonitoring data show actual or potential ambient toxicity to

be the result of the permittee's discharge to the receiving stream or water body.

#### (6) WHOLE EFFLUENT TOXICITY CRITERIA (24-HOUR ACUTE)

## (a) SCREENING

The existing permit includes 24-hour acute freshwater biomonitoring language. A summary of the biomonitoring testing for the facility indicates that in the past three years, the permittee has performed ten 24-hour acute tests, with zero demonstrations of significant lethality (i.e., zero failures).

#### (b) PERMIT ACTION

The draft permit includes 24-hour 100% acute biomonitoring tests for the life of the permit.

## 9. WATER QUALITY VARIANCE REQUESTS

No variance requests have been received.

## 10. PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person

is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Sonia Bhuiya at (512) 239-1205.

## 11. ADMINISTRATIVE RECORD

The following items were considered in developing the draft permit:

#### A. PERMIT(S)

TPDES Permit No. WO0010107001 issued on December 6, 2019.

#### B. APPLICATION

Application received on June 3, 2024, and additional information received on June 26, 2025.

## C. MEMORANDA

Interoffice Memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division. Interoffice Memorandum from the Pretreatment Team of the TCEQ Water Quality Division.

## D. MISCELLANEOUS

Federal Clean Water Act § 402; Texas Water Code § 26.027; 30 TAC Chapters 30, 305, 309, 312, and 319; Commission policies; and U.S. Environmental Protection Agency guidelines.

Texas Surface Water Quality Standards, 30 TAC §§ 307.1 - 307.10.

Procedures to Implement the Texas Surface Water Quality Standards (IP), Texas Commission on Environmental Quality, June 2010, as approved by the City of Lamesa TPDES Permit No. WQ0010107001 Fact Sheet and Executive Director's Preliminary Decision

U.S. Environmental Protection Agency, and the IP, January 2003, for portions of the 2010 IP not approved by the U.S. Environmental Protection Agency.

Texas 2022 Clean Water Act Section 303(d) List, Texas Commission on Environmental Quality, June 1, 2022; approved by the U.S. Environmental Protection Agency on July 7, 2022.

Texas Natural Resource Conservation Commission, Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.

# Attachment A: Screening Calculations for Total Dissolved Solids, Chloride, and Sulfate

## Menu 1 - Discharge to an Intermittent Stream

Applicant Name:

Permit Number, Outfall:

10107001

Segment Number: 001

Enter values needed for screening:			Data Source (edit if different)
TDS CC - segment criterion - TDS	20000	mg/L	2010 TSWQS, Appendix A
Cl CC - segment criterion - chloride	11000	mg/L	2010 TSWQS, Appendix A
SO4 CC - segment criterion - sulfate	2500	mg/L	2010 TSWQS, Appendix A
TDS CE - average effluent concentration - TDS	1170	mg/L	Permit application
Cl CE - average effluent concentration - chloride	391	mg/L	Permit application
SO4 CE - average effluent concentration - sulfate	197	mg/L	Permit application

## **TDS Screening**

The TDS screening value is determined by first calculating an initial TDS concentration, CTDS, as follows:

CTDS = (TDS CC / 500 mg/L) \* 2,500 mg/L

Where:

Ctds = TDS concentration used to determine Csv screening value

TDS CC = TDS criterion at the first downstream segment

500 mg/L = the median TDS concentration in Texas streams

2,500 mg/L = the minimum TDS screening value

CTDS = 100000 mg/L

The next step is to use the initial CTDS to set the actual TDS screening value, TDS Csv, using the following table:

If CTDS		Then TDS Csv
≤ 2,500 mg/L	=	2,500 mg/L
> 2,500 mg/L but ≤ 6,000 mg/L	=	Стрѕ
> 6,000 mg/L	=	6,000 mg/L

Some specific types of intermittent streams have alternative screening values (Csv):

## City of Lamesa TPDES Permit No. WQ0010107001 Fact Sheet and Executive Director's Preliminary Decision

Specific Type of Intermittent Stream	If CTDS is	Default Csv =
Dry except for short-term flow in	< 4,000 mg/L	4,000
		mg/L
immediate response to rainfall.	≥ 4,000 mg/L	CTDS
Constructed ditch conveying stormwater and	< 4,000 mg/L	4,000
		mg/L
wastewater, considered water in the state.	≥ 4,000 mg/L	CTDS
Within 3 miles of tidal waters.	_	6,000
		mg/L

Once TDS Csv is established, the next step is to compare the effluent TDS concentration, TDS CE, to the screening value. Control measures, which may include effluent limitations, are considered for TDS if the effluent TDS is greater than the screening value.

Values needed for Screening				Data
				Source
TDS CE - average effluent TDS concentra	ation	1170	mg/L	Permit application
TDS Csv - TDS screening value		6000	mg/L	Determined above
No control measures needed if:	1170	≤	6000	
Consider control measures if:	1170	>	6000	
No control measures needed for TDS				

# Chloride Screening

If TDS limits are necessary or there are concerns about chloride, additional screening can be performed for chloride. First calculate the screening value for chloride, Cl Csv, as follows:

Cl Csv = (TDS Csv /TDS CC) \* Cl CC

Where:	Cl Csv = chloride screening value
	TDS Csv = TDS screening value
	TDS CC = TDS criterion at the first downstream segment
	Cl CC - chloride criterion at the first downstream segment
	Cl Csv = <b>3300</b> mg/l

Once the CI Csv is established, the next step is to compare the effluent chloride concentration, CI CE, to the screening value. Control measures, which may include effluent limitations, are considered for chloride if the effluent chloride is greater than the screening value.

## City of Lamesa TPDES Permit No. WQ0010107001 Fact Sheet and Executive Director's Preliminary Decision

Values needed for Screening				Data
				Source
Cl CE - average effluent chloride concer	391	mg/L	Permit application	
Cl Csv - chloride screening value	3300	mg/L	Determined above	
No control measures needed if:	391	≤	3300	
Consider control measures if: 391		>	3300	

## No control measures needed for chloride

## **Sulfate Screening**

If TDS limits are necessary or there are concerns about sulfate, additional screening can be performed for sulfate. First calculate the screening value for sulfate, SO4 Csv, as follows:

Where:	SO4 Csv = sulfate screening value
	TDS Csv = TDS screening value
	TDS CC = TDS criterion at the first downstream segment
	SO4 CC - sulfate criterion at the first downstream segment

SO4 Csv = **750** mg/L

Once the SO4 Csv is established, the next step is to compare the effluent sulfate concentration, SO4 CE, to the screening value. Control measures, which may include effluent limitations, are considered for sulfate if the effluent sulfate is greater than the screening value.

Values needed for Screening	Data Source			
SO4 CE - average effluent sulfate conce	ntration	197	mg/L	Permit application
SO4 Csv - sulfate screening value		750	mg/L	Determined above
No control measures needed if: Consider control measures if:	197 197	≤ >	750 750	

No control measures needed for sulfate

## **Attachment B: Calculated Water Quality Based Effluent Limitations**

## TEXTOX MENU #1 - INTERMITTENT STREAM

The water quality-based effluent limitations developed below are calculated using:

Table 1, 2014 Texas Surface Water Quality Standards (30 TAC 307) for Freshwater Aquatic Life  $\,$ 

"Procedures to Implement the Texas Surface Water Quality Standards," TCEQ, June 2010

#### PERMIT INFORMATION

 Permittee Name:
 City of Lamesa

 TPDES Permit No:
 WQ0010107001

 Outfall No:
 001

 Prepared By:
 Sonia Bhuiya

 Date:
 June 16, 2025

#### **DISCHARGE INFORMATION**

Intermittent Receiving Waterbody: Sulphur Springs Draw Segment No: 1412 TSS (mg/L): 14 pH (Standard Units): 7.6 514 Hardness (mg/L as CaCO<sub>3</sub>): Chloride (mg/L): 1700 Effluent Flow for Aquatic Life (MGD): Critical Low Flow [7Q2] (cfs): 0 % Effluent for Acute Aquatic Life: 100

#### CALCULATE DISSOLVED FRACTION (AND ENTER WATER EFFECT RATIO IF APPLICABLE):

Stream/River Metal	Intercept (b)	Slope (m)	Partition Coefficient (Kp)	Dissolved Fraction (Cd/Ct)	Source	Water Effect Ratio (WER)	Source
Aluminum	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Arsenic	5.68	-0.73	69715.05	0.506		1.00	Assumed
Cadmium	6.60	-1.13	201778.70	0.261		1.00	Assumed
Chromium (total)	6.52	-0.93	284512.22	0.201		1.00	Assumed
Chromium (trivalent)	6.52	-0.93	284512.22	0.201		1.00	Assumed
Chromium (hexavalent)	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Copper	6.02	-0.74	148547.47	0.325		1.00	Assumed
Lead	6.45	-0.80	341269.57	0.173		1.00	Assumed
Mercury	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Nickel	5.69	-0.57	108819.57	0.396		1.00	Assumed
Selenium	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Silver	6.38	-1.03	158302.63	0.311		1.00	Assumed
Zinc	6.10	-0.70	198477.09	0.265		1.00	Assumed

#### **AQUATIC LIFE**

## CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:

Parameter	FW Acute Criterion (μg/L)	WLAa (μg/L)	LTAα (μg/L)	Daily Avg. (μg/L)	Daily Max. (μg/L)
Aldrin	3.0	3.00	1.72	2.52	5.34
Aluminum	991	991	568	834	1765
Arsenic	340	672	385	565	1197
Cadmium	42.0389	161	92.1	135	286
Carbaryl	2.0	2.00	1.15	1.68	3.56

# City of Lamesa TPDES Permit No. WQ0010107001 Fact Sheet and Executive Director's Preliminary Decision

Chlordane	2.4	2.40	1.38	2.02	4.27
Chlorpyrifos	0.083	0.0830	0.0476	0.0699	0.147
Chromium (trivalent)	2177.576	10851	6218	9140	19337
Chromium (hexavalent)	15.7	15.7	9.00	13.2	27.9
Copper	66.40689	205	117	172	364
Cyanide (free)	45.8	45.8	26.2	38.5	81.6
4,4'-DDT	1.1	1.10	0.630	0.926	1.96
Demeton	N/A	N/A	N/A	N/A	N/A
Diazinon	0.17	0.170	0.0974	0.143	0.302
Dicofol [Kelthane]	59.3	59.3	34.0	49.9	105
Dieldrin	0.24	0.240	0.138	0.202	0.427
Diuron	210	210	120	176	374
Endosulfan I (alpha)	0.22	0.220	0.126	0.185	0.392
Endosulfan II (beta)	0.22	0.220	0.126	0.185	0.392
Endosulfan sulfate	0.22	0.220	0.126	0.185	0.392
Endrin	0.086	0.0860	0.0493	0.0724	0.153
Guthion [Azinphos Methyl]	N/A	N/A	N/A	N/A	N/A
Heptachlor	0.52	0.520	0.298	0.438	0.926
Hexachlorocyclohexane (gamma)					
[Lindane]	1.126	1.13	0.645	0.948	2.00
Lead	362.4845	2094	1200	1764	3732
Malathion	N/A	N/A	N/A	N/A	N/A
Mercury	2.4	2.40	1.38	2.02	4.27
Methoxychlor	N/A	N/A	N/A	N/A	N/A
Mirex	N/A	N/A	N/A	N/A	N/A
Nickel	1870.421	4720	2705	3975	8411
Nonylphenol	28	28.0	16.0	23.5	49.8
Parathion (ethyl)	0.065	0.0650	0.0372	0.0547	0.115
Pentachlorophenol	15.94268	15.9	9.14	13.4	28.4
Phenanthrene	30	30.0	17.2	25.2	53.4
Polychlorinated Biphenyls [PCBs]	2.0	2.00	1.15	1.68	3.56
Selenium	20	20.0	11.5	16.8	35.6
Silver	0.8	28.6	16.4	24.1	51.0
Toxaphene	0.78	0.780	0.447	0.657	1.38
Tributyltin [TBT]	0.13	0.130	0.0745	0.109	0.231
2,4,5 Trichlorophenol	136	136	77.9	114	242
Zinc	469.0879	1773	1016	1493	3158

## CALCULATE 70% AND 85% OF DAILY AVERAGE EFFLUENT LIMITATIONS:

Aquatic Life	70% of Daily Avg.	85% of Daily Avg.
Parameter	(μg/L)	(μg/L)
Aldrin	1.76	2.14
Aluminum	584	709
Arsenic	396	481
Cadmium	94.8	115
Carbaryl	1.17	1.43
Chlordane	1.41	1.71
Chlorpyrifos	0.0489	0.0594
Chromium (trivalent)	6398	7769
Chromium (hexavalent)	9.25	11.2
Copper	120	146

# City of Lamesa TPDES Permit No. WQ0010107001 Fact Sheet and Executive Director's Preliminary Decision

Cyanide (free)	27.0	32.7
4,4'-DDT	0.648	0.787
Demeton	N/A	N/A
Diazinon	0.100	0.121
Dicofol [Kelthane]	34.9	42.4
Dieldrin	0.141	0.171
Diuron	123	150
Endosulfan I (alpha)	0.129	0.157
Endosulfan II (beta)	0.129	0.157
Endosulfan sulfate	0.129	0.157
Endrin	0.0507	0.0615
Guthion [Azinphos Methyl]	N/A	N/A
Heptachlor	0.306	0.372
Hexachlorocyclohexane (gamma)		
[Lindane]	0.663	0.806
Lead	1234	1499
Malathion	N/A	N/A
Mercury	1.41	1.71
Methoxychlor	N/A	N/A
Mirex	N/A	N/A
Nickel	2782	3379
Nonylphenol	16.5	20.0
Parathion (ethyl)	0.0383	0.0465
Pentachlorophenol	9.40	11.4
Phenanthrene	17.6	21.4
Polychlorinated Biphenyls [PCBs]	1.17	1.43
Selenium	11.7	14.3
Silver	16.8	20.5
Toxaphene	0.459	0.558
Tributyltin [TBT]	0.0766	0.0930
2,4,5 Trichlorophenol	80.1	97.3
Zinc	1045	1269