

#### This file contains the following documents:

- 1. Summary of application (in plain language)
  - English
  - Alternative Language (Spanish)
- 2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
  - English
  - Alternative Language (Spanish)
- 3. Second notice (NAPD-Notice of Preliminary Decision)
  - English
  - Alternative Language (Spanish)
- 4. Application materials \*
- 5. Draft permit \*
- 6. Technical summary or fact sheet \*



# Portada de Paquete Técnico

## Este archivo contiene los siguientes documentos:

- 1. Resumen de la solicitud (en lenguaje sencillo)
  - Inglés
  - Idioma alternativo (español)
- 2. Primer aviso (NORI, Aviso de Recepción de Solicitud e Intención de Obtener un Permiso)
  - Inglés
  - Idioma alternativo (español)
- 3. Segundo aviso (NAPD, Aviso de Decisión Preliminar)
  - Inglés
  - Idioma alternativo (español)
- 4. Materiales de la solicitud \*\*
- 5. Proyecto de permiso \*\*
- 6. Resumen técnico u hoja de datos \*\*



# Permitting Services, LLC

6425 Bankside Drive, Suite 2111 Houston, TX 77096 robin@permittingservices.net Tel. 713-458-8612

August 2, 2024

Texas Commission on Environmental Quality Water Quality Division Application Review and Processing Team (MC148) P.O. Box 13087 Austin, TX 78711-3087

Re:

Application to Renew Permit Number: WQ0010145001 - CITY OF CARRIZO SPRINGS

Customer Number: CN600241418

Regulated Entity Number: RN101721124

Dear Chief Officer,

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Carrizo Springs (CN600241418) operates the Carrizo Springs Wastewater Treatment Plant (RN101721124), the plant is a Extended Aeration and operates as an activated sludge wastewater treatment process to treat the wastewater before it is discharged. The facility is located approximately 0.5 miles NE of the intersection of US Hwy. 83 and S.H.-85 and S.H.-85 in Carrizo Springs, Dimmit County, Texas 78834.

This application is for a renewal to dispose a daily average flow not to exceed 950,000 gallons per day of treated domestic wastewater via outfall 001.

Discharges from the facility are expected to contain seven-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater is treated by an Existing Phase I: The plant operates as an activated sludge wastewater treatment process to treat the wastewater prior to release into a stream. Treatment Plant includes extended aeration: effluent enters through a mechanical screen to a lift station & lifted to an aeration basin. MLSS flows by gravity to the clarifier. Sludge pumps return sludge from clarifier to an

aeration basin or is wasted to sludge beds. Clear effluent from the clarifier flows by gravity to UV for disinfection, to Parshall flume then to a point of discharge. The sludge is transported by truck from City of Carrizo Springs to the City of Carrizo Springs Municipal Landfill in Dimmit County.

The plant discharges treated wastewater at a volume not to exceed an annual average flow of 950,000 gallons per day. The effluent discharges through a 20" pipe to Carrizo Creek; thence to Soldier Slough; thence to Nueces River above Holland Dam in Segment No. 2105 of the Nueces River Basin.

I appreciate your time and effort in reviewing my summary. If you have any questions, please contact me at (713) 458-8612, or via email at <a href="mailto:robin@permittingservices.net">robin@permittingservices.net</a>.

Yours truly,

Robin Butcho

Robin Butcko Senior Wastewater Consultant Permitting Services, LLC (713) 458-8612



# Permitting Services, LLC

6425 Bankside Drive, Suite 2111 Houston, TX 77096 robin@permittingservices.net Tel. 713-458-8612

2 de agosto de 2024

Texas Commission on Environmental Quality Water Quality Division Application Review and Processing Team (MC148) P.O. Box 13087 Austin, TX 78711-3087

Re:

Solicitud de renovación del número de permiso: WQ0010145001

Número de cliente: CN600241418

Número de entidad regulada: RN101721124

Estimado Oficial Principal,

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no son representaciones federales exigibles de la solicitud de permiso.

La ciudad de Carrizo Springs (CN600241418) opera la Planta de Tratamiento de Aguas Residuales (RN101721124) de Carrizo Springs, la planta es de aireación extendida y funciona como una planta de aguas residuales de lodos activados proceso de tratamiento para tratar las aguas residuales antes de su vertido. La instalación está ubicada aproximadamente a 0.5 millas al NE de la intersección de US Hwy. 83 y S.H.-85 y S.H.-85 en Carrizo Springs, Dimmit County, Texas 78834.

Esta solicitud es para una renovación para disponer de un flujo promedio diario que no exceda los 950,000 galones por día de aguas residuales domésticas tratadas a través del desagüe 001.

Se espera que las descargas de la instalación contengan una demanda bioquímica de oxígeno carbonoso (CBOD5) de siete días, sólidos suspendidos totales (TSS), nitrógeno amoniacal (NH3-N) y Escherichia coli. En la sección 7 del Informe Técnico Nacional 1.0 se incluyen contaminantes potenciales adicionales. Análisis de Contaminantes de Efluentes Tratados en el paquete de solicitud de permisos. Las aguas residuales domésticas se tratan mediante una Fase I existente: La planta funciona como un proceso de tratamiento de aguas residuales con lodos activados para tratar las aguas residuales antes de su vertido en un arroyo. La Planta de Tratamiento incluye la extension Aireación: El efluente ingresa a través de una pantalla mecánica a una estación de bombeo y se eleva a una cuenca de aireación. MLSS fluye por

gravedad hacia el clarificador. Las bombas de lodos devuelven los lodos del clarificador a uncuenca de aireación o se desperdicia en lechos de lodos. El efluente claro del clarificador fluye por gravedad a los rayos UV para su desinfección, al canal de Parshall y luego a un punto de descarga. El lodo se transporta en camión desde la ciudad de Carrizo Springs hasta el vertedero municipal de la ciudad de Carrizo Springs en el condado de Dimmit.

La planta descarga aguas residuales tratadas a un volumen que no excede un flujo promedio anual de 950,000 galones por día. El efluente se descarga a través de una tubería de 20" al arroyo Carrizo; de allí al Soldier Slough; de allí al río Nueces por encima de la presa Holland en el segmento No. 2105 de la cuenca del río Nueces.

Agradezco su tiempo y esfuerzo en la revisión de mi resumen. Si tiene alguna pregunta, comuníquese conmigo al (713) 458-8612, o por correo electrónico a robin@permittingservices.net.

Atentamente,

Robin Butcho

Robin Butcko Senior Wastewater Consultant Permitting Services, LLC 713.458.8612 Jon Niermann, *Chairman*Bobby Janecka, *Commissioner*Catarina R. Gonzales, *Commissioner*Kelly Keel, *Executive Director* 



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

September 12, 2024

Ms. Robin Butcko, BBA Senior Wastewater Consultant Permitting Services LLC 6425 Bankside Drive, Suite 2111 Houston, Texas 77096

RE: Application to Renew, for Permit No.: WQ0010145001 (EPA I.D. No. TX0025976)

Applicant Name: City of Carrizo Springs (CN600241418) Site Name: City of Carrizo Springs WWTP (RN101721124)

Type of Application: Renewal without changes

#### **VIA EMAIL**

Dear Ms. Butcko:

We have received the application for the above referenced permit, and it is currently under review. Your attention to the following item(s) are requested before we can declare the application administratively complete. Please submit responses to the following items via email.

The following is a portion of the NORI which contains information relevant to your application. Please read it carefully and indicate if it contains any errors or omissions. The complete notice will be sent to you once the application is declared administratively complete.

APPLICATION. City of Carrizo Springs, P.O. Box 329, Carrizo Springs, Texas 78834, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010145001 (EPA I.D. No. TX0025976) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 950,000 gallons per day. The domestic wastewater treatment facility is located at located approximately 0.5 mile northeast of the intersection of U.S. Highway 83 and State Highway 85, near the city of Carrizo Springs, in Dimmit County, Texas 78834. The discharge route is from the plant site to Carrizo Creek; thence to Soldier Slough; thence to Nueces River Above Holland Dam. TCEQ received this application on September 5, 2024. The permit application will be available for viewing and copying at Carrizo Springs City Hall, 308 Pena Street, Carrizo Springs, in Dimmit County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. This link to an electronic map of the site or facility's general location is provided as a public

Ms. Robin Butcko, BBA Page 2 September 12, 2024 Permit No. WQ0010145001

courtesy and not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-99.85,28.525&level=18

1. The application indicates that public notices in Spanish are required. After confirming the portion of the NORI above does not contain any errors or omissions, please use the attached template to translate the NORI into Spanish. Only the first and last paragraphs are unique to this application and require translation. Please provide the translated Spanish NORI in a Microsoft Word document.

Further information may also be obtained from City of Carrizo Springs at the address stated above or by calling Ms. Robin Butcko, BBA, Senior Wastewater Consultant, at 713-458-8612.

Please submit the complete response, addressed to my attention by September 26, 2024. If you should have any questions, please do not hesitate to contact me by phone at (512) 239-2441 or by email at Francesca.Findlay@tceq.texas.gov

Sincerely,

San Sindley

Francesca Findlay Application Review and Processing Team (MC148) Water Quality Division Texas Commission of Environmental Quality

F.F.

Enclosure(s)

cc: Mr. Ramsey Castillo, Waster Department Supervisor, City of Carizzo Springs, P.O. Box 329, Carizo Springs, Texas 78834

# Comisión de Calidad Ambiental del Estado de Texas



#### AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

#### PERMISO NO. WQ0010145001

**SOLICITUD.** Ciudad de Carrizo Springs, P.O. Box 329, Carrizo Springs, Texas 78834, ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso No. WQ0010145001 (EPA I.D. No. TX 0025976) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 950,000 galones por día. La planta está ubicada aproximadamente 0.5 millas al noreste de la intersección de la autopista U.S. Highway 83 y la carretera estatal 85, cerca de la ciudad de Carrizo Springs en el Condado de Dimmit, Texas. La ruta de descarga es del sitio de la planta a Arroyo Carrizo; de allí a Soldier Slough; de allí al río Nueces Sobre la presa de Holland. La TCEQ recibió esta solicitud el septiembre 5, 2024. La solicitud para el permiso estará disponible para leerla y copiarla en 308 Pena Street, Carrizo Springs, en el condado de Dimmit, Texas antes de la fecha de publicación de este aviso en el periódico. La aplicación incluidas las actualizaciones y los avisos asociados están disponibles electrónicamente en la siguiente pagina web:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-99.85,28.525&level=18

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

#### OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

**LISTA DE CORREO.** Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la

TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía <a href="http://www14.tceq.texas.gov/epic/eComment/">http://www14.tceq.texas.gov/epic/eComment/</a>o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Ciudad de Carrizo Springs a la dirección indicada arriba o llamando a Sra. Robin Butcko al 713-458-8612.

Fecha de emission: 30 de septiembre de 2024

# **Texas Commission on Environmental Quality**



# NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR MUNICIPAL WASTEWATER

#### **RENEWAL**

#### **PERMIT NO. WQ0010145001**

**APPLICATION AND PRELIMINARY DECISION**. City of Carrizo Springs, P.O. Box 329, Carrizo Springs, Texas 78834 has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010145001 which authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 950,000 gallons per day. TCEQ received this application on September 05, 2024.

The facility is located approximately 0.5 miles northeast of the intersection of U.S. Highway 83 and State Highway 85, in the City of Carrizo Springs, Dimmit County, Texas 78834. The treated effluent is discharged to Carrizo Creek, thence to Soldier Slough, thence to Nueces River above Holland Dam in Segment No. 2105 of the Nueces River Basin. The unclassified receiving water use is limited aquatic life use for Carrizo Creek. The designated uses for Segment No. 2105 are primary contact recreation, public water supply, and high aquatic life use. All determinations are preliminary and subject to additional review and/or revisions. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application. https://gisweb.tceq.texas.gov/LocationMapper/?marker=-99.85,28,525&level=18

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at Carrizo Springs City Hall, 308 Pena Street, Carrizo Springs, in Dimmit County, Texas. The application, including any updates, and associated notices are available electronically at the following webpage: <a href="https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications">https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications</a>.

**ALTERNATIVE LANGUAGE NOTICE.** Alternative language notice in Spanish is available at <a href="https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices">https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices</a>. El aviso de idioma alternativo en español está disponible en <a href="https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices">https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices</a>.

**PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting about this application.** The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ holds a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision. A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period. TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

**EXECUTIVE DIRECTOR ACTION**. The Executive Director may issue final approval of the application unless a timely contested case hearing request or request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

**MAILING LIST**. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, Texas Commission on Environmental Quality, P.O. Box 13087, Austin, TX 78711-3087 or electronically at <a href="https://www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a> within 30 days from the date of newspaper publication of this notice.

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at <a href="https://www.tceq.texas.gov/goto/cid">www.tceq.texas.gov/goto/cid</a>. Search the database using the permit number for this application, which is provided at the top of this notice.

**AGENCY CONTACTS AND INFORMATION.** Public comments and requests must be submitted either electronically at <a href="www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC 105, P.O. Box 13087, Austin, Texas 78711-3087. Any personal information you submit to the TCEQ will become part of the agency's record; this includes email addresses. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at <a href="www.tceq.texas.gov/goto/pep">www.tceq.texas.gov/goto/pep</a>. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from City of Carrizo Springs at the address stated above or by calling Ms. Robin Butcko, BBA, Senior Wastewater Consultant, at 713-458-8612.

Issuance Date: April 4, 2025

#### Comisión De Calidad Ambiental Del Estado De Texas



#### ANUNCIO DE SOLICITUD Y DECISIÓN PRELIMINAR PARA EL PERMISO TPDES PARA AGUAS RESIDUALES MUNICIPALES

#### RENOVACIÓN

#### **PERMISO NO. WQ0010145001**

**SOLICITUD Y DECISIÓN PRELIMINAR.** Ciudad de Carrizo Springs, P.O. Box 329, Carrizo Springs, Texas 78834 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) una renovación para autorizar la descarga de aguas residuales domésticas tratadas a un flujo promedio diario que no exceda los 950,000 galones por día. La TCEQ recibió esta solicitud el 05 de septiembre de 2024.

La planta está ubicada en aproximadamente 0.5 millas al noreste de la intersección de la autopista U.S. Highway 83 y la carretera estatal 85, en la ciudad de Carrizo Springs en el Condado de Dimmit Texas 78834. El efluente tratado es descargado al Carrizo Creek, de allí a Soldier Slough, de allí al río Nueces por encima de Holland Dam en el Segmento No. 2105 de la Cuenca del Río Cuenca del Río Nueces. Los usos no clasificados de las aguas receptoras son El uso de la vida acuática es limitado para el arroyo Carrizo. Los usos designados para el Segmento No. 2105 son la recreación de contacto primario, el suministro de agua pública y el uso de alta vida acuática. Todas las determinaciones son preliminares y están sujetas a revisión y/o revisiones adicionales. Este enlace a un mapa electrónico de la ubicación general del sitio o instalación se proporciona como cortesía pública y no es parte de la solicitud o aviso. Para conocer la ubicación exacta, consulte la aplicación.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-99.85,28.525&level=18

El Director Ejecutivo de la TCEQ ha completado la revisión técnica de la solicitud y ha preparado un borrador del permiso. El borrador del permiso, si es aprobado, establecería las condiciones bajo las cuales la instalación debe operar. El Director Ejecutivo ha tomado una decisión preliminar que si este permiso es emitido, cumple con todos los requisitos normativos y legales. La solicitud del permiso, la decisión preliminar del Director Ejecutivo y el borrador del permiso están disponibles para leer y copiar en Ayuntamiento de Carrizo Springs, 308 Pena Street, Carrizo Springs, en el condado de Dimmit, Texas. La solicitud, incluidas las actualizaciones, y los avisos asociados están disponibles electrónicamente en la siguiente página web: La solicitud (cualquier actualización y aviso inclusive) está disponible electrónicamente en la siguiente página web:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

**AVISO DE IDIOMA ALTERNATIVO.** El aviso de idioma alternativo en español está disponible en

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

#### OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono: el nombre del solicitante y número del permiso: la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso para descargar aguas residuales sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

**ACCIÓN DEL DIRECTOR EJECUTIVO.** El Director Ejecutivo puede emitir una aprobación final de la solicitud a menos que exista un pedido antes del plazo de vencimiento de una audiencia administrativa de lo contencioso o se ha presentado un pedido de reconsideración. Si un pedido ha llegado antes del plazo de vencimiento de la audiencia o el pedido de reconsideración ha sido presentado, el Director Ejecutivo no emitirá una aprobación final sobre el permiso y enviará la solicitud y el pedido a los Comisionados de la TECQ para consideración en una reunión programada de la Comisión.

**LISTA DE CORREO.** Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

Todos los comentarios escritos del público y los pedidos una reunión deben ser presentados durante los 30 días después de la publicación del aviso a la Oficina del Secretario Principal, MC 105, TCEQ, P.O. Box 13087, Austin, TX 78711-3087 or por el internet a <a href="www.tceq.texas.gov/about/comments.html">www.tceq.texas.gov/about/comments.html</a>. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia.

**CONTACTOS E INFORMACIÓN DE LA AGENCIA.** Los comentarios y solicitudes públicas deben enviarse electrónicamente a <a href="https://www14.tceq.texas.gov/epic/eComment/">https://www14.tceq.texas.gov/epic/eComment/</a>, o por escrito a Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Cualquier información personal que envíe a al TCEQ pasará a formar parte del registro de la agencia; esto incluye las direcciones de correo electrónico. Para obtener más información sobre esta solicitud de permiso o el proceso de permisos, llame al Programa de Educación Pública de la TCEQ, sin cargo, al 1-800-687-4040 o visite su sitio web en www.tceq.texas.gov/goto/pep. Si desea información en español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Ciudad de Carrizo Springs a la dirección indicada arriba o llamando a Sra. Robin Butcko al 713-458-8612.

Fecha de emission: 4 de abril de 2025



TPDES PERMIT NO. WQ0010145001 [For TCEQ office use only - EPA I.D. No. TX0025976]

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY P.O. Box 13087 Austin, Texas 78711-3087

This is a renewal that replaces TPDES Permit No. WQ0010145001 issued on May 14 2020.

#### PERMIT TO DISCHARGE WASTES

under provisions of Section 402 of the Clean Water Act and Chapter 26 of the Texas Water Code

City of Carrizo Springs

whose mailing address is

P.O. Box 329 Carrizo Springs, Texas 78834

is authorized to treat and discharge wastes from the City of Carizzo Springs Wastewater Treatment Facility, SIC Code 4952

located approximately 0.5 miles northeast of the intersection of U.S. Highway 83 and State Highway 85, in the City of Carrizo Springs, Dimmit County, Texas 78834

to Carrizo Creek, thence to Soldier Slough, thence to Nueces River above Holland Dam in Segment No. 2105 of the Nueces River Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does not grant to the permittee the right to use private or public property for conveyance of wastewater along the discharge route described in this permit. This includes, but is not limited to, property belonging to any individual, partnership, corporation or other entity. Neither does this permit authorize any invasion of personal rights nor any violation of federal, state, or local laws or regulations. It is the responsibility of the permittee to acquire property rights as may be necessary to use the discharge route.

This permit shall expire at midnight, five years from the date of issuance.

ISSUED DATE:	
	For the Commission

#### EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the date of issuance and lasting through the date of expiration, the permittee is authorized to discharge subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.95 million gallons per day (MGD), nor shall the average discharge during any two-hour period (2-hour peak) exceed 2,639 gallons per minute (gpm).

Effluent Characteristic	Discharge Limitations				Min. Self-Monitoring Requirements	
	Daily Avg	7-day Avg	Daily Max	Single Grab	Report Daily Avg. & Daily Max.	
	mg/l (lbs/day)	mg/l	mg/l	mg/l	Measurement Frequency	Sample Type
Flow, MGD	Report	N/A	Report	N/A	Continuous	<b>Totalizing Meter</b>
Carbonaceous Biochemical Oxygen Demand (5-day)	10 (79)	15	25	35	One/week	Composite
<b>Total Suspended Solids</b>	15 (119)	25	40	60	One/week	Composite
Ammonia Nitrogen	3 (24)	6	10	15	One/week	Composite
E. coli, colony-forming units or most probable number per 100 ml	126	N/A	399	N/A	Daily	Grab

- 2. The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored twice per month by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 4 mg/l and shall be monitored once per week by grab sample.

#### **DEFINITIONS AND STANDARD PERMIT CONDITIONS**

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC § 305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§ 5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§ 361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in TWC § 26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

#### 1. Flow Measurements

- a. Annual average flow the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder and limited to major domestic wastewater discharge facilities with one million gallons per day or greater permitted flow.
- b. Daily average flow the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) the highest 2-hour peak flow for any 24-hour period in a calendar month.

#### 2. Concentration Measurements

- a. Daily average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
  - i. For domestic wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.

- ii. For all other wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day.

The daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the daily discharge determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.

- e. Bacteria concentration (*E. coli* or Enterococci) Colony Forming Units (CFU) or Most Probable Number (MPN) of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the nth root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or, computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substituted value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
- f. Daily average loading (lbs/day) the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD x Concentration, mg/l x 8.34).
- g. Daily maximum loading (lbs/day) the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.

## 3. Sample Type

a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (b).

- b. Grab sample an individual sample collected in less than 15 minutes.
- 4. Treatment Facility (facility) wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation and/or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
- 5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
- 6. The term "biosolids" is defined as sewage sludge that has been tested or processed to meet Class A, Class AB, or Class B pathogen standards in 30 TAC Chapter 312 for beneficial use.
- 7. Bypass the intentional diversion of a waste stream from any portion of a treatment facility.

#### MONITORING AND REPORTING REQUIREMENTS

#### 1. Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§ 319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Enforcement Division (MC 224), by the 20th day of the following month for each discharge which is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act (CWA); TWC §§ 26, 27, and 28; and THSC § 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

#### 2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§ 319.11 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC § 25, Environmental Testing Laboratory Accreditation and Certification.

#### 3. Records of Results

a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.

- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge or biosolids use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR § 264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:
  - i. date, time and place of sample or measurement;
  - ii. identity of individual who collected the sample or made the measurement.
  - iii. date and time of analysis;
  - iv. identity of the individual and laboratory who performed the analysis;
  - v. the technique or method of analysis; and
  - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

#### 4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

#### 5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site and/or shall be readily available for review by a TCEQ representative for a period of three years.

#### 6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the Regional Office and the Enforcement

Division (MC 224).

#### 7. Noncompliance Notification

- a. In accordance with 30 TAC § 305.125(9) any noncompliance which may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Except as allowed by 30 TAC § 305.132, report of such information shall be provided orally or by facsimile transmission (FAX) to the Regional Office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the Regional Office and the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
- b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
  - i. Unauthorized discharges as defined in Permit Condition 2(g).
  - ii. Any unanticipated bypass that exceeds any effluent limitation in the permit.
  - iii. Violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
- c. In addition to the above, any effluent violation which deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the Regional Office and the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
- d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
- 8. In accordance with the procedures described in 30 TAC §§ 35.301 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
- 9. Changes in Discharges of Toxic Substances
  - All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the Regional Office, orally or by facsimile transmission within 24 hours, and both the Regional Office and the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - i. One hundred micrograms per liter (100  $\mu$ g/L);
  - ii. Two hundred micrograms per liter (200  $\mu$ g/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500  $\mu$ g/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - i. Five hundred micrograms per liter (500  $\mu$ g/L);
  - ii. One milligram per liter (1 mg/L) for antimony;
  - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.

#### 10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC § 305.128 (relating to Signatories to Reports).

- 11. All POTWs must provide adequate notice to the Executive Director of the following:
  - a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to CWA § 301 or § 306 if it were directly discharging those pollutants;
  - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and
  - c. For the purpose of this paragraph, adequate notice shall include information on:
    - i. The quality and quantity of effluent introduced into the POTW; and
    - ii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

#### PERMIT CONDITIONS

#### 1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
  - i. Violation of any terms or conditions of this permit;
  - ii. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
  - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

#### 2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment, revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.
- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance

with 30 TAC §§ 305.62 and 305.66 and TWC§ 7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC § 305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility which does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under TWC §§ 7.051 7.075 (relating to Administrative Penalties), 7.101 7.111 (relating to Civil Penalties), and 7.141 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§ 301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA § 402, or any requirement imposed in a pretreatment program approved under the CWA §§ 402 (a)(3) or 402 (b)(8).

#### 3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC § 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC § 7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

#### 4. Permit Amendment and/or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
  - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC § 305.534 (relating to New Sources and New Dischargers); or
  - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
  - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes which are not described in the permit application or which would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC § 26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA § 307(a) for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA § 307(a) for toxic pollutants within the time provided in the

regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

#### 5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC § 305.64 (relating to Transfer of Permits) and 30 TAC § 50.133 (relating to Executive Director Action on Application or WQMP update).

#### 6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

## 7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to TWC Chapter 11.

#### 8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

#### 9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

#### 10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

#### 11. Notice of Bankruptcy

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
  - i. the permittee;
  - ii. an entity (as that term is defined in 11 USC, § 101(14)) controlling the permittee or listing the permit or permittee as property of the estate; or
  - iii. an affiliate (as that term is defined in 11 USC, § 101(2)) of the permittee.

- b. This notification must indicate:
  - i. the name of the permittee;
  - ii. the permit number(s);
  - iii. the bankruptcy court in which the petition for bankruptcy was filed; and
  - iv. the date of filing of the petition.

#### **OPERATIONAL REQUIREMENTS**

- 1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
- 2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge or biosolids use and disposal and 30 TAC §§ 319.21 319.29 concerning the discharge of certain hazardous metals.
- 3. Domestic wastewater treatment facilities shall comply with the following provisions:
  - a. The permittee shall notify the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
  - b. The permittee shall submit a closure plan for review and approval to the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment and/or other treatment unit regulated by this permit.
- 4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, and/or retention of inadequately treated wastewater.
- 5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.
- 6. The permittee shall remit an annual water quality fee to the Commission as required by 30

TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC § 7.302(b)(6).

#### 7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §§ 1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words confidential business information on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

- 8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
  - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion and/or upgrading of the domestic wastewater treatment and/or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment and/or collection facilities. In the case of a domestic wastewater treatment facility which reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been secured.

- c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
- 9. Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
- 10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
- 11. Facilities that generate industrial solid waste as defined in 30 TAC § 335.1 shall comply with these provisions:
  - a. Any solid waste, as defined in 30 TAC § 335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
  - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
  - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC § 335.8(b)(1), to the Corrective Action Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
  - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC § 335.5.
  - e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well,

container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.

- f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC § 335 and must include the following, as it pertains to wastewater treatment and discharge:
  - i. Volume of waste and date(s) generated from treatment process;
  - ii. Volume of waste disposed of on-site or shipped off-site;
  - iii. Date(s) of disposal;
  - iv. Identity of hauler or transporter;
  - v. Location of disposal site; and
  - vi. Method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC § 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC § 361.

TCEO Revision 06/2020

#### **SLUDGE PROVISIONS**

The permittee is authorized to dispose of sludge or biosolids only at a Texas Commission on Environmental Quality (TCEQ) authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge. The disposal of sludge or biosolids by land application on property owned, leased or under the direct control of the permittee is a violation of the permit unless the site is authorized with the TCEQ. This provision does not authorize Distribution and Marketing of Class A or Class AB Biosolids. This provision does not authorize the permittee to land apply biosolids on property owned, leased or under the direct control of the permittee.

# SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS LAND APPLICATION

#### A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge or biosolids.
- 2. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
- 3. The land application of processed or unprocessed chemical toilet waste, grease trap waste, grit trap waste, milk solids, or similar non-hazardous municipal or industrial solid wastes, or any of the wastes listed in this provision combined with biosolids, WTP residuals or domestic septage is prohibited unless the grease trap waste is added at a fats, oil and grease (FOG) receiving facility as part of an anaerobic digestion process.

#### **B.** Testing Requirements

1. Sewage sludge or biosolids shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other method that receives the prior approval of the TCEQ for the contaminants listed in 40 CFR Part 261.24, Table 1. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal. Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 16) within seven (7) days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P.O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. The permittee must submit this annual report by September 30th of each year using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 16) and the Enforcement Division (MC 224).

2. Biosolids shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Section I.C. of this permit.

TABLE 1

<u>Pollutant</u>	<b>Ceiling Concentration</b>
	(Milligrams per kilogram)*
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

<sup>\*</sup> Dry weight basis

#### 3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site must be treated by one of the following methods to ensure that the sludge meets either the Class A, Class AB or Class B biosolids pathogen requirements.

a. For sewage sludge to be classified as Class A biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 most probable number (MPN) per gram of total solids (dry weight basis), or the density of Salmonella sp. bacteria in the sewage sludge must be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 1</u> - The temperature of the sewage sludge that is used or disposed shall be maintained at or above a specific value for a period of time. See 30 TAC § 312.82(a)(2)(A) for specific information;

Alternative 5 (PFRP) - Sewage sludge that is used or disposed of must be treated in one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR Part 503, Appendix B. PFRP include composting, heat drying, heat treatment, and thermophilic aerobic digestion; or

Alternative 6 (PFRP Equivalent) - Sewage sludge that is used or disposed of must be treated in a process that has been approved by the U. S. Environmental Protection Agency as being equivalent to those in Alternative 5.

b. For sewage sludge to be classified as Class AB biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 MPN per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 2</u> - The pH of the sewage sludge that is used or disposed shall be raised to above 12 std. units and shall remain above 12 std. units for 72 hours.

The temperature of the sewage sludge shall be above 52° Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12 std. units.

At the end of the 72-hour period during which the pH of the sewage sludge is above 12 std. units, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50%; or

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is less than one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC  $\S$  312.82(a)(2)(C)(i-iii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC  $\S$  312.82(a)(2)(C)(iv-vi) for specific information; or

<u>Alternative 4</u> - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed.

- c. Sewage sludge that meets the requirements of Class AB biosolids may be classified a Class A biosolids if a variance request is submitted in writing that is supported by substantial documentation demonstrating equivalent methods for reducing odors and written approval is granted by the executive director. The executive director may deny the variance request or revoke that approved variance if it is determined that the variance may potentially endanger human health or the environment, or create nuisance odor conditions.
- d. Three alternatives are available to demonstrate compliance with Class B biosolids criteria.

#### Alternative 1

- i. A minimum of seven random samples of the sewage sludge shall be collected within 48 hours of the time the sewage sludge is used or disposed of during each monitoring episode for the sewage sludge.
- ii. The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

<u>Alternative 2</u> - Sewage sludge that is used or disposed of shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR Part 503, Appendix B, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. An independent Texas Licensed Professional Engineer must make a certification to the generator of a sewage sludge that the wastewater treatment facility generating the sewage sludge is designed to achieve one of the PSRP at the permitted design loading of the facility. The certification need only be repeated if the design loading of the facility is increased. The certification shall include a statement indicating the design meets all the applicable standards specified in Appendix B of 40 CFR Part 503;
- iii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iv. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review; and
- v. If the sewage sludge is generated from a mixture of sources, resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the PSRP, and shall meet the certification, operation, and record keeping requirements of this paragraph.

<u>Alternative 3</u> - Sewage sludge shall be treated in an equivalent process that has been approved by the U.S. Environmental Protection Agency, so long as all of the following requirements are met by the generator of the sewage sludge.

i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;

- ii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iii. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review;
- iv. The Executive Director will accept from the U.S. Environmental Protection Agency a finding of equivalency to the defined PSRP; and
- v. If the sewage sludge is generated from a mixture of sources resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the Processes to Significantly Reduce Pathogens, and shall meet the certification, operation, and record keeping requirements of this paragraph.

In addition to the Alternatives 1 - 3, the following site restrictions must be met if Class B biosolids are land applied:

- i. Food crops with harvested parts that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
- v. Domestic livestock shall not be allowed to graze on the land for 30 days after application of biosolids.
- vi. Turf grown on land where biosolids are applied shall not be harvested for 1 year after application of the biosolids when the harvested turf is placed on either land with a high potential for public exposure or a lawn.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of biosolids.
- viii. Public access to land with a low potential for public exposure shall be restricted

for 30 days after application of biosolids.

ix. Land application of biosolids shall be in accordance with the buffer zone requirements found in 30 TAC § 312.44.

## 4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following Alternatives 1 through 10 for vector attraction reduction.

- <u>Alternative 1</u> The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38%.
- Alternative 2 If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30° and 37° Celsius. Volatile solids must be reduced by less than 17% to demonstrate compliance.
- Alternative 3 If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20° Celsius. Volatile solids must be reduced by less than 15% to demonstrate compliance.
- Alternative 4 The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20° Celsius.
- Alternative 5 Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40° Celsius and the average temperature of the sewage sludge shall be higher than 45° Celsius.
- Alternative 6 The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali shall remain at 12 or higher for two hours and then remain at a pH of 11.5 or higher for an additional 22 hours at the time the sewage sludge is prepared for sale or given away in a bag or other container.
- Alternative 7 The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75% based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.
- <u>Alternative 8</u> The percent solids of sewage sludge that contains unstabilized solids

generated in a primary wastewater treatment process shall be equal to or greater than 90% based on the moisture content and total solids prior to mixing with other materials at the time the sludge is used. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

## Alternative 9 -

- i. Biosolids shall be injected below the surface of the land.
- ii. No significant amount of the biosolids shall be present on the land surface within one hour after biosolids are injected.
- iii. When sewage sludge that is injected below the surface of the land is Class A or Class AB with respect to pathogens, the biosolids shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.

## Alternative 10-

- i. Biosolids applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
- ii. When biosolids that are incorporated into the soil is Class A or Class AB with respect to pathogens, the biosolids shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

## C. Monitoring Requirements

Toxicity Characteristic Leaching Procedure (TCLP) Test
PCBs

- once during the term of this permit
- once during the term of this permit

All metal constituents and fecal coliform or *Salmonella* sp. bacteria shall be monitored at the appropriate frequency shown below, pursuant to 30 TAC § 312.46(a)(1):

Amount of biosolids (\*)

metric tons per 365-day period Monitoring Frequency

o to less than 290 Once/Year

290 to less than 1,500 Once/Quarter

1,500 to less than 15,000 Once/Two Months

15,000 or greater Once/Month

(\*) The amount of bulk biosolids applied to the land (dry wt. basis).

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 30 TAC § 312.7

Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal

coliforms, helminth ova, Salmonella sp., and other regulated parameters.

Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.

Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge or biosolids for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.

# SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE FOR APPLICATION TO THE LAND MEETING CLASS A, CLASS AB or B BIOSOLIDS PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A, Class AB or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below listed in Table 3, the following conditions apply:

#### A. Pollutant Limits

#### Table 2

	Cumulative Pollutant Loading Rate
<u>Pollutant</u>	(pounds per acre)*
Arsenic	36
Cadmium	35
Chromium	2677
Copper	1339
Lead	268
Mercury	15
Molybdenum	Report Only
Nickel	375
Selenium	89
Zinc	2500

## Table 3

	Monthly Average
	Concentration
<u>Pollutant</u>	(milligrams per kilogram)*
Arsenic	41
Cadmium	39
Chromium	1200
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report Only
Nickel	420
Selenium	36
Zinc	2800

## **B.** Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, shall be treated by either Class A, Class AB or Class B biosolids pathogen reduction requirements as defined above in Section I.B.3.

\*Dry weight basis

## **C.** Management Practices

- 1. Bulk biosolids shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk biosolids enters a wetland or other waters in the State.
- 2. Bulk biosolids not meeting Class A biosolids requirements shall be land applied in a manner which complies with Applicability in accordance with 30 TAC §312.41 and the Management Requirements in accordance with 30 TAC § 312.44.
- 3. Bulk biosolids shall be applied at or below the agronomic rate of the cover crop.
- 4. An information sheet shall be provided to the person who receives bulk Class A or AB biosolids sold or given away. The information sheet shall contain the following information:
  - a. The name and address of the person who prepared the Class A or AB biosolids that are sold or given away in a bag or other container for application to the land.
  - b. A statement that application of the biosolids to the land is prohibited except in accordance with the instruction on the label or information sheet.
  - c. The annual whole sludge application rate for the biosolids application rate for the biosolids that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Section II above are met.

#### **D. Notification Requirements**

- 1. If bulk biosolids are applied to land in a State other than Texas, written notice shall be provided prior to the initial land application to the permitting authority for the State in which the bulk biosolids are proposed to be applied. The notice shall include:
  - a. The location, by street address, and specific latitude and longitude, of each land application site.
  - b. The approximate time period bulk biosolids will be applied to the site.
  - c. The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk biosolids.
- 2. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the biosolids disposal practice.

## E. Record Keeping Requirements

The documents will be retained at the facility site and/or shall be readily available for review by a TCEQ representative. The person who prepares bulk sewage sludge or a biosolids material shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative for a period

of <u>five years</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply.

- 1. The concentration (mg/kg) in the sludge of each pollutant listed in Table 3 above and the applicable pollutant concentration criteria (mg/kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (lbs/ac) listed in Table 2 above.
- 2. A description of how the pathogen reduction requirements are met (including site restrictions for Class AB and Class B biosolids, if applicable).
- 3. A description of how the vector attraction reduction requirements are met.
- 4. A description of how the management practices listed above in Section II.C are being met
- 5. The following certification statement:

"I certify, under penalty of law, that the applicable pathogen requirements in 30 TAC § 312.82(a) or (b) and the vector attraction reduction requirements in 30 TAC § 312.83(b) have been met for each site on which bulk biosolids are applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

- 6. The recommended agronomic loading rate from the references listed in Section II.C.3. above, as well as the actual agronomic loading rate shall be retained. The person who applies bulk biosolids shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative <u>indefinitely</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply:
  - a. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii), as applicable, and to the permittee's specific sludge treatment activities.
  - b. The location, by street address, and specific latitude and longitude, of each site on which biosolids are applied.
  - c. The number of acres in each site on which bulk biosolids are applied.
  - d. The date and time biosolids are applied to each site.

- e. The cumulative amount of each pollutant in pounds/acre listed in Table 2 applied to each site.
- f. The total amount of biosolids applied to each site in dry tons.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

## F. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 16) and Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.
- 3. Results of tests performed for pollutants found in either Table 2 or 3 as appropriate for the permittee's land application practices.
- 4. The frequency of monitoring listed in Section I.C. that applies to the permittee.
- 5. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 6. PCB concentration in sludge or biosolids in mg/kg.
- 7. Identity of hauler(s) and TCEQ transporter number.
- 8. Date(s) of transport.
- 9. Texas Commission on Environmental Quality registration number, if applicable.
- 10. Amount of sludge or biosolids disposal dry weight (lbs/acre) at each disposal site.
- 11. The concentration (mg/kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/kg) listed in Table 3 above, or the applicable pollutant loading rate limit (lbs/acre) listed in Table 2 above if it exceeds 90% of the limit.
- 12. Level of pathogen reduction achieved (Class A, Class AB or Class B).
- 13. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B biosolids, include information on how site restrictions were met.

- 14. Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.
- 15. Vector attraction reduction alternative used as listed in Section I.B.4.
- 16. Amount of sludge or biosolids transported in dry tons/year.
- 17. The certification statement listed in either 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii) as applicable to the permittee's sludge or biosolids treatment activities, shall be attached to the annual reporting form.
- 18. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the annual reporting form.
  - a. The location, by street address, and specific latitude and longitude.
  - b. The number of acres in each site on which bulk biosolids are applied.
  - c. The date and time bulk biosolids are applied to each site.
  - d. The cumulative amount of each pollutant (i.e., pounds/acre) listed in Table 2 in the bulk biosolids applied to each site.
  - e. The amount of biosolids (i.e., dry tons) applied to each site.

The above records shall be maintained on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

## SECTION III. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL

- A. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 330 and all other applicable state and federal regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge or biosolids meets the requirements in 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- B. If the permittee generates sewage sludge or biosolids and supplies that sewage sludge or biosolids to the owner or operator of a municipal solid waste landfill (MSWLF) for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
- C. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge or biosolids disposal practice.
- D. Sewage sludge or biosolids shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I (Toxicity Characteristic Leaching Procedure) or other method, which receives the prior approval of the TCEQ for contaminants listed in Table 1 of 40 CFR § 261.24. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal.

Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 16) of the appropriate TCEQ field office within 7 days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P. O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 16) and the Enforcement Division (MC 224) by September 30 of each year.

- E. Sewage sludge or biosolids shall be tested as needed, in accordance with the requirements of 30 TAC Chapter 330.
- F. Record Keeping Requirements

The permittee shall develop the following information and shall retain the information for five years.

- 1. The description (including procedures followed and the results) of all liquid Paint Filter Tests performed.
- 2. The description (including procedures followed and results) of all TCLP tests performed.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

## G. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 16) and Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 3. Annual sludge or biosolids production in dry tons/year.
- 4. Amount of sludge or biosolids disposed in a municipal solid waste landfill in dry tons/year.
- 5. Amount of sludge or biosolids transported interstate in dry tons/year.
- 6. A certification that the sewage sludge or biosolids meets the requirements of 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- 7. Identity of hauler(s) and transporter registration number.
- 8. Owner of disposal site(s).
- 9. Location of disposal site(s).
- 10. Date(s) of disposal.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

# SECTION IV. REQUIREMENTS APPLYING TO SLUDGE OR BIOSOLIDS TRANSPORTED TO ANOTHER FACILITY FOR FURTHER PROCESSING

These provisions apply to sludge or biosolids that is transported to another wastewater treatment facility or facility that further processes sludge or biosolids. These provisions are intended to allow transport of sludge or biosolids to facilities that have been authorized to accept sludge or biosolids. These provisions do not limit the ability of the receiving facility to determine whether to accept the sludge or biosolids, nor do they limit the ability of the receiving facility to request additional testing or documentation.

## A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC Chapter 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
- 2. Sludge or biosolids may only be transported using a registered transporter or using an approved pipeline.

## **B.** Record Keeping Requirements

- 1. For sludge or biosolids transported by an approved pipeline, the permittee must maintain records of the following:
  - a. the amount of sludge or biosolids transported;
  - b. the date of transport;
  - c. the name and TCEQ permit number of the receiving facility or facilities;
  - d. the location of the receiving facility or facilities;
  - e. the name and TCEQ permit number of the facility that generated the waste; and
  - f. copy of the written agreement between the permittee and the receiving facility to accept sludge or biosolids.
- 2. For sludge or biosolids transported by a registered transporter, the permittee must maintain records of the completed trip tickets in accordance with 30 TAC § 312.145(a)(1)-(7) and amount of sludge or biosolids transported.
- The above records shall be maintained on-site on a monthly basis and shall be made available to the TCEQ upon request. These records shall be retained for at least five years.

## **C.** Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 16) and Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. the annual sludge or biosolids production;
- 3. the amount of sludge or biosolids transported;
- 4. the owner of each receiving facility;
- 5. the location of each receiving facility; and
- 6. the date(s) of disposal at each receiving facility.

TCEQ Revision 06/2020

## **OTHER REQUIREMENTS**

- 1. The permittee shall employ or contract with one or more licensed wastewater treatment facility operators or wastewater system operations companies holding a valid license or registration according to the requirements of 30 TAC Chapter 30, Occupational Licenses and Registrations, and in particular 30 TAC Chapter 30, Subchapter J, Wastewater Operators and Operations Companies.
  - This Category C facility must be operated by a chief operator or an operator holding a Class C license or higher. The facility must be operated a minimum of five days per week by the licensed chief operator or an operator holding the required level of license or higher. The licensed chief operator or operator holding the required level of license or higher must be available by telephone or pager seven days per week. Where shift operation of the wastewater treatment facility is necessary, each shift which does not have the on-site supervision of the licensed chief operator must be supervised by an operator in charge who is licensed not less than one level below the category for the facility.
- 2. The facility is not located in the Coastal Management Program boundary.
- 3. The permittee shall comply with the requirements of 30 TAC § 309.13(a) through (d). In addition, by ownership of the required buffer zone area, the permittee shall comply with the requirements of 30 TAC § 309.13(e).
- 4. The permittee shall provide facilities for the protection of its wastewater treatment facility from a 100-year flood.
- 5. In accordance with 30 TAC § 319.9, a permittee that has at least twelve months of uninterrupted compliance with its bacteria limit may notify the commission in writing of its compliance and request a less frequent measurement schedule. To request a less frequent schedule, the permittee shall submit a written request to the TCEQ Wastewater Permitting Section (MC 148) for each phase that includes a different monitoring frequency. The request must contain all of the reported bacteria values (Daily Avg. and Daily Max/Single Grab) for the twelve consecutive months immediately prior to the request. If the Executive Director finds that a less frequent measurement schedule is protective of human health and the environment, the permittee may be given a less frequent measurement schedule. For this permit daily may be reduced to 5/week. A violation of any bacteria limit by a facility that has been granted a less frequent measurement schedule will require the permittee to return to the standard frequency schedule and submit written notice to the TCEQ Wastewater Permitting Section (MC 148). The permittee may not apply for another reduction in measurement frequency for at least 24 months from the date of the last violation. The Executive Director may establish a more frequent measurement schedule if necessary to protect human health or the environment.

## CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

- 1. The following pollutants may not be introduced into the treatment facility:
  - a. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed-cup flash point of less than 140° Fahrenheit (60° Celsius) using the test methods specified in 40 CFR § 261.21;
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case shall there be discharges with a pH lower than 5.0 standard units, unless the works are specifically designed to accommodate such discharges;
  - c. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference;
  - d. Any pollutant, including oxygen-demanding pollutants (e.g., biochemical oxygen demand or BOD), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW;
  - e. Heat in amounts which will inhibit biological activity in the POTW, resulting in Interference, but in no case shall there be heat in such quantities that the temperature at the POTW treatment plant exceeds 104° Fahrenheit (40° Celsius) unless the Executive Director, upon request of the POTW, approves alternate temperature limits;
  - f. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through;
  - g. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and
  - h. Any trucked or hauled pollutants except at discharge points designated by the POTW.
- 2. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Clean Water Act, including any requirements established under 40 CFR Part 403 [rev. Federal Register/Vol. 70/No. 198/Friday, October 14, 2005/Rules and Regulations, pages 60134-60798].
- 3. The permittee shall provide adequate notification to the Executive Director, care of the Wastewater Permitting Section (MC 148) of the Water Quality Division, within 30 days subsequent to the permittee's knowledge of either of the following:
  - a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Clean Water Act if it were directly discharging those pollutants; and
  - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Any notice shall include information on the quality and quantity of effluent to be introduced into the treatment works and any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

Revised July 2007

## STATEMENT OF BASIS/TECHNICAL SUMMARY AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

## **DESCRIPTION OF APPLICATION**

Applicant: City of Carrizo Springs

Texas Pollutant Discharge Elimination System (TPDES) Permit

No. WQ0010145001, EPA ID No. TX0025976

Regulated Activity: Domestic Wastewater Permit

Type of Application: Renewal

Request: Renewal with no changes

Authority: Federal Clean Water Act (CWA) § 402; Texas Water Code (TWC)

§ 26.027; 30 Texas Administrative Code (TAC) Chapters 30, 305, 307, 309, 312, and 319; Commission policies; and United States Environmental Protection Agency (EPA) guidelines.

#### EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **five years from the date of issuance**.

#### REASON FOR PROJECT PROPOSED

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.95 million gallons per day (MGD). The existing wastewater treatment plant serves the City of Carrizo Spring.

## PROJECT DESCRIPTION AND LOCATION

The City of Carizzo Springs Wastewater Treatment Facility is an activated sludge process plant operated in the extended aeration mode. Treatment units include a cylindrical screens, an onsite lift station, an aeration basin, a final clarifier, ultraviolet light (UV) system, and sludge drying beds. The facility is in operation.

Sludge generated from the treatment facility is hauled by a registered transporter and disposed of at a TCEQ-authorized land application site, City of Carrizo Springs Landfill, MSW Permit No. 2225, in Dimmit County. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

The plant site is located approximately 0.5 miles northeast of the intersection of U.S. Highway 83 and State Highway 85, in the City of Carrizo Springs, Dimmit County, Texas 78834.

#### **Outfall Location:**

Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

Outfall Number	Latitude	Longitude	Longitude		
001	28.525279N	99.848054W			

The treated effluent is discharged to Carrizo Creek, thence to Soldier Slough, thence to Nueces River above Holland Dam in Segment No. 2105 of the Nueces River Basin. The unclassified receiving water use is limited aquatic life use for Carrizo Creek. The designated uses for Segment No. 2105 are primary contact recreation, public water supply, and high aquatic life use. The effluent limitations in the draft permit will maintain and protect the existing instream uses. All determinations are preliminary and subject to additional review and/or revisions.

Effluent limitations for the conventional effluent parameters (i.e., Five-Day Biochemical Oxygen Demand or Five-Day Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water-quality limited streams as established in the Texas Surface Water Quality Standards (TSWQS) and the State of Texas Water Quality Management Plan (WQMP).

In a case such as this, end-of-pipe compliance with pH limits between 6.0 and 9.0 standard units reasonably assures instream compliance with the TSWQS for pH when the discharge authorized is from a minor facility. This technology-based approach reasonably assures instream compliance with TSWQS criteria due to the relatively smaller discharge volumes authorized by these permits. This conservative assumption is based on TCEQ sampling conducted throughout the state which indicates that instream buffering quickly restores pH levels to ambient conditions. Similarly, this approach has been historically applied within EPA issued NPDES general permits where technology-based pH limits were established to be protective of water quality criteria.

The effluent limitations in the draft permit have been reviewed for consistency with the WQMP. The proposed effluent limitations are contained in the approved WQMP.

The discharge from this permit action is not expected to have an effect on any federal endangered or threatened aquatic or aquatic-dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS's) biological opinion on the State of Texas authorization of the TPDES (September 14, 1998; October 21, 1998, update). To make this determination for TPDES permits, TCEQ and EPA only considered aquatic or aquatic-dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Segment No. 2105 is currently listed on the State's inventory of impaired and threatened waters (the 2022 Clean Water Act Section 303(d) list). The listing is for depressed dissolved oxygen from the confluence with Sauz Macho Creek to the confluence of Line Oak Slough (AU 2105\_02). This application is for renewal of an existing authorization and will not represent an increase in the permitted levels of oxygen demanding constituents to the segment

## SUMMARY OF EFFLUENT DATA

The following is a summary of the applicant's effluent monitoring data for the period August 2022 through August 2024. The average of Daily Average value is computed by the averaging of all 30-day average values for the reporting period for each parameter: flow, five-day carbonaceous biochemical oxygen demand (CBOD $_5$ ), five-day biochemical oxygen demand (BOD $_5$ ), total suspended solids (TSS), and ammonia nitrogen (NH $_3$ -N). The average of Daily Average value for *Escherichia coli* (*E. coli*) in colony-forming units (CFU) or most probable number (MPN) per 100 ml is calculated via geometric mean.

<u>Parameter</u>	<u>Average of Daily Average</u>
Flow, MGD	0.95
CBOD <sub>5</sub> , mg/l	2.8
TSS, mg/l	3.0
NH <sub>3</sub> -N, mg/l	0.26
E. coli CFU or MPN per 100 ml	36

#### DRAFT PERMIT CONDITIONS

The draft permit authorizes a discharge of treated domestic wastewater at a volume not to exceed a daily average flow of 0.95 MGD.

The effluent limitations in the of the draft permit, based on a 30-day average, are 10 mg/l  $CBOD_5$ , 15 mg/l TSS, 3 mg/l  $NH_3$ -N, 126 CFU or most probable number (MPN) of *E. coli* per 100 ml, and 4.0 mg/l minimum dissolved oxygen (DO). The permittee shall utilize an UV system for disinfection purposes and shall not exceed a daily average 126 CFU or MPN per 100 ml for *E. coli*.

The City of Carrizo Springs WWTP does not appear to receive significant industrial wastewater contributions. Based on the information provided by the permittee in the most recent TPDES permit application, the TCEQ determined that there are no significant industrial wastewater contributions currently being discharged to the permittee's POTW. Permit requirements for pretreatment are based on TPDES regulations contained in 30 TAC Chapter 305, which references 40 Code of Federal Regulations (CFR) Part 403, "General Pretreatment Regulations for Existing and New Sources of Pollution" [rev. Federal Register/ Vol. 70/ No. 198/ Friday, October 14, 2005/ Rules and Regulations, pages 60134-60798]. The draft permit includes specific requirements that establish responsibilities of local government, industry, and the public to implement the standards to control pollutants which pass through or interfere with treatment processes in publicly owned treatment works or which may contaminate the sewage sludge. This permit has appropriate pretreatment language for a facility of this size and complexity.

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal, and Transportation. Sludge generated from the treatment facility is hauled by a registered transporter and disposed of at a TCEQ-authorized land application site, City of Carrizo Springs Landfill, MSW Permit No. 2225, in Dimmit County. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

#### SUMMARY OF CHANGES FROM APPLICATION

None.

### SUMMARY OF CHANGES FROM EXISTING PERMIT

Effluent limitations and monitoring requirements in the draft permit remain the same as the existing permit requirements.

The Standard Permit Conditions, Sludge Provisions, and Other Requirements sections of the draft permit have been updated.

For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

The draft permit includes all updates based on the 30 TAC 312 rule change effective April 23, 2020.

#### BASIS FOR DRAFT PERMIT

The following items were considered in developing the draft permit:

- 1. Application received on September 05, 2024, and additional information received on September 14, 2024, February 18, 2025, February 21, 2025, and February 24, 2025.
- 2. TPDES Permit No. WO0010145001 issued on May 14 2020.
- 3. The effluent limitations and conditions in the draft permit comply with EPA-approved portions of the 2018 Texas Surface Water Quality Standards (TSWQS), 30 TAC §§ 307.1-307.10, effective March 1, 2018; 2014 TSWQS, effective March 6, 2014; 2010 TSWQS, effective July 22, 2010; and 2000 TSWQS, effective July 26, 2000.
- 4. The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Effluent Limitations.
- 5. Interoffice Memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division. Interoffice Memorandum from the Pretreatment Team of the TCEQ Water Quality Division.
- 6. Consistency with the Coastal Management Plan: The facility is not located in the Coastal Management Program boundary.

- 7. Procedures to Implement the Texas Surface Water Quality Standards (IP), Texas Commission on Environmental Quality, June 2010, as approved by EPA, and the IP, January 2003, for portions of the 2010 IP not approved by EPA.
- 8. Texas 2022 Clean Water Act Section 303(d) List, Texas Commission on Environmental Quality, June 1, 2022; approved by the U.S. Environmental Protection Agency on July 7, 2022.
- 9. Texas Natural Resource Conservation Commission, Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.

#### PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application, and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment, and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Sahil Hudda at (512) 239-4748.

Sahil Hudda	
Sahil Hudda	Date
Municipal Permits Team	
Wastewater Permitting Section (MC 148)	



## Permitting Services, LLC

6425 Bankside Drive, Suite 2111

Houston, TX 77096

robin@permittingservices.net

Tel. 713-458-8612

August 2, 2024

Texas Commission on Environmental Quality Water Quality Division Application Review and Processing Team (MC148) P.O. Box 13087 Austin, TX 78711-3087

Re:

Application to Renew Permit No. WQ0010145001 – CITY OF CARRIZO SPRINGS (EPA I.D. No. TX0025976)

Dear TCEQ Review Team,

Permitting Services, LLC is pleased to submit a Domestic Wastewater Permit Renewal Application (WQ0010145001) on behalf of the CITY OF CARRIZO SPRINGS WASTEWATER TREATMENT FACILITY (CN600241418) (RN101721124).

In this package you will find the original application and three copies. The Supplemental Permit Information Form, all other relevant forms and attachments are included as well.

I appreciate your time and effort in reviewing my request. If you have any questions, please contact me at (713) 458-8612, or via email at <a href="mailto:robin@permittingservices.net">robin@permittingservices.net</a>.

Yours truly,

Robin Butcho

Robin Butcko
Senior Wastewater Consultant
(713) 458-8612
robin@permittingservices.net





## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

## Complete and submit this checklist with the application.

APPLICANT NAME: City of Carrizo Springs

PERMIT NUMBER (If new, leave blank): WQ00 10145001

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	$\boxtimes$		Original USGS Map	$\boxtimes$	
Administrative Report 1.1		$\boxtimes$	Affected Landowners Map		$\boxtimes$
SPIF	$\boxtimes$		Landowner Disk or Labels		$\boxtimes$
Core Data Form	$\boxtimes$		Buffer Zone Map		$\boxtimes$
Public Involvement Plan Form		$\boxtimes$	Flow Diagram	$\boxtimes$	
Technical Report 1.0			Site Drawing	$\boxtimes$	
Technical Report 1.1		$\boxtimes$	Original Photographs		$\boxtimes$
Worksheet 2.0	$\boxtimes$		Design Calculations		$\boxtimes$
Worksheet 2.1		$\boxtimes$	Solids Management Plan		$\boxtimes$
Worksheet 3.0		$\boxtimes$	Water Balance		$\boxtimes$
Worksheet 3.1		$\boxtimes$			
Worksheet 3.2		$\boxtimes$			
Worksheet 3.3		$\boxtimes$			
Worksheet 4.0		$\boxtimes$			
Worksheet 5.0	$\boxtimes$			UN Dros	The same of the sa
Worksheet 6.0			RECE	I William	2
Worksheet 7.0			SEP 05	202	4
			SEP 05 Water Quality App	italion	s Team

For TCEQ Use Only	
Segment Number	County
Expiration Date	Region
Permit Number	



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

## Section 1. Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

indicate the univality of the application for (check only offe).								
Flow	New/Major Amendment	Renewal						
<0.05 MGD	\$350.00 □	\$315.00 □						
≥0.05 but <0.10 M	GD \$550.00 □	\$515.00 □						
≥0.10 but <0.25 M	GD \$850.00 □	\$815.00 □						
≥0.25 but <0.50 M	GD \$1,250.00 □	\$1,215.00 □						
≥0.50 but <1.0 MG	SD \$1,650.00 □	\$1,615.00 ⊠						
≥1.0 MGD	\$2,050.00 □	\$2,015.00 □						
Minor Amendment	Minor Amendment (for any flow) \$150.00 □							
Payment Informati	ion:							
Mailed	Check/Money Order Number: <u>003754</u>							
	Check/Money Order Amount: \$1,615							
	Name Printed on Check: City of Carrizo S	<u>prings</u>						
EPAY	Voucher Number: Click to enter text.							
Copy of Payment Voucher enclosed? Yes □								
Section 2. Type of Application (Instructions Page 26)								
a. Check the box next to the appropriate authorization type.								

a.	Check the box next to the appropriate authorization type.									
	$\boxtimes$	Publicly-Owned Domestic Wastewater								
		Privately-Owned Domestic Wastewater								
		Conventional Wastewater Treatment								
b.	Che	Check the box next to the appropriate facility status.								
		Active		Inactive						

. Check the box next to the appropriate permit type.							
M	TPDES Permit						
	TLAP						
	TPDES Permit with TLAP component						
	Subsurface Area Drip Dispersal System (SAD	DS)					
Che	eck the box next to the appropriate application	ı typ	e				
	New						
	Major Amendment with Renewal		Minor Amendment with Renewal				
	Major Amendment without Renewal		Minor Amendment without Renewal				
$\boxtimes$	Renewal without changes		Minor Modification of permit				
For	amendments or modifications, describe the p	ropo	sed changes: Click to enter text.				
For	existing permits:						
Peri	mit Number: WQ00 <u>WQ0010145001</u>						
EPA	I.D. (TPDES only): TX <u>0025976</u>						
Exp	iration Date: <u>May 14, 2025</u>						
	2	- 1	Co A williams Information				
	Che	TPDES Permit  □ TLAP  □ TPDES Permit with TLAP component  □ Subsurface Area Drip Dispersal System (SAD)  Check the box next to the appropriate application  □ New  □ Major Amendment with Renewal  □ Major Amendment without Renewal  □ Renewal without changes  For amendments or modifications, describe the p  For existing permits:  Permit Number: WQ00 WQoo1o145001  EPA I.D. (TPDES only): TX 0025976  Expiration Date: May 14, 2025	TPDES Permit  TLAP  TPDES Permit with TLAP component  Subsurface Area Drip Dispersal System (SADDS)  Check the box next to the appropriate application typ  New  Major Amendment with Renewal  Major Amendment without Renewal  Renewal without changes  For amendments or modifications, describe the proportion of the prop				

## Section 3. Facility Owner (Applicant) and Co-Applicant Information (Instructions Page 26)

## A. The owner of the facility must apply for the permit.

What is the Legal Name of the entity (applicant) applying for this permit?

City of Carrizo Springs

(The legal name must be spelled exactly as filed with the Texas Secretary of State, County, or in the legal documents forming the entity.)

If the applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at <a href="http://www15.tceq.texas.gov/crpub/">http://www15.tceq.texas.gov/crpub/</a>

CN: 600241418

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: Mr. Last Name, First Name: Oscar Puente

Title: Mayor Credential: Click to enter text.

**B.** Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

N/A

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the legal documents forming the entity.)

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: <a href="http://www15.tceq.texas.gov/crpub/">http://www15.tceq.texas.gov/crpub/</a>

CN: N/A

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: N/A Last Name, First Name: N/A

Title: N/A Credential: N/A

Provide a brief description of the need for a co-permittee: N/A

## C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. 1

## Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Mrs. Last Name, First Name: Butcko, Robin

Title: Senior Wastewater Consultant Credential: BBA

Organization Name: Permitting Services, LLC

Mailing Address: 6425 Bankside Drive, Suite 2111 City, State, Zip Code: Houston, TX 77096

Phone No.: 713-458-8612 E-mail Address: robin@permittingservices.net

Check one or both: 🛛 Administrative Contact 🔻 Technical Contact

B. Prefix: Mr.q Last Name, First Name: <u>Castillo, Ramsey</u>

Title: Water Department Supervisor Credential: Click to enter text.

Organization Name: City of Carrizo Springs

Mailing Address: PO Box 329 City, State, Zip Code: Carrizo Springs, TX 78834-

6329

Phone No.: 830-876-2476 E-mail Address: rcastillo@cityofcarrizo.org

Check one or both: Administrative Contact Technical Contact

## Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Mrs. Last Name, First Name: Butcko, Robin

Title: Senior Wastewater Consultant Credential: BBA

Organization Name: Permitting Services, LLC

Mailing Address: 6425 Bankside Drive, Suite 2111 City, State, Zip Code: Houston, TX 77096

Page 4 of 17

Phone No.: 713-458-8612 E-mail Address: robin@permittingservices.net

**B.** Prefix: Mr. Last Name, First Name: Castillo, Ramsey

Title: Water Department Supervisor Credential: Click to enter text.

Organization Name: City of Carrizo Springs

Mailing Address: PO Box 329 City, State, Zip Code: Carrizo Springs, TX 78834-

6329

Phone No.: 830-876-2476 E-mail Address: rcastillo@cityofcarrizo.org

## Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Mr. Last Name, First Name: Castillo, Ramsey

Title: Water Department Supervisor Credential: Click to enter text.

Organization Name: City of Carrizo Springs

Mailing Address: PO Box 329 City, State, Zip Code: Carrizo Springs, TX 78834

Phone No.: 830-876-2476 E-mail Address: rcastillo@cityofcarrizo.org

## Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Mr. Last Name, First Name: Camarillo, John

Title: Wastewater Treatment Plant Operator Credential: Click to enter text.

Organization Name: Wastewater Treatment Plant Operator

Mailing Address: PO Box 329 City, State, Zip Code: Carrizo Springs, TX 78834

Phone No.: 830-854-0484 E-mail Address: rcamarillo@cityofcarrizo.org

## Section 8. Public Notice Information (Instructions Page 27)

## A. Individual Publishing the Notices

Prefix: Mrs. Last Name, First Name: <u>Butcko</u>, <u>Robin</u>

Title: Senior Wastewater Consultant Credential: BBA

Organization Name: Permitting Services, LLC

Mailing Address: 6425 Bankside Drive, Suite 2111 City, State, Zip Code: Houston, TX 77096

Phone No.: 713-458-8612 E-mail Address: robin@permittingservices.net

В.	Method for Receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package							
	Ind	licate by a check mark the preferred method for receiving the first notice and instructions:						
	$\boxtimes$	E-mail Address						
		Fax						
		Regular Mail						
C.	Co	ntact permit to be listed in the Notices						
	Pre	fix: Mrs. Last Name, First Name: Butcko, Robin						
	Tit	le: <u>Senior Wastewater Consultant</u> Credential: <u>BBA</u>						
	Org	ganization Name: <u>Permitting Services, LLC</u>						
	Ma	iling Address: 6425 Bankside Drive, Suite 2111 City, State, Zip Code: Houston, TX 77096						
	Pho	one No.: 713-458-8612 E-mail Address: robin@permittingservices.net						
D.	Pul	olic Viewing Information						
		he facility or outfall is located in more than one county, a public viewing place for each inty must be provided.						
	Pul	olic building name: Carrizo Springs City Hall						
	Loc	ration within the building: <u>Reception Area</u>						
	Phy	sical Address of Building: <u>308 W. Pena Street</u>						
	City	y: <u>Carrizo Springs</u> County: <u>Dimmit</u>						
	Contact (Last Name, First Name): <u>Martinez, Gloria</u>							
	Pho	one No.: <u>830-876-2476</u> Ext.: Click to enter text.						
E.	Bili	ngual Notice Requirements						
		s information <b>is required</b> for <b>new, major amendment, minor amendment or minor dification, and renewal</b> applications.						
	This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.							
	Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.							
	1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?							
		⊠ Yes □ No						
		If <b>no</b> , publication of an alternative language notice is not required; <b>skip to</b> Section 9 below.						
		Are the students who attend either the elementary school or the middle school enrolled in a hilingual education program at that school?						

No

Yes

	3.	Do the locatio	students at n?	these	schools	attend	a bilingua	l educa	tion prog	gram a	t another
			Yes	$\boxtimes$	No						
	4.		the school b out of this i							gram l	out the school has
			Yes	$\boxtimes$	No						
	5.		nswer is <b>yes</b> ed. Which lar								tive language are
F.	Pla	in Lang	guage Summ	ary 7	Геmplate						
	Co	mplete	the Plain Lar	nguag	ge Summa	ry (TC	EQ Form 2	0972) a	and inclu	de as a	ın attachment.
	At	tachme	nt: Z								
G.	Pu	blic Inv	olvement Pl	lan F	orm						
٠.						n Form	(TCEO Fo	rm 209	060) for e	ach ap	plication for a
			it or major a								
	At	tachme	nt: <u>N/A</u>								
5-1									- 0		
Se	cti	on 9.	Regulat Page 29		Entity a	nd Pe	ermitted	Site	lnform	ation	(Instructions
A.			is currently 1 LN <u>101721124</u>		ated by T	CEQ, p	rovide the	Regula	ited Entit	y Num	ber (RN) issued to
			TCEQ's Cen currently reg				<u>//www15.t</u>	ceq.tex	as.gov/ci	rpub/	to determine if
B.	Na	me of p	roject or site	e (the	name kn	own by	the comm	nunity	where lo	cated):	
	<u>Cit</u>	y of Carr	rizo Springs W	Vastev	vater Trea	tment P	<u>lant</u>				
C.	Ov	vner of	treatment fa	cility	Click to	enter t	ext.				
	Ov	vnership	of Facility:	$\boxtimes$	Public		Private		Both		Federal
D.	Ow	vner of l	land where t	reatn	nent facili	ity is or	will be:				
	Pre	efix: Clic	ck to enter te	ext.	Las	st Name	e, First Nar	ne: Clic	ck to ente	er text.	
	Tit	le: Click	to enter tex	ct.	Cre	edentia	: Click to	enter te	ext.		
	Or	ganizati	ion Name: <u>Ci</u>	ty of (	Carrizo Sp	rings					
	Ma	iling Ac	ldress: <u>PO B</u> a	ox 320	9		City, State	, Zip C	ode: <u>Carr</u> i	zo Spr	ings, TX 78834
	Ph	one No.	830-876-247	<u> 76</u>	E-1	mail Ac	ldress: Cli	ck to er	nter text.		
			owner is not or deed rec						or co-ap	plican	t, attach a lease
		Attach	ment: <u>N/A</u>								

	Prefix: <u>N/A</u>	Last Name, First Name: <u>N/A</u>				
	Title: <u>N/A</u>	Credential: <u>N/A</u>				
	Organization Name: <u>N/A</u>					
	Mailing Address: N/A	City, State, Zip Code: N/A				
	Phone No.: <u>N/A</u>	E-mail Address: <u>N/A</u>				
If the landowner is not the same person as the facility owner or co-applicant, attach a lagreement or deed recorded easement. See instructions.						
	Attachment: <u>N/A</u>					
F.	F. Owner sewage sludge disposal site (if authorization is requested for sludge disposal on property owned or controlled by the applicant)::					
	Prefix: <u>N/A</u>	Last Name, First Name: <u>N/A</u>				
	Title: <u>N/A</u>	Credential: N/A				
	Organization Name: N/A					
	Mailing Address: <u>N/A</u>	City, State, Zip Code: <u>N/A</u>				
	Phone No.: <u>N/A</u>	E-mail Address: <u>N/A</u>				
If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.						
	Attachment: N/A					
Se	ection 10. TPDES Dischar	ge Information (Instructions Page 31)				
		ge Information (Instructions Page 31) ity location in the existing permit accurate?				
	Is the wastewater treatment facil  ✓ Yes □ No  If no, or a new permit application					
	Is the wastewater treatment facil	ity location in the existing permit accurate?				
A.	Is the wastewater treatment facil  ✓ Yes □ No  If no, or a new permit application of the content of the conten	ity location in the existing permit accurate?  on, please give an accurate description:				
A.	Is the wastewater treatment facil  ✓ Yes □ No  If no, or a new permit application of the content of the conten	ity location in the existing permit accurate?				
A.	Is the wastewater treatment facil  ✓ Yes □ No  If no, or a new permit application of the content of the conten	ity location in the existing permit accurate?  on, please give an accurate description:				
A.	Is the wastewater treatment facil  ✓ Yes ☐ No  If no, or a new permit application of the point of discharge and the dis	ity location in the existing permit accurate?  on, please give an accurate description:				
A.	Is the wastewater treatment facil  ✓ Yes □ No  If no, or a new permit application of the point of discharge and the dis	ity location in the existing permit accurate?  on, please give an accurate description:  the discharge route(s) in the existing permit correct?  ermit application, provide an accurate description of the				
A.	Is the wastewater treatment facil  ✓ Yes ☐ No  If no, or a new permit application of the point of discharge and the dis	on, please give an accurate description:  the discharge route(s) in the existing permit correct?  ermit application, provide an accurate description of the arge route to the nearest classified segment as defined in 30				
A.	Is the wastewater treatment facil  ✓ Yes □ No  If no, or a new permit application of the count	on, please give an accurate description:  the discharge route(s) in the existing permit correct?  ermit application, provide an accurate description of the arge route to the nearest classified segment as defined in 30 of Springs				
A.	Is the wastewater treatment facil  ✓ Yes ☐ No  If no, or a new permit application of the point(s) of discharge and wastewater to the point of discharge and the discharge and	on, please give an accurate description:  the discharge route(s) in the existing permit correct?  ermit application, provide an accurate description of the arge route to the nearest classified segment as defined in 30 of Springs  s/are located: Dimmit discharge to a city, county, or state highway right-of-way, or				

E. Owner of effluent disposal site:

	If <b>yes</b> , indicate by a check mark if:						
	Authorization granted Authorization pending						
	For <b>new and amendment</b> applications, provide copies of letters that show proof of contact and the approval letter upon receipt.						
	Attachment: N/A						
D.	. For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: $N/A$						
Se	ection 11. TLAP Disposal Information (Instructions Page 32)						
Α.	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?						
	□ Yes □ No						
	If <b>no, or a new or amendment permit application</b> , provide an accurate description of the disposal site location:						
	Click to enter text.						
B.	. City nearest the disposal site: Click to enter text.						
C.	. County in which the disposal site is located: Click to enter text.						
D.	. For <b>TLAPs</b> , describe the routing of effluent from the treatment facility to the disposal site:						
	Click to enter text.						
Е.	For <b>TLAPs</b> , please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: Click to enter text.						
Co	ection 12 Miscellaneous Information (Instructions Page 22)						
	ection 12. Miscellaneous Information (Instructions Page 32)						
A.	Is the facility located on or does the treated effluent cross American Indian Land?						
	□ Yes ⊠ No						
В.	If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?						
	□ Yes □ No ⊠ Not Applicable						
	If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.						
	Click to enter text.						

C.	Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?					
		Yes	$\boxtimes$	No		
				on formerly employed by the TCEQ who represented your company and regarding the application: Click to enter text.		
D.	Do you owe any fees to the TCEQ?					
		Yes	$\boxtimes$	No		
	If yes, provide the following information:					
	Acc	ount nui	nber:	Click to enter text.		
	Am	ount pas	t due	: Click to enter text.		
E.	Do you	ı owe any	pena	alties to the TCEQ?		
		Yes	$\boxtimes$	No		
	If yes, please provide the following information:					
	Enforcement order number: Click to enter text.					
	Am	ount pas	t due	: Click to enter text.		
			_			
Se	ction	13. At	tack	nments (Instructions Page 33)		
Indicate which attachments are included with the Administrative Report. Check all that apply:						
	Lease	agreeme	nt or	deed recorded easement, if the land where the treatment facility is		

- Lease agreement or deed recorded easement, if the land where the treatment fac located or the effluent disposal site are not owned by the applicant or co-applicant.
- Original full-size USGS Topographic Map with the following information:
  - Applicant's property boundary
  - Treatment facility boundary
  - Labeled point of discharge for each discharge point (TPDES only)
  - Highlighted discharge route for each discharge point (TPDES only)
  - Onsite sewage sludge disposal site (if applicable)
  - Effluent disposal site boundaries (TLAP only)
  - New and future construction (if applicable)
  - 1 mile radius information
  - 3 miles downstream information (TPDES only)
  - · All ponds.
- Attachment 1 for Individuals as co-applicants
- Other Attachments. Please specify: Core Data Form, Site Drawing, Flow Diagram, Copy of Check, Pollutant Analysis, PLS Language Summaries

## Section 14. Signature Page (Instructions Page 39)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: <u>WO0010145001</u> Applicant: <u>City of Carrizo Springs</u>

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): Oscar Puente	
Signatory title: <u>Mayor</u>	
Signature: Oscul Puerte	Date: 8 - 7-2024
(Use blue ink)	
Subscribed and Sworn to before me by the said_on this	Oscar Puente.  19024.  19 april , 2027.

Notary Public

County, Texas

MELISSA M. GUERRA
My Notary ID # 130159674
Expires April 5, 2027

# DOMESTIC WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: 8

## THIS PAGE INTENTIONALLY LEFT BLANK

# CAMMUSSION OF THE PROPERTY OF

## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

## DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

## Section 1. Permitted or Proposed Flows (Instructions Page 43)

## A. Existing/Interim I Phase

Design Flow (MGD): <u>0.95</u>

2-Hr Peak Flow (MGD): 2.97

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

#### **B.** Interim II Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

## C. Final Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

#### D. Current Operating Phase

Provide the startup date of the facility: August 8, 2017

## Section 2. Treatment Process (Instructions Page 43)

#### A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. **If more than one phase exists or is proposed, a description of** *each phase* **must be provided**.

Activated Sludge – Extended Aeration: Effluent enters through a mechanical screen to lift station & lifted to aeration basin. MLSS flows by gravity to the clarifier. Sludge pumps return sludge from clarifier to aeration basin or is wasted to sludge beds. Clear effluent from clarifier flows by gravity to UV for disinfection, to Parshall flume then to a point of discharge.

#### **B.** Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Cylindrical Screen Channel	1	32'-6" x 5'-2" x 3'-8"
Lift Station	1	23'-8" x 12'-9" x 20'-2.4"
Aeration Basin	1	125'-4" x 105'-4" x 15'-0"
Final Clarifiers	1	65'-0" Dia. x 15'-8" SWD
UV Chamber	1	42'-0" x 2'-4" x 5'-2"
Sludge Drying Beds	1	60'-0" x 32'-0" x 3'-0"
Parshall Flume	1	19'-10" x 6'-8" x 7'-2.4"

#### C. Process Flow Diagram

Provide flow diagrams for the existing facilities and each proposed phase of construction.

Attachment: 3

#### Section 3. Site Information and Drawing (Instructions Page 44)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

• Latitude: <u>28°31'30" N</u>

• Longitude: <u>-99°51'00" W</u>

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

Latitude: N/A

Longitude: N/A

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment: 4			
Provide the name <b>and</b> a des	cription of the area	served by the treatment	t facility.
Collection System Informati		TDDES normite only: Pr	rovide information for
Collection System Informatic each uniquely owned collection systems. examples.  Collection System Information	ction system, existin Please see the inst	ng and new, served by th	nis facility, including
Collection System Name	Owner Name	Owner Type	Population Served
Carrizo Springs WWTP	City of Carrizo Springs	Publicly Owned	4,892
		Choose an item.	
		Choose an item.	
A. 20 11.00 10 V		Choose an item.	
Section 4. Unbuilt P Is the application for a rene  ☐ Yes ☑ No	hases (Instruct) wal of a permit that		ase or phases?
If yes, does the existing per years of being authorized b  ☐ Yes ☐ No		that has not been cons	tructed <b>within five</b>
If yes, provide a detailed dis Failure to provide sufficient recommending denial of th	t justification may	result in the Executive	
Click to enter text.			

#### Section 5. Closure Plans (Instructions Page 45)

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

	□ Yes ⋈ No
If ·	yes, was a closure plan submitted to the TCEQ?
	□ Yes □ No
If ·	yes, provide a brief description of the closure and the date of plan approval.
ag	erial
Se	ection 6. Permit Specific Requirements (Instructions Page 45)
Fo	r applicants with an existing permit, check the Other Requirements or Special ovisions of the permit.
A.	Summary transmittal
	Have plans and specifications been approved for the existing facilities and each proposed phase?
	⊠ Yes □ No
	If yes, provide the date(s) of approval for each phase: August 6, 2014
	Provide information, including dates, on any actions taken to meet a <i>requirement or provision</i> pertaining to the submission of a summary transmittal letter. <b>Provide a copy of</b> an approval letter from the TCEQ, if applicable.
	N/A
В.	Buffer zones
	Have the buffer zone requirements been met?
	⊠ Yes □ No
	Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.
	N/A

C.	Ot	her actions required by the current permit
	su	bes the <i>Other Requirements</i> or <i>Special Provisions</i> section in the existing permit require bmission of any other information or other required actions? Examples include otification of Completion, progress reports, soil monitoring data, etc.
		□ Yes ⋈ No
		yes, provide information below on the status of any actions taken to meet the nditions of an Other Requirement or Special Provision.
	C	lick to enter text.
D.	Gr	it and grease treatment
	1.	Acceptance of grit and grease waste
		Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?
		□ Yes ⊠ No
		If No, stop here and continue with Subsection E. Stormwater Management.
	2.	Grit and grease processing
		Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.
		Click to enter text.
	3.	Grit disposal
		Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?
		□ Yes □ No
		If No, contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

		Describe the method of grit disposal.
		Click to enter text.
	4.	Grease and decanted liquid disposal
		Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.
		Describe how the decant and grease are treated and disposed of after grit separation.
		Click to enter text.
		<u> </u>
E.		ormwater management
	1.	Applicability  Description of the Control of the Co
		Does the facility have a design flow of 1.0 MGD or greater in any phase?
		Yes No
		Does the facility have an approved pretreatment program, under 40 CFR Part 403?
		Yes No
	2	If no to both of the above, then skip to Subsection F, Other Wastes Received.  MSGP coverage
	۷.	Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?
		□ Yes □ No
		<b>If yes,</b> please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:
		TXR05 Click to enter text. or TXRNE Click to enter text.
		If no, do you intend to seek coverage under TXR050000?
		□ Yes □ No
	3.	Conditional exclusion
		Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?
		□ Yes □ No

	If yes, please explain below then proceed to Subsection F, Other Wastes Received:
	Click to enter text,
4.	Existing coverage in individual permit
	Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?
	□ Yes □ No
	<b>If yes,</b> provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.
	Click to enter text.
5.	Zero stormwater discharge
	Do you intend to have no discharge of stormwater via use of evaporation or other means?
	□ Yes □ No
	If yes, explain below then skip to Subsection F. Other Wastes Received.
	Click to enter text.
	Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.
6.	Request for coverage in individual permit
	Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?
	□ Yes □ No
	If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or

discharge it via a separate dedicated stormwater outfall. Please also indicate if you

		it to water in the state.
		Click to enter text.
		Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.
F.	Di	scharges to the Lake Houston Watershed
	Do	oes the facility discharge in the Lake Houston watershed?
		☐ Yes ☒ No
		yes, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions.
G.	Ot	her wastes received including sludge from other WWTPs and septic waste
	1.	Acceptance of sludge from other WWTPs
		Does or will the facility accept sludge from other treatment plants at the facility site?
		□ Yes □ No
		If yes, attach sewage sludge solids management plan. See Example 5 of instructions.
		In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an
		estimate of the BOD <sub>5</sub> concentration of the sludge, and the design BOD <sub>5</sub> concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
		Click to enter text.
		Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	2.	Acceptance of septic waste
		Is the facility accepting or will it accept septic waste?
		□ Yes ⋈ No
		If yes, does the facility have a Type V processing unit?
		□ Yes □ No
		If yes, does the unit have a Municipal Solid Waste permit?
		□ Yes □ No

intend to divert stormwater to the treatment plant headworks and indirectly discharge

If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD<sub>5</sub> concentration of the septic waste, and the design BOD5 concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

ick to enter text.		

required to have influent flow and organic loading monitoring.

3. Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)

Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?

Yes 🖾 No

If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.

Click to enter text.	 	 	

#### Pollutant Analysis of Treated Effluent (Instructions Page Section 7. 50)

Is the facility in operation?

Yes 
No

**If no**, this section is not applicable. Proceed to Section 8.

If yes, provide effluent analysis data for the listed pollutants. Wastewater treatment facilities complete Table 1.0(2). Water treatment facilities discharging filter backwash water. complete Table 1.0(3). Provide copies of the laboratory results sheets. These tables are not applicable for a minor amendment without renewal. See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD <sub>5</sub> , mg/l	<3		1	Grab	8/15/24
Total Suspended Solids, mg/l	3	1.	1	Grab	8/15/24
Ammonia Nitrogen, mg/l	<0.1		1	Grab	8/15/24
Nitrate Nitrogen, mg/l	23.9		1	Grab	8/15/24
Total Kjeldahl Nitrogen, mg/l	2		1	Grab	8/15/24
Sulfate, mg/l	66		1	Grab	8/15/24
Chloride, mg/l	111		1	Grab	8/15/24
Total Phosphorus, mg/l	4.1		1	Grab	8/15/24
pH, standard units	7.9		1	Grab	8/15/24
Dissolved Oxygen*, mg/l	N/A		N/A	N/A	N/A
Chlorine Residual, mg/l	N/A		N/A	N/A	N/A
E.coli (CFU/100ml) freshwater	N/A		N/A	N/A	N/A
Entercocci (CFU/100ml) saltwater	N/A		N/A	N/A	N/A
Total Dissolved Solids, mg/l	336		1	Grab	8/15/24
Electrical Conductivity, µmohs/cm, †	1,034		1	Grab	8/15/24
Oil & Grease, mg/l	N/A		N/A	N/A	N/A
Alkalinity (CaCO <sub>3</sub> )*, mg/l	N/A		N/A	N/A	N/A

<sup>\*</sup>TPDES permits only †TLAP permits only

Table1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l	N/A	N/A	N/A	N/A	N/A
Total Dissolved Solids, mg/l	N/A	N/A	N/A	N/A	N/A
pH, standard units	N/A	N/A	N/A	N/A	N/A
Fluoride, mg/l	N/A	N/A	N/A	N/A	N/A
Aluminum, mg/l	N/A	N/A	N/A	N/A	N/A
Alkalinity (CaCO <sub>3</sub> ), mg/l	N/A	N/A	N/A	N/A	N/A

#### Section 8. Facility Operator (Instructions Page 50)

Facility Operator Name: John Camarillo

Facility Operator's License Classification and Level: C

Facility Operator's License Number: WW0029565

#### Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 51)

#### A. WWTP's Biosolids Management Facility Type Check all that apply. See instructions for guidance Design flow>= 1 MGD Serves >= 10,000 people Class I Sludge Management Facility (per 40 CFR § 503.9) Biosolids generator Biosolids end user - land application (onsite) Biosolids end user - surface disposal (onsite) Biosolids end user - incinerator (onsite) B. WWTP's Biosolids Treatment Process Check all that apply. See instructions for guidance. Aerobic Digestion Air Drying (or sludge drying beds) Lower Temperature Composting Lime Stabilization **Higher Temperature Composting Heat Drying** Thermophilic Aerobic Digestion **Beta Ray Irradiation** Gamma Ray Irradiation

#### Temporary Storage (< 2 years)

**Pasteurization** 

Sludge Lagoon

- Long Term Storage (>= 2 years)
- Methane or Biogas Recovery
- Other Treatment Process: Activated Sludge Extended Aeration

Preliminary Operation (e.g. grinding, de-gritting, blending)

#### C. Biosolids Management

Provide information on the intended biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the permit will authorize

Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)

all biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

#### **Biosolids Management**

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.

If "Other" is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): transport to City of Carrizo Springs Municipal Landfill

#### D. Disposal site

Disposal site name: City of Carrizo Springs Municipal Landfill

TCEQ permit or registration number: <u>MSW2225</u> County where disposal site is located: <u>Dimmit</u>

#### E. Transportation method

Method of transportation (truck, train, pipe, other): City Truck

Name of the hauler: City of Carrizo Springs

Hauler registration number: 22041

Sludge is transported as a:

Liquid 🛘	semi-liquid 🛘	semi-solid 🗆	solid 🗵
Liquia 🗀	semi-nquia 🗀	semi-sona 🗀	sona 2

## Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 53)

#### A. Beneficial use authorization

Does th	he exi	sting	perm	it include	authori	zation t	or lai	nd app	olication	n of	sewage	e slud	ge for
benefic	cial us	e?	1550 1550										
	Yes	$\boxtimes$	No										

If yes, are you requesting to continue this authorization to land apply sewage sludge for beneficial use?

□ Yes □ No

If yes, is the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451) attached to this permit application (see the instructions for details)?

and or com-		100000	
	Vac		NIA
	Yes		No
200000		Congress	

Does the existing storage or dispos	permit include authorization al options?	for any	y of the	follow	ring sludge processing,
Sludge Compo	osting		Yes	$\boxtimes$	No
Marketing and	d Distribution of sludge		Yes	$\boxtimes$	No
Sludge Surfac	e Disposal or Sludge Monofill		Yes	$\boxtimes$	No
Temporary st	orage in sludge lagoons		Yes	$\boxtimes$	No
authorization, is	he above sludge options and t the completed <b>Domestic Was</b> <b>t (TCEQ Form No. 10056)</b> atta No	tewater	r Permit	Appli	ication: Sewage Sludge
Section 11. Sev	vage Sludge Lagoons (I	nstru	ctions	Page	53)
	lude sewage sludge lagoons?				
□ Yes ⊠ No					
If yes, complete the	remainder of this section. If n	o, proce	eed to S	ection	12.
A. Location informa	ntion				
The following ma provide the Attac	ps are required to be submitte hment Number.	ed as p	art of th	ne app	lication. For each map,
<ul> <li>Original G</li> </ul>	eneral Highway (County) Map:				
Attachme	nt: Click to enter text.				
<ul> <li>USDA Nati</li> </ul>	ıral Resources Conservation S	ervice S	Soil Map	:	
Attachme	at: Click to enter text.				
<ul> <li>Federal En</li> </ul>	nergency Management Map:				
Attachme	nt: Click to enter text.				
• Site map:					
Attachme	nt: Click to enter text.				
Discuss in a desc apply.	ription if any of the following	exist w	ithin th	e lago	on area. Check all that
Overlap a	designated 100-year frequenc	cy flood	l plain		
☐ Soils with	flooding classification				
□ Overlap a	n unstable area				
□ Wetlands					
☐ Located le	ess than 60 meters from a fau	lt			
□ None of t	he above				
Attachment:	Click to enter text.				

B. Sludge processing authorization

	the protective measures to be utilized including type and size of protective structures:
	Click to enter text.
В.	Temporary storage information
	Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in <i>Section 7 of Technical Report 1.0.</i>
	Nitrate Nitrogen, mg/kg: Click to enter text.
	Total Kjeldahl Nitrogen, mg/kg: Click to enter text.
	Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: Click to enter text.
	Phosphorus, mg/kg: Click to enter text.
	Potassium, mg/kg: Click to enter text.
	pH, standard units: Click to enter text.
	Ammonia Nitrogen mg/kg: Click to enter text.
	Arsenic: Click to enter text.
	Cadmium: Click to enter text.
	Chromium: Click to enter text.
	Copper: Click to enter text.
	Lead: Click to enter text.
	Mercury: Click to enter text.
	Molybdenum: Click to enter text.
	Nickel: Click to enter text.
	Selenium: Click to enter text.
	Zinc: Click to enter text.
	Total PCBs: Click to enter text.
	Provide the following information:
	Volume and frequency of sludge to the lagoon(s): Click to enter text.
	Total dry tons stored in the lagoons(s) per 365-day period: Click to enter text.
	Total dry tons stored in the lagoons(s) over the life of the unit: Click to enter text.
C.	Liner information
	Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of 1x10 <sup>-7</sup> cm/sec?

□ Yes □ No

	If yes	s, describe the liner below. Please note that a liner is required.
	Click	to enter text.
D.	Site d	evelopment plan
	Provi	de a detailed description of the methods used to deposit sludge in the lagoon(s):
	Click	to enter text.
	Attac	h the following documents to the application.
	•	Plan view and cross-section of the sludge lagoon(s)
		Attachment: Click to enter text.
	•	Copy of the closure plan
		Attachment: Click to enter text.
	•	Copy of deed recordation for the site
		Attachment: Click to enter text.
	•	Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons
		Attachment: Click to enter text.
	•	Description of the method of controlling infiltration of groundwater and surface water from entering the site
		Attachment: Click to enter text.
	•	Procedures to prevent the occurrence of nuisance conditions
		Attachment: Click to enter text.
E.	Grou	ndwater monitoring
	groun	undwater monitoring currently conducted at this site, or are any wells available for dwater monitoring, or are groundwater monitoring data otherwise available for the e lagoon(s)?
		Yes □ No
	types	undwater monitoring data are available, provide a copy. Provide a profile of soil encountered down to the groundwater table and the depth to the shallowest dwater as a separate attachment.
	At	tachment: Click to enter text.

## Section 12. Authorizations/Compliance/Enforcement (Instructions Page 55)

A.	Additional authorizations	
	Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?	
	□ Yes ⋈ No	
	If yes, provide the TCEQ authorization number and description of the authorization:	
C	lick to enter text.	
В.	Permittee enforcement status	
	Is the permittee currently under enforcement for this facility?	
	□ Yes ⋈ No	
	Is the permittee required to meet an implementation schedule for compliance or enforcement?	
	□ Yes ⋈ No	
	<b>If yes</b> to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:	n
C	lick to enter text.	
Se	ction 13. RCRA/CERCLA Wastes (Instructions Page 55)	
Α.	RCRA hazardous wastes	
	Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?	

□ Yes ⊠

#### B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

□ Yes ⊠ No

#### C. Details about wastes received

**If yes** to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: N/A

#### Section 14. Laboratory Accreditation (Instructions Page 64)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification,* which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
  - o periodically inspected by the TCEQ; or
  - located in another state and is accredited or inspected by that state; or
  - performing work for another company with a unit located in the same site; or
  - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the *Signature Page* section in the Instructions, for a list of designated representatives who may sign the certification.

#### **CERTIFICATION:**

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Printed Name: Ramsey Castillo

Title: Water Department Supervisor

Signature:

Date:

- Solids generated at 100, 75, 50, and 25 percent of design flow
- Mixed liquor suspended solids operating range at design and projected actual flow
- Quantity of solids to be removed and a schedule for solids removal
- Identification and ownership of the ultimate sludge disposal site
- For facultative lagoons, design life calculations, monitoring well locations and depths, and the ultimate disposal method for the sludge from the facultative lagoon

An example of a sewage sludge solids management plan has been included as Example 5 of the instructions.

## DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

Section 1. Domestic Drinking Water Supply (Instructions Page 64)
Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?
□ Yes □ No
If <b>no</b> , proceed it Section 2. <b>If yes</b> , provide the following:
Owner of the drinking water supply: Click to enter text.
Distance and direction to the intake: Click to enter text.
Attach a USGS map that identifies the location of the intake.
Attachment: Click to enter text.
Section 2. Discharge into Tidally Affected Waters (Instructions Page 64)
Does the facility discharge into tidally affected waters?
□ Yes ⊠ No
If <b>no</b> , proceed to Section 3. <b>If yes</b> , complete the remainder of this section. If no, proceed to Section 3.
A. Receiving water outfall
Width of the receiving water at the outfall, in feet: Click to enter text.
B. Oyster waters
Are there oyster waters in the vicinity of the discharge?
□ Yes □ No
If yes, provide the distance and direction from outfall(s).
Click to enter text.
C. Sea grasses
Are there any sea grasses within the vicinity of the point of discharge?
□ Yes □ No
If yes, provide the distance and direction from the outfall(s).
Click to enter text.

Section	1 3. Classified Segments (instructions rage 04)
Is the dis	scharge directly into (or within 300 feet of) a classified segment?
	Yes ⋈ No
If yes, th	is Worksheet is complete.
If no, con	mplete Sections 4 and 5 of this Worksheet.
Costion	A Description of Immediate Receiving Waters (Instructions
Section	1 4. Description of Immediate Receiving Waters (Instructions Page 65)
Name of	the immediate receiving waters: Click to enter text.
A. Recei	ving water type
Ident	ify the appropriate description of the receiving waters.
	Stream
	Freshwater Swamp or Marsh
	Lake or Pond
	Surface area, in acres: Click to enter text.
	Average depth of the entire water body, in feet: Click to enter text.
	Average depth of water body within a 500-foot radius of discharge point, in feet: Click to enter text.
	Man-made Channel or Ditch
	Open Bay
	Tidal Stream, Bayou, or Marsh
	Other, specify: Click to enter text.
B. Flow	characteristics
	ream, man-made channel or ditch was checked above, provide the following. For
existi: of the	ng discharges, check one of the following that best characterizes the area <i>upstream</i> e discharge. For new discharges, characterize the area <i>downstream</i> of the discharge k one).
$\boxtimes$	Intermittent - dry for at least one week during most years
m	Intermittent with Perennial Pools - enduring pools with sufficient habitat to aintain significant aquatic life uses
	Perennial - normally flowing
	t the method used to characterize the area upstream (or downstream for new argers).
	USGS flow records
	Historical observation by adjacent landowners
	Personal observation
$\boxtimes$	Other, specify: Operator's Observation

C.	Downs	stream perennial confluences				
	List the names of all perennial streams that join the receiving water within three miles downstream of the discharge point.					
	None					
D.	Downs	stream characteristics				
		receiving water characteristics char rge (e.g., natural or man-made dams		ithin three miles downstream of the ds, reservoirs, etc.)?		
		Yes 🖾 No				
	If yes,	discuss how.				
	N/A					
F.	Norma	l dry weather characteristics				
	Provide general observations of the water body during normal dry weather conditions.					
	N/A					
	Date a	nd time of observation: 7/18/2024 @	1:30p	<u>m</u>		
	Was th	e water body influenced by stormwa	ater r	unoff during observations?		
		Yes ⊠ No				
Se	ction	5. General Characteristics Page 66)	s of	the Waterbody (Instructions		
A.	Upstre	am influences				
		mmediate receiving water upstream iced by any of the following? Check		ne discharge or proposed discharge site at apply.		
		Oil field activities	П	Urban runoff		
		Upstream discharges		Agricultural runoff		
		Septic tanks		Other(s), specify: None of the above		

#### B. Waterbody uses Observed or evidences of the following uses. Check all that apply. Livestock watering Contact recreation Irrigation withdrawal Non-contact recreation Fishing Navigation Domestic water supply Industrial water supply Other(s), specify: Click to enter text. Park activities C. Waterbody aesthetics Check one of the following that best describes the aesthetics of the receiving water and the surrounding area. Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored Common Setting: not offensive; developed but uncluttered; water may be colored

Offensive: stream does not enhance aesthetics; cluttered; highly developed;

or turbid

dumping areas; water discolored

## DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following is required for all publicly owned treatment works.

#### Section 1. All POTWs (Instructions Page 89)

#### A. Industrial users (IUs)

Provide the number of each of the following types of industrial users (IUs) that discharge to your POTW and the daily flows from each user. See the Instructions for definitions of Categorical IUs, Significant IUs – non-categorical, and Other IUs.

### If there are no users, enter 0 (zero).

Categorical IUs:

Number of IUs: o

Average Daily Flows, in MGD: o

Significant IUs - non-categorical:

Number of IUs: o

Average Daily Flows, in MGD: o

Other IUs:

Number of IUs: o

Average Daily Flows, in MGD: 0.005

#### **B.** Treatment plant interference

In the past three years, has your POTW experienced treatment plant interference (see instructions)?

□ Yes ⊠ No

If yes, identify the dates, duration, description of interference, and probable cause(s) and possible source(s) of each interference event. Include the names of the IUs that may have caused the interference.

1	Click to enter text.
L	

C.	reatment plant pass through
	In the past three years, has your POTW experienced pass through (see instructions)?
	□ Yes ⋈ No
	<b>If yes</b> , identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.
	Click to enter text.
D.	Pretreatment program
	Does your POTW have an approved pretreatment program?
	□ Yes ⋈ No
	If yes, complete Section 2 only of this Worksheet.
	Is your POTW required to develop an approved pretreatment program?
	□ Yes ⊠ No
	If yes, complete Section 2.c. and 2.d. only, and skip Section 3.
	<b>If no to either question above</b> , skip Section 2 and complete Section 3 for each significant industrial user and categorical industrial user.
Se	ction 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)
Α.	Substantial modifications
	Have there been any <b>substantial modifications</b> to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?
	☐ Yes ☐ No
	<b>If yes</b> , identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
	Click to enter text.
	\$
	*

B.	Non-substantial modifications									
	Have there been any <b>non-substantial modifications</b> to the approved pretreatment program that have not been submitted to TCEQ for review and acceptance?									
	□ Yes □	No								
		non-substantial mod oose of the modifica		we not been subn	nitted to TCEQ,					
	Click to enter text.	A			The state of the s					
C.	Effluent paramete	ers above the MAL								
		all parameters mea								
	monitoring during	the last three years	. Submit an attac	nment if necessar	у.					
	ble 6.0(1) – Parame		-		1					
Pe	ollutant	Concentration	MAL	Units	Date					
D.	Industrial user int	dustrial user interruptions								
		Has any SIU, CIU, or other IU caused or contributed to any problems (excluding								
	nterferences or pass throughs) at your POTW in the past three years?									
	interferences or pa	ass (inroughs) at you	i roiw iii the pa	st tinee years:						
	man Season	No	i roiw in the pa	st tinee years:						
	☐ Yes ☑  If yes, identify the		each episode, incl		ition, description					
	☐ Yes ☑  If yes, identify the	No industry, describe ond probable polluta	each episode, incl		ntion, description					
	☐ Yes ☑  If yes, identify the of the problems, a	No industry, describe ond probable polluta	each episode, incl		ntion, description					
	☐ Yes ☑  If yes, identify the of the problems, a	No industry, describe ond probable polluta	each episode, incl		ntion, description					
	☐ Yes ☑  If yes, identify the of the problems, a	No industry, describe ond probable polluta	each episode, incl		ntion, description					
	☐ Yes ☑  If yes, identify the of the problems, a	No industry, describe ond probable polluta	each episode, incl		ntion, description					

## Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 90)

A.	General information
	Company Name: Click to enter text.
	SIC Code: Click to enter text.
	Contact name: Click to enter text.
	Address: Click to enter text.
	City, State, and Zip Code: Click to enter text.
	Telephone number: Click to enter text.
	Email address: Click to enter text.
B.	Process information
	Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).
	Click to enter text,
C.	Product and service information
	Provide a description of the principal product(s) or services performed.
	Click to enter text.
D.	Flow rate information
	See the Instructions for definitions of "process" and "non-process wastewater."
	Process Wastewater:
	Discharge, in gallons/day: Click to enter text.
	Discharge Type: 🔲 Continuous 🔲 Batch 🔲 Intermittent
	Non-Process Wastewater:
	Discharge, in gallons/day: Click to enter text.
	Discharge Type: □ Continuous □ Batch □ Intermittent

E.	Pretreatment standards
	Is the SIU or CIU subject to technically based local limits as defined in the <i>i</i> nstructions?
	□ Yes □ No
	Is the SIU or CIU subject to categorical pretreatment standards found in $40$ CFR Parts $405$ - $471$ ?
	□ Yes □ No
	<b>If subject to categorical pretreatment standards</b> , indicate the applicable category and subcategory for each categorical process.
	Category: Subcategories: Click to enter text.
	Click or tap here to enter text. Click to enter text.
	Category: Click to enter text.
	Subcategories: Click to enter text.
	Category: Click to enter text.
	Subcategories: Click to enter text.
	Category: Click to enter text.
	Subcategories: Click to enter text.
	Category: Click to enter text.
	Subcategories: Click to enter text.
F.	Industrial user interruptions
	Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?
	□ Yes □ No
	<b>If yes</b> , identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.
	Click to enter text.

## Attachment 1 Core Data Form

**TCEQ Use Only** 



## **TCEQ Core Data Form**

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

### **SECTION I: General Information**

New Permit, Registration or Authorization (Core	Data Form should be submitted with	the program application.)	
Renewal (Core Data Form should be submitted w.	ith the renewal form)	Other	
2. Customer Reference Number (if issued)	3. Regulated Entity Reference Number (if issued)		
CN 600241418   for CN or RN numbers in   Central Registry**		RN 101721124	

4. General (	eneral Customer Information 5. Effective Date for Customer Information					n/dd/yyyy)		
☐ New Custo	Customer Update to Customer Information Change in Regulated Entity Ownership							
☐Change in	Legal Name (Verifiable with the	e Texas Secretary of State or T	exas Cor	mptroller of Pu	blic Accounts)	ed Entity Ownership		
The Custom	er Name submitted here m	ay be updated automatic	ally bas	sed on what	ic current and a	etive with the T		
(SOS) or Tex	as Comptroller of Public Ac	counts (CPA).	,	on mile	s carrent and a	ctive with the lexa	s Secretary of State	
6. Customer	Legal Name (If an individual,	print last name first: eg: Doe		If new Customer, enter previous Customer below:				
City of Carrizo	Springs							
7. TX SOS/CI	PA Filing Number	8. TX State Tax ID (11	digits)		9. Federal	Tay ID 10 D	HING N. I	
		,	U/		J. Teueral	applic	UNS Number (if able)	
					(9 digits)			
					74-6000491			
11. Type of (				☐ Ind	ividual	Partnership:	General Limited	
	City County Federal	Local State Other		Sol	Sole Proprietorship Other:			
12. Number	of Employees				13. Indeper	ndently Owned and	d Operated?	
☑ 0-20 □	21-100 101-250 25	51-500		☐ Yes				
14. Custome	r Role (Proposed or Actual) – c	as it relates to the Regulated E	Entity lis	ted on this for	m. Please check or	ne of the following		
Owner	Operator	Owner & Oper						
Occupation	al Licensee Responsible	Party VCP/BSA Ap			⊠ Ot	her: Partner		
15. Mailing	City of Carrizo Springs				-			
-	PO Box 329							
Address:	City Carrizo Springs	State	T		T			
			TX	ZIP	78834	ZIP + 4	4	
6. Country P	Mailing Information (if outside	de USA)		17. E-Mail	Address (if applied	cable)		
				rcastillo@cit	yofcarrizosprings.	org		
	e Number		on or C	1				

TCEQ-10400 (11/22) Page 1 of 3

### **SECTION III: Regulated Entity Information**


-0	entity inform	nation (if New R	egulated Entity" is s	elected, a new	permit appli	cation is also requ	irad 1	
New Regulated Entity		to Regulated Entit		te to Regulate			rea.)	
The Regulated Entity N as Inc, LP, or LLC).	lame submit	ted may be upd					al of organiza	tional endings such
22. Regulated Entity N	ame (Enter no	ame of the site who	ere the regulated ac	tion is taking p	lace.)			
City of Carrizo Springs Wa	stewater Treat	ment Facility						
23. Street Address of the Regulated Entity:								
(No PO Boxes)	City		State		ZIP	T	ZIP + 4	
24. County	Dimmit							
		if no Stre	et Address is pro	vided, fields	25-28 are r	equired.		
25. Description to  Physical Location:	Located ap						n Carrizo Spring	s, Dimmit County, Texa
26. Nearest City						State		earest ZIP Code
							7.5	
Carrizo Springs						TX		8834
Carrizo Springs  Latitude/Longitude are used to supply coordina  27. Latitude (N) In Decir	in increm	d may be added one have been p	l/updated to meet provided or to gail	accuracy).		ards. (Geocoding	g of the Physic	al Address may be
atitude/Longitude are used to supply coording 27. Latitude (N) In Deci	in increm	one nave been p	/updated to meetorovided or to gain	28. L	.ongitude (\	ords. (Geocoding	g of the Physic	al Address may be
atitude/Longitude are used to supply coording 27. Latitude (N) In Deci	mal:	one nave been p	novidea or to gail	accuracy).	.ongitude (\	ards. (Geocoding	g of the Physic	oal Address may be
Latitude/Longitude are used to supply coordinate.  27. Latitude (N) In Decide Degrees  28°  29. Primary SIC Code	Minutes	28°31′30″ N	Seconds 30	28. L	ongitude (\ ees -99°	V) In Decimal:  Minutes  de 32.	-99°51 51 Secondary N	700" W Seconds
Latitude/Longitude are used to supply coordina 27. Latitude (N) In Deci	Minutes	28°31′30″ N  31 Secondary SIC	Seconds 30	28. L Degre	ongitude (\ ees -99°	W) In Decimal:  Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	700" W Seconds
catitude/Longitude are used to supply coordinate.  27. Latitude (N) In Decide 128°  28°  29. Primary SIC Code 14 digits)	30. (4 c	28°31′30″ N  31  Secondary SIC digits)	Seconds 30  Code	28. L  Degree  31. Primal (5 or 6 digi	ees -99° ry NAICS Co	V) In Decimal:  Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	700" W Seconds
catitude/Longitude are used to supply coordinate.  27. Latitude (N) In Decide 128°  28°  9. Primary SIC Code 14 digits)  952  3. What is the Primary	30. (4 c	28°31′30″ N  31  Secondary SIC digits)	Seconds 30  Code	28. L  Degree  31. Primal (5 or 6 digi	ees -99° ry NAICS Co	W) In Decimal:  Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	700" W Seconds
Latitude/Longitude are used to supply coordinate.  27. Latitude (N) In Decide 28°  28°  29. Primary SIC Code 4 digits)  952  3. What is the Primary vastewater Treatment	Minutes  30. (4 c	28°31′30″ N  31  Secondary SIC digits)	Seconds 30  Code	28. L  Degree  31. Primal (5 or 6 digi	ees -99° ry NAICS Co	W) In Decimal:  Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	700" W Seconds
Latitude/Longitude are used to supply coordinate.  27. Latitude (N) In Decide 28° 28° 29. Primary SIC Code 4 digits)  952 3. What is the Primary Vastewater Treatment  4. Mailing	Minutes  30. (4 c	28°31′30″ N  31 Secondary SIC digits) this entity? (De	Seconds 30  Code	28. L  Degree  31. Primal (5 or 6 digi	ees -99° ry NAICS Co	W) In Decimal:  Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	700" W Seconds
Latitude/Longitude are used to supply coordinate.  27. Latitude (N) In Decide 28° 28° 29. Primary SIC Code 4 digits)  952 3. What is the Primary Vastewater Treatment  4. Mailing	Minutes  30. (4 c) N/A Business of to	28°31′30″ N  31 Secondary SIC digits) this entity? (De	Seconds 30  Code	28. L  Degree  31. Primal (5 or 6 digi	ees -99° ry NAICS Co	W) In Decimal:  Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	al Address may be '00" W Seconds 00 AICS Code
Latitude/Longitude are used to supply coordinate as a supply coordin	Minutes  30. (4 c) N/A  Business of to the control of Care PO Box 32  City	28°31′30″ N  31  Secondary SIC digits)  this entity? (Do	Seconds  30  Code  o not repeat the SIC of State	31. Primal (5 or 6 digi	ees -99° ry NAICS Co	Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	al Address may be '00" W Seconds 00 AICS Code
Latitude/Longitude are used to supply coordina 27. Latitude (N) In Decidor 28° 28° 29. Primary SIC Code 4 digits)	Minutes  30. (4 c) N/A  Business of to the control of Care PO Box 32  City	28°31′30″ N  31  Secondary SIC digits)  this entity? (Do	Seconds  30  Code  o not repeat the SIC of State	28. L Degree  31. Prima (5 or 6 digital 22132  Degree  TX	ees -99° ry NAICS Cotts)	Minutes  de 32.	99°51 51 Secondary Nor 6 digits)	al Address may be '00" W Seconds 00 AICS Code

**39. TCEQ Programs and ID Numbers** Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

TCEQ-10400 (11/22)
Page 2 of 3

☐ Dam Safety		Districts	Edwards Aqui	fer	Emissions Inventory Air		☐ Industrial Hazardous Waste
☐ Municipal Sol	id Waste	New Source Review Air	OSSF		Petroleur	m Storage Tank	□ PWS
Sludge		Storm Water	☐ Title V Air		Tires		Used Oil
☐ Voluntary Clea	snup	Wastewater WQ0010145001	☐ Wastewater A	griculture	☐ Water Rig	ghts	Other:
	obin Butcko	eparer Info	Ormation  44. Fax Number	41. Title:	Senior W	Vastewater Mana	ager
713 ) 458-8612			( ) -		ermittingservice	ces.net	
. By my signature b	elow, I certify	thorized Si y, to the best of my know e entity specified in Sect	uladaa that tha infa	nation provided i	n this form is t e updates to th	rue and complei	te, and that I have signature authority entified in field 39.
Company:	City of Ca	rrizo Springs		Job Title:	Water 0	Department Supe	ervisor
Name (In Print):	Ramsey C	astillo	7			Phone:	( 830 ) 876- <b>2476</b>
ignature:	Xa	mn. //	Til			Date:	08-26 2024

# Attachment 2 UGSG Map



# Attachment 3 Flow Diagram

# Attachment 4 Site Drawing

Questions or Comments >>

230	FEE.	42111	ry!	Page

Program Area Search

Additional ID Deta	11	Map It	C	ору Ма	p It URI	1		ACCUPATION OF THE OWNER, THE PARTY					AND THE PARTY OF T
Additional ID Pro	gram:	WWPER	TIMIT				Leç	jacy Syster (Code)		5)	**************************************	est utt	
Addition	nal ID:	WQ001	01450	001	Statu	s: ACTI	VE			ID Ty	pe: PERM	IIT	
	Name:	CARRIZ	O SPE	RINGS	WWTP		TO THE OWNER OF THE PARTY.		S		ldn TX00 Id: ID	259	76, EPA
Physical Ad	dress:	308 PEN	VA ST	, CARR	IZO SP	RINGS,	TX 78	834 3262	and an exame	Moreoverse	The state of the s	West Control	(2.4.5.4.4.5.2.4.4.4.4.4.4.4.4.4.4.4.4.4.
Descri	iption:								NAME OF THE OWNER,	CONTRACTOR ASSESSED		CO EWIND	
C C	ounty:	DIMMIT			Regio	n: REGI	ON 1	S - LAREDO					
Neares	t City:	CARRIX	O SPE	RINGS	Stat	e: TX			Nea	rest Z	ip: 7883	4	
Lat	itude:	28° 31 <i>1</i>	min 3	0 sec ()	28.525			Longitude	99°	51 mir	1 0 sec (-	99.	85)
3 Records						THE PERSON NAMED IN COLUMN 1	-		NOT THE RESERVE OF THE		A CANADA CANADA	on age	AND DESCRIPTION OF THE PARTY OF
Industry Types							AND THE REAL PROPERTY.					reconstruction of	
Classification System	(¥1		7	Code	Na	me	Property and the second	Mary Classes West			Primary I	Flao	
NAICS	OFF TON LOW	NAME OF TAXABLE PARTY.		221320	Sev	rage Treat	ment Pa	cilities		mentioned by	Y	- 20	
SIC	Waster and Co. 100		Į.	4952	Sav	rerage Sys	tems				Y		
1-1 of 1 Record													
Site Classifications					TO THE PARTY OF TH		***************************************			HTTS STREET	er milet av	***************************************	
Program S	ite Clas	ssificatio	) f7		Begir	Date		End Date	-,	CMS I	4in Freq	Oty	
WASTEWATER D	OMESTIC	MINOR			01/1/1	800		12/31/3000		C	CONTRACTOR OF THE PARTY OF THE		
1-1 of 1 Record										Market Radio Control	THE RESERVE OF THE PARTY OF THE		
Customers				TV PROMET STATES	THE REPORT OF STREET	VIII TO THE PARTY OF THE PARTY		THE REAL PROPERTY AND ADDRESS OF THE PERSON	THE PROPERTY OF THE PARTY OF TH	Tan	democratic services	*********	The state of the s
Customers		and the state of t	ne endo men	The same of the	T TATALES SERVICES	Department of the original				10.55	t All		
CN Number			Name							Rol	<u>e</u>		**************************************
CN600241418		Je.	ITY OF	CARRIZO	Serings					OWN			
1-1 of 1 Record													
Issued To				The second secon	Mecampe and	NAMES OF TAXABLE PARTY.	le af a fina a primare		-		*****************		
CN Number	Issuec	i To Nam	10		St	art Date	1		View '	Issued	To' Histo	ry	
CN656241418	CITY OF C	CARRIZO SP	PRINGS	SAY LLC	198	8-10-25 0	0:00:00.	3	View		COMPT THE SERVICE	INTERNAL TO	
		Cor - Control			mount bearing	TOWN COLD WATER		PERSONAL PROPERTY.					
Regulated Entity		A CONTRACTOR OF THE PARTY OF TH											
Reference N	umber:	RN101	7211	24	Nam	e: CITY	OF C	ARRIZO SP	RINGS		St	and	-Alone: N
Business Descr	iption:	DOMES	TIC										
Location													7/10-39 11-20
Address:	308 P	ENA ST,	CARR	IZO SP	RINGS	, TX 78	834 3	262					
Description:		7						and the second second					
County:	DIMM	IT						Region	REG	ON 16	- LARED	0	The state of the s
Nearest City:	CARRI	IZO SPRI	INGS			State:	TX		7	Ne	arest Zip	): 7	8834
Latitude:			1000		Mary and the Control of Street,	THE RESERVE THE PERSON NAMED IN	1	Longitute	:1			the same	
	-	The second Property of the Lorenty of			-		-					- Albert	

Este malo ( Discussion I Notico des I Adressidads I Viv. Germant and Tigeres I LEES Houndard Results I Contact de I

© 2002-2019 Texas Commission on Environmental Quality






Version 4.0

User Guide



ATTACHMENT 2 Aerial View of site



### Attachment 5 Pollutant Analysis

### SERVICES CONTROL POLLUTION



REVISED

# Report of Sample Analysis

Client Information	Sample Information	Laboratory Information
Public Works Carrizo Springs, City of PO Box 329 Carrizo Springs, TX 78834	Project Name: TCEQ Minor Permit Renewal Sample ID: Effluent Matrix: Non-Potable Water Date/Time Taken: 8/14/2024 14:00	PCS Sample #: 771739 Page 1 of 2 Date/Fime Received: 8/15/2024 11:35 Report Date: 8/26/2024 Approved by: Chuck Wallgren, Pusident

Carrizo Springs, TX 78834	8834	Da	te/Time Tal	ken: 8/14	Date/Time Taken: 8/14/2024 14:00	Approved by:	Hunk Wallgren, Phesident
Test Description	Flag	Result	Units	RL	Analysis Date/Time	Method	Analyst
Hd	Ĭ	7.9	S.U.	N/A	08/15/2024 15:10	SM 4500-H+B	COM
CBODS		8	mg/L	c	08/15/2024 15:10	SM 5210 B	GOM
Chloride IC		111	mg/L	7		EPA 300.0	JAS
Conductivity, Specific		1,034	umhos/cm at 25° C	°C 1		SM 2510B	227
Nitrate-N IC		23.9	mg/L	0.2		EPA 300.0	JAS
Phosphorus, Total	8	4.1	mg/L	0.10		SM 4500-P/B/E	JAS
Sulfate_IC	R	99	mg/L	2		EPA 300.0	JAS
Total Dissolved Solids		336	mg/L	01	08/21/2024 12:00	SM 2540C	CLH

Blank

LCS LCS Limit

UCL

MSD

Assurance Summary LCL MS

Cimit

Precision N/A

Test Description

207

N/A 102

N/A 96

N/A 98

N/A 23 10 85 - 115

100

N/A 130 101 N/A

828

97 \*102

N/A 20 10

N/A

Conductivity, Specific

Chloride IC

CBODS

Phosphorus, Total

Sulfate IC

Nitrate-N IC

 $\nabla$ 

85 - 115

85 - 115

to data quality objectives and test results meet the requirements of NELAC unless otherwise noted as flagged	
is fla	
ted a	
e no	
erwis	
s oth	
unles	
AC.	
NEI	
ts of	
men	
quire	rest.
he re	regi
reet t	o ale
ılts n	ailat
resu	re ar
d tes	iles a
es an	verat
ectiv	ı deli
y obj	full quality data deliverables are available on req
walit	rality
ara q	nil di
f to a	vith f
hered	H SJAC
a ad	Rep
y da	ient.
Jualii	achn
ing a	e att
ppor	rratis
II su	e na
it: A	a cas
temer	or in
Stal	ous
Quality Statement: All supporting quality data adhered to t	exceptions or in a case narrative attachment. Reports with full quality data deliverables are available on request.
0	0

2.87

Total Dissolved Solids

All data is reported on an 'As Is' basis unless designated as 'Dry Wt.'

RL = Reporting Limits

QC Data Reported in %, Except BOD in mg/L

1 - See Sample LogIn Checklist Comments for Revision Information

These analytical results relate only to the sample tested

This report cannot be report

www.pcslab.net chuck@pcslab.net

1532 Universal City Blvd Universal City, TX 78148-3318 This report cannot be reproduced or duplicated, except in full, without prior written consent from Pollution Control Services.

Main: 210-340-0343 Fax: 210-658-7903

## SERVICES POLLUTION CONTROL



REVISED 1

# Report of Sample Analysis

Cheat Information	Sample Information	Laboratory Information
Public Works Carrizo Springs, City of PO Box 329 Carrizo Springs, TX 78834	Project Name: TCEQ Minor Permit Renewal Sample ID: Effluent Matrix: Non-Potable Water Date/Time Taken: 8/14/2024 14:00	PCS Sample #: 771739 Page 2 of 2 Date/Time Received: 8/15/2024 11:35 Report Date: 8/26/2024

Test Description	Result	Units	RL	Analys	Analysis Date/Time Method	ime	Methoc		Analyst	
Total Suspended Solids Ammonia-N (ISE)	3 <0.1	mg/L mg/L	0.1	08/15/	08/15/2024 15:45 08/15/2024 15:00	S S 0	M 2540 M 4500-	SM 2540 D SM 4500-NH3 D	PML BMR	
Kjeldahl-N, Total	7	mg/L	_	08/21/	08/21/2024 11:00		M 4500-	N B/C	BMR	
										· · · · · ·
Test Description	Precision	Quality Assu Limit	Quality Assurance Summary	MS	MSD	UCL	LCS	UCL LCS LCS Limit	Blank	
Total Suspended Solids	\ \ -1	10	N/A			N/A				
Ammonia-N (ISE)	$\nabla$	10	80	105	106	120	88	85 - 115		141444
Kjeldahl-N, Total	_	0	06	86	66	109	101	85 - 115	7	

Quality Statement: All supporting quality data adhered to data quality objectives and test results meet the requirements of NELAC unless otherwise noted as flagged exceptions or in a case narrative attachment. Reports with full quality data deliverables are available on request.

1 - See Sample LogIn Checklist Comments for Revision Information

www.pcslab.net chuck@pcslab.net

1532 Universal City Blvd
Universal City, TX 78148-3318
This report cannot be reproduced or duplicated, except in full, without prior written consent from Pollution Control Services.

Main: 210-340-0343 Fax: 210-658-7903

### SERVICES CONTROL POLLUTION

Chain of Custods, amber 771738

Springs, City of   Attention: John Camarilli   Attention	REPORT INFORMATION
## Field Sample ID Date Time Goldected By: Collected By: C	arillo   Phone:  930 859 0484   Fax:  830 876 3127
Shart   Shar	Requested Analysis
Shart   Shar	SS
Solis"   Day Wt.   Collected   Collecte	L'
tt / Field Sample ID  Date Time Gill Sond Washer, Start  End: End: Start  Start Start  End: End: Start  End: End: End: Collected  Date Time Gill Start  End: End: Start  End: End: Start  End: End: End: Collected  Start Start  End: Collected  Start Start  End: End: Collected  Start Start  End: End: Collected  Start Start  End: Collected	MVV RZ,I.
ent Start: 2024 Start: 10   10   10   10   10   10   10   10	ni SS SS SS SS SS SS SS SS SS SS SS SS SS
ent   Start;   Start	ph, ALL.
End:	
Start	O HEM O
End: End: End:   Gried   Gried   LW   Gried   G	CH;SO; CHNO,
ent	DICE DISCRIPTION ON THE MODEL
End:   End:   End:   C   C   C   C   C   C	
eint Start: Start; End: □C □ WW □ Soil □G □ Studge □ LW □ O □ PW □ Soil □G □ Studge □ LW □ O □ PW □ Soil □G □ Studge □ LW □ O □ PW □ Soil □G □ Studge □ LW □ O □ PW □ Soil □G □ D □ PW □ Soil □G □ D □ PW □ Soil □G □ D □ PW □ PW □ D □ D □ PW □ PW □ D □ D □ D □ D □ D □ D □ D □ D □ D □	DICE DINGS
tion    Shart:   End:   End:   End:   Cotter	
tion	OICE D.
End:   End:	177177 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Start:   Start:   C   D W   D W   D W     Ead:   Ead:   C   D W   D W   D W     Start:   Start:   C   D W   D W   D W     Ead:   Ead:   Ead:   C   D W   D W     Start:   Start:   D C   D W   D W     Ead:   Ead:   Ead:   D C   D W   D W     Start:   Start:   D C   D W   D W     Start:   Start:   D C   D W   D W     Start:   D C   D C     Start:   D C   D C     D C   D C	DICE O DIEM Other:
Ead: Ead: Coher C	DH,SO,IDHNO,
Start: Start: □C □ DW □ NPW □P □C □ Bud: □C □ WW□ Soil □C □ Studge □ LW □ C □ WW□ Soil □C □ Studge □ LW □ C □ C □ WW□ Soil □C □ C □ WW□ Soil □ C □ C □ C □ C □ C □ C □ C □ C □ C □	DICE ON CHEMONE.
G	ОНЕОСПИО) ТИТО ТОТО ТОТО ТОТО ТОТО ТОТО ТОТО Т
:	DICE DISCHARGORIE
EXPEDITE: (See Surcharge Schedule)   Container Ty	DH <sub>2</sub> SO <sub>1</sub> DHNO <sub>3</sub>
EXPEDITE: (See Surcharge Schedule)	DICE D
☐ Hold for client pick up	□ < 16 Hrs. □ < 24 Hrs. □ 5 days □ Other. Rush Charges Authorized by:
	e: P=Plastic, G=Glass, O=OtherCarrier1D:
Time: 19:20cm	. Received By:   K. K. R.   Date:   5-15-24   Time:   5:20 M
Time:  //.3/pc_	Received By:   /ngan   Kan   Date:   4/5-24   Time:     3

<sup>1532</sup> Universal City Blvd., Ste. 100, Universal City, Texas 78148 P (210) 340-0343 or (800) 880-4616 - F (210) 658-7903

### Rick Wilborn

Carrizo Springs

From:

Chuck Wallgren

Sent:

Tuesday, August 6, 2024 4:21 PM

To:

Rick Wilborn

Subject:

Re: Testing Requirements for Permit Renewal

They don't need oil and grease or total alkalinity or enterococci - and the the DO and chlorine and pH need to come off their on site test data - we should be able to get the extra off the regular weekly sample - just go ahead and get receiving to log this week effluent fir them as TCEQ Minor Permit Renewal

Sent from my iPhone

On Aug 6, 2024, at 4:15 PM, Chuck Wallgren < Chuck@pcslab.net> wrote:

We can do this Minor Permit Renewal Testing list off the regular weekly sample - we don't need anything extra for it - pretty sure we get enough sample to do all the things that they need done -

Sent from my iPhone

On Aug 6, 2024, at 2:39 PM, Rick Wilborn < Rick@pcslab.net> wrote:

Ramsey, thank you very much. Can you please remind me of when you were wanting to do this testing? Do you need anything else from us in advance?

Rick Wilborn

<mage001.png>210-340-0343

General Manager

<image002.png>www.pcslab.net

**Pollution Control Services** 

<image003.png>1532 Universal City Blvd

How are we doing? https://pcslab.net/feedback-survey/

From: Ramsey Castillo <rcastillo@cityofcarrizo.org>

Sent: Tuesday, August 6, 2024 1:37 PM
To: Rick Wilborn < Rick@pcslab.net>

Subject: FW: Testing Requirements for Permit Renewal

Importance: High

### **Pollution Control Services**

771738 Sample Log-In Checklist

OF 10 BT 101	·	~		. ~11
Client/Company Name:	170	C	hecklist Completed	1 by: <u>UA A</u>
Sample Delivery to Lab Via:				
Client Drop Off Commercia	Carrier: BusU	PS Lone Star	FedExl	JSPS
PCS Field Services: Collection/Pick	UpOther:		11	•
Sample Kit/Coolers				
Sample Kit/Cooler? Yes No	Sample Kit/Cooler:	Intact? Yes No		
Custody Seals on Sample K	it/Cooler: Not Present	If Present, Intac	t Broken	
Sample Containers Intact; Unbroken				
Custody Seals on Sample B	ottles: Not Present	If Present, Intact	- Broken	
COC Present with Shipment or Deliv				- 22
Has COC sample date/time and other	pertinent information	been provided by cl	ient/sampler? Yes: -	-No:
Has COC been properly Signed when	Received/Relinquishe	ed? Yes No	# GE	
Does COC agree with Sample Bottle	Information, Bottle Ty	pes, Preservation, e	tc.? Yes No	
All Samples Received before Hold T	ime Expiration? Yes	No	to the managed second	
Sufficient Sample Volumes for Analy				
Zero Headspace in VOA Vial? Yes	No			
Sample Preservation:			•	
* Cooling: Not Required	or Required		4	7
If cooling required, record temperatu	re of submitted sample	s Observed/Correcte	d 711	- °C
Is Ice Present in Sample Kit/Cooler?	Yes No	Samples received s	ame day as collected?	LYes /
Lab Thermometer Make and Serial Numl	er: Vaughan 180700958	3 Other:		
Para Preserved Sample - If present i	nH >122 Vec	No.	H <sub>2</sub> SO <sub>4</sub> HN NaOH	IO3H3PO4
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations.	s pH > 12? Yes  If Present, N  A 4 Date 8-  rvation (PCS log #): 6	No Teets Requirements? 15-24 Time 13-13	NaOH   Yes	d at analysis).
Acid Preserved Sample - If present Base Preserved Sample - If present, i Other Preservation: Sample Preservations Checked by: 7 pH paper used to check sample prese Samples Preserved/Adjusted by Lab:	s pH > 12? Yes  If Present, M A Date S  rvation (PCS log #): Lab # Param	No Meets Requirements? 15-24 Time 13-13 / neters Preserved	NaOH   Yes	d at analysis).
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations.	s pH > 12? Yes  If Present, M A Date S  rvation (PCS log #): Lab # Param	No Teets Requirements? 15-24 Time 13-13	NaOH   Yes	d at analysis).
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:	S pH > 12? Yes  If Present, M  A Date S  rvation (PCS log #): A  Lab # Param  Date : Time	No Jeets Requirements? 15-24 Time (3-/3) neters Preserved	NaOH Yes No A J Z J G (HEM pH checke Preservative Used	d at analysis). Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:	S pH > 12? Yes  If Present, M  A Date S  rvation (PCS log #): A  Lab # Param  Date : Time	No Jeets Requirements? 15-24 Time (3-/3) neters Preserved	NaOH Yes No HEM pH checke Preservative Used  Discrepancies/ Re	d at analysis). Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Time:	If Present, M. Date & Date & Param  Lab # Param  Date: Time  Tation for "No" Re  Contact	No Meets Requirements? 15-24 Time 13-13   neters Preserved  ne: sponses Above/ I ted by:	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Time:	If Present, M. Date & Date & Param  Lab # Param  Date: Time  Tation for "No" Re  Contact	No Meets Requirements? 15-24 Time 13-13   neters Preserved  ne: sponses Above/ I ted by:	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Method of Contact: At Drop Off:	S pH > 12? Yes  If Present, M A	No Meets Requirements? 15-24 Time 13-13 I meters Preserved  re: sponses Above/ I ted by: ce Mail E-Mail	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: Total paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Method of Contact: At Drop Off:  Unable to Contact  Authorized	S pH > 12? Yes	No Meets Requirements? 15-24 Time 13-13 I meters Preserved  Time 15-24 Time 1	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: Depth paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Method of Contact: At Drop Off:  Unable to Contact  Authorized	S pH > 12? Yes  If Present, M A	No Meets Requirements? 15-24 Time 13-13 I meters Preserved  Time 15-24 Time 1	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Method of Contact: At Drop Off: Unable to Contact Regarding / Comments:	S pH > 12? Yes  If Present, N  A	No Meets Requirements? 15-24 Time 13-13   meters Preserved  me: sponses Above/ I ted by: ce Mail E-Mail	NaOH Yes No HEM pH checke Preservative Used	d at analysis). Log #
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Method of Contact: At Drop Off: Unable to Contact  Authorized	S pH > 12? Yes  If Present, N  A	No Meets Requirements? 15-24 Time 13-13   meters Preserved  me: sponses Above/ I ted by: ce Mail E-Mail	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #
Base Preserved Sample - If present, in Other Preservation: Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab: Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified: Notified Date: Method of Contact: At Drop Off: Unable to Contact Regarding / Comments:	S pH > 12? Yes  If Present, N  A	No Meets Requirements? 15-24 Time 13-13   meters Preserved  me: sponses Above/ I ted by: ce Mail E-Mail	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #
Base Preserved Sample - If present, in Other Preservation: Sample Preservations Checked by: Description of the Preservations Checked by: Description of the Preserved of the Preserved of the Preserved of Tech/Analyst:  **Client Notification/ Document Person Notified:** Notified Date: Time: Method of Contact: At Drop Off: Unable to Contact: Authorized Regarding / Comments:  **Actions taken to correct problems/disparents.**	S pH > 12? Yes	No Meets Requirements? 15-24 Time 13-13 Interest Preserved  Time 15-24 Time 1	NaOH Yes No HEM pH checke Preservative Used	d at analysis).  Log #  vision Comment  (Lab Director)
Base Preserved Sample - If present, in Other Preservation:  Sample Preservations Checked by: The paper used to check sample preservations Preserved/Adjusted by Lab:  Adjusted by Tech/Analyst:  Client Notification/ Document Person Notified:  Notified Date:  Method of Contact: At Drop Off: Unable to Contact Regarding / Comments:	S pH > 12? Yes	No Meets Requirements? 15-24 Time 13-13 Ineters Preserved  Time 15-24 Time 15	NaOH Yes No 1214 (HEM pH checke Preservative Used  Discrepancies/ Re	d at analysis).  Log #  vision Comment  (Lab Director

# POLLUTION CONTROL SERVICES



REVISED

## Report of Sample Analysis

Client Information	Sample Information	Laboratory Information
Public Works Carrizo Springs, City of PO Box 329 Carrizo Springs, TX 78834	Project Name: TCEQ Minor Permit Renewal Sample ID: Effluent Matrix: Non-Potable Water Date/Time Taken: 8/14/2024 14:00	PCS Sample #: 771739 Page 1 of 2 Date/Time Received: 8/15/2024 11:35 Report Date: 8/27/2024 Approved by: Chuck Wallgren, Physident

Test Description	Flag	Result	Units	RL	Analys	Analysis Date/Time		Method		Analyst
Hď	I	6.7	S.U.	N/A	08/15/	08/15/2024 15:10		SM 4500-H+B	H+B	GQM
CBODS		\$	mg/L	m	/\$1/80	08/15/2024 15:10		SM 5210	В	GOM
Chloride IC		111	mg/L	2	/\$1/80	08/15/2024 18:59		EPA 300.0	0	JAS
Conductivity, Specific		1,034 µml	umhos/cm at 25° C	c 1	08/15/	2024 16:4		SM 2510	8	CC
Nitrate-N_IC		23.9	mg/L	0.2	08/15/	08/15/2024 18:59		EPA 300.0	•	JAS
Phosphorus, Total		4.1	mg/L	0.10	08/27/	2024 00:		M 4500	P/B/E	JAS
Sulfate_IC	R	99	mg/L	2	/51/80	08/15/2024 18:59		300.	0	JAS
Total Dissolved Solids	í	009	mg/L	10	08/26/	08/26/2024 15:25		SM 2540C	•	PMIL
			Quality Ass	urance Summa	1					
Test Description		Precision	Limit	Limit LCL	MS	MSD	UCL	CCS	LCS LCS Limit	Blank
Hd		N/A	N/A	N/A		*-	N/A			
CBODS		7	23	N/A	N/A	N/A	N/A	207	167 - 228	
Chloride IC		2	10	95	86	96	102	94	85 - 115	
Conductivity, Specific		N/A	N/A	N/A			N/A			
Nitrate-N_IC		2	20	70	26	66	130	102	85 - 115	
Phosphorus, Total		⊽	10	91	96	26	103	100	85 - 115	
Sulfate_IC		£	10	94	*102	66	101	102	85 - 115	
Total Dissolved Solids		7	10	N/A	N/A	N/A	N/A			

Quality Statement: All supporting quality data adhered to data quality objectives and test results meet the requirements of NELAC unless otherwise noted as flagged exceptions or in a case narrative attachment. Reports with full quality data deliverables are available on request.

All data is reported on an 'As Is' basis unless designated as 'Dry Wt'.

These analytical results relate only to the sample tested.

1 - See Sample LogIn Checklist Comments for Revision Information

QC Data Reported in %, Except BOD in mg/L

RL = Reporting Limits

R Spike recovery outside control limits due to matrix effect - LCS within limits \*Approved for release per QA Plan, Exception to Limits - QAM Section 13-4

I Informational purposes only - pH outside hold time - pH Temperature: 30°C

Universal City, TX 78148-3318

This report cannot be reproduced or duplicated, except in full, without prior written consent from Pollution Control Services. 1532 Universal City Blvd

chuck@pcslab.net www.pcslab.net

Main: 210-340-0343 Fax: 210-658-7903

### SERVICES CONTROL POLLUTION



### REVISED

# Report of Sample Analysis

Client Information	Public Works Carrizo Springs, City of PO Box 329 Carrizo Springs, TX 78834 Date
Sample Information	Project Name: TCEQ Minor Permit Renewal Sample ID: Effluent Matrix: Non-Potable Water Date/Time Taken: 8/14/2024 14:00
Laboratory Information	PCS Sample #: 771739 Page 2 of 2 Date/Time Received: 8/15/2024 11:35 Report Date: 8/27/2024

Test Description	Result	Units	RL	Analy	Analysis Date/Time	me	Method		Analyst	
Total Suspended Solids Ammonia-N (ISE)	3	mg/L me/L	1 0 1	08/15	08/15/2024 15:45	10 E	SM 2540 D SM 4500-NH3 D	O H3 D	PML RMR	
Kjeldahl-N, Total	2	mg/L		08/21	08/21/2024 11:00		M 4500-P	VB/C	BMR	
					5			ā		
		Ouality Ass	urance Summ	ary						
Test Description	Precision	Limit	Limit LCL	MS	MSD L	UCL	CS	LCS LCS Limit	Blank	
Total Suspended Solids	⊽	10	N/A			N/A				
Ammonia-N (ISE)	∀	10	80	105	106	120		85 - 115		
Kjeldahl-N, Total	,—	10	90	86	66	109	101	85 - 115	$\nabla$	

s flagged	
ss otherwise noted a	
unle	
ments of N	
eet the require	le on request.
f test results m	les are availab
objectives and	data deliverab
data quality	h full quality of
ata adhered to	t. Reports with
oporting quality data adhere	ve attachment. 1
All su	exceptions or in a case narrative a
dity Statement:	ptions or in t
Qualit	exc

These analytical results relate only to the sample tested.

Main: 21	1532 Universal City Blvd	1532 Universal City Blvd
	l - See Sample LogIn Checklist Comments for Revision Information	
	All data is reported on an 'As Is' basis unless designated as 'Dry Wt'.  RL = Reporting Limits	

www.pcslab.net chuck@pcslab.net

# POLLUTION CONTROL SERVICES

MULTIPLE SAMPLE ANALYSIS REQUEST AND CHAIN OF CUSTODY FORM

Chain of Custods \_ amber 771758

Stamp I sample and COC as same number

CUSTOMER INFORMATION	NOIL	On Later containers of communications communications of the Communication	Management of the last of the	REPOR	T INFO	REPORT INFORMATION								
Name: Carrizo Springs, City of	City of			Attentio	n: John	Attention: John Camarillo		Phon	Phone:   30 854 0484	2	048		Fax:  830   876 3127	6.31241
SAMPLE INFORMATION	Z				(		Requ	Requested Analysis	Analys	is		À		
Project Enformation.			Collected Ry	P	ľ			1				ľ	Instructional	Commente
				Matrix	4	Container	SST		ST ,	ES2		'von		Aminor Parist
teport "Soils"   As Is   Dry WL	W£			DW-Drinking Water, NPW-Non-			D'		OD	MV		<u>/s′1</u>		MEIN
	Sall	Collected			) be	Preservative	ВС				SS	ilo	'h	
Client / Field Sample ID	Date	Time	Pield ( Residi Comp Grab		ŗ		,Hq	EHN	pp' (	ME	ME		PCS Sa	PCS Sample Number
Influent	Start: 08-15-2494	Start 02:5500		1	1	DH-SO, DHNO,		H	<u> </u>	-			777	7.30
	End:		Ö	3 Cladge CLW	<u>18</u>	O ICE O	X	X	-				MS CIB CIN CHEM Obec	НЕМ Офет
Transferrite services constructions constructions constructions and constructions are constructed and constructions and constructions and constructions are constructed and constructions are constructed and construc	Start:	Start:		1	â	DH,SO, DHNO,			<b> </b>					
	End:	End:	<u></u>					17 -7	Distributed of				OS CIR CIN CHEM Other.	HEM Other:
Effluent	Start: 08-14-227	Sturt:	ì		ac	DH-SO, DHNO,	411/00/		1			-	1771	739
	End:	End:	<u> </u>	3 Osher DLW		Olice O		131	<u>X</u> 7			<u>X</u>	AND SON CHEM OFFER	HEM Other:
Effluent	Start: 56-38-7028	100		-	åö	DH, SO, DHNO,			_	_		-		07/
	End:	End:			8							K	DISCOB ON CHEM Other.	HEM Other.
Aeration	Start.	Start.	رق		88	DH, SO, DHNO,				크			77.1	176
				3 ☐ Sludge ☐ LW		oice o				<b>K</b>		<del>- No.,,,,,</del>	CIS CIR CIN CIREM OBSET	НЕМ Офег
	Start	Stert:		1	åč	CH,SO, CHNO,			H	<u> </u>				
	Ead:	Eud:	<u> </u>	Maria Anna	8	Dice O				******			OS OB ON OHEM Other	HEM Other.
RAS	Start: 06 -1024	Start.		1	ae	DH,SO,DHNO,			<u> </u>		-	<u> </u>	771	742
		End:			ia	Dice D				<del>physical accordigit</del>	X		OS OB ON CHEM Other	HEM Other:
And the second s	Starf:	Start	Ö		àE	D H,SO, D HNO,				_				
	End:	Eod:	<u> </u>	-	88	D aoin		-	Martin par				OS CIB CIN CIHEM Other	HEM Other:
Required Turnaround:   Routine (6-10 days)	toutine (6-10 day	*Outreed	TE: (See Su	EXPEDITE: (See Surcharge Schodule)	□ <8 Hm.	Hrs. D < 16 Hrs. D < 24 Hrs.		□ 5 days □	□ Other:		Rush C	harges An	Rush Charges Anthorized by:	
Sample Archive Disposal: C. Laboratory Sandard D Hold for client p	Paboratory Sm	ndard D Hold	for client p	ckup	ontainer	Container Type: P=Plastic, G=Glass.	s, 0=Other	igher					Carrier ID:	
Relinquished By		1	Date: 8/	1/s/24 Time:	" 9.00cm	Dan Received By: K	X	5	1			Date:	6-16-24	Time: 9:20 #
N	19/9		Date: 1	が-2ッ   Time:		11:18 Are Received By: 1	Mar.	. (	13	The same	П	Date:	4-15-34	Time:   // 55
Lev. Multiple Sample COC_EDISOGS 1532 Universal City Blvd S	the 100 Unive	real City. Tex	ac 78 1 48			7			1					
P (210) 340-0343 or (800) 880-4616 - F (210) 658-7903	80-4616 - F	(210) 658-790	E E										Login	Login at miny acstablies

P (210) 340-0343 or (800) 880-4616 - F (210) 658-7903

Samos osmes

Rick Wilborn

Chuck Wallgren

Tuesday, August 6, 2024 4:21 PM

Rick Wilborn
Re: Testing Requirements for Permit Renewal

:Joe[qn5

:oT

Sent

From:

They don't need oil and grease or total alkalinity or enterococci - and the the DO and chlorine and pH need to come off their on site test data - we should be able to get the extra off the regular weekly sample just go ahead and get receiving to log this week effluent fir them as TCEQ Minor Permit Renewal

Sent from my iPhone

On Aug 6, 2024, at 4:15 PM, Chuck Wallgren <Chuck@pcslab.net> wrote:

We can do this Minor Permit Renewal Testing list off the regular weekly sample - we don't need anything extra for it - pretty sure we get enough sample to do all the things that they need done -

Sent from my IPhone

On Aug 6, 2024, at 2:39 PM, Rick Wilborn <Rick@pcslab.net> wrote:

Ramsey, thank you very much. Can you please remind me of when you were wanting to do this testing? Do you need anything else from us in advance?

200-045-015<8nq.1009gemi>

ien.deleouwww.egnq.S009gami>

<image003.png>1532 Universal City Blvd

General Manager Poliution Control Services

Rick Wilborn

How are we doing? https://pcalab.net/feedback-survey/

From: Ramsey Castillo <rcastillo@cityofcarrizo.org>
Sent: Tuesday, August 6, 2024 1:37 PM

To: Rick Wilborn <Rick@pcslab.net>
Subject: FW: Testing Requirements for Permit Renewal
Importance: High

Sample Log-in Checklist DCN: SL-001, Rev. 1 Effective Date: 6/07/2022

### Pollution Control Services

8/27/24 w	0.110	- P>KZ-81	encer le	درر لرو	1 - 2020 20 Lest Lead
العد المستوط	sint amiT gai	-12-12/32 12-12-13	P & TATT P & TATT P & PAN	HISOLUSINIT HISOLUSINIT T	eceiving qualifier needed (requires dualifier entered into techning qualifier entered into techning qualifier centered into techning
				:səjɔuedəɹɔsjp/su	ctions taken to correct problem
(Toto Director)	Tar Tax	isM-3lis	M soice M the Moice of the second of the moice of the moior of t		Method of Contact: At Drop Of
CHISHINASHARAS	V 78315V91/2 158V		Contacted by	me:	Tient Motification/ Docus erson Motified: iT :sisted Date:
stanumo Incisival	A Janinangangili		:этіТ	Date :	djusted by Tech/Analyst:
			Company of the part of the par		
Fed at analysis). Log #	1914	73	Present, Meets Date 8-15-	by: JAA	lase Preserved Sample - If pres ample Preservation: H paper used to check sample   H paper used to check sample
HOO4 HOPO		~* oV	Xes /	esent, is pH <2?	reid Preserved Sample - If pr
o. T	d Ay as collecte	s baviacar salqı	edO salqmas bar ms2 oM	Dier? Ves	ample Preservation: Cooling: Not Required Cooling required, record temp 5 lee Present in Sample KivCoo ab Thermometer Make and Serial ab Thermometer Make and Serial
ı <del>-</del>	C? Yes_No_	Preservation, et	Bottle Types, on? Yes A	tottle Information old Time Expirati Analysis Request	Social Sample Baraphe Bolore Holore Holore Holore Holore Moles Received both Baraphe Volumes for Leadspace in VOA Visi?
:0N	16	resent, Intact MY Yes 46 provided by oli	resent Alf P Jeted at Drop O formation been	ple Bottles: Not P Delivery or Comp other pertinent in	ample Containers Intact; Unbra Custody Seals on Samp OC Present with Shipment or Iss COC sample date/time and las COC Sent properly Signed
	Broken	Present, Intact		ole KivCooler: No	smple Kit/Coolers smple Kit/Cooler? Yes Custody Seals on Samp
SASU	FedEx	Lone Star	s UPS	ercial Carrier: Bu	Smple Delivery to Lab Vis Elent Drop Off Commi CS Field Services: Collection
led by: JAA	hecklist Complet	Э	anticonstructive transmittent (1911) in an experimental electron	02:190	Client/Company Name:
857		6 1	LLLL LlLL	ns2 85 7 1	CS Sample Mo(s)

### Attachment 6 Copy of Check

Attachment 7
PLS Summaries
English / Spanish



### Permitting Services, LLC

6425 Bankside Drive, Suite 2111 Houston, TX 77096 robin@permittingservices.net Tel. 713-458-8612

August 2, 2024

Texas Commission on Environmental Quality Water Quality Division Application Review and Processing Team (MC148) P.O. Box 13087 Austin, TX 78711-3087

Re:

Application to Renew Permit Number: WQ0010145001 - CITY OF CARRIZO SPRINGS

Customer Number: CN600241418

Regulated Entity Number: RN101721124

Dear Chief Officer,

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Carrizo Springs (CN600241418) operates the Carrizo Springs Wastewater Treatment Plant (RN101721124), the plant is a Extended Aeration and operates as an activated sludge wastewater treatment process to treat the wastewater before it is discharged. The facility is located approximately 0.5 miles NE of the intersection of US Hwy. 83 and S.H.-85 and S.H.-85 in Carrizo Springs, Dimmit County, Texas 78834.

This application is for a renewal to dispose a daily average flow not to exceed 950,000 gallons per day of treated domestic wastewater via outfall 001.

Discharges from the facility are expected to contain seven-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater is treated by an Existing Phase I: The plant operates as an activated sludge wastewater treatment process to treat the wastewater prior to release into a stream. Treatment Plant includes extended aeration: effluent enters through a mechanical screen to a lift station & lifted to an aeration basin. MLSS flows by gravity to the clarifier. Sludge pumps return sludge from clarifier to an

aeration basin or is wasted to sludge beds. Clear effluent from the clarifier flows by gravity to UV for disinfection, to Parshall flume then to a point of discharge. The sludge is transported by truck from City of Carrizo Springs to the City of Carrizo Springs Municipal Landfill in Dimmit County.

The plant discharges treated wastewater at a volume not to exceed an annual average flow of 950,000 gallons per day. The effluent discharges through a 20" pipe to Carrizo Creek; thence to Soldier Slough; thence to Nueces River above Holland Dam in Segment No. 2105 of the Nueces River Basin.

I appreciate your time and effort in reviewing my summary. If you have any questions, please contact me at (713) 458-8612, or via email at <a href="mailto:robin@permittingservices.net">robin@permittingservices.net</a>.

Yours truly,

Robin Butcho

Robin Butcko Senior Wastewater Consultant Permitting Services, LLC (713) 458-8612



### Permitting Services, LLC

6425 Bankside Drive, Suite 2111 Houston, TX 77096 robin@permittingservices.net Tel. 713-458-8612

2 de agosto de 2024

Texas Commission on Environmental Quality Water Quality Division Application Review and Processing Team (MC148) P.O. Box 13087 Austin, TX 78711-3087

Re:

Solicitud de renovación del número de permiso: WQ0010145001

Número de cliente: CN600241418

Número de entidad regulada: RN101721124

Estimado Oficial Principal,

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no son representaciones federales exigibles de la solicitud de permiso.

La ciudad de Carrizo Springs (CN600241418) opera la Planta de Tratamiento de Aguas Residuales (RN101721124) de Carrizo Springs, la planta es de aireación extendida y funciona como una planta de aguas residuales de lodos activados proceso de tratamiento para tratar las aguas residuales antes de su vertido. La instalación está ubicada aproximadamente a 0.5 millas al NE de la intersección de US Hwy. 83 y S.H.-85 y S.H.-85 en Carrizo Springs, Dimmit County, Texas 78834.

Esta solicitud es para una renovación para disponer de un flujo promedio diario que no exceda los 950,000 galones por día de aguas residuales domésticas tratadas a través del desagüe 001.

Se espera que las descargas de la instalación contengan una demanda bioquímica de oxígeno carbonoso (CBOD5) de siete días, sólidos suspendidos totales (TSS), nitrógeno amoniacal (NH3-N) y Escherichia coli. En la sección 7 del Informe Técnico Nacional 1.0 se incluyen contaminantes potenciales adicionales. Análisis de Contaminantes de Efluentes Tratados en el paquete de solicitud de permisos. Las aguas residuales domésticas se tratan mediante una Fase I existente: La planta funciona como un proceso de tratamiento de aguas residuales con lodos activados para tratar las aguas residuales antes de su vertido en un arroyo. La Planta de Tratamiento incluye la extension Aireación: El efluente ingresa a través de una pantalla mecánica a una estación de bombeo y se eleva a una cuenca de aireación. MLSS fluye por

gravedad hacia el clarificador. Las bombas de lodos devuelven los lodos del clarificador a uncuenca de aireación o se desperdicia en lechos de lodos. El efluente claro del clarificador fluye por gravedad a los rayos UV para su desinfección, al canal de Parshall y luego a un punto de descarga. El lodo se transporta en camión desde la ciudad de Carrizo Springs hasta el vertedero municipal de la ciudad de Carrizo Springs en el condado de Dimmit.

La planta descarga aguas residuales tratadas a un volumen que no excede un flujo promedio anual de 950,000 galones por día. El efluente se descarga a través de una tubería de 20" al arroyo Carrizo; de allí al Soldier Slough; de allí al río Nueces por encima de la presa Holland en el segmento No. 2105 de la cuenca del río Nueces.

Agradezco su tiempo y esfuerzo en la revisión de mi resumen. Si tiene alguna pregunta, comuníquese conmigo al (713) 458-8612, o por correo electrónico a robin@permittingservices.net.

Atentamente,

Robin Butcho

Robin Butcko Senior Wastewater Consultant Permitting Services, LLC 713.458.8612

### Attachment 8 Supplemental Permit Information Form (SPIF)

### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

### FOR AGENCIES REVIEWING DOMESTIC TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:	
200 N 2 N N 1 N N 1 N 1 N 1 N 1 N 1 N 1 N 1	on Amondanas N
Application type:RenewalMajor AmendmentMin	
County: Segment Number Admin Complete Date:	T
Agency Receiving SPIF:	
	1 71773 33.0
Texas Historical Commission U.S. Fish a	,
Texas Parks and Wildlife Department U.S. Army	Corps of Engineers
This form applies to TPDES permit applications only. (Instructio	ns, Page 53)
The SPIF must be completed as a separate document. The TCEQ we each agency as required by the TCEQ agreement with EPA. If any caddressed or further information is needed, you will be contacted before the permit is issued. Each item must be completely addressed.	ill mail a copy of the SPIF to of the items are not completely to provide the information
Do not refer to a response of any item in the permit application be provided with this form separately from the administrative repapplication will not be declared administratively complete without its entirety including all attachments.	ort of the application. The
The following applies to all applications:	
1. Permittee: <u>City of Carrizo Springs</u>	
Permit No. WQ00 <u>10145001</u> EPA ID No. TX	X <u>0025976</u>
Address of the project (or a location description that includes and county):	
Located approximately 0.5 miles NE of the intersection of US I 85 in Carrizo Springs, Dimmit County, Texas 78834	Hwy. 83 and S.H85 and S.H
55 Hr Carries Springs, Dillining County, Texas 78634	W W

	answer specific questions about the property.
	Prefix (Mr., Ms., Miss): Mr.
	First and Last Name: Ramsey Castillo
	Credential (P.E, P.G., Ph.D., etc.):
	Title: Water Department Supervisor
	Mailing Address: PO Box 329
	City, State, Zip Code: Carrizo Springs, TX 78834
	Phone No.: <u>830-876-2476</u> Ext.: Fax No.:
	E-mail Address: <u>rcastillo@cityofcarrizo.org</u>
2.	List the county in which the facility is located: <u>Dimmit</u>
3.	If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.
	N/A
4.	
	of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify
	the classified segment number.
	Carrizo Creek; thence to Soldier Slough; thence to Nueces River above Holland Dam in
	segment No. 2105 of the Nueces River Basin
5.	Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report).
	Provide original photographs of any structures 50 years or older on the property.
	Does your project involve any of the following? Check all that apply.
	Proposed access roads, utility lines, construction easements
	☐ Visual effects that could damage or detract from a historic property's integrity
	☐ Vibration effects during construction or as a result of project design
	Additional phases of development that are planned for the future
	☐ Sealing caves, fractures, sinkholes, other karst features

5.

	<ul> <li>Disturbance of vegetation or wetlands</li> </ul>
6.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	N/A
7.	Describe existing disturbances, vegetation, and land use:
	N/A
TH AM	E FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR SENDMENTS TO TPDES PERMITS
8.	List construction dates of all buildings and structures on the property:
9.	Provide a brief history of the property, and name of the architect/builder, if known.
	N/A

### Francesca Findlay

From: Robin Butcko <robin@permittingservices.net>
Sent: Saturday, September 14, 2024 2:50 PM

**To:** Francesca Findlay

**Subject:** Re: WQ0010145001 City of Carrizo Springs

Attachments: Carrizo Springs Municipal Discharge Renewal Spanish NORI.docx; wq0010145001-

nod1.pdf

Importance: High

Dear Francesca,

I hope you are doing well. Please see the attached for the Translated NORI. The only thing I see that you might want to fix in the NORI is down below highlighted in yellow. 5<sup>th</sup> line at the end says located at located. This you might want to delete one of the located words. See below.

APPLICATION. City of Carrizo Springs, P.O. Box 329, Carrizo Springs, Texas 78834, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010145001 (EPA I.D. No. TX0025976) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 950,000 gallons per day. The domestic wastewater treatment facility is located at located approximately 0.5 mile northeast of the intersection of U.S. Highway 83 and State Highway 85, near the city of Carrizo Springs, in Dimmit County, Texas 78834. The discharge route is from the plant site to Carrizo Creek; thence to Soldier Slough; thence to Nueces River Above Holland Dam. TCEQ received this application on September 5, 2024. The permit application will be available for viewing and copying at Carrizo Springs City Hall, 308 Pena Street, Carrizo Springs, in Dimmit County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. This link to an electronic map of the site or facility's general location is provided as a public

I hope this helps and thank you for your time and effort in reviewing the NORI.

Regards, Robin

### Robin Butcko

**President & CEO** 6425 Bankside Drive Suite 2111 Houston, TX 77096

**\** 713-458-8612

robin@permittingservices.net www.permittingservices.net

From: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>

Sent: Thursday, September 12, 2024 3:14 PM

To: Robin Butcko <robin@permittingservices.net>

Cc: rcastillo@cityofcarrizo.org <rcastillo@cityofcarrizo.org>

Subject: FW: WQ0010145001 City of Carrizo Springs

Dear Ms. Butcko:

The attached Notice of Deficiency letter sent on September 12, 2024, requesting additional information needed to declare the application administratively complete. Please send the complete response to my attention September 26, 2024.

Thank you,

Francisco Finallar

Dan Sindley

Francesca Findlay License & Permit Specialist ARP Team | Water Quality Division 512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail