



Administrative Package Cover Page

This file contains the following documents:

1. Summary of application (in plain language)
 - English
 - Alternative Language (Spanish)
 2. First Notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
 - English
 - Alternative Language (Spanish)
 3. Application materials
-



Portada de Paquete Administrativo

Este archivo contiene los siguientes documentos:

1. Resumen en lenguaje sencillo (PLS, por sus siglas en inglés) de la actividad propuesta
 - Inglés
 - Idioma alternativo (español)
2. Primer aviso (NORI, por sus siglas en inglés)
 - Inglés
 - Idioma alternativo (español)
3. Solicitud original



PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by [Title 30, Texas Administrative Code \(30 TAC\), Chapter 39, Subchapter H](#). Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in [30 TAC Section 39.426](#), [you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package](#). For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

The City of Hillsboro ((CN600514228)) operates the City of Hillsboro Wastewater Treatment Plant (RN102844180), a wastewater treatment facility. The facility is located at 600 Parham Street, in Hillsboro, Hill County, Texas 76645. This application is for the renewal to discharge an annual average flow of 1,810,000 gallons per day (1.81 MGD) of treated domestic wastewater via Outfall 001..

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD5), total suspended solids (TSS), ammonia nitrogen (NH3-N) and Escherichia coli. Domestic wastewater is treated by an activated sludge process with nitrification and denitrification in an Oxidation Ditch.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

AGUAS RESIDUALES DOMESTICAS /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

La Ciudad de Hillsboro ((CN600514228)) opera la Planta de Tratamiento de Aguas Residuales de la Ciudad de Hillsboro (RN102844180), una instalación de tratamiento de aguas residuales. La instalación está ubicada en 600 Parham Street, en Hillsboro, Condado de Hill, Texas 76645. Esta solicitud es para la renovación para descargar un flujo promedio anual de 1,810,000 galones por día (1.81 MGD) de aguas residuales domésticas tratadas a través del Emisario 001..Este permiso no autorizará una descarga de contaminantes en el agua en el estado.

Se espera que las descargas de la instalación contengan demanda bioquímica de oxígeno carbonoso (CBOD5) de cinco días, sólidos suspendidos totales (SST), nitrógeno ammoniacal (NH3-N) y Escherichia coli. Las aguas residuales domésticas . estará tratado por un proceso de lodos activados con nitrificación en Zanja de Oxidación.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT RENEWAL

PERMIT NO. WQ0010630001

APPLICATION. City of Hillsboro, P.O. Box 568, Hillsboro, Texas 76645, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010630001 (EPA I.D. No. TX0023108) to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 1,810,000 gallons per day. The domestic wastewater treatment facility is located at 600 Parham Street, in the city of Hillsboro, in Hill County, Texas 76645. The discharge route is from the plant site to an unnamed drainage ditch; thence to Little Hackberry Creek; thence to Hackberry Creek; thence to Aquilla Reservoir. TCEQ received this application on August 23, 2024. The permit application will be available for viewing and copying at City of Hillsboro, City Government, 214 East Elm Street, Hillsboro, in Hill County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage:

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.141666,31.999444&level=18>

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at:

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

El aviso de idioma alternativo en español está disponible en

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. **Notice of the Application and Preliminary Decision will be published and mailed to those who are on the county-wide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.**

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public

interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. **Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing.** A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. **If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.**

TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at <https://www14.tceq.texas.gov/epic/eComment/>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from City of Hillsboro at the address stated above or by calling Ms. Susan Hilton, P.E., Project Manager/MRB Group, at 254-771-2054.

Issuance Date: September 16, 2024

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO. WQoo10630001

SOLICITUD. Ciudad de Hillsboro, PO Box 568, Hillsboro, TX 76645 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso No. WQoo10630001 (EPA I.D. No. TX 0023108) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 1,810,000 galones por día. La planta está ubicada 600 Parham Street, Hillsboro en el Condado de Hill, Texas. La ruta de descarga es del sitio de la planta a una zanja de drenaje sin nombre; luego a Little Hackberry Creek; luego a Hackberry Creek; luego al embalse Aquilla Reservoir. La TCEQ recibió esta solicitud el 23 de Agosto 2024. La solicitud para el permiso estará disponible para leerla y copiarla en la Ciudad de Hillsboro Gobierno de la ciudad, 214 East Elm Street, Hillsboro, en el condado de Hill, Texas antes de la fecha de publicación de este aviso en el periódico. La aplicación incluidas las actualizaciones y los avisos asociados están disponibles electrónicamente en la siguiente pagina web: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications> Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.141666,31.999444&level=18>

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. **El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.**

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso.** Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía <http://www14.tceq.texas.gov/epic/eComment> o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del la Ciudad de Hillsboro a la dirección indicada arriba o llamando Ms. Susan Hilton, P.E., Project Manager/MRB Group, at 254-771-2054.

Fecha de emission: 16 de septiembre de 2024



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

APPLICANT NAME: City of Hillsboro

PERMIT NUMBER (If new, leave blank): WQ00 10630001

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Original USGS Map	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Administrative Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Affected Landowners Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
SPIF	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Landowner Disk or Labels	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Core Data Form	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Buffer Zone Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Public Involvement Plan Form	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Flow Diagram	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site Drawing	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Original Photographs	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Design Calculations	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Solids Management Plan	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Water Balance	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.3	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 4.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
Worksheet 5.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 6.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
Worksheet 7.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			

For TCEQ Use Only

Segment Number _____ County _____
Expiration Date _____ Region _____
Permit Number _____



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

Section 1. Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
<0.05 MGD	\$350.00 <input type="checkbox"/>	\$315.00 <input type="checkbox"/>
≥0.05 but <0.10 MGD	\$550.00 <input type="checkbox"/>	\$515.00 <input type="checkbox"/>
≥0.10 but <0.25 MGD	\$850.00 <input type="checkbox"/>	\$815.00 <input type="checkbox"/>
≥0.25 but <0.50 MGD	\$1,250.00 <input type="checkbox"/>	\$1,215.00 <input type="checkbox"/>
≥0.50 but <1.0 MGD	\$1,650.00 <input type="checkbox"/>	\$1,615.00 <input type="checkbox"/>
≥1.0 MGD	\$2,050.00 <input type="checkbox"/>	\$2,015.00 <input checked="" type="checkbox"/>

Minor Amendment (for any flow) \$150.00

Payment Information:

Mailed Check/Money Order Number: Click to enter text.

Check/Money Order Amount: \$2015.00

Name Printed on Check: City of Hillsboro

EPAY Voucher Number: Click to enter text.

Copy of Payment Voucher enclosed? Yes

Section 2. Type of Application (Instructions Page 26)

a. Check the box next to the appropriate authorization type.

- Publicly-Owned Domestic Wastewater
- Privately-Owned Domestic Wastewater
- Conventional Wastewater Treatment

b. Check the box next to the appropriate facility status.

- Active
- Inactive

c. Check the box next to the appropriate permit type.

- TPDES Permit
- TLAP
- TPDES Permit with TLAP component
- Subsurface Area Drip Dispersal System (SADDS)

d. Check the box next to the appropriate application type

- | | |
|---|---|
| <input type="checkbox"/> New | <input type="checkbox"/> Minor Amendment <u>with</u> Renewal |
| <input type="checkbox"/> Major Amendment <u>with</u> Renewal | <input type="checkbox"/> Minor Amendment <u>without</u> Renewal |
| <input type="checkbox"/> Major Amendment <u>without</u> Renewal | <input type="checkbox"/> Minor Modification of permit |
| <input checked="" type="checkbox"/> Renewal without changes | |

e. For amendments or modifications, describe the proposed changes: N/A

f. For existing permits:

Permit Number: WQ00 10630001

EPA I.D. (TPDES only): TX 0023108

Expiration Date: 9/10/2024

Section 3. Facility Owner (Applicant) and Co-Applicant Information (Instructions Page 26)

A. The owner of the facility must apply for the permit.

What is the Legal Name of the entity (applicant) applying for this permit?

City of Hillsboro

(The legal name must be spelled exactly as filed with the Texas Secretary of State, County, or in the legal documents forming the entity.)

If the applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at <http://www15.tceq.texas.gov/crpub/>

CN: 600514228

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: Mr.

Last Name, First Name: Johnson, M. Scott

Title: Mayor

Credential:

B. Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the legal documents forming the entity.)

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: <http://www15.tceq.texas.gov/crpub/>

CN: Click to enter text.

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: Click to enter text.

Last Name, First Name: Click to enter text.

Title: Click to enter text.

Credential: Click to enter text.

Provide a brief description of the need for a co-permittee: Click to enter text.

C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. [Attachment A](#)

Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Ms. Last Name, First Name: Henderson, Megan

Title: City Manager Credential: Click to enter text.

Organization Name: City of Hillsboro

Mailing Address: P.O Box 568 City, State, Zip Code: Hillsboro, TX 76645

Phone No.: 254-582-3271 E-mail Address: mhenderson@hillsborotx.org

Check one or both: Administrative Contact Technical Contact

B. Prefix: Ms. Last Name, First Name: Hilton, Susan

Title: Project Manager Credential: P.E.

Organization Name: MRB Group

Mailing Address: 303 W. Calhoun Ave. City, State, Zip Code: Temple, TX 76501

Phone No.: 254-771-2054 E-mail Address: susan.hilton@mrbgroup.com

Check one or both: Administrative Contact Technical Contact

Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Ms. Last Name, First Name: Hilton, Susan

Title: Project Manager Credential: P.E.

Organization Name: MRB Group

Mailing Address: 303 W. Calhoun Ave. City, State, Zip Code: Temple, TX 76501

Phone No.: 254-771-2054 E-mail Address: susan.hilton@mrbgroup.com

B. Prefix: Ms. Last Name, First Name: Henderson, Megan
Title: City Manager Credential: Click to enter text.
Organization Name: City of Hillsboro
Mailing Address: P.O Box 568 City, State, Zip Code: Hillsboro, TX 76645
Phone No.: 254-582-3271 E-mail Address: mhenderson@hillsborotx.org

Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits ***in effect on September 1 of each year***. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Ms. Last Name, First Name: Henderson, Megan
Title: City Manager Credential: Click to enter text.
Organization Name: City of Hillsboro
Mailing Address: P.O Box 568 City, State, Zip Code: Temple, TX 76645
Phone No.: 254-582-3271 E-mail Address: mhenderson@hillsborotx.org

Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Mr. Last Name, First Name: Dieterich, Terry
Title: Plant Superintendent Credential: Click to enter text.
Organization Name: City of Hillsboro
Mailing Address: P.O Box 568 City, State, Zip Code: Hillsboro, TX 76645
Phone No.: 254-582-3838 E-mail Address: tdieterich@hillsborotx.org

Section 8. Public Notice Information (Instructions Page 27)

A. Individual Publishing the Notices

Prefix: Ms. Last Name, First Name: Hilton, Susan
Title: Project Manager Credential: P.E.
Organization Name: MRB Group
Mailing Address: 303 W. Calhoun Avenue City, State, Zip Code: Temple, TX 76501
Phone No.: 254-771-2054 E-mail Address: susan.hilton@mrbgroup.com

B. Method for Receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package

Indicate by a check mark the preferred method for receiving the first notice and instructions:

- E-mail Address
 Fax
 Regular Mail

C. Contact permit to be listed in the Notices

Prefix: Ms. Last Name, First Name: Hilton, Susan

Title: Project Manager Credential: P.E.

Organization Name: MRB Group

Mailing Address: 303 W. Calhoun Avenue City, State, Zip Code: Temple, TX 76501

Phone No.: 254-771-2054 E-mail Address: susan.hilton@mrbgroup.com

D. Public Viewing Information

If the facility or outfall is located in more than one county, a public viewing place for each county must be provided.

Public building name: City of Hillsboro

Location within the building: Administrative Offices

Physical Address of Building: 214 E. Elm St.

City: Hillsboro County: Hill

Contact (Last Name, First Name): Henderson, Megan

Phone No.: 254-582-3271 Ext.: Click to enter text.

E. Bilingual Notice Requirements

This information is required for new, major amendment, minor amendment or minor modification, and renewal applications.

This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.

Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.

1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?

- Yes No

If no, publication of an alternative language notice is not required; skip to Section 9 below.

2. Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?

- Yes No

3. Do the students at these schools attend a bilingual education program at another location?

Yes No

4. Would the school be required to provide a bilingual education program but the school has waived out of this requirement under 19 TAC §89.1205(g)?

Yes No

5. If the answer is **yes** to **question 1, 2, 3, or 4**, public notices in an alternative language are required. Which language is required by the bilingual program? Spanish

F. Plain Language Summary Template

Complete the Plain Language Summary (TCEQ Form 20972) and include as an attachment.

Attachment: B

G. Public Involvement Plan Form

Complete the Public Involvement Plan Form (TCEQ Form 20960) for each application for a new permit or major amendment to a permit and include as an attachment.

Attachment: N/A

Section 9. Regulated Entity and Permitted Site Information (Instructions Page 29)

- A. If the site is currently regulated by TCEQ, provide the Regulated Entity Number (RN) issued to this site. RN 102844180

Search the TCEQ's Central Registry at <http://www15.tceq.texas.gov/crpublish/> to determine if the site is currently regulated by TCEQ.

- B. Name of project or site (the name known by the community where located):

City of Hillsboro Wastewater Treatment Facility

- C. Owner of treatment facility: City of Hillsboro

Ownership of Facility: Public Private Both Federal

- D. Owner of land where treatment facility is or will be:

Prefix: Click to enter text. Last Name, First Name: Click to enter text.

Title: Click to enter text. Credential: Click to enter text.

Organization Name: City of Hillsboro

Mailing Address: P.O Box 568 City, State, Zip Code: Hillsboro, TX 76645

Phone No.: 254-582-3271 E-mail Address: mhenderson@hillsborotx.org

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: N/A

E. Owner of effluent disposal site:

Prefix: [Click to enter text.](#)

Last Name, First Name: [Click to enter text.](#)

Title: [Click to enter text.](#)

Credential: [Click to enter text.](#)

Organization Name: [Click to enter text.](#)

Mailing Address: [Click to enter text.](#)

City, State, Zip Code: [Click to enter text.](#)

Phone No.: [Click to enter text.](#)

E-mail Address: [Click to enter text.](#)

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: [N/A](#)

F. Owner sewage sludge disposal site (if authorization is requested for sludge disposal on property owned or controlled by the applicant)::

Prefix: [Click to enter text.](#)

Last Name, First Name: [Click to enter text.](#)

Title: [Click to enter text.](#)

Credential: [Click to enter text.](#)

Organization Name: [Click to enter text.](#)

Mailing Address: [Click to enter text.](#)

City, State, Zip Code: [Click to enter text.](#)

Phone No.: [Click to enter text.](#)

E-mail Address: [Click to enter text.](#)

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: [N/A](#)

Section 10. TPDES Discharge Information (Instructions Page 31)

A. Is the wastewater treatment facility location in the existing permit accurate?

Yes No

If **no, or a new permit application**, please give an accurate description:

[Click to enter text.](#)

B. Are the point(s) of discharge and the discharge route(s) in the existing permit correct?

Yes No

If **no, or a new or amendment permit application**, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307:

[Click to enter text.](#)

City nearest the outfall(s): [Hillsboro](#)

County in which the outfalls(s) is/are located: [Hill](#)

C. Is or will the treated wastewater discharge to a city, county, or state highway right-of-way, or a flood control district drainage ditch?

Yes No

If yes, indicate by a check mark if:

- Authorization granted Authorization pending

For **new and amendment** applications, provide copies of letters that show proof of contact and the approval letter upon receipt.

Attachment: N/A

- D. For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: N/A

Section 11. TLAP Disposal Information (Instructions Page 32)

- A. For TLAPs, is the location of the effluent disposal site in the existing permit accurate?

- Yes No

If no, or a new or amendment permit application, provide an accurate description of the disposal site location:

Click to enter text.

- B. City nearest the disposal site:

- C. County in which the disposal site is located:

- D. For TLAPs, describe the routing of effluent from the treatment facility to the disposal site:

Click to enter text.

- E. For TLAPs, please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: Click to enter text.

Section 12. Miscellaneous Information (Instructions Page 32)

- A. Is the facility located on or does the treated effluent cross American Indian Land?

- Yes No

- B. If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?

- Yes No Not Applicable

If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.

Click to enter text.

C. Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?

Yes No

If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application: [Click to enter text.](#)

D. Do you owe any fees to the TCEQ?

Yes No

If yes, provide the following information:

Account number: [Click to enter text.](#)

Amount past due: [Click to enter text.](#)

E. Do you owe any penalties to the TCEQ?

Yes No

If yes, please provide the following information:

Enforcement order number: [Click to enter text.](#)

Amount past due: [Click to enter text.](#)

Section 13. Attachments (Instructions Page 33)

Indicate which attachments are included with the Administrative Report. Check all that apply:

- Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.
- Original full-size USGS Topographic Map with the following information:
- Applicant's property boundary
 - Treatment facility boundary
 - Labeled point of discharge for each discharge point (TPDES only)
 - Highlighted discharge route for each discharge point (TPDES only)
 - Onsite sewage sludge disposal site (if applicable)
 - Effluent disposal site boundaries (TLAP only)
 - New and future construction (if applicable)
 - 1 mile radius information
 - 3 miles downstream information (TPDES only)
 - All ponds.
- Attachment 1 for Individuals as co-applicants
- Other Attachments. Please specify: [Core Data Form](#)

Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQoo10630001

Applicant: City of Hillsboro

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): M. Scott Johnson

Signatory title: Mayor

Signature: _____ Date: _____

(Use blue ink)

Subscribed and Sworn to before me by the said

on this _____ day of _____, 20_____.

My commission expires on the _____ day of _____, 20____.

Notary Public

[SEAL]

County, Texas

DOMESTIC WASTEWATER PERMIT APPLICATION

SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: D

WATER QUALITY PERMIT

PAYMENT SUBMITTAL FORM

Use this form to submit the Application Fee, if the mailing the payment.

- Complete items 1 through 5 below.
- Staple the check or money order in the space provided at the bottom of this document.
- **Do Not mail this form with the application form.**
- Do not mail this form to the same address as the application.
- Do not submit a copy of the application with this form as it could cause duplicate permit entries.

Mail this form and the check or money order to:

BY REGULAR U.S. MAIL

Texas Commission on Environmental Quality
Financial Administration Division
Cashier's Office, MC-214
P.O. Box 13088
Austin, Texas 78711-3088

BY OVERNIGHT/EXPRESS MAIL

Texas Commission on Environmental Quality
Financial Administration Division
Cashier's Office, MC-214
12100 Park 35 Circle
Austin, Texas 78753

Fee Code: WQP Waste Permit No: WQ0010630001

1. Check or Money Order Number:
2. Check or Money Order Amount:
3. Date of Check or Money Order:
4. Name on Check or Money Order: City of Hillsboro
5. APPLICATION INFORMATION

Name of Project or Site: City of Hillsboro Wastewater Treatment Facility

Physical Address of Project or Site: 600 Parham Street, Hillsboro, TX 76645

If the check is for more than one application, attach a list which includes the name of each Project or Site (RE) and Physical Address, exactly as provided on the application.

Staple Check or Money Order in This Space

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

Core Data Form (TCEQ Form No. 10400) Yes

(Required for all application types. Must be completed in its entirety and signed.)

Note: Form may be signed by applicant representative.)

Correct and Current Industrial Wastewater Permit Application Forms Yes

(TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018 or later.)

Water Quality Permit Payment Submittal Form (Page 19) Yes

(Original payment sent to TCEQ Revenue Section. See instructions for mailing address.)

7.5 Minute USGS Quadrangle Topographic Map Attached Yes

(Full-size map if seeking "New" permit.

8 ½ x 11 acceptable for Renewals and Amendments)

Current/Non-Expired, Executed Lease Agreement or Easement N/A Yes

Landowners Map N/A Yes

(See instructions for landowner requirements)

Things to Know:

- All the items shown on the map must be labeled.
- The applicant's complete property boundaries must be delineated which includes boundaries of contiguous property owned by the applicant.
- The applicant cannot be its own adjacent landowner. You must identify the landowners immediately adjacent to their property, regardless of how far they are from the actual facility.
- If the applicant's property is adjacent to a road, creek, or stream, the landowners on the opposite side must be identified. Although the properties are not adjacent to applicant's property boundary, they are considered potentially affected landowners. If the adjacent road is a divided highway as identified on the USGS topographic map, the applicant does not have to identify the landowners on the opposite side of the highway.

Landowners Cross Reference List N/A Yes

(See instructions for landowner requirements)

Landowners Labels or USB Drive attached N/A Yes

(See instructions for landowner requirements)

Original signature per 30 TAC § 305.44 – Blue Ink Preferred Yes

(If signature page is not signed by an elected official or principle executive officer, a copy of signature authority/delegation letter must be attached)

Plain Language Summary Yes



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

Section 1. Permitted or Proposed Flows (Instructions Page 43)

A. Existing/Interim I Phase

Design Flow (MGD): [Click to enter text.](#)

2-Hr Peak Flow (MGD): [Click to enter text.](#)

Estimated construction start date: [Click to enter text.](#)

Estimated waste disposal start date: [Click to enter text.](#)

B. Interim II Phase

Design Flow (MGD): [Click to enter text.](#)

2-Hr Peak Flow (MGD): [Click to enter text.](#)

Estimated construction start date: [Click to enter text.](#)

Estimated waste disposal start date: [Click to enter text.](#)

C. Final Phase

Design Flow (MGD): 1.81

2-Hr Peak Flow (MGD): 5.29

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

D. Current Operating Phase

Provide the startup date of the facility: 10/01/2004

Section 2. Treatment Process (Instructions Page 43)

A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. **If more than one phase exists or is proposed, a description of each phase must be provided.**

Type: Activated Sludge with nitrification-denitrification – Oxidation Ditch Treatment Units
Include: Bar Screen, Grit Removal, Oxidation Ditch, Clarifier, Chlorination, De-chlorination, Sludge Aeration

B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all phases of operation*.

Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Mechanical Fine Screen	1	2.5'x2'x5'
Manual Bar Screen	1	2.5'x2'x5'
Grit Chamber	1	12'x12'
Oxidation Ditch	3	6'x11'x550'
Clarifiers	2	65' diameter x 12' depth
Chlorine Contact Unit	2	9'x22.5'x45'
De-chlorination Chamber	1	8'x5.3'x19.3'
Aerated Sludge Basin	1	12'x36'x36'

C. Process Flow Diagram

Provide flow diagrams for the existing facilities and **each** proposed phase of construction.

Attachment: [E](#)

Section 3. Site Information and Drawing (Instructions Page 44)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

- Latitude: 31.999458
- Longitude: -97.141708

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

- Latitude: Click to enter text.
- Longitude: Click to enter text.

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and

- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment: F

Provide the name **and** a description of the area served by the treatment facility.

City of Hillsboro

Collection System Information for wastewater TPDES permits only: Provide information for each **uniquely owned** collection system, existing and new, served by this facility, including satellite collection systems. Please see the instructions for a detailed explanation and examples.

Collection System Information

Collection System Name	Owner Name	Owner Type	Population Served
City of Hillsboro	City of Hillsboro	Publicly Owned	8,550
		Choose an item.	
		Choose an item.	
		Choose an item.	

Section 4. Unbuilt Phases (Instructions Page 45)

Is the application for a renewal of a permit that contains an unbuilt phase or phases?

Yes No

If yes, does the existing permit contain a phase that has not been constructed **within five years** of being authorized by the TCEQ?

Yes No

If yes, provide a detailed discussion regarding the continued need for the unbuilt phase. **Failure to provide sufficient justification may result in the Executive Director recommending denial of the unbuilt phase or phases.**

Click to enter text.

Section 5. Closure Plans (Instructions Page 45)

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

- Yes No

If yes, was a closure plan submitted to the TCEQ?

- Yes No

If yes, provide a brief description of the closure and the date of plan approval.

Click to enter text.

Section 6. Permit Specific Requirements (Instructions Page 45)

For applicants with an existing permit, check the Other Requirements or Special Provisions of the permit.

A. Summary transmittal

Have plans and specifications been approved for the existing facilities and each proposed phase?

- Yes No

If yes, provide the date(s) of approval for each phase: 12/01/1998

Provide information, including dates, on any actions taken to meet a *requirement or provision* pertaining to the submission of a summary transmittal letter. **Provide a copy of an approval letter from the TCEQ, if applicable.**

Click to enter text.

B. Buffer zones

Have the buffer zone requirements been met?

- Yes No

Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.

Click to enter text.

C. Other actions required by the current permit

Does the *Other Requirements* or *Special Provisions* section in the existing permit require submission of any other information or other required actions? Examples include Notification of Completion, progress reports, soil monitoring data, etc.

Yes No

If yes, provide information below on the status of any actions taken to meet the conditions of an *Other Requirement* or *Special Provision*.

Click to enter text.

D. Grit and grease treatment

1. Acceptance of grit and grease waste

Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?

Yes No

If No, stop here and continue with Subsection E. Stormwater Management.

2. Grit and grease processing

Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.

Click to enter text.

3. Grit disposal

Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?

Yes No

If No, contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

Describe the method of grit disposal.

Click to enter text.

4. ***Grease and decanted liquid disposal***

Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.

Describe how the decant and grease are treated and disposed of after grit separation.

Click to enter text.

E. Stormwater management

1. ***Applicability***

Does the facility have a design flow of 1.0 MGD or greater in any phase?

Yes No

Does the facility have an approved pretreatment program, under 40 CFR Part 403?

Yes No

If no to both of the above, then skip to Subsection F, Other Wastes Received.

2. ***MSGP coverage***

Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?

Yes No

If yes, please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:

TXR05 [Click to enter text.](#) or TXRNE [Click to enter text.](#)

If no, do you intend to seek coverage under TXR050000?

Yes No

3. Conditional exclusion

Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?

Yes No

If yes, please explain below then proceed to Subsection F, Other Wastes Received:

Click to enter text.

4. Existing coverage in individual permit

Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?

Yes No

If yes, provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.

Click to enter text.

5. Zero stormwater discharge

Do you intend to have no discharge of stormwater via use of evaporation or other means?

Yes No

If yes, explain below then skip to Subsection F, Other Wastes Received.

Click to enter text.

Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.

6. Request for coverage in individual permit

Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?

Yes No

If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you intend to divert stormwater to the treatment plant headworks and indirectly discharge it to water in the state.

[Click to enter text.](#)

Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.

F. Discharges to the Lake Houston Watershed

Does the facility discharge in the Lake Houston watershed?

Yes No

If yes, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions.
[Click to enter text.](#)

G. Other wastes received including sludge from other WWTPs and septic waste

1. Acceptance of sludge from other WWTPs

Does or will the facility accept sludge from other treatment plants at the facility site?

Yes No

If yes, attach sewage sludge solids management plan. See Example 5 of instructions.

In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an estimate of the BOD₅ concentration of the sludge, and the design BOD₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

[Click to enter text.](#)

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

2. Acceptance of septic waste

Is the facility accepting or will it accept septic waste?

Yes No

If yes, does the facility have a Type V processing unit?

Yes No

If yes, does the unit have a Municipal Solid Waste permit?

Yes No

If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD₅ concentration of the septic waste, and the design BOD₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

Click to enter text.

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

3. Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)

Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?

Yes No

If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.

Click to enter text.

Section 7. Pollutant Analysis of Treated Effluent (Instructions Page 50)

Is the facility in operation?

Yes No

If no, this section is not applicable. Proceed to Section 8.

If yes, provide effluent analysis data for the listed pollutants. **Wastewater treatment facilities** complete Table 1.0(2). **Water treatment facilities** discharging filter backwash water, complete Table 1.0(3). Provide copies of the laboratory results sheets. **These tables are not applicable for a minor amendment without renewal.** See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) – Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD ₅ , mg/l	3.0	3.0	1	Grab	3/12/2024 10:00am
Total Suspended Solids, mg/l	11	11	1	Grab	3/12/2024 10:00am
Ammonia Nitrogen, mg/l	2.23	2.23	1	Grab	3/12/2024 10:00am
Nitrate Nitrogen, mg/l	2.75	2.75	1	Grab	3/12/2024 10:00am
Total Kjeldahl Nitrogen, mg/l	5.00	5.00	1	Grab	3/12/2024 10:00am
Sulfate, mg/l	129	129	1	Grab	3/12/2024 10:00am
Chloride, mg/l	71.9	71.9	1	Grab	3/12/2024 10:00am
Total Phosphorus, mg/l	<0.40	<0.40	1	Grab	3/12/2024 10:00am
pH, standard units	6.8	6.8	1	Grab	3/12/2024 10:00am
Dissolved Oxygen*, mg/l	6.1	6.1	1	Grab	3/12/2024 10:00am
Chlorine Residual, mg/l					
E.coli (CFU/100ml) freshwater	125	125	1	Grab	3/12/2024 10:00am
Enterococci (CFU/100ml) saltwater					
Total Dissolved Solids, mg/l	470	470	1	Grab	3/12/2024 10:00am
Electrical Conductivity, $\mu\text{mhos}/\text{cm}$, †	763	763	1	Grab	3/12/2024 10:00am
Oil & Grease, mg/l	<5.0	<5.0	1	Grab	3/12/2024 10:00am
Alkalinity (CaCO_3)*, mg/l	133	133	1	Grab	3/12/2024 10:00am

*TPDES permits only

†TLAP permits only

~~Table 1.0(3) – Pollutant Analysis for Water Treatment Facilities~~

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l					
Total Dissolved Solids, mg/l					
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO ₃), mg/l					

Section 8. Facility Operator (Instructions Page 50)

Facility Operator Name: Terry Dieterich

Facility Operator's License Classification and Level: Wastewater Treatment Class B

Facility Operator's License Number: WW0014896

Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 51)

A. WWTP's Biosolids Management Facility Type

Check all that apply. See instructions for guidance

- Design flow >= 1 MGD
- Serves >= 10,000 people
- Class I Sludge Management Facility (per 40 CFR § 503.9)
- Biosolids generator
- Biosolids end user - land application (onsite)
- Biosolids end user - surface disposal (onsite)
- Biosolids end user - incinerator (onsite)

B. WWTP's Biosolids Treatment Process

Check all that apply. See instructions for guidance.

- Aerobic Digestion
- Air Drying (or sludge drying beds)
- Lower Temperature Composting
- Lime Stabilization
- Higher Temperature Composting
- Heat Drying
- Thermophilic Aerobic Digestion
- Beta Ray Irradiation

- Gamma Ray Irradiation
- Pasteurization
- Preliminary Operation (e.g. grinding, de-gritting, blending)
- Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)
- Sludge Lagoon
- Temporary Storage (< 2 years)
- Long Term Storage (>= 2 years)
- Methane or Biogas Recovery
- Other Treatment Process: [Click to enter text.](#)

C. Biosolids Management

Provide information on the *intended* biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the permit will authorize all biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

Biosolids Management

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Disposal in Landfill	Off-site Third-Party Handler or Preparer	Bulk		Class B: PSRP Aerobic Digestion	Option 7: Stabilized sludge is >=75% solids
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.

If “Other” is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): [Click to enter text.](#)

D. Disposal site

Disposal site name: [Itasca Landfill](#)

TCEQ permit or registration number: [RN100213412](#)

County where disposal site is located: [Hill](#)

E. Transportation method

Method of transportation (truck, train, pipe, other): [Roll-Off Containers](#)

Name of the hauler: [Allied Waste Services of Itasca, Republic Services of Itasca](#)

Hauler registration number: [RN106873326](#)

Sludge is transported as a:

Liquid

semi-liquid

semi-solid

solid

Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 53)

A. Beneficial use authorization

Does the existing permit include authorization for land application of sewage sludge for beneficial use?

Yes No

If yes, are you requesting to continue this authorization to land apply sewage sludge for beneficial use?

Yes No

If yes, is the completed **Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451)** attached to this permit application (see the instructions for details)?

Yes No

B. Sludge processing authorization

Does the existing permit include authorization for any of the following sludge processing, storage or disposal options?

Sludge Composting Yes No

Marketing and Distribution of sludge Yes No

Sludge Surface Disposal or Sludge Monofill Yes No

Temporary storage in sludge lagoons Yes No

If yes to any of the above sludge options and the applicant is requesting to continue this authorization, is the completed **Domestic Wastewater Permit Application: Sewage Sludge Technical Report (TCEQ Form No. 10056)** attached to this permit application?

Yes No

Section 11. Sewage Sludge Lagoons (Instructions Page 53)

Does this facility include sewage sludge lagoons?

Yes No

If yes, complete the remainder of this section. If no, proceed to Section 12.

A. Location information

The following maps are required to be submitted as part of the application. For each map, provide the Attachment Number.

- Original General Highway (County) Map:

Attachment: [Click to enter text.](#)

- USDA Natural Resources Conservation Service Soil Map:

Attachment: [Click to enter text.](#)

- Federal Emergency Management Map:

Attachment: [Click to enter text.](#)

- Site map:

Attachment: [Click to enter text.](#)

Discuss in a description if any of the following exist within the lagoon area. Check all that apply.

- Overlap a designated 100-year frequency flood plain
- Soils with flooding classification
- Overlap an unstable area
- Wetlands
- Located less than 60 meters from a fault
- None of the above

Attachment: [Click to enter text.](#)

If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide the protective measures to be utilized including type and size of protective structures:

[Click to enter text.](#)

B. Temporary storage information

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in *Section 7 of Technical Report 1.0*.

Nitrate Nitrogen, mg/kg: [Click to enter text.](#)

Total Kjeldahl Nitrogen, mg/kg: [Click to enter text.](#)

Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: [Click to enter text.](#)

Phosphorus, mg/kg: [Click to enter text.](#)

Potassium, mg/kg: [Click to enter text.](#)

pH, standard units: [Click to enter text.](#)

Ammonia Nitrogen mg/kg: [Click to enter text.](#)

Arsenic: [Click to enter text.](#)

Cadmium: [Click to enter text.](#)

Chromium: [Click to enter text.](#)

Copper: [Click to enter text.](#)

Lead: [Click to enter text.](#)

Mercury: [Click to enter text.](#)

Molybdenum: [Click to enter text.](#)

Nickel: [Click to enter text.](#)

Selenium: [Click to enter text.](#)

Zinc: [Click to enter text.](#)

Total PCBs: [Click to enter text.](#)

Provide the following information:

Volume and frequency of sludge to the lagoon(s): [Click to enter text.](#)

Total dry tons stored in the lagoons(s) per 365-day period: [Click to enter text.](#)

Total dry tons stored in the lagoons(s) over the life of the unit: [Click to enter text.](#)

C. Liner information

Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of 1×10^{-7} cm/sec?

Yes No

If yes, describe the liner below. Please note that a liner is required.

[Click to enter text.](#)

D. Site development plan

Provide a detailed description of the methods used to deposit sludge in the lagoon(s):

[Click to enter text.](#)

Attach the following documents to the application.

- Plan view and cross-section of the sludge lagoon(s)
Attachment: [Click to enter text.](#)
- Copy of the closure plan
Attachment: [Click to enter text.](#)
- Copy of deed recordation for the site
Attachment: [Click to enter text.](#)
- Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons
Attachment: [Click to enter text.](#)
- Description of the method of controlling infiltration of groundwater and surface water from entering the site
Attachment: [Click to enter text.](#)

- Procedures to prevent the occurrence of nuisance conditions

Attachment: [Click to enter text.](#)

E. Groundwater monitoring

Is groundwater monitoring currently conducted at this site, or are any wells available for groundwater monitoring, or are groundwater monitoring data otherwise available for the sludge lagoon(s)?

Yes No

If groundwater monitoring data are available, provide a copy. Provide a profile of soil types encountered down to the groundwater table and the depth to the shallowest groundwater as a separate attachment.

Attachment: [Click to enter text.](#)

Section 12. Authorizations/Compliance/Enforcement (Instructions

Page 55)

A. Additional authorizations

Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?

Yes No

If yes, provide the TCEQ authorization number and description of the authorization:

[Click to enter text.](#)

B. Permittee enforcement status

Is the permittee currently under enforcement for this facility?

Yes No

Is the permittee required to meet an implementation schedule for compliance or enforcement?

Yes No

If yes to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:

Click to enter text.

Section 13. RCRA/CERCLA Wastes (Instructions Page 55)

A. RCRA hazardous wastes

Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

Yes No

B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

Yes No

C. Details about wastes received

If yes to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: N/A

Section 14. Laboratory Accreditation (Instructions Page 56)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - periodically inspected by the TCEQ; or
 - located in another state and is accredited or inspected by that state; or
 - performing work for another company with a unit located in the same site; or
 - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*.

Printed Name: Megan Henderson

Title: City Manager

Signature: _____

Date: _____

DOMESTIC WASTEWATER PERMIT APPLICATION

WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

Section 1. Domestic Drinking Water Supply (Instructions Page 64)

Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?

Yes No

If no, proceed to Section 2. If yes, provide the following:

Owner of the drinking water supply: [Click to enter text.](#)

Distance and direction to the intake: [Click to enter text.](#)

Attach a USGS map that identifies the location of the intake.

Attachment: [Click to enter text.](#)

Section 2. Discharge into Tidally Affected Waters (Instructions Page 64)

Does the facility discharge into tidally affected waters?

Yes No

If no, proceed to Section 3. If yes, complete the remainder of this section. If no, proceed to Section 3.

A. Receiving water outfall

Width of the receiving water at the outfall, in feet: [Click to enter text.](#)

B. Oyster waters

Are there oyster waters in the vicinity of the discharge?

Yes No

If yes, provide the distance and direction from outfall(s).

[Click to enter text.](#)

C. Sea grasses

Are there any sea grasses within the vicinity of the point of discharge?

Yes No

If yes, provide the distance and direction from the outfall(s).

[Click to enter text.](#)

Section 3. Classified Segments (Instructions Page 64)

Is the discharge directly into (or within 300 feet of) a classified segment?

- Yes No

If yes, this Worksheet is complete.

If no, complete Sections 4 and 5 of this Worksheet.

Section 4. Description of Immediate Receiving Waters (Instructions Page 65)

Name of the immediate receiving waters: Unnamed Tributary of Cobb Creek

A. Receiving water type

Identify the appropriate description of the receiving waters.

- Stream
 Freshwater Swamp or Marsh
 Lake or Pond

Surface area, in acres: [Click to enter text.](#)

Average depth of the entire water body, in feet: [Click to enter text.](#)

Average depth of water body within a 500-foot radius of discharge point, in feet:
[Click to enter text.](#)

- Man-made Channel or Ditch
 Open Bay
 Tidal Stream, Bayou, or Marsh
 Other, specify: [Click to enter text.](#)

B. Flow characteristics

If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area *upstream* of the discharge. For new discharges, characterize the area *downstream* of the discharge (check one).

- Intermittent - dry for at least one week during most years
 Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses
 Perennial - normally flowing

Check the method used to characterize the area upstream (or downstream for new dischargers).

- USGS flow records
 Historical observation by adjacent landowners
 Personal observation
 Other, specify: [Click to enter text.](#)

C. Downstream perennial confluences

List the names of all perennial streams that join the receiving water within three miles downstream of the discharge point.

None

D. Downstream characteristics

Do the receiving water characteristics change within three miles downstream of the discharge (e.g., natural or man-made dams, ponds, reservoirs, etc.)?

Yes No

If yes, discuss how.

Click to enter text.

E. Normal dry weather characteristics

Provide general observations of the water body during normal dry weather conditions.

Water body dry other than effluent discharge from the water treatment plant

Date and time of observation: 02/25/2013 1:00 pm

Was the water body influenced by stormwater runoff during observations?

Yes No

Section 5. General Characteristics of the Waterbody (Instructions Page 66)

A. Upstream influences

Is the immediate receiving water upstream of the discharge or proposed discharge site influenced by any of the following? Check all that apply.

- | | |
|---|---|
| <input type="checkbox"/> Oil field activities | <input type="checkbox"/> Urban runoff |
| <input type="checkbox"/> Upstream discharges | <input checked="" type="checkbox"/> Agricultural runoff |
| <input type="checkbox"/> Septic tanks | <input type="checkbox"/> Other(s), specify: <u>Click to enter text.</u> |

B. Waterbody uses

Observed or evidences of the following uses. Check all that apply.

- | | |
|---|--|
| <input type="checkbox"/> Livestock watering | <input type="checkbox"/> Contact recreation |
| <input type="checkbox"/> Irrigation withdrawal | <input type="checkbox"/> Non-contact recreation |
| <input type="checkbox"/> Fishing | <input type="checkbox"/> Navigation |
| <input checked="" type="checkbox"/> Domestic water supply | <input type="checkbox"/> Industrial water supply |
| <input type="checkbox"/> Park activities | <input type="checkbox"/> Other(s), specify: Click to enter text. |

C. Waterbody aesthetics

Check one of the following that best describes the aesthetics of the receiving water and the surrounding area.

- Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional
- Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored
- Common Setting: not offensive; developed but uncluttered; water may be colored or turbid
- Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored

DOMESTIC WASTEWATER PERMIT APPLICATION

WORKSHEET 4.0: POLLUTANT ANALYSIS REQUIREMENTS

The following **is required** for facilities with a permitted or proposed flow of **1.0 MGD or greater**, facilities with an approved **pretreatment** program, or facilities classified as a **major facility**. See instructions for further details.

This worksheet is not required minor amendments without renewal.

Section 1. Toxic Pollutants (Instructions Page 78)

For pollutants identified in Table 4.0(1), indicate the type of sample.

Grab

Composite

Date and time sample(s) collected: 3/12/2024 10:00am

Table 4.0(1) – Toxics Analysis

Pollutant	AVG Effluent Conc. ($\mu\text{g/l}$)	MAX Effluent Conc. ($\mu\text{g/l}$)	Number of Samples	MAL ($\mu\text{g/l}$)
Acrylonitrile	<50	<50	1	50
Aldrin	<0.002	<0.002	1	0.01
Aluminum	0.0892	0.0892	1	2.5
Anthracene	<10	<10	1	10
Antimony	0.0009	0.0009	1	5
Arsenic	0.0010	0.0010	1	0.5
Barium	0.0489	0.0489	1	3
Benzene	<10	<10	1	10
Benzidine	<50	<50	1	50
Benzo(a)anthracene	<5	<5	1	5
Benzo(a)pyrene	<5	<5	1	5
Bis(2-chloroethyl)ether	<10	<10	1	10
Bis(2-ethylhexyl)phthalate	<10	<10	1	10
Bromodichloromethane	<10	<10	1	10
Bromoform	<10	<10	1	10
Cadmium	<0.0005	<0.0005	1	1
Carbon Tetrachloride	<2	<2	1	2
Carbaryl	<5	<5	1	5
Chlordane*	<0.103	<0.103	1	0.2
Chlorobenzene	<10	<10	1	10
Chlorodibromomethane	<10	<10	1	10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Chloroform	<10	<10	1	10
Chlorpyrifos	<0.05	<0.05	1	0.05
Chromium (Total)	0.0005	0.0005	1	3
Chromium (Tri) (*1)	<0.0005	<0.0005	1	N/A
Chromium (Hex)	<0.003	<0.003	1	3
Copper	0.0075	0.0075	1	2
Chrysene	<5	<5	1	5
p-Chloro-m-Cresol	<10	<10	1	10
4,6-Dinitro-o-Cresol	<50	<50	1	50
p-Cresol	<10	<10	1	10
Cyanide (*2)	<0.005	<0.005	1	10
4,4'- DDD	<0.02	<0.02	1	0.1
4,4'- DDE	<0.02	<0.02	1	0.1
4,4'- DDT	<0.004	<0.004	1	0.02
2,4-D	<0.20	<0.20	1	0.7
Demeton (O and S)	<0.0509	<0.0509	1	0.20
Diazinon	<0.0509	<0.0509	1	0.5/0.1
1,2-Dibromoethane	<10	<10	1	10
m-Dichlorobenzene	<10	<10	1	10
o-Dichlorobenzene	<10	<10	1	10
p-Dichlorobenzene	<10	<10	1	10
3,3'-Dichlorobenzidine	<5	<5	1	5
1,2-Dichloroethane	<10	<10	1	10
1,1-Dichloroethylene	<10	<10	1	10
Dichloromethane				20
1,2-Dichloropropane	<10	<10	1	10
1,3-Dichloropropene	<5	<5	1	10
Dicofol	<0.20	<0.20	1	1
Dieldrin	<0.004	<0.004	1	0.02
2,4-Dimethylphenol	<10	<10	1	10
Di-n-Butyl Phthalate	<10	<10	1	10
Diuron	<0.09	<0.09	1	0.09
Endosulfan I (alpha)	<0.002	<0.002	1	0.01

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Endosulfan II (beta)	<0.004	<0.004	1	0.02
Endosulfan Sulfate	<0.02	<0.02	1	0.1
Endrin	<0.004	<0.004	1	0.02
Ethylbenzene	<10	<10	1	10
Fluoride				500
Guthion	<0.0509	<0.0509	1	0.1
Heptachlor	<0.00446	<0.00446	1	0.01
Heptachlor Epoxide	<0.002	<0.002	1	0.01
Hexachlorobenzene	<5	<5	1	5
Hexachlorobutadiene	<10	<10	1	10
Hexachlorocyclohexane (alpha)	<0.01	<0.01	1	0.05
Hexachlorocyclohexane (beta)	<0.01	<0.01	1	0.05
gamma-Hexachlorocyclohexane (Lindane)	<0.01	<0.01	1	0.05
Hexachlorocyclopentadiene	<10	<10	1	10
Hexachloroethane	<20	<20	1	20
Hexachlorophene	<1.26	<1.26	1	10
Lead	0.0005	0.0005	1	0.5
Malathion	<0.0509	<0.0509	1	0.1
Mercury	0.00271	0.00271	1	0.005
Methoxychlor	<0.02	<0.02	1	2
Methyl Ethyl Ketone	<50	<50	1	50
Mirex	<0.02	<0.02	1	0.02
Nickel	0.0025	0.0025	1	2
Nitrate-Nitrogen	2.75	2.75	1	100
Nitrobenzene	<10	<10	1	10
N-Nitrosodiethylamine	<20	<20	1	20
N-Nitroso-di-n-Butylamine	<20	<20	1	20
Nonylphenol	<5	<5	1	333
Parathion (ethyl)	<0.0509	<0.0509	1	0.1
Pentachlorobenzene	<20	<20	1	20
Pentachlorophenol	<5	<5	1	5
Phenanthrene	<10	<10	1	10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Polychlorinated Biphenyls (PCB's) (*3)	<0.04	<0.04	1	0.2
Pyridine	<20	<20	1	20
Selenium	<0.0005	<0.0005	1	5
Silver	<0.0005	<0.0005	1	0.5
1,2,4,5-Tetrachlorobenzene	<10	<10	1	20
1,1,2,2-Tetrachloroethane	<10	<10	1	10
Tetrachloroethylene	<10	<10	1	10
Thallium	<0.0005	<0.0005	1	0.5
Toluene	<10	<10	1	10
Toxaphene	<0.0770	<0.0770	1	0.3
2,4,5-TP (Silvex)	<0.2	<0.2	1	0.3
Tributyltin (see instructions for explanation)				0.01
1,1,1-Trichloroethane	<10	<10	1	10
1,1,2-Trichloroethane	<10	<10	1	10
Trichloroethylene	<10	<10	1	10
2,4,5-Trichlorophenol	<10	<10	1	50
TTHM (Total Trihalomethanes)	<10	<10	1	10
Vinyl Chloride	<10	<10	1	10
Zinc	0.0609	0.0609	1	5

(*1) Determined by subtracting hexavalent Cr from total Cr.

(*2) Cyanide, amenable to chlorination or weak-acid dissociable.

(*3) The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

Section 2. Priority Pollutants

For pollutants identified in Tables 4.0(2)A-E, indicate type of sample.

Grab

Composite

Date and time sample(s) collected: 3/12/2024 10:00 am

Table 4.0(2)A – Metals, Cyanide, and Phenols

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Antimony	0.0009	0.0009	1	5
Arsenic	0.0010	0.0010	1	0.5
Beryllium	<0.0005	<0.0005	1	0.5
Cadmium	<0.0005	<0.0005	1	1
Chromium (Total)	0.0005	0.0005	1	3
Chromium (Hex)	<0.003	<0.003	1	3
Chromium (Tri) (*1)	<0.0005	<0.0005	1	N/A
Copper	0.0005	0.0005	1	2
Lead	0.0005	0.0005	1	0.5
Mercury	0.00271	0.00271	1	0.005
Nickel	0.0025	0.0025	1	2
Selenium	<00005	<00005	1	5
Silver	<0.0005	<0.0005	1	0.5
Thallium	<0.0005	<0.0005	1	0.5
Zinc	0.0609	0.0609	1	5
Cyanide (*2)	<0.005	<0.005	1	10
Phenols, Total	<10	<10	1	10

(*1) Determined by subtracting hexavalent Cr from total Cr.

(*2) Cyanide, amenable to chlorination or weak-acid dissociable

Table 4.0(2)B – Volatile Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrolein	<50	<50	1	50
Acrylonitrile	<50	<50	1	50
Benzene	<10	<10	1	10
Bromoform	<10	<10	1	10
Carbon Tetrachloride	<2	<2	1	2
Chlorobenzene	<10	<10	1	10
Chlorodibromomethane	<10	<10	1	10
Chloroethane	<50	<50	1	50
2-Chloroethylvinyl Ether	<10	<10	1	10
Chloroform	<10	<10	1	10
Dichlorobromomethane [Bromodichloromethane]	<10	<10	1	10
1,1-Dichloroethane	<10	<10	1	10
1,2-Dichloroethane	<10	<10	1	10
1,1-Dichloroethylene	<10	<10	1	10
1,2-Dichloropropane	<10	<10	1	10
1,3-Dichloropropylene [1,3-Dichloropropene]	<5	<5	1	10
1,2-Trans-Dichloroethylene	<10	<10	1	10
Ethylbenzene	<10	<10	1	10
Methyl Bromide	<50	<50	1	50
Methyl Chloride	<50	<50	1	50
Methylene Chloride	<20	<20	1	20
1,1,2,2-Tetrachloroethane	<10	<10	1	10
Tetrachloroethylene	<10	<10	1	10
Toluene	<10	<10	1	10
1,1,1-Trichloroethane	<10	<10	1	10
1,1,2-Trichloroethane	<10	<10	1	10
Trichloroethylene	<10	<10	1	10
Vinyl Chloride	<10	<10	1	10

Table 4.0(2)C – Acid Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2-Chlorophenol	<10	<10	1	10
2,4-Dichlorophenol	<10	<10	1	10
2,4-Dimethylphenol	<10	<10	1	10
4,6-Dinitro-o-Cresol	<50	<50	1	50
2,4-Dinitrophenol	<10	<10	1	50
2-Nitrophenol	<20	<20	1	20
4-Nitrophenol	<50	<50	1	50
P-Chloro-m-Cresol	<10	<10	1	10
Pentalchlorophenol	<5	<5	1	5
Phenol	<10	<10	1	10
2,4,6-Trichlorophenol	<10	<10	1	10

Table 4.0(2)D – Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acenaphthene	<10	<10	1	10
Acenaphthylene	<10	<10	1	10
Anthracene	<10	<10	1	10
Benzidine	<50	<50	1	50
Benzo(a)Anthracene	<5	<5	1	5
Benzo(a)Pyrene	<5	<5	1	5
3,4-Benzofluoranthene	<10	<10	1	10
Benzo(ghi)Perylene	<20	<20	1	20
Benzo(k)Fluoranthene	<5	<5	1	5
Bis(2-Chloroethoxy)Methane	<10	<10	1	10
Bis(2-Chloroethyl)Ether	<10	<10	1	10
Bis(2-Chloroisopropyl)Ether	<10	<10	1	10
Bis(2-Ethylhexyl)Phthalate	<10	<10	1	10
4-Bromophenyl Phenyl Ether	<10	<10	1	10
Butyl benzyl Phthalate	<10	<10	1	10
2-Chloronaphthalene	<10	<10	1	10
4-Chlorophenyl phenyl ether	<10	<10	1	10
Chrysene	<5	<5	1	5
Dibenzo(a,h)Anthracene	<5	<5	1	5
1,2-(o)Dichlorobenzene	<10	<10	1	10
1,3-(m)Dichlorobenzene	<10	<10	1	10
1,4-(p)Dichlorobenzene	<10	<10	1	10
3,3-Dichlorobenzidine	<5	<5	1	5
Diethyl Phthalate	<10	<10	1	10
Dimethyl Phthalate	<10	<10	1	10
Di-n-Butyl Phthalate	<10	<10	1	10
2,4-Dinitrotoluene	<10	<10	1	10
2,6-Dinitrotoluene	<10	<10	1	10
Di-n-Octyl Phthalate	<10	<10	1	10
1,2-Diphenylhydrazine (as Azo-benzene)	<10	<10	1	20
Fluoranthene	<10	<10	1	10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Fluorene	<10	<10	1	10
Hexachlorobenzene	<5	<5	1	5
Hexachlorobutadiene	<10	<10	1	10
Hexachlorocyclo-pentadiene	<10	<10	1	10
Hexachloroethane	<20	<20	1	20
Indeno(1,2,3-cd)pyrene	<5	<5	1	5
Isophorone	<5	<5	1	10
Naphthalene	<10	<10	1	10
Nitrobenzene	<10	<10	1	10
N-Nitrosodimethylamine	<50	<50	1	50
N-Nitrosodi-n-Propylamine	<20	<20	1	20
N-Nitrosodiphenylamine	<20	<20	1	20
Phenanthrene	<10	<10	1	10
Pyrene	<10	<10	1	10
1,2,4-Trichlorobenzene	<10	<10	1	10

Table 4.0(2)E - Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Aldrin	<0.002	<0.002	1	0.01
alpha-BHC (Hexachlorocyclohexane)	<0.009	<0.009	1	0.05
beta-BHC (Hexachlorocyclohexane)	<0.018	<0.018	1	0.05
gamma-BHC (Hexachlorocyclohexane)				0.05
delta-BHC (Hexachlorocyclohexane)	<0.25	<0.25	1	0.05
Chlordane	<0.103	<0.103	1	0.2
4,4-DDT	<0.02	<0.02	1	0.02
4,4-DDE	<0.02	<0.02	1	0.1
4,4,-DDD	<0.004	<0.004	1	0.1
Diethyltin	<0.004	<0.004	1	0.02
Endosulfan I (alpha)	<0.002	<0.002	1	0.01
Endosulfan II (beta)	<0.004	<0.004	1	0.02
Endosulfan Sulfate	<0.02	<0.02	1	0.1
Endrin	<0.004	<0.004	1	0.02
Endrin Aldehyde	<0.02	<0.02	1	0.1
Heptachlor	<0.00446	<0.00446	1	0.01
Heptachlor Epoxide	<0.002	<0.002	1	0.01
PCB-1242	<0.04	<0.04	1	0.2
PCB-1254	<0.04	<0.04	1	0.2
PCB-1221	<0.04	<0.04	1	0.2
PCB-1232	<0.04	<0.04	1	0.2
PCB-1248	<0.04	<0.04	1	0.2
PCB-1260	<0.04	<0.04	1	0.2
PCB-1016	<0.04	<0.04	1	0.2
Toxaphene	<0.077	<0.077	1	0.3

* For PCBS, if all are non-detects, enter the highest non-detect preceded by a "<".

Section 3. Dioxin/Furan Compounds

A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user. Check all that apply.

- 2,4,5-trichlorophenoxy acetic acid
Common Name 2,4,5-T, CASRN 93-76-5
- 2-(2,4,5-trichlorophenoxy) propanoic acid
Common Name Silvex or 2,4,5-TP, CASRN 93-72-1
- 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate
Common Name Erbon, CASRN 136-25-4
- 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate
Common Name Ronnel, CASRN 299-84-3
- 2,4,5-trichlorophenol
Common Name TCP, CASRN 95-95-4
- hexachlorophene
Common Name HCP, CASRN 70-30-4

For each compound identified, provide a brief description of the conditions of its/their presence at the facility.

Click to enter text.

B. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent?

- Yes No

If yes, provide a brief description of the conditions for its presence.

Click to enter text.

C. If any of the compounds in Subsection A **or** B are present, complete Table 4.0(2)F.

For pollutants identified in Table 4.0(2)F, indicate the type of sample.

Grab Composite

Date and time sample(s) collected: [Click to enter text.](#)

Table 4.0(2)F – Dioxin/Furan Compounds

Compound	Toxic Equivalency Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
2,3,7,8 TCDD	1					10
1,2,3,7,8 PeCDD	0.5					50
2,3,7,8 HxCDDs	0.1					50
1,2,3,4,6,7,8 HpCDD	0.01					50
2,3,7,8 TCDF	0.1					10
1,2,3,7,8 PeCDF	0.05					50
2,3,4,7,8 PeCDF	0.5					50
2,3,7,8 HxCDFs	0.1					50
2,3,4,7,8 HpCDFs	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					0.5
PCB 81	0.0003					0.5
PCB 126	0.1					0.5
PCB 169	0.03					0.5
Total						

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following is required for all publicly owned treatment works.

Section 1. All POTWs (Instructions Page 89)

A. Industrial users (IUs)

Provide the number of each of the following types of industrial users (IUs) that discharge to your POTW and the daily flows from each user. See the Instructions for definitions of Categorical IUs, Significant IUs – non-categorical, and Other IUs.

If there are no users, enter 0 (zero).

Categorical IUs:

Number of IUs: 0

Average Daily Flows, in MGD: 0

Significant IUs – non-categorical:

Number of IUs: 0

Average Daily Flows, in MGD: 0

Other IUs:

Number of IUs: 0

Average Daily Flows, in MGD: 0

B. Treatment plant interference

In the past three years, has your POTW experienced treatment plant interference (see instructions)?

Yes No

If yes, identify the dates, duration, description of interference, and probable cause(s) and possible source(s) of each interference event. Include the names of the IUs that may have caused the interference.

Click to enter text.

C. Treatment plant pass through

In the past three years, has your POTW experienced pass through (see instructions)?

- Yes No

If yes, identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.

Click to enter text.

D. Pretreatment program

Does your POTW have an approved pretreatment program?

- Yes No

If yes, complete Section 2 only of this Worksheet.

Is your POTW required to develop an approved pretreatment program?

- Yes No

If yes, complete Section 2.c. and 2.d. only, and skip Section 3.

If no to either question above, skip Section 2 and complete Section 3 for each significant industrial user and categorical industrial user.

Section 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)

A. Substantial modifications

Have there been any **substantial modifications** to the approved pretreatment program that have not been submitted to the TCEQ for approval according to *40 CFR §403.18*?

- Yes No

If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.

Click to enter text.

B. Non-substantial modifications

Have there been any **non-substantial modifications** to the approved pretreatment program that have not been submitted to TCEQ for review and acceptance?

Yes No

If yes, identify all non-substantial modifications that have not been submitted to TCEQ, including the purpose of the modification.

Click to enter text.

C. Effluent parameters above the MAL

In Table 6.0(1), list all parameters measured above the MAL in the POTW's effluent monitoring during the last three years. Submit an attachment if necessary.

Table 6.0(1) – Parameters Above the MAL

Pollutant	Concentration	MAL	Units	Date

D. Industrial user interruptions

Has any SIU, CIU, or other IU caused or contributed to any problems (excluding interferences or pass throughs) at your POTW in the past three years?

Yes No

If yes, identify the industry, describe each episode, including dates, duration, description of the problems, and probable pollutants.

Click to enter text.

Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 90)

A. General information

Company Name: McGill Airflow Corporation

SIC Code: 3444

Contact name: Matthew Lynch

Address: 206 Pecos Street

City, State, and Zip Code: Hillsboro, TX 76654

Telephone number: 254-582-5392

Email address: [Click to enter text.](#)

B. Process information

Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).

No wastewater discharges into the system.

C. Product and service information

Provide a description of the principal product(s) or services performed.

HVAC sheet metal and ductwork

D. Flow rate information

See the Instructions for definitions of “process” and “non-process wastewater.”

Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

Non-Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

E. Pretreatment standards

Is the SIU or CIU subject to technically based local limits as defined in the instructions?

Yes No

Is the SIU or CIU subject to categorical pretreatment standards found in *40 CFR Parts 405-471*?

Yes No

If **subject to categorical pretreatment standards**, indicate the applicable category and subcategory for each categorical process.

Category: Subcategories: [Click to enter text.](#)

Click or tap here to enter text. [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

F. Industrial user interruptions

Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?

Yes No

If yes, identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.

[Click to enter text.](#)

Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 90)

A. General information

Company Name: SRM Concrete

SIC Code: 3273

Contact name: Click to enter text.

Address: 119 Industrial Loop

City, State, and Zip Code: Hillsboro, TX 76654

Telephone number:

Email address: Click to enter text.

B. Process information

Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).

No wastewater discharges into the system.

C. Product and service information

Provide a description of the principal product(s) or services performed.

Concrete

D. Flow rate information

See the Instructions for definitions of “process” and “non-process wastewater.”

Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

Non-Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

E. Pretreatment standards

Is the SIU or CIU subject to technically based local limits as defined in the instructions?

Yes No

Is the SIU or CIU subject to categorical pretreatment standards found in *40 CFR Parts 405-471*?

Yes No

If **subject to categorical pretreatment standards**, indicate the applicable category and subcategory for each categorical process.

Category: Subcategories: [Click to enter text.](#)

Click or tap here to enter text. [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

F. Industrial user interruptions

Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?

Yes No

If yes, identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.

[Click to enter text.](#)

Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 90)

A. General information

Company Name: Clayton Homes

SIC Code: 2451

Contact name: Click to enter text.

Address: 216 Pecos Street

City, State, and Zip Code: Hillsboro, TX 76654

Telephone number: 254-480-0100

Email address: Click to enter text.

B. Process information

Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).

No process wastewater discharges into the system.

C. Product and service information

Provide a description of the principal product(s) or services performed.

Manufactured Homes

D. Flow rate information

See the Instructions for definitions of “process” and “non-process wastewater.”

Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

Non-Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

E. Pretreatment standards

Is the SIU or CIU subject to technically based local limits as defined in the instructions?

Yes No

Is the SIU or CIU subject to categorical pretreatment standards found in *40 CFR Parts 405-471*?

Yes No

If **subject to categorical pretreatment standards**, indicate the applicable category and subcategory for each categorical process.

Category: Subcategories: [Click to enter text.](#)

Click or tap here to enter text. [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

F. Industrial user interruptions

Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?

Yes No

If yes, identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.

[Click to enter text.](#)

Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 90)

A. General information

Company Name: Wisenbaker Building Services

SIC Code: [Click to enter text.](#)

Contact name: [Click to enter text.](#)

Address: 404 Hawkins Street

City, State, and Zip Code: Hillsboro, TX 76654

Telephone number:

Email address: [Click to enter text.](#)

B. Process information

Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).

No process wastewater discharges into the system.

C. Product and service information

Provide a description of the principal product(s) or services performed.

Home cabinets and countertops

D. Flow rate information

See the Instructions for definitions of “process” and “non-process wastewater.”

Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

Non-Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type: Continuous Batch Intermittent

E. Pretreatment standards

Is the SIU or CIU subject to technically based local limits as defined in the instructions?

Yes No

Is the SIU or CIU subject to categorical pretreatment standards found in *40 CFR Parts 405-471*?

Yes No

If **subject to categorical pretreatment standards**, indicate the applicable category and subcategory for each categorical process.

Category: Subcategories: [Click to enter text.](#)

Click or tap here to enter text. [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

Category: [Click to enter text.](#)

Subcategories: [Click to enter text.](#)

F. Industrial user interruptions

Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?

Yes No

If yes, identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.

[Click to enter text.](#)

ATTACHMENT A

CORE DATA FORM



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for Submission (<i>If other is checked please describe in space provided.</i>)	
<input type="checkbox"/> New Permit, Registration or Authorization (<i>Core Data Form should be submitted with the program application.</i>)	
<input checked="" type="checkbox"/> Renewal (<i>Core Data Form should be submitted with the renewal form</i>)	
2. Customer Reference Number (<i>if issued</i>) CN 600514228	Follow this link to search for CN or RN numbers in Central Registry**
3. Regulated Entity Reference Number (<i>if issued</i>) RN 102844180	

SECTION II: Customer Information

4. General Customer Information	5. Effective Date for Customer Information Updates (mm/dd/yyyy)	05/30/2024						
<input type="checkbox"/> New Customer <input type="checkbox"/> Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts)	<input checked="" type="checkbox"/> Update to Customer Information	<input type="checkbox"/> Change in Regulated Entity Ownership						
<i>The Customer Name submitted here may be updated automatically based on what is current and active with the Texas Secretary of State (SOS) or Texas Comptroller of Public Accounts (CPA).</i>								
6. Customer Legal Name (<i>If an individual, print last name first: eg: Doe, John</i>)		<i>If new Customer, enter previous Customer below:</i>						
City of Hillsboro								
7. TX SOS/CPA Filing Number	8. TX State Tax ID (11 digits) 17460010899	9. Federal Tax ID (9 digits) 74-600189	10. DUNS Number (<i>if applicable</i>) 041127077					
11. Type of Customer:	<input type="checkbox"/> Corporation	<input type="checkbox"/> Individual	Partnership: <input type="checkbox"/> General <input type="checkbox"/> Limited					
Government: <input checked="" type="checkbox"/> City <input type="checkbox"/> County <input type="checkbox"/> Federal <input type="checkbox"/> Local <input type="checkbox"/> State <input type="checkbox"/> Other		<input type="checkbox"/> Sole Proprietorship	<input type="checkbox"/> Other:					
12. Number of Employees <input type="checkbox"/> 0-20 <input type="checkbox"/> 21-100 <input checked="" type="checkbox"/> 101-250 <input type="checkbox"/> 251-500 <input type="checkbox"/> 501 and higher		13. Independently Owned and Operated? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
14. Customer Role (<i>Proposed or Actual – as it relates to the Regulated Entity listed on this form. Please check one of the following</i>)								
<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input checked="" type="checkbox"/> Owner & Operator <input type="checkbox"/> Occupational Licensee <input type="checkbox"/> Responsible Party <input type="checkbox"/> VCP/BSA Applicant <input type="checkbox"/> Other:								
15. Mailing Address:	P.O. Box 568							
	City	Hillsboro	State	TX	ZIP	76645	ZIP + 4	0568
16. Country Mailing Information (<i>if outside USA</i>)				17. E-Mail Address (<i>if applicable</i>)				
				tdieterich@hillsborotx.org				
18. Telephone Number			19. Extension or Code			20. Fax Number (<i>if applicable</i>)		

SECTION III: Regulated Entity Information

21. General Regulated Entity Information (*If "New Regulated Entity" is selected, a new permit application is also required.*)

New Regulated Entity Update to Regulated Entity Name Update to Regulated Entity Information

The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).

22. Regulated Entity Name (*Enter name of the site where the regulated action is taking place.*)

City of Hillsboro Wastewater Treatment Plant

23. Street Address of the Regulated Entity: <i>(No PO Boxes)</i>	600 Parham Street							
	City	Hillsboro	State	TX	ZIP	76645	ZIP + 4	
24. County								

If no Street Address is provided, fields 25-28 are required.

25. Description to Physical Location:	Adjacent to George Street approximately 700 feet southwest of the intersection of Parham Street and George Street in Hill County Texas						
--	--	--	--	--	--	--	--

26. Nearest City			State	Nearest ZIP Code		
Hillsboro			TX	76645		

Latitude/Longitude are required and may be added/updated to meet TCEQ Core Data Standards. (Geocoding of the Physical Address may be used to supply coordinates where none have been provided or to gain accuracy).

27. Latitude (N) In Decimal:		31.999458	28. Longitude (W) In Decimal:		97.141708		
Degrees	Minutes	Seconds	Degrees	Minutes	Seconds		
31	59	58.05	97	8	30.15		

29. Primary SIC Code (4 digits)	30. Secondary SIC Code (4 digits)	31. Primary NAICS Code (5 or 6 digits)	32. Secondary NAICS Code (5 or 6 digits)
4952	0000	221320	221320

33. What is the Primary Business of this entity? (<i>Do not repeat the SIC or NAICS description.</i>)							
Municipal government Wastewater Treatment							

34. Mailing Address:	P.O. Box 568						
	City	Hillsboro	State	TX	ZIP	76645	ZIP + 4

35. E-Mail Address:	tdieterich@hillsborotx.org						
36. Telephone Number	37. Extension or Code	38. Fax Number (<i>if applicable</i>)					

(254) 582-3478		(254) 582-396
------------------	--	-----------------

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

<input type="checkbox"/> Dam Safety	<input type="checkbox"/> Districts	<input type="checkbox"/> Edwards Aquifer	<input type="checkbox"/> Emissions Inventory Air	<input type="checkbox"/> Industrial Hazardous Waste
<input type="checkbox"/> Municipal Solid Waste	<input type="checkbox"/> New Source Review Air	<input type="checkbox"/> OSSF	<input type="checkbox"/> Petroleum Storage Tank	<input type="checkbox"/> PWS
<input type="checkbox"/> Sludge	<input type="checkbox"/> Storm Water	<input type="checkbox"/> Title V Air	<input type="checkbox"/> Tires	<input type="checkbox"/> Used Oil
<input type="checkbox"/> Voluntary Cleanup	<input checked="" type="checkbox"/> Wastewater	<input type="checkbox"/> Wastewater Agriculture	<input type="checkbox"/> Water Rights	<input type="checkbox"/> Other:
	RN102844180			

SECTION IV: Preparer Information

40. Name:	Megan Henderson	41. Title:	City Manager
42. Telephone Number		43. Ext./Code	44. Fax Number
(254) 582-3271		(254) 582-0112	mhenderson@hillsborotx.org

SECTION V: Authorized Signature

46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39.

Company:	City of Hillsboro	Job Title:	City Manager
Name (In Print):	Megan Henderson	Phone:	(254) 582- 3271
Signature:		Date:	

ATTACHMENT B

**PLAIN LANGUAGE SUMMARY
(TCEQ FORM 20972)**



PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by [Title 30, Texas Administrative Code \(30 TAC\), Chapter 39, Subchapter H](#). Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in [30 TAC Section 39.426](#), [you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package](#). For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

The City of Hillsboro ((CN600514228)) operates the City of Hillsboro Wastewater Treatment Plant (RN102844180), a wastewater treatment facility. The facility is located at 600 Parham Street, in Hillsboro, Hill County, Texas 76645. This application is for the renewal to discharge an annual average flow of 1,810,000 gallons per day (1.81 MGD) of treated domestic wastewater via Outfall 001..

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD5), total suspended solids (TSS), ammonia nitrogen (NH3-N) and Escherichia coli. Domestic wastewater is treated by an activated sludge process with nitrification and denitrification in an Oxidation Ditch.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

AGUAS RESIDUALES DOMESTICAS /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

La Ciudad de Hillsboro ((CN600514228)) opera la Planta de Tratamiento de Aguas Residuales de la Ciudad de Hillsboro (RN102844180), una instalación de tratamiento de aguas residuales. La instalación está ubicada en 600 Parham Street, en Hillsboro, Condado de Hill, Texas 76645. Esta solicitud es para la renovación para descargar un flujo promedio anual de 1,810,000 galones por día (1.81 MGD) de aguas residuales domésticas tratadas a través del Emisario 001..Este permiso no autorizará una descarga de contaminantes en el agua en el estado.

Se espera que las descargas de la instalación contengan demanda bioquímica de oxígeno carbonoso (CBOD5) de cinco días, sólidos suspendidos totales (SST), nitrógeno ammoniacal (NH3-N) y Escherichia coli. Las aguas residuales domésticas . ~~estará~~ tratado por un proceso de lodos activados con nitrificación en Zanja de Oxidación.

ATTACHMENT C


USGS TOPOGRAPHIC MAP



U.S. DEPARTMENT OF THE INTERIOR
U.S. GEOLOGICAL SURVEY

The National Map
US Topo

PEORIA QUADRANGLE
TEXAS - HILL COUNTY
7.5-MINUTE SERIES



Produced by the United States Geological Survey

North American Datum of 1983 (NAD83), Projection and
1:100-meter grid; Universal Transverse Mercator, Zone 14R

This map is not a legal document. Boundaries may be
generalized for this map scale. Private lands within government
reservations may not be shown. Obtain permission before
entering private lands.

Imagery.....NAIP, September 2016 - November 2016
Roads.....U.S. Census Bureau, 2015 - 2018
Names.....U.S. Census Bureau, 2015 - 2022
Hydrography.....National Hydrography Dataset, 2017
Concours.....National Elevation Dataset, 2017
Boundaries.....Multiple sources; see metadata file 2019 - 2021

Wetlands.....FWS National Wetlands Inventory Not Available

MN

GN

3°24'

60 MILS

0°58'

17 MILS

UTM GRID AND 2019 MAGNETIC NORTH
DECLINATION AT CENTER OF SHEET

U.S. National Grid
100,000-m Square ID

PA

Grid Zone Designation

SCALE 1:24 000

1000 0.5 0 1000 2000
KILOMETERS METERS MILES
0 500 1000 1500 2000
1000 0 1000 2000 3000 4000 5000 6000 7000 8000 9000 10000

CONTOUR INTERVAL 10 FEET
NORTH AMERICAN VERTICAL DATUM OF 1988

This map was produced to conform with the
National Geospatial Program US Topo Product Standard.

TEXAS

QUADRANGLE LOCATION

1	2	3
4	5	
6	7	8

ADJOINING QUADRANGLES

ROAD CLASSIFICATION
Expressway
Secondary Hwy
Ramp
Interstate Route
Local Connector
Local Road
4WD
US Route
State Route

PEORIA, TX
2022

ATTACHMENT D

SUPPLEMENTAL PERMIT INFORMATION FORM

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:

Application type: Renewal Major Amendment Minor Amendment New

County: _____ Segment Number: _____

Admin Complete Date: _____

Agency Receiving SPIF:

Texas Historical Commission U.S. Fish and Wildlife

Texas Parks and Wildlife Department U.S. Army Corps of Engineers

This form applies to TPDES permit applications only. (Instructions, Page 53)

Complete this form as a separate document. TCEQ will mail a copy to each agency as required by our agreement with EPA. If any of the items are not completely addressed or further information is needed, we will contact you to provide the information before issuing the permit. Address each item completely.

Do not refer to your response to any item in the permit application form. Provide each attachment for this form separately from the Administrative Report of the application. The application will not be declared administratively complete without this SPIF form being completed in its entirety including all attachments. Questions or comments concerning this form may be directed to the Water Quality Division's Application Review and Processing Team by email at WQ-ARPTeam@tceq.texas.gov or by phone at (512) 239-4671.

The following applies to all applications:

1. Permittee: City of Hillsboro

Permit No. WQ00 10630001

EPA ID No. TX 0023108

Address of the project (or a location description that includes street/highway, city/vicinity, and county):

600 Parham Street, Adjacent to George Street, approximately 700 feet southwest of the intersection of Parham Street and George Street in Hillsboro, Hill County, Texas.

Provide the name, address, phone and fax number of an individual that can be contacted to answer specific questions about the property.

Prefix (Mr., Ms., Miss): Ms.

First and Last Name: Megan Henderson

Credential (P.E, P.G., Ph.D., etc.):

Title: City Manager

Mailing Address: P.O. Box 568, 214 East Street

City, State, Zip Code: Hillsboro, X 76645

Phone No.: 254-582-3271 Ext.: Fax No.: 254-582-0112

E-mail Address: mhenderson@hillsborotx.org

2. List the county in which the facility is located: Hill
3. If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.

N/A

4. Provide a description of the effluent discharge route. The discharge route must follow the flow of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.

To and Unnamed drainage ditch, thence to Little Hackberry Creek; thence to Hackberry Creek; thence to Aquilla Reservoir in Segment No. 1254 of the Brazos River Basin.

5. Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report).

Provide original photographs of any structures 50 years or older on the property.

Does your project involve any of the following? Check all that apply.

- Proposed access roads, utility lines, construction easements
- Visual effects that could damage or detract from a historic property's integrity
- Vibration effects during construction or as a result of project design
- Additional phases of development that are planned for the future
- Sealing caves, fractures, sinkholes, other karst features

Disturbance of vegetation or wetlands

1. List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):

N/A

2. Describe existing disturbances, vegetation, and land use:

Existing wastewater treatment plant site

THE FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR AMENDMENTS TO TPDES PERMITS

3. List construction dates of all buildings and structures on the property:

N/A

4. Provide a brief history of the property, and name of the architect/builder, if known.


N/A



U.S. DEPARTMENT OF THE INTERIOR
U.S. GEOLOGICAL SURVEY



**PEORIA QUADRANGLE
TEXAS - HILL COUNTY
7.5-MINUTE SERIES**



Produced by the United States Geological Survey

Produced by the United States Geological Survey
North American Datum of 1983 (NAD83)
World Geodetic System of 1984 (WGS84). Projection and
1 000-meter grid:Universal Transverse Mercator, Zone 14R
This map is not a legal document. Boundaries may be
subject to change. Private lands within government

This map is not a legal document. Boundaries may be generalized for this map scale. Private lands within government reservations may not be shown. Obtain permission before entering private lands.

Imagery.....NAIP, September 2013

Imagery.....	NAIP, September 2016	2016	November 2016
Roads.....	U.S. Census Bureau	2015	2018
Names.....	GNIS, 1979	1979	2022
Hydrography.....	National Hydrography Dataset, 2003	2003	2018
Contours.....	National Elevation Dataset, 2019	2019	2017
Boundaries.....	Multiple sources; see metadata file	2019	2021

UTM GRID AND 2019 MAGNETIC NORTH DECLINATION AT CENTER OF SHEET

SCALE 1:24 000

A scale bar at the bottom of the figure. The top part shows 'KILOMETERS' with markings at 0, 500, 1000, and 2000. The bottom part shows 'METERS' with markings at 0, 500, and 1000. The scale is labeled 'SCALE 1:2,100,000'.

MILES
2000 3000 4000 5000 6000 7000
FEET
CONTOUR INTERVAL 10 FEET
NORTH AMERICAN VERTICAL DATUM OF 1988

A small graphic of the state of Texas, used as a section header for Texas-specific content.

QUADRANGLE LOCATION		
1	2	3
4		5
6	7	8
ADJOINING QUADRANGLES		
1 Blanton		
2 Hillsboro West		
3 Hillsboro East		
4 Whitney		
5 Abbott		
6 Smiths Bend		
7 Aquilla		
8 West		


ROAD CLASSIFICATION

Symbol	Description
	Expressway
	Secondary Hwy
	Ramp
	Local Connector
	Local Road
	4WD
	Interstate Route
	US Route
	State Route

PEORIA, TX
2022

ATTACHMENT E


FLOW DIAGRAM



WWTP SCHEMATIC FLOW DIAGRAM
EXISTING FACILITY 1.81 MGD
HILLSBORO, TEXAS

ATTACHMENT F

SITE PLAN



LEGEND

- RAW WASTEWATER LINES
- RETURN SLUDGE LINES
- MIXED LIQUOR LINES
- CLEAN WATER LINES

Site Plan

ATTACHMENT G

ANALYTICAL REPORTS

BIO CHEM LAB, INC. PHONE: 254.829.8001 FAX: 254.829.8013
4751 TOKIO RD .WEST, TX 76691

ANALYTICAL REPORT**CLIENT IDENTIFICATION INFORMATION:**

CITY OF HILLSBORO
PO BOX 568
HILLSBORO, TX 76645
CLIENT CONTACT: TERRY DIETERICH

MARCH 2024 - HILLSBORO

REPORT ID:	HIL- 061124
LAB CONTACT:	SHAY OCHOA
REPORT DATE:	6.11.24
PERMIT RENEWAL	

FIELD DATA / SAMPLE DESCRIPTION

		EFFLUENT
Collection Point		3.12.24 / 10:00
Date/ Time Collected		3.12.24 / 14:00
Date/ Time received by Lab		6221-24
Laboratory Sample ID		BCL.SOP.119
Sampling Description/Procedure		Grab
Sample Type		Aqueous-NPW
Sample Matrix		GF
Collector		SM 4500-H+B
pH, SU		6.8
Dissolved Oxygen, mg/L		SM 4500 O G
Temperature, C		6.1
Date / Time Analyzed	(Field Analysis)	21.2
Analyst Initials		3.12.24 / 10:00
		GF

PARAMETER / UNIT / METHOD

CBOD₅, mg/L	SM 5210 B	3.
Reporting Limit, mg/L		2.
Dilution Factor		1
Date / Time Analyzed		3.13.24 / 10:30
Analyst Initials		LD

TSS, mg/L	SM 2540 D	11.
Reporting Limit, mg/L		2.
Dilution Factor		1
Date / Time Analyzed		3.13.24 / 09:20
Analyst Initials		MH

Sulfate, mg/L	EPA 300.0	129.
Reporting Limit, mg/L		5.00
Dilution Factor		10
Date / Time Analyzed		3.13.24 / 16:11
Analyst Initials		AJ

Chloride, mg/L	EPA 300.0	71.9
Reporting Limit, mg/L		5.00
Dilution Factor		10
Date / Time Analyzed		3.13.24 / 16:11
Analyst Initials		AJ

TDS, mg/L	SM 2540 C	Q 470.
Reporting Limit, mg/L		20.
Dilution Factor		1
Date / Time Analyzed		3.18.24 / 09:30
Analyst Initials		ARJ

Electrical Conductivity, μmhos @ 25°C	SM 2510 B	763.
Reporting Limit, μmhos @ 25°C		10.
Dilution Factor		4
Date Analyzed		3.22.24 / 11:50
Analyst Initials		ARJ / JLJ

Total Alkalinity, mg/L	SM 2320 B	133.
Reporting Limit, mg/L		10.0
Dilution Factor		1
Date / Time Analyzed		3.22.24 / 08:30
Analyst Initials		ARJ

NO₃N, mg/L	(NITRATE-N)	2.75
Reporting Limit, mg/L		0.10
Dilution Factor		10
Date / Time Analyzed		3.13.24 / 16:11
Analyst Initials		AJ

BIO CHEM LAB, INC. PHONE: 254.829.8001 FAX: 254.829.8013
4751 TOKIO RD .WEST, TX 76691

ANALYTICAL REPORT**CLIENT IDENTIFICATION INFORMATION:**

CITY OF HILLSBORO
PO BOX 568
HILLSBORO, TX 76645
CLIENT CONTACT: TERRY DIETERICH

MARCH 2024 - HILLSBORO

REPORT ID:	HIL- 061124
LAB CONTACT:	SHAY OCHOA
REPORT DATE:	
PERMIT RENEWAL	

FIELD DATA / SAMPLE DESCRIPTION

Collection Point	EFFLUENT
Date/ Time Collected	3.12.24 / 10:00
Date/ Time received by Lab	3.12.24 / 14:00
Laboratory Sample ID	6221-24
Sampling Description/Procedure	BCL.SOP.119
Sample Type	Grab
Sample Matrix	Aqueous-NPW
Collector	GF

PARAMETER / UNIT / METHOD

NH₃N, mg/L	SM 4500 NH ₃ B, D	2.23
Reporting Limit, mg/L		0.10
Dilution Factor		1
Date / Time Analyzed		3.18.24 / 20:40
Analyst Initials		SV

TKN, mg/L	SM4500 N _{org} B	5.00
Reporting Limit, mg/L		1.00
Dilution Factor		2
Date / Time Analyzed		3.18.24 / 18:40
Analyst Initials		SV

Total Phosphorus, mg/L	SM 4500 P B.5, E	L
Reporting Limit, mg/L		0.40
Dilution Factor		5
Date / Time Analyzed		
Analyst Initials		

E. coli MPN /100ml	SM 9223 B	125.
Reporting Limit, CFU/100ml		1.
Dilution Factor		1
Date / Time Analyzed		3.12.24 / 16:10
Analyst Initials		MH

Oil and Grease, mg/L	EPA 1664 A	< 5.0
Reporting Limit, mg/L		5.0
Dilution Factor		1
Date / Time Analyzed		3.18.24 / 10:00
Analyst Initials		CD

Hexavalent Chromium, mg/L	SM 3500 Cr-B	< 0.003
Reporting Limit, mg/L		0.003
Dilution Factor		1
Date / Time Analyzed		3.14.24 / 15:30
Analyst Initials		LD

Trivalent Chromium, mg/L	Calc.	< 0.0005
---------------------------------	-------	--------------------

TOTAL METALS ANALYSIS:

PARAMETER	METHOD	REPORTING LIMIT	DILUTION FACTOR	RESULT (mg/L)	DATE/TIME ANALYZED	ANALYST	QUALIFIER
Aluminum	EPA-200.8	0.0050	1	0.0892	3.16.24 / 02:58	JLJ	
Antimony	EPA-200.8	0.0005	1	0.0009	3.16.24 / 02:58	JLJ	
Arsenic	EPA-200.8	0.0005	1	0.0010	6.7.24 / 02:41	JLJ	
Barium	EPA-200.8	0.0005	1	0.0489	6.7.24 / 02:41	JLJ	
Beryllium	EPA-200.8	0.0005	1	< 0.0005	3.16.24 / 02:58	JLJ	
Cadmium	EPA-200.8	0.0005	1	< 0.0005	6.7.24 / 02:41	JLJ	
Chromium	EPA-200.8	0.0005	1	0.0005	3.16.24 / 02:58	JLJ	
Copper	EPA-200.8	0.0005	1	0.0075	3.16.24 / 02:58	JLJ	
Lead	EPA-200.8	0.0005	1	0.0005	3.16.24 / 02:58	JLJ	
Magnesium	EPA-200.8	0.05	1	4.44	3.16.24 / 02:58	JLJ	
Nickel	EPA-200.8	0.0005	1	0.0025	3.16.24 / 02:58	JLJ	
Silver	EPA-200.8	0.0005	1	< 0.0005	3.16.24 / 02:58	JLJ	
Selenium	EPA-200.8	0.0005	1	< 0.0005	6.7.24 / 02:41	JLJ	
Thallium	EPA-200.8	0.0005	1	< 0.0005	3.16.24 / 02:58	JLJ	
Zinc	EPA-200.8	0.0050	1	0.0609	3.16.24 / 02:58	JLJ	
Date Digested		3.13.24					
Time Digested		08:15					
Analyst Initials		JLJ					

BIO CHEM LAB, INC. PHONE: 254.829.8001 FAX: 254.829.8013
4751 TOKIO RD .WEST, TX 76691

ANALYTICAL REPORT**CLIENT IDENTIFICATION INFORMATION:**

CITY OF HILLSBORO
PO BOX 568
HILLSBORO, TX 76645
CLIENT CONTACT: TERRY DIETERICH

MARCH 2024 - HILLSBORO	
REPORT ID:	HIL- 061124
LAB CONTACT:	SHAY OCHOA
REPORT DATE:	6.11.24
QC SUMMARY	

QC ANALYTICAL DATA**CBOD**

SETUP DATE	SETUP ID	BATCH ID	
3.13.24	B-031324-10	B-031324-10-03	
DUPPLICATE	RESULT 1	RESULT 2	% DEV
6188-24	138	149	3.8
BOD-BLANK	CBOD-BLANK	LCS -GGA	LCS-CGGA
0.08	0.08	206	199

TSS

SETUP DATE	SETUP ID	BATCH ID	
3.13.24	T-031324-07	T-031324-07-03	
SAMPLE ID:	RESULT 1	RESULT 2	% DEV
6129-24	23.6	24.6	2.1
6146-24	24	23	2.3
BLANK, mg/L	<2	LCS % REC	99.6

SULFATE

SETUP DATE	SEQUENCE ID		
3.13.24-3.14.24	IC-031324-07		
SAMPLE ID	RESULT 1	RESULT 2	RPD
6221-24	128.7	131.3	2.0
SPIKE ID:	RESULT 1	RESULT 2	% REC
6221-24	128.7	211.4	82.8
IPCS-1 % REC:	97.3	IPCS-2 % REC:	108.6
LCS % REC:	100.3	LCSD % REC:	104.0
BLANK, mg/L:	<0.50		

CHLORIDE

SETUP DATE	SEQUENCE ID		
3.13.24-3.14.24	IC-031324-07		
SAMPLE ID	RESULT 1	RESULT 2	RPD
6221-24	71.9	73.2	1.8
SPIKE ID:	RESULT 1	RESULT 2	% REC
6221-24	71.9	174.0	102.1
IPCS-1 % REC:	99.3	IPCS-2 % REC:	109.9
LCS % REC:	107.5	LCSD % REC:	108.8
BLANK, mg/L:	<0.50		

TDS

DATE	SETUP ID	BATCH ID	
3.18.24	DS-031824-03	DS-031824-03-01	
SAMPLE ID:	RESULT 1	RESULT 2	% DEV
6208-24	624	656	2.5
SPIKE ID:	RESULT 1	RESULT 2	% REC
Q3 6441-24	1,616	1,902	57.2
BLANK, mg/L:	Q1 26.0	LCS, %REC	95.7

CONDUCTIVITY

SETUP DATE	SETUP ID		
3.22.24	EC-032224-03		
SAMPLE ID:	RESULT 1	RESULT 2	% DEV
667-24	307	307	0.0
LCS % REC	100.3	LCSD % REC	98.5
LRB, µmhos	<5	LOQ % REC	99.7

BIO CHEM LAB, INC. PHONE: 254.829.8001 FAX: 254.829.8013
4751 TOKIO RD .WEST, TX 76691

ANALYTICAL REPORT**CLIENT IDENTIFICATION INFORMATION:**

CITY OF HILLSBORO
PO BOX 568
HILLSBORO, TX 76645
CLIENT CONTACT: TERRY DIETERICH

MARCH 2024 - HILLSBORO	
REPORT ID:	HIL- 061124
LAB CONTACT:	SHAY OCHOA
REPORT DATE:	6.11.24
QC SUMMARY	

QC ANALYTICAL DATA**TOTAL ALKALINITY**

SETUP DATE	SETUP ID	BATCH ID	
3.22.24	ALK-032224-03	ALK-032224-03-01	
SAMPLE ID:	RESULT 1	RESULT 2	% DEV
6426-24	250.7	248.8	0.4
SPIKE ID:	RESULT 1	RESULT 2	% REC
6221-24	133.3	226.9	93.5
LRB-BLANK	LCS, %REC	LCSD, %REC	LOQ, % REC
<5	96.0	96.5	99.5

NITRATE AS N

SETUP DATE	SEQUENCE ID		
3.13.24-3.14.24	IC-031324-07		
SAMPLE ID	RESULT 1	RESULT 2	RPD
6221-24	2.8	2.8	0.0
SPIKE ID:	RESULT 1	RESULT 2	% REC
6221-24	2.8	103.7	101.0
IPCS-1 % REC:	97.8	IPCS-2 % REC:	102.3
LCS % REC:	103.8	LCSD % REC:	104.8
BLANK, mg/L:	<0.01		

NH3N

SETUP DATE:	SETUP ID:	BATCH ID:	
03.18.24	N-031824-11	N-031824-11-01	
SAMPLE ID:	RESULT 1:	RESULT 2:	% DEV:
6450-24	22.6	23.0	1.0
6507-24	71.2	72.4	0.8
SPIKE ID:	RESULT 1:	RESULT 2:	% REC:
6498-24	0.06	1.87	90.5
6498-24	0.06	1.84	89.0
BLANK, mg/L:	LCS % REC:	LCSD % REC:	
< 0.05	102.2	103.2	

TKN

SETUP DATE	SETUP ID	BATCH ID	
03.18.24	TKN-031824-03	TKN-031824-03-01	
SAMPLE ID:	RESULT 1:	RESULT 2:	% DEV
6205-24	206	179	6.9
6328-24	40.6	38.2	3.1
SPIKE ID:	RESULT 1:	RESULT 2:	% REC
6254-24	40.2	49.2	89.5
6254-24	40.2	49.3	90.5
BLANK, mg/L:	LCS % REC:	LCSD % REC:	
< 0.25		104.2	109.6

E COLI

SETUP DATE	SETUP ID	BATCH ID	
3.12.24	E-031224-07	E-031224-07-01	
DUPLICATE ID:	RESULT 1 :	RESULT 2 :	PRECISION
6145-24	6	13	QM1 0.31
6164-24	<2	<2	0.00
BLANK, MPN	PRECISION RANGE		
<1	0.0-0.15		

BIO CHEM LAB, INC. **PHONE: 254.829.8001** **FAX: 254.829.8013**
4751 TOKIO RD .WEST, TX 76691
ANALYTICAL REPORT**CLIENT IDENTIFICATION INFORMATION:**

CITY OF HILLSBORO
PO BOX 568
HILLSBORO, TX 76645
CLIENT CONTACT: TERRY DIETERICH

MARCH 2024 - HILLSBORO	
REPORT ID:	HIL- 061124
LAB CONTACT:	SHAY OCHOA
REPORT DATE:	6.11.24
QC SUMMARY	

OIL AND GREASE

SETUP DATE	SETUP ID	BATCH ID	
3.18.24	OG-031824-03	OG-031824-03-01	
DUPLICATE ID:	RESULT 1 :	RESULT 2 :	% DEV
734121604	38.2	37.2	1.3
BLANK, mg/L:	QCS % REC:	LCS % REC:	LCSD % REC:
<1.4	---	95.5	93.0

HEXAVALENT CHROMIUM

SETUP DATE	SETUP ID	BATCH ID	
3.14.24	HC-031424-02	HC-031424-02-01	
SAMPLE ID:	RESULT 1	RESULT 2	% DEV
13317	0.049	0.050	0.9
SPIKE ID:	RESULT 1	RESULT 2	% REC
5909-24	0.00	0.052	104.0
5909-24	0.00	0.052	104.0
BLANK, mg/L	LCS, %REC	LCSD, %REC	
< 0.003	97.7	99.53	

METALS

Batch ID	ICP-031524-05-02		Date Analyzed	3.16.24	MS Sample ID	6156-24					Flags
PARAMETER	Blank	LCS % Rec	LCSD % Rec	LCS %RPD	Reference Sample	Matrix Spike	MS % Rec	Matrix Spike Duplicate	MSD % Rec		Flags
Total Aluminum, mg/L	<0.005	98.9	100.3	1.41	0.1352	0.5333	99.5	0.5348	99.9		
Total Antimony, mg/L	<0.0005	98.7	100.2	1.51	0.001	0.4193	104.6	0.4194	104.6		
Total Beryllium, mg/L	<0.0005	100.3	101.3	0.99	0	0.42	105.0	0.4102	102.6		
Total Chromium, mg/L	<0.0005	102.8	103.2	0.39	0.0007	0.4213	105.2	0.4213	105.2		
Total Copper, mg/L	<0.0005	104.6	105.2	0.57	0.0104	0.4488	109.6	0.4405	107.5		
Total Lead, mg/L	<0.0005	98	97.1	0.92	0.0006	0.4065	101.5	0.399	99.6		
Total Magnesium, mg/L	<0.05	99.7	99.8	0.10	4.5149	45.4483	102.3	45.2149	101.8		
Total Nickel, mg/L	<0.0005	103.5	103.6	0.10	0.0023	0.4292	106.7	0.4258	105.9		
Total Silver, mg/L	<0.0005	96.7	99.4	2.75	0	0.3895	97.4	0.4	100.0		
Total Thallium, mg/L	<0.0005	102.6	102	0.59	0	0.4255	106.4	0.4204	105.1		
Total Zinc, mg/L	<0.005	104.5	104.8	0.29	0.062	0.4941	108.0	0.4889	106.7		

Batch ID	ICP-060724-01-01		Date Analyzed	6.7.24	MS Sample ID	12396-24					Flags
PARAMETER	Blank	LCS % Rec	LCSD % Rec	LCS %RPD	Reference Sample	Matrix Spike	MS % Rec	Matrix Spike Duplicate	MSD % Rec		Flags
Total Arsenic, mg/L	<0.0005	98.9	98.9	0.00	0.0011	0.4091	102.0	0.4121	102.8		
Total Barium, mg/L	<0.0005	102.8	101.2	1.57	0.0524	0.4865	108.5	0.4915	109.8		
Total Cadmium, mg/L	<0.0005	102.1	101.6	0.49	0	0.4303	107.6	0.4271	106.8		
Total Selenium, mg/L	<0.0005	101.5	100.6	0.89	0	0.407	101.8	0.4093	102.3		

ANALYTICAL NOTES, INTERPRETATIONS, METHOD DEVIATIONS OR ENVIRONMENTAL CONDITIONS:

NONE TO REPORT.

STATEMENT OF COMPLIANCE/NON-COMPLIANCE:

The above analytical data was derived from submitted samples that have met all established acceptance criteria, unless otherwise qualified, and are compliant with the laboratory's Quality System. The Director of Operations or designee has authorized the release of this report. The results contained herein relate only to the Laboratory Sample ID(s) documented above. This analytical test report may not be reproduced except in full, without the written approval of the laboratory.

Quality Assurance / Quality Control Data associated with results within this report are documented in the attached QA/QC Report.

Please contact 254.829.8001 with any questions or concerns.



A. Shay Ochoa, Technical Director
Bio Chem Lab, Inc.



BIO CHEM LAB, INC. **PHONE: 254.829.8001** **FAX: 254.829.8013**
4751 TOKIO RD .WEST, TX 76691

ANALYTICAL REPORT**CLIENT IDENTIFICATION INFORMATION:**

CITY OF HILLSBORO
PO BOX 568
HILLSBORO, TX 76645
CLIENT CONTACT: TERRY DIETERICH

MARCH 2024 - HILLSBORO	
REPORT ID:	HIL- 061124
LAB CONTACT:	SHAY OCHOA
REPORT DATE:	6.11.24

BCL PROJECT DATA QUALIFIERS:

- Q** Failed Quality Data. Refer to QA/QC Report of the affected data for specific details.
- Q1** Blank outside desired limits. Data accepted based on passing batch LCS recoveries.
- Q2** LCS recovery outside desired limits. Data accepted on basis of additional narrative if applicable
- Q3** Matrix Spike and/or Matrix Spike Duplicate outside desired limits. Data accepted on basis of passing LCS recoveries.
- QS3** Matrix Spike and/or Matrix Spike Duplicate outside desired limits. Sample not spiked at a high enough concentration to be statistically different from the native sample result. Data accepted on basis of passing LCS recoveries.
- Q4** Sample specific duplicate precision outside desired range.
- QM1** Microbiology precision unable to be evaluated due to low background concentration (< 10 CFU / MPN) of target analyte
- QM2** Microbiology precision unable to be evaluated due to high background concentration (> 2420 CFU / MPN) of target analyte
- QM3** Microbiology precision outside desired range.
- B1** Results for CBOD / BOD reported as less than [< 2 mg/L] with no sample dilution depleting method required 2.00 mg/L
- B2** Results for CBOD / BOD reported as an estimate due to no dilution meeting a method stated depletion criteria.
- B3** Result for CBOD / BOD unable to be determined due to excessive oxidant content, high chlorine residual.
- W1** Result is an average of multiple weighing / drying cycles.
- C** Reported result over the laboratory's calibration range
- C1** Reported result over the laboratory's calibration range but within the laboratory verified Linear Dynamic Range.
- J5** Reported result less than the laboratory reporting limit but greater than the Limit of Detection.
- ND** Not detected
- V** Additional sample volume would have been required to meet analytical method specifications.
- HT** Sample analysis performed outside method / regulatory prescribed holding time.
- T** Sample received outside method / regulatory prescribed requirements for thermal preservation.
- P** Sample received outside method / regulatory prescribed requirements for pH preservation.
- A** Accreditation for analysis performed is either not currently offered or is currently outside the laboratory's scope of accreditation.
- N** The associated analysis was performed by a network / sub-contract laboratory.
- L** Laboratory Error
- PW** Potable Water
- NPW** Non-Potable Water
- Z** Refer to additional notes / supplemental narrative

ADDITIONAL NOTES:

BIO CHEM LAB, INC. PHONE: 254.829.8001 FAX: 254.829.8013
4751 TOKIO RD .WEST, TX 76691

ANALYTICAL REPORT

CLIENT IDENTIFICATION INFORMATION:

CITY OF HILLSBORO
PO BOX 568
HILLSBORO, TX 76645
CLIENT CONTACT: TERRY DIETERICH



OFFICE NO.: 254.829.8001
FAX NO.: 254.829.8013
CELL NO.: 254.749.4320

EMERGENCY: 254-749-4330

SERVICE • VISION • COMMUNITY • COMMITMENT

BIO CHEM LAB, INC

P.O. BOX 356
4751 TOKIO ROAD
WEST, TX 76691-0356
E-MAIL : CUSTOMERSERVICE@BIOCHEMILAB.COM

EMERGENCY: 234-789-4320				
SERVICE • VISION • COMMUNITY • COMMITMENT				
CLIENT / PROJECT: CITY OF HILLSBORO - PERMIT RENEWAL		CONTACT: TERRY DIETERICH	COLLECTED BY: Gibby Ficke	
ADDRESS: P.O. BOX 568	HILLSBORO, TX 76645	PHONE NO.: 254-744-5117	FIELD DATA: pH 6.8	DO 6.1 TEMP 21.2°C
		EMAIL:	FLOW	DATE/TIME 3-12-24 - 10000

PROJECT COMMENTS / SAMPLING PROCEDURES:

Antimony (Sb) is a metalloid element with the symbol Sb and atomic number 51. It is found in the Earth's crust at approximately 0.001% concentration. Sb is a silvery-white metal that is brittle at room temperature but becomes malleable when heated. It has a high melting point of 630°C and a high boiling point of 1,700°C.

(1) Na_2U_3 (2) Na_2U_4 (3) Na_2U_5 (4) Na_2U_6 (5) Na_2U_7 (6) Na_2U_8

Container: <input checked="" type="checkbox"/> Plastic <input type="checkbox"/> Amber Plastic		<input checked="" type="checkbox"/> Clear Glass <input type="checkbox"/> Amber Glass	<input checked="" type="checkbox"/> Bact / MICR <input type="checkbox"/> B - w/lnr Pak / BAG	<input checked="" type="checkbox"/> VOA - 40 mL vial <input type="checkbox"/> OTHER _____	Describe: _____
SH STRIPS: <input checked="" type="checkbox"/> (0-6) 72551576		[7.5-14]: _____		CUSTODY SEALS: <input checked="" type="checkbox"/>	COOLER <input type="checkbox"/> CONTAINERS <input type="checkbox"/> NA/NO
ADDITIONAL PRESERVATION / SAMPLE INTEGRITY NOTES:					
REQUESTED TAT: <input checked="" type="checkbox"/> STANDARD (7-10 DAYS) <input type="checkbox"/> BCL EXPRESS (5-6 DAYS) (1.25X) <input type="checkbox"/> BCL PRIORITY (3-4 DAYS) (1.5X) <input type="checkbox"/> BCL FIRE (1-2 DAYS) (2.0X) Rush service availability may depend on logistics and method.					
SEALS INTACT: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO					

ADDITIONAL PRESERVATION / SAMPLE INTEGRITY NOTES:

REQUESTED TAT: STANDARD (7-10 DAYS) — BCL EXPRESS (5-6 DAYS) (1.25X) — BCL PRIORITY (3-4 DAYS) (1.5X) — BCL FIRE (1-2 DAYS) (2.0X) Rush service availability may depend on logistics and method.

o Chem Lab, Inc.

ANALYTICAL REPORT

PREPARED FOR

Attn: A. Shay Ochoa
Bio Chem Lab, Inc
4751 Tokio Rd
West, Texas 76691

Generated 4/14/2024 6:09:16 PM

JOB DESCRIPTION

City of Hillsboro Permit Renewal

JOB NUMBER

860-69911-1

Eurofins Houston

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization



Generated
4/14/2024 6:09:16 PM

Authorized for release by
Travis Richter, Project Manager
Travis.Richter@et.eurofinsus.com
(281)794-7216

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	6
Detection Summary	9
Client Sample Results	10
Surrogate Summary	17
Isotope Dilution Summary	20
QC Sample Results	22
QC Association Summary	47
Lab Chronicle	52
Certification Summary	53
Method Summary	55
Sample Summary	56
Subcontract Data	57
Chain of Custody	71
Field Data Sheets	78
Receipt Checklists	79

Definitions/Glossary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
U	Indicates the analyte was analyzed for but not detected.

GC/MS Semi VOA

Qualifier	Qualifier Description
*-	LCS and/or LCSD is outside acceptance limits, low biased.
*1	LCS/LCSD RPD exceeds control limits.
H	Sample was prepped or analyzed beyond the specified holding time. This does not meet regulatory requirements.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
S1+	Surrogate recovery exceeds control limits, low biased.
U	Indicates the analyte was analyzed for but not detected.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
H	Sample was prepped or analyzed beyond the specified holding time. This does not meet regulatory requirements.
U	Indicates the analyte was analyzed for but not detected.

GC Semi VOA

Qualifier	Qualifier Description
*+	LCS and/or LCSD is outside acceptance limits, high biased.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
S1+	Surrogate recovery exceeds control limits, high biased.
U	Indicates the analyte was analyzed for but not detected.

HPLC/IC

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

Dioxin

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

Metals

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

General Chemistry

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

Glossary

Abbreviation

These commonly used abbreviations may or may not be present in this report.

□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"

Definitions/Glossary

Client: Bio Chem Lab, Inc

Project/Site: City of Hillsboro Permit Renewal

Job ID: 860-69911-1

Glossary (Continued)

Abbreviation	These commonly used abbreviations may or may not be present in this report.
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: Bio Chem Lab, Inc
Project: City of Hillsboro Permit Renewal

Job ID: 860-69911-1

Job ID: 860-69911-1

Eurofins Houston

Job Narrative 860-69911-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The sample was received on 3/13/2024 2:35 PM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 2 coolers at receipt time were 2.3°C and 2.6°C.

Receipt Exceptions

The following sample was received at the laboratory outside the required temperature criteria: 6221-24 Hillsbors Permit Renewal (860-69911-1). Sample 1 was received out of temp in Sacramento at 12.9C. FedEx tag has delivery for FRI - 15 MAR but was received on 3/18/2024. Containers are 1 L amber glass unpreserved (Containers H, I, J & K).

Subcontract Work

Methods Hexachlorophene, Table 4.0 (1) - Organophosphorous Pesticides (GC): These methods were subcontracted to Ana-Lab Corporation. The subcontract laboratory certifications are different from that of the facility issuing the final report. The subcontract report is appended in its entirety.

Method Asbestos: This method was subcontracted to EMLab P&K. The subcontract laboratory certification is different from that of the facility issuing the final report. The subcontract report is appended in its entirety.

GC/MS VOA

Method 624.1: The continuing calibration verification (CCV) associated with batch 860-149796 recovered outside acceptance criteria, low biased, for Bromomethane (-21.8%). A reporting limit (RL) standard was analyzed, and the target analytes are detected. Since the associated samples were non-detect for the analyte(s), the data are reported.

Method 624.1: The matrix spike (MS) recoveries for analytical batch 860-149796 were outside control limits. Sample matrix interference is suspected because the associated laboratory control sample (LCS) recovery was within acceptance limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

GC/MS Semi VOA

Method 625.1: The surrogate recovery for the method blank associated with preparation batch 860-150228 and analytical batch 860-150257 was outside the control limits.

Method 625.1: Six surrogates are used for this analysis. The laboratory's SOP allows one acid and one base of these surrogates to be outside acceptance criteria without performing re-extraction/re-analysis. The following sample contained an allowable number of surrogate compounds outside limits: 6221-24 Hillsbors Permit Renewal (860-69911-1). These results have been reported and qualified.

Method 625.1: Six surrogates are used for this analysis. The laboratory's SOP allows one acid and one base of these surrogates to be outside acceptance criteria without performing re-extraction/re-analysis. The following sample contained an allowable number of surrogate compounds outside limits: 6221-24 Hillsbors Permit Renewal (860-69911-1). These results have been reported and qualified.

Method 625.1: The laboratory control sample and the laboratory control sample duplicate (LCS/LCSD) for preparation batch 860-150805 and analytical batch 860-150908 recovered outside control limits for the following analyte: Benzidine. Benzidine has been identified as a poor performing analyte when analyzed using this method; therefore, re-extraction/re-analysis was not performed. Batch precision also exceeded control limits for this analyte. These results have been reported and qualified.

Eurofins Houston

Case Narrative

Client: Bio Chem Lab, Inc
Project: City of Hillsboro Permit Renewal

Job ID: 860-69911-1

Job ID: 860-69911-1 (Continued)

Eurofins Houston

Method 625.1: The following sample was re-prepared outside of preparation holding time due to initial analysis LCS/LCSD recoveries outside control limits (low biased).: 6221-24 Hillsbors Permit Renewal (860-69911-1).

Method 625.1: The surrogate recovery for the blank associated with preparation batch 860-150805 and analytical batch 860-150908 was outside the control limits.

Method 625.1: The laboratory control sample and/or the laboratory control sample duplicate (LCS/LCSD) for preparation batch 860-150228 and analytical batch 860-150257 recovered outside control limits for the following analytes: 1,2,4-Trichlorobenzene, 2-Chloronaphthalene, Fluorene and Hexachloroethane. The associated sample was re-prepared and/or re-analyzed outside holding time. Both sets of data have been reported.

Method 625.1: The RPD of the laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) for preparation batch 860-150228 and analytical batch 860-150257 recovered outside control limits for the following analytes: Benzidine and Pyridine.

Method 625.1: The laboratory control sample and/or the laboratory control sample duplicate (LCS/LCSD) for preparation batch 860-150228 and analytical batch 860-150257 recovered outside control limits for the following analyte(s): Benzidine. Benzidine has been identified as a poor performing analyte when analyzed using this method; therefore, re-extraction/re-analysis was not performed. Batch precision also exceeded control limits for these analyte(s). These results have been reported and qualified.

Method Organotins_SIM: The laboratory control sample (LCS) was performed in duplicate (LCSD) to provide precision data for this batch.

Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with preparation batch 570-421863.O'TIN-W

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

GC Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

PCBs

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Pesticides

Method 608.3_Pest: The surrogate recovery for the laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) associated with preparation batch 860-150340 and analytical batch 860-150874 was outside the upper control limits.

(LCS 860-150340/2-A) and (LCSD 860-150340/3-A)

Method 608.3_Pest: The continuing calibration verification (CCV) associated with batch 860-150874 recovered above the upper control limit for 4,4'-DDT, Heptachlor and Methoxychlor. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported. The associated sample is impacted: (CCVRT 860-150874/4).

Method 608.3_Pest: The laboratory control sample (LCS) for preparation batch 860-150340 and analytical batch 860-150874 recovered outside control limits for the following analytes: 4,4'-DDD, Endrin aldehyde, Heptachlor and Methoxychlor. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Method 608.3_Pest: The laboratory control sample duplicate (LCSD) for preparation batch 860-150340 and analytical batch 860-150874 recovered outside control limits for the following analytes: Endrin aldehyde, Heptachlor and Methoxychlor. These analytes were biased high in the LCSD and were not detected in the associated samples; therefore, the data have been reported.

Method 608.3_Pest: Surrogate recovery for the following sample was outside the upper control limit: 6221-24 Hillsbors Permit Renewal (860-69911-1). This sample did not contain any target analytes; therefore, re-extraction and/or re-analysis was not performed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

HPLC/IC

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Houston

Case Narrative

Client: Bio Chem Lab, Inc
Project: City of Hillsboro Permit Renewal

Job ID: 860-69911-1

Job ID: 860-69911-1 (Continued)

Eurofins Houston

Dioxin

Method 1613B: The window defining mixture (WDM) associated with 320-751471 exceeded the 25% valley resolution requirement for 2,3,7,8-TCDD on the DB-5 column analysis. The impact to the data is minimal as associated field samples were non-detect for 2,3,7,8-TCDD.

(WDM 320-751471/1)

Method 1613B: EPA Method 1613B specifies a +/- 15 second retention time difference between the recovery standard in the initial calibration (ICAL) and the continuing calibration verification (CCV). The 13C-1,2,3,4-TCDD and 13C-1,2,3,7,8,9-HxCDD associated with the following samples run on instrument DFS 1 exceeded this criteria: (CCV 320-751471/2), (LCS 320-748976/2-A), (LCSD 320-748976/3-A) and (MB 320-748976/1-A). This retention time shift is due to normal and reasonable column maintenance and does not affect the instrument chromatography resolution, sensitivity, or identification of target analytes. System retention times have been updated for proper analyte identification.

Method 1613B: EPA Method 1613B specifies a +/- 15 second retention time difference between the recovery standard in the initial calibration (ICAL) and the continuing calibration verification (CCV). The 13C-1,2,3,4-TCDD and 13C-1,2,3,7,8,9-HxCDD associated with the following samples run on instrument DFS 1 exceeded this criteria: 6221-24 Hillsbors Permit Renewal (860-69911-1) and (CCV 320-752263/2). This retention time shift is due to normal and reasonable column maintenance and does not affect the instrument chromatography resolution, sensitivity, or identification of target analytes. System retention times have been updated for proper analyte identification.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

General Chemistry

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Tributyltin	14.5		2.96	1.12	ng/L	1		Organotins SIM	Total/NA
Mercury	2.71		0.500	0.200	ng/L	1		1631E	Total/NA
Boron	0.254		0.0500	0.0173	mg/L	1		200.7 Rev 4.4	Total Recoverable
Cyanide, Non-amenable	0.00567		0.00500	0.00233	mg/L	1		4500 CN G NonAm	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Houston

Client Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Date Collected: 03/12/24 10:00

Matrix: Water

Date Received: 03/13/24 14:35

Method: EPA 624.1 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1-Trichloroethane	ND	U	10.0	0.585	ug/L			03/15/24 00:32	1
1,1,2,2-Tetrachloroethane	ND	U	10.0	0.470	ug/L			03/15/24 00:32	1
1,1,2-Trichloroethane	ND	U	10.0	0.411	ug/L			03/15/24 00:32	1
1,1-Dichloroethane	ND	U	10.0	0.635	ug/L			03/15/24 00:32	1
1,1-Dichlorethylene	ND	U	10.0	0.738	ug/L			03/15/24 00:32	1
1,2-Dibromoethane	ND	U	10.0	0.999	ug/L			03/15/24 00:32	1
1,2-Dichlorobenzene	ND	U	10.0	0.429	ug/L			03/15/24 00:32	1
1,2-Dichloroethane	ND	U	10.0	0.372	ug/L			03/15/24 00:32	1
1,2-Dichloropropane	ND	U	10.0	0.556	ug/L			03/15/24 00:32	1
1,3-Dichlorobenzene	ND	U	10.0	0.413	ug/L			03/15/24 00:32	1
1,4-Dichlorobenzene	ND	U	10.0	0.449	ug/L			03/15/24 00:32	1
Methyl Ethyl Ketone	ND	U	50.0	8.28	ug/L			03/15/24 00:32	1
2-Chloroethyl vinyl ether	ND	U	10.0	0.753	ug/L			03/15/24 00:32	1
Acrolein	ND	U F1	50.0	11.1	ug/L			03/15/24 00:32	1
Acrylonitrile	ND	U	50.0	14.3	ug/L			03/15/24 00:32	1
Benzene	ND	U	10.0	0.460	ug/L			03/15/24 00:32	1
Dichlorobromomethane	ND	U	10.0	0.552	ug/L			03/15/24 00:32	1
Bromoform	ND	U	10.0	0.633	ug/L			03/15/24 00:32	1
Carbon tetrachloride	ND	U	2.00	0.896	ug/L			03/15/24 00:32	1
Chlorobenzene	ND	U	10.0	0.455	ug/L			03/15/24 00:32	1
Chloroethane	ND	U	50.0	1.98	ug/L			03/15/24 00:32	1
Chloroform	ND	U	10.0	0.464	ug/L			03/15/24 00:32	1
Methyl chloride	ND	U	50.0	2.04	ug/L			03/15/24 00:32	1
Chlorodibromomethane	ND	U	10.0	0.547	ug/L			03/15/24 00:32	1
Ethylbenzene	ND	U	10.0	0.385	ug/L			03/15/24 00:32	1
Methylene Chloride	ND	U	20.0	1.73	ug/L			03/15/24 00:32	1
Tetrachloroethylene	ND	U	10.0	0.655	ug/L			03/15/24 00:32	1
Toluene	ND	U	10.0	0.475	ug/L			03/15/24 00:32	1
Trichloroethylene	ND	U	10.0	1.50	ug/L			03/15/24 00:32	1
Trihalomethanes, Total	ND	U	10.0	0.633	ug/L			03/15/24 00:32	1
Vinyl chloride	ND	U	10.0	0.428	ug/L			03/15/24 00:32	1
1,2-trans-Dichloroethylene	ND	U	10.0	0.368	ug/L			03/15/24 00:32	1
1,3-Dichloropropene, Total	ND	U	5.00	1.27	ug/L			03/15/24 00:32	1
Surrogate	%Recovery	Qualifier	Limits			D	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	89		63 - 144					03/15/24 00:32	1
Toluene-d8 (Surr)	97		80 - 120					03/15/24 00:32	1

Method: EPA 624.1 - Volatile Organic Compounds (GC/MS) - RA

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Methyl bromide	ND	U	50.0	1.42	ug/L			03/15/24 15:01	1
Surrogate	%Recovery	Qualifier	Limits			D	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	114		63 - 144					03/15/24 15:01	1
Toluene-d8 (Surr)	102		80 - 120					03/15/24 15:01	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,4,5-Tetrachlorobenzene	ND	U	10.0	1.32	ug/L		03/18/24 09:27	03/19/24 15:27	1
1,2,4-Trichlorobenzene	ND	U *-	10.0	1.61	ug/L		03/18/24 09:27	03/19/24 15:27	1

Eurofins Houston

Client Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Date Collected: 03/12/24 10:00

Matrix: Water

Date Received: 03/13/24 14:35

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,2-Diphenylhydrazine	ND	U	10.0	1.49	ug/L		03/18/24 09:27	03/19/24 15:27	1
bis (2-chloroisopropyl) ether	ND	U	10.0	1.79	ug/L		03/18/24 09:27	03/19/24 15:27	1
2,4,5-Trichlorophenol	ND	U	10.0	2.00	ug/L		03/18/24 09:27	03/19/24 15:27	1
2,4,6-Trichlorophenol	ND	U	10.0	1.42	ug/L		03/18/24 09:27	03/19/24 15:27	1
2,4-Dichlorophenol	ND	U	10.0	0.314	ug/L		03/18/24 09:27	03/19/24 15:27	1
2,4-Dimethylphenol	ND	U	10.0	0.649	ug/L		03/18/24 09:27	03/19/24 15:27	1
2,4-Dinitrophenol	ND	U	50.0	1.61	ug/L		03/18/24 09:27	03/19/24 15:27	1
2,4-Dinitrotoluene	ND	U	10.0	1.31	ug/L		03/18/24 09:27	03/19/24 15:27	1
2,6-Dinitrotoluene	ND	U	10.0	1.61	ug/L		03/18/24 09:27	03/19/24 15:27	1
2-Choronaphthalene	ND	U*-	10.0	0.462	ug/L		03/18/24 09:27	03/19/24 15:27	1
2-Chlorophenol	ND	U	10.0	0.649	ug/L		03/18/24 09:27	03/19/24 15:27	1
2-Nitrophenol	ND	U	20.0	1.67	ug/L		03/18/24 09:27	03/19/24 15:27	1
o-Cresol	ND	U	10.0	1.62	ug/L		03/18/24 09:27	03/19/24 15:27	1
m & p - Cresol	ND	U	10.0	2.62	ug/L		03/18/24 09:27	03/19/24 15:27	1
3,3'-Dichlorobenzidine	ND	U	5.00	0.341	ug/L		03/18/24 09:27	03/19/24 15:27	1
4,6-Dinitro-o-cresol	ND	U	50.0	1.44	ug/L		03/18/24 09:27	03/19/24 15:27	1
4-Bromophenyl phenyl ether	ND	U	10.0	0.256	ug/L		03/18/24 09:27	03/19/24 15:27	1
4-Chlorophenyl phenyl ether	ND	U	10.0	1.28	ug/L		03/18/24 09:27	03/19/24 15:27	1
4-Nitrophenol	ND	U	50.0	4.91	ug/L		03/18/24 09:27	03/19/24 15:27	1
p-Chloro-m-cresol	ND	U	10.0	1.57	ug/L		03/18/24 09:27	03/19/24 15:27	1
Acenaphthene	ND	U	10.0	1.39	ug/L		03/18/24 09:27	03/19/24 15:27	1
Acenaphthylene	ND	U	10.0	1.41	ug/L		03/18/24 09:27	03/19/24 15:27	1
Aniline	ND	U	10.0	0.969	ug/L		03/18/24 09:27	03/19/24 15:27	1
Anthracene	ND	U	10.0	1.50	ug/L		03/18/24 09:27	03/19/24 15:27	1
Benzidine	ND	U*- *1	50.0	4.80	ug/L		03/18/24 09:27	03/19/24 15:27	1
Benzo[a]anthracene	ND	U	5.00	0.173	ug/L		03/18/24 09:27	03/19/24 15:27	1
Benzo[a]pyrene	ND	U	5.00	0.364	ug/L		03/18/24 09:27	03/19/24 15:27	1
Benzo[b]fluoranthene	ND	U	10.0	2.04	ug/L		03/18/24 09:27	03/19/24 15:27	1
Benzo[g,h,i]perylene	ND	U	20.0	2.68	ug/L		03/18/24 09:27	03/19/24 15:27	1
Benzo[k]fluoranthene	ND	U	5.00	0.375	ug/L		03/18/24 09:27	03/19/24 15:27	1
Butyl benzyl phthalate	ND	U	10.0	0.337	ug/L		03/18/24 09:27	03/19/24 15:27	1
Chrysene	ND	U	5.00	0.222	ug/L		03/18/24 09:27	03/19/24 15:27	1
Dibenz(a,h)anthracene	ND	U	5.00	0.246	ug/L		03/18/24 09:27	03/19/24 15:27	1
Diethyl phthalate	ND	U	10.0	1.59	ug/L		03/18/24 09:27	03/19/24 15:27	1
Dimethyl phthalate	ND	U	10.0	0.299	ug/L		03/18/24 09:27	03/19/24 15:27	1
Fluoranthene	ND	U	10.0	1.59	ug/L		03/18/24 09:27	03/19/24 15:27	1
Fluorene	ND	U*-	10.0	1.63	ug/L		03/18/24 09:27	03/19/24 15:27	1
Hexachlorobenzene	ND	U	5.00	0.307	ug/L		03/18/24 09:27	03/19/24 15:27	1
Hexachlorobutadiene	ND	U	10.0	0.238	ug/L		03/18/24 09:27	03/19/24 15:27	1
Hexachlorocyclopentadiene	ND	U	10.0	4.58	ug/L		03/18/24 09:27	03/19/24 15:27	1
Hexachloroethane	ND	U*-	20.0	0.526	ug/L		03/18/24 09:27	03/19/24 15:27	1
Indeno[1,2,3-cd]pyrene	ND	U	5.00	2.29	ug/L		03/18/24 09:27	03/19/24 15:27	1
Isophorone	ND	U	10.0	1.64	ug/L		03/18/24 09:27	03/19/24 15:27	1
N-Nitrosodi-n-butylamine	ND	U	20.0	1.49	ug/L		03/18/24 09:27	03/19/24 15:27	1
N-Nitrosodiethylamine	ND	U	20.0	1.75	ug/L		03/18/24 09:27	03/19/24 15:27	1
N-Nitrosodimethylamine	ND	U	50.0	2.02	ug/L		03/18/24 09:27	03/19/24 15:27	1
Naphthalene	ND	U	10.0	0.542	ug/L		03/18/24 09:27	03/19/24 15:27	1
Nitrobenzene	ND	U	10.0	1.66	ug/L		03/18/24 09:27	03/19/24 15:27	1
Pentachlorobenzene	ND	U	20.0	1.07	ug/L		03/18/24 09:27	03/19/24 15:27	1

Eurofins Houston

Client Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Date Collected: 03/12/24 10:00

Matrix: Water

Date Received: 03/13/24 14:35

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Pentachlorophenol	ND	U	5.00	0.234	ug/L		03/18/24 09:27	03/19/24 15:27	1
Phenanthrene	ND	U	10.0	1.42	ug/L		03/18/24 09:27	03/19/24 15:27	1
Phenol	ND	U	10.0	0.423	ug/L		03/18/24 09:27	03/19/24 15:27	1
Pyrene	ND	U	10.0	0.178	ug/L		03/18/24 09:27	03/19/24 15:27	1
Pyridine	ND	U *1	20.0	2.64	ug/L		03/18/24 09:27	03/19/24 15:27	1
Bis(2-chloroethyl)ether	ND	U	10.0	2.16	ug/L		03/18/24 09:27	03/19/24 15:27	1
Bis(2-chloroethoxy)methane	ND	U	10.0	1.76	ug/L		03/18/24 09:27	03/19/24 15:27	1
Bis(2-ethylhexyl) phthalate	ND	U	10.0	0.277	ug/L		03/18/24 09:27	03/19/24 15:27	1
Di-n-butyl phthalate	ND	U	10.0	0.252	ug/L		03/18/24 09:27	03/19/24 15:27	1
Di-n-octyl phthalate	ND	U	10.0	0.373	ug/L		03/18/24 09:27	03/19/24 15:27	1
N-Nitrosodi-n-propylamine	ND	U	20.0	2.88	ug/L		03/18/24 09:27	03/19/24 15:27	1
N-Nitrosodiphenylamine	ND	U	20.0	1.81	ug/L		03/18/24 09:27	03/19/24 15:27	1
Total Cresols	ND	U	10.0	2.62	ug/L		03/18/24 09:27	03/19/24 15:27	1
Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
bis(2-chloromethyl)ether TIC	ND	U	ug/L			542-88-1	03/18/24 09:27	03/19/24 15:27	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2-Fluorophenol (Surr)	20	S1-	28 - 114				03/18/24 09:27	03/19/24 15:27	1
Phenol-d5 (Surr)	13		8 - 424				03/18/24 09:27	03/19/24 15:27	1
Nitrobenzene-d5 (Surr)	54		15 - 314				03/18/24 09:27	03/19/24 15:27	1
2-Fluorobiphenyl	48		29 - 112				03/18/24 09:27	03/19/24 15:27	1
2,4,6-Tribromophenol (Surr)	56		31 - 132				03/18/24 09:27	03/19/24 15:27	1
p-Terphenyl-d14 (Surr)	64		20 - 141				03/18/24 09:27	03/19/24 15:27	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS) - RE

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,4,5-Tetrachlorobenzene	ND	U H	10.0	1.32	ug/L		03/20/24 16:17	03/22/24 00:57	1
1,2,4-Trichlorobenzene	ND	U H	10.0	1.61	ug/L		03/20/24 16:17	03/22/24 00:57	1
1,2-Diphenylhydrazine	ND	U H	10.0	1.49	ug/L		03/20/24 16:17	03/22/24 00:57	1
bis (2-chloroisopropyl) ether	ND	U H	10.0	1.79	ug/L		03/20/24 16:17	03/22/24 00:57	1
2,4,5-Trichlorophenol	ND	U H	10.0	2.00	ug/L		03/20/24 16:17	03/22/24 00:57	1
2,4,6-Trichlorophenol	ND	U H	10.0	1.42	ug/L		03/20/24 16:17	03/22/24 00:57	1
2,4-Dichlorophenol	ND	U H	10.0	0.314	ug/L		03/20/24 16:17	03/22/24 00:57	1
2,4-Dimethylphenol	ND	U H	10.0	0.649	ug/L		03/20/24 16:17	03/22/24 00:57	1
2,4-Dinitrophenol	ND	U H	50.0	1.61	ug/L		03/20/24 16:17	03/22/24 00:57	1
2,4-Dinitrotoluene	ND	U H	10.0	1.31	ug/L		03/20/24 16:17	03/22/24 00:57	1
2,6-Dinitrotoluene	ND	U H	10.0	1.61	ug/L		03/20/24 16:17	03/22/24 00:57	1
2-Chloronaphthalene	ND	U H	10.0	0.462	ug/L		03/20/24 16:17	03/22/24 00:57	1
2-Chlorophenol	ND	U H	10.0	0.649	ug/L		03/20/24 16:17	03/22/24 00:57	1
2-Nitrophenol	ND	U H	20.0	1.67	ug/L		03/20/24 16:17	03/22/24 00:57	1
o-Cresol	ND	U H	10.0	1.62	ug/L		03/20/24 16:17	03/22/24 00:57	1
m & p - Cresol	ND	U H	10.0	2.62	ug/L		03/20/24 16:17	03/22/24 00:57	1
3,3'-Dichlorobenzidine	ND	U H	5.00	0.341	ug/L		03/20/24 16:17	03/22/24 00:57	1
4,6-Dinitro-o-cresol	ND	U H	50.0	1.44	ug/L		03/20/24 16:17	03/22/24 00:57	1
4-Bromophenyl phenyl ether	ND	U H	10.0	0.256	ug/L		03/20/24 16:17	03/22/24 00:57	1
4-Chlorophenyl phenyl ether	ND	U H	10.0	1.28	ug/L		03/20/24 16:17	03/22/24 00:57	1
4-Nitrophenol	ND	U H	50.0	4.91	ug/L		03/20/24 16:17	03/22/24 00:57	1
p-Chloro-m-cresol	ND	U H	10.0	1.57	ug/L		03/20/24 16:17	03/22/24 00:57	1
Acenaphthene	ND	U H	10.0	1.39	ug/L		03/20/24 16:17	03/22/24 00:57	1

Eurofins Houston

Client Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Date Collected: 03/12/24 10:00

Matrix: Water

Date Received: 03/13/24 14:35

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS) - RE (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acenaphthylene	ND	U H	10.0	1.41	ug/L	03/20/24 16:17	03/22/24 00:57	1	1
Aniline	ND	U H	10.0	0.969	ug/L	03/20/24 16:17	03/22/24 00:57	1	2
Anthracene	ND	U H	10.0	1.50	ug/L	03/20/24 16:17	03/22/24 00:57	1	3
Benzidine	ND	U H *-	50.0	4.80	ug/L	03/20/24 16:17	03/22/24 00:57	1	4
Benzo[a]anthracene	ND	U H	5.00	0.173	ug/L	03/20/24 16:17	03/22/24 00:57	1	5
Benzo[a]pyrene	ND	U H	5.00	0.364	ug/L	03/20/24 16:17	03/22/24 00:57	1	6
Benzo[b]fluoranthene	ND	U H	10.0	2.04	ug/L	03/20/24 16:17	03/22/24 00:57	1	7
Benzo[g,h,i]perylene	ND	U H	20.0	2.68	ug/L	03/20/24 16:17	03/22/24 00:57	1	8
Benzo[k]fluoranthene	ND	U H	5.00	0.375	ug/L	03/20/24 16:17	03/22/24 00:57	1	9
Butyl benzyl phthalate	ND	U H	10.0	0.337	ug/L	03/20/24 16:17	03/22/24 00:57	1	10
Chrysene	ND	U H	5.00	0.222	ug/L	03/20/24 16:17	03/22/24 00:57	1	11
Dibenz(a,h)anthracene	ND	U H	5.00	0.246	ug/L	03/20/24 16:17	03/22/24 00:57	1	12
Diethyl phthalate	ND	U H	10.0	1.59	ug/L	03/20/24 16:17	03/22/24 00:57	1	13
Dimethyl phthalate	ND	U H	10.0	0.299	ug/L	03/20/24 16:17	03/22/24 00:57	1	14
Fluoranthene	ND	U H	10.0	1.59	ug/L	03/20/24 16:17	03/22/24 00:57	1	15
Fluorene	ND	U H	10.0	1.63	ug/L	03/20/24 16:17	03/22/24 00:57	1	16
Hexachlorobenzene	ND	U H	5.00	0.307	ug/L	03/20/24 16:17	03/22/24 00:57	1	17
Hexachlorobutadiene	ND	U H	10.0	0.238	ug/L	03/20/24 16:17	03/22/24 00:57	1	18
Hexachlorocyclopentadiene	ND	U H	10.0	4.58	ug/L	03/20/24 16:17	03/22/24 00:57	1	19
Hexachloroethane	ND	U H	20.0	0.526	ug/L	03/20/24 16:17	03/22/24 00:57	1	20
Indeno[1,2,3-cd]pyrene	ND	U H	5.00	2.29	ug/L	03/20/24 16:17	03/22/24 00:57	1	21
Isophorone	ND	U H	10.0	1.64	ug/L	03/20/24 16:17	03/22/24 00:57	1	22
N-Nitrosodi-n-butylamine	ND	U H	20.0	1.49	ug/L	03/20/24 16:17	03/22/24 00:57	1	23
N-Nitrosodiethylamine	ND	U H	20.0	1.75	ug/L	03/20/24 16:17	03/22/24 00:57	1	24
N-Nitrosodimethylamine	ND	U H	50.0	2.02	ug/L	03/20/24 16:17	03/22/24 00:57	1	25
Naphthalene	ND	U H	10.0	0.542	ug/L	03/20/24 16:17	03/22/24 00:57	1	26
Nitrobenzene	ND	U H	10.0	1.66	ug/L	03/20/24 16:17	03/22/24 00:57	1	27
Pentachlorobenzene	ND	U H	20.0	1.07	ug/L	03/20/24 16:17	03/22/24 00:57	1	28
Pentachlorophenol	ND	U H	5.00	0.234	ug/L	03/20/24 16:17	03/22/24 00:57	1	29
Phenanthrene	ND	U H	10.0	1.42	ug/L	03/20/24 16:17	03/22/24 00:57	1	30
Phenol	ND	U H	10.0	0.423	ug/L	03/20/24 16:17	03/22/24 00:57	1	31
Pyrene	ND	U H	10.0	0.178	ug/L	03/20/24 16:17	03/22/24 00:57	1	32
Pyridine	ND	U H	20.0	2.64	ug/L	03/20/24 16:17	03/22/24 00:57	1	33
Bis(2-chloroethyl)ether	ND	U H	10.0	2.16	ug/L	03/20/24 16:17	03/22/24 00:57	1	34
Bis(2-chloroethoxy)methane	ND	U H	10.0	1.76	ug/L	03/20/24 16:17	03/22/24 00:57	1	35
Bis(2-ethylhexyl) phthalate	ND	U H	10.0	0.277	ug/L	03/20/24 16:17	03/22/24 00:57	1	36
Di-n-butyl phthalate	ND	U H	10.0	0.252	ug/L	03/20/24 16:17	03/22/24 00:57	1	37
Di-n-octyl phthalate	ND	U H	10.0	0.373	ug/L	03/20/24 16:17	03/22/24 00:57	1	38
N-Nitrosodi-n-propylamine	ND	U H	20.0	2.88	ug/L	03/20/24 16:17	03/22/24 00:57	1	39
N-Nitrosodiphenylamine	ND	U H	20.0	1.81	ug/L	03/20/24 16:17	03/22/24 00:57	1	40
Total Cresols	ND	U H	10.0	2.62	ug/L	03/20/24 16:17	03/22/24 00:57	1	41

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
bis(2-chloromethyl)ether TIC	ND	U H	ug/L			542-88-1	03/20/24 16:17	03/22/24 00:57	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorophenol (Surr)	27	S1-	28 - 114	03/20/24 16:17	03/22/24 00:57	1
Phenol-d5 (Surr)	19		8 - 424	03/20/24 16:17	03/22/24 00:57	1
Nitrobenzene-d5 (Surr)	62		15 - 314	03/20/24 16:17	03/22/24 00:57	1
2-Fluorobiphenyl	57		29 - 112	03/20/24 16:17	03/22/24 00:57	1

Eurofins Houston

Client Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Date Collected: 03/12/24 10:00

Matrix: Water

Date Received: 03/13/24 14:35

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS) - RE (Continued)

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	84		31 - 132	03/20/24 16:17	03/22/24 00:57	1
p-Terphenyl-d14 (Surr)	100		20 - 141	03/20/24 16:17	03/22/24 00:57	1

Method: ASTM D7065-11 - Determination of Nonylphenols

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Nonylphenol	ND	U	5050	1150	ng/L		03/26/24 12:09	03/28/24 16:52	1
Nonylphenol diethoxylate	ND	U	20200	4610	ng/L		03/26/24 12:09	03/28/24 16:52	1
Nonylphenol monoethoxylate	ND	U	10100	2070	ng/L		03/26/24 12:09	03/28/24 16:52	1
Bisphenol-A	ND	U	2120	1040	ng/L		03/26/24 12:09	03/28/24 16:52	1
4-tert-Octylphenol	ND	U	1010	283	ng/L		03/26/24 12:09	03/28/24 16:52	1
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac			
4-nonylphenol (Surr)	76		58 - 115	03/26/24 12:09	03/28/24 16:52	1			
4-nonylphenol monoethoxylate (Surr)	66		54 - 139	03/26/24 12:09	03/28/24 16:52	1			

Method: Lab SOP Organotins SIM - Organotins (GC/MS SIM)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Tributyltin	14.5		2.96	1.12	ng/L		03/19/24 17:03	03/26/24 13:05	1
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac			
Tripentyltin	87		10 - 120	03/19/24 17:03	03/26/24 13:05	1			

Method: EPA 608.3 - Organochlorine Pesticides in Water

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
4,4'-DDD	ND	U *+	0.0200	0.000814	ug/L		03/19/24 14:10	03/25/24 11:48	1
4,4'-DDE	ND	U	0.0200	0.00109	ug/L		03/19/24 14:10	03/25/24 11:48	1
4,4'-DDT	ND	U	0.00400	0.00379	ug/L		03/19/24 14:10	03/25/24 11:48	1
Aldrin	ND	U	0.00200	0.00113	ug/L		03/19/24 14:10	03/25/24 11:48	1
alpha-BHC	ND	U	0.00900	0.00142	ug/L		03/19/24 14:10	03/25/24 11:48	1
beta-BHC	ND	U	0.0180	0.00389	ug/L		03/19/24 14:10	03/25/24 11:48	1
Chlordane	ND	U	0.103	0.103	ug/L		03/19/24 14:10	03/25/24 11:48	1
delta-BHC	ND	U	0.250	0.00245	ug/L		03/19/24 14:10	03/25/24 11:48	1
Dicofol	ND	U	0.200	0.0500	ug/L		03/19/24 14:10	03/25/24 11:48	1
Dieldrin	ND	U	0.00400	0.000953	ug/L		03/19/24 14:10	03/25/24 11:48	1
Endosulfan I	ND	U	0.00200	0.00107	ug/L		03/19/24 14:10	03/25/24 11:48	1
Endosulfan II	ND	U	0.00400	0.00122	ug/L		03/19/24 14:10	03/25/24 11:48	1
Endosulfan sulfate	ND	U	0.0200	0.00112	ug/L		03/19/24 14:10	03/25/24 11:48	1
Endrin	ND	U	0.00400	0.00156	ug/L		03/19/24 14:10	03/25/24 11:48	1
Endrin aldehyde	ND	U *+	0.0200	0.00118	ug/L		03/19/24 14:10	03/25/24 11:48	1
Hexachlorocyclohexane	ND	U	0.0100	0.00299	ug/L		03/19/24 14:10	03/25/24 11:48	1
Heptachlor	ND	U *+	0.00446	0.00446	ug/L		03/19/24 14:10	03/25/24 11:48	1
Heptachlor epoxide	ND	U	0.00200	0.00134	ug/L		03/19/24 14:10	03/25/24 11:48	1
Methoxychlor	ND	U *+	0.0200	0.00390	ug/L		03/19/24 14:10	03/25/24 11:48	1
Mirex	ND	U	0.0200	0.0200	ug/L		03/19/24 14:10	03/25/24 11:48	1
Toxaphene	ND	U	0.0770	0.0769	ug/L		03/19/24 14:10	03/25/24 11:48	1
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac			
DCB Decachlorobiphenyl (Surr)	154	S1+	15 - 136	03/19/24 14:10	03/25/24 11:48	1			
Tetrachloro-m-xylene (Surr)	82		18 - 126	03/19/24 14:10	03/25/24 11:48	1			

Eurofins Houston

Client Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Matrix: Water

Date Collected: 03/12/24 10:00

Date Received: 03/13/24 14:35

Method: EPA 608.3 - Polychlorinated Biphenyls (PCBs) (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
PCB-1016	ND	U	0.0400	0.0125	ug/L		03/19/24 14:10	03/21/24 10:25	1
PCB-1221	ND	U	0.0400	0.0125	ug/L		03/19/24 14:10	03/21/24 10:25	1
PCB-1232	ND	U	0.0400	0.0125	ug/L		03/19/24 14:10	03/21/24 10:25	1
PCB-1242	ND	U	0.0400	0.0125	ug/L		03/19/24 14:10	03/21/24 10:25	1
PCB-1248	ND	U	0.0400	0.0125	ug/L		03/19/24 14:10	03/21/24 10:25	1
PCB-1254	ND	U	0.0400	0.00780	ug/L		03/19/24 14:10	03/21/24 10:25	1
PCB-1260	ND	U	0.0400	0.00780	ug/L		03/19/24 14:10	03/21/24 10:25	1
Polychlorinated biphenyls, Total	ND	U	0.0400	0.0400	ug/L		03/19/24 14:10	03/21/24 10:25	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
Tetrachloro-m-xylene (Surr)	70		18 - 126				03/19/24 14:10	03/21/24 10:25	1
DCB Decachlorobiphenyl (Surr)	91		15 - 136				03/19/24 14:10	03/21/24 10:25	1

Method: EPA-01 615 - Herbicides (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4,5-TP (Silvex)	ND	U	0.200	0.0422	ug/L		03/19/24 12:59	03/23/24 07:13	1
2,4-D	ND	U	0.200	0.0539	ug/L		03/19/24 12:59	03/23/24 07:13	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2,4-Dichlorophenylacetic acid	70		45 - 150				03/19/24 12:59	03/23/24 07:13	1

Method: EPA-01 632 - Carbamate and Urea Pesticides (HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Carbaryl	ND	U	5.00	1.85	ug/L		03/19/24 13:38	03/29/24 03:54	1
Diuron	ND	U	0.0900	0.0514	ug/L		03/19/24 13:38	03/29/24 03:54	1

Method: EPA 1613B - Dioxins and Furans (HRGC/HRMS)

Analyte	Result	Qualifier	RL	EDL	Unit	D	Prepared	Analyzed	Dil Fac
2,3,7,8-TCDD	ND	U	9.95	0.519	pg/L		03/21/24 08:32	04/04/24 08:30	1
2,3,7,8-TCDF	ND	U	9.95	0.284	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,7,8-PeCDD	ND	U	49.7	1.57	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,7,8-PeCDF	ND	U	49.7	0.815	pg/L		03/21/24 08:32	04/04/24 08:30	1
2,3,4,7,8-PeCDF	ND	U	49.7	0.932	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,4,7,8-HxCDD	ND	U	49.7	1.54	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,6,7,8-HxCDD	ND	U	49.7	1.64	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,7,8,9-HxCDD	ND	U	49.7	1.51	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,4,7,8-HxCDF	ND	U	49.7	0.826	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,6,7,8-HxCDF	ND	U	49.7	0.830	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,7,8,9-HxCDF	ND	U	49.7	0.738	pg/L		03/21/24 08:32	04/04/24 08:30	1
2,3,4,6,7,8-HxCDF	ND	U	49.7	0.746	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,4,6,7,8-HpCDD	ND	U	49.7	0.544	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,4,6,7,8-HpCDF	ND	U	49.7	0.832	pg/L		03/21/24 08:32	04/04/24 08:30	1
1,2,3,4,7,8-HpCDF	ND	U	49.7	0.868	pg/L		03/21/24 08:32	04/04/24 08:30	1
OCDD	ND	U	99.5	1.30	pg/L		03/21/24 08:32	04/04/24 08:30	1
OCDF	ND	U	99.5	0.837	pg/L		03/21/24 08:32	04/04/24 08:30	1
Isotope Dilution	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C-2,3,7,8-TCDD	81		25 - 164				03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,7,8-PeCDD	78		25 - 181				03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,7,8-PeCDF	81		24 - 185				03/21/24 08:32	04/04/24 08:30	1
13C-2,3,7,8-TCDF	91		24 - 169				03/21/24 08:32	04/04/24 08:30	1

Eurofins Houston

Client Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Matrix: Water

Date Collected: 03/12/24 10:00

Date Received: 03/13/24 14:35

Method: EPA 1613B - Dioxins and Furans (HRGC/HRMS) (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C-1,2,3,6,7,8-HxCDD	72		28 - 130	03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,7,8,9-HxCDF	96		29 - 147	03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,4,6,7,8-HpCDF	78		28 - 143	03/21/24 08:32	04/04/24 08:30	1
13C-OCDF	95		17 - 157	03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,4,7,8-HxCDD	79		32 - 141	03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,6,7,8-HxCDF	81		26 - 123	03/21/24 08:32	04/04/24 08:30	1
13C-2,3,4,7,8-PeCDF	77		21 - 178	03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,4,6,7,8-HpCDD	80		23 - 140	03/21/24 08:32	04/04/24 08:30	1
13C-OCDD	82		17 - 157	03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,4,7,8-HxCDF	87		26 - 152	03/21/24 08:32	04/04/24 08:30	1
13C-2,3,4,6,7,8-HxCDF	87		28 - 136	03/21/24 08:32	04/04/24 08:30	1
13C-1,2,3,4,7,8,9-HpCDF	91		26 - 138	03/21/24 08:32	04/04/24 08:30	1
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
37Cl4-2,3,7,8-TCDD	113		35 - 197	03/21/24 08:32	04/04/24 08:30	1

Method: EPA 1668C - Chlorinated Biphenyl Congeners (HRGC/HRMS)

Analyte	Result	Qualifier	RL	EDL	Unit	D	Prepared	Analyzed	Dil Fac
PCB-77	ND	U	19.5	2.35	pg/L		03/20/24 10:22	04/06/24 06:28	1
PCB-81	ND	U	19.5	2.51	pg/L		03/20/24 10:22	04/06/24 06:28	1
PCB-126	ND	U	19.5	0.644	pg/L		03/20/24 10:22	04/06/24 06:28	1
PCB-169	ND	U	19.5	0.294	pg/L		03/20/24 10:22	04/06/24 06:28	1
Isotope Dilution	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
PCB-126L	48		10 - 145				03/20/24 10:22	04/06/24 06:28	1
PCB-169L	51		10 - 145				03/20/24 10:22	04/06/24 06:28	1
PCB-81L	44		10 - 145				03/20/24 10:22	04/06/24 06:28	1
PCB-77L	44		10 - 145				03/20/24 10:22	04/06/24 06:28	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
PCB-28L	65		5 - 145				03/20/24 10:22	04/06/24 06:28	1
PCB-111L	76		10 - 145				03/20/24 10:22	04/06/24 06:28	1
PCB-178L	84		10 - 145				03/20/24 10:22	04/06/24 06:28	1

Method: EPA 1631E - Mercury, Low Level (CVAFS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	2.71		0.500	0.200	ng/L		03/19/24 16:17	03/21/24 11:51	1

Method: EPA 200.7 Rev 4.4 - Metals (ICP) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	0.254		0.0500	0.0173	mg/L		03/17/24 13:00	03/18/24 19:14	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Non-amenable (SM 4500 CN G NonAm)	0.00567		0.00500	0.00233	mg/L		03/22/24 15:39	03/24/24 13:46	1
Cyanide, Total (EPA Kelada 01)	ND	U	0.00500	0.00198	mg/L			03/25/24 13:36	1
Cyanide, Amenable (SM 4500 CN G)	ND	U	0.00500	0.00233	mg/L			03/27/24 09:48	1

Surrogate Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 624.1 - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		DCA (63-144)	TOL (80-120)				
860-69911-1	6221-24 Hillsbors Permit Renewal	89	97				
860-69911-1 - RA	6221-24 Hillsbors Permit Renewal	114	102				
860-69911-1 MS	6221-24 Hillsbors Permit Renewal	85	98				
LCS 860-149796/3	Lab Control Sample	86	99				
LCS 860-149950/3	Lab Control Sample	101	98				
LCSD 860-149796/4	Lab Control Sample Dup	86	99				
LCSD 860-149950/4	Lab Control Sample Dup	100	100				
MB 860-149796/10	Method Blank	90	98				
MB 860-149950/9	Method Blank	109	101				

Surrogate Legend

DCA = 1,2-Dichloroethane-d4 (Surr)

TOL = Toluene-d8 (Surr)

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		2FP (28-114)	PHL (8-424)	NBZ (15-314)	FBP (29-112)	TBP (31-132)	TPHd14 (20-141)
860-69911-1	6221-24 Hillsbors Permit Renewal	20 S1-	13	54	48	56	64
860-69911-1 - RE	6221-24 Hillsbors Permit Renewal	27 S1-	19	62	57	84	100
LCS 860-150228/2-A	Lab Control Sample	33	24	64	60	73	75
LCS 860-150805/2-A	Lab Control Sample	41	29	81	80	91	92
LCSD 860-150228/3-A	Lab Control Sample Dup	34	24	68	64	75	77
LCSD 860-150805/3-A	Lab Control Sample Dup	43	32	84	83	97	100
MB 860-150228/1-A	Method Blank	26 S1-	17	60	51	48	70
MB 860-150805/1-A	Method Blank	24 S1-	16	59	55	62	94

Surrogate Legend

2FP = 2-Fluorophenol (Surr)

PHL = Phenol-d5 (Surr)

NBZ = Nitrobenzene-d5 (Surr)

FBP = 2-Fluorobiphenyl

TBP = 2,4,6-Tribromophenol (Surr)

TPHd14 = p-Terphenyl-d14 (Surr)

Method: D7065-11 - Determination of Nonylphenols

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		4NPH (58-115)	4NPME (54-139)				
860-69911-1	6221-24 Hillsbors Permit Renewal	76	66				
LCS 280-647138/2-A	Lab Control Sample	94	103				
MB 280-647138/1-A	Method Blank	77	84				

Surrogate Legend

4NPH = 4-nonylphenol (Surr)

4NPME = 4-nonylphenol monoethoxylate (Surr)

Eurofins Houston

Surrogate Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: Organotins SIM - Organotins (GC/MS SIM)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TPTT (10-120)
860-69911-1	6221-24 Hillsbors Permit Renewal	87
LCS 570-421863/2-A	Lab Control Sample	52
LCSD 570-421863/3-A	Lab Control Sample Dup	53
MB 570-421863/1-A	Method Blank	66

Surrogate Legend

TPTT = Tripentyltin

Method: 608.3 - Organochlorine Pesticides in Water

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	DCB1 (15-136)	TCX1 (18-126)
860-69911-1	6221-24 Hillsbors Permit Renewal	154 S1+	82
LCS 860-150340/2-A	Lab Control Sample	153 S1+	123
LCSD 860-150340/3-A	Lab Control Sample Dup	142 S1+	113
MB 860-150340/1-A	Method Blank	130	89

Surrogate Legend

DCB = DCB Decachlorobiphenyl (Surr)

TCX = Tetrachloro-m-xylene (Surr)

Method: 608.3 - Polychlorinated Biphenyls (PCBs) (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TCX1 (18-126)	DCB1 (15-136)
860-69911-1	6221-24 Hillsbors Permit Renewal	70	91
LCS 860-150340/4-A	Lab Control Sample	88	136
LCSD 860-150340/5-A	Lab Control Sample Dup	77	132
MB 860-150340/1-A	Method Blank	78	122

Surrogate Legend

TCX = Tetrachloro-m-xylene (Surr)

DCB = DCB Decachlorobiphenyl (Surr)

Method: 615 - Herbicides (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	DCPAA1 (45-150)
860-69911-1	6221-24 Hillsbors Permit Renewal	70
LCS 860-150523/2-A	Lab Control Sample	69
LCSD 860-150523/3-A	Lab Control Sample Dup	71
MB 860-150523/1-A	Method Blank	67

Surrogate Legend

DCPAA = 2,4-Dichlorophenylacetic acid

Eurofins Houston

Surrogate Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 1613B - Dioxins and Furans (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

37TCDD

Lab Sample ID	Client Sample ID	(35-197)
860-69911-1	6221-24 Hillsbors Permit Renewal	113
MB 320-748976/1-A	Method Blank	110

Surrogate Legend

37TCDD = 37Cl4-2,3,7,8-TCDD

Method: 1613B - Dioxins and Furans (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

37TCDD

Lab Sample ID	Client Sample ID	(31-191)
LCS 320-748976/2-A	Lab Control Sample	111
LCSD 320-748976/3-A	Lab Control Sample Dup	110

Surrogate Legend

37TCDD = 37Cl4-2,3,7,8-TCDD

Method: 1668C - Chlorinated Biphenyl Congeners (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

PCB28L PCB111L PCB178L

Lab Sample ID	Client Sample ID	PCB28L	PCB111L	PCB178L
860-69911-1	6221-24 Hillsbors Permit Renewal	65	76	84
MB 320-748762/1-A	Method Blank	67	67	77

Surrogate Legend

PCB28L = PCB-28L

PCB111L = PCB-111L

PCB178L = PCB-178L

Method: 1668C - Chlorinated Biphenyl Congeners (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

PCB28L PCB111L PCB178L

Lab Sample ID	Client Sample ID	PCB28L	PCB111L	PCB178L
LCS 320-748762/2-A	Lab Control Sample	58	58	66
LCSD 320-748762/3-A	Lab Control Sample Dup	62	63	70

Surrogate Legend

PCB28L = PCB-28L

PCB111L = PCB-111L

PCB178L = PCB-178L

Isotope Dilution Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 1613B - Dioxins and Furans (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)									
Lab Sample ID	Client Sample ID	TCDD (25-164)	PeCDD (25-181)	PeCDF (24-185)	TCDF (24-169)	HxDD (28-130)	HxCF (29-147)	HpCDF (28-143)	OCDF (17-157)
860-69911-1	6221-24 Hillsbors Permit Renewal	81	78	81	91	72	96	78	95
MB 320-748976/1-A	Method Blank	72	68	71	84	69	85	72	98
Percent Isotope Dilution Recovery (Acceptance Limits)									
Lab Sample ID	Client Sample ID	HxCDD (32-141)	HxDF (26-123)	PeCF (21-178)	HpCDD (23-140)	OCDD (17-157)	HxCDF (26-152)	13CHxCF (28-136)	HpCDF2 (26-138)
860-69911-1	6221-24 Hillsbors Permit Renewal	79	81	77	80	82	87	87	91
MB 320-748976/1-A	Method Blank	71	73	72	78	85	76	77	89
Surrogate Legend									
TCDD = 13C-2,3,7,8-TCDD									
PeCDD = 13C-1,2,3,7,8-PeCDD									
PeCDF = 13C-1,2,3,7,8-PeCDF									
TCDF = 13C-2,3,7,8-TCDF									
HxDD = 13C-1,2,3,6,7,8-HxCDD									
HxCF = 13C-1,2,3,7,8,9-HxCF									
HpCDF = 13C-1,2,3,4,6,7,8-HpCDF									
OCDF = 13C-OCDF									
HxCDD = 13C-1,2,3,4,7,8-HxCDD									
HxDL = 13C-1,2,3,6,7,8-HxDL									
PeCF = 13C-2,3,4,7,8-PeCDF									
HpCDD = 13C-1,2,3,4,6,7,8-HpCDD									
OCDD = 13C-OCDD									
HxCDF = 13C-1,2,3,4,7,8-HxCDF									
13CHxCF = 13C-2,3,4,6,7,8-HxCDF									
HpCDF2 = 13C-1,2,3,4,7,8,9-HpCDF									

Method: 1613B - Dioxins and Furans (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)									
Lab Sample ID	Client Sample ID	TCDD (20-175)	PeCDD (21-227)	PeCDF (21-192)	TCDF (22-152)	HxDD (25-163)	HxCF (17-205)	HpCDF (21-158)	OCDF (13-199)
LCS 320-748976/2-A	Lab Control Sample	74	74	79	90	73	92	78	108
LCSD 320-748976/3-A	Lab Control Sample Dup	68	65	70	81	65	84	70	93
Percent Isotope Dilution Recovery (Acceptance Limits)									
Lab Sample ID	Client Sample ID	HxCDD (21-193)	HxDL (21-159)	PeCF (13-328)	HpCDD (26-166)	OCDD (13-199)	HxCDF (19-202)	13CHxCF (22-176)	HpCDF2 (20-186)
LCS 320-748976/2-A	Lab Control Sample	71	77	74	85	92	78	83	96
LCSD 320-748976/3-A	Lab Control Sample Dup	65	68	65	76	79	70	76	85
Surrogate Legend									
TCDD = 13C-2,3,7,8-TCDD									
PeCDD = 13C-1,2,3,7,8-PeCDD									
PeCDF = 13C-1,2,3,7,8-PeCDF									
TCDF = 13C-2,3,7,8-TCDF									
HxDD = 13C-1,2,3,6,7,8-HxCDD									
HxCF = 13C-1,2,3,7,8,9-HxCF									
HpCDF = 13C-1,2,3,4,6,7,8-HpCDF									
OCDF = 13C-OCDF									
HxCDD = 13C-1,2,3,4,7,8-HxCDD									

Eurofins Houston

Isotope Dilution Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

HxCDF = 13C-1,2,3,6,7,8-HxCDF

PeCF = 13C-2,3,4,7,8-PeCDF

HpCDD = 13C-1,2,3,4,6,7,8-HpCDD

OCDD = 13C-OCDD

HxCDF = 13C-1,2,3,4,7,8-HxCDF

13CHxCDF = 13C-2,3,4,6,7,8-HxCDF

HpCDF2 = 13C-1,2,3,4,7,8,9-HpCDF

Method: 1668C - Chlorinated Biphenyl Congeners (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PCB126L (10-145)	PCB169L (10-145)	PCB81L (10-145)	PCB77L (10-145)						
860-69911-1	6221-24 Hillsbors Permit Renewal	48	51	44	44						
MB 320-748762/1-A	Method Blank	69	82	60	62						

Surrogate Legend

PCB126L = PCB-126L

PCB169L = PCB-169L

PCB81L = PCB-81L

PCB77L = PCB-77L

Method: 1668C - Chlorinated Biphenyl Congeners (HRGC/HRMS)

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PCB126L (40-145)	PCB169L (40-145)	PCB81L (40-145)	PCB77L (40-145)						
LCS 320-748762/2-A	Lab Control Sample	66	77	58	58						
LCSD 320-748762/3-A	Lab Control Sample Dup	58	73	55	56						

Surrogate Legend

PCB126L = PCB-126L

PCB169L = PCB-169L

PCB81L = PCB-81L

PCB77L = PCB-77L

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 624.1 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 860-149796/10

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 149796

Analyte	MB		MB		D	Prepared	Analyzed	Dil Fac
	Result	Qualifier	RL	MDL				
1,1,1-Trichloroethane	ND	U	10.0	0.585	ug/L		03/14/24 23:31	1
1,1,2,2-Tetrachloroethane	ND	U	10.0	0.470	ug/L		03/14/24 23:31	1
1,1,2-Trichloroethane	ND	U	10.0	0.411	ug/L		03/14/24 23:31	1
1,1-Dichloroethane	ND	U	10.0	0.635	ug/L		03/14/24 23:31	1
1,1-Dichlorethylene	ND	U	10.0	0.738	ug/L		03/14/24 23:31	1
1,2-Dibromoethane	ND	U	10.0	0.999	ug/L		03/14/24 23:31	1
1,2-Dichlorobenzene	ND	U	10.0	0.429	ug/L		03/14/24 23:31	1
1,2-Dichloroethane	ND	U	10.0	0.372	ug/L		03/14/24 23:31	1
1,2-Dichloropropane	ND	U	10.0	0.556	ug/L		03/14/24 23:31	1
1,3-Dichlorobenzene	ND	U	10.0	0.413	ug/L		03/14/24 23:31	1
1,4-Dichlorobenzene	ND	U	10.0	0.449	ug/L		03/14/24 23:31	1
Methyl Ethyl Ketone	ND	U	50.0	8.28	ug/L		03/14/24 23:31	1
2-Chloroethyl vinyl ether	ND	U	10.0	0.753	ug/L		03/14/24 23:31	1
Acrolein	ND	U	50.0	11.1	ug/L		03/14/24 23:31	1
Acrylonitrile	ND	U	50.0	14.3	ug/L		03/14/24 23:31	1
Benzene	ND	U	10.0	0.460	ug/L		03/14/24 23:31	1
Dichlorobromomethane	ND	U	10.0	0.552	ug/L		03/14/24 23:31	1
Bromoform	ND	U	10.0	0.633	ug/L		03/14/24 23:31	1
Methyl bromide	ND	U	50.0	1.42	ug/L		03/14/24 23:31	1
Carbon tetrachloride	ND	U	2.00	0.896	ug/L		03/14/24 23:31	1
Chlorobenzene	ND	U	10.0	0.455	ug/L		03/14/24 23:31	1
Chloroethane	ND	U	50.0	1.98	ug/L		03/14/24 23:31	1
Chloroform	ND	U	10.0	0.464	ug/L		03/14/24 23:31	1
Methyl chloride	ND	U	50.0	2.04	ug/L		03/14/24 23:31	1
Chlorodibromomethane	ND	U	10.0	0.547	ug/L		03/14/24 23:31	1
Ethylbenzene	ND	U	10.0	0.385	ug/L		03/14/24 23:31	1
Methylene Chloride	ND	U	20.0	1.73	ug/L		03/14/24 23:31	1
Tetrachloroethylene	ND	U	10.0	0.655	ug/L		03/14/24 23:31	1
Toluene	ND	U	10.0	0.475	ug/L		03/14/24 23:31	1
Trichloroethylene	ND	U	10.0	1.50	ug/L		03/14/24 23:31	1
Trihalomethanes, Total	ND	U	10.0	0.633	ug/L		03/14/24 23:31	1
Vinyl chloride	ND	U	10.0	0.428	ug/L		03/14/24 23:31	1
1,2-trans-Dichloroethylene	ND	U	10.0	0.368	ug/L		03/14/24 23:31	1
1,3-Dichloropropene, Total	ND	U	5.00	1.27	ug/L		03/14/24 23:31	1

Surrogate	MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	90		63 - 144		03/14/24 23:31	1
Toluene-d8 (Surr)	98		80 - 120		03/14/24 23:31	1

Lab Sample ID: LCS 860-149796/3

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 149796

Analyte	Spike		LCS		D	%Rec	Limits
	Added	Result	Qualifier	Unit			
1,1,1-Trichloroethane	50.0	49.59		ug/L	99	70 - 130	
1,1,2,2-Tetrachloroethane	50.0	49.04		ug/L	98	74 - 125	
1,1,2-Trichloroethane	50.0	48.74		ug/L	97	75 - 130	
1,1-Dichloroethane	50.0	46.41		ug/L	93	71 - 130	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 624.1 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-149796/3

Matrix: Water

Analysis Batch: 149796

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec
		Result	Qualifier				Limits
1,1-Dichlorethylene	50.0	49.51		ug/L		99	50 - 150
1,2-Dibromoethane	50.0	51.55		ug/L		103	73 - 125
1,2-Dichlorobenzene	50.0	52.25		ug/L		105	75 - 125
1,2-Dichloroethane	50.0	42.98		ug/L		86	72 - 130
1,2-Dichloropropane	50.0	49.81		ug/L		100	74 - 125
1,3-Dichlorobenzene	50.0	53.48		ug/L		107	75 - 125
1,4-Dichlorobenzene	50.0	52.69		ug/L		105	75 - 125
Methyl Ethyl Ketone	250	214.6		ug/L		86	60 - 140
2-Chloroethyl vinyl ether	50.0	44.09		ug/L		88	50 - 150
Acrolein	250	206.7		ug/L		83	60 - 140
Acrylonitrile	500	430.2		ug/L		86	60 - 140
Benzene	50.0	52.59		ug/L		105	75 - 125
Dichlorobromomethane	50.0	46.93		ug/L		94	75 - 125
Bromoform	50.0	48.12		ug/L		96	70 - 130
Methyl bromide	50.0	42.17 J		ug/L		84	60 - 140
Carbon tetrachloride	50.0	47.80		ug/L		96	70 - 125
Chlorobenzene	50.0	53.51		ug/L		107	82 - 135
Chloroethane	50.0	50.56		ug/L		101	60 - 140
Chloroform	50.0	47.13		ug/L		94	70 - 121
Methyl chloride	50.0	41.52 J		ug/L		83	60 - 140
Chlorodibromomethane	50.0	49.63		ug/L		99	73 - 125
Ethylbenzene	50.0	52.63		ug/L		105	75 - 125
Methylene Chloride	50.0	45.86		ug/L		92	71 - 125
Tetrachloroethylene	50.0	57.46		ug/L		115	71 - 125
Toluene	50.0	52.97		ug/L		106	75 - 130
Trichloroethylene	50.0	55.09		ug/L		110	75 - 135
Vinyl chloride	50.0	49.46		ug/L		99	60 - 140
cis-1,3-Dichloropropylene	50.0	47.45		ug/L		95	74 - 125
1,2-trans-Dichloroethylene	50.0	50.17		ug/L		100	75 - 125
trans-1,3-Dichloropropylene	50.0	45.84		ug/L		92	66 - 125

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	86		63 - 144
Toluene-d8 (Surr)	99		80 - 120

Lab Sample ID: LCSD 860-149796/4

Matrix: Water

Analysis Batch: 149796

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	Limit
		Result	Qualifier				Limits		
1,1,1-Trichloroethane	50.0	48.20		ug/L		96	70 - 130	3	25
1,1,2,2-Tetrachloroethane	50.0	48.11		ug/L		96	74 - 125	2	25
1,1,2-Trichloroethane	50.0	47.37		ug/L		95	75 - 130	3	25
1,1-Dichloroethane	50.0	45.85		ug/L		92	71 - 130	1	25
1,1-Dichlorethylene	50.0	47.80		ug/L		96	50 - 150	4	25
1,2-Dibromoethane	50.0	50.97		ug/L		102	73 - 125	1	25
1,2-Dichlorobenzene	50.0	50.57		ug/L		101	75 - 125	3	25
1,2-Dichloroethane	50.0	41.68		ug/L		83	72 - 130	3	25

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 624.1 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 860-149796/4

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 149796

Analyte	Spike Added	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	RPD Limit
		Result	Qualifier				Limits		
1,2-Dichloropropane	50.0	47.47		ug/L	95	74 - 125	5	25	
1,3-Dichlorobenzene	50.0	52.09		ug/L	104	75 - 125	3	25	
1,4-Dichlorobenzene	50.0	51.12		ug/L	102	75 - 125	3	25	
Methyl Ethyl Ketone	250	220.3		ug/L	88	60 - 140	3	25	
2-Chloroethyl vinyl ether	50.0	43.45		ug/L	87	50 - 150	1	25	
Acrolein	250	211.4		ug/L	85	60 - 140	2	25	
Acrylonitrile	500	442.0		ug/L	88	60 - 140	3	25	
Benzene	50.0	50.14		ug/L	100	75 - 125	5	25	
Dichlorobromomethane	50.0	44.62		ug/L	89	75 - 125	5	25	
Bromoform	50.0	48.24		ug/L	96	70 - 130	0	25	
Methyl bromide	50.0	42.96	J	ug/L	86	60 - 140	2	25	
Carbon tetrachloride	50.0	47.26		ug/L	95	70 - 125	1	25	
Chlorobenzene	50.0	51.65		ug/L	103	82 - 135	4	25	
Chloroethane	50.0	49.46	J	ug/L	99	60 - 140	2	25	
Chloroform	50.0	46.52		ug/L	93	70 - 121	1	25	
Methyl chloride	50.0	40.82	J	ug/L	82	60 - 140	2	25	
Chlorodibromomethane	50.0	48.02		ug/L	96	73 - 125	3	25	
Ethylbenzene	50.0	50.87		ug/L	102	75 - 125	3	25	
Methylene Chloride	50.0	45.28		ug/L	91	71 - 125	1	25	
Tetrachloroethylene	50.0	55.28		ug/L	111	71 - 125	4	25	
Toluene	50.0	50.74		ug/L	101	75 - 130	4	25	
Trichloroethylene	50.0	52.39		ug/L	105	75 - 135	5	25	
Vinyl chloride	50.0	48.90		ug/L	98	60 - 140	1	25	
cis-1,3-Dichloropropylene	50.0	45.54		ug/L	91	74 - 125	4	25	
1,2-trans-Dichloroethylene	50.0	47.54		ug/L	95	75 - 125	5	25	
trans-1,3-Dichloropropylene	50.0	44.46		ug/L	89	66 - 125	3	25	

Surrogate	LCSD	LCSD	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	86		63 - 144
Toluene-d8 (Surr)	99		80 - 120

Lab Sample ID: 860-69911-1 MS

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 149796

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec
	Result	Qualifier	Added	Result	Qualifier				Limits
1,1,1-Trichloroethane	ND	U	50.0	45.70		ug/L	91	75 - 125	
1,1,2,2-Tetrachloroethane	ND	U	50.0	52.08		ug/L	104	74 - 125	
1,1,2-Trichloroethane	ND	U	50.0	50.13		ug/L	100	75 - 127	
1,1-Dichloroethane	ND	U	50.0	44.13		ug/L	88	72 - 125	
1,1-Dichlorethylene	ND	U	50.0	42.87		ug/L	86	59 - 172	
1,2-Dibromoethane	ND	U	50.0	53.13		ug/L	106	73 - 125	
1,2-Dichlorobenzene	ND	U	50.0	51.27		ug/L	103	75 - 125	
1,2-Dichloroethane	ND	U	50.0	43.38		ug/L	87	68 - 127	
1,2-Dichloropropane	ND	U	50.0	48.42		ug/L	97	74 - 125	
1,3-Dichlorobenzene	ND	U	50.0	52.04		ug/L	104	75 - 125	
1,4-Dichlorobenzene	ND	U	50.0	51.95		ug/L	104	75 - 125	
Methyl Ethyl Ketone	ND	U	250	236.1		ug/L	94	60 - 140	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 624.1 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 860-69911-1 MS

Matrix: Water

Analysis Batch: 149796

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Prep Type: Total/NA

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec
	Result	Qualifier	Added	Result	Qualifier				
2-Chloroethyl vinyl ether	ND	U	50.0	45.92		ug/L	92	50 - 150	
Acrolein	ND	U F1	250	ND	U F1	ug/L	0	50 - 150	
Acrylonitrile	ND	U	500	461.6		ug/L	92	50 - 150	
Benzene	ND	U	50.0	49.79		ug/L	100	66 - 142	
Dichlorobromomethane	ND	U	50.0	47.63		ug/L	93	75 - 125	
Bromoform	ND	U	50.0	50.76		ug/L	102	75 - 125	
Methyl bromide	ND	U	50.0	ND	U	ug/L	71	60 - 140	
Carbon tetrachloride	ND	U	50.0	43.05		ug/L	86	62 - 125	
Chlorobenzene	ND	U	50.0	51.95		ug/L	104	60 - 133	
Chloroethane	ND	U	50.0	ND	U	ug/L	80	60 - 140	
Chloroform	ND	U	50.0	51.16		ug/L	92	70 - 130	
Methyl chloride	ND	U	50.0	ND	U	ug/L	68	60 - 140	
Chlorodibromomethane	ND	U	50.0	50.55		ug/L	101	73 - 125	
Ethylbenzene	ND	U	50.0	50.07		ug/L	100	75 - 125	
Methylene Chloride	ND	U	50.0	44.41		ug/L	89	75 - 125	
Tetrachloroethylene	ND	U	50.0	53.51		ug/L	107	71 - 125	
Toluene	ND	U	50.0	51.27		ug/L	103	59 - 139	
Trichloroethylene	ND	U	50.0	50.84		ug/L	102	62 - 137	
Vinyl chloride	ND	U	50.0	37.43		ug/L	75	60 - 140	
cis-1,3-Dichloropropylene	ND	U	50.0	46.68		ug/L	93	74 - 125	
1,2-trans-Dichloroethylene	ND	U	50.0	45.04		ug/L	90	75 - 125	
trans-1,3-Dichloropropylene	ND	U	50.0	45.89		ug/L	92	66 - 125	

MS MS

Surrogate	MS	MS	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	85		63 - 144
Toluene-d8 (Surr)	98		80 - 120

Lab Sample ID: MB 860-149950/9

Matrix: Water

Analysis Batch: 149950

Client Sample ID: Method Blank

Prep Type: Total/NA

Lab Sample ID: LCS 860-149950/3

Matrix: Water

Analysis Batch: 149950

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 624.1 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: LCSD 860-149950/4

Matrix: Water

Analysis Batch: 149950

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte		Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	RPD
		Added	Result	Qualifier				Limits		
Methyl bromide		50.0	51.70		ug/L		103	60 - 140	2	25
Surrogate										
1,2-Dichloroethane-d4 (Surr)	%Recovery		LCSD	LCSD	Limits	D	%Rec	%Rec	RPD	RPD
	100							63 - 144		
Toluene-d8 (Surr)	100				80 - 120					

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 860-150228/1-A

Matrix: Water

Analysis Batch: 150257

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 150228

Analyte	MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,2,4,5-Tetrachlorobenzene	ND	U	10.0	1.32	ug/L		03/18/24 09:27	03/18/24 16:22	1
1,2,4-Trichlorobenzene	ND	U	10.0	1.61	ug/L		03/18/24 09:27	03/18/24 16:22	1
1,2-Diphenylhydrazine	ND	U	10.0	1.49	ug/L		03/18/24 09:27	03/18/24 16:22	1
bis (2-chloroisopropyl) ether	ND	U	10.0	1.79	ug/L		03/18/24 09:27	03/18/24 16:22	1
2,4,5-Trichlorophenol	ND	U	10.0	2.00	ug/L		03/18/24 09:27	03/18/24 16:22	1
2,4,6-Trichlorophenol	ND	U	10.0	1.42	ug/L		03/18/24 09:27	03/18/24 16:22	1
2,4-Dichlorophenol	ND	U	10.0	0.314	ug/L		03/18/24 09:27	03/18/24 16:22	1
2,4-Dimethylphenol	ND	U	10.0	0.649	ug/L		03/18/24 09:27	03/18/24 16:22	1
2,4-Dinitrophenol	ND	U	50.0	1.61	ug/L		03/18/24 09:27	03/18/24 16:22	1
2,4-Dinitrotoluene	ND	U	10.0	1.31	ug/L		03/18/24 09:27	03/18/24 16:22	1
2,6-Dinitrotoluene	ND	U	10.0	1.61	ug/L		03/18/24 09:27	03/18/24 16:22	1
2-Chloronaphthalene	ND	U	10.0	0.462	ug/L		03/18/24 09:27	03/18/24 16:22	1
2-Chlorophenol	ND	U	10.0	0.649	ug/L		03/18/24 09:27	03/18/24 16:22	1
2-Nitrophenol	ND	U	20.0	1.67	ug/L		03/18/24 09:27	03/18/24 16:22	1
o-Cresol	ND	U	10.0	1.62	ug/L		03/18/24 09:27	03/18/24 16:22	1
m & p - Cresol	ND	U	10.0	2.62	ug/L		03/18/24 09:27	03/18/24 16:22	1
3,3'-Dichlorobenzidine	ND	U	5.00	0.341	ug/L		03/18/24 09:27	03/18/24 16:22	1
4,6-Dinitro-o-cresol	ND	U	50.0	1.44	ug/L		03/18/24 09:27	03/18/24 16:22	1
4-Bromophenyl phenyl ether	ND	U	10.0	0.256	ug/L		03/18/24 09:27	03/18/24 16:22	1
4-Chlorophenyl phenyl ether	ND	U	10.0	1.28	ug/L		03/18/24 09:27	03/18/24 16:22	1
4-Nitrophenol	ND	U	50.0	4.91	ug/L		03/18/24 09:27	03/18/24 16:22	1
p-Chloro-m-cresol	ND	U	10.0	1.57	ug/L		03/18/24 09:27	03/18/24 16:22	1
Acenaphthene	ND	U	10.0	1.39	ug/L		03/18/24 09:27	03/18/24 16:22	1
Acenaphthylene	ND	U	10.0	1.41	ug/L		03/18/24 09:27	03/18/24 16:22	1
Aniline	ND	U	10.0	0.969	ug/L		03/18/24 09:27	03/18/24 16:22	1
Anthracene	ND	U	10.0	1.50	ug/L		03/18/24 09:27	03/18/24 16:22	1
Benzidine	ND	U	50.0	4.80	ug/L		03/18/24 09:27	03/18/24 16:22	1
Benzo[a]anthracene	ND	U	5.00	0.173	ug/L		03/18/24 09:27	03/18/24 16:22	1
Benzo[a]pyrene	ND	U	5.00	0.364	ug/L		03/18/24 09:27	03/18/24 16:22	1
Benzo[b]fluoranthene	ND	U	10.0	2.04	ug/L		03/18/24 09:27	03/18/24 16:22	1
Benzo[g,h,i]perylene	ND	U	20.0	2.68	ug/L		03/18/24 09:27	03/18/24 16:22	1
Benzo[k]fluoranthene	ND	U	5.00	0.375	ug/L		03/18/24 09:27	03/18/24 16:22	1
Butyl benzyl phthalate	ND	U	10.0	0.337	ug/L		03/18/24 09:27	03/18/24 16:22	1
Chrysene	ND	U	5.00	0.222	ug/L		03/18/24 09:27	03/18/24 16:22	1
Dibenz(a,h)anthracene	ND	U	5.00	0.246	ug/L		03/18/24 09:27	03/18/24 16:22	1

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 860-150228/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 150257

Prep Batch: 150228

Analyte	MB	MB	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier									
Diethyl phthalate	ND	U			10.0	1.59	ug/L		03/18/24 09:27	03/18/24 16:22	1
Dimethyl phthalate	ND	U			10.0	0.299	ug/L		03/18/24 09:27	03/18/24 16:22	1
Fluoranthene	ND	U			10.0	1.59	ug/L		03/18/24 09:27	03/18/24 16:22	1
Fluorene	ND	U			10.0	1.63	ug/L		03/18/24 09:27	03/18/24 16:22	1
Hexachlorobenzene	ND	U			5.00	0.307	ug/L		03/18/24 09:27	03/18/24 16:22	1
Hexachlorobutadiene	ND	U			10.0	0.238	ug/L		03/18/24 09:27	03/18/24 16:22	1
Hexachlorocyclopentadiene	ND	U			10.0	4.58	ug/L		03/18/24 09:27	03/18/24 16:22	1
Hexachloroethane	ND	U			20.0	0.526	ug/L		03/18/24 09:27	03/18/24 16:22	1
Indeno[1,2,3-cd]pyrene	ND	U			5.00	2.29	ug/L		03/18/24 09:27	03/18/24 16:22	1
Isophorone	ND	U			10.0	1.64	ug/L		03/18/24 09:27	03/18/24 16:22	1
N-Nitrosodi-n-butylamine	ND	U			20.0	1.49	ug/L		03/18/24 09:27	03/18/24 16:22	1
N-Nitrosodiethylamine	ND	U			20.0	1.75	ug/L		03/18/24 09:27	03/18/24 16:22	1
N-Nitrosodimethylamine	ND	U			50.0	2.02	ug/L		03/18/24 09:27	03/18/24 16:22	1
Naphthalene	ND	U			10.0	0.542	ug/L		03/18/24 09:27	03/18/24 16:22	1
Nitrobenzene	ND	U			10.0	1.66	ug/L		03/18/24 09:27	03/18/24 16:22	1
Pentachlorobenzene	ND	U			20.0	1.07	ug/L		03/18/24 09:27	03/18/24 16:22	1
Pentachlorophenol	ND	U			5.00	0.234	ug/L		03/18/24 09:27	03/18/24 16:22	1
Phenanthrene	ND	U			10.0	1.42	ug/L		03/18/24 09:27	03/18/24 16:22	1
Phenol	ND	U			10.0	0.423	ug/L		03/18/24 09:27	03/18/24 16:22	1
Pyrene	ND	U			10.0	0.178	ug/L		03/18/24 09:27	03/18/24 16:22	1
Pyridine	ND	U			20.0	2.64	ug/L		03/18/24 09:27	03/18/24 16:22	1
Bis(2-chloroethyl)ether	ND	U			10.0	2.16	ug/L		03/18/24 09:27	03/18/24 16:22	1
Bis(2-chloroethoxy)methane	ND	U			10.0	1.76	ug/L		03/18/24 09:27	03/18/24 16:22	1
Bis(2-ethylhexyl) phthalate	ND	U			10.0	0.277	ug/L		03/18/24 09:27	03/18/24 16:22	1
Di-n-butyl phthalate	ND	U			10.0	0.252	ug/L		03/18/24 09:27	03/18/24 16:22	1
Di-n-octyl phthalate	ND	U			10.0	0.373	ug/L		03/18/24 09:27	03/18/24 16:22	1
N-Nitrosodi-n-propylamine	ND	U			20.0	2.88	ug/L		03/18/24 09:27	03/18/24 16:22	1
N-Nitrosodiphenylamine	ND	U			20.0	1.81	ug/L		03/18/24 09:27	03/18/24 16:22	1
Total Cresols	ND	U			10.0	2.62	ug/L		03/18/24 09:27	03/18/24 16:22	1

MB MB

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
bis(2-chloromethyl)ether TIC	ND	U	ug/L			542-88-1	03/18/24 09:27	03/18/24 16:22	1

MB MB

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorophenol (Surr)	26	S1-	28 - 114	03/18/24 09:27	03/18/24 16:22	1
Phenol-d5 (Surr)	17		8 - 424	03/18/24 09:27	03/18/24 16:22	1
Nitrobenzene-d5 (Surr)	60		15 - 314	03/18/24 09:27	03/18/24 16:22	1
2-Fluorobiphenyl	51		29 - 112	03/18/24 09:27	03/18/24 16:22	1
2,4,6-Tribromophenol (Surr)	48		31 - 132	03/18/24 09:27	03/18/24 16:22	1
p-Terphenyl-d14 (Surr)	70		20 - 141	03/18/24 09:27	03/18/24 16:22	1

Lab Sample ID: LCS 860-150228/2-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 150257

Prep Batch: 150228

Analyte	Spike Added	LCS		Unit	D	%Rec		Limits
		Result	Qualifier			%Rec	Limits	
1,2,4,5-Tetrachlorobenzene	40.0	22.85		ug/L		57	41 - 125	
1,2,4-Trichlorobenzene	40.0	21.25	*-	ug/L		53	57 - 130	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-150228/2-A

Matrix: Water

Analysis Batch: 150257

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 150228

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec
	Added	Result	Qualifier				Limits
1,2-Diphenylhydrazine	40.0	30.79		ug/L	77	28 - 136	
bis (2-chloroisopropyl) ether	40.0	29.81		ug/L	75	63 - 139	
2,4,5-Trichlorophenol	40.0	23.90		ug/L	60	35 - 111	
2,4,6-Trichlorophenol	40.0	24.77		ug/L	62	52 - 129	
2,4-Dichlorophenol	40.0	23.75		ug/L	59	53 - 122	
2,4-Dimethylphenol	40.0	29.56		ug/L	74	42 - 120	
2,4-Dinitrophenol	40.0	17.00	J	ug/L	43	12 - 173	
2,4-Dinitrotoluene	40.0	29.56		ug/L	74	48 - 127	
2,6-Dinitrotoluene	40.0	27.51		ug/L	69	68 - 137	
2-Chloronaphthalene	40.0	23.57	*-	ug/L	59	65 - 120	
2-Chlorophenol	40.0	21.58		ug/L	54	36 - 120	
2-Nitrophenol	40.0	24.02		ug/L	60	45 - 167	
o-Cresol	40.0	17.86		ug/L	45	14 - 176	
m & p - Cresol	40.0	18.81		ug/L	47	14 - 176	
3,3'-Dichlorobenzidine	40.0	29.17		ug/L	73	18 - 213	
4,6-Dinitro-o-cresol	40.0	31.39	J	ug/L	78	53 - 130	
4-Bromophenyl phenyl ether	40.0	26.95		ug/L	67	65 - 120	
4-Chlorophenyl phenyl ether	40.0	25.51		ug/L	64	38 - 145	
4-Nitrophenol	40.0	8.683	J	ug/L	22	13 - 129	
p-Chloro-m-cresol	40.0	24.04		ug/L	60	41 - 128	
Acenaphthene	40.0	24.93		ug/L	62	60 - 132	
Acenaphthylene	40.0	24.97		ug/L	62	54 - 126	
Aniline	40.0	17.43		ug/L	44	5 - 115	
Anthracene	40.0	30.36		ug/L	76	43 - 120	
Benzidine	40.0	ND	U *-	ug/L	10	25 - 125	
Benzo[a]anthracene	40.0	29.75		ug/L	74	42 - 133	
Benzo[a]pyrene	40.0	32.85		ug/L	82	32 - 148	
Benzo[b]fluoranthene	40.0	30.54		ug/L	76	42 - 140	
Benzo[g,h,i]perylene	40.0	30.50		ug/L	76	13 - 195	
Benzo[k]fluoranthene	40.0	30.31		ug/L	76	25 - 146	
Butyl benzyl phthalate	40.0	34.11		ug/L	85	12 - 140	
Chrysene	40.0	28.13		ug/L	70	44 - 140	
Dibenz(a,h)anthracene	40.0	32.56		ug/L	81	16 - 200	
Diethyl phthalate	40.0	29.19		ug/L	73	17 - 120	
Dimethyl phthalate	40.0	27.25		ug/L	68	25 - 120	
Fluoranthene	40.0	32.05		ug/L	80	43 - 121	
Fluorene	40.0	27.24	*-	ug/L	68	70 - 120	
Hexachlorobenzene	40.0	27.34		ug/L	68	8 - 142	
Hexachlorobutadiene	40.0	21.47		ug/L	54	38 - 120	
Hexachlorocyclopentadiene	40.0	31.41		ug/L	79	41 - 125	
Hexachloroethane	40.0	20.48	*-	ug/L	51	55 - 120	
Indeno[1,2,3-cd]pyrene	40.0	33.10		ug/L	83	13 - 151	
Isophorone	40.0	26.60		ug/L	66	47 - 180	
N-Nitrosodi-n-butylamine	40.0	24.19		ug/L	60	33 - 141	
N-Nitrosodiethylamine	40.0	25.15		ug/L	63	30 - 160	
N-Nitrosodimethylamine	40.0	13.10	J	ug/L	33	20 - 125	
Naphthalene	40.0	23.75		ug/L	59	36 - 120	
Nitrobenzene	40.0	25.14		ug/L	63	54 - 158	
Pentachlorobenzene	40.0	23.13		ug/L	58	25 - 131	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-150228/2-A

Matrix: Water

Analysis Batch: 150257

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 150228

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Pentachlorophenol	40.0	22.90		ug/L	57	38 - 152	
Phenanthrene	40.0	29.30		ug/L	73	65 - 120	
Phenol	40.0	11.90		ug/L	30	17 - 120	
Pyrene	40.0	32.39		ug/L	81	70 - 120	
Pyridine	40.0	4.491	J	ug/L	11	5 - 94	
Bis(2-chloroethyl)ether	40.0	26.76		ug/L	67	43 - 126	
Bis(2-chloroethoxy)methane	40.0	25.05		ug/L	63	49 - 165	
Bis(2-ethylhexyl) phthalate	40.0	34.65		ug/L	87	29 - 137	
Di-n-butyl phthalate	40.0	33.63		ug/L	84	8 - 120	
Di-n-octyl phthalate	40.0	38.17		ug/L	95	19 - 132	
N-Nitrosodi-n-propylamine	40.0	27.84		ug/L	70	14 - 198	
N-Nitrosodiphenylamine	40.0	28.79		ug/L	72	2 - 196	
Surrogate		LCS	LCS				
		%Recovery	Qualifier	Limits			
2-Fluorophenol (Surr)	33			28 - 114			
Phenol-d5 (Surr)	24			8 - 424			
Nitrobenzene-d5 (Surr)	64			15 - 314			
2-Fluorobiphenyl	60			29 - 112			
2,4,6-Tribromophenol (Surr)	73			31 - 132			
p-Terphenyl-d14 (Surr)	75			20 - 141			

Lab Sample ID: LCSD 860-150228/3-A

Matrix: Water

Analysis Batch: 150257

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 150228

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
1,2,4,5-Tetrachlorobenzene	40.0	24.85		ug/L	62	41 - 125		8	30
1,2,4-Trichlorobenzene	40.0	23.61		ug/L	59	57 - 130		11	30
1,2-Diphenylhydrazine	40.0	33.25		ug/L	83	28 - 136		8	30
bis (2-chloroisopropyl) ether	40.0	33.33		ug/L	83	63 - 139		11	30
2,4,5-Trichlorophenol	40.0	26.86		ug/L	67	35 - 111		12	30
2,4,6-Trichlorophenol	40.0	27.20		ug/L	68	52 - 129		9	30
2,4-Dichlorophenol	40.0	26.29		ug/L	66	53 - 122		10	30
2,4-Dimethylphenol	40.0	32.28		ug/L	81	42 - 120		9	30
2,4-Dinitrophenol	40.0	19.37	J	ug/L	48	12 - 173		13	30
2,4-Dinitrotoluene	40.0	31.92		ug/L	80	48 - 127		8	25
2,6-Dinitrotoluene	40.0	29.47		ug/L	74	68 - 137		7	29
2-Chloronaphthalene	40.0	25.51	*	ug/L	64	65 - 120		8	15
2-Chlorophenol	40.0	23.61		ug/L	59	36 - 120		9	30
2-Nitrophenol	40.0	26.42		ug/L	66	45 - 167		10	30
o-Cresol	40.0	19.28		ug/L	48	14 - 176		8	30
m & p - Cresol	40.0	20.68		ug/L	52	14 - 176		9	30
3,3'-Dichlorobenzidine	40.0	31.91		ug/L	80	18 - 213		9	30
4,6-Dinitro-o-cresol	40.0	33.51	J	ug/L	84	53 - 130		7	30
4-Bromophenyl phenyl ether	40.0	28.77		ug/L	72	65 - 120		7	26
4-Chlorophenyl phenyl ether	40.0	27.21		ug/L	68	38 - 145		6	30
4-Nitrophenol	40.0	9.373	J	ug/L	23	13 - 129		8	30
p-Chloro-m-cresol	40.0	26.90		ug/L	67	41 - 128		11	30

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 860-150228/3-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 150257

Prep Batch: 150228

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec		RPD	RPD Limit
	Added	Result	Qualifier				Limits			
Acenaphthene	40.0	27.54		ug/L	69	60 - 132		10	29	
Acenaphthylene	40.0	27.11		ug/L	68	54 - 126		8	30	
Aniline	40.0	20.58		ug/L	51	5 - 115		17	30	
Anthracene	40.0	32.48		ug/L	81	43 - 120		7	30	
Benzidine	40.0	7.667 J *- *1		ug/L	19	25 - 125		64	30	
Benzo[a]anthracene	40.0	32.32		ug/L	81	42 - 133		8	30	
Benzo[a]pyrene	40.0	34.93		ug/L	87	32 - 148		6	30	
Benzo[b]fluoranthene	40.0	33.58		ug/L	84	42 - 140		9	30	
Benzo[g,h,i]perylene	40.0	31.72		ug/L	79	13 - 195		4	30	
Benzo[k]fluoranthene	40.0	31.22		ug/L	78	25 - 146		3	30	
Butyl benzyl phthalate	40.0	36.46		ug/L	91	12 - 140		7	30	
Chrysene	40.0	29.79		ug/L	74	44 - 140		6	30	
Dibenz(a,h)anthracene	40.0	34.25		ug/L	86	16 - 200		5	30	
Diethyl phthalate	40.0	30.62		ug/L	77	17 - 120		5	30	
Dimethyl phthalate	40.0	29.17		ug/L	73	25 - 120		7	30	
Fluoranthene	40.0	33.89		ug/L	85	43 - 121		6	30	
Fluorene	40.0	28.86		ug/L	72	70 - 120		6	23	
Hexachlorobenzene	40.0	28.96		ug/L	72	8 - 142		6	30	
Hexachlorobutadiene	40.0	23.34		ug/L	58	38 - 120		8	30	
Hexachlorocyclopentadiene	40.0	35.51		ug/L	89	41 - 125		12	30	
Hexachloroethane	40.0	23.01		ug/L	58	55 - 120		12	30	
Indeno[1,2,3-cd]pyrene	40.0	35.02		ug/L	88	13 - 151		6	30	
Isophorone	40.0	29.53		ug/L	74	47 - 180		10	30	
N-Nitrosodi-n-butylamine	40.0	26.54		ug/L	66	33 - 141		9	30	
N-Nitrosodiethylamine	40.0	28.19		ug/L	70	30 - 160		11	30	
N-Nitrosodimethylamine	40.0	13.95 J		ug/L	35	20 - 125		6	30	
Naphthalene	40.0	26.21		ug/L	66	36 - 120		10	30	
Nitrobenzene	40.0	28.18		ug/L	70	54 - 158		11	30	
Pentachlorobenzene	40.0	24.98		ug/L	62	25 - 131		8	30	
Pentachlorophenol	40.0	23.70		ug/L	59	38 - 152		3	30	
Phenanthrene	40.0	31.07		ug/L	78	65 - 120		6	30	
Phenol	40.0	12.99		ug/L	32	17 - 120		9	30	
Pyrene	40.0	34.51		ug/L	86	70 - 120		6	30	
Pyridine	40.0	6.910 J *1		ug/L	17	5 - 94		42	30	
Bis(2-chloroethyl)ether	40.0	29.93		ug/L	75	43 - 126		11	30	
Bis(2-chloroethoxy)methane	40.0	27.70		ug/L	69	49 - 165		10	30	
Bis(2-ethylhexyl) phthalate	40.0	36.95		ug/L	92	29 - 137		6	30	
Di-n-butyl phthalate	40.0	36.14		ug/L	90	8 - 120		7	28	
Di-n-octyl phthalate	40.0	40.16		ug/L	100	19 - 132		5	30	
N-Nitrosodi-n-propylamine	40.0	30.87		ug/L	77	14 - 198		10	30	
N-Nitrosodiphenylamine	40.0	31.46		ug/L	79	2 - 196		9	30	

Surrogate	LCSD	LCSD	Limits
	%Recovery	Qualifier	
2-Fluorophenol (Surr)	34		28 - 114
Phenol-d5 (Surr)	24		8 - 424
Nitrobenzene-d5 (Surr)	68		15 - 314
2-Fluorobiphenyl	64		29 - 112
2,4,6-Tribromophenol (Surr)	75		31 - 132

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 860-150228/3-A

Matrix: Water

Analysis Batch: 150257

Surrogate	LCSD	LCSD	
	%Recovery	Qualifier	Limits
p-Terphenyl-d14 (Surr)	77		20 - 141

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 150228

Lab Sample ID: MB 860-150805/1-A

Matrix: Water

Analysis Batch: 150908

Analyte	MB	MB	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,4,5-Tetrachlorobenzene			ND	U	10.0	1.32	ug/L		03/20/24 16:17	03/21/24 18:10	1
1,2,4-Trichlorobenzene			ND	U	10.0	1.61	ug/L		03/20/24 16:17	03/21/24 18:10	1
1,2-Diphenylhydrazine			ND	U	10.0	1.49	ug/L		03/20/24 16:17	03/21/24 18:10	1
bis (2-chloroisopropyl) ether			ND	U	10.0	1.79	ug/L		03/20/24 16:17	03/21/24 18:10	1
2,4,5-Trichlorophenol			ND	U	10.0	2.00	ug/L		03/20/24 16:17	03/21/24 18:10	1
2,4,6-Trichlorophenol			ND	U	10.0	1.42	ug/L		03/20/24 16:17	03/21/24 18:10	1
2,4-Dichlorophenol			ND	U	10.0	0.314	ug/L		03/20/24 16:17	03/21/24 18:10	1
2,4-Dimethylphenol			ND	U	10.0	0.649	ug/L		03/20/24 16:17	03/21/24 18:10	1
2,4-Dinitrophenol			ND	U	50.0	1.61	ug/L		03/20/24 16:17	03/21/24 18:10	1
2,4-Dinitrotoluene			ND	U	10.0	1.31	ug/L		03/20/24 16:17	03/21/24 18:10	1
2,6-Dinitrotoluene			ND	U	10.0	1.61	ug/L		03/20/24 16:17	03/21/24 18:10	1
2-Chloronaphthalene			ND	U	10.0	0.462	ug/L		03/20/24 16:17	03/21/24 18:10	1
2-Chlorophenol			ND	U	10.0	0.649	ug/L		03/20/24 16:17	03/21/24 18:10	1
2-Nitrophenol			ND	U	20.0	1.67	ug/L		03/20/24 16:17	03/21/24 18:10	1
o-Cresol			ND	U	10.0	1.62	ug/L		03/20/24 16:17	03/21/24 18:10	1
m & p - Cresol			ND	U	10.0	2.62	ug/L		03/20/24 16:17	03/21/24 18:10	1
3,3'-Dichlorobenzidine			ND	U	5.00	0.341	ug/L		03/20/24 16:17	03/21/24 18:10	1
4,6-Dinitro-o-cresol			ND	U	50.0	1.44	ug/L		03/20/24 16:17	03/21/24 18:10	1
4-Bromophenyl phenyl ether			ND	U	10.0	0.256	ug/L		03/20/24 16:17	03/21/24 18:10	1
4-Chlorophenyl phenyl ether			ND	U	10.0	1.28	ug/L		03/20/24 16:17	03/21/24 18:10	1
4-Nitrophenol			ND	U	50.0	4.91	ug/L		03/20/24 16:17	03/21/24 18:10	1
p-Chloro-m-cresol			ND	U	10.0	1.57	ug/L		03/20/24 16:17	03/21/24 18:10	1
Acenaphthene			ND	U	10.0	1.39	ug/L		03/20/24 16:17	03/21/24 18:10	1
Acenaphthylene			ND	U	10.0	1.41	ug/L		03/20/24 16:17	03/21/24 18:10	1
Aniline			ND	U	10.0	0.969	ug/L		03/20/24 16:17	03/21/24 18:10	1
Anthracene			ND	U	10.0	1.50	ug/L		03/20/24 16:17	03/21/24 18:10	1
Benzidine			ND	U	50.0	4.80	ug/L		03/20/24 16:17	03/21/24 18:10	1
Benzo[a]anthracene			ND	U	5.00	0.173	ug/L		03/20/24 16:17	03/21/24 18:10	1
Benzo[a]pyrene			ND	U	5.00	0.364	ug/L		03/20/24 16:17	03/21/24 18:10	1
Benzo[b]fluoranthene			ND	U	10.0	2.04	ug/L		03/20/24 16:17	03/21/24 18:10	1
Benzo[g,h,i]perylene			ND	U	20.0	2.68	ug/L		03/20/24 16:17	03/21/24 18:10	1
Benzo[k]fluoranthene			ND	U	5.00	0.375	ug/L		03/20/24 16:17	03/21/24 18:10	1
Butyl benzyl phthalate			ND	U	10.0	0.337	ug/L		03/20/24 16:17	03/21/24 18:10	1
Chrysene			ND	U	5.00	0.222	ug/L		03/20/24 16:17	03/21/24 18:10	1
Dibenz(a,h)anthracene			ND	U	5.00	0.246	ug/L		03/20/24 16:17	03/21/24 18:10	1
Diethyl phthalate			ND	U	10.0	1.59	ug/L		03/20/24 16:17	03/21/24 18:10	1
Dimethyl phthalate			ND	U	10.0	0.299	ug/L		03/20/24 16:17	03/21/24 18:10	1
Fluoranthene			ND	U	10.0	1.59	ug/L		03/20/24 16:17	03/21/24 18:10	1
Fluorene			ND	U	10.0	1.63	ug/L		03/20/24 16:17	03/21/24 18:10	1
Hexachlorobenzene			ND	U	5.00	0.307	ug/L		03/20/24 16:17	03/21/24 18:10	1
Hexachlorobutadiene			ND	U	10.0	0.238	ug/L		03/20/24 16:17	03/21/24 18:10	1

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 860-150805/1-A

Matrix: Water

Analysis Batch: 150908

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 150805

Analyte	MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Hexachlorocyclopentadiene	ND	U	10.0	4.58	ug/L		03/20/24 16:17	03/21/24 18:10	1
Hexachloroethane	ND	U	20.0	0.526	ug/L		03/20/24 16:17	03/21/24 18:10	1
Indeno[1,2,3-cd]pyrene	ND	U	5.00	2.29	ug/L		03/20/24 16:17	03/21/24 18:10	1
Isophorone	ND	U	10.0	1.64	ug/L		03/20/24 16:17	03/21/24 18:10	1
N-Nitrosodi-n-butylamine	ND	U	20.0	1.49	ug/L		03/20/24 16:17	03/21/24 18:10	1
N-Nitrosodiethylamine	ND	U	20.0	1.75	ug/L		03/20/24 16:17	03/21/24 18:10	1
N-Nitrosodimethylamine	ND	U	50.0	2.02	ug/L		03/20/24 16:17	03/21/24 18:10	1
Naphthalene	ND	U	10.0	0.542	ug/L		03/20/24 16:17	03/21/24 18:10	1
Nitrobenzene	ND	U	10.0	1.66	ug/L		03/20/24 16:17	03/21/24 18:10	1
Pentachlorobenzene	ND	U	20.0	1.07	ug/L		03/20/24 16:17	03/21/24 18:10	1
Pentachlorophenol	ND	U	5.00	0.234	ug/L		03/20/24 16:17	03/21/24 18:10	1
Phenanthrene	ND	U	10.0	1.42	ug/L		03/20/24 16:17	03/21/24 18:10	1
Phenol	ND	U	10.0	0.423	ug/L		03/20/24 16:17	03/21/24 18:10	1
Pyrene	ND	U	10.0	0.178	ug/L		03/20/24 16:17	03/21/24 18:10	1
Pyridine	ND	U	20.0	2.64	ug/L		03/20/24 16:17	03/21/24 18:10	1
Bis(2-chloroethyl)ether	ND	U	10.0	2.16	ug/L		03/20/24 16:17	03/21/24 18:10	1
Bis(2-chloroethoxy)methane	ND	U	10.0	1.76	ug/L		03/20/24 16:17	03/21/24 18:10	1
Bis(2-ethylhexyl) phthalate	ND	U	10.0	0.277	ug/L		03/20/24 16:17	03/21/24 18:10	1
Di-n-butyl phthalate	ND	U	10.0	0.252	ug/L		03/20/24 16:17	03/21/24 18:10	1
Di-n-octyl phthalate	ND	U	10.0	0.373	ug/L		03/20/24 16:17	03/21/24 18:10	1
N-Nitrosodi-n-propylamine	ND	U	20.0	2.88	ug/L		03/20/24 16:17	03/21/24 18:10	1
N-Nitrosodiphenylamine	ND	U	20.0	1.81	ug/L		03/20/24 16:17	03/21/24 18:10	1
Total Cresols	ND	U	10.0	2.62	ug/L		03/20/24 16:17	03/21/24 18:10	1

Tentatively Identified Compound	MB		D	RT	CAS No.	Prepared	Analyzed	Dil Fac
	Est. Result	Qualifier						
bis(2-chloromethyl)ether TIC	ND	U	ug/L		542-88-1	03/20/24 16:17	03/21/24 18:10	1
Surrogate								
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
2-Fluorophenol (Surr)	24	S1-	28 - 114			03/20/24 16:17	03/21/24 18:10	1
Phenol-d5 (Surr)	16		8 - 424			03/20/24 16:17	03/21/24 18:10	1
Nitrobenzene-d5 (Surr)	59		15 - 314			03/20/24 16:17	03/21/24 18:10	1
2-Fluorobiphenyl	55		29 - 112			03/20/24 16:17	03/21/24 18:10	1
2,4,6-Tribromophenol (Surr)	62		31 - 132			03/20/24 16:17	03/21/24 18:10	1
p-Terphenyl-d14 (Surr)	94		20 - 141			03/20/24 16:17	03/21/24 18:10	1

Lab Sample ID: LCS 860-150805/2-A

Matrix: Water

Analysis Batch: 150908

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 150805

Analyte	Spike Added	LCS		Unit	D	%Rec	Limits
		Result	Qualifier				
1,2,4,5-Tetrachlorobenzene	40.0	31.55		ug/L	79	41 - 125	
1,2,4-Trichlorobenzene	40.0	28.12		ug/L	70	57 - 130	
1,2-Diphenylhydrazine	40.0	40.12		ug/L	100	28 - 136	
bis (2-chloroisopropyl) ether	40.0	37.69		ug/L	94	63 - 139	
2,4,5-Trichlorophenol	40.0	32.12		ug/L	80	35 - 111	
2,4,6-Trichlorophenol	40.0	33.54		ug/L	84	52 - 129	
2,4-Dichlorophenol	40.0	31.92		ug/L	80	53 - 122	
2,4-Dimethylphenol	40.0	39.94		ug/L	100	42 - 120	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-150805/2-A

Matrix: Water

Analysis Batch: 150908

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 150805

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec
	Added	Result	Qualifier				Limits
2,4-Dinitrophenol	40.0	24.49	J	ug/L	61	12 - 173	
2,4-Dinitrotoluene	40.0	36.62		ug/L	92	48 - 127	
2,6-Dinitrotoluene	40.0	33.71		ug/L	84	68 - 137	
2-Chloronaphthalene	40.0	33.54		ug/L	84	65 - 120	
2-Chlorophenol	40.0	27.82		ug/L	70	36 - 120	
2-Nitrophenol	40.0	32.78		ug/L	82	45 - 167	
o-Cresol	40.0	23.33		ug/L	58	14 - 176	
m & p - Cresol	40.0	24.21		ug/L	61	14 - 176	
3,3'-Dichlorobenzidine	40.0	36.51		ug/L	91	18 - 213	
4,6-Dinitro-o-cresol	40.0	40.67	J	ug/L	102	53 - 130	
4-Bromophenyl phenyl ether	40.0	35.61		ug/L	89	65 - 120	
4-Chlorophenyl phenyl ether	40.0	33.20		ug/L	83	38 - 145	
4-Nitrophenol	40.0	14.21	J	ug/L	36	13 - 129	
p-Chloro-m-cresol	40.0	30.60		ug/L	76	41 - 128	
Acenaphthene	40.0	33.84		ug/L	85	60 - 132	
Acenaphthylene	40.0	33.17		ug/L	83	54 - 126	
Aniline	40.0	22.85		ug/L	57	5 - 115	
Anthracene	40.0	38.81		ug/L	97	43 - 120	
Benzidine	40.0	7.460	J *-	ug/L	19	25 - 125	
Benzo[a]anthracene	40.0	37.14		ug/L	93	42 - 133	
Benzo[a]pyrene	40.0	41.74		ug/L	104	32 - 148	
Benzo[b]fluoranthene	40.0	38.38		ug/L	96	42 - 140	
Benzo[g,h,i]perylene	40.0	40.14		ug/L	100	13 - 195	
Benzo[k]fluoranthene	40.0	38.72		ug/L	97	25 - 146	
Butyl benzyl phthalate	40.0	42.00		ug/L	105	12 - 140	
Chrysene	40.0	35.08		ug/L	88	44 - 140	
Dibenz(a,h)anthracene	40.0	42.56		ug/L	106	16 - 200	
Diethyl phthalate	40.0	35.54		ug/L	89	17 - 120	
Dimethyl phthalate	40.0	33.67		ug/L	84	25 - 120	
Fluoranthene	40.0	39.37		ug/L	98	43 - 121	
Fluorene	40.0	34.79		ug/L	87	70 - 120	
Hexachlorobenzene	40.0	35.40		ug/L	88	8 - 142	
Hexachlorobutadiene	40.0	27.13		ug/L	68	38 - 120	
Hexachlorocyclopentadiene	40.0	41.73		ug/L	104	41 - 125	
Hexachloroethane	40.0	24.35		ug/L	61	55 - 120	
Indeno[1,2,3-cd]pyrene	40.0	43.50		ug/L	109	13 - 151	
Isophorone	40.0	34.56		ug/L	86	47 - 180	
N-Nitrosodi-n-butylamine	40.0	30.94		ug/L	77	33 - 141	
N-Nitrosodiethylamine	40.0	33.01		ug/L	83	30 - 160	
N-Nitrosodimethylamine	40.0	17.02	J	ug/L	43	20 - 125	
Naphthalene	40.0	31.13		ug/L	78	36 - 120	
Nitrobenzene	40.0	33.71		ug/L	84	54 - 158	
Pentachlorobenzene	40.0	30.47		ug/L	76	25 - 131	
Pentachlorophenol	40.0	30.27		ug/L	76	38 - 152	
Phenanthrone	40.0	37.35		ug/L	93	65 - 120	
Phenol	40.0	15.72		ug/L	39	17 - 120	
Pyrene	40.0	40.85		ug/L	102	70 - 120	
Pyridine	80.0	11.76	J	ug/L	15	5 - 94	
Bis(2-chloroethyl)ether	40.0	34.04		ug/L	85	43 - 126	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 860-150805/2-A

Matrix: Water

Analysis Batch: 150908

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 150805

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec
		Result	Qualifier				Limits
Bis(2-chloroethoxy)methane	40.0	33.41		ug/L	84	49 - 165	
Bis(2-ethylhexyl) phthalate	40.0	43.40		ug/L	109	29 - 137	
Di-n-butyl phthalate	40.0	41.41		ug/L	104	8 - 120	
Di-n-octyl phthalate	40.0	47.37		ug/L	118	19 - 132	
N-Nitrosodi-n-propylamine	40.0	34.76		ug/L	87	14 - 198	
N-Nitrosodiphenylamine	40.0	38.52		ug/L	96	2 - 196	

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
2-Fluorophenol (Surr)	41		28 - 114
Phenol-d5 (Surr)	29		8 - 424
Nitrobenzene-d5 (Surr)	81		15 - 314
2-Fluorobiphenyl	80		29 - 112
2,4,6-Tribromophenol (Surr)	91		31 - 132
p-Terphenyl-d14 (Surr)	92		20 - 141

Lab Sample ID: LCSD 860-150805/3-A

Matrix: Water

Analysis Batch: 150908

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 150805

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD
	Added	Result	Qualifier				Limits	RPD
1,2,4,5-Tetrachlorobenzene	40.0	32.72		ug/L	82	41 - 125	4	30
1,2,4-Trichlorobenzene	40.0	28.52		ug/L	71	57 - 130	1	30
1,2-Diphenylhydrazine	40.0	41.08		ug/L	103	28 - 136	2	30
bis (2-chloroisopropyl) ether	40.0	38.23		ug/L	96	63 - 139	1	30
2,4,5-Trichlorophenol	40.0	34.37		ug/L	86	35 - 111	7	30
2,4,6-Trichlorophenol	40.0	35.10		ug/L	88	52 - 129	5	30
2,4-Dichlorophenol	40.0	33.69		ug/L	84	53 - 122	5	30
2,4-Dimethylphenol	40.0	40.90		ug/L	102	42 - 120	2	30
2,4-Dinitrophenol	40.0	28.22	J	ug/L	71	12 - 173	14	30
2,4-Dinitrotoluene	40.0	40.09		ug/L	100	48 - 127	9	25
2,6-Dinitrotoluene	40.0	35.80		ug/L	89	68 - 137	6	29
2-Chloronaphthalene	40.0	32.11		ug/L	80	65 - 120	4	15
2-Chlorophenol	40.0	28.74		ug/L	72	36 - 120	3	30
2-Nitrophenol	40.0	33.00		ug/L	82	45 - 167	1	30
o-Cresol	40.0	24.67		ug/L	62	14 - 176	6	30
m & p - Cresol	40.0	26.51		ug/L	66	14 - 176	9	30
3,3'-Dichlorobenzidine	40.0	41.62		ug/L	104	18 - 213	13	30
4,6-Dinitro-o-cresol	40.0	45.43	J	ug/L	114	53 - 130	11	30
4-Bromophenyl phenyl ether	40.0	36.26		ug/L	91	65 - 120	2	26
4-Chlorophenyl phenyl ether	40.0	34.17		ug/L	85	38 - 145	3	30
4-Nitrophenol	40.0	17.02	J	ug/L	43	13 - 129	18	30
p-Chloro-m-cresol	40.0	31.86		ug/L	80	41 - 128	4	30
Acenaphthene	40.0	35.45		ug/L	89	60 - 132	5	29
Acenaphthylene	40.0	35.43		ug/L	89	54 - 126	7	30
Aniline	40.0	22.96		ug/L	57	5 - 115	1	30
Anthracene	40.0	42.10		ug/L	105	43 - 120	8	30
Benzidine	40.0	7.117	J *-	ug/L	18	25 - 125	5	30
Benzo[a]anthracene	40.0	40.85		ug/L	102	42 - 133	10	30

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 860-150805/3-A

Matrix: Water

Analysis Batch: 150908

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 150805

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
Benzo[a]pyrene	40.0	46.33		ug/L	116	32 - 148	10	30	
Benzo[b]fluoranthene	40.0	43.81		ug/L	110	42 - 140	13	30	
Benzo[g,h,i]perylene	40.0	43.95		ug/L	110	13 - 195	9	30	
Benzo[k]fluoranthene	40.0	40.83		ug/L	102	25 - 146	5	30	
Butyl benzyl phthalate	40.0	46.21		ug/L	116	12 - 140	10	30	
Chrysene	40.0	38.76		ug/L	97	44 - 140	10	30	
Dibenz(a,h)anthracene	40.0	46.46		ug/L	116	16 - 200	9	30	
Diethyl phthalate	40.0	38.29		ug/L	96	17 - 120	7	30	
Dimethyl phthalate	40.0	35.60		ug/L	89	25 - 120	6	30	
Fluoranthene	40.0	44.57		ug/L	111	43 - 121	12	30	
Fluorene	40.0	36.22		ug/L	91	70 - 120	4	23	
Hexachlorobenzene	40.0	37.04		ug/L	93	8 - 142	5	30	
Hexachlorobutadiene	40.0	26.38		ug/L	66	38 - 120	3	30	
Hexachlorocyclopentadiene	40.0	43.29		ug/L	108	41 - 125	4	30	
Hexachloroethane	40.0	24.36		ug/L	61	55 - 120	0	30	
Indeno[1,2,3-cd]pyrene	40.0	46.98		ug/L	117	13 - 151	8	30	
Isophorone	40.0	36.17		ug/L	90	47 - 180	5	30	
N-Nitrosodi-n-butylamine	40.0	31.91		ug/L	80	33 - 141	3	30	
N-Nitrosodiethylamine	40.0	33.38		ug/L	83	30 - 160	1	30	
N-Nitrosodimethylamine	40.0	17.11 J		ug/L	43	20 - 125	1	30	
Naphthalene	40.0	31.60		ug/L	79	36 - 120	2	30	
Nitrobenzene	40.0	34.17		ug/L	85	54 - 158	1	30	
Pentachlorobenzene	40.0	32.17		ug/L	80	25 - 131	5	30	
Pentachlorophenol	40.0	34.25		ug/L	86	38 - 152	12	30	
Phenanthrene	40.0	40.31		ug/L	101	65 - 120	8	30	
Phenol	40.0	16.55		ug/L	41	17 - 120	5	30	
Pyrene	40.0	43.58		ug/L	109	70 - 120	6	30	
Pyridine	80.0	10.66 J		ug/L	13	5 - 94	10	30	
Bis(2-chloroethyl)ether	40.0	34.67		ug/L	87	43 - 126	2	30	
Bis(2-chloroethoxy)methane	40.0	33.97		ug/L	85	49 - 165	2	30	
Bis(2-ethylhexyl) phthalate	40.0	47.63		ug/L	119	29 - 137	9	30	
Di-n-butyl phthalate	40.0	46.00		ug/L	115	8 - 120	10	28	
Di-n-octyl phthalate	40.0	51.99		ug/L	130	19 - 132	9	30	
N-Nitrosodi-n-propylamine	40.0	36.78		ug/L	92	14 - 198	6	30	
N-Nitrosodiphenylamine	40.0	39.21		ug/L	98	2 - 196	2	30	

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
2-Fluorophenol (Surr)	43		28 - 114
Phenol-d5 (Surr)	32		8 - 424
Nitrobenzene-d5 (Surr)	84		15 - 314
2-Fluorobiphenyl	83		29 - 112
2,4,6-Tribromophenol (Surr)	97		31 - 132
p-Terphenyl-d14 (Surr)	100		20 - 141

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: D7065-11 - Determination of Nonylphenols

Lab Sample ID: MB 280-647138/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 647441

Prep Batch: 647138

Analyte	MB		MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier	%Recovery	Qualifier							
Nonylphenol	ND	U			5000	1140	ng/L		03/26/24 12:09	03/28/24 10:59	1
Nonylphenol diethoxylate	ND	U			20000	4570	ng/L		03/26/24 12:09	03/28/24 10:59	1
Nonylphenol monoethoxylate	ND	U			10000	2050	ng/L		03/26/24 12:09	03/28/24 10:59	1
Bisphenol-A	ND	U			2100	1030	ng/L		03/26/24 12:09	03/28/24 10:59	1
4-tert-Octylphenol	ND	U			1000	280	ng/L		03/26/24 12:09	03/28/24 10:59	1
Surrogate	MB		MB		Limits			D	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier									
4-nonylphenol (Surr)	77				58 - 115				03/26/24 12:09	03/28/24 10:59	1
4-nonylphenol monoethoxylate (Surr)	84				54 - 139				03/26/24 12:09	03/28/24 10:59	1

Lab Sample ID: LCS 280-647138/2-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 647441

Prep Batch: 647138

Analyte	Spike		LCS		Unit	D	%Rec	Limits
	Added	Result	Result	Qualifier				
Nonylphenol	51300	41650			ng/L		81	56 - 125
Nonylphenol diethoxylate	202000	175700			ng/L		87	54 - 128
Nonylphenol monoethoxylate	103000	109400			ng/L		106	57 - 125
Bisphenol-A	10100	6534			ng/L		64	52 - 125
4-tert-Octylphenol	10100	8257			ng/L		82	55 - 125
Surrogate	LCS		LCS			D	%Rec	Limits
	%Recovery	Qualifier		Limits				
4-nonylphenol (Surr)	94			58 - 115				
4-nonylphenol monoethoxylate (Surr)	103			54 - 139				

Method: Organotins SIM - Organotins (GC/MS SIM)

Lab Sample ID: MB 570-421863/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 424204

Prep Batch: 421863

Analyte	MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Tributyltin	ND	U	3.00	1.14	ng/L		03/19/24 17:03	03/26/24 12:47	1
Surrogate	MB		Limits			D	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier							
Tripentyltin	66		10 - 120				03/19/24 17:03	03/26/24 12:47	1

Lab Sample ID: LCS 570-421863/2-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 424204

Prep Batch: 421863

Analyte	Spike		RL	MDL	Unit	D	%Rec	Limits
	Added	Result						
Tributyltin	178	177.0			ng/L		99	10 - 120
Surrogate	LCS		LCS			D	%Rec	Limits
	%Recovery	Qualifier		Limits				
Tripentyltin	52			10 - 120				

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: Organotins SIM - Organotins (GC/MS SIM) (Continued)

Lab Sample ID: LCSD 570-421863/3-A

Matrix: Water

Analysis Batch: 424204

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 421863

Analyte		Spike	LCSD	LCSD	Unit	D	%Rec	Limits	RPD	RPD	Limit
		Added	Result	Qualifier							
Tributyltin		178	190.4		ng/L						
Surrogate											
Tripentyltin		53		Limits							

Method: 608.3 - Organochlorine Pesticides in Water

Lab Sample ID: MB 860-150340/1-A

Matrix: Water

Analysis Batch: 150874

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 150340

Analyte	MB	MB	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier									
4,4'-DDD	ND	U			0.0200	0.000814	ug/L		03/18/24 16:12	03/21/24 09:44	1
4,4'-DDE	ND	U			0.0200	0.00109	ug/L		03/18/24 16:12	03/21/24 09:44	1
4,4'-DDT	ND	U			0.00400	0.00379	ug/L		03/18/24 16:12	03/21/24 09:44	1
Aldrin	ND	U			0.00200	0.00113	ug/L		03/18/24 16:12	03/21/24 09:44	1
alpha-BHC	ND	U			0.00900	0.00142	ug/L		03/18/24 16:12	03/21/24 09:44	1
beta-BHC	ND	U			0.0180	0.00389	ug/L		03/18/24 16:12	03/21/24 09:44	1
Chlordane	ND	U			0.103	0.103	ug/L		03/18/24 16:12	03/21/24 09:44	1
delta-BHC	ND	U			0.250	0.00245	ug/L		03/18/24 16:12	03/21/24 09:44	1
Dicofol	ND	U			0.200	0.0500	ug/L		03/18/24 16:12	03/21/24 09:44	1
Dieldrin	ND	U			0.00400	0.000953	ug/L		03/18/24 16:12	03/21/24 09:44	1
Endosulfan I	ND	U			0.00200	0.00107	ug/L		03/18/24 16:12	03/21/24 09:44	1
Endosulfan II	ND	U			0.00400	0.00122	ug/L		03/18/24 16:12	03/21/24 09:44	1
Endosulfan sulfate	ND	U			0.0200	0.00112	ug/L		03/18/24 16:12	03/21/24 09:44	1
Endrin	ND	U			0.00400	0.00156	ug/L		03/18/24 16:12	03/21/24 09:44	1
Endrin aldehyde	ND	U			0.0200	0.00118	ug/L		03/18/24 16:12	03/21/24 09:44	1
Hexachlorocyclohexane	ND	U			0.0100	0.00299	ug/L		03/18/24 16:12	03/21/24 09:44	1
Heptachlor	ND	U			0.00446	0.00446	ug/L		03/18/24 16:12	03/21/24 09:44	1
Heptachlor epoxide	ND	U			0.00200	0.00134	ug/L		03/18/24 16:12	03/21/24 09:44	1
Methoxychlor	ND	U			0.0200	0.00390	ug/L		03/18/24 16:12	03/21/24 09:44	1
Mirex	ND	U			0.0200	0.0200	ug/L		03/18/24 16:12	03/21/24 09:44	1
Toxaphene	ND	U			0.0770	0.0769	ug/L		03/18/24 16:12	03/21/24 09:44	1
Surrogate											
	MB	MB	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
DCB Decachlorobiphenyl (Surr)			130		15 - 136				03/18/24 16:12	03/21/24 09:44	1
Tetrachloro-m-xylene (Surr)			89		18 - 126				03/18/24 16:12	03/21/24 09:44	1

Lab Sample ID: LCS 860-150340/2-A

Matrix: Water

Analysis Batch: 150874

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 150340

Analyte	Spike	LCS	LCS	Unit	D	%Rec	Limits	
	Added	Result	Qualifier					
4,4'-DDD	0.100	0.1461	*+	ug/L		146	31 - 141	
4,4'-DDE	0.100	0.1340		ug/L		134	30 - 145	
4,4'-DDT	0.100	0.1397		ug/L		140	25 - 160	
Aldrin	0.100	0.1142		ug/L		114	42 - 140	
alpha-BHC	0.100	0.1191		ug/L		119	37 - 140	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 608.3 - Organochlorine Pesticides in Water (Continued)

Lab Sample ID: LCS 860-150340/2-A

Matrix: Water

Analysis Batch: 150874

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 150340

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec
	Added	Result	Qualifier				Limits
beta-BHC	0.100	0.1307		ug/L	131	17 - 147	
delta-BHC	0.100	0.08681	J	ug/L	87	19 - 140	
Dieldrin	0.100	0.1219		ug/L	122	36 - 146	
Endosulfan I	0.100	0.1343		ug/L	134	45 - 153	
Endosulfan II	0.100	0.1399		ug/L	140	22 - 171	
Endosulfan sulfate	0.100	0.09852		ug/L	99	26 - 144	
Endrin	0.100	0.1401		ug/L	140	30 - 147	
Endrin aldehyde	0.100	0.1380	*+	ug/L	138	60 - 130	
Hexachlorocyclohexane	0.100	0.1296		ug/L	130	34 - 140	
Heptachlor	0.100	0.1590	*+	ug/L	159	34 - 140	
Heptachlor epoxide	0.100	0.1341		ug/L	134	37 - 142	
Methoxychlor	0.100	0.1632	*+	ug/L	163	50 - 130	

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
DCB Decachlorobiphenyl (Surr)	153	S1+	15 - 136
Tetrachloro-m-xylene (Surr)	123		18 - 126

Lab Sample ID: LCSD 860-150340/3-A

Matrix: Water

Analysis Batch: 150874

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 150340

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD
	Added	Result	Qualifier				Limits	RPD
4,4'-DDD	0.100	0.1405		ug/L	141	31 - 141	4	30
4,4'-DDE	0.100	0.1308		ug/L	131	30 - 145	2	30
4,4'-DDT	0.100	0.1339		ug/L	134	25 - 160	4	30
Aldrin	0.100	0.1120		ug/L	112	42 - 140	2	30
alpha-BHC	0.100	0.1156		ug/L	116	37 - 140	3	30
beta-BHC	0.100	0.1248		ug/L	125	17 - 147	5	30
delta-BHC	0.100	0.08247	J	ug/L	82	19 - 140	5	30
Dieldrin	0.100	0.1189		ug/L	119	36 - 146	3	30
Endosulfan I	0.100	0.1316		ug/L	132	45 - 153	2	30
Endosulfan II	0.100	0.1342		ug/L	134	22 - 171	4	30
Endosulfan sulfate	0.100	0.09556		ug/L	96	26 - 144	3	30
Endrin	0.100	0.1337		ug/L	134	30 - 147	5	30
Endrin aldehyde	0.100	0.1350	*+	ug/L	135	60 - 130	2	30
Hexachlorocyclohexane	0.100	0.1255		ug/L	126	34 - 140	3	30
Heptachlor	0.100	0.1552	*+	ug/L	155	34 - 140	2	30
Heptachlor epoxide	0.100	0.1311		ug/L	131	37 - 142	2	30
Methoxychlor	0.100	0.1590	*+	ug/L	159	50 - 130	3	30

Surrogate	LCSD	LCSD	Limits
	%Recovery	Qualifier	
DCB Decachlorobiphenyl (Surr)	142	S1+	15 - 136
Tetrachloro-m-xylene (Surr)	113		18 - 126

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 608.3 - Polychlorinated Biphenyls (PCBs) (GC)

Lab Sample ID: MB 860-150340/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 150683

Prep Batch: 150340

Analyte	MB		MB		D	Prepared	Analyzed	Dil Fac
	Result	Qualifier	RL	MDL				
PCB-1016	ND	U	0.0400	0.0125	ug/L	03/18/24 16:12	03/20/24 16:36	1
PCB-1221	ND	U	0.0400	0.0125	ug/L	03/18/24 16:12	03/20/24 16:36	1
PCB-1232	ND	U	0.0400	0.0125	ug/L	03/18/24 16:12	03/20/24 16:36	1
PCB-1242	ND	U	0.0400	0.0125	ug/L	03/18/24 16:12	03/20/24 16:36	1
PCB-1248	ND	U	0.0400	0.0125	ug/L	03/18/24 16:12	03/20/24 16:36	1
PCB-1254	ND	U	0.0400	0.00780	ug/L	03/18/24 16:12	03/20/24 16:36	1
PCB-1260	ND	U	0.0400	0.00780	ug/L	03/18/24 16:12	03/20/24 16:36	1
Polychlorinated biphenyls, Total	ND	U	0.0400	0.0400	ug/L	03/18/24 16:12	03/20/24 16:36	1
Surrogate	MB		MB		D	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier	Limits					
Tetrachloro-m-xylene (Surr)	78		18 - 126			03/18/24 16:12	03/20/24 16:36	1
DCB Decachlorobiphenyl (Surr)	122		15 - 136			03/18/24 16:12	03/20/24 16:36	1

Lab Sample ID: LCS 860-150340/4-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 150683

Prep Batch: 150340

Analyte	Spike		LCS		D	%Rec	Limits
	Added	Result	Qualifier	Unit			
PCB-1016	1.00	0.9508		ug/L		95	61 - 103
PCB-1260	1.00	1.109		ug/L		111	37 - 130
Surrogate	LCS		LCS		D	%Rec	Limits
	%Recovery	Qualifier	Limits				
Tetrachloro-m-xylene (Surr)	88		18 - 126				
DCB Decachlorobiphenyl (Surr)	136		15 - 136				

Lab Sample ID: LCSD 860-150340/5-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 150683

Prep Batch: 150340

Analyte	Spike		LCSD		D	%Rec	RPD
	Added	Result	Qualifier	Unit			
PCB-1016	1.00	0.9020		ug/L		90	61 - 103
PCB-1260	1.00	1.068		ug/L		107	37 - 130
Surrogate	LCSD		LCSD		D	Limits	RPD
	%Recovery	Qualifier	Limits				
Tetrachloro-m-xylene (Surr)	77		18 - 126				
DCB Decachlorobiphenyl (Surr)	132		15 - 136				

Method: 615 - Herbicides (GC)

Lab Sample ID: MB 860-150523/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151087

Prep Batch: 150523

Analyte	MB		D	Prepared	Analyzed	Dil Fac
	Result	Qualifier				
2,4,5-TP (Silvex)	ND	U	0.200	0.0422	ug/L	1
2,4-D	ND	U	0.200	0.0539	ug/L	1

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 615 - Herbicides (GC) (Continued)

Lab Sample ID: MB 860-150523/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151087

Prep Batch: 150523

Surrogate	MB	MB	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4-Dichlorophenylacetic acid			67		45 - 150	03/18/24 12:56	03/23/24 03:44	1

Lab Sample ID: LCS 860-150523/2-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151087

Prep Batch: 150523

Analyte	Spike	LCS	LCS	Unit	D	%Rec	Limits	Prepared	Analyzed	Dil Fac
	Added	Result	Qualifier							
2,4,5-TP (Silvex)	2.00	1.466		ug/L		73	55 - 140			
2,4-D	2.00	1.401		ug/L		70	55 - 145			
Surrogate	LCS	LCS								
	%Recovery	Qualifier	Limits							
2,4-Dichlorophenylacetic acid	69		45 - 150							

Lab Sample ID: LCSD 860-150523/3-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151087

Prep Batch: 150523

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	Limits	Prepared	Analyzed	RPD	Limit
	Added	Result	Qualifier								
2,4,5-TP (Silvex)	2.00	1.549		ug/L		77	55 - 140			5	25
2,4-D	2.00	1.533		ug/L		77	55 - 145			9	25
Surrogate	LCSD	LCSD									
	%Recovery	Qualifier	Limits								
2,4-Dichlorophenylacetic acid	71		45 - 150								

Method: 632 - Carbamate and Urea Pesticides (HPLC)

Lab Sample ID: MB 860-150532/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 152881

Prep Batch: 150532

Analyte	MB	MB	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Carbaryl			ND	U	5.00	1.85	ug/L		03/19/24 13:38	03/29/24 00:04	1
Diuron			ND	U	0.0900	0.0514	ug/L		03/19/24 13:38	03/29/24 00:04	1

Lab Sample ID: LCS 860-150532/2-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 152881

Prep Batch: 150532

Analyte	Spike	LCS	LCS	Unit	D	%Rec	Limits	Prepared	Analyzed	RPD	Limit
	Added	Result	Qualifier								
Carbaryl	100	89.28		ug/L		89	70 - 130				
Diuron	2.00	1.818		ug/L		91	70 - 130				

Lab Sample ID: LCSD 860-150532/3-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 152881

Prep Batch: 150532

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	Limits	Prepared	Analyzed	RPD	Limit
	Added	Result	Qualifier								
Carbaryl	100	91.26		ug/L		91	70 - 130			2	20
Diuron	2.00	1.858		ug/L		93	70 - 130			2	20

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 1613B - Dioxins and Furans (HRGC/HRMS)

Lab Sample ID: MB 320-748976/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 751471

Prep Batch: 748976

Analyte	MB		MB		D	Prepared	Analyzed	Dil Fac
	Result	Qualifier	RL	EDL				
2,3,7,8-TCDD	ND	U	10.0	0.283	pg/L	03/21/24 08:32	04/01/24 09:26	1
2,3,7,8-TCDF	ND	U	10.0	0.0582	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,7,8-PeCDD	ND	U	50.0	0.911	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,7,8-PeCDF	ND	U	50.0	0.402	pg/L	03/21/24 08:32	04/01/24 09:26	1
2,3,4,7,8-PeCDF	ND	U	50.0	0.429	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,4,7,8-HxCDD	ND	U	50.0	0.572	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,6,7,8-HxCDD	ND	U	50.0	0.596	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,7,8,9-HxCDD	ND	U	50.0	0.557	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,4,7,8-HxCDF	ND	U	50.0	0.397	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,6,7,8-HxCDF	ND	U	50.0	0.389	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,7,8,9-HxCDF	ND	U	50.0	0.331	pg/L	03/21/24 08:32	04/01/24 09:26	1
2,3,4,6,7,8-HxCDF	ND	U	50.0	0.351	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,4,6,7,8-HpCDD	ND	U	50.0	0.441	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,4,6,7,8-HpCDF	ND	U	50.0	0.787	pg/L	03/21/24 08:32	04/01/24 09:26	1
1,2,3,4,7,8,9-HpCDF	ND	U	50.0	0.732	pg/L	03/21/24 08:32	04/01/24 09:26	1
OCDD	ND	U	100	0.857	pg/L	03/21/24 08:32	04/01/24 09:26	1
OCDF	ND	U	100	0.680	pg/L	03/21/24 08:32	04/01/24 09:26	1

Isotope Dilution	MB		MB		Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier	Limits				
13C-2,3,7,8-TCDD	72		25 - 164		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,7,8-PeCDD	68		25 - 181		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,7,8-PeCDF	71		24 - 185		03/21/24 08:32	04/01/24 09:26	1
13C-2,3,7,8-TCDF	84		24 - 169		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,6,7,8-HxCDD	69		28 - 130		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,7,8,9-HxCDF	85		29 - 147		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,4,6,7,8-HpCDF	72		28 - 143		03/21/24 08:32	04/01/24 09:26	1
13C-OCDF	98		17 - 157		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,4,7,8-HxCDD	71		32 - 141		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,6,7,8-HxCDF	73		26 - 123		03/21/24 08:32	04/01/24 09:26	1
13C-2,3,4,7,8-PeCDF	72		21 - 178		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,4,6,7,8-HpCDD	78		23 - 140		03/21/24 08:32	04/01/24 09:26	1
13C-OCDD	85		17 - 157		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,4,7,8-HxCDF	76		26 - 152		03/21/24 08:32	04/01/24 09:26	1
13C-2,3,4,6,7,8-HxCDF	77		28 - 136		03/21/24 08:32	04/01/24 09:26	1
13C-1,2,3,4,7,8,9-HpCDF	89		26 - 138		03/21/24 08:32	04/01/24 09:26	1

Surrogate	MB		MB		Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier	Limits				
37Cl-2,3,7,8-TCDD	110		35 - 197		03/21/24 08:32	04/01/24 09:26	1

Lab Sample ID: LCS 320-748976/2-A	Client Sample ID: Lab Control Sample		Prep Type: Total/NA	Prep Batch: 748976
	Matrix: Water	Analysis Batch: 751471		

Analyte	Spike		LCS		D	%Rec	
	Added	Result	Qualifier	Unit		%Rec	Limits
2,3,7,8-TCDD	200	253.3		pg/L	127	67 - 158	
2,3,7,8-TCDF	200	277.2		pg/L	139	75 - 158	
1,2,3,7,8-PeCDD	1000	1059		pg/L	106	70 - 142	
1,2,3,7,8-PeCDF	1000	1122		pg/L	112	80 - 134	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 1613B - Dioxins and Furans (HRGC/HRMS) (Continued)

Lab Sample ID: LCS 320-748976/2-A

Matrix: Water

Analysis Batch: 751471

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 748976

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2,3,4,7,8-PeCDF	1000	1114		pg/L	111	68 - 160	
1,2,3,4,7,8-HxCDD	1000	1081		pg/L	108	70 - 164	
1,2,3,6,7,8-HxCDD	1000	1106		pg/L	111	76 - 134	
1,2,3,7,8,9-HxCDD	1000	1180		pg/L	118	64 - 162	
1,2,3,4,7,8-HxCDF	1000	1165		pg/L	116	72 - 134	
1,2,3,6,7,8-HxCDF	1000	1172		pg/L	117	84 - 130	
1,2,3,7,8,9-HxCDF	1000	1181		pg/L	118	78 - 130	
2,3,4,6,7,8-HxCDF	1000	1183		pg/L	118	70 - 156	
1,2,3,4,6,7,8-HpCDD	1000	1005		pg/L	100	70 - 140	
1,2,3,4,6,7,8-HpCDF	1000	1122		pg/L	112	82 - 122	
1,2,3,4,7,8,9-HpCDF	1000	1061		pg/L	106	78 - 138	
OCDD	2000	2048		pg/L	102	78 - 144	
OCDF	2000	2115		pg/L	106	63 - 170	

Isotope Dilution	LCS %Recovery	LCS Qualifier	Limits
13C-2,3,7,8-TCDD	74		20 - 175
13C-1,2,3,7,8-PeCDD	74		21 - 227
13C-1,2,3,7,8-PeCDF	79		21 - 192
13C-2,3,7,8-TCDF	90		22 - 152
13C-1,2,3,6,7,8-HxCDD	73		25 - 163
13C-1,2,3,7,8,9-HxCDF	92		17 - 205
13C-1,2,3,4,6,7,8-HpCDF	78		21 - 158
13C-OCDF	108		13 - 199
13C-1,2,3,4,7,8-HxCDD	71		21 - 193
13C-1,2,3,6,7,8-HxCDF	77		21 - 159
13C-2,3,4,7,8-PeCDF	74		13 - 328
13C-1,2,3,4,6,7,8-HpCDD	85		26 - 166
13C-OCDD	92		13 - 199
13C-1,2,3,4,7,8-HxCDF	78		19 - 202
13C-2,3,4,6,7,8-HxCDF	83		22 - 176
13C-1,2,3,4,7,8,9-HpCDF	96		20 - 186

Surrogate	LCS %Recovery	LCS Qualifier	Limits
37Cl4-2,3,7,8-TCDD	111		31 - 191

Lab Sample ID: LCSD 320-748976/3-A

Matrix: Water

Analysis Batch: 751471

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 748976

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
2,3,7,8-TCDD	200	251.1		pg/L	126	67 - 158		1	50
2,3,7,8-TCDF	200	280.9		pg/L	140	75 - 158		1	50
1,2,3,7,8-PeCDD	1000	1057		pg/L	106	70 - 142		0	50
1,2,3,7,8-PeCDF	1000	1114		pg/L	111	80 - 134		1	50
2,3,4,7,8-PeCDF	1000	1109		pg/L	111	68 - 160		0	50
1,2,3,4,7,8-HxCDD	1000	1051		pg/L	105	70 - 164		3	50
1,2,3,6,7,8-HxCDD	1000	1114		pg/L	111	76 - 134		1	50
1,2,3,7,8,9-HxCDD	1000	1202		pg/L	120	64 - 162		2	50

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 1613B - Dioxins and Furans (HRGC/HRMS) (Continued)

Lab Sample ID: LCSD 320-748976/3-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 751471

Prep Batch: 748976

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	RPD	RPD
	Added	Result	Qualifier				Limits	Limit		
1,2,3,4,7,8-HxCDF	1000	1156		pg/L		116	72 - 134	1	50	
1,2,3,6,7,8-HxCDF	1000	1189		pg/L		119	84 - 130	1	50	
1,2,3,7,8,9-HxCDF	1000	1173		pg/L		117	78 - 130	1	50	
2,3,4,6,7,8-HxCDF	1000	1182		pg/L		118	70 - 156	0	50	
1,2,3,4,6,7,8-HpCDD	1000	988.4		pg/L		99	70 - 140	2	50	
1,2,3,4,6,7,8-HpCDF	1000	1115		pg/L		112	82 - 122	1	50	
1,2,3,4,7,8,9-HpCDF	1000	1070		pg/L		107	78 - 138	1	50	
OCDD	2000	2046		pg/L		102	78 - 144	0	50	
OCDF	2000	2096		pg/L		105	63 - 170	1	50	

Isotope Dilution	LCSD	LCSD	Limits							
	%Recovery	Qualifier								
13C-2,3,7,8-TCDD	68		20 - 175							
13C-1,2,3,7,8-PeCDD	65		21 - 227							
13C-1,2,3,7,8-PeCDF	70		21 - 192							
13C-2,3,7,8-TCDF	81		22 - 152							
13C-1,2,3,6,7,8-HxCDD	65		25 - 163							
13C-1,2,3,7,8,9-HxCDF	84		17 - 205							
13C-1,2,3,4,6,7,8-HpCDF	70		21 - 158							
13C-OCDF	93		13 - 199							
13C-1,2,3,4,7,8-HxCDD	65		21 - 193							
13C-1,2,3,6,7,8-HxCDF	68		21 - 159							
13C-2,3,4,7,8-PeCDF	65		13 - 328							
13C-1,2,3,4,6,7,8-HpCDD	76		26 - 166							
13C-OCDD	79		13 - 199							
13C-1,2,3,4,7,8-HxCDF	70		19 - 202							
13C-2,3,4,6,7,8-HxCDF	76		22 - 176							
13C-1,2,3,4,7,8,9-HpCDF	85		20 - 186							
Surrogate	LCSD	LCSD	Limits							
	%Recovery	Qualifier								
37Cl-2,3,7,8-TCDD	110		31 - 191							

Method: 1668C - Chlorinated Biphenyl Congeners (HRGC/HRMS)

Lab Sample ID: MB 320-748762/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 752984

Prep Batch: 748762

Analyte	MB	MB	RL	EDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
PCB-77	ND	U	20.0	1.52	pg/L		03/20/24 10:22	04/06/24 10:59	1
PCB-81	ND	U	20.0	1.64	pg/L		03/20/24 10:22	04/06/24 10:59	1
PCB-126	ND	U	20.0	0.327	pg/L		03/20/24 10:22	04/06/24 10:59	1
PCB-169	ND	U	20.0	0.135	pg/L		03/20/24 10:22	04/06/24 10:59	1
Isotope Dilution	MB	MB					Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier							
PCB-126L	69		10 - 145				03/20/24 10:22	04/06/24 10:59	1
PCB-169L	82		10 - 145				03/20/24 10:22	04/06/24 10:59	1
PCB-81L	60		10 - 145				03/20/24 10:22	04/06/24 10:59	1
PCB-77L	62		10 - 145				03/20/24 10:22	04/06/24 10:59	1

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 1668C - Chlorinated Biphenyl Congeners (HRGC/HRMS) (Continued)

Lab Sample ID: MB 320-748762/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 752984

Prep Batch: 748762

Surrogate	MB	MB	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
PCB-28L		67	67		5 - 145	03/20/24 10:22	04/06/24 10:59	1
PCB-111L		67			10 - 145	03/20/24 10:22	04/06/24 10:59	1
PCB-178L		77			10 - 145	03/20/24 10:22	04/06/24 10:59	1

Lab Sample ID: LCS 320-748762/2-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 752984

Prep Batch: 748762

Analyte	Spike	LCS	LCS	Unit	D	%Rec	Limits	%Rec
	Added	Result	Qualifier					
PCB-77	2000	1823		pg/L		91	60 - 135	
PCB-81	2000	1952		pg/L		98	60 - 135	
PCB-126	2000	1941		pg/L		97	60 - 135	
PCB-169	2000	1753		pg/L		88	60 - 135	

Isotope Dilution	LCS	LCS	%Recovery	Qualifier	Limits	Unit	D	%Rec
PCB-126L	66		66		40 - 145			
PCB-169L	77				40 - 145			
PCB-81L	58				40 - 145			
PCB-77L	58				40 - 145			

Surrogate	LCS	LCS	%Recovery	Qualifier	Limits	Unit	D	%Rec
PCB-28L		58	58		15 - 145			
PCB-111L		58			40 - 145			
PCB-178L		66			40 - 145			

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	Limits	RPD	Limit
	Added	Result	Qualifier						
PCB-77	2000	1826		pg/L		91	60 - 135	0	50
PCB-81	2000	1987		pg/L		99	60 - 135	2	50
PCB-126	2000	1939		pg/L		97	60 - 135	0	50
PCB-169	2000	1751		pg/L		88	60 - 135	0	50

Isotope Dilution	LCSD	LCSD	%Recovery	Qualifier	Limits	Unit	D	%Rec
PCB-126L		58	58		40 - 145			
PCB-169L		73			40 - 145			
PCB-81L		55			40 - 145			
PCB-77L		56			40 - 145			

Surrogate	LCSD	LCSD	%Recovery	Qualifier	Limits	Unit	D	%Rec
PCB-28L		62	62		15 - 145			
PCB-111L		63			40 - 145			
PCB-178L		70			40 - 145			

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 1631E - Mercury, Low Level (CVAFS)

Lab Sample ID: MB 400-665231/3-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 665335

Prep Batch: 665231

Analyte	MB		Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	MB	MB									
Mercury	ND	U			0.500	0.200	ng/L		03/20/24 16:00	03/21/24 10:04	1

Lab Sample ID: LCS 400-665231/4-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 665335

Prep Batch: 665231

Analyte	Spike		LCS	LCS	Unit	D	%Rec	Limits	RPD
	Added	Result	Qualifier	ng/L	%Rec	Limits	RPD	Limit	
Mercury		5.00	5.225		105	79 - 121	0	20	

Lab Sample ID: LCSD 400-665231/5-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 665335

Prep Batch: 665231

Analyte	Spike		LCSD	LCSD	Unit	D	%Rec	Limits	RPD
	Added	Result	Qualifier	ng/L	%Rec	Limits	RPD	Limit	
Mercury		5.00	5.218		104	79 - 121	0	20	

Method: 200.7 Rev 4.4 - Metals (ICP)

Lab Sample ID: MB 860-149016/1-D

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total Recoverable

Analysis Batch: 150442

Prep Batch: 150158

Analyte	MB		Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	MB	MB									
Boron	ND	U			0.0500	0.0173	mg/L		03/17/24 13:00	03/18/24 18:48	1

Lab Sample ID: LCS 860-149016/2-C

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total Recoverable

Analysis Batch: 150442

Prep Batch: 150158

Analyte	Spike		LCS	LCS	Unit	D	%Rec	Limits	RPD
	Added	Result	Qualifier	ng/L	%Rec	Limits	RPD	Limit	
Boron		1.00	0.9730		97	85 - 115	0	20	

Lab Sample ID: LCSD 860-149016/3-C

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total Recoverable

Analysis Batch: 150442

Prep Batch: 150158

Analyte	Spike		LCSD	LCSD	Unit	D	%Rec	Limits	RPD
	Added	Result	Qualifier	ng/L	%Rec	Limits	RPD	Limit	
Boron		1.00	0.9730		97	85 - 115	0	20	

Lab Sample ID: LLCS 860-150158/4-A

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total Recoverable

Analysis Batch: 150442

Prep Batch: 150158

Analyte	Spike		LLCS	LLCS	Unit	D	%Rec	Limits	RPD
	Added	Result	Qualifier	ng/L	%Rec	Limits	RPD	Limit	
Boron		0.0500	0.05260		105	50 - 150	0	20	

Eurofins Houston

QC Sample Results

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method: 4500 CN G NonAm - Cyanide, Non-amenable

Lab Sample ID: MB 860-151204/4-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151354

Prep Batch: 151204

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Non-amenable	ND	U	0.00500	0.00233	mg/L		03/22/24 15:39	03/24/24 12:52	1

Method: Kelada 01 - Cyanide, Total, Acid Dissociable and Thiocyanate

Lab Sample ID: MB 860-151515/24

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151515

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Total	ND	U	0.00500	0.00198	mg/L			03/25/24 12:08	1

Lab Sample ID: MB 860-151515/94

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151515

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Total	ND	U	0.00500	0.00198	mg/L			03/25/24 15:26	1

Lab Sample ID: LCS 860-151515/26

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151515

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Cyanide, Total	0.100	0.1008		mg/L		101	90 - 110

Lab Sample ID: LCSD 860-151515/96

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151515

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Cyanide, Total	0.100	0.1005		mg/L		101	90 - 110	3	20

Lab Sample ID: LLCS 860-151515/25

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 151515

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Cyanide, Total	0.00500	0.006883		mg/L		138	50 - 150

Eurofins Houston

QC Association Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

GC/MS VOA

Analysis Batch: 149796

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	624.1	
MB 860-149796/10	Method Blank	Total/NA	Water	624.1	
LCS 860-149796/3	Lab Control Sample	Total/NA	Water	624.1	
LCSD 860-149796/4	Lab Control Sample Dup	Total/NA	Water	624.1	
860-69911-1 MS	6221-24 Hillsbors Permit Renewal	Total/NA	Water	624.1	

Analysis Batch: 149950

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1 - RA	6221-24 Hillsbors Permit Renewal	Total/NA	Water	624.1	
MB 860-149950/9	Method Blank	Total/NA	Water	624.1	
LCS 860-149950/3	Lab Control Sample	Total/NA	Water	624.1	
LCSD 860-149950/4	Lab Control Sample Dup	Total/NA	Water	624.1	

GC/MS Semi VOA

Prep Batch: 150228

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	625	
MB 860-150228/1-A	Method Blank	Total/NA	Water	625	
LCS 860-150228/2-A	Lab Control Sample	Total/NA	Water	625	
LCSD 860-150228/3-A	Lab Control Sample Dup	Total/NA	Water	625	

Analysis Batch: 150257

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 860-150228/1-A	Method Blank	Total/NA	Water	625.1	150228
LCS 860-150228/2-A	Lab Control Sample	Total/NA	Water	625.1	150228
LCSD 860-150228/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	150228

Analysis Batch: 150475

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	625.1	150228

Prep Batch: 150805

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1 - RE	6221-24 Hillsbors Permit Renewal	Total/NA	Water	625	
MB 860-150805/1-A	Method Blank	Total/NA	Water	625	
LCS 860-150805/2-A	Lab Control Sample	Total/NA	Water	625	
LCSD 860-150805/3-A	Lab Control Sample Dup	Total/NA	Water	625	

Analysis Batch: 150908

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1 - RE	6221-24 Hillsbors Permit Renewal	Total/NA	Water	625.1	150805
MB 860-150805/1-A	Method Blank	Total/NA	Water	625.1	150805
LCS 860-150805/2-A	Lab Control Sample	Total/NA	Water	625.1	150805
LCSD 860-150805/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	150805

Prep Batch: 421863

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	Organotin	
MB 570-421863/1-A	Method Blank	Total/NA	Water	Organotin	
LCS 570-421863/2-A	Lab Control Sample	Total/NA	Water	Organotin	

Eurofins Houston

QC Association Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

GC/MS Semi VOA (Continued)

Prep Batch: 421863 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCSD 570-421863/3-A	Lab Control Sample Dup	Total/NA	Water	Organotin	

Analysis Batch: 424204

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	Organotins SIM	421863
MB 570-421863/1-A	Method Blank	Total/NA	Water	Organotins SIM	421863
LCS 570-421863/2-A	Lab Control Sample	Total/NA	Water	Organotins SIM	421863
LCSD 570-421863/3-A	Lab Control Sample Dup	Total/NA	Water	Organotins SIM	421863

Prep Batch: 647138

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	D7065-11	
MB 280-647138/1-A	Method Blank	Total/NA	Water	D7065-11	
LCS 280-647138/2-A	Lab Control Sample	Total/NA	Water	D7065-11	

Analysis Batch: 647441

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	D7065-11	647138
MB 280-647138/1-A	Method Blank	Total/NA	Water	D7065-11	647138
LCS 280-647138/2-A	Lab Control Sample	Total/NA	Water	D7065-11	647138

GC Semi VOA

Prep Batch: 150340

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	608	
MB 860-150340/1-A	Method Blank	Total/NA	Water	608	
LCS 860-150340/2-A	Lab Control Sample	Total/NA	Water	608	
LCS 860-150340/4-A	Lab Control Sample	Total/NA	Water	608	
LCSD 860-150340/3-A	Lab Control Sample Dup	Total/NA	Water	608	
LCSD 860-150340/5-A	Lab Control Sample Dup	Total/NA	Water	608	

Prep Batch: 150523

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	3511	
MB 860-150523/1-A	Method Blank	Total/NA	Water	3511	
LCS 860-150523/2-A	Lab Control Sample	Total/NA	Water	3511	
LCSD 860-150523/3-A	Lab Control Sample Dup	Total/NA	Water	3511	

Analysis Batch: 150683

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 860-150340/1-A	Method Blank	Total/NA	Water	608.3	150340
LCS 860-150340/4-A	Lab Control Sample	Total/NA	Water	608.3	150340
LCSD 860-150340/5-A	Lab Control Sample Dup	Total/NA	Water	608.3	150340

Analysis Batch: 150868

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	608.3	150340

Eurofins Houston

QC Association Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

GC Semi VOA

Analysis Batch: 150874

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 860-150340/1-A	Method Blank	Total/NA	Water	608.3	150340
LCS 860-150340/2-A	Lab Control Sample	Total/NA	Water	608.3	150340
LCSD 860-150340/3-A	Lab Control Sample Dup	Total/NA	Water	608.3	150340

Analysis Batch: 151087

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	615	150523
MB 860-150523/1-A	Method Blank	Total/NA	Water	615	150523
LCS 860-150523/2-A	Lab Control Sample	Total/NA	Water	615	150523
LCSD 860-150523/3-A	Lab Control Sample Dup	Total/NA	Water	615	150523

Analysis Batch: 151403

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	608.3	150340

HPLC/IC

Prep Batch: 150532

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	CWA_Prep	13
MB 860-150532/1-A	Method Blank	Total/NA	Water	CWA_Prep	14
LCS 860-150532/2-A	Lab Control Sample	Total/NA	Water	CWA_Prep	15
LCSD 860-150532/3-A	Lab Control Sample Dup	Total/NA	Water	CWA_Prep	16

Analysis Batch: 152881

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	632	150532
MB 860-150532/1-A	Method Blank	Total/NA	Water	632	150532
LCS 860-150532/2-A	Lab Control Sample	Total/NA	Water	632	150532
LCSD 860-150532/3-A	Lab Control Sample Dup	Total/NA	Water	632	150532

Specialty Organics

Prep Batch: 748762

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	HRMS-Sep	
MB 320-748762/1-A	Method Blank	Total/NA	Water	HRMS-Sep	
LCS 320-748762/2-A	Lab Control Sample	Total/NA	Water	HRMS-Sep	
LCSD 320-748762/3-A	Lab Control Sample Dup	Total/NA	Water	HRMS-Sep	

Prep Batch: 748976

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	1613B	
MB 320-748976/1-A	Method Blank	Total/NA	Water	1613B	
LCS 320-748976/2-A	Lab Control Sample	Total/NA	Water	1613B	
LCSD 320-748976/3-A	Lab Control Sample Dup	Total/NA	Water	1613B	

Analysis Batch: 751471

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 320-748976/1-A	Method Blank	Total/NA	Water	1613B	748976
LCS 320-748976/2-A	Lab Control Sample	Total/NA	Water	1613B	748976
LCSD 320-748976/3-A	Lab Control Sample Dup	Total/NA	Water	1613B	748976

Eurofins Houston

QC Association Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Specialty Organics

Analysis Batch: 752263

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	1613B	748976

Analysis Batch: 752982

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	1668C	748762

Analysis Batch: 752984

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 320-748762/1-A	Method Blank	Total/NA	Water	1668C	748762
LCS 320-748762/2-A	Lab Control Sample	Total/NA	Water	1668C	748762
LCSD 320-748762/3-A	Lab Control Sample Dup	Total/NA	Water	1668C	748762

Metals

Filtration Batch: 149016

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 860-149016/1-D	Method Blank	Total Recoverable	Water	Filtration	
LCS 860-149016/2-C	Lab Control Sample	Total Recoverable	Water	Filtration	
LCSD 860-149016/3-C	Lab Control Sample Dup	Total Recoverable	Water	Filtration	

Prep Batch: 150158

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total Recoverable	Water	200.7	
MB 860-149016/1-D	Method Blank	Total Recoverable	Water	200.7	149016
LCS 860-149016/2-C	Lab Control Sample	Total Recoverable	Water	200.7	149016
LCSD 860-149016/3-C	Lab Control Sample Dup	Total Recoverable	Water	200.7	149016
LLCS 860-150158/4-A	Lab Control Sample	Total Recoverable	Water	200.7	

Analysis Batch: 150442

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total Recoverable	Water	200.7 Rev 4.4	150158
MB 860-149016/1-D	Method Blank	Total Recoverable	Water	200.7 Rev 4.4	150158
LCS 860-149016/2-C	Lab Control Sample	Total Recoverable	Water	200.7 Rev 4.4	150158
LCSD 860-149016/3-C	Lab Control Sample Dup	Total Recoverable	Water	200.7 Rev 4.4	150158
LLCS 860-150158/4-A	Lab Control Sample	Total Recoverable	Water	200.7 Rev 4.4	150158

Prep Batch: 665231

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	1631E	
MB 400-665231/3-A	Method Blank	Total/NA	Water	1631E	
LCS 400-665231/4-A	Lab Control Sample	Total/NA	Water	1631E	
LCSD 400-665231/5-A	Lab Control Sample Dup	Total/NA	Water	1631E	

Analysis Batch: 665335

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	1631E	665231
MB 400-665231/3-A	Method Blank	Total/NA	Water	1631E	665231
LCS 400-665231/4-A	Lab Control Sample	Total/NA	Water	1631E	665231
LCSD 400-665231/5-A	Lab Control Sample Dup	Total/NA	Water	1631E	665231

QC Association Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

General Chemistry

Prep Batch: 151204

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	Distill/CN	
MB 860-151204/4-A	Method Blank	Total/NA	Water	Distill/CN	
LCS 860-151204/5-A	Lab Control Sample	Total/NA	Water	Distill/CN	
LCSD 860-151204/6-A	Lab Control Sample Dup	Total/NA	Water	Distill/CN	

Analysis Batch: 151354

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	4500 CN G NonAm	151204
MB 860-151204/4-A	Method Blank	Total/NA	Water	4500 CN G NonAm	151204
LCS 860-151204/5-A	Lab Control Sample	Total/NA	Water	4500 CN G NonAm	151204
LCSD 860-151204/6-A	Lab Control Sample Dup	Total/NA	Water	4500 CN G NonAm	151204

Analysis Batch: 151515

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	Kelada 01	
MB 860-151515/24	Method Blank	Total/NA	Water	Kelada 01	
MB 860-151515/94	Method Blank	Total/NA	Water	Kelada 01	
LCS 860-151515/26	Lab Control Sample	Total/NA	Water	Kelada 01	
LCSD 860-151515/96	Lab Control Sample Dup	Total/NA	Water	Kelada 01	
LLCS 860-151515/25	Lab Control Sample	Total/NA	Water	Kelada 01	

Analysis Batch: 151833

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-69911-1	6221-24 Hillsbors Permit Renewal	Total/NA	Water	SM 4500 CN G	

Lab Chronicle

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Client Sample ID: 6221-24 Hillsbors Permit Renewal

Lab Sample ID: 860-69911-1

Date Collected: 03/12/24 10:00

Matrix: Water

Date Received: 03/13/24 14:35

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	624.1		1	5 mL	5 mL	149796	03/15/24 00:32	AN	EET HOU
Total/NA	Analysis	624.1	RA	1	5 mL	5 mL	149950	03/15/24 15:01	AN	EET HOU
Total/NA	Prep	625			1000 mL	1.00 mL	150228	03/18/24 09:27	DR	EET HOU
Total/NA	Analysis	625.1		1	1 mL	1 mL	150475	03/19/24 15:27	PXS	EET HOU
Total/NA	Prep	625	RE		1000 mL	1.00 mL	150805	03/20/24 16:17	DR	EET HOU
Total/NA	Analysis	625.1	RE	1	1 mL	1 mL	150908	03/22/24 00:57	PXS	EET HOU
Total/NA	Prep	D7065-11			990.3 mL	1 mL	647138	03/26/24 12:09	EDW	EET DEN
Total/NA	Analysis	D7065-11		1	200 uL	200 uL	647441	03/28/24 16:52	MAB	EET DEN
Total/NA	Prep	Organotin			1014.8 mL	1 mL	421863	03/19/24 17:03	UWEZ	EET CAL 4
Total/NA	Analysis	Organotins SIM		1	1 mL	1 mL	424204	03/26/24 13:05	ULLI	EET CAL 4
Total/NA	Prep	608			1000 mL	1 mL	150340	03/19/24 14:10	BH	EET HOU
Total/NA	Analysis	608.3		1			150868	03/21/24 10:25	WP	EET HOU
Total/NA	Prep	608			1000 mL	1 mL	150340	03/19/24 14:10	BH	EET HOU
Total/NA	Analysis	608.3		1			151403	03/25/24 11:48	WP	EET HOU
Total/NA	Prep	3511			50 mL	4 mL	150523	03/19/24 12:59	TH	EET HOU
Total/NA	Analysis	615		1			151087	03/23/24 07:13	WP	EET HOU
Total/NA	Prep	CWA_Prep			1000 mL	10 mL	150532	03/19/24 13:38	DR	EET HOU
Total/NA	Analysis	632		1			152881	03/29/24 03:54	YG	EET HOU
Total/NA	Prep	1613B			1005.2 mL	20.0 uL	748976	03/21/24 08:32	GSH	EET SAC
Total/NA	Analysis	1613B		1	1 Sample	1 Sample	752263	04/04/24 08:30	CB	EET SAC
Total/NA	Prep	HRMS-Sep			1027.6 mL	20.0 uL	748762	03/20/24 10:22	GSH	EET SAC
Total/NA	Analysis	1668C		1	1 uL	1 uL	752982	04/06/24 06:28	JBC	EET SAC
Total/NA	Prep	1631E			40 mL	40 mL	665231	03/19/24 16:17	VLC	EET PEN
							Completed:	03/20/24 09:00 ¹		
Total/NA	Analysis	1631E		1			665335	03/21/24 11:51	VLC	EET PEN
Total Recoverable	Prep	200.7			50 mL	50 mL	150158	03/17/24 13:00	MD	EET HOU
Total Recoverable	Analysis	200.7 Rev 4.4		1			150442	03/18/24 19:14	JDM	EET HOU
Total/NA	Prep	Distill/CN			6 mL	6 mL	151204	03/22/24 15:39	SA	EET HOU
Total/NA	Analysis	4500 CN G NonAm		1			151354	03/24/24 13:46	HN	EET HOU
Total/NA	Analysis	Kelada 01		1	50 mL	50 mL	151515	03/25/24 13:36	AA	EET HOU
Total/NA	Analysis	SM 4500 CN G		1			151833	03/27/24 09:48	SC	EET HOU

¹ This procedure uses a method stipulated length of time for the process. Both start and end times are displayed.

Laboratory References:

Ana-Lab Co = Ana-Lab Corporation, 2600 Dudley Rd, Kilgore, TX 75662

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

EET DEN = Eurofins Denver, 4955 Yarrow Street, Arvada, CO 80002, TEL (303)736-0100

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

EET PEN = Eurofins Pensacola, 3355 McLemore Drive, Pensacola, FL 32514, TEL (850)474-1001

EET SAC = Eurofins Sacramento, 880 Riverside Parkway, West Sacramento, CA 95605, TEL (916)373-5600

EMLab P&K = EMLab P&K, Subcont.report available upon request, 3113 Red Bluff Road, Pasadena, TX 77503

Eurofins Houston

Accreditation/Certification Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Laboratory: Eurofins Houston

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arkansas DEQ	State	88-00759	08-03-24
Florida	NELAP	E871002	06-30-24
Louisiana (All)	NELAP	03054	06-30-24
Oklahoma	NELAP	1306	08-31-24
Oklahoma	State	2023-139	08-31-24
Texas	NELAP	T104704215	06-30-24
Texas	TCEQ Water Supply	T104704215	12-28-25
USDA	US Federal Programs	525-23-79-79507	03-20-26

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arizona	State	AZ0830	11-16-24
California	Los Angeles County Sanitation Districts	10109	08-01-24
California	State	3082	07-31-24
Kansas	NELAP	E-10420	08-01-24
Nevada	State	CA00111	07-31-24
Oregon	NELAP	4175	02-03-25
USDA	US Federal Programs	P330-22-00059	06-08-26
Washington	State	C916-18	10-11-24

Laboratory: Eurofins Denver

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Texas	NELAP	T104704183-23-23	09-30-24

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
D7065-11	D7065-11	Water	4-tert-Octylphenol
D7065-11	D7065-11	Water	Bisphenol-A
D7065-11	D7065-11	Water	Nonylphenol
D7065-11	D7065-11	Water	Nonylphenol diethoxylate
D7065-11	D7065-11	Water	Nonylphenol monoethoxylate

Laboratory: Eurofins Pensacola

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Texas	NELAP	T104704286	09-30-24

Laboratory: Eurofins Sacramento

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Alaska (UST)	State	17-020	02-20-27
ANAB	Dept. of Defense ELAP	L2468	01-20-27
ANAB	Dept. of Energy	L2468.01	01-20-27
ANAB	ISO/IEC 17025	L2468	01-20-27

Accreditation/Certification Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Laboratory: Eurofins Sacramento (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arizona	State	AZ0708	08-11-24
Arkansas DEQ	State	88-0691	05-18-24
California	State	2897	01-31-26
Colorado	State	CA00044	08-31-24
Florida	NELAP	E87570	06-30-24
Georgia	State	4040	01-29-25
Hawaii	State	Eurofins Sacramento	01-29-25
Illinois	NELAP	200060	03-31-25
Kansas	NELAP	E-10375	10-31-24
Louisiana	NELAP	01944	06-30-24
Louisiana (All)	NELAP	01944	06-30-24
Maine	State	CA00004	04-14-24
Michigan	State	9947	01-29-25
Nevada	State	CA00044	07-31-24
New Hampshire	NELAP	2997	04-18-24
New Jersey	NELAP	CA005	06-30-24
New York	NELAP	11666	04-01-25
Ohio	State	41252	01-29-25
Oregon	NELAP	4040	01-29-25
Texas	NELAP	T104704399-23-17	05-31-24
US Fish & Wildlife	US Federal Programs	A22139	04-30-24
USDA	US Federal Programs	P330-18-00239	02-28-26
Utah	NELAP	CA000442023-16	02-28-25
Virginia	NELAP	460278	03-14-25
Washington	State	C581	05-05-24
West Virginia (DW)	State	9930C	01-31-25
Wisconsin	State	998204680	08-31-24
Wyoming	State Program	8TMS-L	01-28-19 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: Bio Chem Lab, Inc

Job ID: 860-69911-1

Project/Site: City of Hillsboro Permit Renewal

Method	Method Description	Protocol	Laboratory
624.1	Volatile Organic Compounds (GC/MS)	EPA	EET HOU
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET HOU
D7065-11	Determination of Nonylphenols	ASTM	EET DEN
Organotins SIM	Organotins (GC/MS SIM)	Lab SOP	EET CAL 4
608.3	Organochlorine Pesticides in Water	EPA	EET HOU
608.3	Polychlorinated Biphenyls (PCBs) (GC)	EPA	EET HOU
615	Herbicides (GC)	EPA-01	EET HOU
632	Carbamate and Urea Pesticides (HPLC)	EPA-01	EET HOU
1613B	Dioxins and Furans (HRGC/HRMS)	EPA	EET SAC
1668C	Chlorinated Biphenyl Congeners (HRGC/HRMS)	EPA	EET SAC
1631E	Mercury, Low Level (CVAFS)	EPA	EET PEN
200.7 Rev 4.4	Metals (ICP)	EPA	EET HOU
4500 CN G	Cyanide, Non-amenable	SM	EET HOU
NonAm			
Kelada 01	Cyanide, Total, Acid Dissociable and Thiocyanate	EPA	EET HOU
SM 4500 CN G	Cyanide, Amenable	SM	EET HOU
100.2	EPA 100.2 Asbestos in Drinking Water	EPA	EMLab P&K
604.1	EPA 604.1 - Hexachlorophene	EPA	Ana-Lab Co
614	EPA 614 - Organophosphorus Pesticides	EPA	Ana-Lab Co
1613B	Separatory Funnel (L/L) Extraction with Soxhlet Extraction of Dioxin and Furans	EPA	EET SAC
1631E	Preparation, Mercury, Low Level	EPA	EET PEN
200.7	Preparation, Total Recoverable Metals	EPA	EET HOU
3511	Microextraction of Organic Compounds	SW846	EET HOU
608	Liquid-Liquid Extraction (Separatory Funnel)	EPA	EET HOU
625	Liquid-Liquid Extraction	EPA	EET HOU
CWA_Prep	Liquid-Liquid Extraction (Separatory Funnel)	EPA	EET HOU
D7065-11	Liquid-Liquid Extraction (Continuous)	ASTM	EET DEN
Distill/CN	Distillation, Cyanide	None	EET HOU
HRMS-Sep	Separatory Funnel (Liquid-Liquid) Extraction	EPA	EET SAC
Organotin	Extraction (Organotins)	WRC	EET CAL 4

Protocol References:

ASTM = ASTM International

EPA = US Environmental Protection Agency

EPA-01 = "Methods For The Determination Of Nonconventional Pesticides In Municipal And Industrial Wastewater", EPA/821/R/92/002, April 1992.

Lab SOP = Laboratory Standard Operating Procedure

None = None

SM = "Standard Methods For The Examination Of Water And Wastewater"

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

WRC = WRC Notebook 11431-39, ICI America's Western Research Center May, 1989.

Laboratory References:

Ana-Lab Co = Ana-Lab Corporation, 2600 Dudley Rd, Kilgore, TX 75662

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

EET DEN = Eurofins Denver, 4955 Yarrow Street, Arvada, CO 80002, TEL (303)736-0100

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

EET PEN = Eurofins Pensacola, 3355 McLemore Drive, Pensacola, FL 32514, TEL (850)474-1001

EET SAC = Eurofins Sacramento, 880 Riverside Parkway, West Sacramento, CA 95605, TEL (916)373-5600

EMLab P&K = EMLab P&K, Subcont.report available upon request, 3113 Red Bluff Road, Pasadena, TX 77503

Eurofins Houston

Sample Summary

Client: Bio Chem Lab, Inc

Project/Site: City of Hillsboro Permit Renewal

Job ID: 860-69911-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
860-69911-1	6221-24 Hillsbors Permit Renewal	Water	03/12/24 10:00	03/13/24 14:35

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

Eurofins J3 Resources, Inc.

6110 W. 34th Street, Houston, Texas 77092

Phone: (713) 290-0221 Fax: (713) 290-0248


J3 Resources

Asbestos in Water by Transmission Electron Microscopy (TEM)
EPA/600/R-94/134 - (EPA 100.2)

Travis Richter
 Eurofins XENCO Laboratories
 4143 Greenbriar Drive
 Stafford, TX 77477

Order #: 3573937
 Project #: 86006551
 Receipt Date/Time: 03-15-2024 18:35
 Analysis Date: 03/25/2024
 Report Date: 03/25/2024

City of Hillsboro Permit Renewal

Client Sample ID	Sample Collection Date/Time	Sample Filtration Date/Time	Aliquot Volume (mL)	Dilution Factor	Asbestos Structures (> 0.5 µm)	Asbestos Structures (> 10 µm)	Asbestos Type	Analytical Sensitivity	Asbestos Concentration	95% Confidence Limits (Lower - Upper)
*6221-24 Hillsboro Permit Renewal (860-69911-1)	3/12/24 10:00	3/18/24 12:50	70	1	0	0	None Detected	0.19	< 0.19	< 0.19 - 0.72 MFL

Analyst: Taylor Smylie

Scott M. Ward, Ph.D. Lab Director

This report relates only to the samples tested. This report is for the exclusive use of the addressed client and shall not be reproduced except in full, without written approval by Eurofins J3 Resources, Inc. (EJ3). All samples received in good condition and filtered within 48 hours of receipt unless otherwise noted. Only asbestos structures greater than 10µm are considered in calculating asbestos concentration in MFL. This report shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. mL = Milliliters; MFL = Million Fibers per Liter; N/A = Not Applicable

* - Indicates sample was received outside of holding time for method.

NVLAP Lab Code: 200525-0

TDSHS License: 30-0273

Project
1095724

TABM-G

Eurofins Test America Houston
Bethany A McDaniel
4145 Greenbriar Drive
Stafford, TX 77477

Printed 03/26/2024
9:48

TABLE OF CONTENTS

This report consists of this Table of Contents and the following pages:

Report Name	Description	Pages
1095724_r02_01_ProjectSamples	SPL Kilgore Project P:1095724 C:TABM Project Sample Cross Reference t:304	1
1095724_r03_03_ProjectResults	SPL Kilgore Project P:1095724 C:TABM Project Results t:304 PO: US1313021524	3
1095724_r10_05_ProjectQC	SPL Kilgore Project P:1095724 C:TABM Project Quality Control Groups	3
1095724_r99_09_CoC_1_of_1	SPL Kilgore CoC TABM 1095724_1_of_1	5
Total Pages:		12

Email: Kilgore.ProjectManagement@spllabs.com



Report Page 1 of 13



SAMPLE CROSS REFERENCE

Project
1095724

Printed 3/26/2024 Page 1 of 1
ww

Eurofins Test America Houston
Bethany A McDaniel
4145 Greenbriar Drive
Stafford, TX 77477

Sample	Sample ID	Taken	Time	Received	
2281758	(860-69911-1)	03/12/2024	10:00:00	03/15/2024	

Bottle 01 Client Supplied Amber Glass

Bottle 02 Client Supplied Amber Glass

Bottle 03 Prepared Bottle: OPXL/OPXS 2 mL Autosampler Vial (Batch 1109805) Volume: 1.00000 mL <== Derived from 02 (983 ml)

Bottle 04 Prepared Bottle: 2 mL Autosampler Vial (Batch 1109991) Volume: 5.00000 mL <== Derived from 01 (993 ml)

Method	Bottle	PrepSet	Preparation	QcGroup	Analytical
EPA 604.1	04	1109991	03/19/2024	1110422	03/20/2024
EPA 614	03	1109805	03/18/2024	1111016	03/21/2024
EPA 622	03	1109805	03/18/2024	1111003	03/21/2024

Email: Kilgore.ProjectManagement@spllabs.com

Report Page 2 of 13

TABM-G

Eurofins Test America Houston
 Bethany A McDaniel
 4145 Greenbriar Drive
 Stafford, TX 77477

Page 1 of 3

Project
1095724

Printed: 03/26/2024

RESULTS

Sample Results

2281758 (860-69911-1)

6221-24 HILLSBORS PERMIT RENEW

Received: 03/15/2024

Non-Potable Water

Collected by: Client

Eurofins Test Americ

PO:

US1313021524

Taken: 03/12/2024

10:00:00

EPA 604.1

Prepared:	1109991	03/19/2024	13:00:00	Analyzed	1110422	03/20/2024	20:53:00	BRU
-----------	---------	------------	----------	----------	---------	------------	----------	-----

Parameter

Hexachlorophene

Results

<1.26

Units

ug/L

RL

1.26

Flags

CAS

70-30-4

Bottle

04

EPA 614

Prepared:	1109805	03/18/2024	14:20:00	Analyzed	1111016	03/21/2024	01:52:00	KAP
-----------	---------	------------	----------	----------	---------	------------	----------	-----

Parameter

Azinphos-methyl (Guthion)

Results

<0.0509

Units

ug/L

RL

0.0509

Flags

CAS

86-50-0

Bottle

03

NELAC

Demeton

NELAC

Diazinon

NELAC

Malathion

NELAC

Parathion, ethyl

NELAC

Parathion, methyl

<0.0509

ug/L

0.0509

Flags

CAS

8065-48-3

Bottle

03

NELAC

Diazinon

NELAC

Malathion

NELAC

Parathion, ethyl

NELAC

Parathion, methyl

<0.0509

ug/L

0.0509

Flags

CAS

333-41-5

Bottle

03

NELAC

Parathion, ethyl

NELAC

Parathion, methyl

<0.0509

ug/L

0.0509

Flags

CAS

121-75-5

Bottle

03

NELAC

Parathion, ethyl

NELAC

Parathion, methyl

<0.0509

ug/L

0.0509

Flags

CAS

56-38-2

Bottle

03

NELAC

Parathion, ethyl

NELAC

Parathion, methyl

<0.050

ug/L

0.050

Flags

CAS

298-00-0

Bottle

03

Sample Preparation

2281758 (860-69911-1)

6221-24 HILLSBORS PERMIT RENEW

Received: 03/15/2024

US1313021524

03/12/2024

Prepared:

03/18/2024

09:43:22

Calculated

03/18/2024

09:43:22

CAL

Environmental Fee (per Project)

Verified



Report Page 3 of 13

TABM-G

Eurofins Test America Houston
Bethany A McDaniel
4145 Greenbriar Drive
Stafford, TX 77477

Page 2 of 3

Project
1095724

Printed: 03/26/2024

2281758 (860-69911-1)

6221-24 HILLSBORS PERMIT RENEW

Received: 03/15/2024

US1313021524

03/12/2024

EPA 604.1

Prepared: 1109991 03/19/2024 13:00:00 Analyzed 1109991 03/19/2024 13:00:00 MCC

Hexachlorophene Extraction

5/993 ml

01

EPA 604.1

Prepared: 1109991 03/19/2024 13:00:00 Analyzed 1110422 03/20/2024 20:53:00 BRU

Hexachlorophene Expansion

Entered 70-30-4

04

EPA 608.3

Prepared: 1109805 03/18/2024 14:20:00 Analyzed 1109805 03/18/2024 14:20:00 MCC

Solvent Extraction

1/983 ml

02

EPA 614

Prepared: 1109805 03/18/2024 14:20:00 Analyzed 1111016 03/21/2024 01:52:00 KAP

Permit Organophos. Pesticides

Entered

03

EPA 622

Prepared: 1109805 03/18/2024 14:20:00 Analyzed 1111003 03/21/2024 01:52:00 KAP

NELAC For use with EXP !CPP only

Entered

03



Report Page 4 of 13

TABM-G

Eurofins Test America Houston
Bethany A McDaniel
4145 Greenbriar Drive
Stafford, TX 77477

Page 3 of 3

Project

1095724

Printed: 03/26/2024


Qualifiers:

We report results on an As Received (or Wet) basis unless marked Dry Weight.

Unless otherwise noted, testing was performed at SPL, Inc.- Kilgore laboratory which holds International, Federal, and state accreditations. Please see our Websites for details.

(N)ELAC - Covered in our NELAC scope of accreditation
z -- Not covered by our NELAC scope of accreditation

These analytical results relate to the sample tested. This report may NOT be reproduced EXCEPT in FULL without written approval of SPL Kilgore. Unless otherwise specified, these test results meet the requirements of NELAC.
RL is the Reporting Limit (sample specific quantitation limit) and is at or above the Method Detection Limit (MDL). CAS is Chemical Abstract Service number. RL is our Reporting Limit, or Minimum Quantitation Level. The RL takes into account the Instrument Detection Limit (IDL), Method Detection Limit (MDL), and Practical Quantitation Limit (PQL), and any dilutions and/or concentrations performed during sample preparation (EQL). Our analytical result must be above this RL before we report a value in the 'Results' column of our report (without a 'J' flag). Otherwise, we report ND (Not Detected above RL), because the result is "<" (less than) the number in the RL column. MAL is Minimum Analytical Level and is typically from regulatory agencies. Unless we report a result in the result column, or interferences prevent it, we work to have our RL at or below the MAL.



Bill Peery, MS, VP Technical Services

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18



Report Page 5 of 13

QUALITY CONTROL



Page 1 of 3

TABM-G

Eurofins Test America Houston
Bethany A McDaniel
4145 Greenbriar Drive
Stafford, TX 77477

Project
1095724

Printed 03/26/2024

Analytical Set		1110422						EPA 604.1					
Blank													
<u>Parameter</u>		<u>PrepSet</u>	<u>Reading</u>	<u>MDL</u>	<u>MQL</u>	<u>Units</u>			<u>File</u>				
Hexachlorophene		1109991	ND	0.890	1.25	ug/L			126121548				
CCV													
<u>Parameter</u>			<u>Reading</u>	<u>Known</u>	<u>Units</u>	<u>Recover%</u>	<u>Limits%</u>			<u>File</u>			
Hexachlorophene			5070	5000	ug/L	101	70.0 - 130			126121547			
Hexachlorophene			5260	5000	ug/L	105	70.0 - 130			126121554			
Hexachlorophene			5430	5000	ug/L	109	70.0 - 130			126121557			
Hexachlorophene			5420	5000	ug/L	108	70.0 - 130			126121560			
LCS Dup													
<u>Parameter</u>		<u>PrepSet</u>	<u>LCS</u>	<u>LCSD</u>			<u>Known</u>	<u>Limits%</u>	<u>LCS%</u>	<u>LCSD%</u>	<u>Units</u>	<u>RPD</u>	
Hexachlorophene		1109991	43.8	53.7			50.0	25.5 - 145	87.6	107	ug/L	19.9	
		1111003						EPA 622					
Blank													
<u>Parameter</u>		<u>PrepSet</u>	<u>Reading</u>	<u>MDL</u>	<u>MQL</u>	<u>Units</u>			<u>File</u>				
Chlorpyrifos		1109805	ND	0.0904	50.0	ug/L			126135522				
CCV													
<u>Parameter</u>			<u>Reading</u>	<u>Known</u>	<u>Units</u>	<u>Recover%</u>	<u>Limits%</u>			<u>File</u>			
Chlorpyrifos			968	1000	ug/L	96.8	48.0 - 150			126135521			
Chlorpyrifos			1190	1000	ug/L	119	48.0 - 150			126135532			
Chlorpyrifos			1180	1000	ug/L	118	48.0 - 150			126135539			
LCS Dup													
<u>Parameter</u>		<u>PrepSet</u>	<u>LCS</u>	<u>LCSD</u>			<u>Known</u>	<u>Limits%</u>	<u>LCS%</u>	<u>LCSD%</u>	<u>Units</u>	<u>RPD</u>	
Chlorpyrifos		1109805	653	632			1000	0.100 - 128	65.3	63.2	ug/L	3.27	
Surrogate													
<u>Parameter</u>		<u>Sample</u>	<u>Type</u>	<u>Reading</u>	<u>Known</u>	<u>Units</u>	<u>Recover%</u>	<u>Limits%</u>			<u>File</u>		
Tributylphosphate			CCV	980	1000	ug/L	98.0	0.100 - 115			126135521		
Tributylphosphate			CCV	1140	1000	ug/L	114	0.100 - 115			126135532		
Tributylphosphate			CCV	1130	1000	ug/L	113	0.100 - 115			126135539		
Triphenylphosphate			CCV	964	1000	ug/L	96.4	0.100 - 115			126135521		
Triphenylphosphate			CCV	1200	1000	ug/L	120 *	0.100 - 115			126135532		
Triphenylphosphate			CCV	1260	1000	ug/L	126 *	0.100 - 115			126135539		
Tributylphosphate		1109805	Blank	601	1000	ug/L	60.1	0.100 - 115			126135522		
Tributylphosphate		1109805	LCS	611	1000	ug/L	61.1	0.100 - 115			126135523		
Tributylphosphate		1109805	LCS Dup	610	1000	ug/L	61.0	0.100 - 115			126135524		
Triphenylphosphate		1109805	Blank	630	1000	ug/L	63.0	0.100 - 115			126135522		
Triphenylphosphate		1109805	LCS	649	1000	ug/L	64.9	0.100 - 115			126135523		
Triphenylphosphate		1109805	LCS Dup	644	1000	ug/L	64.4	0.100 - 115			126135524		
		1111016						EPA 614					

Email: Kilgore.ProjectManagement@spllabs.com



Report Page 6 of 13

QUALITY CONTROL



TABM-G

Eurofins Test America Houston
 Bethany A McDaniel
 4145 Greenbriar Drive
 Stafford, TX 77477

Page 2 of 3

Project

1095724

Printed 03/26/2024

Blank

<u>Parameter</u>	<u>PrepSet</u>	<u>Reading</u>	<u>MDL</u>	<u>MQL</u>	<u>Units</u>	<u>File</u>
Azinphos-methyl (Guthion)	1109805	ND	41.4	50.0	ug/L	126135811
Demeton	1109805	ND	31.9	50.0	ug/L	126135811
Diazinon	1109805	ND	19.7	50.0	ug/L	126135811
Malathion	1109805	ND	24.8	50.0	ug/L	126135811
Parathion, ethyl	1109805	ND	23.9	50.0	ug/L	126135811
Parathion, methyl	1109805	ND	27.4	50.0	ug/L	126135811

CCV

<u>Parameter</u>	<u>Reading</u>	<u>Known</u>	<u>Units</u>	<u>Recover%</u>	<u>Limits%</u>	<u>File</u>
Azinphos-methyl (Guthion)	981	1000	ug/L	98.1	37.5 - 164	126135810
Azinphos-methyl (Guthion)	1110	1000	ug/L	111	37.5 - 164	126135821
Azinphos-methyl (Guthion)	1060	1000	ug/L	106	37.5 - 164	126135828
Demeton	981	1000	ug/L	98.1	58.6 - 150	126135810
Demeton	1140	1000	ug/L	114	58.6 - 150	126135821
Demeton	1140	1000	ug/L	114	58.6 - 150	126135828
Diazinon	1030	1000	ug/L	103	65.4 - 138	126135810
Diazinon	1130	1000	ug/L	113	65.4 - 138	126135821
Diazinon	1230	1000	ug/L	123	65.4 - 138	126135828
Malathion	952	1000	ug/L	95.2	49.5 - 160	126135810
Malathion	1170	1000	ug/L	117	49.5 - 160	126135821
Malathion	1220	1000	ug/L	122	49.5 - 160	126135828
Parathion, ethyl	968	1000	ug/L	96.8	56.0 - 142	126135810
Parathion, ethyl	1060	1000	ug/L	106	56.0 - 142	126135821
Parathion, ethyl	1060	1000	ug/L	106	56.0 - 142	126135828
Parathion, methyl	975	1000	ug/L	97.5	12.6 - 194	126135810
Parathion, methyl	1020	1000	ug/L	102	12.6 - 194	126135821
Parathion, methyl	981	1000	ug/L	98.1	12.6 - 194	126135828

LCS Dup

<u>Parameter</u>	<u>PrepSet</u>	<u>LCS</u>	<u>LCSD</u>	<u>Known</u>	<u>Limits%</u>	<u>LCS%</u>	<u>LCSD%</u>	<u>Units</u>	<u>RPD</u>	<u>Limit%</u>
Azinphos-methyl (Guthion)	1109805	646	702	1000	0.100 - 155	64.6	70.2	ug/L	8.31	30.0
Demeton	1109805	475	448	1000	0.100 - 109	47.5	44.8	ug/L	5.85	30.0
Diazinon	1109805	521	517	1000	0.100 - 125	52.1	51.7	ug/L	0.771	30.0
Malathion	1109805	785	798	1000	0.100 - 130	78.5	79.8	ug/L	1.64	30.0
Parathion, ethyl	1109805	793	776	1000	0.100 - 122	79.3	77.6	ug/L	2.17	30.0
Parathion, methyl	1109805	635	621	1000	0.100 - 131	63.5	62.1	ug/L	2.23	30.0

Surrogate

<u>Parameter</u>	<u>Sample</u>	<u>Type</u>	<u>Reading</u>	<u>Known</u>	<u>Units</u>	<u>Recover%</u>	<u>Limits%</u>	<u>File</u>
Tributylphosphate	CCV	980	2000	ug/L	49.0	0.100 - 106	126135810	
Tributylphosphate	CCV	1140	2000	ug/L	57.0	0.100 - 106	126135821	
Tributylphosphate	CCV	1130	2000	ug/L	56.5	0.100 - 106	126135828	
Triphenylphosphate	CCV	964	2000	ug/L	48.2	0.100 - 172	126135810	
Triphenylphosphate	CCV	1200	2000	ug/L	60.0	0.100 - 172	126135821	
Triphenylphosphate	CCV	1260	2000	ug/L	63.0	0.100 - 172	126135828	
Tributylphosphate	1109805	Blank	601	2000	ug/L	30.0	0.100 - 106	126135811



Email: Kilgore.ProjectManagement@spllabs.com

Report Page 7 of 13

QUALITY CONTROL



TABM-G

Eurofins Test America Houston
 Bethany A McDaniel
 4145 Greenbriar Drive
 Stafford, TX 77477

Page 3 of 3

Project
1095724

Printed 03/26/2024

Surrogate

<u>Parameter</u>	<u>Sample</u>	<u>Type</u>	<u>Reading</u>	<u>Known</u>	<u>Units</u>	<u>Recover%</u>	<u>Limits%</u>	<u>File</u>
Tributylphosphate	1109805	LCS	611	2000	ug/L	30.6	0.100 - 106	126135812
Tributylphosphate	1109805	LCS Dup	610	2000	ug/L	30.5	0.100 - 106	126135813
Triphenylphosphate	1109805	Blank	630	2000	ug/L	31.5	0.100 - 172	126135811
Triphenylphosphate	1109805	LCS	649	2000	ug/L	32.4	0.100 - 172	126135812
Triphenylphosphate	1109805	LCS Dup	644	2000	ug/L	32.2	0.100 - 172	126135813
Tributylphosphate	2281758	Unknown	0.831	2.03	ug/L	40.9	0.100 - 106	126135820
Triphenylphosphate	2281758	Unknown	0.832	2.03	ug/L	41.0	0.100 - 172	126135820

* Out RPD is Relative Percent Difference: $\text{abs}(r_1-r_2) / \text{mean}(r_1,r_2) * 100\%$

Recover% is Recovery Percent: result / known * 100%

Blank - Method Blank (reagent water or other blank matrices that contains all reagents except standard(s) and is processed simultaneously with and under the same conditions as samples; carried through preparation and analytical procedures exactly like a sample; monitors); CCV - Continuing Calibration Verification (same standard used to prepare the curve; typically a mid-range concentration; verifies the continued validity of the calibration curve); LCS Dup - Laboratory Control Sample Duplicate (replicate LCS; analyzed when there is insufficient sample for duplicate or MSD; quantifies accuracy and precision.); Surrogate - Surrogate (mimics the analyte of interest but is unlikely to be found in environmental samples; added to analytical samples for QC purposes. **ANSI/ASQC E4 1994 Ref #4 TRADE QA Resources Guide.)

Email: Kilgore.ProjectManagement@spillabs.com



Report Page 8 of 13

Eurofins Houston
4145 Greenbriar Dr
Houston, TX 77077

Eurofins House
4145 Greenbriar Dr
Austin TX 78727

1 of 5

1095724 CoC Print Group 001 of 001

Chain of Custody Record



eurofins

Environment Testing
Report Page 9 of 13

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

2 of 5

1095724 CoC Print Group 001 of 001

ICOC No:
860-104553

Containers	Container Type	Preservative
2	Amber Glass 1 liter - unpreserved	None

Subcontract Method Instructions

Sample IDs	Method	Method Description	Method Comments
1	SUBCONTRACT	SUB (Hexachlorophene)/ Hexachlorophene	
1	SUBCONTRACT	SUB (Table 4.0 (1) - Organophosphorous Pesticides (GC))/ Organophos Pesticides	Guthion, Chlorpyrifos, Demeton, Diazinon, Malation, Ethyl Parathion

Report Page 10 of 13

1
12
3
4
45
6
7
8
910
1112
13
1415
16
17

18

3 of 5

1095724 CoC Print Group 001 of 001

Bottle Order Information

Bottle Order:

Bottle Order #:

Request From Client: 3/14/2024

Date Order Posted:

Order Status: Ready To Process

Prepared By:

Deliver By Date: 3/14/2024 11:59:00PM

Lab Project Number:

PWSID:

Order Completion Information

Creator: Lisandra Torrez

Filled by:

Sent Date:

Sent Via:

Tracking #:

Report Page 11 of 13

Sets Bottles/Sat Qty Bottle Type Description Preservative Method Matrix Sample Type Comments Lot #**Notes to Field Staff****Health and Safety Notes: Preservative****Comment**

Scan QR code for field sampler instructions

Relinquished By	Company	Date	Time	Received By	Company	Seal #:
Relinquished By	Company	Date	Time	Received By	Company	Seal #:

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Shipping Order ID: 27738

Page 3 of 3

Printed on 3/14/2024 4:39:14PM

1 12 3 4 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18

4 of 5

1095724 CoC Print Group 001 of 001



Environment Testing



Eurofins Houston
4145 Greenbriar Dr
Stafford, TX 77477
Phone (281) 240-4200

Shipping Order Form

Shipping Order ID: 27738

Ship Via: FedEx Priority Overnight

Due On: 3/14/2024 11:59:00PM

Ship To Information

Project Manager:

Company Name: Ana-Lab Corporation
Attention: Shipping/Receiving
Address 1: 2600 Dudley Rd
Address 2:
Address 3:
City: Kilgore
State: TX
Zip: 75662
Phone #:
Project Ref:

Notes to Bottler/Shipping Department

Shipping Method: Standard packing

- Ready to Fill Return Shipment Labels
 Preprinted COC Prepaid Return
 Number of COC Copies Eurofins Houston
 Seats on Bottle Short Hold Times
 Seats on Coolers Temperature Control
 Priority Rush

**Min Due Date: 3/19/2024
11:59:00PM**

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Shipping Order ID: 27738

Page 1 of 3


Printed on 3/14/2024 4:39:14PM

Report Page 12 of 13

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

5 of 5

1095724 CoC Print Group 001 of 001



<https://www.fedex.com/shipping/shipAction.html?method=doC>

3/14/24, 4:40 PM

Chain of Custody Record

Client Information		Sampler Globby Ficke		Lab P#: Richter Travis W		Carrier Tracking No(s):	
Client Contact	A. Shay Ochoa	Phone:	254-829-8001	E-Mail:	Travis.Richter@eurofinsus.com	State of Origin:	
Company Address:	4751 Tokio Rd West TX, 76691	Due Date Requested:		TAT Requested (days):		Job #:	
Project Name:	City of Hillsboro Permit Renewal	Compliance Project:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	PO#:		IR ID:	HOU-368
Site:	SSOW#:	Purchase Order Requested		WFO#:		Corrected Temp:	2.6
		Project #:	86006551	VO#:		Temp:	2.1
		Address:	254-829-8001(Tel)	Phone:		C/F:+0.2	
		Email:	aocioha@biochemlabix.com			Corrected Temp:	2.3
Analysis Requested							
Preservation Codes:							
<input checked="" type="checkbox"/> A HCl <input type="checkbox"/> M Hexane <input checked="" type="checkbox"/> B NaOH <input type="checkbox"/> N None <input checked="" type="checkbox"/> C Zn Acetate <input type="checkbox"/> O AsNaO2 <input checked="" type="checkbox"/> D Nitric Acid <input type="checkbox"/> P Na2O4S <input checked="" type="checkbox"/> E NaHSO4 <input type="checkbox"/> Q Na2SC3 <input checked="" type="checkbox"/> F MeOH <input type="checkbox"/> R Na2SO4 <input checked="" type="checkbox"/> G Ammonia <input type="checkbox"/> S H2SO4 <input checked="" type="checkbox"/> H Ascorbic Acid <input type="checkbox"/> T TSP Dodecylbenzene <input checked="" type="checkbox"/> I Ice <input type="checkbox"/> U Acetone <input checked="" type="checkbox"/> J DI Water <input type="checkbox"/> V MCAA <input checked="" type="checkbox"/> K EDTA <input type="checkbox"/> W pH 4-5 <input checked="" type="checkbox"/> L EDA <input type="checkbox"/> Y Trizma <input checked="" type="checkbox"/> Other <input type="checkbox"/> Z other (specify)							
Serial Number of Detector/Interferer:							
200.7 (MDF) Custom List							
SUBCONTRACT Asbestos							
335.4 Total Cyanide							
4500-CN-G_Nanarm, SM4500CN-G_Calc							
SUBCONTRACT Hexachlorophene							
615-MOD (MDF) Local Method							
Organotinns, SIM Tributyltin Only							
67065-11 Nonylphenol							
1613B_1688C							
624.1 (MDF)							
SUBCONTRACT Organophosphates							
632 Cadmium, & Dluron							
608.3-PCB, 608.3-Pest, 625.1							
Matrix (Water, Solid, Oil, Waste, Ash)							
Sample Date							
Sample Time							
Sample Type (C=Comp, G=grab)							
Preservation Code:							
6221-24 Hillsboro Permit Renewal							
3.12.24 1000 Grab							
Water							
Water							
Special Instructions/Note:							
Temp: 2.4 IR ID:HOU-368							
Corrected Temp: 2.6							
Temp: 2.1 IR ID:HOU-368							
C/F:+0.2							
Corrected Temp: 2.3							
860-69911 Chain of Custody							
Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)							
<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months							
Special Instructions/QC Requirements:							
Empty Kit Relinquished by:		Date:	Time:	Method of Shipment:			
Relinquished by:		Date/Time:	Company	Received by:	Date/Time:	Company	
Richter		3/12/24 / 1400	BCC	Reported By: Howie Richter	3/12/24 / 1400	Company BCC	
		Date/Time:	Company	Received by:	Date/Time:	Company	
		3/12/24 / 1615	BCC		3/12/24 / 1615	Dynardo	
		Date/Time:	Company	Received by:	Date/Time:	Company	
		3/13/24 / 1435	BCC		3/13/24 / 1435	John Rich	
Custody Seals Intact.							
<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
Cohen Temperature(s) °C and Other Remarks:							

Ver 6/16/2019

Chain of Custody Record

Client Information		Sampler: <u>Gibby Ficke</u>	Lab PM: <u>Richier Travis W</u>	Carrier Tracking No(s): <u>800-27593-9335-2</u>	CC#:
Client Contact: A. Shay Ochoa	Phone: <u>281-829-8001</u>	E-Mail: <u>Travis.Richier@ef.eurofinsus.com</u>	State of Origin: <u></u>	Page: <u>2 of 2</u>	Job #:
Analysis Requested					
Address: 4751 Toklo Rd City: West State Zip: TX 76691 Phone: 254-829-8001 (Tel) Email: <u>aocioha@biochemlabtx.com</u> Project Name: <u>City of Hillsboro Permit Renewal</u> Site: <u>SSC#:</u>	Date Requested: TAT Requested (days): Compliance Project: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No PO #: Purchase Order Requested WO #: Project #: <u>80006351</u> SSC #: <u></u>	Sample Date <u>6/22/24</u>	Sample Time <u>10:00 AM</u>	Sample Type (C=comp, G=grab) <u>Grab</u>	Matrix (solvent, solvent, dilution, acidic) <u>Water</u>
				Preservation Code: <u>N</u>	Total Number of Contaminants: <u>16316_LHg</u>
Special Instructions/Note:					
Title/Etched Sample (Yes or No): <input checked="" type="checkbox"/>					
Field Filtered Sample: <input type="checkbox"/>					
Special Instructions/QC Requirements:					
Possible Hazard Identification <input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological		Sample Disposal (<input checked="" type="checkbox"/> A fee may be assessed if samples are retained longer than 1 month) <input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For Months			
Deliverable Requested. I, II, III, IV Other (specify): <u></u>					
Empty Kit Relinquished by: <u>Bob Rich</u>					
Custody Seals intact: <input checked="" type="checkbox"/> Custody Seal No. <input type="checkbox"/> Yes <input type="checkbox"/> No		Method of Shipment: <u>3/3/24 1435</u>			
Date/Time: <u>3/12/24 / 1400</u>	Company: <u>BCC</u>	Received by: <u>Bob Rich</u>	Date/Time: <u>3/12/24 / 1400</u>	Company: <u>BCC</u>	Received by: <u>Bob Rich</u>
Date/Time: <u>3/12/24 / 1615</u>	Company: <u>BCC</u>	Date/Time: <u>3/12/24 / 1615</u>	Company: <u>Dynasco</u>	Date/Time: <u>3/13/24 1435</u>	Company: <u>Dynasco</u>

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

FedEx Ship Manager - Print Your Label(s)



860-69911 Waybill

P: 1, 15618-434 MTW EXP 01/24
2/3

www.fedex.com/shipping/shipAction.handle?method=doContinue

Chain of Custody Record



Environment testing

Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central, LLC places the ownership of method, analytic & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the subcontract laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing South Central, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central, LLC.

Fossile Hazard / Identifications

Unconfirmed		Primary Deliverable Rank: 2		Special Instructions/QC Requirements:		Archive For Months	
Deliverable Requested: I, II, III, IV, Other (specify)		Date:	Time:	Method of Shipment:			
Empty Kit Relinquished by:	<i>J. C. L.</i>	Date/Time: 3/14/2014	Company	Received by: <i>J. C. L.</i>	Date/Time: 3/15/2014	Company	Company
Relinquished by:	<i>J. C. L.</i>	Date/Time: 3/14/2014	Company	Received by: <i>J. C. L.</i>	Date/Time: 3/15/2014	Company	Company
Relinquished by:	<i>J. C. L.</i>	Date/Time: 3/14/2014	Company	Received by: <i>J. C. L.</i>	Date/Time: 3/15/2014	Company	Company
Relinquished by:	<i>J. C. L.</i>	Date/Time: 3/14/2014	Company	Received by: <i>J. C. L.</i>	Date/Time: 3/15/2014	Company	Company
Custody Seals Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:			



Stafford TX 77477
Phone: 281-240-4200

Note: Since laboratory accreditations are subject to change Eurofins Environment Testing South Central LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody if the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed the samples must be shipped back to the Eurofins Environment Testing South Central LLC laboratory or other instructions will be provided. Any changes to accredited status should be brought to Eurofins Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central LLC.

Possible Hazard Identification

Unconfirmed

Return To Client Disposal By Lab Archive For _____ Mont _____

Special Instructions/QC Requirements.

Primary Deliverable Rank: 2

卷之三

Date.

Received by _____ Date/Time: _____ Company: _____

卷之三

Received by _____ Date/time: _____ Company: _____

Received by _____ Date/time: _____ Company: _____

Cooler Temperature(s) °C and Other Remarks.

Ver 06

Chain of Custody Record



Client Information (Sub Contract Lab)		Sampler:	Richter, Travis W	Lab PM:	Richter, Travis W	Carrier Tracking No(s):	COC No. 860-104557.1
Client Contact:	Phone:	E-Mail:	Travis.Richter@et.eurofinsus.com	State of Origin:	Texas	Page:	Page 1 of 1
Shipping/Receiving	Address:	NE LAP - Texas		Job #:	860-699-11-1	Preservation Codes:	
Company:	Address:	Due Date Requested: 3/26/2024		Analysis Requested			
Eurofins Environment Testing Southeast,	3355 McLenore Drive,	TAT Requested (days):					
City: Pensacola	State, Zip: FL, 32514	PO #:					
Phone: 850-474-1001(Tel)	Fax: 850-478-2671(Fax)	VO #:					
Email:	Project #: 86006551	SSOW#:					
Project Name: City of Hillsboro Permit Renewal	Site:						
Sample Identification - Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (Water, Soil, Oil, Other), BT=Issue, AA=Air	Total Number of Containers	Special Instructions/Note:
6221-24 Hillsboro Permit Renewal (860-699-11-1)		3/12/24	10:00	Water	X	2	
Preformed Sample (Yes or No)							
Preliminary Sample (Yes or No)							
Total Filtered Sample (Yes or No)							
1331E/1631E_Prep LLHG							
A - HCl B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA M - Hexane N - None O - AsNaO2 P - Na2OaS Q - Na2SO3 R - Na2SO4 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCA W - pH 4-5 Y - Trizma Z - other (specify) Other:							
Unconfirmed							
Deliverable Requested: I, II, III, IV, Other (specify)							
Primary Deliverable Rank: 2							
Empty Kit Relinquished by:							
Relinquished by:	Date/Time:	Date/Time:	Date/Time:	Received by:	Received by:	Received by:	Method of Shipment:
	2024-03-12 1800	2024-03-12 1800	2024-03-12 1800	BB	BB	BB	Date/Time: Company
Relinquished by:	Date/Time:	Date/Time:	Date/Time:	Received by:	Received by:	Received by:	Date/Time: Company
Relinquished by:	Date/Time:	Date/Time:	Date/Time:	Received by:	Received by:	Received by:	Date/Time: Company
Custody Seals Intact: Custody Seal No.: Δ Yes △ No							
Cooler Temperature(s) °C and Other Remarks: 1.7°C 3.2°C T211							

Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central, LLC places the ownership of method, analytic & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing South Central, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central, LLC.

Possible Hazard Identification

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

Return To Client

Disposal By Lab

Archive For Months

Special Instructions/QC Requirements:

Ver: 06/08/2021

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

Chain of Custody Record



Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing South Central, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing South Central LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central, LLC.

Possible Hazard Identification

Unconfirmed

Deliverable Requested I II III IV Other (specify)

Primary Deliverable Rank: 2

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

Return To Client *Disposal By Lab* *Archive For* *Months*

Empty Kit Relinquished by

Da

— 1 —

Method of Shipment

Relinquished by *livel*

Date/Time:

— 1 —

1

— 1 —

—
—

— 1 —

100

— 1 —

Cooler Temperature(s) °C and Other Remarks

Sign 1-7 1-7



Environment Testing

Sacramento Sample
Receiving Notes (SSRN)Job: 860-69911 Field SheetTracking # 7755 6192 2641SO / FO / SAT / 2-Day / Ground / UPS / CDO / Courier
GSL / OnTrac / Goldstreak / USPS / Other _____

Use this form to record Sample Custody Seal, Cooler Custody Seal, Temperature & corrected Temperature & other observations.
File in the job folder with the COC

<p>Therm. ID: <u>604</u> Corr. Factor (+/-) <u>N/A</u> °C</p> <p>Ice <input type="checkbox"/> Wet <input checked="" type="checkbox"/> Gel <input type="checkbox"/> Other <input type="checkbox"/></p> <p>Cooler Custody Seal: <u>—</u></p> <p>Cooler ID: <u>—</u></p> <p>Temp Observed. <u>12.9</u> °C Corrected. <u>12.9</u> °C From Temp Blank <input type="checkbox"/> Sample <input checked="" type="checkbox"/></p> <p>Opening/Processing The Shipment</p> <table border="0"> <tr> <td>Yes <input type="checkbox"/></td> <td>No <input checked="" type="checkbox"/></td> <td>NA <input type="checkbox"/></td> </tr> <tr> <td>Cooler compromised/tampered with? <input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Cooler Temperature is acceptable? <input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Frozen samples show signs of thaw? <input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> </table> <p>Initials: <u>SO</u> Date <u>3/18/24</u></p> <p>Unpacking/Labeling The Samples</p> <table border="0"> <tr> <td>Yes <input type="checkbox"/></td> <td>No <input type="checkbox"/></td> <td>NA <input type="checkbox"/></td> </tr> <tr> <td>Containers are not broken or leaking? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Samples compromised/tampered with? <input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>COC is complete w/o discrepancies <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Sample custody seal? <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>Sample containers have legible labels? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Sample date/times are provided? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Appropriate containers are used? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Sample bottles are completely filled? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Sample preservatives verified? <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>Is the Field Sampler's name on COC? <input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Samples w/o discrepancies? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Zero headspace?* <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>Alkalinity has no headspace? <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>Perchlorate has headspace? (Methods 314, 331, 6850) <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>Multiphasic samples are not present? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> </table> <p>*Containers requiring zero headspace have no headspace, or bubble < 6 mm (1/4")</p> <p>Initials: <u>SO</u> Date <u>3/18/24</u></p>	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	NA <input type="checkbox"/>	Cooler compromised/tampered with? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Cooler Temperature is acceptable? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Frozen samples show signs of thaw? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	Containers are not broken or leaking? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Samples compromised/tampered with? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	COC is complete w/o discrepancies <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample custody seal? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sample containers have legible labels? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample date/times are provided? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Appropriate containers are used? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample bottles are completely filled? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample preservatives verified? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Is the Field Sampler's name on COC? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Samples w/o discrepancies? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Zero headspace?* <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Alkalinity has no headspace? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Perchlorate has headspace? (Methods 314, 331, 6850) <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Multiphasic samples are not present? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<p>Notes:</p> <p><u>only water in cooler</u> <u>-> 1 L milk</u></p> <p><u>flex tag</u> <u>FRI-15 MAR Rec on 3/18/24</u></p> <p><u>1 COCS wet in most</u> <u>(860)</u></p> <p><u>1L PC H-K Container</u></p> <p>Trizma Lot #(s): _____ _____</p> <p>Ammonium _____ Acetate Lot #(s): _____ _____</p> <p>Login Completion</p> <table border="0"> <tr> <td>Yes <input checked="" type="checkbox"/></td> <td>No <input type="checkbox"/></td> <td>NA <input type="checkbox"/></td> </tr> <tr> <td>Receipt Temperature on COC? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>NCM Filed? <input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Samples received within hold time? <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> <tr> <td>Log Release checked in TALS? <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> </tr> </table> <p>Initials <u>SO</u> Date <u>3/18/24</u></p>	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	Receipt Temperature on COC? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	NCM Filed? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Samples received within hold time? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Log Release checked in TALS? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>	NA <input type="checkbox"/>																																																																										
Cooler compromised/tampered with? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																																										
Cooler Temperature is acceptable? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																																										
Frozen samples show signs of thaw? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																																										
Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>																																																																										
Containers are not broken or leaking? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Samples compromised/tampered with? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																																										
COC is complete w/o discrepancies <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Sample custody seal? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																																																																										
Sample containers have legible labels? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Sample date/times are provided? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Appropriate containers are used? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Sample bottles are completely filled? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Sample preservatives verified? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																																																																										
Is the Field Sampler's name on COC? <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																																										
Samples w/o discrepancies? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Zero headspace?* <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																																																																										
Alkalinity has no headspace? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																																																																										
Perchlorate has headspace? (Methods 314, 331, 6850) <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																																																																										
Multiphasic samples are not present? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>																																																																										
Receipt Temperature on COC? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
NCM Filed? <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																																										
Samples received within hold time? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																																																																										
Log Release checked in TALS? <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																																																																										

Login Sample Receipt Checklist

Client: Bio Chem Lab, Inc

Job Number: 860-69911-1

Login Number: 69911

List Source: Eurofins Houston

List Number: 1

Creator: Rubio, Yuri

Question

Answer

Comment

Radioactivity wasn't checked or is </= background as measured by a survey meter.

The cooler's custody seal, if present, is intact.

Sample custody seals, if present, are intact.

The cooler or samples do not appear to have been compromised or tampered with.

Samples were received on ice.

Cooler Temperature is acceptable.

Cooler Temperature is recorded.

COC is present.

COC is filled out in ink and legible.

COC is filled out with all pertinent information.

Is the Field Sampler's name present on COC?

There are no discrepancies between the containers received and the COC.

Samples are received within Holding Time (excluding tests with immediate HTs)

Sample containers have legible labels.

Containers are not broken or leaking.

Sample collection date/times are provided.

Appropriate sample containers are used.

Sample bottles are completely filled.

Sample Preservation Verified.

There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs

Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").

Multiphasic samples are not present.

Samples do not require splitting or compositing.

Residual Chlorine Checked.

Login Sample Receipt Checklist

Client: Bio Chem Lab, Inc

Job Number: 860-69911-1

Login Number: 69911

List Source: Eurofins Calscience

List Number: 3

List Creation: 03/15/24 06:11 PM

Creator: Khana, Piyush

Question	Answer	Comment	
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A		1
The cooler's custody seal, if present, is intact.	True	Seal present with no number.	2
Sample custody seals, if present, are intact.	N/A		3
The cooler or samples do not appear to have been compromised or tampered with.	True		4
Samples were received on ice.	True		5
Cooler Temperature is acceptable.	True		6
Cooler Temperature is recorded.	True	1.7	7
COC is present.	True		8
COC is filled out in ink and legible.	True		9
COC is filled out with all pertinent information.	True		10
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.	11
There are no discrepancies between the containers received and the COC.	True		12
Samples are received within Holding Time (excluding tests with immediate HTs)	True		13
Sample containers have legible labels.	True		14
Containers are not broken or leaking.	True		15
Sample collection date/times are provided.	True		16
Appropriate sample containers are used.	True		17
Sample bottles are completely filled.	True		18
Sample Preservation Verified.	True		
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True		
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True		
Multiphasic samples are not present.	True		
Samples do not require splitting or compositing.	True		
Residual Chlorine Checked.	False		

Login Sample Receipt Checklist

Client: Bio Chem Lab, Inc

Job Number: 860-69911-1

Login Number: 69911

List Source: Eurofins Denver

List Number: 2

List Creation: 03/15/24 03:43 PM

Creator: Naylis, Patrick J

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	N/A	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Login Sample Receipt Checklist

Client: Bio Chem Lab, Inc

Job Number: 860-69911-1

Login Number: 69911

List Source: Eurofins Pensacola

List Number: 4

List Creation: 03/16/24 02:47 PM

Creator: Pardonner, Brett

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.7°C IR11 3.2°
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	N/A	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Login Sample Receipt Checklist

Client: Bio Chem Lab, Inc

Job Number: 860-69911-1

Login Number: 69911

List Source: Eurofins Sacramento

List Number: 5

List Creation: 03/18/24 12:58 PM

Creator: Oropeza, Salvador

Question	Answer	Comment	
Radioactivity wasn't checked or is </= background as measured by a survey meter.	True		1
The cooler's custody seal, if present, is intact.	N/A		2
Sample custody seals, if present, are intact.	N/A		3
The cooler or samples do not appear to have been compromised or tampered with.	True		4
Samples were received on ice.	False	Water present in cooler; indicates evidence of melted ice.	5
Cooler Temperature is acceptable.	False	Refer to Job Narrative for details.	6
Cooler Temperature is recorded.	True	12.9C	7
COC is present.	True		8
COC is filled out in ink and legible.	True		9
COC is filled out with all pertinent information.	True		10
Is the Field Sampler's name present on COC?	False	Received project as a subcontract.	11
There are no discrepancies between the containers received and the COC.	True		12
Samples are received within Holding Time (excluding tests with immediate HTs)	True		13
Sample containers have legible labels.	True		14
Containers are not broken or leaking.	True		15
Sample collection date/times are provided.	True		16
Appropriate sample containers are used.	True		17
Sample bottles are completely filled.	True		18
Sample Preservation Verified.	N/A		
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True		
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True		
Multiphasic samples are not present.	True		
Samples do not require splitting or compositing.	True		
Residual Chlorine Checked.	N/A		

**BIO CHEM LAB, INC.  4751 TOKIO ROAD  WEST, TEXAS 76691
PHONE_ 254.829.8001 FAX_254.829.8013**

City of Hillsboro
P O Box 568
Hillsboro, Texas 76645

Attention: Mr. Terry Dieterich
Date: 4.17.24
Re: Permit Renewal

PROJECT COVER LETTER – HILLSBORO

On 3.12.24, Bio Chem Lab, Inc. received in the field and subsequently received at their facility grab sample from the **City of Hillsboro** for permit renewal analysis. The samples were received into the logging system as having parent Sample ID(s) **6221-24**.

The subcontract analysis was networked to Eurofins in Stafford, Texas on 3.12.24. The report is included in its entirety and has Report ID(s): **860-69911-1**.

We believe this report to be complete for the analysis requested and ready for submission to the client. Prior to release, the data within this report has been reviewed for completion and accuracy. This report will not be reproduced except in its entirety, and only by written request of the above noted client.

For any additional questions / concerns regarding this analytical report please call 254.829.8001. Please note that Bio Chem Lab, Inc. and its network laboratories are accredited in accordance with NELAP.

Sincerely,



Andrew Janek, Technical Director
Bio Chem Lab, Inc.

**THANK YOU FOR ALLOWING BIO CHEM LAB, INC. THE OPPORTUNITY TO BE YOUR
ANALYTICAL SERVICE PROVIDER.**

Trinity Houston
1145 Greenbriar Dr
Stafford, TX 77477
Phone (281) 240-4200

Chain of Custody Record

Ver. 01/16/2019

THANK YOU FOR ALLOWING BIO CHEM LAB, INC. THE OPPORTUNITY TO BE YOUR
ANALYTICAL SERVICE PROVIDER.



Environment Testing

Chain of Custody Record

Eurofins Houston
4145 Greenbriar Dr
Stafford, TX 77477
Phone (281) 240-2200

Ver: 01/16/2019

THANK YOU FOR ALLOWING BIO CHEM LAB, INC. THE OPPORTUNITY TO BE YOUR
ANALYTICAL SERVICE PROVIDER.



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for Submission (<i>If other is checked please describe in space provided.</i>)	
<input type="checkbox"/> New Permit, Registration or Authorization (<i>Core Data Form should be submitted with the program application.</i>)	
<input checked="" type="checkbox"/> Renewal (<i>Core Data Form should be submitted with the renewal form</i>)	
2. Customer Reference Number (<i>if issued</i>) CN 600514228	Follow this link to search for CN or RN numbers in Central Registry**
3. Regulated Entity Reference Number (<i>if issued</i>) RN 102844180	

SECTION II: Customer Information

4. General Customer Information	5. Effective Date for Customer Information Updates (mm/dd/yyyy)	05/30/2024						
<input type="checkbox"/> New Customer <input type="checkbox"/> Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts)	<input checked="" type="checkbox"/> Update to Customer Information	<input type="checkbox"/> Change in Regulated Entity Ownership						
<i>The Customer Name submitted here may be updated automatically based on what is current and active with the Texas Secretary of State (SOS) or Texas Comptroller of Public Accounts (CPA).</i>								
6. Customer Legal Name (<i>If an individual, print last name first: eg: Doe, John</i>)		<i>If new Customer, enter previous Customer below:</i>						
City of Hillsboro								
7. TX SOS/CPA Filing Number	8. TX State Tax ID (11 digits) 17460010899	9. Federal Tax ID (9 digits) 74-600189	10. DUNS Number (<i>if applicable</i>) 041127077					
11. Type of Customer:	<input type="checkbox"/> Corporation	<input type="checkbox"/> Individual	Partnership: <input type="checkbox"/> General <input type="checkbox"/> Limited					
Government: <input checked="" type="checkbox"/> City <input type="checkbox"/> County <input type="checkbox"/> Federal <input type="checkbox"/> Local <input type="checkbox"/> State <input type="checkbox"/> Other		<input type="checkbox"/> Sole Proprietorship	<input type="checkbox"/> Other:					
12. Number of Employees <input type="checkbox"/> 0-20 <input type="checkbox"/> 21-100 <input checked="" type="checkbox"/> 101-250 <input type="checkbox"/> 251-500 <input type="checkbox"/> 501 and higher		13. Independently Owned and Operated? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
14. Customer Role (<i>Proposed or Actual – as it relates to the Regulated Entity listed on this form. Please check one of the following</i>)								
<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input checked="" type="checkbox"/> Owner & Operator <input type="checkbox"/> Occupational Licensee <input type="checkbox"/> Responsible Party <input type="checkbox"/> VCP/BSA Applicant <input type="checkbox"/> Other:								
15. Mailing Address:	P.O. Box 568							
	City	Hillsboro	State	TX	ZIP	76645	ZIP + 4	0568
16. Country Mailing Information (<i>if outside USA</i>)				17. E-Mail Address (<i>if applicable</i>)				
				tdieterich@hillsborotx.org				
18. Telephone Number			19. Extension or Code			20. Fax Number (<i>if applicable</i>)		

SECTION III: Regulated Entity Information

21. General Regulated Entity Information (If "New Regulated Entity" is selected, a new permit application is also required.)

New Regulated Entity Update to Regulated Entity Name Update to Regulated Entity Information

The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).

22. Regulated Entity Name (Enter name of the site where the regulated action is taking place.)

City of Hillsboro Wastewater Treatment Plant

23. Street Address of the Regulated Entity: <u>(No PO Boxes)</u>	600 Parham Street							
	City	Hillsboro	State	TX	ZIP	76645	ZIP + 4	
24. County	Hill							

If no Street Address is provided, fields 25-28 are required.

25. Description to Physical Location:	Adjacent to George Street approximately 700 feet southwest of the intersection of Parham Street and George Street in Hill County Texas						
--	--	--	--	--	--	--	--

26. Nearest City			State	Nearest ZIP Code		
Hillsboro			TX	76645		

Latitude/Longitude are required and may be added/updated to meet TCEQ Core Data Standards. (Geocoding of the Physical Address may be used to supply coordinates where none have been provided or to gain accuracy).

27. Latitude (N) In Decimal:		31.999458		28. Longitude (W) In Decimal:		97.141708	
Degrees	Minutes	Seconds		Degrees	Minutes	Seconds	
31	59	58.05		97	8	30.15	

29. Primary SIC Code (4 digits)	30. Secondary SIC Code (4 digits)	31. Primary NAICS Code (5 or 6 digits)	32. Secondary NAICS Code (5 or 6 digits)
4952	0000	221320	221320

33. What is the Primary Business of this entity? (Do not repeat the SIC or NAICS description.) Municipal Government Wastewater Treatment							
--	--	--	--	--	--	--	--

34. Mailing Address:	P.O. Box 568						
	City	Hillsboro	State	TX	ZIP	76645	ZIP + 4

35. E-Mail Address:	tdieterich@hillsborotx.org						
36. Telephone Number	37. Extension or Code			38. Fax Number (if applicable)			

(254) 582-3478		(254) 582-396
------------------	--	-----------------

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

<input type="checkbox"/> Dam Safety	<input type="checkbox"/> Districts	<input type="checkbox"/> Edwards Aquifer	<input type="checkbox"/> Emissions Inventory Air	<input type="checkbox"/> Industrial Hazardous Waste
<input type="checkbox"/> Municipal Solid Waste	<input type="checkbox"/> New Source Review Air	<input type="checkbox"/> OSSF	<input type="checkbox"/> Petroleum Storage Tank	<input type="checkbox"/> PWS
<input type="checkbox"/> Sludge	<input type="checkbox"/> Storm Water	<input type="checkbox"/> Title V Air	<input type="checkbox"/> Tires	<input type="checkbox"/> Used Oil
<input type="checkbox"/> Voluntary Cleanup	<input checked="" type="checkbox"/> Wastewater	<input type="checkbox"/> Wastewater Agriculture	<input type="checkbox"/> Water Rights	<input type="checkbox"/> Other:
	RN102844180			

SECTION IV: Preparer Information

40. Name:	Megan Henderson		41. Title:	City Manager
42. Telephone Number	43. Ext./Code	44. Fax Number	45. E-Mail Address	
(254) 582-3271		(254) 582-0112	mhenderson@hillsborotx.org	

SECTION V: Authorized Signature

46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39.

Company:	City of Hillsboro	Job Title:	City Manager	
Name (In Print):	Megan Henderson		Phone:	(254) 582-3271
Signature:			Date:	7/11/24

Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0010630001

Applicant: City of Hillsboro


Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.


Signatory name (typed or printed): M. Scott Johnson

Signatory title: Mayor

Signature:  Date: 8-12-2024
(Use blue ink)

Subscribed and Sworn to before me by the said M. Scott Johnson
on this 12th day of August, 2024.


My commission expires on the 20th day of July, 2026.



Notary Public

[SEAL]

Hill
County, Texas



Francesca Findlay

From: Hilton, Susan <Susan.Hilton@mrbgroup.com>
Sent: Friday, August 30, 2024 12:02 PM
To: Francesca Findlay
Cc: mhenderson@hillsborotx.org
Subject: RE: WQ0010630001 City of Hillsboro
Attachments: Municipal Discharge Renewal Spanish NORI - Hillsboro.docx; 10400 Core Data Form WIP.pdf; Signature Page - Mayor.pdf

Hello –

Attached are the following documents:

1. Signed and notarized Administrative Report 1.0, Section 14.
2. Core Data form with Item 24 completed and data form signed.
3. NORI – Spanish version in Word.

The NORI contained in your letter is correct except that we would suggest an additional comma in the average annual flow – 1,810,000.

Please let us know if you have additional questions.

SUSAN HILTON, P.E. / MRB Group / 254.313.9182

From: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>
Sent: Monday, August 26, 2024 4:02 PM
To: mhenderson@hillsborotx.org
Cc: Hilton, Susan <Susan.Hilton@mrbgroup.com>
Subject: FW: WQ0010630001 City of Hillsboro

Dear Ms. Henderson:

The attached Notice of Deficiency letter sent on August 26, 2024, requesting additional information needed to declare the application administratively complete. Please send the complete response to my attention September 10, 2024.

Thank you,



Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division

512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail