



# Technical Package Cover Page

**This file contains the following documents:**

1. Summary of application (in plain language)
    - English
    - Alternative Language (Spanish)
  2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
    - English
    - Alternative Language (Spanish)
  3. Second notice (NAPD-Notice of Preliminary Decision)
    - English
    - Alternative Language (Spanish)
  4. Application materials
  5. Draft permit
  6. Technical summary or fact sheet
- 



# Portada de Paquete Técnico

**Este archivo contiene los siguientes documentos:**

1. Resumen de la solicitud (en lenguaje sencillo)
  - Inglés
  - Idioma alternativo (español)
2. Primer aviso (NORI, Aviso de Recepción de Solicitud e Intención de Obtener un Permiso)
  - Inglés
  - Idioma alternativo (español)
3. Segundo aviso (NAPD, Aviso de Decisión Preliminar)
  - Inglés
  - Idioma alternativo (español)
4. Materiales de la solicitud
5. Proyecto de permiso
6. Resumen técnico u hoja de datos



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

## Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by [Title 30, Texas Administrative Code \(30 TAC\), Chapter 39, Subchapter H](#). Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in [30 TAC Section 39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS DOMESTIC WASTEWATER/STORMWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.*

Trinity Bay Conservation District (CN600675417) operates Winnie-Stowell Wastewater Treatment Facility (RN102077393), a lagoon/wetland system. The facility is located at 760 East Buccaneer Drive, in Winnie, Chambers County, Texas 77665. This application is for a renewal to discharge treated domestic wastewater at an annual average flow of 1,980,000 gallons per day via Outfall 001.

Discharges from the facility are expected to contain carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen, and *Escherichia coli*. Domestic wastewater is treated by a facultative lagoon, eight wetland cells, post aeration, and chlorination.

**PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP**

**AGUAS RESIDUALES DOMESTICAS /AGUAS PLUVIALES**

*El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.*

Districto de conservación de Trinity Bay (CN600675417) opera Winnie-Stowell Instalación de Tratamiento de Aguas Residuales (RN102077393), una sistema de lagunas/humedales. La instalación está ubicada en 760 East Buccaneer Drive, en Winnie, Condado de Chambers, Texas 7665. Esta solicitud es para una renovación para descargar aguas residuales domésticas tratadas a un flujo promedio anual de 1,980,000 galones por día a través del Emisario 001.

Se espera que las descargas de la instalación contengan demanda bioquímica carbonosa de oxígeno, sólidos suspendidos totales, nitrógeno amoniacal y *Escherichia coli*. Aguas residuales domésticas. está tratado por una laguna facultativa, ocho celdas de humedal, post aireación y cloración..

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



## NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT RENEWAL

PERMIT NO. WQ0010851001

**APPLICATION.** Trinity Bay Conservation District, P.O. Box 599, Stowell, Texas 77661, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010851001 (EPA I.D. No. TX0020460) to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 1,980,000 gallons per day. The domestic wastewater treatment facility is located at 760 East Buccaneer Drive, in the city of Winnie, in Chambers County, Texas 77665. The discharge route is from the plant site to South Fork Mayhaw Bayou; thence to Mayhaw Bayou; thence to South Fork Taylor Bayou; thence to Taylor Bayou Above Tidal. TCEQ received this application on December 17, 2024. The permit application will be available for viewing and copying at Trinity Bay Conservation District, 2500 State Highway 124, Stowell, in Chambers County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

**ALTERNATIVE LANGUAGE NOTICE.** Alternative language notice in Spanish is available at: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

El aviso de idioma alternativo en español está disponible en

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

**ADDITIONAL NOTICE.** TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. **Notice of the Application and Preliminary Decision will be published and mailed to those who are on the county-wide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.**

**PUBLIC COMMENT / PUBLIC MEETING.** You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public

interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

**OPPORTUNITY FOR A CONTESTED CASE HEARING.** After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. **Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing.** A contested case hearing is a legal proceeding similar to a civil trial in state district court.

**TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.**

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. **If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.**

**TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.**

**MAILING LIST.** If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at [www.tceq.texas.gov/goto/cid](http://www.tceq.texas.gov/goto/cid). Search the database using the permit number for this application, which is provided at the top of this notice.

**AGENCY CONTACTS AND INFORMATION.** All public comments and requests must be submitted either electronically at <https://www14.tceq.texas.gov/epic/eComment/>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at [www.tceq.texas.gov/goto/pep](http://www.tceq.texas.gov/goto/pep). Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Trinity Bay Conservation District at the address stated above or by calling Mr. Jerry Shadden, General Manager, at 409-658-3677.

Issuance Date: January 6, 2025

# Comisión de Calidad Ambiental del Estado de Texas



## AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

### PERMISO NO. WQ0010851001

**SOLICITUD.** Distrito de Conservación de Trinity Bay, P.O. Box 599, Stowell, Texas 77661 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso No. WQ0010851001 (EPA I.D. No. TX0020460) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 1,980,000 galones por día. La planta está ubicada 760 East Buccaneer Drive en el Condado de Chambers, Texas. La ruta de descarga es del sitio de la planta a South Fork Mayhaw Bayou; de allí a Mayhaw Bayou; de allí a South Fork Taylor Bayou; de allí a Taylor Bayou Above Tidal. La TCEQ recibió esta solicitud el 17 de Diciembre de 2024. La solicitud para el permiso estará disponible para leerla y copiarla en 2500 State Highway 124, Stowell, Texas, antes de la fecha de publicación de este aviso en el periódico. La aplicación incluidas las actualizaciones y los avisos asociados están disponibles electrónicamente en la siguiente pagina web:

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

**AVISO ADICIONAL.** El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. **El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.**

**COMENTARIO PUBLICO / REUNION PUBLICA.** Usted puede presentar **comentarios públicos o pedir una reunión pública sobre esta solicitud.** El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

**OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.**

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso.** Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

**PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS:** su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

**LISTA DE CORREO.** Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas de correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agregue su nombre en una de las listas designe cual lista(s) y envía por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

**CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía <http://www14.tceq.texas.gov/epic/eComment/> o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087.** Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Distrito de Conservación de Trinity Bay a la dirección indicada arriba o llamando a Sr. Jerry Shadden al 409-658-3677.

Fecha de emission: 6 de enero de 2025

# Comisión De Calidad Ambiental Del Estado De Texas



## AVISO COMBINADO DE RECEPCIÓN DE SOLICITUD Y INTENCIÓN DE OBTENER PERMISO DE CALIDAD DEL AGUA (NORI)

Y

## AVISO DE LA SOLICITUD Y DECISIÓN PRELIMINAR PARA EL PERMISO DEL SISTEMA DE ELIMINACION DE DESCARGAS DE CONTAMINANTES DE TEXAS (TPDES) PARA AGUAS RESIDUALES MUNICIPALES

### RENOVACIÓN

#### PERMISO NO. WQ0010851001

**SOLICITUD Y DECISIÓN PRELIMINAR.** Distrito de conservación de Trinity Bay, P.O. Box 599, Stowell, Texas 77661 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) una renovación para autorizar la descarga de aguas residuales domésticas tratadas a un caudal medio anual que no exceda los 1,980,000 galones por día. La TCEQ recibió esta solicitud el 17 de Diciembre de 2024.

**Este aviso combinado se emite para corregir la dirección de la ubicación de las instalaciones que figuraba en el NORI.**

La planta está ubicada **760 East Buccaneer Drive, en Stowell, en el Condado de Chambers, Texas**. El efluente tratado es descargado al South Fork Mayhaw Bayou en el Segmento No. 0701 de la Cuenca del Costera de Naches-Trinity. Los usos no clasificados de las aguas receptoras son mínima usos de la vida acuática para South Fork Mayhaw Bayou. Los usos designados para el Segmento No. 0701 son recreación de contacto primario y uso intermedio de la vida acuática. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

El Director Ejecutivo de la TCEQ ha completado la revisión técnica de la solicitud y ha preparado un borrador del permiso. El borrador del permiso, si es aprobado, establecería las condiciones bajo las cuales la instalación debe operar. El Director Ejecutivo ha tomado una decisión preliminar que si este permiso es emitido, cumple con todos los requisitos normativos y legales. La solicitud del permiso, la decisión preliminar del Director Ejecutivo y el borrador del permiso están disponibles para leer y copiar en **Distrito de Conservación de Trinity Bay, 2500 State Highway 124, Stowell, Condado de Chambers, Texas**. La solicitud está disponible para su consulta y reproducción a través del siguiente enlace:

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

**AVISO DE IDIOMA ALTERNATIVO.** El aviso de idioma alternativo en español está disponible en <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

**COMENTARIO PUBLICO / REUNION PUBLICA.** Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud.

El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

**OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.**

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso.** Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

**PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS:** su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso para descargar aguas residuales sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

**ACCIÓN DEL DIRECTOR EJECUTIVO.** El Director Ejecutivo puede emitir una aprobación final de la solicitud a menos que exista un pedido antes del plazo de vencimiento de una audiencia administrativa de lo contencioso o se ha presentado un pedido de reconsideración. Si un pedido ha llegado antes del plazo de vencimiento de la audiencia o el pedido de reconsideración ha sido presentado, el Director Ejecutivo no emitirá una aprobación final sobre el permiso y enviará la solicitud y el pedido a los Comisionados de la TECQ para consideración en una reunión programada de la Comisión.

**LISTA DE CORREO.** Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agregue su nombre en una de las listas designe cual lista(s) y envía por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

**Todos los comentarios escritos del público y los pedidos una reunión deben ser presentados durante los 30 días después de la publicación del aviso a la Oficina del Secretario Principal, MC 105, TCEQ, P.O. Box 13087, Austin, TX 78711-3087 or por el internet a <https://www.tceq.texas.gov/goto/comment>.** Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia.

**INFORMACIÓN DISPONIBLE EN LÍNEA.** Para obtener detalles sobre el estado de la solicitud, visite la Base de Datos Integrada de los Comisionados en <https://www.tceq.texas.gov/goto/cid/>. Busque en la base de datos utilizando el número de permiso para esta solicitud, que se proporciona en la parte superior de este aviso.

**CONTACTOS E INFORMACIÓN DE LA AGENCIA.** Los comentarios y solicitudes públicas deben enviarse electrónicamente a <https://www.tceq.texas.gov/goto/comment>, o por escrito a Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Cualquier información personal que envíe a al TCEQ pasará a formar parte del registro de la agencia; esto incluye las direcciones de correo electrónico. Para obtener más información sobre esta solicitud de permiso o el proceso de permisos, llame al Programa de Educación Pública de la TCEQ, sin cargo, al 1-800-687-4040 o visite su sitio web en <https://www.tceq.texas.gov/agency/decisions/participation/permitting-participation>. Si desea información en español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Distrito de conservación de Trinity Bay a la dirección indicada arriba o llamando a Jerry Shadden al 409-658-3677.

Fecha de emisión 7 de noviembre de 2025

# Texas Commission on Environmental Quality



## COMBINED

### NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT (NORI)

### AND

### NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR MUNICIPAL WASTEWATER

### RENEWAL

### PERMIT NO. WQ0010851001

**APPLICATION AND PRELIMINARY DECISION.** Trinity Bay Conservation District, P.O. Box 599, Stowell, Texas 77661 has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010851001, which authorizes the discharge of treated domestic wastewater at an annual average flow not to exceed 1,980,000 gallons per day. TCEQ received this application on December 17, 2024.

**This combined notice is being issued to correct address of the facility location from what was stated in the NORI.**

The facility is located at **760 East Buccaneer Drive, in Stowell, Chambers County, Texas 77665**. The treated effluent is discharged to South Fork Mayhaw Bayou, thence to Mayhaw Bayou, thence to South Fork Taylor Bayou, thence to Taylor Bayou Above Tidal in Segment No. 0701 of the Neches-Trinity Coastal Basin. The unclassified receiving water use is minimal aquatic life use for South Fork Mayhaw Bayou. The designated uses for Segment No. 0701 are primary contact recreation and intermediate aquatic life use. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at **Trinity Bay Conservation District, 2500 State Highway 124, Stowell, Chambers County, Texas**. The application is available for viewing and copying, at the following webpage:

<https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

**ALTERNATIVE LANGUAGE NOTICE.** Alternative language notice in Spanish is available at <https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices>. El aviso de idioma alternativo en español está disponible en <https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices>.

**PUBLIC COMMENT / PUBLIC MEETING.** You may submit public comments or request a public meeting about this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ holds a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

**OPPORTUNITY FOR A CONTESTED CASE HEARING.** After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. **Unless the application is directly referred for a contested case hearing, the response to comments will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision.** A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

**TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.**

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. **If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period. TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.**

**EXECUTIVE DIRECTOR ACTION.** The Executive Director may issue final approval of the application unless a timely contested case hearing request or request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

**MAILING LIST.** If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

**All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, Texas Commission on Environmental Quality, P.O. Box 13087, Austin, TX 78711-3087 or electronically at [www.tceq.texas.gov/goto/comment](http://www.tceq.texas.gov/goto/comment) within 30 days from the date of newspaper publication of this notice.**

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at [www.tceq.texas.gov/goto/cid](http://www.tceq.texas.gov/goto/cid). Search the database using the permit number for this application, which is provided at the top of this notice.

**AGENCY CONTACTS AND INFORMATION.** Public comments and requests must be submitted either electronically at [www.tceq.texas.gov/goto/comment](http://www.tceq.texas.gov/goto/comment), or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC 105, P.O. Box 13087, Austin, Texas 78711-3087. Any personal information you submit to the TCEQ will become part of the agency's record; this includes email addresses. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at [www.tceq.texas.gov/goto/pep](http://www.tceq.texas.gov/goto/pep). Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Trinity Bay Conservation District at the address stated above or by calling Mr. Jerry Shadden, General Manager, at 409-658-3677.

Issuance Date: November 7, 2025



**PLUMMER**

1550-007-07

December 17, 2024

Texas Commission on Environmental Quality  
Water Quality Division  
Applications Review and Processing Team  
MC-148  
PO Box 13087  
Austin, TX 78711

RECEIVED  
DEC 17 2024  
TCEQ MAIL CENTER  
BC

Re: Trinity Bay Conservation District (CN600675417)  
Winnie-Stowell Wastewater Treatment Facility (RN102077393)  
Application for Renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No.  
WQ0010851001

To Whom It May Concern:

On behalf of Trinity Bay Conservation District, Plummer Associates, Inc. (Plummer) submits one original renewal application for the above-referenced permit. The application fee of \$2,015.00 for the Domestic Wastewater Permit Application has been submitted to the Texas Commission on Environmental Quality Cashier's Office (MC-214) under a separate cover.

Please feel free to contact me at [alewis@plummer.com](mailto:alewis@plummer.com) or (512) 687-2154, if you have any questions regarding this submittal.

Sincerely,

PLUMMER  
TBPE Firm Registration No. F-13

Ashley Lewis  
*Water Quality/Permitting Team Leader*

Enclosures: TPDES Permit Renewal Application (1 original)

cc: Jerry Shadden, General Manager, Trinity Bay Conservation District  
Joseph Mouton, Chief Operator, Trinity Bay Conservation District



**TRINITY BAY CONSERVATION DISTRICT**

**WINNIE-STOWELL WASTEWATER  
TREATMENT FACILITY**

**TPDES PERMIT RENEWAL APPLICATION  
PERMIT NO. WQ0010851001**

**SUBMITTED TO:  
TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**



**December 2024**

PROJECT #: 1550-007-07

**PLUMMER**

**TRINITY BAY CONSERVATION DISTRICT  
WINNIE-STOWELL WASTEWATER TREATMENT FACILITY  
TPDES PERMIT RENEWAL APPLICATION**

**TABLE OF CONTENTS**

**I. ADMINISTRATIVE REPORT**

Domestic Administrative Report 1.0  
Supplemental Permit Information Form (SPIF)

**II. TECHNICAL REPORT**

Domestic Technical Report 1.0  
Domestic Worksheet 2.0  
Domestic Worksheet 4.0  
Domestic Worksheet 5.0  
Domestic Worksheet 6.0

**III. ATTACHMENTS**

<u>No.</u>	<u>Description</u>	<u>Reference</u>
A	Core Data Form	Admin Rpt 1.0, Section 3.C
B	Plain Language Summary	Admin Rpt 1.0, Section 8.F
C	USGS Map	Admin Rpt 1.0, Section 13
D	Supplemental Permit Information Form	SPIF
E	Process Flow Diagram	Tech Rpt 1.0, Section 2.C
F	Site Drawing	Tech Rpt 1.0, Section 3
G	Pollutant Analysis of Treated Effluent	Tech Rpt 1.0, Section 7; Wks 4.0 Section 1 & 2
H	List of Facility Operators	Tech Rpt 1.0, Section 8
I	Summary of WET Test Results	Wks 5.0 Section 3



# DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

**Complete and submit this checklist with the application.**

APPLICANT NAME: Trinity Bay Conservation District

PERMIT NUMBER (If new, leave blank): WQ00 10851001

**Indicate if each of the following items is included in your application.**

	Y	N		Y	N
Administrative Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Original USGS Map	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Administrative Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Affected Landowners Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
SPIF	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Landowner Disk or Labels	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Core Data Form	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Buffer Zone Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Public Involvement Plan Form	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Flow Diagram	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site Drawing	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Original Photographs	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Design Calculations	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Solids Management Plan	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Water Balance	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.3	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 4.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
Worksheet 5.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
Worksheet 6.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
Worksheet 7.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			

**For TCEQ Use Only**

Segment Number \_\_\_\_\_ County \_\_\_\_\_  
 Expiration Date \_\_\_\_\_ Region \_\_\_\_\_  
 Permit Number \_\_\_\_\_



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

## DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

### Section 1. Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
<0.05 MGD	\$350.00 <input type="checkbox"/>	\$315.00 <input type="checkbox"/>
≥0.05 but <0.10 MGD	\$550.00 <input type="checkbox"/>	\$515.00 <input type="checkbox"/>
≥0.10 but <0.25 MGD	\$850.00 <input type="checkbox"/>	\$815.00 <input type="checkbox"/>
≥0.25 but <0.50 MGD	\$1,250.00 <input type="checkbox"/>	\$1,215.00 <input type="checkbox"/>
≥0.50 but <1.0 MGD	\$1,650.00 <input type="checkbox"/>	\$1,615.00 <input type="checkbox"/>
≥1.0 MGD	\$2,050.00 <input type="checkbox"/>	\$2,015.00 <input checked="" type="checkbox"/>

Minor Amendment (for any flow) \$150.00

**Payment Information:**

Mailed      Check/Money Order Number: 21688  
 Check/Money Order Amount: \$2,015.00  
 Name Printed on Check: Trinity Bay Conservation District

EPAY      Voucher Number: N/A

Copy of Payment Voucher enclosed?      Yes     N/A

### Section 2. Type of Application (Instructions Page 26)

a. Check the box next to the appropriate authorization type.

- Publicly-Owned Domestic Wastewater
- Privately-Owned Domestic Wastewater
- Conventional Wastewater Treatment

b. Check the box next to the appropriate facility status.

- Active       Inactive

c. Check the box next to the appropriate permit type.

- TPDES Permit
- TLAP
- TPDES Permit with TLAP component
- Subsurface Area Drip Dispersal System (SADDS)

d. Check the box next to the appropriate application type

- New
- Major Amendment *with* Renewal
- Major Amendment *without* Renewal
- Renewal without changes
- Minor Amendment *with* Renewal
- Minor Amendment *without* Renewal
- Minor Modification of permit

e. For amendments or modifications, describe the proposed changes: N/A

f. For existing permits:

Permit Number: WQ00 10851001

EPA I.D. (TPDES only): TX 0020460

Expiration Date: July 2, 2025

### Section 3. Facility Owner (Applicant) and Co-Applciant Information (Instructions Page 26)

A. The owner of the facility must apply for the permit.

What is the Legal Name of the entity (applicant) applying for this permit?

Trinity Bay Conservation District

*(The legal name must be spelled exactly as filed with the Texas Secretary of State, County, or in the legal documents forming the entity.)*

If the applicant is currently a customer with the TCEQ, what is the Customer Number (CN)?  
You may search for your CN on the TCEQ website at <http://www15.tceq.texas.gov/crpub/>

CN: 600675417

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: Mr.

Last Name, First Name: Shadden, Jerry

Title: General Manager

Credential: N/A

B. Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

N/A

*(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the legal documents forming the entity.)*

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: <http://www15.tceq.texas.gov/crpub/>

CN: N/A

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: N/A

Last Name, First Name: N/A

Title: N/A

Credential: N/A

Provide a brief description of the need for a co-permittee: N/A

### C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. A

## Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Mr. Last Name, First Name: Mouton, Joey  
Title: Water Superintendent Credential: N/A  
Organization Name: Trinity Bay Conservation District  
Mailing Address: P.O. Box 599 City, State, Zip Code: Stowell, TX 77661  
Phone No.: (409) 296-3602 E-mail Address: joey@tbcd.org  
Check one or both:  Administrative Contact  Technical Contact

B. Prefix: Ms. Last Name, First Name: Lewis, Ashley  
Title: Water Quality/Permitting Team Leader Credential: N/A  
Organization Name: Plummer Associates, Inc.  
Mailing Address: 8911 N Capital of TX Hwy, Bldg 1 – Ste 1250 City, State, Zip Code: Austin, TX 78759  
Phone No.: (512)452 5905 E-mail Address: alewis@plummer.com  
Check one or both:  Administrative Contact  Technical Contact

## Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Mr. Last Name, First Name: Shadden, Jerry  
Title: General Manager Credential: N/A  
Organization Name: Trinity Bay Conservation District  
Mailing Address: P.O. Box 599 City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 658-3677

E-mail Address: jerry@tbcd.org

B. Prefix: Mr.

Last Name, First Name: Mouton, Joey

Title: Water Superintendent

Credential: N/A

Organization Name: Trinity Bay Conservation District

Mailing Address: P.O. Box 599

City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 296-3602

E-mail Address: joey@tbcd.org

## Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Mr.

Last Name, First Name: Shadden, Jerry

Title: General Manager

Credential: N/A

Organization Name: Trinity Bay Conservation District

Mailing Address: P.O. Box 599

City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 658-3677

E-mail Address: jerry@tbcd.org

## Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Mr.

Last Name, First Name: Shadden, Jerry

Title: General Manager

Credential: N/A

Organization Name: Trinity Bay Conservation District

Mailing Address: P.O. Box 599

City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 658-3677

E-mail Address: jerry@tbcd.org

## Section 8. Public Notice Information (Instructions Page 27)

### A. Individual Publishing the Notices

Prefix: Mr.

Last Name, First Name: Shadden, Jerry

Title: General Manager

Credential: N/A

Organization Name: Trinity Bay Conservation District

Mailing Address: P.O. Box 599

City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 658-3677

E-mail Address: jerry@tbcd.org

**B. Method for Receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package**

Indicate by a check mark the preferred method for receiving the first notice and instructions:

E-mail Address

Fax

Regular Mail

**C. Contact permit to be listed in the Notices**

Prefix: Mr. Last Name, First Name: Shadden, Jerry

Title: General Manager Credential: N/A

Organization Name: Trinity Bay Conservation District

Mailing Address: P.O. Box 599 City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 658-3677 E-mail Address: jerry@tbcd.org

**D. Public Viewing Information**

*If the facility or outfall is located in more than one county, a public viewing place for each county must be provided.*

Public building name: Trinity Bay Conservation District

Location within the building: Front Desk

Physical Address of Building: 2500 State Highway 124

City: Stowell County: Chambers

Contact (Last Name, First Name): Shadden, Jerry

Phone No.: (409) 658-3677 Ext.: N/A

**E. Bilingual Notice Requirements**

This information **is required** for **new, major amendment, minor amendment or minor modification, and renewal** applications.

This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.

Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.

1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?

Yes  No

If **no**, publication of an alternative language notice is not required; **skip to** Section 9 below.

2. Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?

Yes  No

3. Do the students at these schools attend a bilingual education program at another location?

Yes  No

4. Would the school be required to provide a bilingual education program but the school has waived out of this requirement under 19 TAC §89.1205(g)?

Yes  No

5. If the answer is **yes** to **question 1, 2, 3, or 4**, public notices in an alternative language are required. Which language is required by the bilingual program? Spanish

#### F. Plain Language Summary Template

Complete the Plain Language Summary (TCEQ Form 20972) and include as an attachment.

Attachment: B

#### G. Public Involvement Plan Form

Complete the Public Involvement Plan Form (TCEQ Form 20960) for each application for a **new permit or major amendment to a permit** and include as an attachment.

Attachment: N/A

## Section 9. Regulated Entity and Permitted Site Information (Instructions Page 29)

A. If the site is currently regulated by TCEQ, provide the Regulated Entity Number (RN) issued to this site. RN 102077393

Search the TCEQ's Central Registry at <http://www15.tceq.texas.gov/crpub/> to determine if the site is currently regulated by TCEQ.

B. Name of project or site (the name known by the community where located):

Winnie-Stowell Wastewater Treatment Facility

C. Owner of treatment facility: Trinity Bay Conservation District

Ownership of Facility:  Public  Private  Both  Federal

D. Owner of land where treatment facility is or will be:

Prefix: N/A

Last Name, First Name: N/A

Title: N/A

Credential: N/A

Organization Name: Trinity Bay Conservation District

Mailing Address: P.O. Box 599

City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 781-4016

E-mail Address: jerry@tbcd.org

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: N/A

E. Owner of effluent disposal site:

Prefix: N/A

Last Name, First Name: N/A

Title: N/A

Credential: N/A

Organization Name: N/A

Mailing Address: N/A

City, State, Zip Code: N/A

Phone No.: N/A

E-mail Address: N/A

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

**Attachment:** N/A

F. Owner sewage sludge disposal site (if authorization is requested for sludge disposal on property owned or controlled by the applicant):

Prefix: N/A

Last Name, First Name: N/A

Title: N/A

Credential: N/A

Organization Name: N/A

Mailing Address: N/A

City, State, Zip Code: N/A

Phone No.: N/A

E-mail Address: N/A

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

**Attachment:** N/A

**Section 10. TPDES Discharge Information (Instructions Page 31)**

A. Is the wastewater treatment facility location in the existing permit accurate?

Yes  No

If **no**, or a new permit application, please give an accurate description:

N/A

B. Are the point(s) of discharge and the discharge route(s) in the existing permit correct?

Yes  No

If **no**, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307:

N/A

City nearest the outfall(s): Winnie, TX

County in which the outfalls(s) is/are located: Chambers

C. Is or will the treated wastewater discharge to a city, county, or state highway right-of-way, or a flood control district drainage ditch?

Yes  No

If **yes**, indicate by a check mark if:

- Authorization granted       Authorization pending

For **new and amendment** applications, provide copies of letters that show proof of contact and the approval letter upon receipt.

**Attachment:** N/A

- D. For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: N/A

## Section 11. TLAP Disposal Information (Instructions Page 32)

- A. For TLAPs, is the location of the effluent disposal site in the existing permit accurate?

- Yes       No      N/A

If **no, or a new or amendment permit application**, provide an accurate description of the disposal site location:

N/A

- B. City nearest the disposal site: N/A

- C. County in which the disposal site is located: N/A

- D. For TLAPs, describe the routing of effluent from the treatment facility to the disposal site:

N/A

- E. For TLAPs, please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: N/A

## Section 12. Miscellaneous Information (Instructions Page 32)

- A. Is the facility located on or does the treated effluent cross American Indian Land?

- Yes       No

- B. If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?

- Yes       No       Not Applicable

If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.

N/A

C. Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?

Yes     No

If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application: Alex Garoutte, Plummer Associates, Inc.

D. Do you owe any fees to the TCEQ?

Yes     No

If **yes**, provide the following information:

Account number: N/A

Amount past due: N/A

E. Do you owe any penalties to the TCEQ?

Yes     No

If **yes**, please provide the following information:

Enforcement order number: N/A

Amount past due: N/A

### Section 13. Attachments (Instructions Page 33)

Indicate which attachments are included with the Administrative Report. Check all that apply:

- Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.
- Original full-size USGS Topographic Map with the following information: See Attachment C
  - Applicant's property boundary
  - Treatment facility boundary
  - Labeled point of discharge for each discharge point (TPDES only)
  - Highlighted discharge route for each discharge point (TPDES only)
  - Onsite sewage sludge disposal site (if applicable)
  - Effluent disposal site boundaries (TLAP only)
  - New and future construction (if applicable)
  - 1 mile radius information
  - 3 miles downstream information (TPDES only)
  - All ponds.
- Attachment 1 for Individuals as co-applicants
- Other Attachments. Please specify: See Table of Contents

**Section 14. Signature Page (Instructions Page 34)**

*If co-applicants are necessary, each entity must submit an original, separate signature page.*

Permit Number: WQ0010851001

Applicant: Trinity Bay Conservation District


Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.


Signatory name (typed or printed): Jerry Shadden

Signatory title: General Manager

Signature:  Date: 12-10-2024  
(Use blue ink)

Subscribed and Sworn to before me by the said Jerry Shadden  
on this 10th day of December, 20 24.  
My commission expires on the 3rd day of September, 20 27.

  
Notary Public



[SEAL]

Chambers  
County, Texas

**DOMESTIC WASTEWATER PERMIT APPLICATION**  
**SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)**

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

**Attachment:** D



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

**DOMESTIC WASTEWATER PERMIT APPLICATION  
TECHNICAL REPORT 1.0**

---

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

**Section 1. Permitted or Proposed Flows (Instructions Page 43)**

**A. Existing/Interim I Phase**

Design Flow (MGD): 1.98

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

**B. Interim II Phase**

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

**C. Final Phase**

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

**D. Current Operating Phase**

Provide the startup date of the facility: 4/29/2002

**Section 2. Treatment Process (Instructions Page 43)**

**A. Current Operating Phase**

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. **If more than one phase exists or is proposed, a description of *each phase* must be provided.**

The Winnie-Stowell WWTF is a lagoon/wetland system with two trains of wetland cells following a facultative lagoon. Each wetland train has a series of four cells, for a total of eight wetland cells. The wetland cells are a free water surface type. Treatment units include a lift station, a bar screen, a facultative lagoon, two wetland trains followed by chlorination and dechlorination units, then a post aeration structure.

## B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for ***all*** phases of operation.

**Table 1.0(1) - Treatment Units**

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Facultative Lagoon	1	13.5 acres, 9' deep (avg)
Wetland Cells	8	10 acres, 2' deep (avg) each
Post Aeration/Flow Measurement	1	8' x 5' x 2'
Chlorination Basin	4	6' x 72' x 4.44' each
Dechlorination Basin	1	6' x 32.5 x 4.23

## C. Process Flow Diagram

Provide flow diagrams for the existing facilities and **each** proposed phase of construction.

**Attachment: E**

## Section 3. Site Information and Drawing (Instructions Page 44)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

- Latitude: 29.802765
- Longitude: -94.362178

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

- Latitude: N/A
- Longitude: N/A

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

**Attachment: F**

Provide the name **and** a description of the area served by the treatment facility.

The Winnie-Stowell Wastewater Treatment Facility serves the Cities of Winnie and Stowell, TX.

Collection System Information for wastewater TPDES permits only: Provide information for each **uniquely owned** collection system, existing and new, served by this facility, including satellite collection systems. Please see the instructions for a detailed explanation and examples.

**Collection System Information**

Collection System Name	Owner Name	Owner Type	Population Served
City of Winnie	City of Winnie	Publicly Owned	3,162
City of Stowell	City of Stowell	Publicly Owned	1,743

**Section 4. Unbuilt Phases (Instructions Page 45)**

Is the application for a renewal of a permit that contains an unbuilt phase or phases?

Yes  No

If yes, does the existing permit contain a phase that has not been constructed **within five years** of being authorized by the TCEQ?

Yes  No N/A

If yes, provide a detailed discussion regarding the continued need for the unbuilt phase. **Failure to provide sufficient justification may result in the Executive Director recommending denial of the unbuilt phase or phases.**

N/A

**Section 5. Closure Plans (Instructions Page 45)**

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

Yes  No

If **yes**, was a closure plan submitted to the TCEQ?

Yes  No N/A

If **yes**, provide a brief description of the closure and the date of plan approval.

N/A

**Section 6. Permit Specific Requirements (Instructions Page 45)**

**For applicants with an existing permit, check the Other Requirements or Special Provisions of the permit.**

**A. Summary transmittal**

Have plans and specifications been approved for the existing facilities and each proposed phase?

Yes  No

If **yes**, provide the date(s) of approval for each phase: 6/12/2003; 10/14/2004; 4/24/2012

Provide information, including dates, on any actions taken to meet a *requirement or provision* pertaining to the submission of a summary transmittal letter. **Provide a copy of an approval letter from the TCEQ, if applicable.**

N/A

**B. Buffer zones**

Have the buffer zone requirements been met?

Yes  No

Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.

N/A

**C. Other actions required by the current permit**

Does the *Other Requirements* or *Special Provisions* section in the existing permit require submission of any other information or other required actions? Examples include Notification of Completion, progress reports, soil monitoring data, etc.

Yes  No

**If yes**, provide information below on the status of any actions taken to meet the conditions of an *Other Requirement* or *Special Provision*.

In accordance with Other Requirement No. 8, the sludge accumulation and water depth in the facultative lagoon was measured during the permit term. The measurement data did not indicate that the sludge accumulation had impacted design volume. Sludge removal has not occurred.

#### D. Grit and grease treatment

##### 1. *Acceptance of grit and grease waste*

Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?

Yes  No

**If No**, stop here and continue with Subsection E. Stormwater Management.

##### 2. *Grit and grease processing*

Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.

N/A

##### 3. *Grit disposal*

Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?

Yes  No N/A

**If No**, contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

Describe the method of grit disposal.

N/A

**4. Grease and decanted liquid disposal**

Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.

Describe how the decant and grease are treated and disposed of after grit separation.

N/A

**E. Stormwater management**

**1. Applicability**

Does the facility have a design flow of 1.0 MGD or greater in any phase?

Yes  No

Does the facility have an approved pretreatment program, under 40 CFR Part 403?

Yes  No

**If no to both of the above, then skip to Subsection F, Other Wastes Received.**

**2. MSGP coverage**

Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?

Yes  No

**If yes, please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:**

TXR05 N/A or TXRNE N/A

**If no, do you intend to seek coverage under TXR050000?**

Yes  No

**3. Conditional exclusion**

Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?

Yes  No

**If yes, please explain below then proceed to Subsection F, Other Wastes Received:**

N/A

**4. Existing coverage in individual permit**

Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?

Yes  No

If yes, provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.

N/A

**5. Zero stormwater discharge**

Do you intend to have no discharge of stormwater via use of evaporation or other means?

Yes  No

If yes, explain below then skip to Subsection F. Other Wastes Received.

N/A

Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.

**6. Request for coverage in individual permit**

Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?

Yes  No

If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you intend to divert stormwater to the treatment plant headworks and indirectly discharge it to water in the state.

N/A

Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.

**F. Discharges to the Lake Houston Watershed**

Does the facility discharge in the Lake Houston watershed?

Yes  No

If yes, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions.  
N/A

**G. Other wastes received including sludge from other WWTPs and septic waste**

**1. Acceptance of sludge from other WWTPs**

Does or will the facility accept sludge from other treatment plants at the facility site?

Yes  No

**If yes, attach sewage sludge solids management plan. See Example 5 of the instructions.**

In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an estimate of the BOD<sub>5</sub> concentration of the sludge, and the design BOD<sub>5</sub> concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

N/A

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

**2. Acceptance of septic waste**

Is the facility accepting or will it accept septic waste?

Yes  No

**If yes, does the facility have a Type V processing unit?**

Yes  No N/A

**If yes, does the unit have a Municipal Solid Waste permit?**

Yes  No N/A

If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD<sub>5</sub> concentration of the septic waste, and the design BOD<sub>5</sub> concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

N/A

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

**3. Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)**

Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?

Yes  No

If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.

N/A

**Section 7. Pollutant Analysis of Treated Effluent (Instructions Page 50)**

Is the facility in operation?

Yes  No [See Attachment G](#)

If no, this section is not applicable. Proceed to Section 8.

If yes, provide effluent analysis data for the listed pollutants. **Wastewater treatment facilities** complete Table 1.0(2). **Water treatment facilities** discharging filter backwash water, complete Table 1.0(3). Provide copies of the laboratory results sheets. **These tables are not applicable for a minor amendment without renewal.** See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

**Table 1.0(2) – Pollutant Analysis for Wastewater Treatment Facilities**

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD <sub>5</sub> , mg/l	2.4	2.4	1	Grab	11/1/2024; 11:20
Total Suspended Solids, mg/l	1.5	1.5	1	Grab	11/1/2024; 11:20
Ammonia Nitrogen, mg/l	3.3	3.3	1	Grab	11/1/2024; 11:20
Nitrate Nitrogen, mg/l	0.06	0.06	1	Grab	11/1/2024; 11:20

Total Kjeldahl Nitrogen, mg/l	4.3	4.3	1	Grab	11/1/2024; 11:20
Sulfate, mg/l	29.0	29.0	1	Grab	11/1/2024; 11:20
Chloride, mg/l	42.3	42.3	1	Grab	11/1/2024; 11:20
Total Phosphorus, mg/l	2.64	2.64	1	Grab	11/1/2024; 11:20
pH, standard units	7.6	7.6	1	Grab	11/1/2024; 11:20
Dissolved Oxygen*, mg/l	7.2	7.2	1	Grab	11/1/2024; 11:20
Chlorine Residual, mg/l	<0.1	<0.1	1	Grab	11/1/2024; 11:20
<i>E.coli</i> (CFU/100ml) freshwater	1	1	1	Grab	11/1/2024; 11:20
Enterococci (CFU/100ml) saltwater	N/A		1	Grab	11/1/2024; 11:20
Total Dissolved Solids, mg/l	238	238	1	Grab	11/1/2024; 11:20
Electrical Conductivity, $\mu$ mohs/cm, †	N/A		1	Grab	11/1/2024; 11:20
Oil & Grease, mg/l	<5.0	<5.0	1	Grab	11/1/2024; 11:20
Alkalinity (CaCO <sub>3</sub> )*, mg/l	110	110	1	Grab	11/1/2024; 11:20

\*TPDES permits only

†TLAP permits only

**Table 1.0(3) – Pollutant Analysis for Water Treatment Facilities**

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l	N/A				
Total Dissolved Solids, mg/l	N/A				
pH, standard units	N/A				
Fluoride, mg/l	N/A				
Aluminum, mg/l	N/A				
Alkalinity (CaCO <sub>3</sub> ), mg/l	N/A				

## Section 8. Facility Operator (Instructions Page 50)

Facility Operator Name: [See Attachment H](#)

Facility Operator's License Classification and Level: [See Attachment H](#)

Facility Operator's License Number: [See Attachment H](#)

## Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 51)

### A. WWTP's Biosolids Management Facility Type

Check all that apply. See instructions for guidance

Design flow  $\geq$  1 MGD

- Serves  $\geq 10,000$  people
- Class I Sludge Management Facility (per 40 CFR § 503.9)
- Biosolids generator
- Biosolids end user - land application (onsite)
- Biosolids end user - surface disposal (onsite)
- Biosolids end user - incinerator (onsite)

## B. WWTP's Biosolids Treatment Process

Check all that apply. See instructions for guidance.

- Aerobic Digestion
- Air Drying (or sludge drying beds)
- Lower Temperature Composting
- Lime Stabilization
- Higher Temperature Composting
- Heat Drying
- Thermophilic Aerobic Digestion
- Beta Ray Irradiation
- Gamma Ray Irradiation
- Pasteurization
- Preliminary Operation (e.g. grinding, de-gritting, blending)
- Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)
- Sludge Lagoon
- Temporary Storage ( $< 2$  years)
- Long Term Storage ( $\geq 2$  years)
- Methane or Biogas Recovery
- Other Treatment Process:

## C. Biosolids Management

Provide information on the *intended* biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the permit will authorize all biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

**Biosolids Management**

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Storage	On-Site Owner or Operator	Not Applicable	Not Applicable	Not Applicable	Not Applicable

If “Other” is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): Sludge accumulates in the facultative lagoon. Disposal is not expected for another 20 years or more, will be performed according to applicable regulations.

**D. Disposal site**

Disposal site name: N/A

TCEQ permit or registration number: N/A

County where disposal site is located: N/A

**E. Transportation method**

Method of transportation (truck, train, pipe, other): N/A

Name of the hauler: N/A

Hauler registration number: N/A

Sludge is transported as a:

Liquid     semi-liquid     semi-solid     solid

**Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 53)**

**A. Beneficial use authorization**

Does the existing permit include authorization for land application of sewage sludge for beneficial use?

Yes     No

If yes, are you requesting to continue this authorization to land apply sewage sludge for beneficial use?

Yes     No    N/A

If yes, is the completed **Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451)** attached to this permit application (see the instructions for details)?

Yes     No    N/A

**B. Sludge processing authorization**

Does the existing permit include authorization for any of the following sludge processing, storage or disposal options?

- Sludge Composting  Yes  No
- Marketing and Distribution of sludge  Yes  No
- Sludge Surface Disposal or Sludge Monofill  Yes  No
- Temporary storage in sludge lagoons  Yes  No

If **yes** to any of the above sludge options and the applicant is requesting to continue this authorization, is the completed **Domestic Wastewater Permit Application: Sewage Sludge Technical Report (TCEQ Form No. 10056)** attached to this permit application?

- Yes  No N/A

**Section 11. Sewage Sludge Lagoons (Instructions Page 53)**

Does this facility include sewage sludge lagoons?

- Yes  No

If yes, complete the remainder of this section. If no, proceed to Section 12.

**A. Location information**

The following maps are required to be submitted as part of the application. For each map, provide the Attachment Number.

- Original General Highway (County) Map:  
**Attachment:** N/A
- USDA Natural Resources Conservation Service Soil Map:  
**Attachment:** N/A
- Federal Emergency Management Map:  
**Attachment:** N/A
- Site map:  
**Attachment:** N/A

Discuss in a description if any of the following exist within the lagoon area. Check all that apply.

- Overlap a designated 100-year frequency flood plain
- Soils with flooding classification
- Overlap an unstable area
- Wetlands
- Located less than 60 meters from a fault
- None of the above

**Attachment:** N/A

If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide the protective measures to be utilized including type and size of protective structures:

<u>N/A</u>
------------

**B. Temporary storage information**

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in *Section 7 of Technical Report 1.0*.

Nitrate Nitrogen, mg/kg: N/A

Total Kjeldahl Nitrogen, mg/kg: N/A

Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: N/A

Phosphorus, mg/kg: N/A

Potassium, mg/kg: N/A

pH, standard units: N/A

Ammonia Nitrogen mg/kg: N/A

Arsenic: N/A

Cadmium: N/A

Chromium: N/A

Copper: N/A

Lead: N/A

Mercury: N/A

Molybdenum: N/A

Nickel: N/A

Selenium: N/A

Zinc: N/A

Total PCBs: N/A

Provide the following information:

Volume and frequency of sludge to the lagoon(s): N/A

Total dry tons stored in the lagoons(s) per 365-day period: N/A

Total dry tons stored in the lagoons(s) over the life of the unit: N/A

**C. Liner information**

Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of  $1 \times 10^{-7}$  cm/sec?

Yes  No N/A

If yes, describe the liner below. Please note that a liner is required.

N/A

**D. Site development plan**

Provide a detailed description of the methods used to deposit sludge in the lagoon(s):

N/A

Attach the following documents to the application.

- Plan view and cross-section of the sludge lagoon(s)  
**Attachment:** N/A
- Copy of the closure plan  
**Attachment:** N/A
- Copy of deed recordation for the site  
**Attachment:** N/A
- Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons  
**Attachment:** N/A
- Description of the method of controlling infiltration of groundwater and surface water from entering the site  
**Attachment:** N/A
- Procedures to prevent the occurrence of nuisance conditions  
**Attachment:** N/A

**E. Groundwater monitoring**

Is groundwater monitoring currently conducted at this site, or are any wells available for groundwater monitoring, or are groundwater monitoring data otherwise available for the sludge lagoon(s)?

Yes  No N/A

If groundwater monitoring data are available, provide a copy. Provide a profile of soil types encountered down to the groundwater table and the depth to the shallowest groundwater as a separate attachment.

**Attachment:** N/A

**Section 12. Authorizations/Compliance/Enforcement (Instructions**

**A. Additional authorizations**

Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?

- Yes  No

If yes, provide the TCEQ authorization number and description of the authorization:

N/A

**B. Permittee enforcement status**

Is the permittee currently under enforcement for this facility?

- Yes  No

Is the permittee required to meet an implementation schedule for compliance or enforcement?

- Yes  No

If yes to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:

N/A

**Section 13. RCRA/CERCLA Wastes (Instructions Page 55)**

**A. RCRA hazardous wastes**

Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

- Yes  No

**B. Remediation activity wastewater**

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

Yes  No

**C. Details about wastes received**

**If yes** to either Subsection A or B above, provide detailed information concerning these wastes with the application.

**Attachment:** N/A

## Section 14. Laboratory Accreditation (Instructions Page 56)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
  - periodically inspected by the TCEQ; or
  - located in another state and is accredited or inspected by that state; or
  - performing work for another company with a unit located in the same site; or
  - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

### CERTIFICATION:


I certify that all laboratory tests submitted with this application meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*.

Printed Name: Jerry Shadden

Title: General Manager

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

  
12-10-2024

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

## Section 1. Domestic Drinking Water Supply (Instructions Page 64)

Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?

Yes  No

If **no**, proceed to Section 2. If **yes**, provide the following:

Owner of the drinking water supply: N/A

Distance and direction to the intake: N/A

Attach a USGS map that identifies the location of the intake.

Attachment: N/A

## Section 2. Discharge into Tidally Affected Waters (Instructions Page 64)

Does the facility discharge into tidally affected waters?

Yes  No

If **no**, proceed to Section 3. If **yes**, complete the remainder of this section. If no, proceed to Section 3.

### A. Receiving water outfall

Width of the receiving water at the outfall, in feet: N/A

### B. Oyster waters

Are there oyster waters in the vicinity of the discharge?

Yes  No N/A

If **yes**, provide the distance and direction from outfall(s).

N/A

### C. Sea grasses

Are there any sea grasses within the vicinity of the point of discharge?

Yes  No N/A

If **yes**, provide the distance and direction from the outfall(s).

N/A

### Section 3. Classified Segments (Instructions Page 64)

Is the discharge directly into (or within 300 feet of) a classified segment?

- Yes  No

If **yes**, this Worksheet is complete.

If **no**, complete Sections 4 and 5 of this Worksheet.

### Section 4. Description of Immediate Receiving Waters (Instructions Page 65)

Name of the immediate receiving waters: South Fork Mayhaw Bayou

#### A. Receiving water type

Identify the appropriate description of the receiving waters.

- Stream  
 Freshwater Swamp or Marsh  
 Lake or Pond

Surface area, in acres:

Average depth of the entire water body, in feet:

Average depth of water body within a 500-foot radius of discharge point, in feet:

- Man-made Channel or Ditch  
 Open Bay  
 Tidal Stream, Bayou, or Marsh  
 Other, specify:

#### B. Flow characteristics

If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area *upstream* of the discharge. For new discharges, characterize the area *downstream* of the discharge (check one).

- Intermittent - dry for at least one week during most years  
 Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses  
 Perennial - normally flowing

Check the method used to characterize the area upstream (or downstream for new dischargers).

- USGS flow records  
 Historical observation by adjacent landowners  
 Personal observation  
 Other, specify:

**C. Downstream perennial confluences**

List the names of all perennial streams that join the receiving water within three miles downstream of the discharge point.

None

**D. Downstream characteristics**

Do the receiving water characteristics change within three miles downstream of the discharge (e.g., natural or man-made dams, ponds, reservoirs, etc.)?

- Yes  No

If yes, discuss how.

N/A

**E. Normal dry weather characteristics**

Provide general observations of the water body during normal dry weather conditions.

Receiving waters upstream are clear.

Date and time of observation: 9/11/2024; 3:00 P.M.

Was the water body influenced by stormwater runoff during observations?

- Yes  No

**Section 5. General Characteristics of the Waterbody (Instructions Page 66)**

**A. Upstream influences**

Is the immediate receiving water upstream of the discharge or proposed discharge site influenced by any of the following? Check all that apply.

- |   |   |
|---|---|
| <input type="checkbox"/> Oil field activities | <input checked="" type="checkbox"/> Urban runoff        |
| <input type="checkbox"/> Upstream discharges  | <input checked="" type="checkbox"/> Agricultural runoff |
| <input type="checkbox"/> Septic tanks         | <input type="checkbox"/> Other(s), specify:             |

## B. Waterbody uses

Observed or evidences of the following uses. Check all that apply.

- |  |   |
|--|---|
| <input type="checkbox"/> Livestock watering    | <input type="checkbox"/> Contact recreation                                       |
| <input type="checkbox"/> Irrigation withdrawal | <input type="checkbox"/> Non-contact recreation                                   |
| <input type="checkbox"/> Fishing               | <input type="checkbox"/> Navigation   |
| <input type="checkbox"/> Domestic water supply | <input type="checkbox"/> Industrial water supply                                  |
| <input type="checkbox"/> Park activities       | <input checked="" type="checkbox"/> Other(s), specify: <u>Stormwater Drainage</u> |

## C. Waterbody aesthetics

Check one of the following that best describes the aesthetics of the receiving water and the surrounding area.

- Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional
- Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored
- Common Setting: not offensive; developed but uncluttered; water may be colored or turbid
- Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 4.0: POLLUTANT ANALYSIS REQUIREMENTS

The following **is required** for facilities with a permitted or proposed flow of **1.0 MGD or greater**, facilities with an approved **pretreatment** program, or facilities classified as a **major** facility. See instructions for further details.

This worksheet is not required minor amendments without renewal.

## Section 1. Toxic Pollutants (Instructions Page 78)

For pollutants identified in Table 4.0(1), indicate the type of sample.

Grab  Composite

Date and time sample(s) collected: See Attachment G

**Table 4.0(1) – Toxics Analysis**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrylonitrile	<50	<50	1	50
Aldrin	<0.01	<0.01	1	0.01
Aluminum	37.6	37.6	1	2.5
Anthracene	<10	<10	1	10
Antimony	<5	<5	1	5
Arsenic	1.34	1.34	1	0.5
Barium	85.4	85.4	1	3
Benzene	<10	<10	1	10
Benzidine	<50	<50	1	50
Benzo(a)anthracene	<5	<5	1	5
Benzo(a)pyrene	<5	<5	1	5
Bis(2-chloroethyl)ether	<10	<10	1	10
Bis(2-ethylhexyl)phthalate	<10	<10	1	10
Bromodichloromethane	<10	<10	1	10
Bromoform	<10	<10	1	10
Cadmium	<1	<1	1	1
Carbon Tetrachloride	<2	<2	1	2
Carbaryl	<5	<5	1	5
Chlordane*	<0.2	<0.2	1	0.2
Chlorobenzene	<10	<10	1	10
Chlorodibromomethane	<10	<10	1	10

<b>Pollutant</b>	<b>AVG Effluent Conc. (µg/l)</b>	<b>MAX Effluent Conc. (µg/l)</b>	<b>Number of Samples</b>	<b>MAL (µg/l)</b>
Chloroform	<10	<10	1	10
Chlorpyrifos	<0.05	<0.05	1	0.05
Chromium (Total)	<3	<3	1	3
Chromium (Tri) (*1)	<3	<3	1	N/A
Chromium (Hex)	<3	<3	1	3
Copper	<2	<2	1	2
Chrysene	<5	<5	1	5
p-Chloro-m-Cresol	<10	<10	1	10
4,6-Dinitro-o-Cresol	<50	<50	1	50
p-Cresol	<10	<10	1	10
Cyanide (*2)	<10	<10	1	10
4,4'- DDD	<0.1	<0.1	1	0.1
4,4'- DDE	<0.1	<0.1	1	0.1
4,4'- DDT	<0.02	<0.02	1	0.02
2,4-D	<0.7	<0.7	1	0.7
Demeton (O and S)	<0.2	<0.2	1	0.20
Diazinon	<0.1	<0.1	1	0.5/0.1
1,2-Dibromoethane	<10	<10	1	10
m-Dichlorobenzene	<10	<10	1	10
o-Dichlorobenzene	<10	<10	1	10
p-Dichlorobenzene	<10	<10	1	10
3,3'-Dichlorobenzidine	<5	<5	1	5
1,2-Dichloroethane	<10	<10	1	10
1,1-Dichloroethylene	<10	<10	1	10
Dichloromethane	<20	<20	1	20
1,2-Dichloropropane	<10	<10	1	10
1,3-Dichloropropene	<10	<10	1	10
Dicofol	<1	<1	1	1
Dieldrin	<0.02	<0.02	1	0.02
2,4-Dimethylphenol	<10	<10	1	10
Di-n-Butyl Phthalate	<10	<10	1	10
Diuron	<0.09	<0.09	1	0.09
Endosulfan I (alpha)	<0.01	<0.01	1	0.01

<b>Pollutant</b>	<b>AVG Effluent Conc. (µg/l)</b>	<b>MAX Effluent Conc. (µg/l)</b>	<b>Number of Samples</b>	<b>MAL (µg/l)</b>
Endosulfan II (beta)	<0.02	<0.02	1	0.02
Endosulfan Sulfate	<0.1	<0.1	1	0.1
Endrin	<0.02	<0.02	1	0.02
Ethylbenzene	<10	<10	1	10
Fluoride	<500	<500	1	500
Guthion	<0.1	<0.1	1	0.1
Heptachlor	<0.01	<0.01	1	0.01
Heptachlor Epoxide	<0.01	<0.01	1	0.01
Hexachlorobenzene	<5	<5	1	5
Hexachlorobutadiene	<10	<10	1	10
Hexachlorocyclohexane (alpha)	<0.05	<0.05	1	0.05
Hexachlorocyclohexane (beta)	<0.05	<0.05	1	0.05
gamma-Hexachlorocyclohexane (Lindane)	<0.05	<0.05	1	0.05
Hexachlorocyclopentadiene	<10	<10	1	10
Hexachloroethane	<20	<20	1	20
Hexachlorophene	<10	<10	1	10
Lead	<0.5	<0.5	1	0.5
Malathion	<0.1	<0.1	1	0.1
Mercury	<0.005	<0.005	1	0.005
Methoxychlor	<2	<2	1	2
Methyl Ethyl Ketone	<50	<50	1	50
Mirex	<0.02	<0.02	1	0.02
Nickel	<2	<2	1	2
Nitrate-Nitrogen	<100	<100	1	100
Nitrobenzene	<10	<10	1	10
N-Nitrosodiethylamine	<20	<20	1	20
N-Nitroso-di-n-Butylamine	<20	<20	1	20
Nonylphenol	<333	<333	1	333
Parathion (ethyl)	<0.1	<0.1	1	0.1
Pentachlorobenzene	<20	<20	1	20
Pentachlorophenol	<5	<5	1	5
Phenanthrene	<10	<10	1	10

<b>Pollutant</b>	<b>AVG Effluent Conc. (µg/l)</b>	<b>MAX Effluent Conc. (µg/l)</b>	<b>Number of Samples</b>	<b>MAL (µg/l)</b>
Polychlorinated Biphenyls (PCB's) (*3)	<0.2	<0.2	1	0.2
Pyridine	<20	<20	1	20
Selenium	<5	<5	1	5
Silver	<0.5	<0.5	1	0.5
1,2,4,5-Tetrachlorobenzene	<20	<20	1	20
1,1,2,2-Tetrachloroethane	<10	<10	1	10
Tetrachloroethylene	<10	<10	1	10
Thallium	<0.5	<0.5	1	0.5
Toluene	<10	<10	1	10
Toxaphene	<0.3	<0.3	1	0.3
2,4,5-TP (Silvex)	<0.3	<0.3	1	0.3
Tributyltin (see instructions for explanation)	N/A			0.01
1,1,1-Trichloroethane	<10	<10	1	10
1,1,2-Trichloroethane	<10	<10	1	10
Trichloroethylene	<10	<10	1	10
2,4,5-Trichlorophenol	<50	<50	1	50
TTHM (Total Trihalomethanes)	<10	<10	1	10
Vinyl Chloride	<10	<10	1	10
Zinc	10.8	10.8	1	5

(\*1) Determined by subtracting hexavalent Cr from total Cr.

(\*2) Cyanide, amenable to chlorination or weak-acid dissociable.

(\*3) The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

## Section 2. Priority Pollutants

For pollutants identified in Tables 4.0(2)A-E, indicate type of sample.

Grab

Composite

Date and time sample(s) collected: See Attachment G

**Table 4.0(2)A – Metals, Cyanide, and Phenols**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Antimony	<5	<5	1	5
Arsenic	1.34	1.34	1	0.5
Beryllium	<0.5	<0.5	1	0.5
Cadmium	<1	<1	1	1
Chromium (Total)	<3	<3	1	3
Chromium (Hex)	<3	<3	1	3
Chromium (Tri) (*1)	<3	<3	1	N/A
Copper	<2	<2	1	2
Lead	<0.5	<0.5	1	0.5
Mercury	<0.005	<0.005	1	0.005
Nickel	<2	<2	1	2
Selenium	<5	<5	1	5
Silver	<0.5	<0.5	1	0.5
Thallium	<0.5	<0.5	1	0.5
Zinc	10.8	10.8	1	5
Cyanide (*2)	<10	<10	1	10
Phenols, Total	<10	<10	1	10

(\*1) Determined by subtracting hexavalent Cr from total Cr.

(\*2) Cyanide, amenable to chlorination or weak-acid dissociable

**Table 4.0(2)B – Volatile Compounds**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrolein	<50	<50	1	50
Acrylonitrile	<50	<50	1	50
Benzene	<10	<10	1	10
Bromoform	<10	<10	1	10
Carbon Tetrachloride	<2	<2	1	2
Chlorobenzene	<10	<10	1	10
Chlorodibromomethane	<10	<10	1	10
Chloroethane	<50	<50	1	50
2-Chloroethylvinyl Ether	<10	<10	1	10
Chloroform	<10	<10	1	10
Dichlorobromomethane [Bromodichloromethane]	<10	<10	1	10
1,1-Dichloroethane	<10	<10	1	10
1,2-Dichloroethane	<10	<10	1	10
1,1-Dichloroethylene	<10	<10	1	10
1,2-Dichloropropane	<10	<10	1	10
1,3-Dichloropropylene [1,3-Dichloropropene]	<10	<10	1	10
1,2-Trans-Dichloroethylene	<10	<10	1	10
Ethylbenzene	<10	<10	1	10
Methyl Bromide	<50	<50		50
Methyl Chloride	<50	<50	1	50
Methylene Chloride	<20	<20	1	20
1,1,2,2-Tetrachloroethane	<10	<10	1	10
Tetrachloroethylene	<10	<10	1	10
Toluene	<10	<10	1	10
1,1,1-Trichloroethane	<10	<10	1	10
1,1,2-Trichloroethane	<10	<10	1	10
Trichloroethylene	<10	<10	1	10
Vinyl Chloride	<10	<10	1	10

**Table 4.0(2)C – Acid Compounds**

<b>Pollutant</b>	<b>AVG Effluent Conc. (µg/l)</b>	<b>MAX Effluent Conc. (µg/l)</b>	<b>Number of Samples</b>	<b>MAL (µg/l)</b>
2-Chlorophenol	<10	<10	1	10
2,4-Dichlorophenol	<10	<10	1	10
2,4-Dimethylphenol	<10	<10	1	10
4,6-Dinitro-o-Cresol	<50	<50	1	50
2,4-Dinitrophenol	<50	<50	1	50
2-Nitrophenol	<20	<20	1	20
4-Nitrophenol	<50	<50	1	50
P-Chloro-m-Cresol	<10	<10	1	10
Pentachlorophenol	<5	<5	1	5
Phenol	<10	<10	1	10
2,4,6-Trichlorophenol	<10	<10	1	10

**Table 4.0(2)D – Base/Neutral Compounds**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acenaphthene	<10	<10	1	10
Acenaphthylene	<10	<10	1	10
Anthracene	<10	<10	1	10
Benzidine	<50	<50	1	50
Benzo(a)Anthracene	<5	<5	1	5
Benzo(a)Pyrene	<5	<5	1	5
3,4-Benzofluoranthene	<10	<10	1	10
Benzo(ghi)Perylene	<20	<20	1	20
Benzo(k)Fluoranthene	<5	<5	1	5
Bis(2-Chloroethoxy)Methane	<10	<10	1	10
Bis(2-Chloroethyl)Ether	<10	<10	1	10
Bis(2-Chloroisopropyl)Ether	<10	<10	1	10
Bis(2-Ethylhexyl)Phthalate	<10	<10	1	10
4-Bromophenyl Phenyl Ether	<10	<10	1	10
Butyl benzyl Phthalate	<10	<10	1	10
2-Chloronaphthalene	<10	<10	1	10
4-Chlorophenyl phenyl ether	<10	<10	1	10
Chrysene	<5	<5	1	5
Dibenzo(a,h)Anthracene	<5	<5	1	5
1,2-(o)Dichlorobenzene	<10	<10	1	10
1,3-(m)Dichlorobenzene	<10	<10	1	10
1,4-(p)Dichlorobenzene	<10	<10	1	10
3,3-Dichlorobenzidine	<5	<5	1	5
Diethyl Phthalate	<10	<10	1	10
Dimethyl Phthalate	<10	<10	1	10
Di-n-Butyl Phthalate	<10	<10	1	10
2,4-Dinitrotoluene	<10	<10	1	10
2,6-Dinitrotoluene	<10	<10	1	10
Di-n-Octyl Phthalate	<10	<10	1	10
1,2-Diphenylhydrazine (as Azo-benzene)	<20	<20	1	20
Fluoranthene	<10	<10	1	10

<b>Pollutant</b>	<b>AVG Effluent Conc. (µg/l)</b>	<b>MAX Effluent Conc. (µg/l)</b>	<b>Number of Samples</b>	<b>MAL (µg/l)</b>
Fluorene	<10	<10	1	10
Hexachlorobenzene	<5	<5	1	5
Hexachlorobutadiene	<10	<10	1	10
Hexachlorocyclo-pentadiene	<10	<10	1	10
Hexachloroethane	<20	<20	1	20
Indeno(1,2,3-cd)pyrene	<5	<5	1	5
Isophorone	<10	<10	1	10
Naphthalene	<10	<10	1	10
Nitrobenzene	<10	<10	1	10
N-Nitrosodimethylamine	<50	<50	1	50
N-Nitrosodi-n-Propylamine	<20	<20	1	20
N-Nitrosodiphenylamine	<20	<20	1	20
Phenanthrene	<10	<10	1	10
Pyrene	<10	<10	1	10
1,2,4-Trichlorobenzene	<10	<10	1	10

**Table 4.0(2)E - Pesticides**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Aldrin	<0.01	<0.01	1	0.01
alpha-BHC (Hexachlorocyclohexane)	<0.05	<0.05	1	0.05
beta-BHC (Hexachlorocyclohexane)	<0.05	<0.05	1	0.05
gamma-BHC (Hexachlorocyclohexane)	<0.05	<0.05	1	0.05
delta-BHC (Hexachlorocyclohexane)	<0.05	<0.05	1	0.05
Chlordane	<0.2	<0.2	1	0.2
4,4-DDT	<0.02	<0.02	1	0.02
4,4-DDE	<0.1	<0.1	1	0.1
4,4,-DDD	<0.1	<0.1	1	0.1
Dieldrin	<0.02	<0.02	1	0.02
Endosulfan I (alpha)	<0.01	<0.01	1	0.01
Endosulfan II (beta)	<0.020	<0.02	1	0.02
Endosulfan Sulfate	<0.1	<0.1	1	0.1
Endrin	<0.02	<0.02	1	0.02
Endrin Aldehyde	<0.1	<0.1	1	0.1
Heptachlor	<0.01	<0.01	1	0.01
Heptachlor Epoxide	<0.01	<0.01	1	0.01
PCB-1242	<0.2	<0.2	1	0.2
PCB-1254	<0.2	<0.2	1	0.2
PCB-1221	<0.2	<0.2	1	0.2
PCB-1232	<0.2	<0.2	1	0.2
PCB-1248	<0.2	<0.2	1	0.2
PCB-1260	<0.2	<0.2	1	0.2
PCB-1016	<0.2	<0.2	1	0.2
Toxaphene	<0.3	<0.3	1	0.3

\* For PCBs, if all are non-detects, enter the highest non-detect preceded by a "<".

### Section 3. Dioxin/Furan Compounds

A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user. Check all that apply.

- 2,4,5-trichlorophenoxy acetic acid  
Common Name 2,4,5-T, CASRN 93-76-5
- 2-(2,4,5-trichlorophenoxy) propanoic acid  
Common Name Silvex or 2,4,5-TP, CASRN 93-72-1
- 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate  
Common Name Erbon, CASRN 136-25-4
- 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate  
Common Name Ronnel, CASRN 299-84-3
- 2,4,5-trichlorophenol  
Common Name TCP, CASRN 95-95-4
- hexachlorophene  
Common Name HCP, CASRN 70-30-4

For each compound identified, provide a brief description of the conditions of its/their presence at the facility.

N/A
-----

B. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent?

- Yes  No

If yes, provide a brief description of the conditions for its presence.

N/A
-----

C. If any of the compounds in Subsection A or B are present, complete Table 4.0(2)F.

For pollutants identified in Table 4.0(2)F, indicate the type of sample.

Grab  Composite  N/A

Date and time sample(s) collected: N/A

**Table 4.0(2)F – Dioxin/Furan Compounds**

Compound	Toxic Equivalency Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
2,3,7,8 TCDD	1					10
1,2,3,7,8 PeCDD	0.5					50
2,3,7,8 HxCDDs	0.1					50
1,2,3,4,6,7,8 HpCDD	0.01					50
2,3,7,8 TCDF	0.1					10
1,2,3,7,8 PeCDF	0.05					50
2,3,4,7,8 PeCDF	0.5					50
2,3,7,8 HxCDFs	0.1					50
2,3,4,7,8 HpCDFs	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					0.5
PCB 81	0.0003					0.5
PCB 126	0.1					0.5
PCB 169	0.03					0.5
Total						

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 5.0: TOXICITY TESTING REQUIREMENTS

The following **is required** for facilities with a current operating design flow of **1.0 MGD or greater**, with an EPA-approved **pretreatment** program (or those required to have one under 40 CFR Part 403), or are required to perform Whole Effluent Toxicity testing. See instructions for further details.

This worksheet is not required for minor amendments without renewal.

## Section 1. Required Tests (Instructions Page 88)

Indicate the number of 7-day chronic or 48-hour acute Whole Effluent Toxicity (WET) tests performed in the four and one-half years prior to submission of the application.

7-day Chronic: N/A

48-hour Acute: N/A

## Section 2. Toxicity Reduction Evaluations (TREs)

Has this facility completed a TRE in the past four and a half years? Or is the facility currently performing a TRE?

Yes  No

If **yes**, describe the progress to date, if applicable, in identifying and confirming the toxicant.

N/A



# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following is required for all publicly owned treatment works.

## Section 1. All POTWs (Instructions Page 89)

### A. Industrial users (IUs)

Provide the number of each of the following types of industrial users (IUs) that discharge to your POTW and the daily flows from each user. See the Instructions for definitions of Categorical IUs, Significant IUs - non-categorical, and Other IUs.

**If there are no users, enter 0 (zero).**

Categorical IUs:

Number of IUs: 0

Average Daily Flows, in MGD: 0

Significant IUs - non-categorical:

Number of IUs: 0

Average Daily Flows, in MGD: 0

Other IUs:

Number of IUs: 0

Average Daily Flows, in MGD: 0

### B. Treatment plant interference

In the past three years, has your POTW experienced treatment plant interference (see instructions)?

Yes  No

**If yes**, identify the dates, duration, description of interference, and probable cause(s) and possible source(s) of each interference event. Include the names of the IUs that may have caused the interference.

N/A

**C. Treatment plant pass through**

In the past three years, has your POTW experienced pass through (see instructions)?

Yes  No

If yes, identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.

N/A

**D. Pretreatment program**

Does your POTW have an approved pretreatment program?

Yes  No

If yes, complete Section 2 only of this Worksheet.

Is your POTW required to develop an approved pretreatment program?

Yes  No

If yes, complete Section 2.c. and 2.d. only, and skip Section 3.

If no to either question above, skip Section 2 and complete Section 3 for each significant industrial user and categorical industrial user.

**E. Service Area Map**

Attach a map indicating the service area of the POTW. The map should include the applicant’s service area boundaries and the location of any known industrial users discharging to the POTW. Please see the instructions for guidance.

Attachment: N/A

**Section 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 90)**

**A. Substantial modifications**

Have there been any **substantial modifications** to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?

Yes  No N/A

If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.

N/A

**B. Non-substantial modifications**

Have there been any **non-substantial modifications** to the approved pretreatment program that have not been submitted to TCEQ for review and acceptance?

Yes  No N/A

If yes, identify all non-substantial modifications that have not been submitted to TCEQ, including the purpose of the modification.

N/A

**C. Effluent parameters above the MAL**

In Table 6.0(1), list all parameters measured above the MAL in the POTW’s effluent monitoring during the last three years. Submit an attachment if necessary.

**Table 6.0(1) – Parameters Above the MAL**

Pollutant	Concentration	MAL	Units	Date
<u>N/A</u>				

**D. Industrial user interruptions**

Has any SIU, CIU, or other IU caused or contributed to any problems (excluding interferences or pass throughs) at your POTW in the past three years?

Yes  No N/A

If yes, identify the industry, describe each episode, including dates, duration, description of the problems, and probable pollutants.

N/A

### Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 90)

#### A. General information

Company Name: N/A

SIC Code: N/A

Contact name: N/A

Address: N/A

City, State, and Zip Code: N/A

Telephone number: N/A

Email address: N/A

#### B. Process information

Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).

N/A

#### C. Product and service information

Provide a description of the principal product(s) or services performed.

N/A

#### D. Flow rate information

See the Instructions for definitions of “process” and “non-process wastewater.”

Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type:  Continuous  Batch  Intermittent

Non-Process Wastewater:

Discharge, in gallons/day: N/A

Discharge Type:  Continuous  Batch  Intermittent

#### E. Pretreatment standards

Is the SIU or CIU subject to technically based local limits as defined in the instructions?

Yes  No N/A

Is the SIU or CIU subject to categorical pretreatment standards found in *40 CFR Parts 405-471*?

Yes  No N/A

**If subject to categorical pretreatment standards**, indicate the applicable category and subcategory for each categorical process.

Category: N/A

Subcategories: N/A

#### F. Industrial user interruptions

Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?

Yes  No N/A

**If yes**, identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.

<u>N/A</u>
------------

**TRINITY BAY CONSERVATION DISTRICT  
WINNIE-STOWELL WASTEWATER TREATMENT FACILITY  
TPDES PERMIT RENEWAL APPLICATION**

**TABLE OF ATTACHMENTS**

<b><u>No.</u></b>	<b><u>Description</u></b>	<b><u>Reference</u></b>
A	Core Data Form	Admin Rpt 1.0, Section 3.C
B	Plain Language Summary	Admin Rpt 1.0, Section 8.F
C	USGS Map	Admin Rpt 1.0, Section 13
D	Supplemental Permit Information Form	SPIF
E	Process Flow Diagram	Tech Rpt 1.0, Section 2.C
F	Site Drawing	Tech Rpt 1.0, Section 3
G	Pollutant Analysis of Treated Effluent	Tech Rpt 1.0, Section 7; Wks 4.0 Section 1 & 2
H	List of Facility Operators	Tech Rpt 1.0, Section 8
I	Summary of WET Test Results	Wks 5.0 Section 3

**ATTACHMENT A**

**Core Data Form  
Admin Rpt 1.0, Section 3.C**



# TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

## SECTION I: General Information

<b>1. Reason for Submission</b> (If other is checked please describe in space provided.)		
<input type="checkbox"/> New Permit, Registration or Authorization (Core Data Form should be submitted with the program application.)		
<input checked="" type="checkbox"/> Renewal (Core Data Form should be submitted with the renewal form)	<input type="checkbox"/> Other	
<b>2. Customer Reference Number</b> (if issued)	<a href="#">Follow this link to search for CN or RN numbers in Central Registry**</a>	<b>3. Regulated Entity Reference Number</b> (if issued)
CN 600675417		RN 102077393

## SECTION II: Customer Information

<b>4. General Customer Information</b>		<b>5. Effective Date for Customer Information Updates</b> (mm/dd/yyyy)	
<input type="checkbox"/> New Customer <input type="checkbox"/> Update to Customer Information <input type="checkbox"/> Change in Regulated Entity Ownership <input type="checkbox"/> Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts)			
<i>The Customer Name submitted here may be updated automatically based on what is current and active with the Texas Secretary of State (SOS) or Texas Comptroller of Public Accounts (CPA).</i>			
<b>6. Customer Legal Name</b> (If an individual, print last name first: eg: Doe, John)		<i>If new Customer, enter previous Customer below:</i>	
Trinity Bay Conservation District			
<b>7. TX SOS/CPA Filing Number</b>	<b>8. TX State Tax ID</b> (11 digits)	<b>9. Federal Tax ID</b> (9 digits)	<b>10. DUNS Number</b> (if applicable)
<b>11. Type of Customer:</b>		Partnership: <input type="checkbox"/> General <input type="checkbox"/> Limited	
<input type="checkbox"/> Corporation Government: <input type="checkbox"/> City <input type="checkbox"/> County <input type="checkbox"/> Federal <input type="checkbox"/> Local <input type="checkbox"/> State <input checked="" type="checkbox"/> Other		<input type="checkbox"/> Individual <input type="checkbox"/> Sole Proprietorship <input type="checkbox"/> Other:	
<b>12. Number of Employees</b>		<b>13. Independently Owned and Operated?</b>	
<input type="checkbox"/> 0-20 <input checked="" type="checkbox"/> 21-100 <input type="checkbox"/> 101-250 <input type="checkbox"/> 251-500 <input type="checkbox"/> 501 and higher		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<b>14. Customer Role</b> (Proposed or Actual) – as it relates to the Regulated Entity listed on this form. Please check one of the following			
<input type="checkbox"/> Owner <input type="checkbox"/> Operator <input checked="" type="checkbox"/> Owner & Operator <input type="checkbox"/> Other: <input type="checkbox"/> Occupational Licensee <input type="checkbox"/> Responsible Party <input type="checkbox"/> VCP/BSA Applicant			
<b>15. Mailing Address:</b>	P.O. Box 599		
	<b>City</b>	Stowell	<b>State</b> TX <b>ZIP</b> 77661 <b>ZIP + 4</b> 0599
<b>16. Country Mailing Information</b> (if outside USA)		<b>17. E-Mail Address</b> (if applicable)	
		jerry@tbcd.org	

<b>18. Telephone Number</b>	<b>19. Extension or Code</b>	<b>20. Fax Number (if applicable)</b>
( 409 ) 296-3602	0	( 409 ) 296-1055

## SECTION III: Regulated Entity Information

<b>21. General Regulated Entity Information</b> (If 'New Regulated Entity' is selected, a new permit application is also required.)								
<input type="checkbox"/> New Regulated Entity <input type="checkbox"/> Update to Regulated Entity Name <input type="checkbox"/> Update to Regulated Entity Information								
<i>The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).</i>								
<b>22. Regulated Entity Name</b> (Enter name of the site where the regulated action is taking place.)								
Winnie-Stowell Wastewater Treatment Facility								
<b>23. Street Address of the Regulated Entity:</b>  (No PO Boxes)	760 East Buccaneer Drive							
	<b>City</b>	Winnie	<b>State</b>	TX	<b>ZIP</b>	77665	<b>ZIP + 4</b>	
<b>24. County</b>	Chambers							

If no Street Address is provided, fields 25-28 are required.

<b>25. Description to Physical Location:</b>									
<b>26. Nearest City</b>							<b>State</b>	<b>Nearest ZIP Code</b>	
<i>Latitude/Longitude are required and may be added/updated to meet TCEQ Core Data Standards. (Geocoding of the Physical Address may be used to supply coordinates where none have been provided or to gain accuracy).</i>									
<b>27. Latitude (N) In Decimal:</b>		29.802866			<b>28. Longitude (W) In Decimal:</b>		-94.368345		
Degrees	Minutes	Seconds	Degrees	Minutes	Seconds				
<b>29. Primary SIC Code</b>		<b>30. Secondary SIC Code</b>		<b>31. Primary NAICS Code</b>		<b>32. Secondary NAICS Code</b>			
(4 digits)		(4 digits)		(5 or 6 digits)		(5 or 6 digits)			
4952				221320					
<b>33. What is the Primary Business of this entity?</b> (Do not repeat the SIC or NAICS description.)									
Treatment of domestic wastewater.									
<b>34. Mailing Address:</b>	P.O. Box 599								
	<b>City</b>	Stowell	<b>State</b>	TX	<b>ZIP</b>	77661	<b>ZIP + 4</b>		
<b>35. E-Mail Address:</b>		jerry@tbcd.org							
<b>36. Telephone Number</b>			<b>37. Extension or Code</b>			<b>38. Fax Number (if applicable)</b>			
( 409 ) 296-3602						( 409 ) 296-1055			

**39. TCEQ Programs and ID Numbers** Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

<input type="checkbox"/> Dam Safety	<input type="checkbox"/> Districts	<input type="checkbox"/> Edwards Aquifer	<input type="checkbox"/> Emissions Inventory Air	<input type="checkbox"/> Industrial Hazardous Waste
<input type="checkbox"/> Municipal Solid Waste	<input type="checkbox"/> New Source Review Air	<input type="checkbox"/> OSSF	<input type="checkbox"/> Petroleum Storage Tank	<input type="checkbox"/> PWS
<input type="checkbox"/> Sludge	<input type="checkbox"/> Storm Water	<input type="checkbox"/> Title V Air	<input type="checkbox"/> Tires	<input type="checkbox"/> Used Oil
<input type="checkbox"/> Voluntary Cleanup	<input checked="" type="checkbox"/> Wastewater	<input type="checkbox"/> Wastewater Agriculture	<input type="checkbox"/> Water Rights	<input type="checkbox"/> Other:
	WQ0010851001			

**SECTION IV: Preparer Information**

<b>40. Name:</b>	Alexandra Garoutte	<b>41. Title:</b>	Scientist in Training
<b>42. Telephone Number</b>	<b>43. Ext./Code</b>	<b>44. Fax Number</b>	<b>45. E-Mail Address</b>
( 512 ) 452-5905		( ) -	agaroutte@plummer.com

**SECTION V: Authorized Signature**

46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39.

<b>Company:</b>	Trinity Bay Conservation District	<b>Job Title:</b>	General Manager
<b>Name (In Print):</b>	Jerry Shadden	<b>Phone:</b>	( 409 ) 781- 4016
<b>Signature:</b>		<b>Date:</b>	12-10-2024

**ATTACHMENT B**

**Plain Language Summary  
Admin Rpt 1.0, Section 8.F**



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# PLAIN LANGUAGE SUMMARY FOR TPDES OR TLAP PERMIT APPLICATIONS

## Plain Language Summary Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary as required by [Title 30, Texas Administrative Code \(30 TAC\), Chapter 39, Subchapter H](#). Applicants may modify the template as necessary to accurately describe their facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how the applicant will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements.

If you are subject to the alternative language notice requirements in [30 TAC Section 39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS DOMESTIC WASTEWATER/STORMWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.*

Trinity Bay Conservation District (CN600675417) operates Winnie-Stowell Wastewater Treatment Facility (RN102077393), a lagoon/wetland system. The facility is located at 760 East Buccaneer Drive, in Winnie, Chambers County, Texas 77665. This application is for a renewal to discharge treated domestic wastewater at an annual average flow of 1,980,000 gallons per day via Outfall 001.

Discharges from the facility are expected to contain carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen, and *Escherichia coli*. Domestic wastewater is treated by a facultative lagoon, eight wetland cells, post aeration, and chlorination.

## PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

### AGUAS RESIDUALES DOMESTICAS /AGUAS PLUVIALES


*El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.*

Districto de conservación de Trinity Bay (CN600675417) opera Winnie-Stowell Instalación de Tratamiento de Aguas Residuales (RN102077393), una sistema de lagunas/humedales. La instalación está ubicada en 760 East Buccaneer Drive, en Winnie, Condado de Chambers, Texas 7665. Esta solicitud es para una renovación para descargar aguas residuales domésticas tratadas a un flujo promedio anual de 1,980,000 galones por día a través del Emisario 001.

Se espera que las descargas de la instalación contengan demanda bioquímica carbonosa de oxígeno, sólidos suspendidos totales, nitrógeno amoniacal y *Escherichia coli*. Aguas residuales domésticas. está tratado por una laguna facultativa, ocho celdas de humedal, post aireación y cloración..

**ATTACHMENT C**

**USGS Map  
Admin Rpt 1.0, Section 13**



 Monitor Wells

ATTACHMENT C  
TRINITY BAY CONSERVATION DISTRICT  
WINNIE-STOWELL WASTEWATER TREATMENT FACILITY  
TPDES PERMIT RENEWAL APPLICATION  
USGS MAP

TEXAS REGISTERED ENGINEERING FIRM F-13  
Z:\Shared\Projects\Water\1550\007-07\05 Project Work\03 GIS\Application Attachments - WS.aprx Jgriesel

**ATTACHMENT D**

**Supplemental Permit Information Form  
SPIF**

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

## FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

**TCEQ USE ONLY:**

Application type: \_\_\_Renewal \_\_\_Major Amendment \_\_\_Minor Amendment \_\_\_New

County: \_\_\_\_\_ Segment Number: \_\_\_\_\_

Admin Complete Date: \_\_\_\_\_

Agency Receiving SPIF:

\_\_\_ Texas Historical Commission

\_\_\_ U.S. Fish and Wildlife

\_\_\_ Texas Parks and Wildlife Department

\_\_\_ U.S. Army Corps of Engineers

**This form applies to TPDES permit applications only.** (Instructions, Page 53)

Complete this form as a separate document. TCEQ will mail a copy to each agency as required by our agreement with EPA. If any of the items are not completely addressed or further information is needed, we will contact you to provide the information before issuing the permit. Address each item completely.

**Do not refer to your response to any item in the permit application form.** Provide each attachment for this form separately from the Administrative Report of the application. The application will not be declared administratively complete without this SPIF form being completed in its entirety including all attachments. Questions or comments concerning this form may be directed to the Water Quality Division's Application Review and Processing Team by email at [WQ-ARPTeam@tceq.texas.gov](mailto:WQ-ARPTeam@tceq.texas.gov) or by phone at (512) 239-4671.

The following applies to all applications:

1. Permittee: Trinity Bay Conservation District

Permit No. WQ00 10851001

EPA ID No. TX 0020460

Address of the project (or a location description that includes street/highway, city/vicinity, and county):

760 East Buccaneer Drive, Winnie, Chambers County, Texas 77665.

Provide the name, address, phone and fax number of an individual that can be contacted to answer specific questions about the property.

Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Jerry Shadden

Credential (P.E, P.G., Ph.D., etc.): N/A

Title: General Manager

Mailing Address: P.O. Box 599

City, State, Zip Code: Stowell, TX 77661

Phone No.: (409) 781-4016 Ext.: N/A Fax No.: (409) 296-1055

E-mail Address: jerry@tbcd.org

2. List the county in which the facility is located: Chambers
3. If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.

N/A

4. Provide a description of the effluent discharge route. The discharge route must follow the flow of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.

To South Fork Mayhaw Bayou; thence to Mayhaw Bayou; thence to South Fork Taylor Bayou; thence to the Taylor Bayou Above Tidal in Segment No. 0701 of the Neches-Trinity Coastal Basin.

5. Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report). See SPIF 1 and SPIF 2

Provide original photographs of any structures 50 years or older on the property. N/A

Does your project involve any of the following? Check all that apply. N/A

- Proposed access roads, utility lines, construction easements
- Visual effects that could damage or detract from a historic property's integrity
- Vibration effects during construction or as a result of project design
- Additional phases of development that are planned for the future
- Sealing caves, fractures, sinkholes, other karst features

Disturbance of vegetation or wetlands

1. List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):

N/A

2. Describe existing disturbances, vegetation, and land use:

Existing disturbances, vegetation, and land use include those typical of a wetland treatment facility.




THE FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR AMENDMENTS TO TPDES PERMITS

3. List construction dates of all buildings and structures on the property:


N/A

4. Provide a brief history of the property, and name of the architect/builder, if known.

N/A



**SPIF 1**  
**TRINITY BAY CONSERVATION DISTRICT**  
**WINNIE-STOWELL WASTEWATER TREATMENT FACILITY**  
**TPDES PERMIT RENEWAL APPLICATION**  
**GENERAL LOCATION MAP**



SPIF 2  
TRINITY BAY CONSERVATION DISTRICT  
WINNIE-STOWELL WASTEWATER TREATMENT FACILITY  
TPDES PERMIT RENEWAL APPLICATION  
USGS MAP

TEXAS REGISTERED ENGINEERING FIRM F-13  
Z:\Shared\Projects\Water\1550\007-07\05 Project Work\03 GIS\Application Attachments - WS.aprx

**ATTACHMENT E**

**Process Flow Diagram  
Tech Rpt 1.0, Section 2.C**




PLUMMER

LEGEND

—— FLOW STREAM, LIQUIDS


----- FLOW STREAM, SOLIDS



ATTACHMENT E  
TRINITY BAY CONSERVATION DISTRICT  
WINNIE-STOWELL WASTEWATER TREATMENT FACILITY  
TPDES PERMIT RENEWAL APPLICATION  
PROCESS FLOW DIAGRAM

**ATTACHMENT F**

**Site Drawing  
Tech Rpt 1.0, Section 3**



**FACILITY'S SERVICE AREA**

**TREATMENT FACILITY BOUNDARY**

**ATTACHMENT F  
TRINITY BAY CONSERVATION DISTRICT  
WINNIE-STOWELL WASTEWATER TREATMENT FACILITY  
TPDES PERMIT RENEWAL APPLICATION  
SITE DRAWING**

TEXAS REGISTERED ENGINEERING FIRM F-13  
Z:\Shared\Projects\Water\1550\007-07\05 Project Work\03 GIS\Application Attachments - WS.aprx

**ATTACHMENT G**

**Pollutant Analysis of Treated Effluent  
Tech Rpt 1.0, Section 7;  
Wks 4.0 Section 1 & 2**



P.O. Box 1089 Coldspring Tx 77331  
Website: eastexlabs.com  
Email: eastexlab@eastex.net  
Tel: 936 653 3249



December 16, 2024

Trinity Bay Conservation District  
Winnie WWTP  
P.O. Box 599; 2500 SH 124  
Stowell, TX 77661

RE: **Winnie Permit Renewal**

Enclosed are the results of analyses for samples received by the laboratory on 11/01/24 16:15, with Lab ID Number 4431013. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Mark Bourgeois  
Special Projects Manager

**CORRECTED REPORT**  
**ORIGINAL REPORT**  
**DATE**  
11/27/24



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**LABORATORY ANALYTICAL REPORT**

Project: Winnie Permit Renewal  
 Client Matrix: Water

Sample Date & Time: 10/31/2024 08:00  
 Collector: AD  
 Sample Type: Composite  
 Print Date: 12/16/2024

**Eff PR Comp  
 4431013-01 (Water)**

Analyte	Result	Reporting Limit	Units	Nelac Status	Batch	Analyzed Date & Time	Method	Notes
<b><u>Metals</u></b>								
-								
Aluminum - Total	37.6	2.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Antimony - Total	<2.00	2.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Arsenic, Total	1.34	0.500	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Barium, Total	85.4	1.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Beryllium, Total	<0.500	0.500	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Cadmium, Total	<1.00	1.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Chromium, Total	<1.00	1.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Copper, Total	<1.00	1.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Lead, Total	<0.500	0.500	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Nickel, Total	<2.00	2.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Selenium, Total	<2.00	2.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Silver, Total	<0.500	0.500	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Thallium, Total	<0.500	0.500	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
Zinc, Total	10.8	5.00	ug/L	A	B4K0198	11/05/2024 13:24	EPA 200.8	
<b><u>Wet Lab</u></b>								
-								
Chromium, Trivalent	<3	3	ug/L	N	B4L1390	12/10/2024 14:17	-	
Fluoride	236	100	ug/L	A	B4K0222	11/01/2024 18:25	EPA 300.0	
Nitrate as N	78.1	50.0	ug/L	A	B4K0222	11/01/2024 18:25	EPA 300.0	13



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

Project: Winnie Permit Renewal  
 Client Matrix: Water

Sample Date & Time: 11/01/2024 11:20  
 Collector: AD  
 Sample Type: Grab  
 Print Date: 12/16/2024

**Eff PR Grab**  
**4431013-02 (Water)**

Analyte	Result	Reporting Limit	Units	Nelac Status	Batch	Analyzed Date & Time	Method	Notes
<b><u>Field</u></b>								
- Chlorine	<0.1	0.1	mg/L	N	B4K1742	11/01/2024 11:20	SM 4500 Cl F	
DO	7.2		mg/L	N	B4K1742	11/01/2024 07:45	SM 4500 O G	
pH	7.6		std unit	N	B4K1742	11/01/2024 07:45	SM 4500 H + B	
<b><u>Metals</u></b>								
- Total Phosphorus	2.64	0.0600	mg/L	A	B4K0422	11/06/2024 13:56	EPA 200.7	
<b><u>Microbiological Lab</u></b>								
- E coli IDEXX	1	1	mpn/100ml	A	B4K0382	11/01/2024 16:20	Colilert 18	
<b><u>Wet Lab</u></b>								
- Alkalinity	110	20.0	mg CaCO3/L	A	B4K0485	11/06/2024 11:37	SM 2320 B	
Ammonia as N	3.3	0.1	mg/L	A	B4K0340	11/11/2024 11:19	SM 4500 NH3 G	
CBOD 5	2.4	2.0	mg/L	A	B4K0227	11/02/2024 06:12	SM 5210 B	
Chloride	42.3	5.0	mg/L	A	B4K0222	11/01/2024 18:25	EPA 300.0	
Conductivity	457	10.0	µmhos/cm @25C	A	B4K0303	11/07/2024 08:55	SM 2510 B	
Cyanide	<5.00	5.00	ug/L	A	B4K1511	11/15/2024 16:20	SM 4500 CN- E	
Nitrate as N	0.06	0.05	mg/L	A	B4K0222	11/01/2024 18:25	EPA 300.0	13
Oil Grease, HEM	<5.0	5.0	mg/L	A	B4K0267	11/04/2024 09:30	EPA 1664A	
Phenol, low level	<10.0	10.0	ppb	A	B4K1105	11/08/2024 10:15	EPA 420.1	53
Sulfate	29.0	4.0	mg/L	A	B4K0222	11/01/2024 18:25	EPA 300.0	
TKN	4.3	1.0	mg/L	A	B4K0240	11/08/2024 17:30	EPA 351.2	12, 13
TSS	1.5	1.0	mg/L	A	B4K0286	11/04/2024 15:46	SM 2540 D	
<b><u>Wet Lab</u></b>								
- TDS	238	10.0	mg/L	A	N408098	11/04/2024 08:20	SM 2540 C	3, 6

Eastex Environmental Laboratory - Coldspring

The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
 This analytical report must be reproduced in its entirety.

\*NELAC Status: A=Accredited, N=Accreditation not offered, O=Not Accredited, P=Approved



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**EPA 200.8 - Quality Control**  
**Eastex Environmental Laboratory - Coldspring**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

**Batch B4K0198 - EPA 200.8**

**Prepared: 11/04/24 10:18**

**Blank (B4K0198-BLK1)**

**Analyzed: 11/5/2024 1:18:00PM**

Aluminum - Total	ND	2.00	ug/L							
Antimony - Total	ND	2.00	ug/L							
Arsenic, Total	ND	0.500	ug/L							
Barium, Total	ND	1.00	ug/L							
Beryllium, Total	ND	0.500	ug/L							
Cadmium, Total	ND	1.00	ug/L							
Chromium, Total	ND	1.00	ug/L							
Copper, Total	ND	1.00	ug/L							
Lead, Total	ND	0.500	ug/L							
Nickel, Total	ND	2.00	ug/L							
Selenium, Total	ND	2.00	ug/L							
Silver, Total	ND	0.500	ug/L							
Thallium, Total	ND	0.500	ug/L							
Zinc, Total	ND	5.00	ug/L							

**LCS (B4K0198-BS1)**

**Analyzed: 11/5/2024 1:21:00PM**

Aluminum - Total	106	2.00	ug/L	100		106	85-115			
Antimony - Total	104	2.00	ug/L	100		104	85-115			
Arsenic, Total	105	0.500	ug/L	100		105	85-115			
Barium, Total	103	1.00	ug/L	100		103	85-115			
Beryllium, Total	101	0.500	ug/L	100		101	85-115			
Cadmium, Total	103	1.00	ug/L	100		103	85-115			
Chromium, Total	105	1.00	ug/L	100		105	85-115			
Copper, Total	107	1.00	ug/L	100		107	85-115			
Lead, Total	99.7	0.500	ug/L	100		99.7	85-115			
Nickel, Total	106	2.00	ug/L	100		106	85-115			
Selenium, Total	103	2.00	ug/L	100		103	85-115			
Silver, Total	105	0.500	ug/L	100		105	85-115			
Thallium, Total	99.4	0.500	ug/L	100		99.4	85-115			
Zinc, Total	103	5.00	ug/L	100		103	85-115			

**Matrix Spike (B4K0198-MS1)**

**Source: 4431013-01**

**Analyzed: 11/5/2024 1:30:00PM**

Aluminum - Total	142	2.00	ug/L	100	37.6	104	70-130			
Antimony - Total	104	2.00	ug/L	100	ND	104	70-130			
Arsenic, Total	102	0.500	ug/L	100	1.34	100	70-130			
Barium, Total	188	1.00	ug/L	100	85.4	103	70-130			
Beryllium, Total	102	0.500	ug/L	100	0.0740	101	70-130			

Eastex Environmental Laboratory - Coldspring

*The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
 This analytical report must be reproduced in its entirety.*

\*NELAC Status: A=Accredited, N=Accreditation not offered, O=Not Accredited, P=Approved



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**EPA 200.8 - Quality Control**  
**Eastex Environmental Laboratory - Coldspring**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	-----	-----------	-------

**Batch B4K0198 - EPA 200.8**      **Prepared: 11/04/24 10:18**

Matrix Spike (B4K0198-MS1)	Source: 4431013-01			Analyzed: 11/5/2024 1:30:00PM						
Cadmium, Total	101	1.00	ug/L	100	ND	101	70-130			
Chromium, Total	100	1.00	ug/L	100	0.243	99.8	70-130			
Copper, Total	100	1.00	ug/L	100	ND	100	70-130			
Lead, Total	99.1	0.500	ug/L	100	0.114	99.0	70-130			
Nickel, Total	102	2.00	ug/L	100	ND	102	70-130			
Selenium, Total	100	2.00	ug/L	100	ND	100	70-130			
Silver, Total	100	0.500	ug/L	100	ND	100	70-130			
Thallium, Total	98.1	0.500	ug/L	100	0.0430	98.0	70-130			
Zinc, Total	110	5.00	ug/L	100	10.8	99.3	70-130			

Matrix Spike Dup (B4K0198-MSD1)	Source: 4431013-01			Analyzed: 11/5/2024 1:34:00PM						
Aluminum - Total	139	2.00	ug/L	100	37.6	102	70-130	1.66	20	
Antimony - Total	105	2.00	ug/L	100	ND	105	70-130	1.12	20	
Arsenic, Total	101	0.500	ug/L	100	1.34	99.7	70-130	0.510	20	
Barium, Total	190	1.00	ug/L	100	85.4	104	70-130	0.797	20	
Beryllium, Total	103	0.500	ug/L	100	0.0740	103	70-130	1.69	20	
Cadmium, Total	102	1.00	ug/L	100	ND	102	70-130	1.12	20	
Chromium, Total	97.7	1.00	ug/L	100	0.243	97.4	70-130	2.41	20	
Copper, Total	98.8	1.00	ug/L	100	ND	98.8	70-130	1.64	20	
Lead, Total	101	0.500	ug/L	100	0.114	101	70-130	1.98	20	
Nickel, Total	100	2.00	ug/L	100	ND	100	70-130	1.73	20	
Selenium, Total	100	2.00	ug/L	100	ND	100	70-130	0.0279	20	
Silver, Total	102	0.500	ug/L	100	ND	102	70-130	1.14	20	
Thallium, Total	101	0.500	ug/L	100	0.0430	101	70-130	2.69	20	
Zinc, Total	108	5.00	ug/L	100	10.8	97.1	70-130	2.01	20	

**Batch B4K0222 - No Prep**      **Prepared: 11/01/24 18:25**

Blank (B4K0222-BLK1)	Analyzed: 11/1/2024 6:25:00PM									
Chloride	ND	5.0	mg/L							
Nitrate as N	ND	0.05	mg/L							
Sulfate	ND	4.0	mg/L							
Fluoride	ND	100	ug/L							
Nitrate as N	ND	50.0	ug/L							

LCS (B4K0222-BS1)	Analyzed: 11/1/2024 6:25:00PM									
Chloride	26.4		mg/L	25.0		105	90-110			
Fluoride	0.476		mg/L	0.500		95.2	90-110			

Eastex Environmental Laboratory - Coldspring

*The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
 This analytical report must be reproduced in its entirety.*

\*NELAC Status: A=Accredited, N=Accreditation not offered, O=Not Accredited, P=Approved



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**EPA 300.0 - Quality Control**  
**Eastex Environmental Laboratory - Coldspring**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch B4K0222 - No Prep</b>		<b>Prepared: 11/01/24 18:25</b>								
<b>LCS (B4K0222-BS1)</b>		<b>Analyzed: 11/1/2024 6:25:00PM</b>								
Nitrate as N	1.7387		mg/L	1.50		116	90-110			13
Sulfate	21.7		mg/L	20.0		108	90-110			
<b>Matrix Spike (B4K0222-MS1)</b>		<b>Source: 4431013-01</b>		<b>Analyzed: 11/1/2024 6:25:00PM</b>						
Chloride	169	5.0	mg/L	125	42.3	102	80-120			
Nitrate as N	8.5846	0.05	mg/L	7.50	0.0781	113	80-120			13
Sulfate	131	4.0	mg/L	100	28.2	103	80-120			
Fluoride	2780	100	ug/L	2500	236	102	80-120			
Nitrate as N	8584.6	50.0	ug/L	7500	78.1	113	80-120			13
<b>Matrix Spike Dup (B4K0222-MSD1)</b>		<b>Source: 4431013-01</b>		<b>Analyzed: 11/1/2024 6:25:00PM</b>						
Chloride	169	5.0	mg/L	125	42.3	102	80-120	0.126	20	
Nitrate as N	8.5292	0.05	mg/L	7.50	0.0781	113	80-120	0.647	20	13
Sulfate	131	4.0	mg/L	100	28.2	103	80-120	0.101	20	
Fluoride	2770	100	ug/L	2500	236	101	80-120	0.191	20	
Nitrate as N	8529.2	50.0	ug/L	7500	78.1	113	80-120	0.647	20	13
<b>Batch B4K0227 - No Prep</b>		<b>Prepared: 11/02/24 06:12</b>								
<b>Blank (B4K0227-BLK1)</b>		<b>Analyzed: 11/2/2024 6:12:00AM</b>								
CBOD 5	ND	2.0	mg/L							
<b>LCS (B4K0227-BS1)</b>		<b>Analyzed: 11/2/2024 6:12:00AM</b>								
CBOD 5	169		mg/L	198		85.4	4.59-115.40			
<b>Duplicate (B4K0227-DUP1)</b>		<b>Source: 4431013-02</b>		<b>Analyzed: 11/2/2024 6:12:00AM</b>						
CBOD 5	1.94	2.0	mg/L		2.44			22.8	30	
<b>Batch B4K0240 - No Prep</b>		<b>Prepared: 11/06/24 10:30</b>								
<b>Blank (B4K0240-BLK1)</b>		<b>Analyzed: 11/8/2024 5:30:00PM</b>								
TKN	ND	1.0	mg/L							12
<b>LCS (B4K0240-BS1)</b>		<b>Analyzed: 11/8/2024 5:30:00PM</b>								
TKN	7.48		mg/L	10.0		74.8	90-110			12, 13
<b>Matrix Spike (B4K0240-MS1)</b>		<b>Source: 4440280-01</b>		<b>Analyzed: 11/8/2024 5:30:00PM</b>						
TKN	13.0	1.0	mg/L	10.0	0.373	127	80-120			12, 13, 23
<b>Matrix Spike Dup (B4K0240-MSD1)</b>		<b>Source: 4440280-01</b>		<b>Analyzed: 11/8/2024 5:30:00PM</b>						

Eastex Environmental Laboratory - Coldspring

*The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
 This analytical report must be reproduced in its entirety.*

\*NELAC Status: A=Accredited, N=Accreditation not offered, O=Not Accredited, P=Approved



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**EPA 351.2 - Quality Control**  
**Eastex Environmental Laboratory - Coldspring**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch B4K0240 - No Prep</b>		<b>Prepared: 11/06/24 10:30</b>								
<b>Matrix Spike Dup (B4K0240-MSD1)</b>		<b>Source: 4440280-01</b>			<b>Analyzed: 11/8/2024 5:30:00PM</b>					
TKN	13.6	1.0	mg/L	10.0	0.373	132	80-120	3.96	20	12, 13
<b>Batch B4K0267 - No Prep</b>		<b>Prepared: 11/04/24 09:30</b>								
<b>Blank (B4K0267-BLK1)</b>		<b>Analyzed: 11/4/2024 9:30:00AM</b>								
Oil Grease, HEM	ND	5.0	mg/L							
<b>LCS (B4K0267-BS1)</b>		<b>Analyzed: 11/4/2024 9:30:00AM</b>								
Oil Grease, HEM	40.0	5.0	mg/L	40.0		100	78-114			
<b>LCS Dup (B4K0267-BSD1)</b>		<b>Analyzed: 11/4/2024 9:30:00AM</b>								
Oil Grease, HEM	40.2	5.0	mg/L	40.0		100	78-114	0.499	18	
<b>Matrix Spike (B4K0267-MS1)</b>		<b>Source: 4441255-02</b>			<b>Analyzed: 11/4/2024 9:30:00AM</b>					
Oil Grease, HEM	41.5	5.2	mg/L	40.0	ND	104	78-114			
<b>Batch B4K0286 - No Prep</b>		<b>Prepared: 11/04/24 15:46</b>								
<b>Blank (B4K0286-BLK1)</b>		<b>Analyzed: 11/4/2024 3:46:00PM</b>								
TSS	ND	1.0	mg/L							
<b>Duplicate (B4K0286-DUP1)</b>		<b>Source: 4441703-01</b>			<b>Analyzed: 11/4/2024 3:46:00PM</b>					
TSS	176	1.0	mg/L		164			7.06	10	
<b>Batch B4K0303 - No Prep</b>		<b>Prepared: 11/07/24 08:55</b>								
<b>Blank (B4K0303-BLK1)</b>		<b>Analyzed: 11/7/2024 8:55:00AM</b>								
Conductivity	ND	10.0	µmhos/cm @25C							
<b>LCS (B4K0303-BS1)</b>		<b>Analyzed: 11/7/2024 8:55:00AM</b>								
Conductivity	1000		µmhos/cm @25C	1000		100	80-120			
<b>Duplicate (B4K0303-DUP1)</b>		<b>Source: 4431013-02</b>			<b>Analyzed: 11/7/2024 8:55:00AM</b>					
Conductivity	457	10.0	µmhos/cm @25C	457				0.00	20	
<b>Batch B4K0340 - No Prep</b>		<b>Prepared: 11/11/24 11:19</b>								
<b>Blank (B4K0340-BLK1)</b>		<b>Analyzed: 11/11/2024 11:19:00AM</b>								

Eastex Environmental Laboratory - Coldspring

*The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
 This analytical report must be reproduced in its entirety.*

\*NELAC Status: A=Accredited, N=Accreditation not offered, O=Not Accredited, P=Approved



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**SM 4500 NH3 G - Quality Control**  
**Eastex Environmental Laboratory - Coldspring**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch B4K0340 - No Prep</b>		<b>Prepared: 11/11/24 11:19</b>								
<b>Blank (B4K0340-BLK1)</b>		<b>Analyzed: 11/11/2024 11:19:00AM</b>								
Ammonia as N	ND	0.1	mg/L							
<b>LCS (B4K0340-BS1)</b>		<b>Analyzed: 11/11/2024 11:19:00AM</b>								
Ammonia as N	3.60		mg/L	4.00		90.0	90-110			
<b>Matrix Spike (B4K0340-MS1)</b>		<b>Source: 4431013-02 Analyzed: 11/11/2024 11:19:00AM</b>								
Ammonia as N	5.8	0.1	mg/L	2.50	3.3	100	80-120			
<b>Matrix Spike Dup (B4K0340-MSD1)</b>		<b>Source: 4431013-02 Analyzed: 11/11/2024 11:19:00AM</b>								
Ammonia as N	5.8	0.1	mg/L	2.50	3.3	100	80-120	0.00	20	
<b>Batch B4K0382 - No Prep Micro</b>		<b>Prepared: 11/01/24 16:20</b>								
<b>Blank (B4K0382-BLK1)</b>		<b>Analyzed: 11/1/2024 4:20:00PM</b>								
E coli IDEXX	ND		1 mpn/100ml							
<b>Duplicate (B4K0382-DUP1)</b>		<b>Source: 4441714-01 Analyzed: 11/1/2024 4:20:00PM</b>								
E coli IDEXX	6	2	mpn/100ml		13			71.0	200	
<b>Batch B4K0422 - EPA 200.7</b>		<b>Prepared: 11/04/24 14:05</b>								
<b>Blank (B4K0422-BLK1)</b>		<b>Analyzed: 11/6/2024 1:53:18PM</b>								
Total Phosphorus	ND	0.0600	mg/L							
<b>LCS (B4K0422-BS1)</b>		<b>Analyzed: 11/6/2024 1:54:54PM</b>								
Total Phosphorus	2.39	0.0600	mg/L	2.52		94.8	85-115			
<b>Matrix Spike (B4K0422-MS1)</b>		<b>Source: 4431013-02 Analyzed: 11/6/2024 1:59:42PM</b>								
Total Phosphorus	5.51	0.0600	mg/L	2.52	2.64	114	70-130			
<b>Matrix Spike Dup (B4K0422-MSD1)</b>		<b>Source: 4431013-02 Analyzed: 11/6/2024 2:01:18PM</b>								
Total Phosphorus	5.26	0.0600	mg/L	2.52	2.64	104	70-130	4.60	20	
<b>Batch B4K0485 - No Prep</b>		<b>Prepared: 11/06/24 11:37</b>								
<b>Blank (B4K0485-BLK1)</b>		<b>Analyzed: 11/6/2024 11:37:00AM</b>								
Alkalinity	ND		20.0 mg CaCO3/L							
<b>LCS (B4K0485-BS1)</b>		<b>Analyzed: 11/6/2024 11:37:00AM</b>								
Alkalinity	46.0		mg CaCO3/L	50.0		92.0	80-120			

Eastex Environmental Laboratory - Coldspring

*The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
 This analytical report must be reproduced in its entirety.*

\*NELAC Status: A=Accredited, N=Accreditation not offered, O=Not Accredited, P=Approved



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**SM 2320 B - Quality Control**  
**Eastex Environmental Laboratory - Coldspring**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch B4K0485 - No Prep</b>		<b>Prepared: 11/06/24 11:37</b>								
<b>Duplicate (B4K0485-DUP1)</b>		<b>Source: 4431013-02</b>			<b>Analyzed: 11/6/2024 11:37:00AM</b>					
Alkalinity	110	20.0	mg CaCO3/L		110			0.00	20	
<b>Batch B4K1105 - No Prep</b>		<b>Prepared: 11/08/24 10:15</b>								
<b>Blank (B4K1105-BLK1)</b>		<b>Analyzed: 11/8/2024 10:15:00AM</b>								
Phenol, low level	ND	10.0	ppb							
<b>LCS (B4K1105-BS1)</b>		<b>Analyzed: 11/8/2024 10:15:00AM</b>								
Phenol, low level	46.1		ppb	50.0		92.3	80-120			
<b>LCS Dup (B4K1105-BSD1)</b>		<b>Analyzed: 11/8/2024 10:15:00AM</b>								
Phenol, low level	36.0		ppb	50.0		72.1	80-120	24.6	20	53
<b>Matrix Spike (B4K1105-MS1)</b>		<b>Source: 4411718-02</b>			<b>Analyzed: 11/8/2024 10:15:00AM</b>					
Phenol, low level	ND	10.0	ppb	50.0	ND		80-120			23
<b>Batch B4K1511 - No Prep</b>		<b>Prepared: 11/15/24 13:55</b>								
<b>Blank (B4K1511-BLK1)</b>		<b>Analyzed: 11/15/2024 4:20:00PM</b>								
Cyanide	ND	5.00	ug/L							
<b>LCS (B4K1511-BS1)</b>		<b>Analyzed: 11/15/2024 4:20:00PM</b>								
Cyanide	39.0		ug/L	40.0		97.5	90-110			
<b>Matrix Spike (B4K1511-MS1)</b>		<b>Source: 4450654-01</b>			<b>Analyzed: 11/15/2024 4:20:00PM</b>					
Cyanide	ND	5.00	ug/L	40.0	ND		90-110			23
<b>Matrix Spike Dup (B4K1511-MSD1)</b>		<b>Source: 4450654-01</b>			<b>Analyzed: 11/15/2024 4:20:00PM</b>					
Cyanide	ND	5.00	ug/L	40.0	ND		90-110		20	

**SM 2540 C - Quality Control**  
**Eastex Environmental Laboratory - Nacogdoches**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch N408098 - No Prep</b>		<b>Prepared: 11/04/24 08:20</b>								
<b>Blank (N408098-BLK1)</b>		<b>Analyzed: 11/4/2024 8:20:00AM</b>								
TDS	ND	10.0	mg/L							

Eastex Environmental Laboratory - Coldspring

*The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
 This analytical report must be reproduced in its entirety.*

\*NELAC Status: A=Accredited, N=Accreditation not offered, O=Not Accredited, P=Approved



P.O. Box 1089 Coldspring Tx 77331  
 Website: eastexlabs.com  
 Email: eastexlab@eastex.net  
 Tel: 936 653 3249



Winnie WWTP  
 P.O. Box 599; 2500 SH 124  
 Stowell TX, 77661

**SM 2540 C - Quality Control**  
**Eastex Environmental Laboratory - Nacogdoches**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
<b>Batch N408098 - No Prep</b>		<b>Prepared: 11/04/24 08:20</b>								
<b>LCS (N408098-BS1)</b>					<b>Analyzed: 11/4/2024 8:20:00AM</b>					
TDS	48.0		mg/L	50.0		96.0	90-110			
<b>Duplicate (N408098-DUP1)</b>		<b>Source: N4J1029-01</b>			<b>Analyzed: 11/4/2024 8:20:00AM</b>					
TDS	1220	10.0	mg/L		1230			1.31	10	

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Natalie Sewell  
Eastex Environmental Laboratory Inc.  
PO BOX 1089  
Coldspring, Texas 77331

Generated 12/16/2024 10:06:32 AM Revision 1

## JOB DESCRIPTION

Winnie Permit Renewal Eff PR Comp

## JOB NUMBER

860-86090-1


# Eurofins Houston

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

## Authorization



Generated  
12/16/2024 10:06:32 AM  
Revision 1

Authorized for release by  
Sylvia Garza, Project Manager  
[Sylvia.Garza@et.eurofinsus.com](mailto:Sylvia.Garza@et.eurofinsus.com)  
(832)544-2004

# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	6
Detection Summary . . . . .	8
Client Sample Results . . . . .	9
Surrogate Summary . . . . .	13
QC Sample Results . . . . .	15
QC Association Summary . . . . .	29
Lab Chronicle . . . . .	32
Certification Summary . . . . .	33
Method Summary . . . . .	35
Sample Summary . . . . .	36
Chain of Custody . . . . .	37
Receipt Checklists . . . . .	69

# Definitions/Glossary

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

## Qualifiers

### GC/MS Semi VOA

Qualifier	Qualifier Description
*-	LCS and/or LCSD is outside acceptance limits, low biased.
*+	LCS and/or LCSD is outside acceptance limits, high biased.
I	Value is EMPC (estimated maximum possible concentration).
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
S1-	Surrogate recovery exceeds control limits, low biased.
U	Indicates the analyte was analyzed for but not detected.

### GC Semi VOA

Qualifier	Qualifier Description
*1	LCS/LCSD RPD exceeds control limits.
p	The %RPD between the primary and confirmation column/detector is >40%. The lower value has been reported.
S1-	Surrogate recovery exceeds control limits, low biased.
U	Indicates the analyte was analyzed for but not detected.

### HPLC/IC

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

### Metals

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points

## Definitions/Glossary

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Glossary (Continued)

Abbreviation	These commonly used abbreviations may or may not be present in this report.
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

3

5

# Case Narrative

Client: Eastex Environmental Laboratory Inc.  
Project: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Job ID: 860-86090-1**

**Eurofins Houston**

**Job Narrative  
860-86090-1**

4

## REVISION

The report being provided is a revision of the original report sent on 11/27/2024. The report (revision 1) is being revised due to include missing cmpds N-Nitroso-di-n-Butylamine, Pentachlorobenzene, 1,2,4,5-Tetrachlorobenzene.

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

## **Receipt**

The samples were received on 11/4/2024 7:34 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 1.8°C.

## **GC/MS Semi VOA**

Method 625.1\_QQQ: The continuing calibration verification (CCV) associated with batch 860-198704 recovered above the upper control limit for Guthion, Chlorpyrifos, Diazinon and Malathion. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported.

Method 625.1\_QQQ: The continuing calibration verification (CCV) associated with batch 860-199354 for 2,4-Dinitrophenol (50.2%) and 4,6-Dinitro-2-methylphenol (61.4 %) within control limits % recoveries for these target analytes acceptance criteria based on laboratory control charts.

(CCVIS 860-199354/2)

Method 625.1\_QQQ: The continuing calibration verification (CCV) associated with batch 860-199354 recovered above the upper control limit for Guthion, Diazinon and Malathion. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported. The associated sample is impacted: (CCV 860-199354/4).

Method 625.1\_QQQ: 2,2'-oxybis[1-chloropropane] was detected above the reporting limit (RL) in the method blank associated with preparation batch 860-199125 and analytical batch 860-199354 as well as in the following sample: (MB 860-199125/1-A). All affected samples were re-extracted and re-analyzed. Both sets of data have been reported.

Method 625.1\_QQQ: The method blank for preparation batch 860-199125 and analytical batch 860-199354 contained Phenol above the method detection limit. This target analyte concentration was less than half the reporting limit (1/2RL) in the method blank.

Method 625.1\_QQQ: The continuing calibration verification (CCV) associated with batch 860-200061 recovered above the upper control limit for Guthion and Diazinon. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported. The associated sample is impacted: (CCV 860-200061/4).

Method 625.1\_QQQ: The laboratory control sample and laboratory control sample duplicate (LCS/LCSD) for preparation batch 860-197815 and analytical batch 860-198704 recovered outside control limits for the following analytes: 4,6-Dinitro-2-methylphenol, Hexachloroethane, N-Nitrosodimethylamine, 1,2,4-Trichlorobenzene and Hexachlorobutadiene. The associated sample(s) was re-prepared and/or re-analyzed outside holding time.

Method 625.1\_QQQ: The laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) for preparation batch 860-197815 and analytical batch 860-198704 recovered outside control limits for the following analyte: Guthion. This analyte was biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Eurofins Houston

## Case Narrative

Client: Eastex Environmental Laboratory Inc.  
Project: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Job ID: 860-86090-1 (Continued)**

**Eurofins Houston**

Method 625.1\_QQQ: The laboratory control sample duplicate (LCSD) for preparation batch 860-197815 and analytical batch 860-198704 recovered outside control limits for the following analytes: Diazinon and Malathion. These analytes were biased high in the LCSD and were not detected in the associated samples; therefore, the data have been reported.

Method 625.1\_QQQ: The laboratory control sample and the laboratory control sample duplicate (LCS/LCSD) for preparation batch 860-199125 and analytical batch 860-199354 recovered outside control limits for the following analytes: 2,2'-oxybis[1-chloropropane], Dimethyl phthalate, 2,4-Dimethylphenol, 4,6-Dinitro-2-methylphenol, Hexachloroethane, N-Nitrosodimethylamine, 1,2,4-Trichlorobenzene and Hexachlorobutadiene. The associated sample(s) was re-prepared and/or re-analyzed outside holding time.

Method 625.1\_QQQ: The laboratory control sample and the laboratory control sample duplicate (LCS/LCSD) for preparation batch 860-199125 and analytical batch 860-199354 recovered outside control limits for the following analytes: Guthion, Chlorpyrifos, Demeton Total, Diazinon Ethyl Parathion and Malathion. The associated sample(s) was re-prepared and/or re-analyzed outside holding time.

Method 625.1\_QQQ: The following sample was diluted due to the nature of the sample matrix: Winnie Permit Renewal Eff PR Comp (860-86090-1). Elevated reporting limits (RLs) are provided.

Method 625.1\_QQQ: The following sample was re-prepared outside of preparation holding time due to initial analysis LCS/LCSD recoveries outside control limits (biased low): Winnie Permit Renewal Eff PR Comp (860-86090-1).

Method 625.1\_QQQ: Six surrogates are used for this analysis. The laboratory's SOP allows one acid and one base of these surrogates to be outside acceptance criteria without performing re-extraction/re-analysis. The following sample contained an allowable number of surrogate compounds outside limits: Winnie Permit Renewal Eff PR Comp (860-86090-1). These results have been reported and qualified.

Method D7065\_11: The reference method requires samples to be preserved to a pH of 1-2. The following sample Winnie Permit Renewal Eff PR Comp (860-86090-1) in preparation batch 280-674294 was received with insufficient preservation at a pH of 5. The sample was preserved to the appropriate pH in the laboratory.

Method D7065\_11: The following sample was diluted due to the nature of the sample matrix: Winnie Permit Renewal Eff PR Comp (860-86090-1). The samples were dark and orange in color, and a lower dilution had too much matrix interference in the chromatography. Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### GC Semi VOA

Method 615\_MOD: The RPD of the laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) for preparation batch 860-198654 and analytical batch 860-198926 recovered outside control limits for the following analytes: Dichloroprop and Silvex (2,4,5-TP).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Pesticides/PCBs

Method 608.3: The surrogate recovery for the laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) associated with preparation batch 860-197793 and analytical batch 860-197846 was outside the control limits.

(LCS 860-197793/4-A) and (LCSD 860-197793/5-A)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### HPLC/IC

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Houston

# Detection Summary

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Client Sample ID: Winnie Permit Renewal Eff PR Comp**

**Lab Sample ID: 860-86090-1**

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
2,6-Dinitrotoluene	0.237	J I	0.572	0.116	ug/L	1		625.1	Total/NA
Polychlorinated biphenyls, Total		NC	0.000503	0.000252	mg/L	1		608.3	Total/NA
Mercury	0.000537		0.000500	0.000290	ug/L	1		1631E	Total/NA

**Client Sample ID: Winnie Permit Renewal Eff PR Comp Hg  
Blank**

**Lab Sample ID: 860-86090-2**

No Detections.

5

This Detection Summary does not include radiochemical test results.

Eurofins Houston

# Client Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Client Sample ID: Winnie Permit Renewal Eff PR Comp**

**Lab Sample ID: 860-86090-1**

Date Collected: 10/31/24 08:00

Matrix: Water

Date Received: 11/04/24 07:34

**Method: EPA 625.1 - Semivolatile Organic Compounds (GC-MS/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Acenaphthene	<0.108	U	0.572	0.108	ug/L		11/05/24 09:15	11/09/24 19:46	1
Acenaphthylene	<0.0998	U	0.572	0.0998	ug/L		11/05/24 09:15	11/09/24 19:46	1
Diazinon	<0.0149	U	0.114	0.0149	ug/L		11/05/24 09:15	11/09/24 19:46	1
Anthracene	<0.0939	U	0.572	0.0939	ug/L		11/05/24 09:15	11/09/24 19:46	1
Demeton, Total	<0.0168	U	0.0572	0.0168	ug/L		11/05/24 09:15	11/09/24 19:46	1
Azobenzene	<0.104	U	0.572	0.104	ug/L		11/05/24 09:15	11/09/24 19:46	1
Benzidine	<0.0901	U	1.14	0.0901	ug/L		11/05/24 09:15	11/09/24 19:46	1
Benzo[a]anthracene	<0.00954	U	0.114	0.00954	ug/L		11/05/24 09:15	11/09/24 19:46	1
Disulfoton	<0.203	U	0.572	0.203	ug/L		11/05/24 09:15	11/09/24 19:46	1
Benzo[a]pyrene	<0.0100	U	0.114	0.0100	ug/L		11/05/24 09:15	11/09/24 19:46	1
Malathion	<0.0150	U	0.0572	0.0150	ug/L		11/05/24 09:15	11/09/24 19:46	1
Benzo[b]fluoranthene	<0.0665	U	0.572	0.0665	ug/L		11/05/24 09:15	11/09/24 19:46	1
Methyl parathion	<0.320	U	0.572	0.320	ug/L		11/05/24 09:15	11/09/24 19:46	1
Benzo[g,h,i]perylene	<0.0346	U	0.572	0.0346	ug/L		11/05/24 09:15	11/09/24 19:46	1
Benzo[k]fluoranthene	<0.0473	U	0.572	0.0473	ug/L		11/05/24 09:15	11/09/24 19:46	1
Bis(2-chloroethoxy)methane	<0.0976	U	0.572	0.0976	ug/L		11/05/24 09:15	11/09/24 19:46	1
Bis(2-chloroethyl)ether	<0.215	U	0.572	0.215	ug/L		11/05/24 09:15	11/09/24 19:46	1
Bis(2-ethylhexyl) phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 19:46	1
4-Bromophenyl phenyl ether	<0.100	U	0.572	0.100	ug/L		11/05/24 09:15	11/09/24 19:46	1
Butyl benzyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 19:46	1
4-Chloro-3-methylphenol	<0.104	U	0.572	0.104	ug/L		11/05/24 09:15	11/09/24 19:46	1
2-Chloronaphthalene	<0.379	U *	0.572	0.379	ug/L		11/05/24 09:15	11/09/24 19:46	1
2-Chlorophenol	<0.0757	U	0.572	0.0757	ug/L		11/05/24 09:15	11/09/24 19:46	1
4-Chlorophenyl phenyl ether	<0.131	U	0.572	0.131	ug/L		11/05/24 09:15	11/09/24 19:46	1
Chlorpyrifos	<0.0159	U	0.0572	0.0159	ug/L		11/05/24 09:15	11/09/24 19:46	1
Chrysene	<0.0817	U	0.572	0.0817	ug/L		11/05/24 09:15	11/09/24 19:46	1
Demeton, Total	<0.0168	U	0.0572	0.0168	ug/L		11/05/24 09:15	11/09/24 19:46	1
Diazinon	<0.0149	U *+	0.114	0.0149	ug/L		11/05/24 09:15	11/09/24 19:46	1
Dibenz(a,h)anthracene	<0.0510	U	0.114	0.0510	ug/L		11/05/24 09:15	11/09/24 19:46	1
1,2-Dichlorobenzene	<0.0942	U	0.572	0.0942	ug/L		11/05/24 09:15	11/09/24 19:46	1
1,3-Dichlorobenzene	<0.102	U	0.572	0.102	ug/L		11/05/24 09:15	11/09/24 19:46	1
1,4-Dichlorobenzene	<0.0780	U	0.572	0.0780	ug/L		11/05/24 09:15	11/09/24 19:46	1
3,3'-Dichlorobenzidine	<0.183	U	0.572	0.183	ug/L		11/05/24 09:15	11/09/24 19:46	1
2,4-Dichlorophenol	<0.140	U	0.572	0.140	ug/L		11/05/24 09:15	11/09/24 19:46	1
Diethyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 19:46	1
2,4-Dimethylphenol	<0.192	U	0.572	0.192	ug/L		11/05/24 09:15	11/09/24 19:46	1
Dimethyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 19:46	1
Di-n-butyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 19:46	1
4,6-Dinitro-2-methylphenol	<0.202	U *	1.14	0.202	ug/L		11/05/24 09:15	11/09/24 19:46	1
2,4-Dinitrophenol	<0.104	U	2.86	0.104	ug/L		11/05/24 09:15	11/09/24 19:46	1
2,4-Dinitrotoluene	<0.205	U	0.572	0.205	ug/L		11/05/24 09:15	11/09/24 19:46	1
<b>2,6-Dinitrotoluene</b>	<b>0.237</b>	<b>J I</b>	0.572	0.116	ug/L		11/05/24 09:15	11/09/24 19:46	1
Di-n-octyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 19:46	1
1,2-Diphenylhydrazine	<0.287	U	0.572	0.287	ug/L		11/05/24 09:15	11/09/24 19:46	1
Fluoranthene	<0.0884	U	0.572	0.0884	ug/L		11/05/24 09:15	11/09/24 19:46	1
Fluorene	<0.0950	U	0.572	0.0950	ug/L		11/05/24 09:15	11/09/24 19:46	1
Hexachlorobenzene	<0.0976	U	0.572	0.0976	ug/L		11/05/24 09:15	11/09/24 19:46	1
Hexachlorobutadiene	<0.103	U *	0.572	0.103	ug/L		11/05/24 09:15	11/09/24 19:46	1
Hexachlorocyclopentadiene	<0.0513	U	0.572	0.0513	ug/L		11/05/24 09:15	11/09/24 19:46	1

Eurofins Houston

# Client Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Client Sample ID: Winnie Permit Renewal Eff PR Comp**

**Lab Sample ID: 860-86090-1**

Date Collected: 10/31/24 08:00

Matrix: Water

Date Received: 11/04/24 07:34

**Method: EPA 625.1 - Semivolatile Organic Compounds (GC-MS/MS) (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hexachloroethane	<0.102	U *-	0.572	0.102	ug/L		11/05/24 09:15	11/09/24 19:46	1
Indeno[1,2,3-cd]pyrene	<0.100	U	0.572	0.100	ug/L		11/05/24 09:15	11/09/24 19:46	1
Isophorone	<0.107	U	0.572	0.107	ug/L		11/05/24 09:15	11/09/24 19:46	1
Malathion	<0.0150	U *+	0.0572	0.0150	ug/L		11/05/24 09:15	11/09/24 19:46	1
2-Methylphenol	<0.105	U	0.572	0.105	ug/L		11/05/24 09:15	11/09/24 19:46	1
m & p - Cresol	<0.139	U	0.572	0.139	ug/L		11/05/24 09:15	11/09/24 19:46	1
Naphthalene	<0.0946	U	0.572	0.0946	ug/L		11/05/24 09:15	11/09/24 19:46	1
Nitrobenzene	<0.0737	U	0.572	0.0737	ug/L		11/05/24 09:15	11/09/24 19:46	1
2-Nitrophenol	<0.136	U	0.572	0.136	ug/L		11/05/24 09:15	11/09/24 19:46	1
4-Nitrophenol	<0.135	U	0.572	0.135	ug/L		11/05/24 09:15	11/09/24 19:46	1
N-Nitrosodimethylamine	<0.100	U *-	0.572	0.100	ug/L		11/05/24 09:15	11/09/24 19:46	1
N-Nitrosodi-n-propylamine	<0.119	U	0.572	0.119	ug/L		11/05/24 09:15	11/09/24 19:46	1
N-Nitrosodiphenylamine	<0.145	U	0.572	0.145	ug/L		11/05/24 09:15	11/09/24 19:46	1
Pentachlorophenol	<1.04	U	1.14	1.04	ug/L		11/05/24 09:15	11/09/24 19:46	1
Phenanthrene	<0.134	U	0.572	0.134	ug/L		11/05/24 09:15	11/09/24 19:46	1
Phenol	<0.449	U	2.86	0.449	ug/L		11/05/24 09:15	11/09/24 19:46	1
Pyrene	<0.0850	U	0.572	0.0850	ug/L		11/05/24 09:15	11/09/24 19:46	1
Pyridine	<1.44	U	2.86	1.44	ug/L		11/05/24 09:15	11/09/24 19:46	1
1,2,4-Trichlorobenzene	<0.0767	U *-	0.572	0.0767	ug/L		11/05/24 09:15	11/09/24 19:46	1
2,4,6-Trichlorophenol	<0.231	U	0.572	0.231	ug/L		11/05/24 09:15	11/09/24 19:46	1
2,4,5-Trichlorophenol	<0.143	U	0.572	0.143	ug/L		11/05/24 09:15	11/09/24 19:46	1
N-Nitrosodi-n-butylamine	<0.516	U	1.14	0.516	ug/L		11/05/24 09:15	11/09/24 19:46	1
Pentachlorobenzene	<0.266	U	0.572	0.266	ug/L		11/05/24 09:15	11/09/24 19:46	1
1,2,4,5-Tetrachlorobenzene	<0.0959	U *-	0.572	0.0959	ug/L		11/05/24 09:15	11/09/24 19:46	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorobiphenyl	69		43 - 130	11/05/24 09:15	11/09/24 19:46	1
2-Fluorophenol (Surr)	65		19 - 120	11/05/24 09:15	11/09/24 19:46	1
Nitrobenzene-d5 (Surr)	94		37 - 133	11/05/24 09:15	11/09/24 19:46	1
Phenol-d5 (Surr)	47		8 - 124	11/05/24 09:15	11/09/24 19:46	1
p-Terphenyl-d14 (Surr)	58		47 - 130	11/05/24 09:15	11/09/24 19:46	1
2,4,6-Tribromophenol (Surr)	100		35 - 130	11/05/24 09:15	11/09/24 19:46	1
2-Fluorobiphenyl	69		43 - 130	11/05/24 09:15	11/09/24 19:46	1
2-Fluorophenol (Surr)	65		19 - 120	11/05/24 09:15	11/09/24 19:46	1
Nitrobenzene-d5 (Surr)	94		37 - 133	11/05/24 09:15	11/09/24 19:46	1
Phenol-d5 (Surr)	47		8 - 124	11/05/24 09:15	11/09/24 19:46	1
p-Terphenyl-d14 (Surr)	58		47 - 130	11/05/24 09:15	11/09/24 19:46	1
2,4,6-Tribromophenol (Surr)	100		35 - 130	11/05/24 09:15	11/09/24 19:46	1

**Method: EPA 625.1 - Semivolatile Organic Compounds (GC-MS/MS) - RA**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Guthion	<0.0162	U	0.0572	0.0162	ug/L		11/05/24 09:15	11/15/24 15:46	1
Ethyl Parathion	<0.0503	U	0.114	0.0503	ug/L		11/05/24 09:15	11/15/24 15:46	1
2,2'-oxybis[1-chloropropane]	<0.128	U	0.572	0.128	ug/L		11/05/24 09:15	11/15/24 15:46	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorobiphenyl	49		43 - 130	11/05/24 09:15	11/15/24 15:46	1
2-Fluorophenol (Surr)	46		19 - 120	11/05/24 09:15	11/15/24 15:46	1
Nitrobenzene-d5 (Surr)	58		37 - 133	11/05/24 09:15	11/15/24 15:46	1
Phenol-d5 (Surr)	27		8 - 124	11/05/24 09:15	11/15/24 15:46	1

Eurofins Houston

# Client Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Client Sample ID: Winnie Permit Renewal Eff PR Comp**

**Lab Sample ID: 860-86090-1**

Date Collected: 10/31/24 08:00

Matrix: Water

Date Received: 11/04/24 07:34

**Method: EPA 625.1 - Semivolatile Organic Compounds (GC-MS/MS) - RA (Continued)**

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
<i>p</i> -Terphenyl-d14 (Surr)	42	S1-	47 - 130	11/05/24 09:15	11/15/24 15:46	1
2,4,6-Tribromophenol (Surr)	64		35 - 130	11/05/24 09:15	11/15/24 15:46	1
2-Fluorobiphenyl	49		43 - 130	11/05/24 09:15	11/15/24 15:46	1
2-Fluorophenol (Surr)	46		19 - 120	11/05/24 09:15	11/15/24 15:46	1
Nitrobenzene-d5 (Surr)	58		37 - 133	11/05/24 09:15	11/15/24 15:46	1
Phenol-d5 (Surr)	27		8 - 124	11/05/24 09:15	11/15/24 15:46	1
<i>p</i> -Terphenyl-d14 (Surr)	42	S1-	47 - 130	11/05/24 09:15	11/15/24 15:46	1
2,4,6-Tribromophenol (Surr)	64		35 - 130	11/05/24 09:15	11/15/24 15:46	1

**Method: ASTM D7065-11 - Determination of Nonylphenols**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Nonylphenol	<6210	U	27300	6210	ng/L		11/08/24 11:36	11/11/24 17:25	5
Bisphenol-A	<5610	U	11400	5610	ng/L		11/08/24 11:36	11/11/24 17:25	5
4-tert-Octylphenol	<1530	U	5450	1530	ng/L		11/08/24 11:36	11/11/24 17:25	5

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-nonylphenol (Surr)	86		58 - 115	11/08/24 11:36	11/11/24 17:25	5
4-nonylphenol monoethoxylate (Surr)	137		54 - 139	11/08/24 11:36	11/11/24 17:25	5

**Method: EPA 608.3 - Organochlorine Pesticides/PCBs in Water**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Aldrin	<0.0000159	U	0.0000503	0.0000159	mg/L		11/05/24 07:55	11/05/24 14:10	1
alpha-BHC	<0.0000160	U	0.0000503	0.0000160	mg/L		11/05/24 07:55	11/05/24 14:10	1
beta-BHC	<0.0000173	U	0.0000503	0.0000173	mg/L		11/05/24 07:55	11/05/24 14:10	1
Chlordane (technical)	<0.000196	U	0.00101	0.000196	mg/L		11/05/24 07:55	11/05/24 14:10	1
cis-Chlordane	<0.0000189	U	0.0000503	0.0000189	mg/L		11/05/24 07:55	11/05/24 14:10	1
4,4'-DDD	<0.0000180	U	0.0000503	0.0000180	mg/L		11/05/24 07:55	11/05/24 14:10	1
4,4'-DDE	<0.0000162	U	0.0000503	0.0000162	mg/L		11/05/24 07:55	11/05/24 14:10	1
4,4'-DDT	<0.0000181	U	0.0000503	0.0000181	mg/L		11/05/24 07:55	11/05/24 14:10	1
delta-BHC	<0.00000879	U	0.0000503	0.0000087	mg/L		11/05/24 07:55	11/05/24 14:10	1
Dicofol	<0.0000252	U	0.0000252	0.0000252	mg/L		11/05/24 07:55	11/05/24 14:10	1
Dieldrin	<0.0000174	U	0.0000503	0.0000174	mg/L		11/05/24 07:55	11/05/24 14:10	1
Endosulfan I	<0.0000187	U	0.0000503	0.0000187	mg/L		11/05/24 07:55	11/05/24 14:10	1
Endosulfan II	<0.0000178	U	0.0000503	0.0000178	mg/L		11/05/24 07:55	11/05/24 14:10	1
Endosulfan sulfate	<0.0000153	U	0.0000503	0.0000153	mg/L		11/05/24 07:55	11/05/24 14:10	1
Endrin	<0.0000167	U	0.0000503	0.0000167	mg/L		11/05/24 07:55	11/05/24 14:10	1
Endrin aldehyde	<0.0000168	U	0.0000503	0.0000168	mg/L		11/05/24 07:55	11/05/24 14:10	1
Endrin ketone	<0.0000172	U	0.0000503	0.0000172	mg/L		11/05/24 07:55	11/05/24 14:10	1
gamma-BHC (Lindane)	<0.0000171	U	0.0000503	0.0000171	mg/L		11/05/24 07:55	11/05/24 14:10	1
Heptachlor	<0.0000279	U	0.0000503	0.0000279	mg/L		11/05/24 07:55	11/05/24 14:10	1
Heptachlor epoxide	<0.0000183	U	0.0000503	0.0000183	mg/L		11/05/24 07:55	11/05/24 14:10	1
Methoxychlor	<0.0000187	U	0.0000503	0.0000187	mg/L		11/05/24 07:55	11/05/24 14:10	1
Mirex	<0.0000252	U	0.0000252	0.0000252	mg/L		11/05/24 07:55	11/05/24 14:10	1
PCB-1016	<0.0000524	U	0.000252	0.0000524	mg/L		11/05/24 07:55	11/05/24 14:10	1
PCB-1221	<0.0000524	U	0.000503	0.0000524	mg/L		11/05/24 07:55	11/05/24 14:10	1
PCB-1232	<0.0000524	U	0.000503	0.0000524	mg/L		11/05/24 07:55	11/05/24 14:10	1
PCB-1242	<0.0000524	U	0.000252	0.0000524	mg/L		11/05/24 07:55	11/05/24 14:10	1
PCB-1248	<0.0000524	U	0.000503	0.0000524	mg/L		11/05/24 07:55	11/05/24 14:10	1
PCB-1254	<0.0000659	U	0.000503	0.0000659	mg/L		11/05/24 07:55	11/05/24 14:10	1

Eurofins Houston

# Client Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Client Sample ID: Winnie Permit Renewal Eff PR Comp**

**Lab Sample ID: 860-86090-1**

Date Collected: 10/31/24 08:00

Matrix: Water

Date Received: 11/04/24 07:34

**Method: EPA 608.3 - Organochlorine Pesticides/PCBs in Water (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
PCB-1260	<0.0000659	U	0.000252	0.0000659	mg/L		11/05/24 07:55	11/05/24 14:10	1
<b>Polychlorinated biphenyls, Total</b>	<b>NC</b>		0.000503	0.000252	mg/L		11/05/24 07:55	11/05/24 14:10	1
Toxaphene	<0.000339	U	0.00101	0.000339	mg/L		11/05/24 07:55	11/05/24 14:10	1
trans-Chlordane	<0.0000190	U	0.0000503	0.0000190	mg/L		11/05/24 07:55	11/05/24 14:10	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
DCB Decachlorobiphenyl (Surr)	45		45 - 115				11/05/24 07:55	11/05/24 14:10	1
Tetrachloro-m-xylene	60		41 - 110				11/05/24 07:55	11/05/24 14:10	1

**Method: EPA-01 615 - Herbicides (GC)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4-D	<0.0000542	U	0.000201	0.0000542	mg/L		11/07/24 14:32	11/11/24 12:25	1
2,4-DB	<0.0000496	U	0.000201	0.0000496	mg/L		11/07/24 14:32	11/11/24 12:25	1
Silvex (2,4,5-TP)	<0.0000425	U *1	0.000201	0.0000425	mg/L		11/07/24 14:32	11/11/24 12:25	1
2,4,5-T	<0.0000395	U	0.000201	0.0000395	mg/L		11/07/24 14:32	11/11/24 12:25	1
Dalapon	<0.0000479	U	0.000201	0.0000479	mg/L		11/07/24 14:32	11/11/24 12:25	1
Dicamba	<0.0000426	U	0.000201	0.0000426	mg/L		11/07/24 14:32	11/11/24 12:25	1
Dichlorprop	<0.0000530	U *1	0.000201	0.0000530	mg/L		11/07/24 14:32	11/11/24 12:25	1
Dinoseb	<0.0000345	U	0.000201	0.0000345	mg/L		11/07/24 14:32	11/11/24 12:25	1
MCPA	<0.00529	U	0.0201	0.00529	mg/L		11/07/24 14:32	11/11/24 12:25	1
MCPP	<0.0100	U	0.0201	0.0100	mg/L		11/07/24 14:32	11/11/24 12:25	1
Pentachlorophenol	<0.0000446	U	0.000201	0.0000446	mg/L		11/07/24 14:32	11/11/24 12:25	1
Hexachlorophene	<0.000813	U	0.00503	0.000813	mg/L		11/07/24 14:32	11/11/24 12:25	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
2,4-Dichlorophenylacetic acid	49		45 - 150				11/07/24 14:32	11/11/24 12:25	1

**Method: EPA-01 632 - Carbamate and Urea Pesticides (HPLC)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Carbaryl	<1.85	U	5.00	1.85	ug/L		11/04/24 14:31	11/07/24 17:41	1
Diuron	<0.0514	U	0.0900	0.0514	ug/L		11/04/24 14:31	11/07/24 17:41	1

**Method: EPA 1631E - Mercury, Low Level (CVAFS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	0.000537		0.000500	0.000290	ug/L			11/06/24 16:36	1

**Client Sample ID: Winnie Permit Renewal Eff PR Comp Hg**

**Lab Sample ID: 860-86090-2**

**Blank**

Date Collected: 10/31/24 08:00

Matrix: Water

Date Received: 11/04/24 07:34

**Method: EPA 1631E - Mercury, Low Level (CVAFS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.000290	U	0.000500	0.000290	ug/L			11/06/24 17:27	1

## Surrogate Summary

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)							
		FBP (43-130)	FBP (43-130)	2FP (19-120)	2FP (19-120)	NBZ (37-133)	NBZ (37-133)	PHL (8-124)	PHL (8-124)
860-86090-1	Winnie Permit Renewal Eff PR C	69	69	65	65	94	94	47	47
860-86090-1 - RA	Winnie Permit Renewal Eff PR Comp	49	49	46	46	58	58	27	27
LCS 860-197815/2-A	Lab Control Sample	83	83	42	42	93	93	32	32
LCS 860-197815/4-A	Lab Control Sample	79	79	38	38	95	95	34	34
LCSD 860-197815/3-A	Lab Control Sample Dup	83	83	45	45	98	98	33	33
LCSD 860-197815/5-A	Lab Control Sample Dup	84	84	34	34	104	104	30	30
MB 860-197815/1-A	Method Blank	86	86	44	44	93	93	32	32

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		TPHd14 (47-130)	TPHd14 (47-130)	TBP (35-130)	TBP (35-130)
860-86090-1	Winnie Permit Renewal Eff PR C	58	58	100	100
860-86090-1 - RA	Winnie Permit Renewal Eff PR Comp	42 S1-	42 S1-	64	64
LCS 860-197815/2-A	Lab Control Sample	76	76	75	75
LCS 860-197815/4-A	Lab Control Sample	72	72	68	68
LCSD 860-197815/3-A	Lab Control Sample Dup	78	78	75	75
LCSD 860-197815/5-A	Lab Control Sample Dup	79	79	68	68
MB 860-197815/1-A	Method Blank	76	76	80	80

**Surrogate Legend**

FBP = 2-Fluorobiphenyl  
2FP = 2-Fluorophenol (Surr)  
NBZ = Nitrobenzene-d5 (Surr)  
PHL = Phenol-d5 (Surr)  
TPHd14 = p-Terphenyl-d14 (Surr)  
TBP = 2,4,6-Tribromophenol (Surr)

### Method: D7065-11 - Determination of Nonylphenols

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)	
		4NPH (58-115)	4NPME (54-139)
860-86090-1	Winnie Permit Renewal Eff PR C	86	137
LCS 280-674294/2-A	Lab Control Sample	87	92
LCSD 280-674294/3-A	Lab Control Sample Dup	89	92
MB 280-674294/1-A	Method Blank	67	55

**Surrogate Legend**

4NPH = 4-nonylphenol (Surr)  
4NPME = 4-nonylphenol monoethoxylate (Surr)

### Method: 608.3 - Organochlorine Pesticides/PCBs in Water

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)	
		DCB1 (45-115)	TCX1 (41-110)
860-86090-1	Winnie Permit Renewal Eff PR C	45	60
LCS 860-197793/2-A	Lab Control Sample	50	60
LCS 860-197793/4-A	Lab Control Sample	38 S1-	58

Eurofins Houston

## Surrogate Summary

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 608.3 - Organochlorine Pesticides/PCBs in Water (Continued)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)	
		DCB1 (45-115)	TCX1 (41-110)
LCSD 860-197793/3-A	Lab Control Sample Dup	50	61
LCSD 860-197793/5-A	Lab Control Sample Dup	40 S1-	62
MB 860-197793/1-A	Method Blank	69	61

**Surrogate Legend**

DCB = DCB Decachlorobiphenyl (Surr)  
 TCX = Tetrachloro-m-xylene

### Method: 615 - Herbicides (GC)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		DCPAA1 (45-150)
860-86090-1	Winnie Permit Renewal Eff PR C	49
LCS 860-198654/2-A	Lab Control Sample	81
LCS 860-198654/4-A	Lab Control Sample	79
LCSD 860-198654/3-A	Lab Control Sample Dup	105
LCSD 860-198654/5-A	Lab Control Sample Dup	64
MB 860-198654/1-A	Method Blank	87

**Surrogate Legend**

DCPAA = 2,4-Dichlorophenylacetic acid

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS)

Lab Sample ID: MB 860-197815/1-A

Matrix: Water

Analysis Batch: 198704

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 197815

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Acenaphthene	<0.107	U	0.571	0.107	ug/L		11/05/24 09:15	11/09/24 09:21	1
Acenaphthylene	<0.0996	U	0.571	0.0996	ug/L		11/05/24 09:15	11/09/24 09:21	1
Anthracene	<0.0938	U	0.571	0.0938	ug/L		11/05/24 09:15	11/09/24 09:21	1
Azobenzene	<0.104	U	0.571	0.104	ug/L		11/05/24 09:15	11/09/24 09:21	1
Benzidine	<0.0900	U	1.14	0.0900	ug/L		11/05/24 09:15	11/09/24 09:21	1
Benzo[a]anthracene	<0.00953	U	0.114	0.00953	ug/L		11/05/24 09:15	11/09/24 09:21	1
Disulfoton	<0.203	U	0.571	0.203	ug/L		11/05/24 09:15	11/09/24 09:21	1
Benzo[a]pyrene	<0.0100	U	0.114	0.0100	ug/L		11/05/24 09:15	11/09/24 09:21	1
Benzo[b]fluoranthene	<0.0664	U	0.571	0.0664	ug/L		11/05/24 09:15	11/09/24 09:21	1
Methyl parathion	<0.319	U	0.571	0.319	ug/L		11/05/24 09:15	11/09/24 09:21	1
Benzo[g,h,i]perylene	<0.0345	U	0.571	0.0345	ug/L		11/05/24 09:15	11/09/24 09:21	1
Benzo[k]fluoranthene	<0.0473	U	0.571	0.0473	ug/L		11/05/24 09:15	11/09/24 09:21	1
Bis(2-chloroethoxy)methane	<0.0974	U	0.571	0.0974	ug/L		11/05/24 09:15	11/09/24 09:21	1
Bis(2-chloroethyl)ether	<0.214	U	0.571	0.214	ug/L		11/05/24 09:15	11/09/24 09:21	1
Bis(2-ethylhexyl) phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 09:21	1
4-Bromophenyl phenyl ether	<0.100	U	0.571	0.100	ug/L		11/05/24 09:15	11/09/24 09:21	1
Butyl benzyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 09:21	1
4-Chloro-3-methylphenol	<0.104	U	0.571	0.104	ug/L		11/05/24 09:15	11/09/24 09:21	1
2-Chloronaphthalene	<0.378	U	0.571	0.378	ug/L		11/05/24 09:15	11/09/24 09:21	1
2-Chlorophenol	<0.0756	U	0.571	0.0756	ug/L		11/05/24 09:15	11/09/24 09:21	1
4-Chlorophenyl phenyl ether	<0.130	U	0.571	0.130	ug/L		11/05/24 09:15	11/09/24 09:21	1
Chlorpyrifos	<0.0159	U	0.0571	0.0159	ug/L		11/05/24 09:15	11/09/24 09:21	1
Chrysene	<0.0815	U	0.571	0.0815	ug/L		11/05/24 09:15	11/09/24 09:21	1
Demeton, Total	<0.0168	U	0.0571	0.0168	ug/L		11/05/24 09:15	11/09/24 09:21	1
Diazinon	<0.0148	U	0.114	0.0148	ug/L		11/05/24 09:15	11/09/24 09:21	1
Dibenz(a,h)anthracene	<0.0509	U	0.114	0.0509	ug/L		11/05/24 09:15	11/09/24 09:21	1
1,2-Dichlorobenzene	<0.0941	U	0.571	0.0941	ug/L		11/05/24 09:15	11/09/24 09:21	1
1,3-Dichlorobenzene	<0.102	U	0.571	0.102	ug/L		11/05/24 09:15	11/09/24 09:21	1
1,4-Dichlorobenzene	<0.0779	U	0.571	0.0779	ug/L		11/05/24 09:15	11/09/24 09:21	1
3,3'-Dichlorobenzidine	<0.183	U	0.571	0.183	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,4-Dichlorophenol	<0.140	U	0.571	0.140	ug/L		11/05/24 09:15	11/09/24 09:21	1
Diethyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,4-Dimethylphenol	<0.192	U	0.571	0.192	ug/L		11/05/24 09:15	11/09/24 09:21	1
Dimethyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 09:21	1
Di-n-butyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 09:21	1
4,6-Dinitro-2-methylphenol	<0.201	U	1.14	0.201	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,4-Dinitrophenol	<0.104	U	2.86	0.104	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,4-Dinitrotoluene	<0.205	U	0.571	0.205	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,6-Dinitrotoluene	<0.116	U	0.571	0.116	ug/L		11/05/24 09:15	11/09/24 09:21	1
Di-n-octyl phthalate	<1.43	U	2.86	1.43	ug/L		11/05/24 09:15	11/09/24 09:21	1
1,2-Diphenylhydrazine	<0.286	U	0.571	0.286	ug/L		11/05/24 09:15	11/09/24 09:21	1
Ethyl Parathion	<0.0502	U	0.114	0.0502	ug/L		11/05/24 09:15	11/09/24 09:21	1
Fluoranthene	<0.0883	U	0.571	0.0883	ug/L		11/05/24 09:15	11/09/24 09:21	1
Fluorene	<0.0948	U	0.571	0.0948	ug/L		11/05/24 09:15	11/09/24 09:21	1
Guthion	<0.0162	U	0.0571	0.0162	ug/L		11/05/24 09:15	11/09/24 09:21	1
Hexachlorobenzene	<0.0975	U	0.571	0.0975	ug/L		11/05/24 09:15	11/09/24 09:21	1
Hexachlorobutadiene	<0.103	U	0.571	0.103	ug/L		11/05/24 09:15	11/09/24 09:21	1
Hexachlorocyclopentadiene	<0.0512	U	0.571	0.0512	ug/L		11/05/24 09:15	11/09/24 09:21	1

8

Eurofins Houston

# QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

## Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS) (Continued)

Lab Sample ID: MB 860-197815/1-A  
 Matrix: Water  
 Analysis Batch: 198704

Client Sample ID: Method Blank  
 Prep Type: Total/NA  
 Prep Batch: 197815

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Hexachloroethane	<0.102	U	0.571	0.102	ug/L		11/05/24 09:15	11/09/24 09:21	1
Indeno[1,2,3-cd]pyrene	<0.100	U	0.571	0.100	ug/L		11/05/24 09:15	11/09/24 09:21	1
Isophorone	<0.107	U	0.571	0.107	ug/L		11/05/24 09:15	11/09/24 09:21	1
Malathion	<0.0150	U	0.0571	0.0150	ug/L		11/05/24 09:15	11/09/24 09:21	1
2-Methylphenol	<0.105	U	0.571	0.105	ug/L		11/05/24 09:15	11/09/24 09:21	1
m & p - Cresol	<0.139	U	0.571	0.139	ug/L		11/05/24 09:15	11/09/24 09:21	1
Naphthalene	<0.0944	U	0.571	0.0944	ug/L		11/05/24 09:15	11/09/24 09:21	1
Nitrobenzene	<0.0736	U	0.571	0.0736	ug/L		11/05/24 09:15	11/09/24 09:21	1
2-Nitrophenol	<0.136	U	0.571	0.136	ug/L		11/05/24 09:15	11/09/24 09:21	1
4-Nitrophenol	<0.135	U	0.571	0.135	ug/L		11/05/24 09:15	11/09/24 09:21	1
N-Nitrosodimethylamine	<0.100	U	0.571	0.100	ug/L		11/05/24 09:15	11/09/24 09:21	1
N-Nitrosodi-n-propylamine	<0.119	U	0.571	0.119	ug/L		11/05/24 09:15	11/09/24 09:21	1
N-Nitrosodiphenylamine	<0.145	U	0.571	0.145	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,2'-oxybis[1-chloropropane]	<0.128	U	0.571	0.128	ug/L		11/05/24 09:15	11/09/24 09:21	1
Pentachlorophenol	<1.04	U	1.14	1.04	ug/L		11/05/24 09:15	11/09/24 09:21	1
Phenanthrene	<0.134	U	0.571	0.134	ug/L		11/05/24 09:15	11/09/24 09:21	1
Phenol	<0.448	U	2.86	0.448	ug/L		11/05/24 09:15	11/09/24 09:21	1
Pyrene	<0.0849	U	0.571	0.0849	ug/L		11/05/24 09:15	11/09/24 09:21	1
Pyridine	<1.44	U	2.86	1.44	ug/L		11/05/24 09:15	11/09/24 09:21	1
1,2,4-Trichlorobenzene	<0.0766	U	0.571	0.0766	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,4,6-Trichlorophenol	<0.231	U	0.571	0.231	ug/L		11/05/24 09:15	11/09/24 09:21	1
2,4,5-Trichlorophenol	<0.143	U	0.571	0.143	ug/L		11/05/24 09:15	11/09/24 09:21	1
N-Nitrosodi-n-butylamine	<0.516	U	1.14	0.516	ug/L		11/05/24 09:15	11/09/24 09:21	1
Pentachlorobenzene	<0.266	U	0.571	0.266	ug/L		11/05/24 09:15	11/09/24 09:21	1
1,2,4,5-Tetrachlorobenzene	<0.0957	U	0.571	0.0957	ug/L		11/05/24 09:15	11/09/24 09:21	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
2-Fluorobiphenyl	86		43 - 130	11/05/24 09:15	11/09/24 09:21	1
2-Fluorophenol (Surr)	44		19 - 120	11/05/24 09:15	11/09/24 09:21	1
Nitrobenzene-d5 (Surr)	93		37 - 133	11/05/24 09:15	11/09/24 09:21	1
Phenol-d5 (Surr)	32		8 - 124	11/05/24 09:15	11/09/24 09:21	1
p-Terphenyl-d14 (Surr)	76		47 - 130	11/05/24 09:15	11/09/24 09:21	1
2,4,6-Tribromophenol (Surr)	80		35 - 130	11/05/24 09:15	11/09/24 09:21	1

Lab Sample ID: LCS 860-197815/2-A  
 Matrix: Water  
 Analysis Batch: 198704

Client Sample ID: Lab Control Sample  
 Prep Type: Total/NA  
 Prep Batch: 197815

Analyte	Spike Added	LCS LCS		Unit	D	%Rec	Limits
		Result	Qualifier				
Acenaphthene	2.86	2.175		ug/L		76	60 - 132
Acenaphthylene	2.86	2.108		ug/L		74	54 - 126
Anthracene	2.86	2.421		ug/L		85	43 - 120
Azobenzene	2.86	2.239		ug/L		78	63 - 130
Benzidine	2.86	0.6322	J	ug/L		22	11 - 110
Benzo[a]anthracene	2.86	2.773		ug/L		97	42 - 133
Benzo[a]pyrene	2.86	2.532		ug/L		89	32 - 148
Benzo[b]fluoranthene	2.86	2.633		ug/L		92	42 - 140
Benzo[g,h,i]perylene	2.86	2.311		ug/L		81	25 - 195

Eurofins Houston

# QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

## Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS) (Continued)

Lab Sample ID: LCS 860-197815/2-A

Matrix: Water

Analysis Batch: 198704

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 197815

%Rec

Limits

Analyte	Spike	LCS	LCS	Unit	D	%Rec	Limits
	Added	Result	Qualifier				
Benzo[k]fluoranthene	2.86	2.656		ug/L		93	25 - 146
Bis(2-chloroethoxy)methane	2.86	2.422		ug/L		85	49 - 165
Bis(2-chloroethyl)ether	2.86	2.416		ug/L		85	43 - 126
Bis(2-ethylhexyl) phthalate	2.86	2.451	J	ug/L		86	29 - 137
4-Bromophenyl phenyl ether	2.86	2.509		ug/L		88	65 - 120
Butyl benzyl phthalate	2.86	2.251	J	ug/L		79	70 - 130
4-Chloro-3-methylphenol	2.86	2.378		ug/L		83	41 - 128
2-Chloronaphthalene	2.86	1.855		ug/L		65	65 - 120
2-Chlorophenol	2.86	2.181		ug/L		76	36 - 120
4-Chlorophenyl phenyl ether	2.86	2.202		ug/L		77	38 - 145
Chrysene	2.86	2.617		ug/L		92	47 - 130
Dibenz(a,h)anthracene	2.86	2.346		ug/L		82	32 - 200
1,2-Dichlorobenzene	2.86	1.117		ug/L		39	32 - 130
1,3-Dichlorobenzene	2.86	1.019		ug/L		36	26 - 130
1,4-Dichlorobenzene	2.86	1.057		ug/L		37	28 - 130
3,3'-Dichlorobenzidine	2.86	1.942		ug/L		68	20 - 150
2,4-Dichlorophenol	2.86	2.213		ug/L		77	53 - 122
Diethyl phthalate	2.86	2.234	J	ug/L		78	62 - 120
2,4-Dimethylphenol	2.86	2.175		ug/L		76	42 - 120
Dimethyl phthalate	2.86	2.543	J	ug/L		89	67 - 120
Di-n-butyl phthalate	2.86	2.358	J	ug/L		83	8 - 120
4,6-Dinitro-2-methylphenol	2.86	0.6596	J *-	ug/L		23	53 - 130
2,4-Dinitrophenol	2.86	0.8248	J	ug/L		29	26 - 173
2,4-Dinitrotoluene	2.86	3.005		ug/L		105	48 - 127
2,6-Dinitrotoluene	2.86	3.105		ug/L		109	68 - 137
Di-n-octyl phthalate	2.86	2.330	J	ug/L		82	19 - 132
1,2-Diphenylhydrazine	2.86	2.034		ug/L		71	48 - 130
Fluoranthene	2.86	2.510		ug/L		88	43 - 121
Fluorene	2.86	2.389		ug/L		84	70 - 120
Hexachlorobenzene	2.86	2.395		ug/L		84	8 - 142
Hexachlorobutadiene	2.86	0.7090	*-	ug/L		25	38 - 120
Hexachlorocyclopentadiene	2.86	0.5757		ug/L		20	10 - 130
Hexachloroethane	2.86	0.6994	*-	ug/L		24	55 - 120
Indeno[1,2,3-cd]pyrene	2.86	2.258		ug/L		79	29 - 151
Isophorone	2.86	2.692		ug/L		94	47 - 180
2-Methylphenol	2.86	1.970		ug/L		69	14 - 176
m & p - Cresol	2.86	1.965		ug/L		69	22 - 130
Naphthalene	2.86	1.698		ug/L		59	36 - 120
Nitrobenzene	2.86	2.574		ug/L		90	54 - 130
2-Nitrophenol	2.86	2.349		ug/L		82	45 - 167
4-Nitrophenol	2.86	0.5075	J	ug/L		18	13 - 129
N-Nitrosodimethylamine	2.86	0.6288	*-	ug/L		22	30 - 130
N-Nitrosodi-n-propylamine	2.86	2.364		ug/L		83	14 - 198
N-Nitrosodiphenylamine	2.86	2.580		ug/L		90	60 - 130
2,2'-oxybis[1-chloropropane]	2.86	2.068		ug/L		72	63 - 139
Pentachlorophenol	2.86	1.318		ug/L		46	38 - 152
Phenanthrene	2.86	2.568		ug/L		90	65 - 120
Phenol	2.86	1.080	J I	ug/L		38	17 - 120
Pyrene	2.86	2.524		ug/L		88	70 - 120

Eurolins Houston

8

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS) (Continued)

Lab Sample ID: LCS 860-197815/2-A

Matrix: Water

Analysis Batch: 198704

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 197815

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Pyridine	2.86	<1.44	U	ug/L		15	1 - 126
1,2,4-Trichlorobenzene	2.86	1.123	*-	ug/L		39	57 - 130
2,4,6-Trichlorophenol	2.86	1.805		ug/L		63	52 - 129
2,4,5-Trichlorophenol	2.86	2.482		ug/L		87	35 - 130
N-Nitrosodi-n-butylamine	2.86	2.524		ug/L		88	58 - 130
Pentachlorobenzene	2.86	2.327		ug/L		81	47 - 130
1,2,4,5-Tetrachlorobenzene	2.86	1.313	*-	ug/L		46	52 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2-Fluorobiphenyl	83		43 - 130
2-Fluorophenol (Surr)	42		19 - 120
Nitrobenzene-d5 (Surr)	93		37 - 133
Phenol-d5 (Surr)	32		8 - 124
p-Terphenyl-d14 (Surr)	76		47 - 130
2,4,6-Tribromophenol (Surr)	75		35 - 130

Lab Sample ID: LCS 860-197815/4-A

Matrix: Water

Analysis Batch: 198704

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 197815

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Demeton-O	0.857	1.188		ug/L		139	50 - 150
Demeton-S	2.00	2.096		ug/L		105	50 - 150
Disulfoton	5.71	5.380		ug/L		94	38 - 134
Methyl parathion	5.71	5.765		ug/L		101	26 - 159
Chlorpyrifos	2.86	2.949		ug/L		103	34 - 130
Diazinon	2.86	3.636		ug/L		127	37 - 130
Ethyl Parathion	2.86	3.597		ug/L		126	25 - 173
Guthion	2.86	6.026	*+	ug/L		211	70 - 200
Malathion	2.86	3.944		ug/L		138	50 - 150
N-Nitrosodi-n-butylamine	11.4	9.483		ug/L		83	58 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2-Fluorobiphenyl	79		43 - 130
2-Fluorophenol (Surr)	38		19 - 120
Nitrobenzene-d5 (Surr)	95		37 - 133
Phenol-d5 (Surr)	34		8 - 124
p-Terphenyl-d14 (Surr)	72		47 - 130
2,4,6-Tribromophenol (Surr)	68		35 - 130

Lab Sample ID: LCSD 860-197815/3-A

Matrix: Water

Analysis Batch: 198704

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 197815

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Acenaphthene	2.86	2.213		ug/L		77	60 - 132	2	29
Acenaphthylene	2.86	2.279		ug/L		80	54 - 126	8	30
Anthracene	2.86	2.468		ug/L		86	43 - 120	2	30

Eurofins Houston

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS) (Continued)

Lab Sample ID: LCSD 860-197815/3-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 198704

Prep Batch: 197815

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	Limit
							Limits	RPD		
Azobenzene	2.86	2.267		ug/L		79	63 - 130	1	30	
Benzenidine	2.86	0.7024	J	ug/L		25	11 - 110	11	30	
Benzo[a]anthracene	2.86	2.916		ug/L		102	42 - 133	5	30	
Benzo[a]pyrene	2.86	2.706		ug/L		95	32 - 148	7	30	
Benzo[b]fluoranthene	2.86	2.845		ug/L		100	42 - 140	8	30	
Benzo[g,h,i]perylene	2.86	2.457		ug/L		86	25 - 195	6	30	
Benzo[k]fluoranthene	2.86	2.877		ug/L		101	25 - 146	8	30	
Bis(2-chloroethoxy)methane	2.86	2.581		ug/L		90	49 - 165	6	30	
Bis(2-chloroethyl)ether	2.86	2.435		ug/L		85	43 - 126	1	30	
Bis(2-ethylhexyl) phthalate	2.86	2.655	J	ug/L		93	29 - 137	8	30	
4-Bromophenyl phenyl ether	2.86	2.459		ug/L		86	65 - 120	2	26	
Butyl benzyl phthalate	2.86	2.317	J	ug/L		81	70 - 130	3	30	
4-Chloro-3-methylphenol	2.86	2.491		ug/L		87	41 - 128	5	30	
2-Chloronaphthalene	2.86	1.832	*-	ug/L		64	65 - 120	1	15	
2-Chlorophenol	2.86	2.318		ug/L		81	36 - 120	6	30	
4-Chlorophenyl phenyl ether	2.86	2.239		ug/L		78	38 - 145	2	30	
Chrysene	2.86	2.785		ug/L		97	47 - 130	6	30	
Dibenz(a,h)anthracene	2.86	2.465		ug/L		86	32 - 200	5	30	
1,2-Dichlorobenzene	2.86	1.189		ug/L		42	32 - 130	6	30	
1,3-Dichlorobenzene	2.86	1.049		ug/L		37	26 - 130	3	30	
1,4-Dichlorobenzene	2.86	1.085		ug/L		38	28 - 130	3	30	
3,3'-Dichlorobenzidine	2.86	2.122		ug/L		74	20 - 150	9	30	
2,4-Dichlorophenol	2.86	2.291		ug/L		80	53 - 122	3	30	
Diethyl phthalate	2.86	2.309	J	ug/L		81	62 - 120	3	30	
2,4-Dimethylphenol	2.86	2.312		ug/L		81	42 - 120	6	30	
Dimethyl phthalate	2.86	2.634	J	ug/L		92	67 - 120	4	30	
Di-n-butyl phthalate	2.86	2.498	J	ug/L		87	8 - 120	6	28	
4,6-Dinitro-2-methylphenol	2.86	0.7993	J I *-	ug/L		28	53 - 130	19	30	
2,4-Dinitrophenol	2.86	0.7924	J I	ug/L		28	26 - 173	4	30	
2,4-Dinitrotoluene	2.86	3.077		ug/L		108	48 - 127	2	25	
2,6-Dinitrotoluene	2.86	3.092		ug/L		108	68 - 137	0	29	
Di-n-octyl phthalate	2.86	2.472	J	ug/L		87	19 - 132	6	30	
1,2-Diphenylhydrazine	2.86	2.278		ug/L		80	48 - 130	11	30	
Fluoranthene	2.86	2.643		ug/L		92	43 - 121	5	30	
Fluorene	2.86	2.458		ug/L		86	70 - 120	3	23	
Hexachlorobenzene	2.86	2.544		ug/L		89	8 - 142	6	30	
Hexachlorobutadiene	2.86	0.7703	*-	ug/L		27	38 - 120	8	30	
Hexachlorocyclopentadiene	2.86	0.5738		ug/L		20	10 - 130	0	30	
Hexachloroethane	2.86	0.7216	*-	ug/L		25	55 - 120	3	30	
Indeno[1,2,3-cd]pyrene	2.86	2.382		ug/L		83	29 - 151	5	30	
Isophorone	2.86	2.772		ug/L		97	47 - 180	3	30	
2-Methylphenol	2.86	1.969		ug/L		69	14 - 176	0	30	
m & p - Cresol	2.86	2.143		ug/L		75	22 - 130	9	30	
Naphthalene	2.86	1.706		ug/L		60	36 - 120	1	30	
Nitrobenzene	2.86	2.720		ug/L		95	54 - 130	6	30	
2-Nitrophenol	2.86	2.481		ug/L		87	45 - 167	5	30	
4-Nitrophenol	2.86	0.4121	J	ug/L		14	13 - 129	21	30	
N-Nitrosodimethylamine	2.86	0.6823	*-	ug/L		24	30 - 130	8	30	
N-Nitrosodi-n-propylamine	2.86	2.683		ug/L		94	14 - 198	13	30	

Eurofins Houston

8

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS) (Continued)

Lab Sample ID: LCSD 860-197815/3-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 198704

Prep Batch: 197815

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD
									Limit
N-Nitrosodiphenylamine	2.86	2.684		ug/L		94	60 - 130	4	30
2,2'-oxybis[1-chloropropane]	2.86	2.079		ug/L		73	63 - 139	1	30
Pentachlorophenol	2.86	1.402		ug/L		49	38 - 152	6	30
Phenanthrene	2.86	2.615		ug/L		92	65 - 120	2	24
Phenol	2.86	1.044	J	ug/L		37	17 - 120	3	30
Pyrene	2.86	2.750		ug/L		96	70 - 120	9	30
Pyridine	2.86	<1.44	U	ug/L		16	1 - 126	3	30
1,2,4-Trichlorobenzene	2.86	1.209	*-	ug/L		42	57 - 130	7	30
2,4,6-Trichlorophenol	2.86	1.817		ug/L		64	52 - 129	1	30
2,4,5-Trichlorophenol	2.86	2.232		ug/L		78	35 - 130	11	30
N-Nitrosodi-n-butylamine	2.86	2.621		ug/L		92	58 - 130	4	30
Pentachlorobenzene	2.86	2.207		ug/L		77	47 - 130	5	30
1,2,4,5-Tetrachlorobenzene	2.86	1.384	*-	ug/L		48	52 - 130	5	30

Surrogate	%Recovery	LCSD Qualifier	LCSD Limits
2-Fluorophenol (Surr)	45		19 - 120
Nitrobenzene-d5 (Surr)	98		37 - 133
Phenol-d5 (Surr)	33		8 - 124
p-Terphenyl-d14 (Surr)	78		47 - 130
2,4,6-Tribromophenol (Surr)	75		35 - 130

Lab Sample ID: LCSD 860-197815/5-A

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 198704

Prep Batch: 197815

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD
									Limit
Demeton-O	0.857	1.287		ug/L		150	50 - 150	8	30
Demeton-S	2.00	2.533		ug/L		127	50 - 150	19	30
Disulfoton	5.71	6.372		ug/L		112	38 - 134	17	30
Methyl parathion	5.71	6.768		ug/L		118	26 - 159	16	30
Chlorpyrifos	2.86	3.628		ug/L		127	34 - 130	21	30
Diazinon	2.86	4.421	*+	ug/L		155	37 - 130	19	30
Ethyl Parathion	2.86	4.581		ug/L		160	25 - 173	24	30
Guthion	2.86	6.666	*+	ug/L		233	70 - 200	10	30
Malathion	2.86	4.964	*+	ug/L		174	50 - 150	23	30
N-Nitrosodi-n-butylamine	11.4	12.02		ug/L		105	58 - 130	24	30

Surrogate	%Recovery	LCSD Qualifier	LCSD Limits
2-Fluorophenol (Surr)	34		19 - 120
Nitrobenzene-d5 (Surr)	104		37 - 133
Phenol-d5 (Surr)	30		8 - 124
p-Terphenyl-d14 (Surr)	79		47 - 130
2,4,6-Tribromophenol (Surr)	68		35 - 130

Eurofins Houston

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 625.1 - Semivolatile Organic Compounds (GC-MS/MS) (Continued)

**Lab Sample ID: MB 860-199125/1-A**  
**Matrix: Water**  
**Analysis Batch: 199354**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 199125**

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Disulfoton	<0.203	U	0.571	0.203	ug/L		11/12/24 06:44	11/13/24 04:32	1
Methyl parathion	<0.319	U	0.571	0.319	ug/L		11/12/24 06:44	11/13/24 04:32	1
N-Nitrosodi-n-butylamine	<0.516	U	1.14	0.516	ug/L		11/12/24 06:44	11/13/24 04:32	1
Pentachlorobenzene	<0.266	U	0.571	0.266	ug/L		11/12/24 06:44	11/13/24 04:32	1
1,2,4,5-Tetrachlorobenzene	<0.0957	U	0.571	0.0957	ug/L		11/12/24 06:44	11/13/24 04:32	1

**Lab Sample ID: LCS 860-199125/4-A**  
**Matrix: Water**  
**Analysis Batch: 199354**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 199125**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec	Limits
Demeton-O	0.857	2.069	*+	ug/L		241	50 - 150	
Demeton-S	2.00	3.190	*+	ug/L		159	50 - 150	
Disulfoton	5.71	9.651	*+	ug/L		169	38 - 134	
Methyl parathion	5.71	11.01	*+	ug/L		193	26 - 159	
N-Nitrosodi-n-butylamine	11.4	14.02		ug/L		123	58 - 130	

**Lab Sample ID: LCSD 860-199125/3-A**  
**Matrix: Water**  
**Analysis Batch: 199354**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 199125**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec	Limits	RPD	Limit
N-Nitrosodi-n-butylamine	2.86	3.475		ug/L		122	58 - 130	2	30	
Pentachlorobenzene	2.86	2.153		ug/L		75	47 - 130	11	30	
1,2,4,5-Tetrachlorobenzene	2.86	1.501		ug/L		53	52 - 130	5	30	

**Lab Sample ID: LCSD 860-199125/5-A**  
**Matrix: Water**  
**Analysis Batch: 199354**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 199125**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec	Limits	RPD	Limit
Demeton-O	0.857	2.128	*+	ug/L		248	50 - 150	3	30	
Demeton-S	2.00	3.243	*+	ug/L		162	50 - 150	2	30	
Disulfoton	5.71	9.463	*+	ug/L		166	38 - 134	2	30	
Methyl parathion	5.71	10.71	*+	ug/L		187	26 - 159	3	30	
N-Nitrosodi-n-butylamine	11.4	13.91		ug/L		122	58 - 130	1	30	

### Method: D7065-11 - Determination of Nonylphenols

**Lab Sample ID: MB 280-674294/1-A**  
**Matrix: Water**  
**Analysis Batch: 674439**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 674294**

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Nonylphenol	<1140	U	5000	1140	ng/L		11/08/24 11:36	11/10/24 15:13	1
Bisphenol-A	<1030	U	2100	1030	ng/L		11/08/24 11:36	11/10/24 15:13	1
4-tert-Octylphenol	<280	U	1000	280	ng/L		11/08/24 11:36	11/10/24 15:13	1

Eurolins Houston

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: D7065-11 - Determination of Nonylphenols (Continued)

Lab Sample ID: MB 280-674294/1-A  
Matrix: Water  
Analysis Batch: 674439

Client Sample ID: Method Blank  
Prep Type: Total/NA  
Prep Batch: 674294

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
4-nonylphenol (Surr)	67		58 - 115	11/08/24 11:36	11/10/24 15:13	1
4-nonylphenol monoethoxylate (Surr)	55		54 - 139	11/08/24 11:36	11/10/24 15:13	1

Lab Sample ID: LCS 280-674294/2-A  
Matrix: Water  
Analysis Batch: 674439

Client Sample ID: Lab Control Sample  
Prep Type: Total/NA  
Prep Batch: 674294

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits	%Rec
Bisphenol-A	10100	7139		ng/L		70	52 - 125	
4-tert-Octylphenol	10100	10260		ng/L		102	55 - 125	

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
4-nonylphenol (Surr)	87		58 - 115
4-nonylphenol monoethoxylate (Surr)	92		54 - 139

Lab Sample ID: LCSD 280-674294/3-A  
Matrix: Water  
Analysis Batch: 674439

Client Sample ID: Lab Control Sample Dup  
Prep Type: Total/NA  
Prep Batch: 674294

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
Bisphenol-A	10100	7662		ng/L		76	52 - 125	7	22
4-tert-Octylphenol	10100	10070		ng/L		100	55 - 125	2	24

Surrogate	LCSD LCSD		Limits
	%Recovery	Qualifier	
4-nonylphenol (Surr)	89		58 - 115
4-nonylphenol monoethoxylate (Surr)	92		54 - 139

### Method: 608.3 - Organochlorine Pesticides/PCBs in Water

Lab Sample ID: MB 860-197793/1-A  
Matrix: Water  
Analysis Batch: 197846

Client Sample ID: Method Blank  
Prep Type: Total/NA  
Prep Batch: 197793

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Aldrin	<0.0000158	U	0.0000500	0.0000158	mg/L		11/05/24 07:55	11/05/24 10:49	1
alpha-BHC	<0.0000159	U	0.0000500	0.0000159	mg/L		11/05/24 07:55	11/05/24 10:49	1
beta-BHC	<0.0000172	U	0.0000500	0.0000172	mg/L		11/05/24 07:55	11/05/24 10:49	1
Chlordane (technical)	<0.000195	U	0.00100	0.000195	mg/L		11/05/24 07:55	11/05/24 10:49	1
cis-Chlordane	<0.0000188	U	0.0000500	0.0000188	mg/L		11/05/24 07:55	11/05/24 10:49	1
4,4'-DDD	<0.0000179	U	0.0000500	0.0000179	mg/L		11/05/24 07:55	11/05/24 10:49	1
4,4'-DDE	<0.0000161	U	0.0000500	0.0000161	mg/L		11/05/24 07:55	11/05/24 10:49	1
4,4'-DDT	<0.0000180	U	0.0000500	0.0000180	mg/L		11/05/24 07:55	11/05/24 10:49	1
delta-BHC	<0.00000874	U	0.0000500	0.00000874	mg/L		11/05/24 07:55	11/05/24 10:49	1
Dicofol	<0.0000250	U	0.0000250	0.0000250	mg/L		11/05/24 07:55	11/05/24 10:49	1

Eurofins Houston

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 608.3 - Organochlorine Pesticides/PCBs in Water (Continued)

Lab Sample ID: MB 860-197793/1-A

Matrix: Water

Analysis Batch: 197846

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 197793

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Dieldrin	<0.0000173	U	0.0000500	0.0000173	mg/L		11/05/24 07:55	11/05/24 10:49	1
Endosulfan I	<0.0000186	U	0.0000500	0.0000186	mg/L		11/05/24 07:55	11/05/24 10:49	1
Endosulfan II	<0.0000177	U	0.0000500	0.0000177	mg/L		11/05/24 07:55	11/05/24 10:49	1
Endosulfan sulfate	<0.0000152	U	0.0000500	0.0000152	mg/L		11/05/24 07:55	11/05/24 10:49	1
Endrin	<0.0000166	U	0.0000500	0.0000166	mg/L		11/05/24 07:55	11/05/24 10:49	1
Endrin aldehyde	<0.0000167	U	0.0000500	0.0000167	mg/L		11/05/24 07:55	11/05/24 10:49	1
Endrin ketone	<0.0000171	U	0.0000500	0.0000171	mg/L		11/05/24 07:55	11/05/24 10:49	1
gamma-BHC (Lindane)	<0.0000170	U	0.0000500	0.0000170	mg/L		11/05/24 07:55	11/05/24 10:49	1
Heptachlor	<0.0000277	U	0.0000500	0.0000277	mg/L		11/05/24 07:55	11/05/24 10:49	1
Heptachlor epoxide	<0.0000182	U	0.0000500	0.0000182	mg/L		11/05/24 07:55	11/05/24 10:49	1
Methoxychlor	<0.0000186	U	0.0000500	0.0000186	mg/L		11/05/24 07:55	11/05/24 10:49	1
Mirex	<0.0000250	U	0.0000250	0.0000250	mg/L		11/05/24 07:55	11/05/24 10:49	1
PCB-1016	<0.0000521	U	0.000250	0.0000521	mg/L		11/05/24 07:55	11/05/24 10:49	1
PCB-1221	<0.0000521	U	0.000500	0.0000521	mg/L		11/05/24 07:55	11/05/24 10:49	1
PCB-1232	<0.0000521	U	0.000500	0.0000521	mg/L		11/05/24 07:55	11/05/24 10:49	1
PCB-1242	<0.0000521	U	0.000250	0.0000521	mg/L		11/05/24 07:55	11/05/24 10:49	1
PCB-1248	<0.0000521	U	0.000500	0.0000521	mg/L		11/05/24 07:55	11/05/24 10:49	1
PCB-1254	<0.0000655	U	0.000500	0.0000655	mg/L		11/05/24 07:55	11/05/24 10:49	1
PCB-1260	<0.0000655	U	0.000250	0.0000655	mg/L		11/05/24 07:55	11/05/24 10:49	1
Polychlorinated biphenyls, Total		NC	0.000500	0.000250	mg/L		11/05/24 07:55	11/05/24 10:49	1
Toxaphene	<0.000337	U	0.00100	0.000337	mg/L		11/05/24 07:55	11/05/24 10:49	1
trans-Chlordane	<0.0000188	U	0.0000500	0.0000188	mg/L		11/05/24 07:55	11/05/24 10:49	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
DCB Decachlorobiphenyl (Surr)	69		45 - 115	11/05/24 07:55	11/05/24 10:49	1
Tetrachloro-m-xylene	61		41 - 110	11/05/24 07:55	11/05/24 10:49	1

Lab Sample ID: LCS 860-197793/2-A

Matrix: Water

Analysis Batch: 197846

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 197793

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec	Limits
Aldrin	0.00125	0.0009233		mg/L		74		52 - 110
alpha-BHC	0.00125	0.0009597		mg/L		77		58 - 105
beta-BHC	0.00125	0.0009159		mg/L		73		52 - 98
cis-Chlordane	0.00125	0.0009090		mg/L		73		53 - 106
4,4'-DDD	0.00125	0.001014		mg/L		81		60 - 111
4,4'-DDE	0.00125	0.0008677		mg/L		69		47 - 97
4,4'-DDT	0.00125	0.001061		mg/L		85		53 - 96
delta-BHC	0.00125	0.001017		mg/L		81		30 - 120
Dieldrin	0.00125	0.0009146		mg/L		73		57 - 107
Endosulfan I	0.00125	0.0009913		mg/L		79		56 - 110
Endosulfan II	0.00125	0.001146		mg/L		92		58 - 108
Endosulfan sulfate	0.00125	0.0008801	p	mg/L		70		57 - 101
Endrin	0.00125	0.001213		mg/L		97		55 - 102
Endrin aldehyde	0.00125	0.0008926	p	mg/L		71		48 - 96
Endrin ketone	0.00125	0.001053		mg/L		84		59 - 107
gamma-BHC (Lindane)	0.00125	0.001030		mg/L		82		59 - 107

Eurofins Houston

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 608.3 - Organochlorine Pesticides/PCBs in Water (Continued)

Lab Sample ID: LCS 860-197793/2-A

Matrix: Water

Analysis Batch: 197846

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 197793

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Heptachlor	0.00125	0.001066		mg/L		85	55 - 106
Heptachlor epoxide	0.00125	0.0009867		mg/L		79	56 - 109
Methoxychlor	0.00125	0.0007120	p	mg/L		57	53 - 102
trans-Chlordane	0.00125	0.0009074		mg/L		73	52 - 103

Surrogate	LCS %Recovery	LCS Qualifier	Limits
DCB Decachlorobiphenyl (Surr)	50		45 - 115
Tetrachloro-m-xylene	60		41 - 110

Lab Sample ID: LCS 860-197793/4-A

Matrix: Water

Analysis Batch: 197846

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 197793

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
PCB-1016	0.00500	0.003886		mg/L		78	50 - 140
PCB-1260	0.00500	0.003278		mg/L		66	37 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
DCB Decachlorobiphenyl (Surr)	38	S1-	45 - 115
Tetrachloro-m-xylene	58		41 - 110

Lab Sample ID: LCSD 860-197793/3-A

Matrix: Water

Analysis Batch: 197846

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 197793

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Aldrin	0.00125	0.0009153		mg/L		73	52 - 110	1	30
alpha-BHC	0.00125	0.0009688		mg/L		78	58 - 105	1	30
beta-BHC	0.00125	0.0009215		mg/L		74	52 - 98	1	30
cis-Chlordane	0.00125	0.0009037		mg/L		72	53 - 106	1	30
4,4'-DDD	0.00125	0.001008		mg/L		81	60 - 111	1	30
4,4'-DDE	0.00125	0.0008716		mg/L		70	47 - 97	0	30
4,4'-DDT	0.00125	0.001066		mg/L		85	53 - 96	0	30
delta-BHC	0.00125	0.001011		mg/L		81	30 - 120	1	30
Dieldrin	0.00125	0.0009131		mg/L		73	57 - 107	0	30
Endosulfan I	0.00125	0.0009744		mg/L		78	56 - 110	2	30
Endosulfan II	0.00125	0.001138		mg/L		91	58 - 108	1	30
Endosulfan sulfate	0.00125	0.0008756	p	mg/L		70	57 - 101	1	30
Endrin	0.00125	0.001213		mg/L		97	55 - 102	0	30
Endrin aldehyde	0.00125	0.0008917	p	mg/L		71	48 - 96	0	30
Endrin ketone	0.00125	0.001056		mg/L		85	59 - 107	0	30
gamma-BHC (Lindane)	0.00125	0.001033		mg/L		83	59 - 107	0	30
Heptachlor	0.00125	0.001066		mg/L		85	55 - 106	0	30
Heptachlor epoxide	0.00125	0.0009857		mg/L		79	56 - 109	0	30
Methoxychlor	0.00125	0.0006974	p	mg/L		56	53 - 102	2	30
trans-Chlordane	0.00125	0.0009018		mg/L		72	52 - 103	1	30

Eurolins Houston

8

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 608.3 - Organochlorine Pesticides/PCBs in Water (Continued)

Lab Sample ID: LCSD 860-197793/3-A  
Matrix: Water  
Analysis Batch: 197846

Client Sample ID: Lab Control Sample Dup  
Prep Type: Total/NA  
Prep Batch: 197793

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
DCB Decachlorobiphenyl (Surr)	50		45 - 115
Tetrachloro-m-xylene	61		41 - 110

Lab Sample ID: LCSD 860-197793/5-A  
Matrix: Water  
Analysis Batch: 197846

Client Sample ID: Lab Control Sample Dup  
Prep Type: Total/NA  
Prep Batch: 197793

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
PCB-1016	0.00500	0.004074		mg/L		81	50 - 140	5	30
PCB-1260	0.00500	0.003416		mg/L		68	37 - 130	4	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
DCB Decachlorobiphenyl (Surr)	40	S1-	45 - 115
Tetrachloro-m-xylene	62		41 - 110

### Method: 615 - Herbicides (GC)

Lab Sample ID: MB 860-198654/1-A  
Matrix: Water  
Analysis Batch: 198926

Client Sample ID: Method Blank  
Prep Type: Total/NA  
Prep Batch: 198654

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4-D	<0.0000539	U	0.000200	0.0000539	mg/L		11/07/24 14:32	11/11/24 10:10	1
2,4-DB	<0.0000493	U	0.000200	0.0000493	mg/L		11/07/24 14:32	11/11/24 10:10	1
Silvex (2,4,5-TP)	<0.0000422	U	0.000200	0.0000422	mg/L		11/07/24 14:32	11/11/24 10:10	1
2,4,5-T	<0.0000393	U	0.000200	0.0000393	mg/L		11/07/24 14:32	11/11/24 10:10	1
Dalapon	<0.0000476	U	0.000200	0.0000476	mg/L		11/07/24 14:32	11/11/24 10:10	1
Dicamba	<0.0000423	U	0.000200	0.0000423	mg/L		11/07/24 14:32	11/11/24 10:10	1
Dichlorprop	<0.0000527	U	0.000200	0.0000527	mg/L		11/07/24 14:32	11/11/24 10:10	1
Dinoseb	<0.0000343	U	0.000200	0.0000343	mg/L		11/07/24 14:32	11/11/24 10:10	1
MCPA	<0.00526	U	0.0200	0.00526	mg/L		11/07/24 14:32	11/11/24 10:10	1
MCPP	<0.00996	U	0.0200	0.00996	mg/L		11/07/24 14:32	11/11/24 10:10	1
Pentachlorophenol	<0.0000443	U	0.000200	0.0000443	mg/L		11/07/24 14:32	11/11/24 10:10	1
Hexachlorophene	<0.000808	U	0.00500	0.000808	mg/L		11/07/24 14:32	11/11/24 10:10	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4-Dichlorophenylacetic acid	87		45 - 150	11/07/24 14:32	11/11/24 10:10	1

Lab Sample ID: LCS 860-198654/2-A  
Matrix: Water  
Analysis Batch: 198926

Client Sample ID: Lab Control Sample  
Prep Type: Total/NA  
Prep Batch: 198654

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
2,4-D	0.00200	0.001424		mg/L		71	55 - 145
2,4-DB	0.00200	0.001276		mg/L		64	55 - 150
Silvex (2,4,5-TP)	0.00200	0.001482		mg/L		74	55 - 140
2,4,5-T	0.00200	0.001245		mg/L		62	60 - 130
Dalapon	0.00200	0.001434		mg/L		72	50 - 150

Eurofins Houston

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 615 - Herbicides (GC) (Continued)

Lab Sample ID: LCS 860-198654/2-A				Client Sample ID: Lab Control Sample					
Matrix: Water				Prep Type: Total/NA					
Analysis Batch: 198926				Prep Batch: 198654					
Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec		
							Limits		
Dicamba	0.00200	0.001646		mg/L		82	55 - 135		
Dichlorprop	0.00200	0.001190		mg/L		59	55 - 140		
Dinoseb	0.00200	0.0007374		mg/L		37	20 - 100		
MCPA	0.200	0.1611		mg/L		81	55 - 145		
MCPP	0.200	0.1505		mg/L		75	65 - 155		
Pentachlorophenol	0.00200	0.001345		mg/L		67	50 - 135		
Surrogate		LCS %Recovery	LCS Qualifier	Limits					
2,4-Dichlorophenylacetic acid		81		45 - 150					

Lab Sample ID: LCS 860-198654/4-A				Client Sample ID: Lab Control Sample					
Matrix: Water				Prep Type: Total/NA					
Analysis Batch: 198926				Prep Batch: 198654					
Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec		
							Limits		
Hexachlorophene	0.00800	0.007899		mg/L		99	60 - 135		
Surrogate		LCS %Recovery	LCS Qualifier	Limits					
2,4-Dichlorophenylacetic acid		79		45 - 150					

Lab Sample ID: LCSD 860-198654/3-A				Client Sample ID: Lab Control Sample Dup						
Matrix: Water				Prep Type: Total/NA						
Analysis Batch: 198926				Prep Batch: 198654						
Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	
							Limits		RPD	Limit
2,4-D	0.00200	0.001795		mg/L		90	55 - 145	23	25	
2,4-DB	0.00200	0.001642		mg/L		82	55 - 150	25	25	
Silvex (2,4,5-TP)	0.00200	0.001919	*1	mg/L		96	55 - 140	26	25	
2,4,5-T	0.00200	0.001503		mg/L		75	60 - 130	19	25	
Dalapon	0.00200	0.001843		mg/L		92	50 - 150	25	25	
Dicamba	0.00200	0.002090		mg/L		105	55 - 135	24	25	
Dichlorprop	0.00200	0.001545	*1	mg/L		77	55 - 140	26	25	
Dinoseb	0.00200	0.0007481		mg/L		37	20 - 100	1	25	
MCPA	0.200	0.2071		mg/L		104	55 - 145	25	25	
MCPP	0.200	0.1919		mg/L		96	65 - 155	24	25	
Pentachlorophenol	0.00200	0.001683		mg/L		84	50 - 135	22	25	
Surrogate		LCSD %Recovery	LCSD Qualifier	Limits						
2,4-Dichlorophenylacetic acid		105		45 - 150						

Lab Sample ID: LCSD 860-198654/5-A				Client Sample ID: Lab Control Sample Dup						
Matrix: Water				Prep Type: Total/NA						
Analysis Batch: 198926				Prep Batch: 198654						
Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	
							Limits		RPD	Limit
Hexachlorophene	0.00800	0.006311		mg/L		79	60 - 135	22	25	

Eurofins Houston

8

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 615 - Herbicides (GC) (Continued)

Lab Sample ID: LCSD 860-198654/5-A  
 Matrix: Water  
 Analysis Batch: 198926

Client Sample ID: Lab Control Sample Dup  
 Prep Type: Total/NA  
 Prep Batch: 198654

Surrogate	LCSD LCSD		Limits
	%Recovery	Qualifier	
2,4-Dichlorophenylacetic acid	64		45 - 150

### Method: 632 - Carbamate and Urea Pesticides (HPLC)

Lab Sample ID: MB 860-197679/1-A  
 Matrix: Water  
 Analysis Batch: 198450

Client Sample ID: Method Blank  
 Prep Type: Total/NA  
 Prep Batch: 197679

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Carbaryl	<1.85	U	5.00	1.85	ug/L		11/04/24 14:31	11/07/24 16:03	1
Diuron	<0.0514	U	0.0900	0.0514	ug/L		11/04/24 14:31	11/07/24 16:03	1

Lab Sample ID: LCS 860-197679/2-A  
 Matrix: Water  
 Analysis Batch: 198450

Client Sample ID: Lab Control Sample  
 Prep Type: Total/NA  
 Prep Batch: 197679

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Carbaryl	100	109.0		ug/L		109	70 - 130
Diuron	2.00	2.300		ug/L		115	70 - 130

Lab Sample ID: LCSD 860-197679/3-A  
 Matrix: Water  
 Analysis Batch: 198450

Client Sample ID: Lab Control Sample Dup  
 Prep Type: Total/NA  
 Prep Batch: 197679

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	
								RPD	Limit
Carbaryl	100	96.74		ug/L		97	70 - 130	12	20
Diuron	2.00	2.309		ug/L		115	70 - 130	0	20

### Method: 1631E - Mercury, Low Level (CVAFS)

Lab Sample ID: MB 192-25492/3  
 Matrix: Water  
 Analysis Batch: 25492

Client Sample ID: Method Blank  
 Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Mercury	<0.000290	U	0.000500	0.000290	ug/L			11/06/24 15:49	1

Lab Sample ID: MB 192-25492/4  
 Matrix: Water  
 Analysis Batch: 25492

Client Sample ID: Method Blank  
 Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Mercury	<0.000290	U	0.000500	0.000290	ug/L			11/06/24 15:54	1

Lab Sample ID: MB 192-25492/5  
 Matrix: Water  
 Analysis Batch: 25492

Client Sample ID: Method Blank  
 Prep Type: Total/NA

Analyte	MB MB		RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
Mercury	<0.000290	U	0.000500	0.000290	ug/L			11/06/24 15:59	1

Eurofins Houston

## QC Sample Results

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Method: 1631E - Mercury, Low Level (CVAFS) (Continued)

Lab Sample ID: LCS 192-25492/6  
 Matrix: Water  
 Analysis Batch: 25492

Client Sample ID: Lab Control Sample  
 Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Mercury	0.00500	0.004962		ug/L		99	77 - 123

Lab Sample ID: 860-86090-1 MS  
 Matrix: Water  
 Analysis Batch: 25492

Client Sample ID: Winnie Permit Renewal Eff PR Comp  
 Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Mercury	0.000537		0.00500	0.004529		ug/L		80	71 - 125

Lab Sample ID: 860-86090-1 MSD  
 Matrix: Water  
 Analysis Batch: 25492

Client Sample ID: Winnie Permit Renewal Eff PR Comp  
 Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Mercury	0.000537		0.00500	0.004621		ug/L		82	71 - 125	2	24

8

# QC Association Summary

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

## GC/MS Semi VOA

### Prep Batch: 197815

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1 - RA	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	3511	
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	3511	
MB 860-197815/1-A	Method Blank	Total/NA	Water	3511	
LCS 860-197815/2-A	Lab Control Sample	Total/NA	Water	3511	
LCS 860-197815/4-A	Lab Control Sample	Total/NA	Water	3511	
LCSD 860-197815/3-A	Lab Control Sample Dup	Total/NA	Water	3511	
LCSD 860-197815/5-A	Lab Control Sample Dup	Total/NA	Water	3511	

### Analysis Batch: 198704

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 860-197815/1-A	Method Blank	Total/NA	Water	625.1	197815
LCS 860-197815/2-A	Lab Control Sample	Total/NA	Water	625.1	197815
LCS 860-197815/4-A	Lab Control Sample	Total/NA	Water	625.1	197815
LCSD 860-197815/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	197815
LCSD 860-197815/5-A	Lab Control Sample Dup	Total/NA	Water	625.1	197815

### Analysis Batch: 198746

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	625.1	197815

### Prep Batch: 199125

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1 - RE	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	3511	
MB 860-199125/1-A	Method Blank	Total/NA	Water	3511	
LCS 860-199125/4-A	Lab Control Sample	Total/NA	Water	3511	
LCSD 860-199125/3-A	Lab Control Sample Dup	Total/NA	Water	3511	
LCSD 860-199125/5-A	Lab Control Sample Dup	Total/NA	Water	3511	

### Analysis Batch: 199354

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 860-199125/1-A	Method Blank	Total/NA	Water	625.1	199125
LCS 860-199125/4-A	Lab Control Sample	Total/NA	Water	625.1	199125
LCSD 860-199125/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	199125
LCSD 860-199125/5-A	Lab Control Sample Dup	Total/NA	Water	625.1	199125

### Analysis Batch: 200061

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1 - RA	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	625.1	197815
860-86090-1 - RE	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	625.1	199125

### Prep Batch: 674294

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	D7065-11	
MB 280-674294/1-A	Method Blank	Total/NA	Water	D7065-11	
LCS 280-674294/2-A	Lab Control Sample	Total/NA	Water	D7065-11	
LCSD 280-674294/3-A	Lab Control Sample Dup	Total/NA	Water	D7065-11	

### Analysis Batch: 674439

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 280-674294/1-A	Method Blank	Total/NA	Water	D7065-11	674294
LCS 280-674294/2-A	Lab Control Sample	Total/NA	Water	D7065-11	674294

Eurofins Houston

## QC Association Summary

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### GC/MS Semi VOA (Continued)

#### Analysis Batch: 674439 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCSD 280-674294/3-A	Lab Control Sample Dup	Total/NA	Water	D7065-11	674294

#### Analysis Batch: 674489

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	D7065-11	674294

### GC Semi VOA

#### Prep Batch: 197793

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	3511	
MB 860-197793/1-A	Method Blank	Total/NA	Water	3511	
LCS 860-197793/2-A	Lab Control Sample	Total/NA	Water	3511	
LCS 860-197793/4-A	Lab Control Sample	Total/NA	Water	3511	
LCSD 860-197793/3-A	Lab Control Sample Dup	Total/NA	Water	3511	
LCSD 860-197793/5-A	Lab Control Sample Dup	Total/NA	Water	3511	

#### Analysis Batch: 197846

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	608.3	197793
MB 860-197793/1-A	Method Blank	Total/NA	Water	608.3	197793
LCS 860-197793/2-A	Lab Control Sample	Total/NA	Water	608.3	197793
LCS 860-197793/4-A	Lab Control Sample	Total/NA	Water	608.3	197793
LCSD 860-197793/3-A	Lab Control Sample Dup	Total/NA	Water	608.3	197793
LCSD 860-197793/5-A	Lab Control Sample Dup	Total/NA	Water	608.3	197793

#### Prep Batch: 198654

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	3511	
MB 860-198654/1-A	Method Blank	Total/NA	Water	3511	
LCS 860-198654/2-A	Lab Control Sample	Total/NA	Water	3511	
LCS 860-198654/4-A	Lab Control Sample	Total/NA	Water	3511	
LCSD 860-198654/3-A	Lab Control Sample Dup	Total/NA	Water	3511	
LCSD 860-198654/5-A	Lab Control Sample Dup	Total/NA	Water	3511	

#### Analysis Batch: 198926

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	615	198654
MB 860-198654/1-A	Method Blank	Total/NA	Water	615	198654
LCS 860-198654/2-A	Lab Control Sample	Total/NA	Water	615	198654
LCS 860-198654/4-A	Lab Control Sample	Total/NA	Water	615	198654
LCSD 860-198654/3-A	Lab Control Sample Dup	Total/NA	Water	615	198654
LCSD 860-198654/5-A	Lab Control Sample Dup	Total/NA	Water	615	198654

### HPLC/IC

#### Prep Batch: 197679

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	CWA_Prep	
MB 860-197679/1-A	Method Blank	Total/NA	Water	CWA_Prep	
LCS 860-197679/2-A	Lab Control Sample	Total/NA	Water	CWA_Prep	
LCSD 860-197679/3-A	Lab Control Sample Dup	Total/NA	Water	CWA_Prep	

Eurofins Houston

## QC Association Summary

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### HPLC/IC

#### Analysis Batch: 198450

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	632	197679
MB 860-197679/1-A	Method Blank	Total/NA	Water	632	197679
LCS 860-197679/2-A	Lab Control Sample	Total/NA	Water	632	197679
LCSD 860-197679/3-A	Lab Control Sample Dup	Total/NA	Water	632	197679

### Metals

#### Analysis Batch: 25492

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-86090-1	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	1631E	
860-86090-2	Winnie Permit Renewal Eff PR Comp Hg Blank	Total/NA	Water	1631E	
MB 192-25492/3	Method Blank	Total/NA	Water	1631E	
MB 192-25492/4	Method Blank	Total/NA	Water	1631E	
MB 192-25492/5	Method Blank	Total/NA	Water	1631E	
LCS 192-25492/6	Lab Control Sample	Total/NA	Water	1631E	
860-86090-1 MS	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	1631E	
860-86090-1 MSD	Winnie Permit Renewal Eff PR Comp	Total/NA	Water	1631E	

9

# Lab Chronicle

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

**Client Sample ID: Winnie Permit Renewal Eff PR Comp**

**Lab Sample ID: 860-86090-1**

**Date Collected: 10/31/24 08:00**

**Matrix: Water**

**Date Received: 11/04/24 07:34**

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	3511	RA		69.9 mL	4 mL	197815	11/05/24 09:15	DR	EET HOU
Total/NA	Analysis	625.1	RA	1	1 mL	1 mL	200061	11/15/24 15:46	PXS	EET HOU
Total/NA	Prep	3511	RE		69.9 mL	4 mL	199125	11/12/24 06:44	DR	EET HOU
Total/NA	Analysis	625.1	RE	20	1 mL	1 mL	200061	11/15/24 19:18	PXS	EET HOU
Total/NA	Prep	3511			69.9 mL	4 mL	197815	11/05/24 09:15	DR	EET HOU
Total/NA	Analysis	625.1		1	1 mL	1 mL	198746	11/09/24 19:46	T1S	EET HOU
Total/NA	Prep	D7065-11			917.3 mL	1 mL	674294	11/08/24 11:36	EDW	EET DEN
Total/NA	Analysis	D7065-11		5	200 uL	200 uL	674489	11/11/24 17:25	DCM	EET DEN
Total/NA	Prep	3511			49.7 mL	5 mL	197793	11/05/24 07:55	DR	EET HOU
Total/NA	Analysis	608.3		1			197846	11/05/24 14:10	KM	EET HOU
Total/NA	Prep	3511			49.7 mL	4 mL	198654	11/07/24 14:32	BH	EET HOU
Total/NA	Analysis	615		1			198926	11/11/24 12:25	WP	EET HOU
Total/NA	Prep	CWA_Prep			1000 mL	10 mL	197679	11/04/24 14:31	DR	EET HOU
Total/NA	Analysis	632		1			198450	11/07/24 17:41	YG	EET HOU
Total/NA	Analysis	1631E		1	5 mL	5 mL	25492	11/06/24 16:36	EQ5	EET ARK

**Client Sample ID: Winnie Permit Renewal Eff PR Comp Hg**

**Lab Sample ID: 860-86090-2**

**Blank**

**Date Collected: 10/31/24 08:00**

**Matrix: Water**

**Date Received: 11/04/24 07:34**

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	1631E		1	5 mL	5 mL	25492	11/06/24 17:27	EQ5	EET ARK

**Laboratory References:**

EET ARK = Eurofins Arkansas, 8600 Kanis Rd, Little Rock, AR 72204, TEL (501)224-5060  
 EET DEN = Eurofins Denver, 4955 Yarrow Street, Arvada, CO 80002, TEL (303)736-0100  
 EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

## Accreditation/Certification Summary

Client: Eastex Environmental Laboratory Inc.  
 Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Laboratory: Eurofins Houston

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arkansas DEQ	State	88-00759	08-03-25
Florida	NELAP	E871002	06-30-25
Louisiana (All)	NELAP	03054	06-30-25
Oklahoma	NELAP	1306	08-31-25
Texas	NELAP	T104704215	06-30-25
Texas	TCEQ Water Supply	T104704215	12-28-25
USDA	US Federal Programs	525-23-79-79507	03-20-26

### Laboratory: Eurofins Arkansas

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arkansas DEQ	State	60-00889	03-02-25
Florida	NELAP	E871188	06-30-25
Iowa	State	436	10-02-25
Louisiana (All)	NELAP	01946	06-30-25
Oklahoma	State	8709	12-31-24
Oregon	NELAP	4192	07-12-25
Texas	NELAP	T104704575	05-31-25
Washington	State	C1087	07-13-25

### Laboratory: Eurofins Denver

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	2907.01	10-31-25
A2LA	ISO/IEC 17025	2907.01	10-31-25
Alabama	State Program	40730	09-30-12 *
Alaska (UST)	State	18-001	11-30-25
Arizona	State	AZ0713	12-19-24
Arkansas DEQ	State	19-047-0	04-21-25
California	State	2513	01-08-25
Colorado	Petroleum Storage Tank Program	4025 (or)	01-08-25
Colorado	State	CO00026	06-30-25
Connecticut	State	PH-0686	09-30-26
Florida	NELAP	E87667-57	06-30-25
Georgia	State	4025-011	01-08-25
Illinois	NELAP	2000172024-9	05-31-25
Iowa	State	370	11-30-24
Kansas	NELAP	E-10166	04-30-25
Kentucky (WW)	State	KY98047	12-31-24
Louisiana	NELAP	30785	06-30-14 *
Louisiana (All)	NELAP	30785	06-30-25
Minnesota	NELAP	1788752	12-31-24
Nevada	State	CO00026	11-24-24
New Hampshire	NELAP	2053	04-28-25
New Jersey	NELAP	230001	06-30-25
New York	NELAP	59923	04-01-25
North Dakota	State	R-034	01-08-25
Oklahoma	NELAP	8614	08-31-24 *
Oregon	NELAP	4025	01-08-25

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

## Accreditation/Certification Summary

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

### Laboratory: Eurofins Denver (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Pennsylvania	NELAP	013	07-31-25
South Carolina	State	72002001	01-08-24 *
Texas	NELAP	TX104704183-08-TX	09-30-09 *
Texas	NELAP	T104704183	09-30-25
US Fish & Wildlife	US Federal Programs	058448	07-31-25
USDA	US Federal Programs	P330-20-00065	12-19-25
Utah	NELAP	QUAN5	06-30-13 *
Utah	NELAP	CO00026	07-31-25
Virginia	NELAP	460232	06-14-25
Washington	State	C583	08-03-25
West Virginia DEP	State	354	11-29-24
Wisconsin	State	999615430	08-31-25
Wyoming (UST)	A2LA	2907.01	10-31-25

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Houston

# Method Summary

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

Method	Method Description	Protocol	Laboratory
625.1	Semivolatile Organic Compounds (GC-MS/MS)	EPA	EET HOU
D7065-11	Determination of Nonylphenols	ASTM	EET DEN
608.3	Organochlorine Pesticides/PCBs in Water	EPA	EET HOU
615	Herbicides (GC)	EPA-01	EET HOU
632	Carbamate and Urea Pesticides (HPLC)	EPA-01	EET HOU
1631E	Mercury, Low Level (CVAFS)	EPA	EET ARK
3511	Microextraction of Organic Compounds	SW846	EET HOU
CWA_Prep	Liquid-Liquid Extraction (Separatory Funnel)	EPA	EET HOU
D7065-11	Liquid-Liquid Extraction (Continuous)	ASTM	EET DEN

### Protocol References:

ASTM = ASTM International

EPA = US Environmental Protection Agency

EPA-01 = "Methods For The Determination Of Nonconventional Pesticides In Municipal And Industrial Wastewater", EPA/821/R/92/002, April 1992.

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

### Laboratory References:

EET ARK = Eurofins Arkansas, 8600 Kanis Rd, Little Rock, AR 72204, TEL (501)224-5060

EET DEN = Eurofins Denver, 4955 Yarrow Street, Arvada, CO 80002, TEL (303)736-0100

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200

12

# Sample Summary

Client: Eastex Environmental Laboratory Inc.  
Project/Site: Winnie Permit Renewal Eff PR Comp

Job ID: 860-86090-1

---

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Collected</u>	<u>Received</u>
860-86090-1	Winnie Permit Renewal Eff PR Comp	Water	10/31/24 08:00	11/04/24 07:34
860-86090-2	Winnie Permit Renewal Eff PR Comp Hg Blank	Water	10/31/24 08:00	11/04/24 07:34



# SUBCONTRACT ORDER

**Sending Laboratory:**

Eastex Environmental Laboratory - Coldspring  
 PO Box 1089  
 Coldspring, TX 77331

Phone 936-653-3249  
 eastexlab@eastex.net  
 Project Manager Daniel Bowen  
 dbowen@eastexlabs.com

**Subcontracted Laboratory:**

**Eurofins Xenco LLC**  
 4147 Greenbriar Dr  
 Stafford, TX 77477

Phone 713-690-4444  
 Fax 713-690 5646

PO 110424C

**Requested Turnaround 10 Days**

**Sample ID: Winnie Permit Renewal Eff PR Comp      Sample No: 4431013-01      Water      Sampled: 10-31-2024 8:00**

- Semi-Volatiles-Permit (625.1)
- Pesticides-Permit 608 3
- Pesticides Mirex, Dicofol 608 3
- PCB-Permit 608 3
- Organophosphorus Pesticides
- Nonylphenol
- Mercury LL Blank
- Mercury LL
- Carbaryl/Diuron EPA 632
- Acidic Herbicides-Permit

14

Containers Supplied. 15



860-86090 Chain of Custody

**Special Instructions. SEE LIST**

Please do not run any  
volatiles or metals.

See Attached

Received Iced Y/N

Temp: 19 IR ID:HOU-368  
 C/F -0.1  
 Corrected Temp: 18

Temp. \_\_\_\_\_

Winnie WWTP

*Janna Tucker*  
 Released By

*11/4/24 734*  
 Date & Time

*JCIRS*  
 Received By

*11/4/24 734*  
 Date & Time

## DOMESTIC WORKSHEET 4.0

### POLLUTANT ANALYSES REQUIREMENTS\*

The following is required for facilities with a permitted or proposed flow of 1.0 MGD or greater, facilities with an approved pretreatment program, or facilities classified as a major facility. See instructions for further details.

This worksheet is not required for minor amendments without renewal

### Section 1. Toxic Pollutants (Instructions Page 87)

For pollutants identified in Table 4.0(1), indicate the type of sample

Grab       Composite

Date and time sample(s) collected.

*Table 4.0(1) - Toxics Analysis*

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrylonitrile				50
Aldrin				0.01
Aluminum				2.5
Anthracene				10
Antimony				5
Arsenic				0.5
Barium				3
Benzene				10
Benzidine				50
Benzo(a)anthracene				5

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Benzo(a)pyrene				5
Bis(2 chloroethyl)ether				10
Bis(2 ethylhexyl)phthalate				10
Bromodichloromethane				10
Bromoform				10
Cadmium				1
Carbon Tetrachloride				2
Carbaryl				5
Chlordane*				0.2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroform				10
Chlorpyrifos				0.05
Chromium (Total)				3
Chromium (Tri) (*1)				N/A
Chromium (Hex)				3
Copper				2
Chrysene				5
p Chloro m Cresol				10
4,6 Dinitro o Cresol				50
p Cresol				10

Pollutant	AVG Effluent Conc (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Cyanide (*2)				10
4,4' DDD				0.1
4,4' DDE				0.1
4,4' DDT				0.02
2,4 D				0.7
Demeton (O and S)				0.20
Diazinon				0.5/0.1
1,2 Dibromoethane				10
m Dichlorobenzene				10
o Dichlorobenzene				10
p Dichlorobenzene				10
3,3' Dichlorobenzidine				5
1,2 Dichloroethane				10
1,1 Dichloroethylene				10
Dichloromethane				20
1,2 Dichloropropane				10
1,3 Dichloropropene				10
Dicofol				1
Dieldrin				0.02
2,4 Dimethylphenol				10
Di n Butyl Phthalate				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Diuron				0.09
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Ethylbenzene				10
Fluoride				500
Guthion				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclohexane (alpha)				0.05
Hexachlorocyclohexane (beta)				0.05
gamma Hexachlorocyclohexane (Lindane)				0.05
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Hexachlorophene				10
Lead				0.5
Malathion				0.1

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Mercury				0.005
Methoxychlor				2
Methyl Ethyl Ketone				50
Mirex				0.02
Nickel				2
Nitrate Nitrogen				100
Nitrobenzene				10
N Nitrosodiethylamine				20
N Nitroso di n Butylamine				20
Nonylphenol				333
Parathion (ethyl)				0.1
Pentachlorobenzene				20
Pentachlorophenol				5
Phenanthrene				10
Polychlorinated Biphenyls (PCB's) (*3)				0.2
Pyridine				20
Selenium				5
Silver				0.5
1,2,4,5 Tetrachlorobenzene				20
1,1,2,2 Tetrachloroethane				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Tetrachloroethylene				10
Thallium				0.5
Toluene				10
Toxaphene				0.3
2,4,5 TP (Silvex)				0.3
Tributyltin (see instructions for explanation)				0.01
1,1,1 Trichloroethane				10
1,1,2 Trichloroethane				10
Trichloroethylene				10
2,4,5 Trichlorophenol				50
TTHM (Total Trihalomethanes)				10
Vinyl Chloride				10
Zinc				5

(\*1) Determined by subtracting hexavalent Cr from total Cr.

(\*2) Cyanide, amenable to chlorination or weak-acid dissociable.

(\*3) The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

## Section 2. Priority Pollutants

For pollutants identified in Tables 4.0(2)A-E, indicate type of sample

Grab  Composite

Date and time sample(s) collected

*Table 4.0(2)A - Metals, Cyanide, Phenols*

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Antimony				5
Arsenic				0.5
Beryllium				0.5
Cadmium				1
Chromium (Total)				3
Chromium (Hex)				3
Chromium (Tri) (*1)				N/A
Copper				2
Lead				0.5
Mercury				0.005
Nickel				2
Selenium				5
Silver				0.5
Thallium				0.5
Zinc				5
Cyanide (*2)				10
Phenols, Total				10

(\*1) Determined by subtracting hexavalent Cr from total Cr.

(\*2) Cyanide, amenable to chlorination or weak-acid dissociable

**Table 4.0(2)B - Volatile Compounds**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrolein				50
Acrylonitrile				50
Benzene				10
Bromoform				10
Carbon Tetrachloride				2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroethane				50
2 Chloroethylvinyl Ether				10
Chloroform				10
Dichlorobromomethane [Bromodichloromethane]				10
1,1 Dichloroethane				10
1,2 Dichloroethane				10
1,1 Dichloroethylene				10
1,2 Dichloropropane				10
1,3 Dichloropropylene [1,3 Dichloropropene]				10
1,2 Trans Dichloroethylene				10
Ethylbenzene				10
Methyl Bromide				50
Methyl Chloride				50
Methylene Chloride				20
1,1,2,2 Tetrachloroethane				10
Tetrachloroethylene				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Toluene				10
1,1,1 Trichloroethane				10
1,1,2 Trichloroethane				10
Trichloroethylene				10
Vinyl Chloride				10

*Table 4.0(2)C - Acid Compounds*

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2 Chlorophenol				10
2,4 Dichlorophenol				10
2,4 Dimethylphenol				10
4,6 Dinitro o Cresol				50
2,4 Dinitrophenol				50
2 Nitrophenol				20
4 Nitrophenol				50
P Chloro m Cresol				10
Pentalchlorophenol				5
Phenol				10
2,4,6 Trichlorophenol				10

Table 4.0(2)D - Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acenaphthene				10
Acenaphthylene				10
Anthracene				10
Benzidine				50
Benzo(a)Anthracene				5
Benzo(a)Pyrene				5
3,4 Benzofluoranthene				10
Benzo(ghi)Perylene				20
Benzo(k)Fluoranthene				5
Bis(2 Chloroethoxy)Methane				10
Bis(2 Chloroethyl)Ether				10
Bis(2 Chloroisopropyl)Ether				10
Bis(2 Ethylhexyl)Phthalate				10
4 Bromophenyl Phenyl Ether				10
Butyl benzyl Phthalate				10
2 Chloronaphthalene				10
4 Chlorophenyl phenyl ether				10
Chrysene				5
Dibenzo(a,h)Anthracene				5
1,2 (o)Dichlorobenzene				10
1,3 (m)Dichlorobenzene				10
1,4 (p)Dichlorobenzene				10
3,3 Dichlorobenzidine				5
Diethyl Phthalate				10
Dimethyl Phthalate				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Di n Butyl Phthalate				10
2,4 Dinitrotoluene				10
2,6 Dinitrotoluene				10
Di n Octyl Phthalate				10
1,2 Diphenylhydrazine (as Azo benzene)				20
Fluoranthene				10
Fluorene				10
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclo pentadiene				10
Hexachloroethane				20
Indeno(1,2,3 cd)pyrene				5
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N Nitrosodimethylamine				50
N Nitrosodi n Propylamine				20
N Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4 Trichlorobenzene				10

Table 4.0(2)E Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Aldrin				0.01
alpha BHC (Hexachlorocyclohexane)				0.05
beta BHC (Hexachlorocyclohexane)				0.05
gamma BHC (Hexachlorocyclohexane)				0.05
delta BHC (Hexachlorocyclohexane)				0.05
Chlordane				0.2
4,4 DDT				0.02
4,4 DDE				0.1
4,4, DDD				0.1
Dieldrin				0.02
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Endrin Aldehyde				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
PCB 1242				0.2
PCB 1254				0.2
PCB 1221				0.2
PCB 1232				0.2

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
PCB 1248				0.2
PCB 1260				0.2
PCB 1016				0.2
Toxaphene				0.3

\* For PCBS, if all are non detects, enter the highest non detect preceded by a "<"

### Section 3. Dioxin/Furan Compounds

A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user  
Check all that apply

- 2,4,5 trichlorophenoxy acetic acid  
Common Name 2,4,5 T, CASRN 93 76 5
- 2 (2,4,5 trichlorophenoxy) propanoic acid  
Common Name Silvex or 2,4,5 TP, CASRN 93 72 1
- 2 (2,4,5 trichlorophenoxy) ethyl 2,2 dichloropropionate  
Common Name Erbon, CASRN 136 25 4
- 0,0 dimethyl 0-(2,4,5 trichlorophenyl) phosphorothioate  
Common Name Ronnel, CASRN 299 84 3
- 2,4,5 trichlorophenol  
Common Name TCP, CASRN 95 95 4
- hexachlorophene  
Common Name HCP, CASRN 70-30-4

For each compound identified, provide a brief description of the conditions of its/their presence at the facility



# SUBCONTRACT ORDER

**Sending Laboratory:**

Eastex Environmental Laboratory - Coldspring  
 PO Box 1089  
 Coldspring, TX 77331

Phone 936-653-3249  
 eastexlab@eastex.net  
 Project Manager Daniel Bowen  
 dbowen@eastexlabs.com

**Subcontracted Laboratory:**

**Eurofins Xenco LLC**  
 4147 Greenbriar Dr  
 Stafford, TX 77477

Phone 713-690-4444  
 Fax 713-690 5646

PO 110424C

**Requested Turnaround 10 Days**

**Sample ID: Winnie Permit Renewal Eff PR Comp    Sample No: 4431013-01    Water    Sampled: 10-31-2024 8:00**

- Semi-Volatiles-Permit (625.1)
- Pesticides-Permit 608 3
- Pesticides Mirex, Dicofol 608 3
- PCB-Permit 608 3
- Organophosphorus Pesticides
- Nonylphenol
- Mercury LL Blank
- Mercury LL
- Carbaryl/Diuron EPA 632
- Acidic Herbicides-Permit

14

Containers Supplied. 15



860-86090 Chain of Custody

**Special Instructions.** SEE LIST

Please do not run any  
volatiles or metals.

See Attached

Received Iced Y/N    Temp. \_\_\_\_\_

Winnie WWTP

*Janna Tucker*  
 Released By

*11/4/24 734*  
 Date & Time

*JARS*  
 Received By

*11/4/24 734*  
 Date & Time

## DOMESTIC WORKSHEET 4.0

### POLLUTANT ANALYSES REQUIREMENTS\*

The following is required for facilities with a permitted or proposed flow of 1.0 MGD or greater, facilities with an approved pretreatment program, or facilities classified as a major facility. See instructions for further details.

This worksheet is not required for minor amendments without renewal

### Section 1. Toxic Pollutants (Instructions Page 87)

For pollutants identified in Table 4.0(1), indicate the type of sample

Grab       Composite

Date and time sample(s) collected.

*Table 4.0(1) - Toxics Analysis*

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrylonitrile				50
Aldrin				0.01
Aluminum				2.5
Anthracene				10
Antimony				5
Arsenic				0.5
Barium				3
Benzene				10
Benzidine				50
Benzo(a)anthracene				5

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Benzo(a)pyrene				5
Bis(2 chloroethyl)ether				10
Bis(2 ethylhexyl)phthalate				10
Bromodichloromethane				10
Bromoform				10
Cadmium				1
Carbon Tetrachloride				2
Carbaryl				5
Chlordane*				0 2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroform				10
Chlorpyrifos				0 05
Chromium (Total)				3
Chromium (Tri) (*1)				N/A
Chromium (Hex)				3
Copper				2
Chrysene				5
p Chloro m Cresol				10
4,6 Dinitro o Cresol				50
p Cresol				10

Pollutant	AVG Effluent Conc (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Cyanide (*2)				10
4,4' DDD				0 1
4,4' DDE				0 1
4,4' DDT				0 02
2,4 D				0 7
Demeton (O and S)				0 20
Diazinon				0 5/0 1
1,2 Dibromoethane				10
m Dichlorobenzene				10
o Dichlorobenzene				10
p Dichlorobenzene				10
3,3' Dichlorobenzidine				5
1,2 Dichloroethane				10
1,1 Dichloroethylene				10
Dichloromethane				20
1,2 Dichloropropane				10
1,3 Dichloropropene				10
Dicofol				1
Dieldrin				0 02
2,4 Dimethylphenol				10
Di n Butyl Phthalate				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Diuron				0.09
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Ethylbenzene				10
Fluoride				500
Guthion				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclohexane (alpha)				0.05
Hexachlorocyclohexane (beta)				0.05
gamma Hexachlorocyclohexane (Lindane)				0.05
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Hexachlorophene				10
Lead				0.5
Malathion				0.1

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Mercury				0.005
Methoxychlor				2
Methyl Ethyl Ketone				50
Mirex				0.02
Nickel				2
Nitrate Nitrogen				100
Nitrobenzene				10
N Nitrosodiethylamine				20
N Nitroso di n Butylamine				20
Nonylphenol				333
Parathion (ethyl)				0.1
Pentachlorobenzene				20
Pentachlorophenol				5
Phenanthrene				10
Polychlorinated Biphenyls (PCB's) (*3)				0.2
Pyridine				20
Selenium				5
Silver				0.5
1,2,4,5 Tetrachlorobenzene				20
1,1,2,2 Tetrachloroethane				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Tetrachloroethylene				10
Thallium				0.5
Toluene				10
Toxaphene				0.3
2,4,5 TP (Silvex)				0.3
Tributyltin (see instructions for explanation)				0.01
1,1,1 Trichloroethane				10
1,1,2 Trichloroethane				10
Trichloroethylene				10
2,4,5 Trichlorophenol				50
TTHM (Total Trihalomethanes)				10
Vinyl Chloride				10
Zinc				5

(\*1) Determined by subtracting hexavalent Cr from total Cr.

(\*2) Cyanide, amenable to chlorination or weak-acid dissociable.

(\*3) The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

## Section 2. Priority Pollutants

For pollutants identified in Tables 4.0(2)A-E, indicate type of sample

Grab  Composite

Date and time sample(s) collected

**Table 4.0(2)A - Metals, Cyanide, Phenols**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Antimony				5
Arsenic				0.5
Beryllium				0.5
Cadmium				1
Chromium (Total)				3
Chromium (Hex)				3
Chromium (Tri) (*1)				N/A
Copper				2
Lead				0.5
Mercury				0.005
Nickel				2
Selenium				5
Silver				0.5
Thallium				0.5
Zinc				5
Cyanide (*2)				10
Phenols, Total				10

(\*1) Determined by subtracting hexavalent Cr from total Cr.

(\*2) Cyanide, amenable to chlorination or weak-acid dissociable

**Table 4.0(2)B - Volatile Compounds**

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrolein				50
Acrylonitrile				50
Benzene				10
Bromoform				10
Carbon Tetrachloride				2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroethane				50
2 Chloroethylvinyl Ether				10
Chloroform				10
Dichlorobromomethane [Bromodichloromethane]				10
1,1 Dichloroethane				10
1,2 Dichloroethane				10
1,1 Dichloroethylene				10
1,2 Dichloropropane				10
1,3 Dichloropropylene [1,3 Dichloropropene]				10
1,2 Trans Dichloroethylene				10
Ethylbenzene				10
Methyl Bromide				50
Methyl Chloride				50
Methylene Chloride				20
1,1,2,2 Tetrachloroethane				10
Tetrachloroethylene				10

14

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Toluene				10
1,1,1 Trichloroethane				10
1,1,2 Trichloroethane				10
Trichloroethylene				10
Vinyl Chloride				10

*Table 4.0(2)C - Acid Compounds*

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2 Chlorophenol				10
2,4 Dichlorophenol				10
2,4 Dimethylphenol				10
4,6 Dinitro o Cresol				50
2,4 Dinitrophenol				50
2 Nitrophenol				20
4 Nitrophenol				50
P Chloro m Cresol				10
Pentalchlorophenol				5
Phenol				10
2,4,6 Trichlorophenol				10

Table 4.0(2)D - Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acenaphthene				10
Acenaphthylene				10
Anthracene				10
Benzidine				50
Benzo(a)Anthracene				5
Benzo(a)Pyrene				5
3,4 Benzofluoranthene				10
Benzo(ghi)Perylene				20
Benzo(k)Fluoranthene				5
Bis(2 Chloroethoxy)Methane				10
Bis(2 Chloroethyl)Ether				10
Bis(2 Chloroisopropyl)Ether				10
Bis(2 Ethylhexyl)Phthalate				10
4 Bromophenyl Phenyl Ether				10
Butyl benzyl Phthalate				10
2 Chloronaphthalene				10
4 Chlorophenyl phenyl ether				10
Chrysene				5
Dibenzo(a,h)Anthracene				5
1,2 (o)Dichlorobenzene				10
1,3 (m)Dichlorobenzene				10
1,4 (p)Dichlorobenzene				10
3,3 Dichlorobenzidine				5
Diethyl Phthalate				10
Dimethyl Phthalate				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Di n Butyl Phthalate				10
2,4 Dinitrotoluene				10
2,6 Dinitrotoluene				10
Di n Octyl Phthalate				10
1,2 Diphenylhydrazine (as Azo benzene)				20
Fluoranthene				10
Fluorene				10
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclo pentadiene				10
Hexachloroethane				20
Indeno(1,2,3 cd)pyrene				5
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N Nitrosodimethylamne				50
N Nitrosodi n Propylamine				20
N Nitrosodiphenylamne				20
Phenanthrene				10
Pyrene				10
1,2,4 Trichlorobenzene				10

Table 4.0(2)E Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Aldrin				0.01
alpha BHC (Hexachlorocyclohexane)				0.05
beta BHC (Hexachlorocyclohexane)				0.05
gamma BHC (Hexachlorocyclohexane)				0.05
delta BHC (Hexachlorocyclohexane)				0.05
Chlordane				0.2
4,4 DDT				0.02
4,4 DDE				0.1
4,4, DDD				0.1
Dieldrin				0.02
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Endrin Aldehyde				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
PCB 1242				0.2
PCB 1254				0.2
PCB 1221				0.2
PCB 1232				0.2

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
PCB 1248				0.2
PCB 1260				0.2
PCB 1016				0.2
Toxaphene				0.3

\* For PCBS, if all are non detects, enter the highest non detect preceded by a "<"

### Section 3. Dioxin/Furan Compounds

A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user  
Check all that apply

- 2,4,5 trichlorophenoxy acetic acid  
Common Name 2,4,5 T, CASRN 93 76 5
- 2 (2,4,5 trichlorophenoxy) propanoic acid  
Common Name Silvex or 2,4,5 TP, CASRN 93 72 1
- 2 (2,4,5 trichlorophenoxy) ethyl 2,2 dichloropropionate  
Common Name Erbon, CASRN 136 25 4
- 0,0 dimethyl 0-(2,4,5 trichlorophenyl) phosphorothioate  
Common Name Ronnel, CASRN 299 84 3
- 2,4,5 trichlorophenol  
Common Name TCP, CASRN 95 95 4
- hexachlorophene  
Common Name HCP, CASRN 70-30-4

For each compound identified, provide a brief description of the conditions of its/their presence at the facility



**Eurofins Houston**  
 4145 Greenbriar Dr  
 Stafford, TX 77477  
 Phone: 281-240-4200

### Chain of Custody Record



**eurofins** | Environment Testing

<b>Client Information (Sub Contract Lab)</b>		Sampler: N/A		Lab PM: Garza, Sylvia		Carrier Tracking No(s): N/A <i>797 1930968</i>		COC No: 860-171284.1	
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Sylvia.Garza@et.eurofinsus.com		State of Origin: Texas		Page: Page 1 of 1	
Company: Eurofins Environment Testing South Centr				Accreditations Required (See note): NELAP - Texas				Job #: 860-86090-1	
Address: 8600 Kanis Rd, City: Little Rock State, Zip: AR, 72204		Due Date Requested: 11/11/2024		<b>Analysis Requested</b>				Preservation Codes:	
Phone: 501-224-5060(Tel) 501-224-5075(Fax)		TAT Requested (days): N/A							
Email: N/A		PO #: N/A		Project Name: Winnie Permit Renewal Eff PR Comp		Project #: 86000838		Other: N/A	
Project Name: Winnie Permit Renewal Eff PR Comp		Project #: 86000838							
Site: N/A		SSOW#: N/A		Sample Type (C=comp, G=grab)		Matrix (W=water, B=soil, O=water/soil, BT=Tissue, AN/AI)		Special Instructions/Note:	
Sample Identification - Client ID (Lab ID)		Sample Date							
Sample Date		Sample Time		Preservation Code		Perform Analysis (Yes or No)		Number of Samples	
Winnie Permit Renewal Eff PR Comp (860-86090-1)		10/31/24		08:00 Central		G		Water	
Winnie Permit Renewal Eff PR Comp Hg Blank (860-86090-2)		10/31/24		08:00 Central		G		Water	
<p>Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central, LLC places the ownership of method, analyte &amp; accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing South Central, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central, LLC.</p>									
<b>Possible Hazard Identification</b>					<b>Sample Disposal ( A fee may be assessed if samples are retained longer than 1 month)</b>				
Unconfirmed					<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months				
Deliverable Requested: I, II, III, IV, Other (specify)			Primary Deliverable Rank: 2		Special Instructions/QC Requirements:				
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:			
Relinquished by: <i>[Signature]</i>		Date/Time: 11/1/24 17:00		Company:		Received by: <i>[Signature]</i>		Date/Time: 11-5-24 08:25	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:					

Page 66 of 71

12/16/2024 (Rev. 1)





## Login Sample Receipt Checklist

Client: Eastex Environmental Laboratory Inc.

Job Number: 860-86090-1

Login Number: 86090

List Source: Eurofins Houston

List Number: 1

Creator: Rubio, Yuri

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	

## Login Sample Receipt Checklist

Client: Eastex Environmental Laboratory Inc.

Job Number: 860-86090-1

**Login Number: 86090**  
**List Number: 2**  
**Creator: Hansen, Lauren K**

**List Source: Eurofins Arkansas**  
**List Creation: 11/05/24 09:19 AM**

Question	Answer	Comment
Radioactivity wasn't checked or is <math>\leq</math> background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

## Login Sample Receipt Checklist

Client: Eastex Environmental Laboratory Inc.

Job Number: 860-86090-1

Login Number: 86090  
List Number: 3  
Creator: Padgett, Dylan T

List Source: Eurofins Denver  
List Creation: 11/06/24 06:49 PM

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	N/A	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

15





# EASTEX ENVIRONMENTAL LABORATORY, INC.

P.O. Box 1089 \* Coldspring, TX 77331  
(936) 653-3249 \* (800) 525-0508

P.O. Box 631375 \* Nacogdoches, TX 75963-1375  
(936) 569-8879 \* FAX (936) 569-8951

www.eastexlabs.com

White Copy-Follows Samples  
Yellow Copy-Laboratory  
Pink Copy-Client Copy

**REPORT TO:**

**INVOICE TO:**

<b>Company:</b> T.B.C.D	<b>Company:</b>	<b>Remarks:</b>
<b>Address:</b> P.O. Box 599 Stowell, Tx 77661	<b>Address:</b> SAME	
<b>Attn:</b> Mike Will	<b>Attn:</b>	
<b>Phone#:</b> 409-296-3602	<b>Phone#:</b>	

<b>Email:</b>	<b>INSTRUCTIONS:</b> C or G: C= Composite G= Grab Matrix: DW=Drinking Water WW=Wastewater SO=Soil/Sludge OT= Other Container Size: 1=Gallon 2=1/2 Gallon 3=Quart/Liter 4=500mL 5=250mL 6=125mL (4oz) 7=60mL (2 oz) 8= 40mL Vial 9=Other Type: P= Plastic G= Glass T= Teflon S= Sterile Preservatives: C=Chilled S=Sulfuric Acid N=Nitric Acid B=Base/Caustic Z= Zn Acetate ST=Sodium Thiosulfate H=HCL O= Other
<b>P.O. #:</b>	
<b>Sampler's Name (print):</b> Adam Davis	
<b>Sampler's Signature:</b> <i>Adam Davis</i>	
<b>Project Name:</b>	

Work Order ID	Sample ID	Date	Time	Matrix	C or G	DO	Field Data				Containers				X	X
							pH	Cl2	Flow	Temp	#	Size	Type	Pres		
4431013	EFF (A)	10-31-24	8:00a	WW	G					.193	1	8	G	C	X	
	EFF (B)	10-31-24	10:00a	WW	G					.196	1	8	G	C	X	
	EFF (C)	10-31-24	12:00pm	WW	G					.199	1	8	G	C	X	
	EFF (D)	10-31-24	2:00p	WW	G					.166	1	8	G	C	X	
	LL HG Blank <sup>(6)</sup>				G						1	8	G	C		X

ANALYSIS REQUESTED  
LL HG  
Blank LL HG

Relinquished By: <i>Adam Davis</i>	Received By: <i>[Signature]</i>	Date: 11-1-24	Time: 1410	Received Iced: YES / NO
Relinquished By: <i>[Signature]</i>	Received By: <i>[Signature]</i>	Date: 11-1-24	Time: 1615	Received Iced: YES / NO
Relinquished By: <i>[Signature]</i>	Received By and/or Checked in By: <i>Chmi Rogoz</i>	Date: 11-1-24	Time: 1615	Received Iced: YES / NO

<b>LAB USE ONLY</b>	Sample Condition Acceptable: (YES) / NO	Temp C: 1.6	*Therm ID: 15	Logged In By: <i>[Signature]</i>	Date: 11-1-24	Time: 1822
Alternate Check In:	Date:	Time:				

\*Thermometer has 0.0 factor and recorded temperature is actual temperature

**ATTACHMENT H**

**List of Facility Operators  
Tech Rpt 1.0, Section 8**

**ATTACHMENT H  
TRINITY BAY CONSERVATION DISTRICT  
WINNIE-STOWELL WASTEWATER TREATMENT FACILITY  
TPDES PERMIT RENEWAL AMENDMENT APPLICATION  
LIST OF FACILITY OPERATORS**

<b>Name</b>	<b>Classification</b>	<b>License No.</b>
Joseph D. Mouton	C	WW0045527
Adam R. Davis	C	WW0069249

**ATTACHMENT I**

**Summary of WET Test Results  
Wks 5.0 Section 3**

**ATTACHMENT I**  
**TRINITY BAY CONSERVATION DISTRICT**  
**WINNIE-STOWELL WASTEWATER TREATMENT FACILITY**  
**TPDES PERMIT RENEWAL AMENDMENT APPLICATION**  
**SUMMARY OF WET TEST RESULTS**

**7-DAY CHRONIC TEST RESULTS**

<b>Test Date</b>	<b>Test Species</b>	<b>NOEC Survival</b>	<b>LOEC Survival</b>
2/20/2019	<i>Daphnia pulex</i>	100% Effluent	100% Effluent
2/20/2019	<i>Pimephales promelas</i>	100% Effluent	100% Effluent
11/6/2019	<i>Daphnia pulex</i>	100% Effluent	100% Effluent
11/6/2019	<i>Pimephales promelas</i>	100% Effluent	100% Effluent
2/19/2020	<i>Daphnia pulex</i>	100% Effluent	100% Effluent
2/19/2020	<i>Pimephales promelas</i>	100% Effluent	100% Effluent
12/2/2020	<i>Daphnia pulex</i>	100% Effluent	100% Effluent
12/2/2020	<i>Pimephales promelas</i>	100% Effluent	100% Effluent
5/27/2021	<i>Daphnia pulex</i>	100% Effluent	100% Effluent
5/27/2021	<i>Pimephales promelas</i>	100% Effluent	100% Effluent
9/1/2021	<i>Daphnia pulex</i>	100% Effluent	100% Effluent
9/1/2021	<i>Pimephales promelas</i>	100% Effluent	100% Effluent
12/1/2021	<i>Daphnia pulex</i>	100% Effluent	100% Effluent
12/1/2021	<i>Pimephales promelas</i>	100% Effluent	100% Effluent
1/12/2022	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
1/12/2022	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
4/14/2022	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
4/14/2022	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
7/20/2022	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
7/20/2022	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
11/10/2022	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
11/10/2022	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
2/1/2023	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
2/1/2023	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
4/26/2023	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
4/26/2023	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
7/26/2023	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
7/26/2023	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
11/1/2023	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
11/1/2023	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
1/24/2024	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
1/24/2024	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent
4/24/2024	<i>Ceriodaphnia dubia</i>	100% Effluent	>100% Effluent
4/24/2024	<i>Pimephales promelas</i>	100% Effluent	>100% Effluent

**ATTACHMENT I**  
**TRINITY BAY CONSERVATION DISTRICT**  
**WINNIE-STOWELL WASTEWATER TREATMENT FACILITY**  
**TPDES PERMIT RENEWAL AMENDMENT APPLICATION**  
**SUMMARY OF WET TEST RESULTS**

**24-HOUR ACUTE TEST RESULTS**

<b>Test Date</b>	<b>Test Species</b>	<b>LC50</b>
2/18/2019	<i>Daphnia pulex</i>	>100% Effluent
2/18/2019	<i>Pimephales promelas</i>	>100% Effluent
2/19/2020	<i>Daphnia pulex</i>	>100% Effluent
2/19/2020	<i>Pimephales promelas</i>	>100% Effluent
8/23/2021	<i>Daphnia pulex</i>	>100% Effluent
8/23/2021	<i>Pimephales promelas</i>	>100% Effluent
1/11/2022	<i>Ceriodaphnia dubia</i>	>100% Effluent
1/11/2022	<i>Pimephales promelas</i>	>100% Effluent
7/20/2022	<i>Ceriodaphnia dubia</i>	>100% Effluent
7/20/2022	<i>Pimephales promelas</i>	>100% Effluent
11/10/2022	<i>Ceriodaphnia dubia</i>	>100% Effluent
11/10/2022	<i>Pimephales promelas</i>	>100% Effluent
2/1/2023	<i>Ceriodaphnia dubia</i>	>100% Effluent
2/1/2023	<i>Pimephales promelas</i>	>100% Effluent
7/25/2023	<i>Ceriodaphnia dubia</i>	>100% Effluent
7/25/2023	<i>Pimephales promelas</i>	>100% Effluent
4/24/2024	<i>Ceriodaphnia dubia</i>	>100% Effluent
4/24/2024	<i>Pimephales promelas</i>	>100% Effluent



# PLUMMER

1550-007-07

January 2, 2025

Ms. Francesca Findlay  
Texas Commission on Environmental Quality  
Applications Review and Processing Team  
MC-148  
PO Box 13087  
Austin, TX 78711

Re: Trinity Bay Conservation District (CN600675417)  
Winnie-Stowell Wastewater Treatment Facility (RN102077393)  
Application for Renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No.  
WQ0010851001

Dear Ms. Findlay:

On behalf of Trinity Bay Conservation District, Plummer Associates, Inc. (Plummer) provides the following responses to your Notice of Deficiency (NOD) letter dated December 19, 2024, regarding the application for the above-referenced facility. The responses are provided in the order presented in your NOD letter. A copy of your NOD letter is provided as Enclosure A.

- 1. Public Viewing Information:** The address in the permit application is correct. The application will be made available for public viewing and copying at the front desk of the Trinity Bay Conservation District Building, located at 2500 State Highway 124 in Stowell, Chambers County, Texas 77661.
- 2. Notice of Receipt of Application and Intent to Obtain a Water Quality Permit (NORI):** Plummer has reviewed the provided NORI language. Plummer has no revisions to the provided language; however, the last paragraph of NORI was omitted from the NOD. This paragraph should read as follows:  

[Further information may also be obtained from Trinity Bay Conservation District at the address stated above or by calling Mr. Jerry Shadden, General Manager, at 409-658-3677.](#)
- 3. Spanish NORI:** The translated Spanish NORI is provided as Enclosure B.

Please feel free to contact me at [alewis@plummer.com](mailto:alewis@plummer.com) or (512) 687-2154, if you have any questions regarding this submittal.

Ms. Francesca Findlay

January 2, 2025

Page 2

Sincerely,

PLUMMER

TBPE Firm Registration No. F-13

A handwritten signature in cursive script that reads "Ashley Lewis".

Ashley Lewis

*Water Quality/Permitting Team Leader*

Enclosures: (2)

cc: Jerry Shadden, General Manager, Trinity Bay Conservation District  
Joseph Mouton, Chief Operator, Trinity Bay Conservation District

**ENCLOSURE A**  
**Notice of Deficiency Letter**  
**December 19, 2024**

Jon Niermann, *Chairman*  
Bobby Janecka, *Commissioner*  
Catarina R. Gonzales, *Commissioner*  
Kelly Keel, *Executive Director*



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

December 19, 2024

Mr. Joey Mouton  
Water Superintendent  
Trinity Bay Conservation District  
P.O. Box 599  
Stowell, Texas 77661

RE: Application to Renew, for Permit No.: WQ0010851001 (EPA I.D. No. TX0020460)  
Applicant Name: Trinity Bay Conservation District (CN600675417)  
Site Name: Winnie Stowell WWTP (RN102077393)  
Type of Application: Renewal without changes

### VIA EMAIL

Dear Mr. Mouton:

We have received the application for the above referenced permit, and it is currently under review. Your attention to the following item(s) are requested before we can declare the application administratively complete. Please submit responses to the following items via email. In addition, please submit one original and two copies (including a cover letter) of the complete response.

1. Please verify with the proper authority that the application will be made available for public viewing and copying. The public place must be located within the county or counties in which the facility and outfall(s) are or will be located. The address must be a physical address.
2. The following is a portion of the NORI which contains information relevant to your application. Please read it carefully and indicate if it contains any errors or omissions. The complete notice will be sent to you once the application is declared administratively complete.

Mr. Joey Mouton  
Page 2  
December 19, 2024  
Permit No. WQ0010851001


**APPLICATION.** Trinity Bay Conservation District, P.O. Box 599, Stowell, Texas 77661, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010851001 (EPA I.D. No. TX0020460) to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 1,980,000 gallons per day. The domestic wastewater treatment facility is located at 760 East Buccaneer Drive, in the city of Winnie, in Chambers County, Texas 77665. The discharge route is from the plant site to South Fork Mayhaw Bayou; thence to Mayhaw Bayou; thence to South Fork Taylor Bayou; thence to Taylor Bayou Above Tidal. TCEQ received this application on December 17, 2024. The permit application will be available for viewing and copying at Trinity Bay Conservation District, 2500 State Highway 124, Stowell, in Chambers County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

3. The application indicates that public notices in Spanish are required. After confirming the portion of the NORI above does not contain any errors or omissions, please use the attached template to translate the NORI into Spanish. Only the first and last paragraphs are unique to this application and require translation. Please provide the translated Spanish NORI in a Microsoft Word document.

Please submit the complete response, addressed to my attention by January 2, 2025. If you should have any questions, please do not hesitate to contact me by phone at (512) 239-2441 or by email at [Francesca.Findlay@tceq.texas.gov](mailto:Francesca.Findlay@tceq.texas.gov)

Sincerely,



Francesca Findlay  
Application Review and Processing Team (MC148)  
Water Quality Division  
Texas Commission of Environmental Quality

F.F.

Enclosure(s)

cc: Ms. Ashley Lewis, Water Quality/Permitting Team Leader, Plummer Associates, Inc.,  
8911 North Capital of Texas Highway Building 1, Suite 1250, Austin, Texas 78759

**ENCLOSURE B**  
**Spanish NORI**

# Comisión de Calidad Ambiental del Estado de Texas



## AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

### PERMISO NO. WQ0010851001

**SOLICITUD.** Distrito de Conservación de Trinity Bay, P.O. Box 599, Stowell, Texas 77661 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso No. WQ0010851001 (EPA I.D. No. TX0020460) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 1,980,000 galones por día. La planta está ubicada 760 East Buccaneer Drive en el Condado de Chambers, Texas. La ruta de descarga es del sitio de la planta a South Fork Mayhaw Bayou; de allí a Mayhaw Bayou; de allí a South Fork Taylor Bayou; de allí a Taylor Bayou Above Tidal. La TCEQ recibió esta solicitud el 17 de Diciembre de 2024. La solicitud para el permiso estará disponible para leerla y copiarla en 2500 State Highway 124, Stowell, Texas, antes de la fecha de publicación de este aviso en el periódico. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

**AVISO ADICIONAL.** El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. **El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.**

**COMENTARIO PUBLICO / REUNION PUBLICA.** Usted puede presentar **comentarios públicos o pedir una reunión pública sobre esta solicitud.** El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

**OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.** Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida**

**directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso.** Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

**PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS:** su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

**LISTA DE CORREO.** Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas de correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agregue su nombre en una de las listas designe cual lista(s) y envía por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

**CONTACTOS E INFORMACIÓN A LA AGENCIA.** Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía

<http://www14.tceq.texas.gov/epic/eComment/> o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Distrito de Conservación de Trinity Bay a la dirección indicada arriba o llamando a Sr. Jerry Shadden al 409-658-3677.

Fecha de emission:

## Francesca Findlay

---

**From:** Lewis, Ashley <alewis@plummer.com>  
**Sent:** Thursday, January 2, 2025 11:46 AM  
**To:** Francesca Findlay  
**Cc:** joey@tbcd.org; jerry; Garoutte, Alexandra  
**Subject:** RE: WQ0010851001 Trinity Bay Conservation District  
**Attachments:** 20250102\_NOD Response Ltr\_WS.pdf

Francesca,

On behalf of the Trinity Bay Conservation District, please see the attached response to the Notice of Deficiency letter for the Winnie-Stowell permit application. Please let me know if you have any question.

Thanks,

### Ashley Lewis

*Water Quality/Permitting Team Leader*  
Plummer

**P:** 512.452.5905

**D:** 512.687.2154

[www.plummer.com](http://www.plummer.com)

---

**From:** Francesca Findlay <Francesca.Findlay@tceq.texas.gov>  
**Sent:** Thursday, December 19, 2024 9:13 AM  
**To:** joey@tbcd.org  
**Cc:** Lewis, Ashley <alewis@plummer.com>  
**Subject:** FW:WQ0010851001 Trinity Bay Conservation District

**CAUTION:** This email originated from outside of Plummer. DO NOT CLICK links or attachments unless you recognize the sender and know the content is safe.

Dear Mr. Mouton:

The attached Notice of Deficiency letter sent on December 19, 2024, requesting additional information needed to declare the application administratively complete. Please send the complete response to my attention January 2, 2025.

Thank you,

Francesca Findlay  
License & Permit Specialist  
ARP Team | Water Quality Division  
512-239-2441  
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at <http://www.tceq.texas.gov/customersurvey>.



# PLUMMER

1550-007-07

January 2, 2025

Ms. Francesca Findlay  
Texas Commission on Environmental Quality  
Applications Review and Processing Team  
MC-148  
PO Box 13087  
Austin, TX 78711

Re: Trinity Bay Conservation District (CN600675417)  
Winnie-Stowell Wastewater Treatment Facility (RN102077393)  
Application for Renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No.  
WQ0010851001

Dear Ms. Findlay:

On behalf of Trinity Bay Conservation District, Plummer Associates, Inc. (Plummer) provides the following responses to your Notice of Deficiency (NOD) letter dated December 19, 2024, regarding the application for the above-referenced facility. The responses are provided in the order presented in your NOD letter. A copy of your NOD letter is provided as Enclosure A.

- 1. Public Viewing Information:** The address in the permit application is correct. The application will be made available for public viewing and copying at the front desk of the Trinity Bay Conservation District Building, located at 2500 State Highway 124 in Stowell, Chambers County, Texas 77661.
- 2. Notice of Receipt of Application and Intent to Obtain a Water Quality Permit (NORI):** Plummer has reviewed the provided NORI language. Plummer has no revisions to the provided language; however, the last paragraph of NORI was omitted from the NOD. This paragraph should read as follows:  

[Further information may also be obtained from Trinity Bay Conservation District at the address stated above or by calling Mr. Jerry Shadden, General Manager, at 409-658-3677.](#)
- 3. Spanish NORI:** The translated Spanish NORI is provided as Enclosure B.

Please feel free to contact me at [alewis@plummer.com](mailto:alewis@plummer.com) or (512) 687-2154, if you have any questions regarding this submittal.

Ms. Francesca Findlay

January 2, 2025

Page 2

Sincerely,

PLUMMER

TBPE Firm Registration No. F-13

A handwritten signature in cursive script that reads "Ashley Lewis".

Ashley Lewis

*Water Quality/Permitting Team Leader*

Enclosures: (2)

cc: Jerry Shadden, General Manager, Trinity Bay Conservation District  
Joseph Mouton, Chief Operator, Trinity Bay Conservation District

**ENCLOSURE A**  
**Notice of Deficiency Letter**  
**December 19, 2024**

Jon Niermann, *Chairman*  
Bobby Janecka, *Commissioner*  
Catarina R. Gonzales, *Commissioner*  
Kelly Keel, *Executive Director*



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

December 19, 2024

Mr. Joey Mouton  
Water Superintendent  
Trinity Bay Conservation District  
P.O. Box 599  
Stowell, Texas 77661

RE: Application to Renew, for Permit No.: WQ0010851001 (EPA I.D. No. TX0020460)  
Applicant Name: Trinity Bay Conservation District (CN600675417)  
Site Name: Winnie Stowell WWTP (RN102077393)  
Type of Application: Renewal without changes

### VIA EMAIL

Dear Mr. Mouton:

We have received the application for the above referenced permit, and it is currently under review. Your attention to the following item(s) are requested before we can declare the application administratively complete. Please submit responses to the following items via email. In addition, please submit one original and two copies (including a cover letter) of the complete response.

1. Please verify with the proper authority that the application will be made available for public viewing and copying. The public place must be located within the county or counties in which the facility and outfall(s) are or will be located. The address must be a physical address.
2. The following is a portion of the NORI which contains information relevant to your application. Please read it carefully and indicate if it contains any errors or omissions. The complete notice will be sent to you once the application is declared administratively complete.

Mr. Joey Mouton  
Page 2  
December 19, 2024  
Permit No. WQ0010851001


**APPLICATION.** Trinity Bay Conservation District, P.O. Box 599, Stowell, Texas 77661, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010851001 (EPA I.D. No. TX0020460) to authorize the discharge of treated wastewater at a volume not to exceed an annual average flow of 1,980,000 gallons per day. The domestic wastewater treatment facility is located at 760 East Buccaneer Drive, in the city of Winnie, in Chambers County, Texas 77665. The discharge route is from the plant site to South Fork Mayhaw Bayou; thence to Mayhaw Bayou; thence to South Fork Taylor Bayou; thence to Taylor Bayou Above Tidal. TCEQ received this application on December 17, 2024. The permit application will be available for viewing and copying at Trinity Bay Conservation District, 2500 State Highway 124, Stowell, in Chambers County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

3. The application indicates that public notices in Spanish are required. After confirming the portion of the NORI above does not contain any errors or omissions, please use the attached template to translate the NORI into Spanish. Only the first and last paragraphs are unique to this application and require translation. Please provide the translated Spanish NORI in a Microsoft Word document.

Please submit the complete response, addressed to my attention by January 2, 2025. If you should have any questions, please do not hesitate to contact me by phone at (512) 239-2441 or by email at [Francesca.Findlay@tceq.texas.gov](mailto:Francesca.Findlay@tceq.texas.gov)

Sincerely,



Francesca Findlay  
Application Review and Processing Team (MC148)  
Water Quality Division  
Texas Commission of Environmental Quality

F.F.

Enclosure(s)

cc: Ms. Ashley Lewis, Water Quality/Permitting Team Leader, Plummer Associates, Inc.,  
8911 North Capital of Texas Highway Building 1, Suite 1250, Austin, Texas 78759

**ENCLOSURE B**  
**Spanish NORI**

# Comisión de Calidad Ambiental del Estado de Texas



## AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

### PERMISO NO. WQ0010851001

**SOLICITUD.** Distrito de Conservación de Trinity Bay, P.O. Box 599, Stowell, Texas 77661 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso No. WQ0010851001 (EPA I.D. No. TX0020460) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 1,980,000 galones por día. La planta está ubicada 760 East Buccaneer Drive en el Condado de Chambers, Texas. La ruta de descarga es del sitio de la planta a South Fork Mayhaw Bayou; de allí a Mayhaw Bayou; de allí a South Fork Taylor Bayou; de allí a Taylor Bayou Above Tidal. La TCEQ recibió esta solicitud el 17 de Diciembre de 2024. La solicitud para el permiso estará disponible para leerla y copiarla en 2500 State Highway 124, Stowell, Texas, antes de la fecha de publicación de este aviso en el periódico. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-94.372222,29.805555&level=18>

**AVISO ADICIONAL.** El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. **El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.**

**COMENTARIO PUBLICO / REUNION PUBLICA.** Usted puede presentar **comentarios públicos o pedir una reunión pública sobre esta solicitud.** El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

**OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.** Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida**

**directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso.** Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

**PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS:** su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

**LISTA DE CORREO.** Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas de correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agregue su nombre en una de las listas designe cual lista(s) y envía por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

**CONTACTOS E INFORMACIÓN A LA AGENCIA.** Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía

<http://www14.tceq.texas.gov/epic/eComment/> o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Distrito de Conservación de Trinity Bay a la dirección indicada arriba o llamando a Sr. Jerry Shadden al 409-658-3677.

Fecha de emission:

## Francesca Findlay

---

**From:** Lewis, Ashley <alewis@plummer.com>  
**Sent:** Thursday, January 2, 2025 11:46 AM  
**To:** Francesca Findlay  
**Cc:** joey@tbcd.org; jerry; Garoutte, Alexandra  
**Subject:** RE: WQ0010851001 Trinity Bay Conservation District  
**Attachments:** 20250102\_NOD Response Ltr\_WS.pdf

Francesca,

On behalf of the Trinity Bay Conservation District, please see the attached response to the Notice of Deficiency letter for the Winnie-Stowell permit application. Please let me know if you have any question.

Thanks,

### Ashley Lewis

*Water Quality/Permitting Team Leader*  
Plummer

**P:** 512.452.5905

**D:** 512.687.2154

[www.plummer.com](http://www.plummer.com)

---

**From:** Francesca Findlay <Francesca.Findlay@tceq.texas.gov>  
**Sent:** Thursday, December 19, 2024 9:13 AM  
**To:** joey@tbcd.org  
**Cc:** Lewis, Ashley <alewis@plummer.com>  
**Subject:** FW:WQ0010851001 Trinity Bay Conservation District

**CAUTION:** This email originated from outside of Plummer. DO NOT CLICK links or attachments unless you recognize the sender and know the content is safe.

Dear Mr. Mouton:

The attached Notice of Deficiency letter sent on December 19, 2024, requesting additional information needed to declare the application administratively complete. Please send the complete response to my attention January 2, 2025.

Thank you,

Francesca Findlay  
License & Permit Specialist  
ARP Team | Water Quality Division  
512-239-2441  
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at <http://www.tceq.texas.gov/customersurvey>.



TPDES PERMIT NO.  
WQ0010851001  
*[For TCEQ office use only - EPA I.D.  
No. TX0020460]*

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
P.O. Box 13087  
Austin, Texas 78711-3087

This is a renewal that replaces TPDES  
Permit No. WQ0010851001 issued on  
July 2, 2020.

PERMIT TO DISCHARGE WASTES  
under provisions of  
Section 402 of the Clean Water Act  
and Chapter 26 of the Texas Water Code

Trinity Bay Conservation District

whose mailing address is

P.O. Box 599  
Stowell, Texas 77661

is authorized to treat and discharge wastes from the Winnie Stowell Wastewater Treatment  
Facility, SIC Code 4952

located at 760 East Buccaneer Drive, in Stowell, Chambers County, Texas 77665

to South Fork Mayhaw Bayou, thence to Mayhaw Bayou, thence to South Fork Taylor Bayou,  
thence to Taylor Bayou Above Tidal in Segment No. 0701 of the Neches-Trinity Coastal Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth  
in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ),  
the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does  
not grant to the permittee the right to use private or public property for conveyance of  
wastewater along the discharge route described in this permit. This includes, but is not limited  
to, property belonging to any individual, partnership, corporation, or other entity. Neither does  
this permit authorize any invasion of personal rights nor any violation of federal, state, or local  
laws or regulations. It is the responsibility of the permittee to acquire property rights as may be  
necessary to use the discharge route.

This permit shall expire at midnight, **five years from the date of issuance.**

ISSUED DATE:

---

For the Commission

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the date of issuance and lasting through the date of expiration, the permittee is authorized to discharge subject to the following effluent limitations:

The annual average flow of effluent shall not exceed 1.98 million gallons per day (MGD).

Effluent Characteristic	Discharge Limitations				Min. Self-Monitoring Requirements	
	Daily Avg mg/l (lbs/day)	7-day Avg mg/l	Daily Max mg/l	Single Grab mg/l	Report Daily Avg. & Daily Max. Measurement Frequency	Sample Type
Flow, MGD	Report	N/A	Report	N/A	Continuous	Totalizing Meter
Carbonaceous Biochemical Oxygen Demand (5-day)	10 (165)	15	25	35	Two/week	Composite
Total Suspended Solids	15 (248)	25	40	60	Two/week	Composite
Ammonia Nitrogen					Two/week	Composite
April - September	10 (165)	25	50	75	Two/week	Composite
October - March	12 (198)	30	60	90	Two/week	Composite
<i>E. coli</i> , colony-forming units or most probable number per 100 ml	126	N/A	399	N/A	One/week	Grab

2. The effluent shall contain a total chlorine residual of at least 1.0 mg/l after a detention time of at least 20 minutes (based on peak flow) and shall be monitored daily by grab sample at each chlorine contact chamber. The permittee shall dechlorinate the chlorinated effluent to less than 0.1 mg/l total chlorine residual and shall monitor total chlorine residual daily by grab sample after the dechlorination process. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per week by grab sample.
4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored twice per week by grab sample.
7. The annual average flow and maximum 2-hour peak flow shall be reported monthly.

## DEFINITIONS AND STANDARD PERMIT CONDITIONS

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC § 305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§ 5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§ 361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in TWC § 26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

### 1. Flow Measurements

- a. Annual average flow - the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder and limited to major domestic wastewater discharge facilities with one million gallons per day or greater permitted flow.
- b. Daily average flow - the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow - the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow - the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) - the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) - the highest 2-hour peak flow for any 24-hour period in a calendar month.

### 2. Concentration Measurements

- a. Daily average concentration - the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
  - i. For domestic wastewater treatment plants - When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.

- ii. For all other wastewater treatment plants - When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration - the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration - the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge - the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day.

The daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the daily discharge determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.

- e. Bacteria concentration (*E. coli* or Enterococci) - Colony Forming Units (CFU) or Most Probable Number (MPN) of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the  $n$ th root of the product of all measurements made in a calendar month, where  $n$  equals the number of measurements made; or, computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substituted value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
  - f. Daily average loading (lbs/day) - the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD x Concentration, mg/l x 8.34).
  - g. Daily maximum loading (lbs/day) - the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.
3. Sample Type
- a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (b).

- b. Grab sample - an individual sample collected in less than 15 minutes.
4. Treatment Facility (facility) - wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation and/or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
6. The term "biosolids" is defined as sewage sludge that has been tested or processed to meet Class A, Class AB, or Class B pathogen standards in 30 TAC Chapter 312 for beneficial use.
7. Bypass - the intentional diversion of a waste stream from any portion of a treatment facility.

## **MONITORING AND REPORTING REQUIREMENTS**

### **1. Self-Reporting**

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§ 319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Enforcement Division (MC 224), by the 20th day of the following month for each discharge which is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act (CWA); TWC §§ 26, 27, and 28; and THSC § 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

### **2. Test Procedures**

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§ 319.11 - 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC § 25, Environmental Testing Laboratory Accreditation and Certification.

### **3. Records of Results**

- a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.

- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge or biosolids use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR § 264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:
  - i. date, time and place of sample or measurement;
  - ii. identity of individual who collected the sample or made the measurement.
  - iii. date and time of analysis;
  - iv. identity of the individual and laboratory who performed the analysis;
  - v. the technique or method of analysis; and
  - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

#### 4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

#### 5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site and/or shall be readily available for review by a TCEQ representative for a period of three years.

#### 6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the Regional Office and the Enforcement

Division (MC 224).

#### 7. Noncompliance Notification

- a. In accordance with 30 TAC § 305.125(9) any noncompliance which may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Except as allowed by 30 TAC § 305.132, report of such information shall be provided orally or by facsimile transmission (FAX) to the Regional Office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the Regional Office and the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
  - b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
    - i. Unauthorized discharges as defined in Permit Condition 2(g).
    - ii. Any unanticipated bypass that exceeds any effluent limitation in the permit.
    - iii. Violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
  - c. In addition to the above, any effluent violation which deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the Regional Office and the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
  - d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
8. In accordance with the procedures described in 30 TAC §§ 35.301 - 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
9. Changes in Discharges of Toxic Substances

All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the Regional Office, orally or by facsimile transmission within 24 hours, and both the Regional Office and the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
  - i. One hundred micrograms per liter (100 µg/L);
  - ii. Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
  - i. Five hundred micrograms per liter (500 µg/L);
  - ii. One milligram per liter (1 mg/L) for antimony;
  - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.

#### 10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC § 305.128 (relating to Signatories to Reports).

#### 11. All POTWs must provide adequate notice to the Executive Director of the following:

- a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to CWA § 301 or § 306 if it were directly discharging those pollutants;
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and
- c. For the purpose of this paragraph, adequate notice shall include information on:
  - i. The quality and quantity of effluent introduced into the POTW; and
  - ii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

**PERMIT CONDITIONS**

## 1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
  - i. Violation of any terms or conditions of this permit;
  - ii. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
  - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

## 2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment, revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.
- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance

with 30 TAC §§ 305.62 and 305.66 and TWC§ 7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC § 305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility which does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under TWC §§ 7.051 - 7.075 (relating to Administrative Penalties), 7.101 - 7.111 (relating to Civil Penalties), and 7.141 - 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§ 301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA § 402, or any requirement imposed in a pretreatment program approved under the CWA §§ 402 (a)(3) or 402 (b)(8).

### 3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC § 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC § 7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

### 4. Permit Amendment and/or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
  - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC § 305.534 (relating to New Sources and New Dischargers); or
  - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
  - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes which are not described in the permit application or which would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC § 26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA § 307(a) for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA § 307(a) for toxic pollutants within the time provided in the

regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC § 305.64 (relating to Transfer of Permits) and 30 TAC § 50.133 (relating to Executive Director Action on Application or WQMP update).

6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to TWC Chapter 11.

8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

11. Notice of Bankruptcy

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
  - i. the permittee;
  - ii. an entity (as that term is defined in 11 USC, § 101(14)) controlling the permittee or listing the permit or permittee as property of the estate; or
  - iii. an affiliate (as that term is defined in 11 USC, § 101(2)) of the permittee.

- b. This notification must indicate:
  - i. the name of the permittee;
  - ii. the permit number(s);
  - iii. the bankruptcy court in which the petition for bankruptcy was filed; and
  - iv. the date of filing of the petition.

## **OPERATIONAL REQUIREMENTS**

1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge or biosolids use and disposal and 30 TAC §§ 319.21 - 319.29 concerning the discharge of certain hazardous metals.
3. Domestic wastewater treatment facilities shall comply with the following provisions:
  - a. The permittee shall notify the Domestic Permits Team, Domestic Wastewater Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
  - b. The permittee shall submit a closure plan for review and approval to the Domestic Permits Team, Domestic Wastewater Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment and/or other treatment unit regulated by this permit.
4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, and/or retention of inadequately treated wastewater.
5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.
6. The permittee shall remit an annual water quality fee to the Commission as required by 30

TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC § 7.302(b)(6).

7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §§ 1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words confidential business information on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.

- a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion and/or upgrading of the domestic wastewater treatment and/or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment and/or collection facilities. In the case of a domestic wastewater treatment facility which reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

- b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been secured.

- c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
9. Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
  10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
  11. Facilities that generate industrial solid waste as defined in 30 TAC § 335.1 shall comply with these provisions:
    - a. Any solid waste, as defined in 30 TAC § 335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
    - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
    - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC § 335.8(b)(1), to the Corrective Action Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
    - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC § 335.5.
    - e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well,

container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.

- f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC § 335 and must include the following, as it pertains to wastewater treatment and discharge:
  - i. Volume of waste and date(s) generated from treatment process;
  - ii. Volume of waste disposed of on-site or shipped off-site;
  - iii. Date(s) of disposal;
  - iv. Identity of hauler or transporter;
  - v. Location of disposal site; and
  - vi. Method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC § 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC § 361.

TCEQ Revision 06/2020

## SLUDGE PROVISIONS

The permittee is authorized to dispose of sludge only at a Texas Commission on Environmental Quality (TCEQ) authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge. **The disposal of sludge or biosolids by land application on property owned, leased or under the direct control of the permittee is a violation of the permit unless the site is authorized with the TCEQ. This provision does not authorize Distribution and Marketing of Class A or Class AB Biosolids. This provision does not authorize the permittee to land apply biosolids on property owned, leased or under the direct control of the permittee.**

### SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS LAND APPLICATION

#### A. General Requirements

1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge or biosolids.
2. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
3. The land application of processed or unprocessed chemical toilet waste, grease trap waste, grit trap waste, milk solids, or similar non-hazardous municipal or industrial solid wastes, or any of the wastes listed in this provision combined with biosolids, WTP residuals or domestic septage is prohibited unless the grease trap waste is added at a fats, oil and grease (FOG) receiving facility as part of an anaerobic digestion process.

#### B. Testing Requirements

1. Sewage sludge or biosolids shall be tested prior to sludge disposal in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other method that receives the prior approval of the TCEQ for the contaminants listed in 40 CFR Part 261.24, Table 1. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal. Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 12) within seven (7) days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P.O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. The permittee shall submit the following information in an annual report to the TCEQ by September 30<sup>th</sup> of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ’s website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 12) and the Enforcement Division (MC 224).

2. Biosolids shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Section I.C. of this permit.

TABLE 1

<u>Pollutant</u>	<u>Ceiling Concentration</u> <u>(Milligrams per kilogram)*</u>
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

\* Dry weight basis

3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site must be treated by one of the following methods to ensure that the sludge meets either the Class A, Class AB or Class B biosolids pathogen requirements.

- a. For sewage sludge to be classified as Class A biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 most probable number (MPN) per gram of total solids (dry weight basis), or the density of Salmonella sp. bacteria in the sewage sludge must be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

Alternative 1 - The temperature of the sewage sludge that is used or disposed shall be maintained at or above a specific value for a period of time. See 30 TAC § 312.82(a)(3)(A) for specific information;

Alternative 5 (PFRP) - Sewage sludge that is used or disposed of must be treated in one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR Part 503, Appendix B. PFRP include composting, heat drying, heat treatment, and thermophilic aerobic digestion; or

Alternative 6 (PFRP Equivalent) - Sewage sludge that is used or disposed of must be treated in a process that has been approved by the U. S. Environmental Protection Agency as being equivalent to those in Alternative 5.

- b. For sewage sludge to be classified as Class AB biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 MPN per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

Alternative 2 - The pH of the sewage sludge that is used or disposed shall be raised to above 12 std. units and shall remain above 12 std. units for 72 hours.

The temperature of the sewage sludge shall be above 52° Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12 std. units.

At the end of the 72-hour period during which the pH of the sewage sludge is above 12 std. units, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50%; or

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is less than one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(i-iii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(iv-vi) for specific information; or

Alternative 4 - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed.

- c. Sewage sludge that meets the requirements of Class AB biosolids may be classified a Class A biosolids if a variance request is submitted in writing that is supported by substantial documentation demonstrating equivalent methods for reducing odors and written approval is granted by the executive director. The executive director may deny the variance request or revoke that approved variance if it is determined that the variance may potentially endanger human health or the environment, or create nuisance odor conditions.
- d. Three alternatives are available to demonstrate compliance with Class B biosolids criteria.

Alternative 1

- i. A minimum of seven random samples of the sewage sludge shall be collected within 48 hours of the time the sewage sludge is used or disposed of during each monitoring episode for the sewage sludge.
- ii. The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

Alternative 2 - Sewage sludge that is used or disposed of shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR Part 503, Appendix B, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. An independent Texas Licensed Professional Engineer must make a certification to the generator of a sewage sludge that the wastewater treatment facility generating the sewage sludge is designed to achieve one of the PSRP at the permitted design loading of the facility. The certification need only be repeated if the design loading of the facility is increased. The certification shall include a statement indicating the design meets all the applicable standards specified in Appendix B of 40 CFR Part 503;
- iii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iv. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review; and
- v. If the sewage sludge is generated from a mixture of sources, resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the PSRP, and shall meet the certification, operation, and record keeping requirements of this paragraph.

Alternative 3 - Sewage sludge shall be treated in an equivalent process that has been approved by the U.S. Environmental Protection Agency, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;

- ii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iii. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review;
- iv. The Executive Director will accept from the U.S. Environmental Protection Agency a finding of equivalency to the defined PSRP; and
- v. If the sewage sludge is generated from a mixture of sources resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the Processes to Significantly Reduce Pathogens, and shall meet the certification, operation, and record keeping requirements of this paragraph.

In addition to the Alternatives 1 – 3, the following site restrictions must be met if Class B biosolids are land applied:

- i. Food crops with harvested parts that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
- v. Domestic livestock shall not be allowed to graze on the land for 30 days after application of biosolids.
- vi. Turf grown on land where biosolids are applied shall not be harvested for 1 year after application of the biosolids when the harvested turf is placed on either land with a high potential for public exposure or a lawn.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of biosolids.

- viii. Public access to land with a low potential for public exposure shall be restricted for 30 days after application of biosolids.
  - ix. Land application of biosolids shall be in accordance with the buffer zone requirements found in 30 TAC § 312.44.
4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following Alternatives 1 through 10 for vector attraction reduction.

- Alternative 1 - The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38%.
- Alternative 2 - If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30° and 37° Celsius. Volatile solids must be reduced by less than 17% to demonstrate compliance.
- Alternative 3 - If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20° Celsius. Volatile solids must be reduced by less than 15% to demonstrate compliance.
- Alternative 4 - The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20° Celsius.
- Alternative 5 - Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40° Celsius and the average temperature of the sewage sludge shall be higher than 45° Celsius.
- Alternative 6 - The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali shall remain at 12 or higher for two hours and then remain at a pH of 11.5 or higher for an additional 22 hours at the time the sewage sludge is prepared for sale or given away in a bag or other container.
- Alternative 7 - The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75% based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

Alternative 8 - The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90% based on the moisture content and total solids prior to mixing with other materials at the time the sludge is used. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

- Alternative 9 -
- i. Biosolids shall be injected below the surface of the land.
  - ii. No significant amount of the biosolids shall be present on the land surface within one hour after the biosolids are injected.
  - iii. When sewage sludge that is injected below the surface of the land is Class A or Class AB with respect to pathogens, the biosolids shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.

- Alternative 10-
- i. Biosolids applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
  - ii. When biosolids that are incorporated into the soil is Class A or Class AB with respect to pathogens, the biosolids shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

**C. Monitoring Requirements**

Toxicity Characteristic Leaching Procedure (TCLP) Test - prior to sludge disposal  
 PCBs - prior to sludge disposal

All metal constituents and fecal coliform or *Salmonella* sp. bacteria shall be monitored at the appropriate frequency shown below, pursuant to 30 TAC § 312.46(a)(1):

<u>Amount of biosolids (*) metric tons per 365-day period</u>	<u>Monitoring Frequency</u>
0 to less than 290	Once/Year
290 to less than 1,500	Once/Quarter
1,500 to less than 15,000	Once/Two Months
15,000 or greater	Once/Month

(\*) *The amount of bulk biosolids applied to the land (dry wt. basis).*

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 30 TAC § 312.7

Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.

Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and dewatering), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.

Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge or biosolids for disposal at a landfill) and whether the material is ultimately conveyed off-site in bulk or in bags.

**SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE OR BIOSOLIDS FOR APPLICATION TO THE LAND MEETING CLASS A, CLASS AB or B PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3**

For those permittees meeting Class A, Class AB or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below listed in Table 3, the following conditions apply:

**A. Pollutant Limits**

Table 2

<u>Pollutant</u>	Cumulative Pollutant Loading Rate (pounds per acre)*
Arsenic	36
Cadmium	35
Chromium	2677
Copper	1339
Lead	268
Mercury	15
Molybdenum	Report Only
Nickel	375
Selenium	89
Zinc	2500

Table 3

<u>Pollutant</u>	Monthly Average Concentration (milligrams per kilogram)*
Arsenic	41
Cadmium	39
Chromium	1200
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report Only
Nickel	420
Selenium	36
Zinc	2800

\*Dry weight basis

**B. Pathogen Control**

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, shall be treated by either Class A, Class AB or Class B biosolids pathogen reduction requirements as defined above in Section I.B.3.

### **C. Management Practices**

1. Bulk biosolids shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk sewage sludge enters a wetland or other waters in the State.
2. Bulk biosolids not meeting Class A requirements shall be land applied in a manner which complies with Applicability in accordance with 30 TAC §312.41 and the Management Requirements in accordance with 30 TAC § 312.44.
3. Bulk biosolids shall be applied at or below the agronomic rate of the cover crop.
4. An information sheet shall be provided to the person who receives bulk Class A or AB biosolids sold or given away. The information sheet shall contain the following information:
  - a. The name and address of the person who prepared the Class A or AB biosolids that are sold or given away in a bag or other container for application to the land.
  - b. A statement that application of the biosolids to the land is prohibited except in accordance with the instruction on the label or information sheet.
  - c. The annual whole sludge application rate for the biosolids application rate for the biosolids that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Section II above are met.

### **D. Notification Requirements**

1. If bulk biosolids are applied to land in a State other than Texas, written notice shall be provided prior to the initial land application to the permitting authority for the State in which the bulk biosolids are proposed to be applied. The notice shall include:
  - a. The location, by street address, and specific latitude and longitude, of each land application site.
  - b. The approximate time period bulk biosolids will be applied to the site.
  - c. The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk biosolids.

### **E. Record Keeping Requirements**

The documents will be retained at the facility site and/or shall be readily available for review by a TCEQ representative. The person who prepares bulk sewage sludge or a biosolids material shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative for a period of five years. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply.

1. The concentration (mg/kg) in the sludge of each pollutant listed in Table 3 above and the applicable pollutant concentration criteria (mg/kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (lbs/ac) listed in Table 2 above.
2. A description of how the pathogen reduction requirements are met (including site restrictions for Class AB and Class B biosolids, if applicable).
3. A description of how the vector attraction reduction requirements are met.
4. A description of how the management practices listed above in Section II.C are being met.
5. The following certification statement:

“I certify, under penalty of law, that the applicable pathogen requirements in 30 TAC § 312.82(a) or (b) and the vector attraction reduction requirements in 30 TAC § 312.83(b) have been met for each site on which bulk biosolids are applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment.”
6. The recommended agronomic loading rate from the references listed in Section II.C.3. above, as well as the actual agronomic loading rate shall be retained. The person who applies bulk biosolids shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative indefinitely. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply:
  - a. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii), as applicable, and to the permittee’s specific sludge treatment activities.
  - b. The location, by street address, and specific latitude and longitude, of each site on which biosolids are applied.
  - c. The number of acres in each site on which bulk biosolids are applied.
  - d. The date and time biosolids are applied to each site.
  - e. The cumulative amount of each pollutant in pounds/acre listed in Table 2 applied to each site.
  - f. The total amount of biosolids applied to each site in dry tons.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

## F. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30<sup>th</sup> of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 12) and the Enforcement Division (MC 224).

1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
2. Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.
3. Results of tests performed for pollutants found in either Table 2 or 3 as appropriate for the permittee's land application practices.
4. The frequency of monitoring listed in Section I.C. that applies to the permittee.
5. Toxicity Characteristic Leaching Procedure (TCLP) results.
6. PCB concentration in sludge or biosolids in mg/kg.
7. Identity of hauler(s) and TCEQ transporter number.
8. Date(s) of transport.
9. Texas Commission on Environmental Quality registration number, if applicable.
10. Amount of sludge or biosolids disposal dry weight (lbs/acre) at each disposal site.
11. The concentration (mg/kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/kg) listed in Table 3 above, or the applicable pollutant loading rate limit (lbs/acre) listed in Table 2 above if it exceeds 90% of the limit.
12. Level of pathogen reduction achieved (Class A, Class AB or Class B).
13. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B biosolids, include information on how site restrictions were met.
14. Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.
15. Vector attraction reduction alternative used as listed in Section I.B.4.
16. Amount of sludge or biosolids transported in dry tons/year.

17. The certification statement listed in either 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii) as applicable to the permittee's sludge or biosolids treatment activities, shall be attached to the annual report.
18. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the annual report.
  - a. The location, by street address, and specific latitude and longitude.
  - b. The number of acres in each site on which bulk biosolids are applied.
  - c. The date and time bulk biosolids are applied to each site.
  - d. The cumulative amount of each pollutant (i.e., pounds/acre) listed in Table 2 in the bulk biosolids applied to each site.
  - e. The amount of biosolids (i.e., dry tons) applied to each site.

The above records shall be maintained on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

**SECTION III. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL**

- A. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 330 and all other applicable state and federal regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge meets the requirements in 30 TAC § 330 concerning the quality of the sludge or biosolids disposed in a municipal solid waste landfill.
- B. If the permittee generates sewage sludge and supplies that sewage sludge or biosolids to the owner or operator of a municipal solid waste landfill (MSWLF) for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
- C. Sewage sludge or biosolids shall be tested prior to sludge disposal in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I (Toxicity Characteristic Leaching Procedure) or other method, which receives the prior approval of the TCEQ for contaminants listed in Table 1 of 40 CFR § 261.24. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal.

Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 12) of the appropriate TCEQ field office within 7 days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P. O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 12) and the Enforcement Division (MC 224), by September 30 of each year.

- D. Sewage sludge or biosolids shall be tested as needed, in accordance with the requirements of 30 TAC Chapter 330.
- E. Record Keeping Requirements

The permittee shall develop the following information and shall retain the information for five years.

1. The description (including procedures followed and the results) of all liquid Paint Filter Tests performed.
2. The description (including procedures followed and results) of all TCLP tests performed.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

#### F. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30<sup>th</sup> of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 12) and the Enforcement Division (MC 224).

1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and dewatering), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
2. Toxicity Characteristic Leaching Procedure (TCLP) results.
3. Annual sludge or biosolids production in dry tons/year.
4. Amount of sludge or biosolids disposed in a municipal solid waste landfill in dry tons/year.
5. Amount of sludge or biosolids transported interstate in dry tons/year.
6. A certification that the sewage sludge or biosolids meets the requirements of 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
7. Identity of hauler(s) and transporter registration number.
8. Owner of disposal site(s).
9. Location of disposal site(s).
10. Date(s) of disposal.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

#### **SECTION IV. REQUIREMENTS APPLYING TO SLUDGE OR BIOSOLIDS TRANSPORTED TO ANOTHER FACILITY FOR FURTHER PROCESSING**

These provisions apply to sludge or biosolids that is transported to another wastewater treatment facility or facility that further processes sludge or biosolids. These provisions are intended to allow transport of sludge or biosolids to facilities that have been authorized to accept sludge or biosolids. These provisions do not limit the ability of the receiving facility to determine whether to accept the sludge or biosolids, nor do they limit the ability of the receiving facility to request additional testing or documentation.

##### **A. General Requirements**

1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC Chapter 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
2. Sludge or biosolids may only be transported using a registered transporter or using an approved pipeline.

##### **B. Record Keeping Requirements**

1. For sludge transported by an approved pipeline, the permittee must maintain records of the following:
  - a. the amount of sludge or biosolids transported;
  - b. the date of transport;
  - c. the name and TCEQ permit number of the receiving facility or facilities;
  - d. the location of the receiving facility or facilities;
  - e. the name and TCEQ permit number of the facility that generated the waste; and
  - f. copy of the written agreement between the permittee and the receiving facility to accept sludge or biosolids.
2. For sludge or biosolids transported by a registered transporter, the permittee must maintain records of the completed trip tickets in accordance with 30 TAC § 312.145(a)(1)-(7) and amount of sludge or biosolids transported.
3. The above records shall be maintained on-site on a monthly basis and shall be made available to the TCEQ upon request. These records shall be retained for at least five years.

### **C. Reporting Requirements**

The permittee shall submit the following information in an annual report to the TCEQ by September 30<sup>th</sup> of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 12) and the Enforcement Division (MC 224).

1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
2. the annual sludge or biosolids production;
3. the amount of sludge or biosolids transported;
4. the owner of each receiving facility;
5. the location of each receiving facility; and
6. the date(s) of disposal at each receiving facility.

**OTHER REQUIREMENTS**

1. The permittee shall employ or contract with one or more licensed wastewater treatment facility operators or wastewater system operations companies holding a valid license or registration according to the requirements of 30 TAC Chapter 30, Occupational Licenses and Registrations, and, in particular, 30 TAC Chapter 30, Subchapter J, Wastewater Operators and Operations Companies.

This Category C facility must be operated by a chief operator or an operator holding a Category C license or higher. The facility must be operated a minimum of five days per week by the licensed chief operator or an operator holding the required level of license or higher. The licensed chief operator or operator holding the required level of license or higher must be available by telephone or pager seven days per week. Where shift operation of the wastewater treatment facility is necessary, each shift that does not have the on-site supervision of the licensed chief operator must be supervised by an operator in charge who is licensed not less than one level below the category for the facility.

2. The Executive Director has reviewed this action for consistency with the goals and policies of the Texas Coastal Management Program (CMP) in accordance with the regulations of the General Land Office (GLO) and has determined that the action is consistent with the applicable CMP goals and policies.
3. There is no mixing zone established for this discharge to an intermittent stream. Acute toxic criteria apply at the point of discharge.
4. Facilities for the retention of treated or untreated wastewater shall be adequately lined to control seepage. The following methods of pond lining are acceptable.
  - a. In-situ clay soils or placed and compacted clay soils meeting the following requirements:
    - i. More than 30% passing a No. 200 mesh sieve;
    - ii. Liquid limit greater 30%;
    - iii. Plasticity index greater than 15;
    - iv. A minimum thickness of 2 feet;
    - v. Permeability equal to or less than  $1 \times 10^{-7}$  cm/sec (\*); and
    - vi. Soil compaction will be 95% standard proctor at optimum moisture content (\*).  
(\* ) For new and/or modified ponds only.
  - b. Membrane lining with a minimum thickness of 20 mils, and an underdrain leak detection system.
  - c. An alternate method of pond lining may be utilized with prior approval from the Executive Director.

The permittee has furnished certification by a Texas Licensed Professional Engineer that the completed pond lining meets the appropriate criteria above. If sludge removal occurs, it may be necessary to recertify the pond liner. The certification shall be sent to the TCEQ Regional Office (MC Region 12) and the Water Quality Compliance Monitoring Team (MC 224) of the Enforcement Division.

5. Sludge holding areas shall be diked to prevent run off of contaminated stormwater into surface waters of the state.

6. The permittee shall provide facilities for the protection of its wastewater treatment facility from a 100-year flood.
7. In accordance with 30 TAC § 319.9, a permittee that has at least twelve months of uninterrupted compliance with its bacteria limit may notify the commission in writing of its compliance and request a less frequent measurement schedule. To request a less frequent schedule, the permittee shall submit a written request to the TCEQ Domestic Wastewater Section (MC 148) for each phase that includes a different monitoring frequency. The request must contain all of the reported bacteria values (Daily Avg. and Daily Max/Single Grab) for the twelve consecutive months immediately prior to the request. If the Executive Director finds that a less frequent measurement schedule is protective of human health and the environment, the permittee may be given a less frequent measurement schedule. For this permit, one/week may be reduced to two/month. **A violation of any bacteria limit by a facility that has been granted a less frequent measurement schedule will require the permittee to return to the standard frequency schedule and submit written notice to the TCEQ Domestic Wastewater Section (MC 148).** The permittee may not apply for another reduction in measurement frequency for at least 24 months from the date of the last violation. The Executive Director may establish a more frequent measurement schedule if necessary to protect human health or the environment.
8.
  - a. The permittee shall monitor sludge accumulation and water depth in the facultative lagoon and/or stabilization ponds at least once every three years to ensure the ponds maintain the design storage volume and provide sufficient volume for sludge accumulation. Sludge shall be removed from the stabilization ponds if the permittee determines the capacity for sludge storage in the ponds is reduced from the design capacity by more than 25 percent. Removal of sludge shall be conducted during favorable wind conditions to help carry odors away from nearby receptors. Sludge shall be disposed according to the sludge Provisions and Other Requirements in this permit.
  - b. The permittee shall maintain records of the following measurements and calculations and shall include the following information:
    - i. Measurements of depth of water and sludge in each pond.
    - ii. Calculations based on design storage volume indicating volume of sludge and water in each pond with direct comparison to design storage volume.
    - iii. Calculations indicating detention time of the pond system based on the permitted daily average flow.
    - iv. Certification statement clearly indicating if pond system requires removal of the accumulated sludge.
  - c. If sludge removal occurs, the permittee is required to submit a recertification of the pond liners by a Texas Licensed Professional Engineer or because dredging of sludge from the ponds may compromise the pond liners. The permittee shall furnish certification by a Texas Licensed Professional Engineer or a Texas Licensed Professional Geoscientist that the completed pond lining meets the appropriate criteria above prior to utilization of the facilities. The certification shall be sent to the TCEQ Regional Office (MC Region 12) and the Water Quality Enforcement Division (MC 224).

The above records shall be maintained and be available for inspection by authorized

representatives of the Commission for at least five years.

**CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS**

1. The following pollutants may not be introduced into the treatment facility:
  - a. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed-cup flash point of less than 140° Fahrenheit (60° Celsius) using the test methods specified in 40 CFR § 261.21;
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case shall there be discharges with a pH lower than 5.0 standard units, unless the works are specifically designed to accommodate such discharges;
  - c. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference;
  - d. Any pollutant, including oxygen-demanding pollutants (e.g., biochemical oxygen demand), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW;
  - e. Heat in amounts which will inhibit biological activity in the POTW, resulting in Interference, but in no case shall there be heat in such quantities that the temperature at the POTW treatment plant exceeds 104° Fahrenheit (40° Celsius) unless the Executive Director, upon request of the POTW, approves alternate temperature limits;
  - f. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through;
  - g. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and
  - h. Any trucked or hauled pollutants except at discharge points designated by the POTW.
2. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Clean Water Act, including any requirements established under 40 CFR Part 403 [*rev. Federal Register/ Vol. 70/ No. 198/ Friday, October 14, 2005/ Rules and Regulations, pages 60134-60798*].
3. The permittee shall provide adequate notification to the Executive Director, care of the Domestic Wastewater Section (MC 148) of the Water Quality Division, within 30 days subsequent to the permittee's knowledge of either of the following:
  - a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Clean Water Act if it were directly discharging those pollutants; and
  - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Any notice shall include information on the quality and quantity of effluent to be introduced into the treatment works and any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

Revised July 2007

**BIOMONITORING REQUIREMENTS****48-HOUR ACUTE BIOMONITORING REQUIREMENTS: FRESHWATER**

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

1. Scope, Frequency, and Methodology

- a. The permittee shall test the effluent for toxicity in accordance with the provisions below. Such testing will determine if an appropriately dilute effluent sample adversely affects the survival of the test organisms.
- b. The permittee shall conduct the following toxicity tests using the test organisms, procedures, and quality assurance requirements specified in this part of this permit and in accordance with "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms," fifth edition (EPA-821-R-02-012) or its most recent update:
  - 1) Acute static renewal 48-hour definitive toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*). A minimum of five replicates with eight organisms per replicate shall be used in the control and in each dilution. This test shall be conducted once per quarter.
  - 2) Acute static renewal 48-hour definitive toxicity test using the fathead minnow (*Pimephales promelas*). A minimum of five replicates with eight organisms per replicate shall be used in the control and in each dilution. This test shall be conducted once per quarter.

The permittee must perform and submit a valid test for each test species during the required reporting period for that species. A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution. A repeat test shall include the control and all effluent dilutions and use the appropriate number of organisms and replicates, as specified above. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. The permittee shall use five effluent dilution concentrations and a control in each toxicity test. These effluent dilution concentrations are 32%, 42%, 56%, 75%, and 100% effluent. The critical dilution, defined as 100% effluent, is the effluent concentration representative of the proportion of effluent in the receiving water during critical low flow or critical mixing conditions.
- d. This permit may be amended to require a WET limit, a chemical-specific limit, a best management practice, or other appropriate actions to address toxicity. The permittee may be required to conduct a toxicity reduction evaluation (TRE) after multiple toxic events.
- e. Testing Frequency Reduction
  - 1) If none of the first four consecutive quarterly tests demonstrates

significant lethal effects, the permittee may submit this information in writing and, upon approval, reduce the testing frequency to once per six months for the invertebrate test species and once per year for the vertebrate test species.

- 2) If one or more of the first four consecutive quarterly tests demonstrates significant lethal effects, the permittee shall continue quarterly testing for that species until this permit is reissued. If a testing frequency reduction had been previously granted and a subsequent test demonstrates significant lethal effects, the permittee shall resume a quarterly testing frequency for that species until this permit is reissued.

## 2. Required Toxicity Testing Conditions

- a. Test Acceptance - The permittee shall repeat any toxicity test, including the control and all effluent dilutions, which fails to meet any of the following criteria:
  - 1) a control mean survival of 90% or greater; and
  - 2) a coefficient of variation percent (CV%) of 40 or less for both the control and critical dilution. However, if significant lethality is demonstrated, a CV% greater than 40 shall not invalidate the test. The CV% requirement does not apply when significant lethality occurs.
- b. Statistical Interpretation
  - 1) For the water flea and fathead minnow tests, the statistical analyses used to determine if there is a significant difference between the control and an effluent dilution shall be in accordance with the manual referenced in Part 1.b.
  - 2) The permittee is responsible for reviewing test concentration-response relationships to ensure that calculated test results are interpreted and reported correctly. The document entitled "Method Guidance and Recommendation for Whole Effluent Toxicity (WET) Testing (40 CFR Part 136)" (EPA 821-B-00-004) provides guidance on determining the validity of test results.
  - 3) If significant lethality is demonstrated (that is, there is a statistically significant difference in survival at the critical dilution when compared to the survival in the control), the conditions of test acceptability are met, and the survival of the test organisms are equal to or greater than 90% in the critical dilution and all dilutions below that, then the permittee shall report a survival No Observed Effect Concentration (NOEC) of not less than the critical dilution for the reporting requirements.
  - 4) The NOEC is defined as the greatest effluent dilution at which no significant lethality is demonstrated. The Lowest Observed Effect Concentration (LOEC) is defined as the lowest effluent dilution at which significant lethality is demonstrated. Significant lethality is defined as a statistically significant difference the survival of the test organism in a

specified effluent dilution when compared to the survival of the test organism in the control.

- 5) The use of NOECs and LOECs assumes either a monotonic (continuous) concentration-response relationship or a threshold model of the concentration-response relationship. For any test result that demonstrates a non-monotonic (non-continuous) response, the NOEC should be determined based on the guidance manual referenced in Item 2.
- 6) Pursuant to the responsibility assigned to the permittee in Part 2.b.2), test results that demonstrate a non-monotonic (non-continuous) concentration-response relationship may be submitted, prior to the due date, for technical review. The guidance manual referenced in Item 2 will be used when making a determination of test acceptability.
- 7) TCEQ staff will review test results for consistency with rules, procedures, and permit requirements.

c. Dilution Water

- 1) Dilution water used in the toxicity tests must be the receiving water collected at a point upstream of the discharge point as close as possible to the discharge point but unaffected by the discharge. Where the toxicity tests are conducted on effluent discharges to receiving waters that are classified as intermittent streams, or where the toxicity tests are conducted on effluent discharges where no receiving water is available due to zero flow conditions, the permittee shall:
  - a) substitute a synthetic dilution water that has a pH, hardness, and alkalinity similar to that of the closest downstream perennial water unaffected by the discharge; or
  - b) use the closest downstream perennial water unaffected by the discharge.
- 2) Where the receiving water proves unsatisfactory as a result of preexisting instream toxicity (i.e. fails to fulfill the test acceptance criteria Part 2.a.), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
  - a) a synthetic lab water control was performed (in addition to the receiving water control) which fulfilled the test acceptance requirements of Part 2.a;
  - b) the test indicating receiving water toxicity was carried out to completion; and
  - c) the permittee submitted all test results indicating receiving water toxicity with the reports and information required in Part 3.

- 3) The synthetic dilution water shall consist of standard, moderately hard, reconstituted water. Upon approval, the permittee may substitute other appropriate dilution water with chemical and physical characteristics similar to that of the receiving water.

d. Samples and Composites

- 1) The permittee shall collect a minimum of two composite samples from Outfall 001. The second composite sample will be used for the renewal of the dilution concentrations for each toxicity test.
- 2) The permittee shall collect the composite samples such that the samples are representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged on an intermittent basis.
- 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the first composite sample. The holding time for the subsequent composite sample shall not exceed 72 hours. Samples shall be maintained at a temperature of 0-6 degrees Centigrade during collection, shipping, and storage.
- 4) If Outfall 001 ceases discharging during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions, and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume sufficient to complete the required toxicity tests with renewal of the effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report.
- 5) The effluent sample shall not be dechlorinated after sample collection.

3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted in accordance with the manual referenced in Part 1.b for every valid and invalid toxicity test initiated, whether carried to completion or not.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 1 forms provided with this permit.
  - 1) Annual biomonitoring test results are due on or before January 20th for biomonitoring conducted during the previous 12-month period.

- 2) Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.
  - 3) Quarterly biomonitoring test results are due on or before April 20th, July 20th, October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.
  - 4) Monthly biomonitoring test results are due on or before the 20th day of the month following sampling.
- c. Enter the following codes for the appropriate parameters for valid tests only:
- 1) For the water flea, Parameter TEM3D, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 2) For the water flea, Parameter TOM3D, report the NOEC for survival.
  - 3) For the water flea, Parameter TXM3D, report the LOEC for survival.
  - 4) For the fathead minnow, Parameter TEM6C, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 5) For the fathead minnow, Parameter TOM6C, report the NOEC for survival.
  - 6) For the fathead minnow, Parameter TXM6C, report the LOEC for survival.
- d. Enter the following codes for retests only:
- 1) For retest number 1, Parameter 22415, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 2) For retest number 2, Parameter 22416, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."

#### 4. Persistent Toxicity

The requirements of this part apply only when a toxicity test demonstrates significant lethality. Significant lethality was defined in Part 2.b.

- a. The permittee shall conduct a total of 2 additional tests (retests) for any species that demonstrates significant lethality. The two retests shall be conducted monthly during the next two consecutive months. The permittee shall not substitute either of the two retests in lieu of routine toxicity testing. All reports shall be submitted within 20 days of test completion. Test completion is defined as the last day of the test.
- b. If one or both of the two retests specified in Part 4.a. demonstrates significant

lethality, the permittee shall initiate the TRE requirements as specified in Part 5.

- c. The provisions of Part 4.a. are suspended upon completion of the two retests and submittal of the TRE action plan and schedule defined in Part 5.

5. Toxicity Reduction Evaluation

- a. Within 45 days of the retest that demonstrates significant lethality, the permittee shall submit a general outline for initiating a TRE. The outline shall include, but not be limited to, a description of project personnel, a schedule for obtaining consultants (if needed), a discussion of influent and effluent data available for review, a sampling and analytical schedule, and a proposed TRE initiation date.
- b. Within 90 days of the retest that demonstrates significant lethality, the permittee shall submit a TRE action plan and schedule for conducting a TRE. The plan shall specify the approach and methodology to be used in performing the TRE. A TRE is a step-wise investigation combining toxicity testing with physical and chemical analyses to determine actions necessary to eliminate or reduce effluent toxicity to a level not effecting significant lethality at the critical dilution. The TRE action plan shall describe an approach for the reduction or elimination of lethality for both test species defined in Part 1.b. At a minimum, the TRE action plan shall include the following:
  - 1) Specific Activities - The TRE action plan shall specify the approach the permittee intends to utilize in conducting the TRE, including toxicity characterizations, identifications, confirmations, source evaluations, treatability studies, and alternative approaches. When conducting characterization analyses, the permittee shall perform multiple characterizations and follow the procedures specified in the document entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA/600/6-91/003) or alternate procedures. The permittee shall perform multiple identifications and follow the methods specified in the documents entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081). All characterization, identification, and confirmation tests shall be conducted in an orderly and logical progression;
  - 2) Sampling Plan - The TRE action plan should describe sampling locations, methods, holding times, chain of custody, and preservation techniques. The effluent sample volume collected for all tests shall be adequate to perform the toxicity characterization/identification/confirmation procedures and chemical-specific analyses when the toxicity tests show significant lethality. Where the permittee has identified or suspects a specific pollutant and source of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical-specific analyses for the identified and suspected pollutant and source of effluent toxicity;

- 3) Quality Assurance Plan - The TRE action plan should address record keeping and data evaluation, calibration and standardization, baseline tests, system blanks, controls, duplicates, spikes, toxicity persistence in the samples, randomization, reference toxicant control charts, and mechanisms to detect artifactual toxicity; and
  - 4) Project Organization - The TRE action plan should describe the project staff, project manager, consulting engineering services (where applicable), consulting analytical and toxicological services, etc.
- c. Within 30 days of submittal of the TRE action plan and schedule, the permittee shall implement the TRE.
- d. The permittee shall submit quarterly TRE activities reports concerning the progress of the TRE. The quarterly reports are due on or before April 20th, July 20th, October 20th, and January 20th. The report shall detail information regarding the TRE activities including:
- 1) results and interpretation of any chemical specific analyses for the identified and suspected pollutant performed during the quarter;
  - 2) results and interpretation of any characterization, identification, and confirmation tests performed during the quarter;
  - 3) any data and substantiating documentation which identifies the pollutant(s) and source of effluent toxicity;
  - 4) results of any studies/evaluations concerning the treatability of the facility's effluent toxicity;
  - 5) any data that identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution; and
  - 6) any changes to the initial TRE plan and schedule that are believed necessary as a result of the TRE findings.
- e. During the TRE, the permittee shall perform, at a minimum, quarterly testing using the more sensitive species. Testing for the less sensitive species shall continue at the frequency specified in Part 1.b.
- f. If the effluent ceases to effect significant lethality, i.e., there is a cessation of lethality, the permittee may end the TRE. A cessation of lethality is defined as no significant lethality for a period of 12 consecutive months with at least monthly testing. At the end of the 12 months, the permittee shall submit a statement of intent to cease the TRE and may then resume the testing frequency specified in Part 1.b.

This provision accommodates situations where operational errors and upsets, spills, or sampling errors triggered the TRE, in contrast to a situation where a single toxicant or group of toxicants cause lethality. This provision does not apply

as a result of corrective actions taken by the permittee. Corrective actions are defined as proactive efforts that eliminate or reduce effluent toxicity. These include, but are not limited to, source reduction or elimination, improved housekeeping, changes in chemical usage, and modifications of influent streams and effluent treatment.

The permittee may only apply this cessation of lethality provision once. If the effluent again demonstrates significant lethality to the same species, the permit will be amended to add a WET limit with a compliance period, if appropriate. However, prior to the effective date of the WET limit, the permittee may apply for a permit amendment removing and replacing the WET limit with an alternate toxicity control measure by identifying and confirming the toxicant and an appropriate control measure.

- g. The permittee shall complete the TRE and submit a final report on the TRE activities no later than 28 months from the last test day of the retest that confirmed significant lethal effects at the critical dilution. The permittee may petition the Executive Director (in writing) for an extension of the 28-month limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification/TRE. The report shall provide information pertaining to the specific control mechanism selected that will, when implemented, result in the reduction of effluent toxicity to no significant lethality at the critical dilution. The report shall also provide a specific corrective action schedule for implementing the selected control mechanism.
- h. Based on the results of the TRE and proposed corrective actions, this permit may be amended to modify the biomonitoring requirements, where necessary, require a compliance schedule for implementation of corrective actions, specify a WET limit, specify a best management practice, and specify a chemical-specific limit.
- i. Copies of any and all required TRE plans and reports shall also be submitted to the U.S. EPA Region 6 office, 6WQ-PO.

TABLE 1 (SHEET 1 OF 2)

WATER FLEA SURVIVAL

Dates and Times                      Date    Time                      Date    Time  
 Composites                      No. 1 FROM: \_\_\_\_\_ TO: \_\_\_\_\_  
 Collected                      No. 2 FROM: \_\_\_\_\_ TO: \_\_\_\_\_

Test initiated: \_\_\_\_\_ am/pm \_\_\_\_\_ date  
 Dilution water used: \_\_\_\_\_ Receiving water    \_\_\_\_\_ Synthetic Dilution water

PERCENT SURVIVAL

Time	Rep	Percent effluent					
		0%	32%	42%	56%	75%	100%
24h	A						
	B						
	C						
	D						
	E						
48h	A						
	B						
	C						
	D						
	E						
Mean at test end							
CV%*							

\*Coefficient of Variation = Standard Deviation x 100/mean

Dunnett's Procedure or Steel's Many-One Rank Test as appropriate:

Is the mean survival at 48 hours significantly less than the control survival?

CRITICAL DILUTION (100%): \_\_\_\_\_ YES \_\_\_\_\_ NO

Enter percent effluent corresponding to the NOEC below:

1) NOEC survival = \_\_\_\_\_% effluent

2) LOEC survival = \_\_\_\_\_% effluent

TABLE 1 (SHEET 2 OF 2)

FATHEAD MINNOW SURVIVAL

Dates and Times Composites Collected No. 1 FROM: \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_ TO: \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_  
 No. 2 FROM: \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_ TO: \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

Test initiated: \_\_\_\_\_ am/pm \_\_\_\_\_ date

Dilution water used: \_\_\_\_\_ Receiving water \_\_\_\_\_ Synthetic Dilution water

PERCENT SURVIVAL

Time	Rep	Percent effluent					
		0%	32%	42%	56%	75%	100%
24h	A						
	B						
	C						
	D						
	E						
48h	A						
	B						
	C						
	D						
	E						
Mean at test end							
CV%*							

\* Coefficient of Variation = standard deviation x 100/mean

Dunnett's Procedure or Steel's Many-One Rank Test as appropriate:

Is the mean survival at 48 hours significantly less than the control survival?

CRITICAL DILUTION (100%): \_\_\_\_\_ YES \_\_\_\_\_ NO

Enter percent effluent corresponding to the NOEC below:

1) NOEC survival = \_\_\_\_\_% effluent

2) LOEC survival = \_\_\_\_\_% effluent

24-HOUR ACUTE BIOMONITORING REQUIREMENTS: FRESHWATER

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

1. Scope, Frequency, and Methodology

- a. The permittee shall test the effluent for lethality in accordance with the provisions in this section. Such testing will determine compliance with Texas Surface Water Quality Standard 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the appropriate test organisms in 100% effluent for a 24-hour period.
- b. The toxicity tests specified shall be conducted once per six months. The permittee shall conduct the following toxicity tests using the test organisms, procedures, and quality assurance requirements specified in this section of the permit and in accordance with “Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms,” fifth edition (EPA-821-R-02-012) or its most recent update:
  - 1) Acute 24-hour static toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*). A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution.
  - 2) Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*). A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution.

The permittee must perform and report a valid test for each test species during the prescribed reporting period. An invalid test must be repeated during the same reporting period. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. In addition to an appropriate control, a 100% effluent concentration shall be used in the toxicity tests. The control and dilution water shall consist of standard, synthetic, moderately hard, reconstituted water.
- d. This permit may be amended to require a WET limit, a best management practice, a chemical-specific limit, or other appropriate actions to address toxicity. The permittee may be required to conduct a toxicity reduction evaluation (TRE) after multiple toxic events.
- e. As the dilution series specified in the 48-Hour Acute Biomonitoring Requirements includes a 100% effluent concentration, the results from those tests may fulfill the requirements of this section; any tests performed in the proper time interval may be substituted. Compliance will be evaluated as specified in Part 1.a. The 50% survival in 100% effluent for a 24-hour period standard applies to all tests utilizing a 100% effluent dilution, regardless of whether the results are submitted to comply with the minimum testing frequency.

## 2. Required Toxicity Testing Conditions

- a. Test Acceptance – The permittee shall repeat any toxicity test, including the control, if the control fails to meet a mean survival equal to or greater than 90%.
- b. Dilution Water - In accordance with Part 1.c., the control and dilution water shall consist of standard, synthetic, moderately hard, reconstituted water.
- c. Samples and Composites
  - 1) The permittee shall collect one composite sample from Outfall 001.
  - 2) The permittee shall collect the composite sample such that the sample is representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged on an intermittent basis.
  - 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the composite sample. The sample shall be maintained at a temperature of 0-6 degrees Centigrade during collection, shipping, and storage.
  - 4) If Outfall 001 ceases discharging during the collection of the effluent composite sample, the requirements for the minimum number of effluent portions are waived. However, the permittee must have collected a composite sample volume sufficient for completion of the required test. The abbreviated sample collection, duration, and methodology must be documented in the full report.
  - 5) The effluent sample shall not be dechlorinated after sample collection.

## 3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this permit in accordance with the manual referenced in Part 1.b. for every valid and invalid toxicity test initiated.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 2 forms provided with this permit.
  - 1) Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.
  - 2) Quarterly biomonitoring test results are due on or before April 20th, July 20th, and October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.

- c. Enter the following codes for the appropriate parameters for valid tests only:
  - 1) For the water flea, Parameter TIE3D, enter a “0” if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter “1.”
  - 2) For the fathead minnow, Parameter TIE6C, enter a “0” if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter “1.”
- d. Enter the following codes for retests only:
  - 1) For retest number 1, Parameter 22415, enter a “0” if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter “1.”
  - 2) For retest number 2, Parameter 22416, enter a “0” if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter “1.”

#### 4. Persistent Mortality

The requirements of this part apply when a toxicity test demonstrates significant lethality, which is defined as a mean mortality of 50% or greater of organisms exposed to the 100% effluent concentration for 24 hours.

- a. The permittee shall conduct 2 additional tests (retests) for each species that demonstrates significant lethality. The two retests shall be conducted once per week for 2 weeks. Five effluent dilution concentrations in addition to an appropriate control shall be used in the retests. These effluent concentrations are 6%, 13%, 25%, 50%, and 100% effluent. The first retest shall be conducted within 15 days of the laboratory determination of significant lethality. All test results shall be submitted within 20 days of test completion of the second retest. Test completion is defined as the 24th hour.
- b. If one or both of the two retests specified in Part 4.a. demonstrates significant lethality, the permittee shall initiate the TRE requirements as specified in Part 5.

#### 5. Toxicity Reduction Evaluation

- a. Within 45 days of the retest that demonstrates significant lethality, the permittee shall submit a general outline for initiating a TRE. The outline shall include, but not be limited to, a description of project personnel, a schedule for obtaining consultants (if needed), a discussion of influent and effluent data available for review, a sampling and analytical schedule, and a proposed TRE initiation date.
- b. Within 90 days of the retest that demonstrates significant lethality, the permittee shall submit a TRE action plan and schedule for conducting a TRE. The plan shall specify the approach and methodology to be used in performing the TRE. A TRE is a step-wise investigation combining toxicity testing with physical and chemical

analyses to determine actions necessary to eliminate or reduce effluent toxicity to a level not effecting significant lethality at the critical dilution. The TRE action plan shall lead to the successful elimination of significant lethality for both test species defined in Part 1.b. At a minimum, the TRE action plan shall include the following:

- 1) **Specific Activities** - The TRE action plan shall specify the approach the permittee intends to utilize in conducting the TRE, including toxicity characterizations, identifications, confirmations, source evaluations, treatability studies, and alternative approaches. When conducting characterization analyses, the permittee shall perform multiple characterizations and follow the procedures specified in the document entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA/600/6-91/003) or alternate procedures. The permittee shall perform multiple identifications and follow the methods specified in the documents entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081). All characterization, identification, and confirmation tests shall be conducted in an orderly and logical progression;
  - 2) **Sampling Plan** - The TRE action plan should describe sampling locations, methods, holding times, chain of custody, and preservation techniques. The effluent sample volume collected for all tests shall be adequate to perform the toxicity characterization/identification/confirmation procedures, and chemical-specific analyses when the toxicity tests show significant lethality. Where the permittee has identified or suspects a specific pollutant and source of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical-specific analyses for the identified and suspected pollutant and source of effluent toxicity;
  - 3) **Quality Assurance Plan** - The TRE action plan should address record keeping and data evaluation, calibration and standardization, baseline tests, system blanks, controls, duplicates, spikes, toxicity persistence in the samples, randomization, reference toxicant control charts, and mechanisms to detect artifactual toxicity; and
  - 4) **Project Organization** - The TRE Action Plan should describe the project staff, manager, consulting engineering services (where applicable), consulting analytical and toxicological services, etc.
- c. Within 30 days of submittal of the TRE action plan and schedule, the permittee shall implement the TRE.
- d. The permittee shall submit quarterly TRE activities reports concerning the progress of the TRE. The quarterly TRE Activities Reports are due on or before April 20th, July 20th, October 20th, and January 20th. The report shall detail information regarding the TRE activities including:

- 1) results and interpretation of any chemical-specific analyses for the identified and suspected pollutant performed during the quarter;
  - 2) results and interpretation of any characterization, identification, and confirmation tests performed during the quarter;
  - 3) any data and substantiating documentation that identifies the pollutant and source of effluent toxicity;
  - 4) results of any studies/evaluations concerning the treatability of the facility's effluent toxicity;
  - 5) any data that identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to eliminate significant lethality; and
  - 6) any changes to the initial TRE plan and schedule that are believed necessary as a result of the TRE findings.
- e. During the TRE, the permittee shall perform, at a minimum, quarterly testing using the more sensitive species. Testing for the less sensitive species shall continue at the frequency specified in Part 1.b.
- f. If the effluent ceases to effect significant lethality, i.e., there is a cessation of lethality, the permittee may end the TRE. A cessation of lethality is defined as no significant lethality for a period of 12 consecutive weeks with at least weekly testing. At the end of the 12 weeks, the permittee shall submit a statement of intent to cease the TRE and may then resume the testing frequency specified in Part 1.b.

This provision accommodates situations where operational errors and upsets, spills, or sampling errors triggered the TRE, in contrast to a situation where a single toxicant or group of toxicants cause lethality. This provision does not apply as a result of corrective actions taken by the permittee. Corrective actions are defined as proactive efforts that eliminate or reduce effluent toxicity. These include, but are not limited to, source reduction or elimination, improved housekeeping, changes in chemical usage, and modifications of influent streams and effluent treatment.

The permittee may only apply this cessation of lethality provision once. If the effluent again demonstrates significant lethality to the same species, the permit will be amended to add a WET limit with a compliance period, if appropriate. However, prior to the effective date of the WET limit, the permittee may apply for a permit amendment removing and replacing the WET limit with an alternate toxicity control measure by identifying and confirming the toxicant and an appropriate control measure.

- g. The permittee shall complete the TRE and submit a final report on the TRE activities no later than 18 months from the last test day of the retest that demonstrates significant lethality. The permittee may petition the Executive

Director (in writing) for an extension of the 18-month limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE. The report shall specify the control mechanism that will, when implemented, reduce effluent toxicity as specified in Part 5.h. The report shall also specify a corrective action schedule for implementing the selected control mechanism.

- h. Within 3 years of the last day of the test confirming toxicity, the permittee shall comply with 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the test organism in 100% effluent at the end of 24-hours. The permittee may petition the Executive Director (in writing) for an extension of the 3-year limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE.

The permittee may be exempted from complying with 30 TAC § 307.6(e)(2)(B) upon proving that toxicity is caused by an excess, imbalance, or deficiency of dissolved salts. This exemption excludes instances where individually toxic components (e.g., metals) form a salt compound. Following the exemption, this permit may be amended to include an ion-adjustment protocol, alternate species testing, or single species testing.

- i. Based upon the results of the TRE and proposed corrective actions, this permit may be amended to modify the biomonitoring requirements where necessary, require a compliance schedule for implementing corrective actions, specify a WET limit, specify a best management practice, and specify a chemical-specific limit.
- j. Copies of any and all required TRE plans and reports shall also be submitted to the U.S. EPA Region 6 office, 6WQ-PO.

TABLE 2 (SHEET 1 OF 2)

WATER FLEA SURVIVAL

GENERAL INFORMATION

	Time	Date
Composite Sample Collected		
Test Initiated		

PERCENT SURVIVAL

Time	Rep	Percent effluent					
		0%	6%	13%	25%	50%	100%
24h	A						
	B						
	C						
	D						
	E						
	MEAN*						

Enter percent effluent corresponding to the LC50 below:

24 hour LC50 = \_\_\_\_\_% effluent

TABLE 2 (SHEET 2 OF 2)  
 FATHEAD MINNOW SURVIVAL

GENERAL INFORMATION

	Time	Date
Composite Sample Collected		
Test Initiated		

PERCENT SURVIVAL

Time	Rep	Percent effluent					
		0%	6%	13%	25%	50%	100%
24h	A						
	B						
	C						
	D						
	E						
	MEAN						

Enter percent effluent corresponding to the LC50 below:

24 hour LC50 = \_\_\_\_\_% effluent

## FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

For draft Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0010851001, EPA I.D. No. TX0020460, to discharge to water in the state.

Issuing Office: Texas Commission on Environmental Quality  
P.O. Box 13087  
Austin, Texas 78711-3087

Applicant: Trinity Bay Conservation District  
P.O. Box 599  
Stowell, Texas 77661

Prepared By: Sujata Sinha  
Domestic Permits Team  
Domestic Wastewater Section (MC 148)  
Water Quality Division  
(512) 239-1963

Date: October 29, 2025

Permit Action: Renewal

### 1. EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **five years from the date of issuance**.

### 2. APPLICANT ACTIVITY

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of the existing permit that authorizes the discharge of treated domestic wastewater at an annual average flow not to exceed 1.98 million gallons per day (MGD). The existing wastewater treatment facility serves the Cities of Winnie and Stowell.

### 3. FACILITY AND DISCHARGE LOCATION

The plant site is located at 760 East Buccaneer Drive, in Stowell, Chambers County, Texas 77665.

#### Outfall Location:

<b>Outfall Number</b>	<b>Latitude</b>	<b>Longitude</b>
001	29.802765 N	94.362178 W

The treated effluent is discharged to South Fork Mayhaw Bayou, thence to Mayhaw Bayou, thence to South Fork Taylor Bayou, thence to Taylor Bayou Above Tidal in Segment No. 0701 of the Neches-Trinity Coastal Basin. The unclassified receiving water use is minimal aquatic life use for South Fork Mayhaw Bayou. The designated uses for

Segment No. 0701 are primary contact recreation and intermediate aquatic life use.

**4. TREATMENT PROCESS DESCRIPTION AND SEWAGE SLUDGE DISPOSAL**

The Winnie Stowell Wastewater Treatment Facility is a pond system with two trains of wetland cells followed by chlorination and dechlorination units. Treatment units include a bar screen, a facultative lagoon, eight wetland cells, a post aeration chamber, a chlorine contact chamber, and a dechlorination chamber. The facility is in operation.

The facility is a pond system and sludge from the ponds has not been removed for sludge disposal to date. The draft permit authorizes the disposal of sludge at any TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

**5. INDUSTRIAL WASTE CONTRIBUTION**

The draft permit includes pretreatment requirements that are appropriate for a facility of this size and complexity. The facility does not appear to receive significant industrial wastewater contributions.

**6. SUMMARY OF SELF-REPORTED EFFLUENT ANALYSES**

The following is a summary of the applicant’s effluent monitoring data for the period September 2023 through September 2025. The average of Daily Average value is computed by the averaging of all 30-day average values for the reporting period for each parameter: flow, five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), and ammonia nitrogen (NH<sub>3</sub>-N). The average of Daily Average value for *Escherichia coli* (*E. coli*) in colony-forming units (CFU) or most probable number (MPN) per 100 ml is calculated via geometric mean.

<u>Parameter</u>	<u>Average of Daily Avg</u>
Flow, MGD	0.91
CBOD <sub>5</sub> , mg/l	5.4
TSS, mg/l	8.8
NH <sub>3</sub> -N, mg/l	4.0
<i>E. coli</i> , CFU or MPN per 100 ml	4.0

**7. DRAFT PERMIT CONDITIONS AND MONITORING REQUIREMENTS**

The effluent limitations and monitoring requirements for those parameters that are limited in the draft permit are as follows:

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

The annual average flow of effluent shall not exceed 1.98 MGD.

<u>Parameter</u>	<u>30-Day Average</u>		<u>7-Day</u>	<u>Daily</u>
	<u>mg/l</u>	<u>lbs/day</u>	<u>Average</u>	<u>Maximum</u>
			<u>mg/l</u>	<u>mg/l</u>
CBOD <sub>5</sub>	10	165	15	25
TSS	15	248	25	40

Trinity Bay Conservation District TPDES Permit No. WQ0010851001  
 Fact Sheet and Executive Director’s Preliminary Decision

NH <sub>3</sub> -N				
April–September	10	165	25	50
October–March	12	198	30	60
DO (minimum)	5.0	N/A	N/A	N/A
<i>E. coli</i> , CFU or MPN per 100 ml	126	N/A	N/A	399

The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per week by grab sample. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.

The effluent shall contain a total chlorine residual of at least 1.0 mg/l after a detention time of at least 20 minutes (based on peak flow) and shall be monitored daily by grab sample at each chlorine contact chamber. The permittee shall dechlorinate the chlorinated effluent to less than 0.1 mg/l total chlorine residual and shall monitor total chlorine residual daily by grab sample after the dechlorination process. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.

<u>Parameter</u>	<u>Monitoring Requirement</u>
Flow, MGD	Continuous
CBOD <sub>5</sub>	Two/week
TSS	Two/week
NH <sub>3</sub> -N	Two/week
Total P	Two/week
DO	Two/week
<i>E. coli</i> /Enterococci	One/week

**B. SEWAGE SLUDGE REQUIREMENTS**

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal, and Transportation. The facility is a pond system and sludge from the ponds has not been removed for sludge disposal to date. The draft permit authorizes the disposal of sludge at any TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

**C. PRETREATMENT REQUIREMENTS**

Permit requirements for pretreatment are based on TPDES regulations contained in 30 TAC Chapter 305, which references 40 Code of Federal Regulations (CFR) Part 403, “General Pretreatment Regulations for Existing and New Sources of Pollution” [*rev. Federal Register/ Vol. 70/ No. 198/ Friday, October 14, 2005/ Rules and Regulations, pages 60134-60798*]. The permit includes specific requirements that establish responsibilities of local government, industry, and the public to implement the standards to control pollutants which pass through or interfere with treatment processes in publicly owned treatment works or which may contaminate the sewage sludge. This permit has appropriate pretreatment language for a facility of this size and complexity.

D. WHOLE EFFLUENT TOXICITY (BIOMONITORING) REQUIREMENTS

- (1) The draft permit includes 48-hour acute freshwater biomonitoring requirements as follows. The permit requires five dilutions in addition to the control (0% effluent) to be used in the toxicity tests. These additional effluent concentrations shall be 32%, 42%, 56%, 75%, and 100% . The low-flow effluent concentration (critical dilution) is defined as 100% effluent. The critical dilution is in accordance with the "Aquatic Life Criteria" section of the "Water Quality Based Effluent Limitations/Conditions" section.
  - (a) Acute static renewal 48-hour definitive toxicity tests using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*). The frequency of the testing is once per quarter for at least the first year of testing, after which the permittee may apply for a testing frequency reduction.
  - (b) Acute static renewal 48-hour definitive toxicity test using the fathead minnow (*Pimephales promelas*). The frequency of the testing is once per quarter for at least the first year of testing, after which the permittee may apply for a testing frequency reduction.
- (2) The draft permit includes the following minimum 24-hour acute freshwater biomonitoring requirements at a frequency of once per six months:
  - (a) Acute 24-hour static toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*).
  - (b) Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*).

E. SUMMARY OF CHANGES FROM APPLICATION

None.

F. SUMMARY OF CHANGES FROM EXISTING PERMIT

The Standard Permit Conditions, Sludge Provisions, Other Requirements, and Biomonitoring sections of the draft permit have been updated. Pretreatment requirements have been continued in the draft permit.

For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

Certain accidental discharges or spills of treated or untreated wastewater from wastewater treatment facilities or collection systems owned or operated by a local government may be reported on a monthly basis in accordance with 30 TAC §

305.132.

The draft permit includes all updates based on the 30 TAC § 312 rule change effective April 23, 2020.

## **8. DRAFT PERMIT RATIONALE**

### **A. TECHNOLOGY-BASED EFFLUENT LIMITATIONS/CONDITIONS**

Regulations promulgated in Title 40 of the CFR require that technology-based limitations be placed in wastewater discharge permits based on effluent limitations guidelines, where applicable, or on best professional judgment (BPJ) in the absence of guidelines.

Effluent limitations for maximum and minimum pH are in accordance with 40 CFR § 133.102(c) and 30 TAC § 309.1(b).

### **B. WATER QUALITY SUMMARY AND COASTAL MANAGEMENT PLAN**

#### **(1) WATER QUALITY SUMMARY**

The treated effluent is discharged to South Fork Mayhaw Bayou, thence to Mayhaw Bayou, thence to South Fork Taylor Bayou, thence to Taylor Bayou Above Tidal in Segment No. 0701 of the Neches-Trinity Coastal Basin. The unclassified receiving water use is minimal aquatic life use for South Fork Mayhaw Bayou. The designated uses for Segment No. 0701 are primary contact recreation and intermediate aquatic life use. The effluent limitations in the draft permit will maintain and protect the existing instream uses. All determinations are preliminary and subject to additional review and/or revisions.

The discharge from this permit action is not expected to have an effect on any federal endangered or threatened aquatic or aquatic-dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS) biological opinion on the State of Texas authorization of the TPDES (September 14, 1998; October 21, 1998, update). To make this determination for TPDES permits, TCEQ and EPA only considered aquatic or aquatic-dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. Though the piping plover, *Charadrius melodius* Ord, can occur in pick one or both as appropriate Chambers County, the county is north of Copano Bay and not a watershed of high priority per Appendix A of the biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Segment No. 0701 is currently listed on the state's inventory of impaired and threatened waters (the 2024 CWA § 303(d) list). The listing is specifically for depressed dissolved oxygen in a reach extending from the saltwater lock 7.7 km (4.8 mi) downstream of State Highway 73 in

Jefferson County, per WQS App. C, upstream to the confluences with North Fork Taylor Bayou and South Fork Bayou (Assessment Units 0701\_01 and 0701\_02). This discharge is into the watershed of the dissolved oxygen impaired portion of Segment No. 0701. This application is for renewal of an existing authorization and does not represent an increase in the permitted levels of oxygen demanding constituents to the watershed of the impairment.

The pollutant analysis of treated effluent provided by the permittee in the application indicated 238 mg/l total dissolved solids (TDS), 29 mg/l sulfate, and 42.3 mg/l chloride present in the effluent. The segment criteria for Segment No. 0701 are 234 mg/l for TDS, 35 mg/l for sulfate, and 54 mg/l for chlorides. Based on dissolved solids screening, no additional limits or monitoring requirements are needed for total dissolved solids, chloride, or sulfate.

The effluent limitations and conditions in the draft permit comply with EPA-approved portions of the 2018 Texas Surface Water Quality Standards (TSWQS), 30 TAC §§ 307.1 - 307.10, effective March 1, 2018; 2014 TSWQS, effective March 6, 2014; 2010 TSWQS, effective July 22, 2010; and 2000 TSWQS, effective July 26, 2000.

(2) CONVENTIONAL PARAMETERS

Effluent limitations for the conventional effluent parameters (i.e., Five-Day Biochemical Oxygen Demand or Five-Day Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water quality-limited streams as established in the TSWQS and the State of Texas Water Quality Management Plan (WQMP).

The effluent limitations in the draft permit have been reviewed for consistency with the WQMP. The existing effluent limitations are consistent with the approved WQMP.

The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Effluent Limitations.

(3) COASTAL MANAGEMENT PLAN

The Executive Director has reviewed this action for consistency with the goals and policies of the Texas Coastal Management Program (CMP) in accordance with the regulations of the General Land Office (GLO) and has determined that the action is consistent with the applicable CMP goals and policies.

C. WATER QUALITY-BASED EFFLUENT LIMITATIONS/CONDITIONS

(1) GENERAL COMMENTS

The Texas Surface Water Quality Standards (30 TAC Chapter 307) state that surface waters will not be toxic to man, or to terrestrial or aquatic life. The methodology outlined in the "Procedures to Implement the Texas Surface Water Quality Standards" is designed to ensure compliance with 30 TAC Chapter 307. Specifically, the methodology is designed to ensure that no source will be allowed to discharge any wastewater that: (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical state water quality standard; (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation that threatens human health.

(2) AQUATIC LIFE CRITERIA

(a) SCREENING

Water quality-based effluent limitations are calculated from freshwater aquatic life criteria found in Table 1 of the Texas Surface Water Quality Standards (30 TAC Chapter 307).

There is no mixing zone or zone of initial dilution for this discharge directly to an intermittent stream; acute freshwater criteria apply at the end of pipe. Chronic freshwater criteria do not apply to discharges to intermittent streams where there is no perennial waterbody within three miles downstream from the point of discharge. The following critical effluent percentage is being used:

Acute Effluent %: 100%

Waste load allocations (WLAs) are calculated using the above estimated effluent percentages, criteria outlined in the Texas Surface Water Quality Standards, and partitioning coefficients for metals (when appropriate and designated in the implementation procedures). The WLA is the end-of-pipe effluent concentration that can be discharged when, after mixing in the receiving stream, instream numerical criteria will not be exceeded. From the WLA, a long-term average (LTA) is calculated using a log normal probability distribution, a given coefficient of variation (0.6), and a 90<sup>th</sup> percentile confidence level. The LTA is the long-term average effluent concentration for which the WLA will never be exceeded using a selected percentile confidence level. The LTA is used to calculate a daily average and daily maximum effluent limitation for the protection of aquatic life using the same statistical considerations with the 99<sup>th</sup> percentile confidence level and a standard number of monthly effluent samples collected (12). Assumptions used in deriving the effluent limitations include segment values for hardness, chlorides, pH, and total suspended solids (TSS) according to the segment-specific values contained in the TCEQ guidance document "*Procedures to Implement the Texas Surface Water Quality Standards.*" The segment values are 58 mg/l for hardness (as calcium carbonate), 54 mg/l chlorides, 6.8 standard units for pH, and 11 mg/l for TSS. For additional details on the calculation of water quality-based effluent limitations, refer to the TCEQ guidance document.

TCEQ practice for determining significant potential is to compare the reported analytical data against percentages of the calculated daily average water quality-based effluent limitation. Permit limitations are required when analytical data reported in the application exceeds 85% of the calculated daily average water quality-based effluent limitation. Monitoring and reporting is required when analytical data reported in the application exceeds 70% of the calculated daily average water quality-based effluent limitation. See Attachment A of this Fact Sheet.

(b) PERMIT ACTION

Analytical data reported in the application was screened against calculated water quality-based effluent limitations for the protection of aquatic life. Reported analytical data does not exceed 70% of the calculated daily average water quality-based effluent limitations for aquatic life protection.

(3) AQUATIC ORGANISM BIOACCUMULATION CRITERIA

(a) SCREENING

The discharge point is located at a distance greater than three miles upstream of perennial waters. Human health screening is not applicable because of the distance between the discharge point and perennial waters that support fisheries.

(b) PERMIT ACTION

None.

(4) DRINKING WATER SUPPLY PROTECTION

(a) SCREENING

Water Quality Segment No. 0701, which receives the discharge from this facility, is not designated as a public water supply. Screening reported analytical data of the effluent against water quality-based effluent limitations calculated for the protection of a drinking water supply is not applicable.

(b) PERMIT ACTION

None.

(5) WHOLE EFFLUENT TOXICITY (BIOMONITORING) CRITERIA

(a) SCREENING

TCEQ has determined that there may be pollutants present in the effluent that may have the potential to cause toxic conditions in the receiving

stream. Whole effluent biomonitoring is the most direct measure of potential toxicity that incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. Biomonitoring of the effluent is, therefore, required as a condition of this permit to assess potential toxicity.

The existing permit includes 48-hour acute freshwater biomonitoring requirements. A summary of the biomonitoring testing for the facility indicates that a reasonable potential determination was performed in accordance with 40 CFR §122.44(d)(1)(ii) to determine whether the discharge will reasonably be expected to cause or contribute to an exceedance of a state water quality standard or criterion within that standard. Each test species is evaluated separately. The RP determination is based on representative data from the previous three years of 48-hour acute WET testing. This determination was performed in accordance with the methodology outlined in the TCEQ letter to the EPA dated December 28, 2015, and approved by the EPA in a letter dated December 28, 2015.

(b) PERMIT ACTION

With zero failures except as noted, a determination of no RP was made, and WET limits are not required. Both test species are eligible for the testing frequency reduction after one year of quarterly testing.

(6) WHOLE EFFLUENT TOXICITY CRITERIA (24-HOUR ACUTE)

(a) SCREENING

The existing permit includes 24-hour acute freshwater biomonitoring language. A summary of the biomonitoring testing for the facility indicates that in the past three years, the permittee has performed twelve 24-hour acute tests, with zero demonstrations of significant lethality (i.e., zero failures).

(b) PERMIT ACTION

With zero failures except as noted, a determination of no RP was made, and WET limits are not required. Both test species are eligible for the testing frequency reduction after one year of quarterly testing.

**9. WATER QUALITY VARIANCE REQUESTS**

No variance requests have been received.

**10. PROCEDURES FOR FINAL DECISION**

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place

throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Sujata Sinha at (512) 239-1963.

#### **11. ADMINISTRATIVE RECORD**

The following items were considered in developing the draft permit:

A. PERMIT(S)

TPDES Permit No. WQ0010851001 issued on July 2, 2020.

B. APPLICATION

Application received on December 17, 2024, and additional information received on October 27, 2025.

C. MEMORANDA

Interoffice Memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division. Interoffice Memorandum from the Pretreatment Team of the TCEQ Water Quality Division.

D. MISCELLANEOUS

Federal Clean Water Act § 402; Texas Water Code § 26.027; 30 TAC Chapters 30, 305, 309, 312, and 319; Commission policies; and U.S. Environmental Protection Agency guidelines.

Texas Surface Water Quality Standards, 30 TAC §§ 307.1 - 307.10.

*Procedures to Implement the Texas Surface Water Quality Standards (IP)*, Texas Commission on Environmental Quality, June 2010, as approved by the U.S. Environmental Protection Agency, and the IP, January 2003, for portions of the 2010 IP not approved by the U.S. Environmental Protection Agency.

Texas 2024 Clean Water Act Section 303(d) List, Texas Commission on Environmental Quality, June 26, 2024; approved by the U.S. Environmental Protection Agency on November 13, 2024.

Texas Natural Resource Conservation Commission, Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.

Trinity Bay Conservation District TPDES Permit No. WQ0010851001  
 Fact Sheet and Executive Director's Preliminary Decision

**Attachment A: Calculated Water Quality Based Effluent Limitations**

**TEXTTOX MENU #1 - INTERMITTENT STREAM**

The water quality-based effluent limitations developed below are calculated using:

Table 1, 2014 Texas Surface Water Quality Standards (30 TAC 307) for Freshwater Aquatic Life  
 "Procedures to Implement the Texas Surface Water Quality Standards," TCEQ, June 2010

**PERMIT INFORMATION**

Permittee Name:	Trinity Bay Conservation District
TPDES Permit No:	WQ0010851001
Outfall No:	001
Prepared By:	Sujata Sinha
Date:	10/20/2025

**DISCHARGE INFORMATION**

Intermittent Receiving Waterbody:	South Fork Mayhaw Bayou
Segment No:	0701
TSS (mg/L):	12
pH (Standard Units):	6.8
Hardness (mg/L as CaCO <sub>3</sub> ):	58
Chloride (mg/L):	54
Effluent Flow for Aquatic Life (MGD):	1.98
Critical Low Flow [7Q2] (cfs):	0
% Effluent for Acute Aquatic Life:	100

**CALCULATE DISSOLVED FRACTION (AND ENTER WATER EFFECT RATIO IF APPLICABLE):**

<i>Stream/River Metal</i>	<i>Intercept (b)</i>	<i>Slope (m)</i>	<i>Partition Coefficient (Kp)</i>	<i>Dissolved Fraction (Cd/Ct)</i>	<i>Source</i>	<i>Water Effect Ratio (WER)</i>	<i>Source</i>
Aluminum	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Arsenic	5.68	-0.73	78018.52	0.516		1.00	Assumed
Cadmium	6.60	-1.13	240173.56	0.258		1.00	Assumed
Chromium (total)	6.52	-0.93	328368.46	0.202		1.00	Assumed
Chromium (trivalent)	6.52	-0.93	328368.46	0.202		1.00	Assumed
Chromium (hexavalent)	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Copper	6.02	-0.74	166496.80	0.334		1.00	Assumed
Lead	6.45	-0.80	386060.17	0.178		1.00	Assumed
Mercury	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Nickel	5.69	-0.57	118813.75	0.412		1.00	Assumed
Selenium	N/A	N/A	N/A	1.00	Assumed	1.00	Assumed
Silver	6.38	-1.03	185542.46	0.310		1.00	Assumed
Zinc	6.10	-0.70	221092.05	0.274		1.00	Assumed

**AQUATIC LIFE**

**CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:**

<i>Parameter</i>	<i>FW Acute Criterion (µg/L)</i>	<i>WLAa (µg/L)</i>	<i>LTAa (µg/L)</i>	<i>Daily Avg. (µg/L)</i>	<i>Daily Max. (µg/L)</i>
Aldrin	3.0	3.00	1.72	2.52	5.34
Aluminum	991	991	568	834	1765
Arsenic	340	658	377	554	1173
Cadmium	5.051947	19.6	11.2	16.5	34.9
Carbaryl	2.0	2.00	1.15	1.68	3.56
Chlordane	2.4	2.40	1.38	2.02	4.27
Chlorpyrifos	0.083	0.0830	0.0476	0.0699	0.147

Trinity Bay Conservation District TPDES Permit No. WQ0010851001  
 Fact Sheet and Executive Director's Preliminary Decision

Chromium (trivalent)	364.7053	1802	1032	1517	3210
Chromium (hexavalent)	15.7	15.7	9.00	13.2	27.9
Copper	8.500521	25.5	14.6	21.4	45.4
Cyanide (free)	45.8	45.8	26.2	38.5	81.6
4,4'-DDT	1.1	1.10	0.630	0.926	1.96
Demeton	N/A	N/A	N/A	N/A	N/A
Diazinon	0.17	0.170	0.0974	0.143	0.302
Dicofol [Kelthane]	59.3	59.3	34.0	49.9	105
Dieldrin	0.24	0.240	0.138	0.202	0.427
Diuron	210	210	120	176	374
Endosulfan I ( <i>alpha</i> )	0.22	0.220	0.126	0.185	0.392
Endosulfan II ( <i>beta</i> )	0.22	0.220	0.126	0.185	0.392
Endosulfan sulfate	0.22	0.220	0.126	0.185	0.392
Endrin	0.086	0.0860	0.0493	0.0724	0.153
Guthion [Azinphos Methyl]	N/A	N/A	N/A	N/A	N/A
Heptachlor	0.52	0.520	0.298	0.438	0.926
Hexachlorocyclohexane ( <i>gamma</i> ) [Lindane]	1.126	1.13	0.645	0.948	2.00
Lead	35.52059	200	115	168	356
Malathion	N/A	N/A	N/A	N/A	N/A
Mercury	2.4	2.40	1.38	2.02	4.27
Methoxychlor	N/A	N/A	N/A	N/A	N/A
Mirex	N/A	N/A	N/A	N/A	N/A
Nickel	295.3416	716	411	603	1276
Nonylphenol	28	28.0	16.0	23.5	49.8
Parathion (ethyl)	0.065	0.0650	0.0372	0.0547	0.115
Pentachlorophenol	7.134913	7.13	4.09	6.00	12.7
Phenanthrene	30	30.0	17.2	25.2	53.4
Polychlorinated Biphenyls [PCBs]	2.0	2.00	1.15	1.68	3.56
Selenium	20	20.0	11.5	16.8	35.6
Silver	0.8	12.1	6.92	10.1	21.5
Toxaphene	0.78	0.780	0.447	0.657	1.38
Tributyltin [TBT]	0.13	0.130	0.0745	0.109	0.231
2,4,5 Trichlorophenol	136	136	77.9	114	242
Zinc	73.85973	270	155	227	480

**CALCULATE 70% AND 85% OF DAILY AVERAGE EFFLUENT LIMITATIONS:**

<b>Aquatic Life</b>	<b>70% of Daily Avg.</b>	<b>85% of Daily Avg.</b>
<b>Parameter</b>	<b>(µg/L)</b>	<b>(µg/L)</b>
Aldrin	1.76	2.14
Aluminum	584	709
Arsenic	388	471
Cadmium	11.5	14.0
Carbaryl	1.17	1.43
Chlordane	1.41	1.71
Chlorpyrifos	0.0489	0.0594
Chromium (trivalent)	1062	1290
Chromium (hexavalent)	9.25	11.2
Copper	15.0	18.2
Cyanide (free)	27.0	32.7
4,4'-DDT	0.648	0.787
Demeton	N/A	N/A

Trinity Bay Conservation District TPDES Permit No. WQ0010851001  
 Fact Sheet and Executive Director's Preliminary Decision

Diazinon	0.100	0.121
Dicofol [Kelthane]	34.9	42.4
Dieldrin	0.141	0.171
Diuron	123	150
Endosulfan I ( <i>alpha</i> )	0.129	0.157
Endosulfan II ( <i>beta</i> )	0.129	0.157
Endosulfan sulfate	0.129	0.157
Endrin	0.0507	0.0615
Guthion [Azinphos Methyl]	N/A	N/A
Heptachlor	0.306	0.372
Hexachlorocyclohexane ( <i>gamma</i> ) [Lindane]	0.663	0.806
Lead	117	143
Malathion	N/A	N/A
Mercury	1.41	1.71
Methoxychlor	N/A	N/A
Mirex	N/A	N/A
Nickel	422	512
Nonylphenol	16.5	20.0
Parathion (ethyl)	0.0383	0.0465
Pentachlorophenol	4.20	5.10
Phenanthrene	17.6	21.4
Polychlorinated Biphenyls [PCBs]	1.17	1.43
Selenium	11.7	14.3
Silver	7.11	8.64
Toxaphene	0.459	0.558
Tributyltin [TBT]	0.0766	0.0930
2,4,5 Trichlorophenol	80.1	97.3
Zinc	159	193