



Administrative Package Cover Page

This file contains the following documents:

1. Summary of application (in plain language)
 - English
 - Alternative Language (Spanish)
 2. First Notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
 - English
 - Alternative Language (Spanish)
 3. Application materials
-



Portada de Paquete Administrativo

Este archivo contiene los siguientes documentos:

1. Resumen de la solicitud (en lenguaje sencillo)
 - Inglés
 - Idioma alternativo (español)
2. Primer aviso (NORI- Aviso de Recepción de Solicitud e Intención de Obtener un Permiso)
 - Inglés
 - Idioma alternativo (español)
3. Materiales de la solicitud

CSWR-Texas (CN605844786) operates Fountainview wastewater treatment facility (WWTF), (RN101608586), a wastewater treatment plant used in the transportation, storage, and disposal of domestic sewage under the jurisdiction of the Texas Commission on Environmental Quality (TCEQ). The facility is located at 5530 N Sam Houston Parkway, in Houston, Harris County, Texas 77032.

This application is for a renewal to discharge an average annual flow of 380,000 gallons per day of treated domestic wastewater through Outfall 001.

The facility is expected to discharge carbonaceous biochemical oxygen demand (CBOD), total suspended solids (TSS), ammoniacal nitrogen (NH₃-N) and *Escherichia coli*. At this plant, domestic wastewater is treated by removing large solids, aeration and clarification. Sludge is further treated in digester basins. Wastewater is disinfected with chlorine before being discharged.

CSWR-Texas (CN605844786) opera la instalación de tratamiento de aguas residuales de Fountainview, (RN101608586), una planta de tratamiento de aguas residuales utilizada en el transporte, almacenamiento y eliminación de aguas residuales domésticas bajo la jurisdicción de la Comisión de Calidad Ambiental de Texas (TCEQ). La instalación está ubicada en 5530 N Sam Houston Parkway, en Houston, Condado de Harris, Texas 77032.

Esta solicitud es para una renovación para descargar un flujo anual promedio de 380,000 galones por día de aguas residuales domésticas tratadas a través del Emisario 001.

Se espera que la instalación descargue demanda bioquímica de oxígeno carbonoso (CBOD), sólidos suspendidos totales (SST), nitrógeno amoniacal (NH₃-N) y *Escherichia coli*. En esta planta se realizan el tratamiento de aguas residuales domésticas mediante eliminación de sólidos grandes, aireación y clarificación. Los lodos se tratan posteriormente en cuencas digestoras. Las aguas residuales se desinfectan con cloro antes de ser vertidas.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT RENEWAL

PERMIT NO. WQ0011200001

APPLICATION. CSWR-Texas Utility Operating Company, LLC, 1630 Des Peres Road, Suite 140, Des Peres, Missouri 63131, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0011200001 (EPA I.D. No. TX0031461) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 380,000 gallons per day. The domestic wastewater treatment facility is located at 5530 North Sam Houston Parkway East, Houston, in Harris County, Texas 77032. The discharge route is from the plant site to a Harris County Flood Control District ditch; thence to Greens Bayou Above Tidal. TCEQ received this application on April 16, 2024. The permit application will be available for viewing and copying at United States Postal Service, 1411 Wunsche Loop, Spring, in Harris County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: <https://www.tceq.texas.gov/permitting/wastewater/tpdes-applications>. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application. <https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.310783,29.937964&level=18>

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at: <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>. El aviso de idioma alternativo en español está disponible en <https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications>.

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. **Notice of the Application and Preliminary Decision will be published and mailed to those who are on the county-wide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.**

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public

interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. **Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application.** If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. **If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.**

TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met./

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at <https://www14.tceq.texas.gov/epic/eComment/>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from CSWR-Texas Utility Operating Company, LLC at the address stated above or by calling Mrs. April Dobbins, M.B.A., EHS Compliance, at 314-380-9508.

Issuance Date: June 5, 2024

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO. WQ0011200001

SOLICITUD. CSWR-Texas Utility Operating Company, LLC, 1630 Des Peres Road, Suite 140, Des Peres, Missouri 63131, ha solicitado a la La Comisión de Calidad Ambiental de Texas (TCEQ) para renovar el Permiso No. Permiso No. WQ0011200001 (EPA I.D. No. TX0031461) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio de 380,000 galones por día. La planta está ubicada en 5530 North Sam Houston Parkway East, Houston, en el Condado de Harris, Texas 77032. La descarga la ruta es desde el sitio de la planta hasta una zanja del Distrito de Control de Inundaciones del Condado de Harris; de allí a los verdes Pantano por encima de la marea. TCEQ recibió esta solicitud el 16 de abril de 2024. La solicitud para el permiso estará disponible para leerla y copiarla en United States Postal Service, 1411 Wunsche Loop, Spring, en el condado de Harris, Texas, antes de la fecha de publicación de este aviso en el periódico. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.310833,29.938055&level=18>

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. **El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.**

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar **comentarios públicos o pedir una reunión pública sobre esta solicitud.** El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO. Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. **A menos que la solicitud haya sido referida**

directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas de correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agregue su nombre en una de las listas designe cual lista(s) y envía por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía

<http://www14.tceq.texas.gov/epic/eComment/> o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener más información de CSWR-Texas Utility Operating Company, LLC a la dirección indicada arriba o llamando a la Sra. April Dobbins, M.B.A., Cumplimiento de EHS, al 314-380-9508.

Fecha de emission: 5 de junio de 2024

Erwin Madrid

From: steers@tceq.texas.gov
Sent: Wednesday, April 17, 2024 10:46 AM
To: Krista Obernuefemann
Subject: TCEQ ePay Receipt for 582EA000606784

This is an automated message from the TCEQ ePay system. Please do not reply.

Trace Number: 582EA000606784

Date: 04/17/2024 10:46 AM

Payment Method: ACH - Authorization 0070274806 TCEQ Amount: \$1,215.00 Texas.gov Price: \$1,215.00*

* This service is provided by Texas.gov, the official website of Texas. The price of this service includes funds that support the ongoing operations and enhancements of Texas.gov, which is provided by a third party in partnership with the State.

Actor: KRISTA OBERNUEFEMANN
Email: krista@cswrgroup.com

Payment Contact: KRISTA OBERNUEFEMANN
Phone: 314-380-8515
Company: CSWR TEXAS UTILITY OPERATING CO
Address: 1630 DES PERES RD STE 140, ST LOUIS, MO 63131

Fees Paid:

Fee Description	AR Number	Amount
-----------------	-----------	--------

WW PERMIT - FACILITY WITH FLOW >= .25 & < .50 MGD - RENEWAL		\$1,200.00
---	--	------------

30 TAC 305.53B WQ RENEWAL NOTIFICATION FEE		\$15.00
--	--	---------

TCEQ Amount: \$1,215.00

=====

Voucher: 701718

Trace Number: 582EA000606784

Date: 04/17/2024 10:46 AM

Payment Method: ACH - Authorization 0070274806 Voucher Amount: \$1,200.00 Fee Paid: WW PERMIT - FACILITY WITH FLOW >= .25 & < .50 MGD - RENEWAL RN Number: RN101608586 Site Name: FOUNTAINVIEW WASTEWATER TREATMENT FACILITY Site Location: 5530 N SAM PKWY EAST HOUSTON TX 77032 Customer Name: CSWR-TEXAS UTILITY OPERATING COMPANY LLC Customer Address: 1630 DES PERES RD STE 140, ST LOUIS, MO 63131 Program Area ID: WQ0011200001

Voucher: 701719

Trace Number: 582EA000606784

Date: 04/17/2024 10:46 AM

Payment Method: ACH - Authorization 0070274806 Voucher Amount: \$15.00 Fee Paid: 30 TAC 305.53B WQ RENEWAL NOTIFICATION FEE

=====

To print out a copy of the receipt and vouchers for this transaction either click on or copy and paste the following url into your browser:

https://nam12.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww3.tceq.texas.gov%2Fepay%2Findex.cfm%3Ffuseaction%3Dcor.search%26trace_num_txt%3D582EA000606784&data=05%7C02%7Ckrista%40cswrgroup.com%7C7c2

01efbdf1540deae2008dc5ef581ca%7C06f916ed67ae4182a05de0515983a000%7C0%7C0%7C638489655745416576%7C
Unknown%7CTWFpbGZsb3d8eyJWljoiMC4wLjAwMDAiLCJQIjoiV2luMzliLCJBTiI6Ik1haWwiLCJXVCi6Mn0%3D%7C0%7C%7
C%7C&sdata=L6gyO%2FKuF1mmJ9oXvhoM%2B91%2FPRvS12o2nUtz2Qbvrxo%3D&reserved=0.

This e-mail transmission and any attachments are believed to have been sent free of any virus or other defect that might affect any computer system into which it is received and opened. It is, however, the recipient's responsibility to ensure that the e-mail transmission and any attachments are virus free, and the sender accepts no responsibility for any damage that may in any way arise from their use.



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

APPLICANT: CSWR - Texas Utility Operating Company, LLC

PERMIT NUMBER: WQ0011200001

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Original USGS Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Administrative Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Affected Landowners Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
SPIF	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Landowner Disk or Labels	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Core Data Form	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Buffer Zone Map	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Public Involvement Plan Form	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Flow Diagram	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Site Drawing	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Technical Report 1.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Original Photographs	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Design Calculations	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 2.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Solids Management Plan	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Water Balance	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Worksheet 3.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 3.3	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 4.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 5.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 6.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			
Worksheet 7.0	<input type="checkbox"/>	<input checked="" type="checkbox"/>			

For TCEQ Use Only

Segment Number _____ County _____
 Expiration Date _____ Region _____
 Permit Number _____



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
**APPLICATION FOR A DOMESTIC WASTEWATER PERMIT
ADMINISTRATIVE REPORT 1.0**

If you have questions about completing this form please contact the Applications Review and Processing Team at 512-239-4671.

Section 1. Application Fees (Instructions Page 29)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
<0.05 MGD	\$350.00 <input type="checkbox"/>	\$315.00 <input type="checkbox"/>
≥0.05 but <0.10 MGD	\$550.00 <input type="checkbox"/>	\$515.00 <input type="checkbox"/>
≥0.10 but <0.25 MGD	\$850.00 <input type="checkbox"/>	\$815.00 <input type="checkbox"/>
≥0.25 but <0.50 MGD	\$1,250.00 <input type="checkbox"/>	\$1,215.00 <input checked="" type="checkbox"/>
≥0.50 but <1.0 MGD	\$1,650.00 <input type="checkbox"/>	\$1,615.00 <input type="checkbox"/>
≥1.0 MGD	\$2,050.00 <input type="checkbox"/>	\$2,015.00 <input type="checkbox"/>

Minor Amendment (for any flow) \$150.00 ☐

Payment Information:

Mailed Check/Money Order Number:
Check/Money Order Amount:
Name Printed on Check:
EPAY Voucher Number:
Copy of Payment Voucher enclosed? Yes ☐

Section 2. Type of Application (Instructions Page 29)

- | | |
|---|---|
| <input type="checkbox"/> New TPDES | <input type="checkbox"/> New TLAP |
| <input type="checkbox"/> Major Amendment <u>with</u> Renewal | <input checked="" type="checkbox"/> Minor Amendment <u>with</u> Renewal |
| <input type="checkbox"/> Major Amendment <u>without</u> Renewal | <input type="checkbox"/> Minor Amendment <u>without</u> Renewal |
| <input type="checkbox"/> Renewal without changes | <input type="checkbox"/> Minor Modification of permit |

For amendments or modifications, describe the proposed changes: Owner Change, Name Change

For existing permits:

Permit Number: WQ0011200001

EPA I.D. (TPDES only): TX0031461

Expiration Date: 09/18/2024

Section 3. Facility Owner (Applicant) and Co-Applciant Information (Instructions Page 29)

A. The owner of the facility must apply for the permit.

What is the Legal Name of the entity (applicant) applying for this permit?

CSWR-Texas Utility Operating Company, LLC

(The legal name must be spelled exactly as filed with the Texas Secretary of State, County, or in the legal documents forming the entity.)

If the applicant is currently a customer with the TCEQ, what is the Customer Number (CN)?
You may search for your CN on the TCEQ website at <http://www15.tceq.texas.gov/crpub/>

CN: 605844786

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Josiah Cox

Credential (P.E, P.G., Ph.D., etc.): N/A

Title: President

B. Co-applciant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applciant applying for this permit?

N/A

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the legal documents forming the entity.)

If the co-applciant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at:
<http://www15.tceq.texas.gov/crpub/>

CN: N/A

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix (Mr., Ms., Miss): N/A

First and Last Name: N/A

Credential (P.E, P.G., Ph.D., etc.): N/A

Title: N/A

Provide a brief description of the need for a co-permittee: N/A

C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0.

Attachment: Core Data Form Only

Section 4. Application Contact Information (Instructions Page 30)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix (Mr., Ms., Miss): Mrs.

First and Last Name: April Dobbins

Credential (P.E, P.G., Ph.D., etc.): M.B.A.

Title: EHS Compliance

Organization Name: CSWR

Mailing Address: 1630 Des Peres Road, Ste. 140

City, State, Zip Code: Des Peres, Missouri 63131

Phone No.: 314-380-9508 Ext.: N/A Fax No.: N/A

E-mail Address: adobbins@cswrgroup.com

Check one or both: ☒ Administrative Contact ☒ Technical Contact

B. Prefix (Mr., Ms., Miss): Ms.

First and Last Name: Amberly Schulz

Credential (P.E, P.G., Ph.D., etc.):

Title: Compliance Specialist

Organization Name: TRC

Mailing Address: 1000 Clark Avenue 4th Floor

City, State, Zip Code: St. Louis

Phone No.: 573-214-1075 Ext.: MO Fax No.: 63102

E-mail Address: aschulz@trccompanies.com

Check one or both: ☐ Administrative Contact ☒ Technical Contact

Section 5. Permit Contact Information (Instructions Page 30)

Provide two names of individuals that can be contacted throughout the permit term.

A. Prefix (Mr., Ms., Miss): Mrs.

First and Last Name: April Dobbins
Credential (P.E, P.G., Ph.D., etc.): M.B.A.
Title: EHS Compliance
Organization Name: CSWR
Mailing Address: 1630 Des Peres Road, Ste. 140
City, State, Zip Code: Des Peres, MO 63131
Phone No.: 314-380-9508 Ext.: N/A Fax No.: N/A
E-mail Address: adobbins@cswrgroup.com

B. Prefix (Mr., Ms., Miss): Mr.

First and Last Name: Karl Stephens
Credential (P.E, P.G., Ph.D., etc.):
Title: Regional Manager
Organization Name: CSWR
Mailing Address: 1630 Des Peres Road, Ste. 140
City, State, Zip Code: Des Peres, MO 63131
Phone No.: 314-380-8505 Ext.: N/A Fax No.: N/A
E-mail Address: karl@cswrgroup.com

Section 6. Billing Information (Instructions Page 30)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits ***in effect on September 1 of each year***. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix (Mr., Ms., Miss): Ms.
First and Last Name: Krista
Credential (P.E, P.G., Ph.D., etc.): Obernuefemann
Title: Accounts Payable
Organization Name: CSWR
Mailing Address: 1630 Des Peres Road, Ste. 140
City, State, Zip Code: Des Peres, MO 63131
Phone No.: 314-380-8515 Ext.: N/A Fax No.: N/A
E-mail Address: ap@cswrgroup.com

Section 7. DMR/MER Contact Information (Instructions Page 31)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (EPA 3320-1) or maintain Monthly Effluent Reports.

Prefix (Mr., Ms., Miss): Mrs.
First and Last Name: April Dobbins
Credential (P.E, P.G., Ph.D., etc.): M.B.A.
Title: EHS Compliance
Organization Name: CSWR
Mailing Address: 1630 Des Peres Road, Ste. 140
City, State, Zip Code: Des Peres, MO 63131
Phone No.: 314-380-9508 Ext.: N/A Fax No.: N/A
E-mail Address: adobbins@cswrgroup.com

DMR data is required to be submitted electronically. Create an account at:
<https://www.tceq.texas.gov/permitting/netdmr/netdmr.html>.

Section 8. Public Notice Information (Instructions Page 31)

A. Individual Publishing the Notices

Prefix (Mr., Ms., Miss): Mrs.
First and Last Name: April Dobbins
Credential (P.E, P.G., Ph.D., etc.): M.B.A.
Title: EHS Compliance
Organization Name: CSWR
Mailing Address: 1630 Des Peres Road, Ste. 140
City, State, Zip Code: Des Peres, MO 63131
Phone No.: 314-380-9508 Ext.: N/A Fax No.: N/A
E-mail Address: adobbins@cswrgroup.com

B. Method for Receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package

Indicate by a check mark the preferred method for receiving the first notice and instructions:

- ☒ E-mail Address
- ☐ Fax
- ☐ Regular Mail

C. Contact person to be listed in the Notices

Prefix (Mr., Ms., Miss): Mrs.
First and Last Name: April Dobbins

Credential (P.E, P.G., Ph.D., etc.): M.B.A.

Title: EHS Compliance

Organization Name: CSWR

Phone No.: 314-380-9508 Ext.: N/A

E-mail: adobbins@cswrgroup.com

D. Public Viewing Information

If the facility or outfall is located in more than one county, a public viewing place for each county must be provided.

Public building name: United States Postal Services

Location within the building: N/A

Physical Address of Building: 1411 Wunshe Loop

City: Spring

County: Harris

Contact Name: N/A

Phone No.: 281-288-8465 Ext.: N/A

E. Bilingual Notice Requirements:

This information is required for new, major amendment, minor amendment or minor modification, and renewal applications.

This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.

Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.

1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?

☒ Yes ☐ No

If **no**, publication of an alternative language notice is not required; **skip to** Section 9 below.

2. Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?

☒ Yes ☐ No

3. Do the students at these schools attend a bilingual education program at another location?

☐ Yes ☐ No

4. Would the school be required to provide a bilingual education program but the school has waived out of this requirement under 19 TAC §89.1205(g)?

☐ Yes ☐ No

5. If the answer is yes to question 1, 2, 3, or 4, public notices in an alternative language are required. Which language is required by the bilingual program? Spanish

F. Public Involvement Plan Form

Complete the Public Involvement Plan Form (TCEQ Form 20960) for each application for a new permit or major amendment to a permit and include as an attachment.

Attachment: Not necessary, this is a renewal with owner change only.

Section 9. Regulated Entity and Permitted Site Information (Instructions Page 33)

- A. If the site is currently regulated by TCEQ, provide the Regulated Entity Number (RN) issued to this site. RN101608586

Search the TCEQ's Central Registry at <http://www15.tceq.texas.gov/crpub/> to determine if the site is currently regulated by TCEQ.

- B. Name of project or site (the name known by the community where located):

Fountainview Wastewater Treatment Facility

- C. Owner of treatment facility: CSWR-Texas Utility Operating Company, LLC

Ownership of Facility: ☐ Public ☒ Private ☐ Both ☐ Federal

- D. Owner of land where treatment facility is or will be:

Prefix (Mr., Ms., Miss): Mr.

First and Last Name: CSWR-Texas Utility Operating Company, LLC

Mailing Address: 1630 Des Peres Road, Ste. 140

City, State, Zip Code: Des Peres, Missouri 63131

Phone No.: 314-736-4672

E-mail Address: jcox@cswrgroup.com

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: N/A

- E. Owner of effluent disposal site:

Prefix (Mr., Ms., Miss): N/A

First and Last Name: Houston County Flood Control Ditch

Mailing Address: 9900 NW Fwy

City, State, Zip Code: Houston, TX 77092

Phone No.: 346-286-4000

E-mail Address: [REDACTED]

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: N/A

- F. Owner of sewage sludge disposal site (if authorization is requested for sludge disposal on property owned or controlled by the applicant):

Prefix (Mr., Ms., Miss): N/A

First and Last Name: N/A

Mailing Address: N/A

City, State, Zip Code: N/A

Phone No.: N/A

E-mail Address: N/A

If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.

Attachment: N/A

Section 10. TPDES Discharge Information (Instructions Page 34)

- A. Is the wastewater treatment facility location in the existing permit accurate?

☒ Yes ☐ No

If **no**, or a new permit application, please give an accurate description:

N/A

- B. Are the point(s) of discharge and the discharge route(s) in the existing permit correct?

☒ Yes ☐ No

If **no**, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307:

N/A

City nearest the outfall(s): Houston

County in which the outfalls(s) is/are located: Harris

Outfall Latitude: 29.937659

Longitude: -95.310854

- C. Is or will the treated wastewater discharge to a city, county, or state highway right-of-way, or a flood control district drainage ditch?

☒ Yes ☐ No

If **yes**, indicate by a check mark if:

☒ Authorization granted ☐ Authorization pending

For **new and amendment** applications, provide copies of letters that show proof of contact and the approval letter upon receipt.

Attachment: N/A

- D. For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge.

N/A

Section 11. TLAP Disposal Information (Instructions Page 36)

- A. For TLAPs, is the location of the effluent disposal site in the existing permit accurate?

☐ Yes ☐ No

If **no, or a new or amendment permit application**, provide an accurate description of the disposal site location:

N/A

- B. City nearest the disposal site: N/A

- C. County in which the disposal site is located: N/A

- D. Disposal Site Latitude: N/A Longitude: N/A

- E. For TLAPs, describe the routing of effluent from the treatment facility to the disposal site:

N/A

- F. For TLAPs, please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained:

N/A

Section 12. Miscellaneous Information (Instructions Page 37)

- A. Is the facility located on or does the treated effluent cross American Indian Land?

☐ Yes ☒ No

- B. If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?

☐ Yes ☐ No ☒ Not Applicable

If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.

N/A

- C. Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?

☐ Yes ☒ No

If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application:

N/A

- D. Do you owe any fees to the TCEQ?

☐ Yes ☒ No

If yes, provide the following information:

Account number: N/A

Amount past due: N/A

- E. Do you owe any penalties to the TCEQ?

☐ Yes ☒ No

If yes, please provide the following information:

Enforcement order number: N/A

Amount past due: N/A

Section 13. Attachments (Instructions Page 38)

Indicate which attachments are included with the Administrative Report. Check all that apply:

- ☐ Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.
- ☐ Original full-size USGS Topographic Map with the following information:
 - Applicant's property boundary
 - Treatment facility boundary
 - Labeled point of discharge for each discharge point (TPDES only)

- Highlighted discharge route for each discharge point (TPDES only)
 - Onsite sewage sludge disposal site (if applicable)
 - Effluent disposal site boundaries (TLAP only)
 - New and future construction (if applicable)
 - 1 mile radius information
 - 3 miles downstream information (TPDES only)
 - All ponds.
- ☐ Attachment 1 for Individuals as co-applicants
- ☒ Other Attachments. Please specify: 8x12 reproduced topo map

Section 14. Signature Page (Instructions Page 39)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0011200001

Applicant: CSWR

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): Michael Duncan

Signatory title: Vice President

Signature: _____

(Use blue ink)

Date: _____

MD
4-16-24

Subscribed and Sworn to before me by the said Michael Duncan

on this 16th day of April, 20 24.

My commission expires on the 4th day of May, 20 24.

Daniel Janowiak
Notary Public

St. Louis
County, ~~Texas~~ Missouri

DANIEL RYAN JANOWIAK
Notary Public, Notary Seal
State of Missouri
St. Charles County
Commission # 20374795
My Commission Expires 05-04-2024

[SEAL]

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

1. Enter applicant's name here. (2. Enter Customer Number here (i.e., CN6#####).) 3. Choose from the drop-down menu. 4. Enter name of facility here. 5. Enter Regulated Entity Number here (i.e., RN1#####). 6. Choose from the drop-down menu. 7. Enter facility description here.. The facility 8. Choose from the drop-down menu. located 9. Enter location here. , in 10. Enter city name here., 11. Enter county name here. County, Texas 12. Enter zip code here..

13. Enter summary of application request here. <<For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain 14. List all expected pollutants here.. 15. Enter types of wastewater discharged here. 16. Choose from the drop-down menu, treated by 17. Enter a description of wastewater treatment used at the facility here..

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS

TPDES o TLAP

AGUAS RESIDUALES DOMÉSTICAS

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no son representaciones federales exigibles de la solicitud de permiso.

1. Introduzca el nombre del solicitante aquí. (2. Introduzca el número de cliente aquí (es decir, CN6 #####).) 3. Elija del menú desplegable. 4. Introduzca el nombre de la instalación aquí. 5. Introduzca el número de entidad regulada aquí (es decir, RN1 #####). 6. Elija del menú desplegable. 7. Introduzca la descripción de la instalación aquí. . La instalación 8. Elija del menú desplegable. ubicado 9. Introduzca la ubicación aquí. , en 10. Introduzca el nombre de la ciudad aquí. , Condado de 11. Introduzca el nombre del condado aquí. , Texas 12. Introduzca el código postal aquí. . 13. Introduzca el resumen de la solicitud de solicitud aquí. <<Para las aplicaciones de TLAP incluya la siguiente oración, de lo contrario, elimine:>> Este permiso no autorizará una descarga de contaminantes en el agua en el estado.

Se espera que las descargas de la instalación contengan 14. Liste todos los contaminantes esperados aquí. . 15. Introduzca los tipos de aguas residuales descargadas aquí. 16. Elija del menú desplegable. tratado por 17. Introduzca una descripción del tratamiento de aguas residuales utilizado en la instalación aquí.

DOMESTIC ADMINISTRATIVE REPORT 1.1

The following information is required for new and amendment applications.

Section 1. Affected Landowner Information (Instructions Page 41)

- A. Indicate by a check mark that the landowners map or drawing, with scale, includes the following information, as applicable:
- ☐ The applicant's property boundaries
 - ☐ The facility site boundaries within the applicant's property boundaries
 - ☐ The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone
 - ☐ The property boundaries of all landowners surrounding the applicant's property (Note: if the application is a major amendment for a lignite mine, the map must include the property boundaries of all landowners adjacent to the new facility (ponds).)
 - ☐ The point(s) of discharge and highlighted discharge route(s) clearly shown for one mile downstream
 - ☐ The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge
 - ☐ The property boundaries of the landowners along the watercourse for a one-half mile radius from the point of discharge if the point of discharge is into a lake, bay, estuary, or affected by tides
 - ☐ The boundaries of the effluent disposal site (for example, irrigation area or subsurface drainfield site) and all evaporation/holding ponds within the applicant's property
 - ☐ The property boundaries of all landowners surrounding the effluent disposal site
 - ☐ The boundaries of the sludge land application site (for land application of sewage sludge for beneficial use) and the property boundaries of landowners surrounding the applicant's property boundaries where the sewage sludge land application site is located
 - ☐ The property boundaries of landowners within one-half mile in all directions from the applicant's property boundaries where the sewage sludge disposal site (for example, sludge surface disposal site or sludge monofill) is located
- B. ☐ Indicate by a check mark that a separate list with the landowners' names and mailing addresses cross-referenced to the landowner's map has been provided.
- C. Indicate by a check mark in which format the landowners list is submitted:
- ☐ USB Drive ☐ Four sets of labels
- D. Provide the source of the landowners' names and mailing addresses: N/A
- E. As required by *Texas Water Code § 5.115*, is any permanent school fund land affected by this application?
- ☐ Yes ☐ No

If **yes**, provide the location and foreseeable impacts and effects this application has on the land(s):

Section 2. Original Photographs (Instructions Page 44)

Provide original ground level photographs. Indicate with checkmarks that the following information is provided.

- ☐ At least one original photograph of the new or expanded treatment unit location
- ☐ At least two photographs of the existing/proposed point of discharge and as much area downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is to an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.
- ☐ At least one photograph of the existing/proposed effluent disposal site
- ☐ A plot plan or map showing the location and direction of each photograph

Section 3. Buffer Zone Map (Instructions Page 44)

- A. Buffer zone map. Provide a buffer zone map on 8.5 x 11-inch paper with all of the following information. The applicant's property line and the buffer zone line may be distinguished by using dashes or symbols and appropriate labels.
- The applicant's property boundary;
 - The required buffer zone; and
 - Each treatment unit; and
 - The distance from each treatment unit to the property boundaries.
- B. Buffer zone compliance method. Indicate how the buffer zone requirements will be met. Check all that apply.
- ☐ Ownership
 - ☐ Restrictive easement
 - ☐ Nuisance odor control
 - ☐ Variance
- C. Unsuitable site characteristics. Does the facility comply with the requirements regarding unsuitable site characteristic found in 30 TAC § 309.13(a) through (d)?
- ☐ Yes ☐ No

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:

Application type: ____ Renewal ____ Major Amendment ____ Minor Amendment ____ New

County: _____ Segment Number: _____

Admin Complete Date: _____

Agency Receiving SPIF:

____ Texas Historical Commission

____ U.S. Fish and Wildlife

____ Texas Parks and Wildlife Department

____ U.S. Army Corps of Engineers

This form applies to TPDES permit applications only. (Instructions, Page 53)

The SPIF must be completed as a separate document. The TCEQ will mail a copy of the SPIF to each agency as required by the TCEQ agreement with EPA. If any of the items are not completely addressed or further information is needed, you will be contacted to provide the information before the permit is issued. Each item must be completely addressed.

Do not refer to a response of any item in the permit application form. Each attachment must be provided with this form separately from the administrative report of the application. The application will not be declared administratively complete without this form being completed in its entirety including all attachments.

The following applies to all applications:

1. Permittee:

Permit No. WQ00

EPA ID No. TX

Address of the project (or a location description that includes street/highway, city/vicinity, and county):

Provide the name, address, phone and fax number of an individual that can be contacted to answer specific questions about the property.

Prefix (Mr., Ms., Miss): [REDACTED]

First and Last Name: [REDACTED]

Credential (P.E, P.G., Ph.D., etc.): [REDACTED]

Title: [REDACTED]

Mailing Address: [REDACTED]

City, State, Zip Code: [REDACTED]

Phone No.: [REDACTED] Ext.: [REDACTED] Fax No.: [REDACTED]

E-mail Address: [REDACTED]

2. List the county in which the facility is located: [REDACTED]
3. If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.

4. Provide a description of the effluent discharge route. The discharge route must follow the flow of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.

5. Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report).

Provide original photographs of any structures 50 years or older on the property.

Does your project involve any of the following? Check all that apply.

- ☐ Proposed access roads, utility lines, construction easements
- ☐ Visual effects that could damage or detract from a historic property's integrity
- ☐ Vibration effects during construction or as a result of project design
- ☐ Additional phases of development that are planned for the future

- ☐ Sealing caves, fractures, sinkholes, other karst features
- ☐ Disturbance of vegetation or wetlands

6. List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):

7. Describe existing disturbances, vegetation, and land use:

THE FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR AMENDMENTS TO TPDES PERMITS

8. List construction dates of all buildings and structures on the property:

9. Provide a brief history of the property, and name of the architect/builder, if known.

WATER QUALITY PERMIT

PAYMENT SUBMITTAL FORM

Use this form to submit the Application Fee, if the mailing the payment.

- Complete items 1 through 5 below.
- Staple the check or money order in the space provided at the bottom of this document.
- **Do not mail this form with the application form.**
- Do not mail this form to the same address as the application.
- Do not submit a copy of the application with this form as it could cause duplicate permit entries.

Mail this form and the check or money order to:

BY REGULAR U.S. MAIL

Texas Commission on Environmental Quality
Financial Administration Division
Cashier's Office, MC-214
P.O. Box 13088
Austin, Texas 78711-3088

BY OVERNIGHT/EXPRESS MAIL

Texas Commission on Environmental Quality
Financial Administration Division
Cashier's Office, MC-214
12100 Park 35 Circle
Austin, Texas 78753

Fee Code: WQP Waste Permit No: WQ0011200001

1. Check or Money Order Number:
2. Check or Money Order Amount:
3. Date of Check or Money Order:
4. Name on Check or Money Order:

5. APPLICATION INFORMATION

Name of Project or Site: Fountainview WWTF

Physical Address of Project or Site: 5530 N Sam Pkwy East, Houston, TX 77032

If the check is for more than one application, attach a list which includes the name of each Project or Site (RE) and Physical Address, exactly as provided on the application.

Staple Check or Money Order in This Space

THIS PAGE INTENTIONALLY LEFT BLANK

ATTACHMENT 1

INDIVIDUAL INFORMATION

Section 1. Individual Information (Instructions Page 50)

Complete this attachment if the facility applicant or co-applicant is an individual. Make additional copies of this attachment if both are individuals.

Prefix (Mr., Ms., Miss):

Full legal name (first, middle, last):

Driver's License or State Identification Number:

Date of Birth:

Mailing Address:

City, State, and Zip Code:

Phone Number:

Fax Number:

E-mail Address:

CN:

For Commission Use Only:

Customer Number:

Regulated Entity Number:

Permit Number:

CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

Core Data Form (TCEQ Form No. 10400) ☒ Yes
(Required for all applications types. Must be completed in its entirety and signed.
Note: Form may be signed by applicant representative.)

Correct and Current Industrial Wastewater Permit Application Forms ☐ Yes
(TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018 or later.)

Water Quality Permit Payment Submittal Form (Page 19) ☒ Yes
(Original payment sent to TCEQ Revenue Section. See instructions for mailing address.)

7.5 Minute USGS Quadrangle Topographic Map Attached ☒ Yes
(Full-size map if seeking "New" permit.
8 ½ x 11 acceptable for Renewals and Amendments)

Current/Non-Expired, Executed Lease Agreement or Easement Attached ☒ N/A ☐ Yes

Landowners Map ☒ N/A ☐ Yes
(See instructions for landowner requirements)

Things to Know:

- All the items shown on the map must be labeled.
- The applicant's complete property boundaries must be delineated which includes boundaries of contiguous property owned by the applicant.
- The applicant cannot be its own adjacent landowner. You must identify the landowners immediately adjacent to their property, regardless of how far they are from the actual facility.
- If the applicant's property is adjacent to a road, creek, or stream, the landowners on the opposite side must be identified. Although the properties are not adjacent to applicant's property boundary, they are considered potentially affected landowners. If the adjacent road is a divided highway as identified on the USGS topographic map, the applicant does not have to identify the landowners on the opposite side of the highway.

Landowners Cross Reference List ☒ N/A ☐ Yes
(See instructions for landowner requirements)

Landowners Labels or USB Drive attached ☒ N/A ☐ Yes
(See instructions for landowner requirements)

Original signature per 30 TAC § 305.44 - Blue Ink Preferred ☒ Yes
(If signature page is not signed by an elected official or principle executive officer, a copy of signature authority/delegation letter must be attached)



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
DOMESTIC WASTEWATER PERMIT APPLICATION

DOMESTIC TECHNICAL REPORT 1.0

The Following Is Required For All Applications
Renewal, New, And Amendment

Section 1. Permitted or Proposed Flows (Instructions Page 51)

A. Existing/Interim I Phase

Design Flow (MGD): 0.024 MGD

2-Hr Peak Flow (MGD): 50 gpm

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

B. Interim II Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

C. Final Phase

Design Flow (MGD): 0.024 MGD

2-Hr Peak Flow (MGD): 50 gpm

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

D. Current operating phase: 0.024 MGD

Provide the startup date of the facility: Operating

Section 2. Treatment Process (Instructions Page 51)

A. Treatment process description

Provide a detailed description of the treatment process. **Include the type of**

treatment plant, mode of operation, and all treatment units. Start with the plant's head works and finish with the point of discharge. Include all sludge processing and drying units. If more than one phase exists or is proposed in the permit, a description of *each phase* must be provided. Process description:

The lift station delivers effluent to the influent splitter box, which sends effluent to the aeration basins. Effluent is then pumped to the clarifier, and to the aerobic digester. Treatment includes three blowers. Sludge removed, thickened, and hauled offsite. After treatment, effluent is passed through two chlorine contact basins and discharged to the outfall into Harris County Flood Control Ditch No. P133-00-00.

Port or pipe diameter at the discharge point, in inches: 24"

B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Aeration Basins	4	624 ft ² each, 52ft x 12ft x 12ft
Clarifier	1	44 ft Diameter 12 ft deep
Aerobic Digesters		12 ft x 52 ft x12 ft
Blowers	3	17 ft X 8.5 ft x 9.5 ft (all three in sequence)
Chlorine contact basins	2	Basin 1: 27.5 ft x 2 ft x 9 ft Basin 2: 26 ft x 12 ft x 12 ft
(See plans for details)		

C. Process flow diagrams

Provide flow diagrams for the existing facilities and **each** proposed phase of construction.

Attachment: WWTP Drawings

Section 3. Site Drawing (Instructions Page 52)

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment: Figure 1, Figure 2

Provide the name and a description of the area served by the treatment facility.

This treatment system serves the Tri-County Point Subdivision in Jackson County, Palacios, Texas.

Section 4. Unbuilt Phases (Instructions Page 52)

Is the application for a renewal of a permit that contains an unbuilt phase or phases?

Yes ☐ No ☒

If yes, does the existing permit contain a phase that has not been constructed within five years of being authorized by the TCEQ?

Yes ☐ No ☒

If yes, provide a detailed discussion regarding the continued need for the unbuilt phase. Failure to provide sufficient justification may result in the Executive Director recommending denial of the unbuilt phase or phases.

N/A

Section 5. Closure Plans (Instructions Page 53)

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

Yes ☐

No ☒

If yes, was a closure plan submitted to the TCEQ?

Yes ☐

No ☐

If yes, provide a brief description of the closure and the date of plan approval.

N/A

Section 6. Permit Specific Requirements (Instructions Page 53)

For applicants with an existing permit, check the *Other Requirements* or *Special Provisions* of the permit.

A. Summary transmittal

Have plans and specifications been approved for the existing facilities and each proposed phase?

Yes ☒

No ☐

If yes, provide the date(s) of approval for each phase: N/A

Provide information, including dates, on any actions taken to meet a requirement or provision pertaining to the submission of a summary transmittal letter. Provide a copy of an approval letter from the TCEQ, if applicable.

N/A

B. Buffer zones

Have the buffer zone requirements been met?

Yes ☒ No ☐

Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.

C. Other actions required by the current permit

Does the *Other Requirements* or *Special Provisions* section in the existing permit require submission of any other information or other required actions? Examples include Notification of Completion, progress reports, soil monitoring data, etc.

Yes ☒ No ☐

If yes, provide information below on the status of any actions taken to meet the conditions of an *Other Requirement* or *Special Provision*.

Protection of the facility from 100 yr flood:

D. Grit and grease treatment

1. Acceptance of grit and grease waste

Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?

Yes ☐ No ☒

If No, stop here and continue with Subsection E. Stormwater Management.

2. Grit and grease processing

Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.

N/A

3. Grit disposal

Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?

Yes ☐ No ☐

If No, contact the TCEQ Municipal Solid Waste team at 512-239-0000. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

Describe the method of grit disposal.

N/A

4. Grease and decanted liquid disposal

Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-0000.

Describe how the decant and grease are treated and disposed of after grit separation.

N/A

E. Stormwater management

1. Applicability

Does the facility have a design flow of 1.0 MGD or greater in any phase?

Yes ☐ No ☒

Does the facility have an approved pretreatment program, under 40 CFR Part 403?

Yes ☐ No ☒

If **no** to both of the above, then skip to Subsection F, Other Wastes Received.

2. MSGP coverage

Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?

Yes ☐ No ☐

If **yes**, please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:

TXR05 [REDACTED] or TXRNE [REDACTED]

If **no**, do you intend to seek coverage under TXR050000?

Yes ☐ No ☐

3. Conditional exclusion

Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?

Yes ☐ No ☐

If **yes**, please explain below then proceed to Subsection F, Other Wastes Received:

N/A

4. Existing coverage in individual permit

Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?

Yes ☐ No ☐

If **yes**, provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.

N/A

5. Zero stormwater discharge

Do you intend to have no discharge of stormwater via use of evaporation or other means?

Yes ☐ No ☐

If **yes**, explain below then skip to Subsection F. Other Wastes Received.

N/A

Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.

6. Request for coverage in individual permit

Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?

Yes ☐ No ☐

If **yes**, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you intend to divert stormwater to

the treatment plant headworks and indirectly discharge it to water in the state.

N/A

Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.

F. Discharges to the Lake Houston Watershed

Does the facility discharge in the Lake Houston watershed?

Yes ☐ No ☒

If yes, a Sewage Sludge Solids Management Plan is required. See Example 5 in the instructions.

G. Other wastes received including sludge from other WWTPs and septic waste

1. Acceptance of sludge from other WWTPs

Does the facility accept or will it accept sludge from other treatment plants at the facility site?

Yes ☐ No ☒

If yes, attach sewage sludge solids management plan. See Example 5 of the instructions.

In addition, provide the date that the plant started accepting sludge or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an estimate of the BOD₅ concentration of the sludge, and the design BOD₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

N/A

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

2. Acceptance of septic waste

Is the facility accepting or will it accept septic waste?

Yes ☐ No ☒

If yes, does the facility have a Type V processing unit?

Yes ☐ No ☐

If yes, does the unit have a Municipal Solid Waste permit?

Yes ☐ No ☐

If yes to any of the above, provide a the date that the plant started accepting septic waste, or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD₅ concentration of the septic waste, and the design BOD₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.

N/A

Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.

3. Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)

Is the facility accepting or will it accept wastes that are not domestic in nature excluding the categories listed above?

Yes ☐ No ☒

If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also

note if this information has or has not changed since the last permit action.

N/A

Section 7. Pollutant Analysis of Treated Effluent (Instructions Page 58)

Is the facility in operation?

Yes ☒

No ☐

If **no**, this section is not applicable. Proceed to Section 8.

If **yes**, provide effluent analysis data for the listed pollutants. **Wastewater treatment facilities** complete Table 1.0(2). **Water treatment facilities** discharging filter backwash water, complete Table 1.0(3).

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD ₅ , mg/l	2.03	2.03	1	grab	03/22/24 8:00
Total Suspended Solids, mg/l	2.11	2.11	1	grab	03/22/24 8:00
Ammonia Nitrogen, mg/l	<0.05	<0.05	1	grab	03/22/24 8:00
Nitrate Nitrogen, mg/l	0.736	0.736	1	grab	03/22/24 8:00
Total Kjeldahl Nitrogen, mg/l	1.23	1.23	1	grab	03/22/24 8:00
Sulfate, mg/l	23.7	23.7	1	grab	03/22/24 8:00
Chloride, mg/l	108	108	1	grab	03/22/24

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
					8:00
Total Phosphorus, mg/l	0.214	0.214	1	grab	03/22/24 8:00
pH, standard units	7.27	7.27	1	instant	03/22/24 8:00
Dissolved Oxygen*, mg/l	7.53	7.53	1	field	03/22/24 8:00
Chlorine Residual, mg/l	3.0	3.0	1	field	03/22/24 8:00
<i>E.coli</i> (CFU/100ml) freshwater	3.10	3.10	1	Grab (Colilert)	03/22/24 8:00
Enterococci (CFU/100ml) saltwater					
Total Dissolved Solids, mg/l	358	358	1	grab	03/22/24 8:00
Electrical Conductivity, µmohs/cm, †	726	726	1	grab	03/22/24 8:00
Oil & Grease, mg/l	<5.0	<5.0	1	grab	03/22/24 8:00
Alkalinity (CaCO ₃)*, mg/l	163	163	1	grab	03/22/24 8:00

*TPDES permits only

†TLAP permits only

Table 1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l					
Total Dissolved Solids, mg/l					
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO ₃), mg/l					

Section 8. Facility Operator (Instructions Page 60)

Facility Operator Name: Jonathon Helm and Eric Montez

Facility Operator's License Classification and Level: Wastewater Operator D

Facility Operator's License Number: WW0053123 and WW0072141, respectively

Section 9. Sewage Sludge Management and Disposal (Instructions Page 60)

A. Sludge disposal method

Identify the current or anticipated sludge disposal method or methods from the following list. Check all that apply.

- ☐ Permitted landfill
- ☐ Permitted or Registered land application site for beneficial use
- ☐ Land application for beneficial use authorized in the wastewater permit
- ☒ Permitted sludge processing facility
- ☐ Marketing and distribution as authorized in the wastewater permit
- ☐ Composting as authorized in the wastewater permit
- ☐ Permitted surface disposal site (sludge monofill)
- ☐ Surface disposal site (sludge monofill) authorized in the wastewater

permit

- ☐ Transported to another permitted wastewater treatment plant or permitted sludge processing facility. If you selected this method, a written statement or contractual agreement from the wastewater treatment plant or permitted sludge processing facility accepting the sludge must be included with this application.
- ☐ Other:

B. Sludge disposal site

Disposal site name: Richey Road District

TCEQ permit or registration number: 12378

County where disposal site is located: Harris

C. Sludge transportation method

Method of transportation (truck, train, pipe, other): Truck

Name of the hauler: GFL Environmental

Hauler registration number: 25978

Sludge is transported as a:

Liquid ☐ semi-liquid ☒ semi-solid ☐ solid ☐

**Section 10. Permit Authorization for Sewage Sludge Disposal
(Instructions Page 60)**

A. Beneficial use authorization

Does the existing permit include authorization for land application of sewage sludge for beneficial use?

Yes ☐ No ☒

If **yes**, are you requesting to continue this authorization to land apply sewage sludge for beneficial use?

Yes ☐ No ☐

If **yes**, is the completed **Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451)** attached to this permit application (see the instructions for details)?

Yes ☐ No ☐

B. Sludge processing authorization

Does the existing permit include authorization for any of the following sludge processing, storage or disposal options?

Sludge Composting	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
Marketing and Distribution of sludge	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
Sludge Surface Disposal or Sludge Monofill	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>
Temporary storage in sludge lagoons	Yes <input type="checkbox"/>	No <input checked="" type="checkbox"/>

If yes to any of the above sludge options and the applicant is requesting to continue this authorization, is the completed **Domestic Wastewater Permit Application: Sewage Sludge Technical Report (TCEQ Form No. 10056)** attached to this permit application?

Yes ☐ No ☒

Section 11. Sewage Sludge Lagoons (Instructions Page 61)

Does this facility include sewage sludge lagoons?

Yes ☐ No ☒

If yes, complete the remainder of this section. If no, proceed to Section 12.

A. Location information

The following maps are required to be submitted as part of the application. For each map, provide the Attachment Number.

- Original General Highway (County) Map:

Attachment: N/A

- USDA Natural Resources Conservation Service Soil Map:

Attachment: N/A

- Federal Emergency Management Map:

Attachment: N/A

- Site map:

Attachment: N/A

Discuss in a description if any of the following exist within the lagoon area.

Check all that apply.

- ☐ Overlap a designated 100-year frequency flood plain

- ☐ Soils with flooding classification
- ☐ Overlap an unstable area
- ☐ Wetlands
- ☐ Located less than 60 meters from a fault
- ☐ None of the above

Attachment: N/A

If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide the protective measures to be utilized including type and size of protective structures:

N/A

B. Temporary storage information

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in Section 7 of Technical Report 1.0.

Nitrate Nitrogen, mg/kg: N/A

Total Kjeldahl Nitrogen, mg/kg: N/A

Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: N/A

Phosphorus, mg/kg: N/A

Potassium, mg/kg: N/A

pH, standard units: N/A

Ammonia Nitrogen mg/kg: N/A

Arsenic: N/A

Cadmium: N/A

Chromium: N/A

Copper: N/A

Lead: N/A

Mercury: N/A

Molybdenum: N/A

Nickel: N/A

Selenium: N/A

Zinc: N/A

Total PCBs: N/A

Provide the following information:

Volume and frequency of sludge to the lagoon(s): N/A

Total dry tons stored in the lagoons(s) per 365-day period: N/A

Total dry tons stored in the lagoons(s) over the life of the unit: N/A

C. Liner information

Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of 1×10^{-7} cm/sec?

Yes ☐ No ☐

If yes, describe the liner below. Please note that a liner is required.

N/A

D. Site development plan

Provide a detailed description of the methods used to deposit sludge in the lagoon(s):

N/A

Attach the following documents to the application.

- Plan view and cross-section of the sludge lagoon(s)

Attachment: N/A

- Copy of the closure plan

Attachment: N/A

- Copy of deed recordation for the site

Attachment: N/A

- Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons

Attachment: N/A

- Description of the method of controlling infiltration of groundwater and surface water from entering the site

Attachment: N/A

- Procedures to prevent the occurrence of nuisance conditions

Attachment: N/A

E. Groundwater monitoring

Is groundwater monitoring currently conducted at this site, or are any wells available for groundwater monitoring, or are groundwater monitoring data otherwise available for the sludge lagoon(s)?

Yes ☐ No ☐

If groundwater monitoring data are available, provide a copy. Provide a profile of soil types encountered down to the groundwater table and the depth to the shallowest groundwater as a separate attachment.

Attachment: N/A

Section 12. Authorizations/Compliance/Enforcement (Instructions Page 63)

A. Additional authorizations

Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?

Yes ☐ No ☒

If yes, provide the TCEQ authorization number and description of the authorization:

N/A

B. Permittee enforcement status

Is the permittee currently under enforcement for this facility?

Yes ☐ No ☒

Is the permittee required to meet an implementation schedule for compliance or enforcement?

Yes ☒ No ☐

Section 14. Laboratory Accreditation (Instructions Page 64)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - periodically inspected by the TCEQ; or
 - located in another state and is accredited or inspected by that state; or
 - performing work for another company with a unit located in the same site; or
 - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review *30 TAC Chapter 25* for specific requirements.


The following certification statement shall be signed and submitted with every application. See the *Signature Page* section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of *30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification*.

Printed Name: Michael Duncan

Title: Vice President Sign and date in the box below.

Signature: 
Date: 4-16-24

If **yes** to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:

Case No. 83-15124

Section 13. RCRA/CERCLA Wastes (Instructions Page 63)

A. RCRA hazardous wastes

Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

Yes ☐ No ☒

B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

Yes ☐ No ☒

C. Details about wastes received

If **yes** to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: N/A

DOMESTIC TECHNICAL REPORT 1.1

The following is required for new and amendment applications

Section 1. Justification for Permit (Instructions Page 66)

A. Justification of permit need

Provide a detailed discussion regarding the need for any phase(s) not currently permitted. Failure to provide sufficient justification may result in the Executive Director recommending denial of the proposed phase(s) or permit.

B. Regionalization of facilities

Provide the following information concerning the potential for regionalization of domestic wastewater treatment facilities:

1. *Municipally incorporated areas*

If the applicant is a city, then Item 1 is not applicable. Proceed to Item 2 Utility CCN areas.

Is any portion of the proposed service area located in an incorporated city?

Yes ☐ No ☐ Not Applicable ☐

If yes, within the city limits of:

If yes, attach correspondence from the city.

Attachment:

If consent to provide service is available from the city, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the city versus the cost of the proposed facility or expansion attached.

Attachment:

2. *Utility CCN areas*

Is any portion of the proposed service area located inside another utility's CCN area?

Yes ☐ No ☐

If **yes**, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the CCN facilities versus the cost of the proposed facility or expansion.

Attachment:

3. Nearby WWTPs or collection systems

Are there any domestic permitted wastewater treatment facilities or collection systems located within a three-mile radius of the proposed facility?

Yes ☐ No ☐

If **yes**, attach a list of these facilities that includes the permittee's name and permit number, and an area map showing the location of these facilities.

Attachment:

If **yes**, attach copies of your certified letters to these facilities **and** their response letters concerning connection with their system.

Attachment:

Does a permitted domestic wastewater treatment facility or a collection system located within three (3) miles of the proposed facility currently have the capacity to accept or is willing to expand to accept the volume of wastewater proposed in this application?

Yes ☐ No ☐

If **yes**, attach an analysis of expenditures required to connect to a permitted wastewater treatment facility or collection system located within 3 miles versus the cost of the proposed facility or expansion.

Attachment:

Section 2. Organic Loading (Instructions Page 67)

Is this facility in operation?

Yes ☐ No ☐

If **no**, proceed to Item B, Proposed Organic Loading.

If yes, provide organic loading information in Item A, Current Organic Loading

A. Current organic loading

Facility Design Flow (flow being requested in application):

Average Influent Organic Strength or BOD₅ Concentration in mg/l:

Average Influent Loading (lbs/day = total average flow X average BOD₅ conc. X 8.34):

Provide the source of the average organic strength or BOD₅ concentration.

B. Proposed organic loading

This table must be completed if this application is for a facility that is not in operation or if this application is to request an increased flow that will impact organic loading.

Table 1.1(1) – Design Organic Loading

Source	Total Average Flow (MGD)	Influent BOD ₅ Concentration (mg/l)
Municipality		
Subdivision		
Trailer park – transient		
Mobile home park		
School with cafeteria and showers		
School with cafeteria,		

Source	Total Average Flow (MGD)	Influent BOD ₅ Concentration (mg/l)
no showers		
Recreational park, overnight use		
Recreational park, day use		
Office building or factory		
Motel		
Restaurant		
Hospital		
Nursing home		
Other		
TOTAL FLOW from all sources		
AVERAGE BOD ₅ from all sources		

Section 3. Proposed Effluent Quality and Disinfection (Instructions Page 68)

A. Existing/Interim I Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l:

Total Suspended Solids, mg/l:

Ammonia Nitrogen, mg/l:

Total Phosphorus, mg/l:

Dissolved Oxygen, mg/l:

Other: [REDACTED]

B. Interim II Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l: [REDACTED]

Total Suspended Solids, mg/l: [REDACTED]

Ammonia Nitrogen, mg/l: [REDACTED]

Total Phosphorus, mg/l: [REDACTED]

Dissolved Oxygen, mg/l: [REDACTED]

Other: [REDACTED]

C. Final Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l: [REDACTED]

Total Suspended Solids, mg/l: [REDACTED]

Ammonia Nitrogen, mg/l: [REDACTED]

Total Phosphorus, mg/l: [REDACTED]

Dissolved Oxygen, mg/l: [REDACTED]

Other: [REDACTED]

D. Disinfection Method

Identify the proposed method of disinfection.

- ☐ Chlorine: [REDACTED] mg/l after [REDACTED] minutes detention time at peak flow
Dechlorination process: [REDACTED]
- ☐ Ultraviolet Light: [REDACTED] seconds contact time at peak flow
- ☐ Other: [REDACTED]

Section 4. Design Calculations (Instructions Page 68)

Attach design calculations and plant features for each proposed phase. Example 4 of the instructions includes sample design calculations and plant features.

Attachment: [REDACTED]

Section 5. Facility Site (Instructions Page 68)

A. 100-year floodplain

Will the proposed facilities be located above the 100-year frequency flood level?

Yes ☐ No ☐

If **no**, describe measures used to protect the facility during a flood event. Include a site map showing the location of the treatment plant within the 100-year frequency flood level. If applicable, provide the size and types of protective structures.

Provide the source(s) used to determine 100-year frequency flood plain.

For a new or expansion of a facility, will a wetland or part of a wetland be filled?

Yes ☐ No ☐

If **yes**, has the applicant applied for a US Corps of Engineers 404 Dredge and Fill Permit?

Yes ☐ No ☐

If **yes**, provide the permit number:

If **no**, provide the approximate date you anticipate submitting your application to the Corps:

B. Wind rose

Attach a wind rose. Attachment:

Section 6. Permit Authorization for Sewage Sludge Disposal (Instructions Page 69)

A. Beneficial use authorization

Are you requesting to include authorization to land apply sewage sludge for beneficial use on property located adjacent to the wastewater treatment facility under the wastewater permit?

Yes ☐ No ☐

If yes, attach the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451)

Attachment: 

B. Sludge processing authorization

Identify the sludge processing, storage or disposal options that will be conducted at the wastewater treatment facility:

- ☐ Sludge Composting
- ☐ Marketing and Distribution of sludge
- ☐ Sludge Surface Disposal or Sludge Monofill

If any of the above sludge options are selected, attach a completed DOMESTIC WASTEWATER PERMIT APPLICATION: SEWAGE SLUDGE TECHNICAL REPORT (TCEQ Form No. 10056).

Attachment: 

Section 7. Sewage Sludge Solids Management Plan (Instructions Page 69)

Attach a solids management plan to the application.

Attachment: 

The sewage sludge solids management plan must contain the following information:

- Treatment units and processes dimensions and capacities
- Solids generated at 100, 75, 50, and 25 percent of design flow
- Mixed liquor suspended solids operating range at design and projected actual flow
- Quantity of solids to be removed and a schedule for solids removal
- Identification and ownership of the ultimate sludge disposal site
- For facultative lagoons, design life calculations, monitoring well locations and depths, and the ultimate disposal method for the sludge from the facultative lagoon

An example of a sewage sludge solids management plan has been included as Example 5 of the instructions.

DOMESTIC TECHNICAL REPORT WORKSHEET 2.0

RECEIVING WATERS

The following is required for all TPDES permit applications

Section 1. Domestic Drinking Water Supply (Instructions Page 73)

Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?

Yes ☐ No ☒

If yes, provide the following:

Owner of the drinking water supply: N/A

Distance and direction to the intake: N/A

Attach a USGS map that identifies the location of the intake.

Attachment: N/A

Section 2. Discharge into Tidally Affected Waters (Instructions Page 73)

Does the facility discharge into tidally affected waters?

Yes ☐ No ☒

If yes, complete the remainder of this section. If no, proceed to Section 3.

A. Receiving water outfall

Width of the receiving water at the outfall, in feet: N/A

B. Oyster waters

Are there oyster waters in the vicinity of the discharge?

Yes ☐ No ☒

If yes, provide the distance and direction from outfall(s).

<u>N/A</u>

C. Sea grasses

Are there any sea grasses within the vicinity of the point of discharge?

Yes ☐ No ☒

If yes, provide the distance and direction from the outfall(s).

N/A

Section 3. Classified Segments (Instructions Page 73)

Is the discharge directly into (or within 300 feet of) a classified segment?

Yes ☐ No ☒

If yes, this Worksheet is complete.

If no, complete Sections 4 and 5 of this Worksheet.

**Section 4. Description of Immediate Receiving Waters
(Instructions Page 75)**

Name of the immediate receiving waters: Harris County Flood Control Ditch
P133-00-00

A. Receiving water type

Identify the appropriate description of the receiving waters.

- ☐ Stream
- ☐ Freshwater Swamp or Marsh
- ☐ Lake or Pond

Surface area, in acres:

Average depth of the entire water body, in feet:

Average depth of water body within a 500-foot radius of discharge point, in feet:

- ☒ Man-made Channel or Ditch

- ☐ Open Bay
- ☐ Tidal Stream, Bayou, or Marsh
- ☐ Other, specify:

B. Flow characteristics

If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area *upstream* of the discharge. For new discharges, characterize the area *downstream* of the discharge (check one).

- ☒ Intermittent - dry for at least one week during most years
- ☐ Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses
- ☐ Perennial - normally flowing

Check the method used to characterize the area upstream (or downstream for new dischargers).

- ☐ USGS flow records
- ☐ Historical observation by adjacent landowners
- ☐ Personal observation
- ☐ Other, specify:

C. Downstream perennial confluences

List the names of all perennial streams that join the receiving water within three miles downstream of the discharge point.

<u>Tributary to Green's Bayou, Green's Bayou</u>

D. Downstream characteristics

Do the receiving water characteristics change within three miles downstream of the discharge (e.g., natural or man-made dams, ponds, reservoirs, etc.)?

Yes ☐ No ☒

If yes, discuss how.

Ditch possibly leads to natural stream

E. Normal dry weather characteristics

Provide general observations of the water body during normal dry weather conditions.

Date and time of observation: 11/15/2017 12:00 PM

Was the water body influenced by stormwater runoff during observations?

Yes ☐

No ☐

Section 5. General Characteristics of the Waterbody (Instructions Page 74)

A. Upstream influences

Is the immediate receiving water upstream of the discharge or proposed discharge site influenced by any of the following? Check all that apply.

- | | |
|---|--|
| <input type="checkbox"/> Oil field activities | <input checked="" type="checkbox"/> Urban runoff |
| <input type="checkbox"/> Upstream discharges | <input type="checkbox"/> Agricultural runoff |
| <input type="checkbox"/> Septic tanks | <input type="checkbox"/> Other(s), specify 11/15/2017 12:00 PM |

B. Waterbody uses

Observed or evidences of the following uses. Check all that apply.

- | | |
|--|---|
| <input type="checkbox"/> Livestock watering | <input type="checkbox"/> Contact recreation |
| <input type="checkbox"/> Irrigation withdrawal | <input type="checkbox"/> Non-contact recreation |
| <input type="checkbox"/> Fishing | <input type="checkbox"/> Navigation |

- | | |
|--|--|
| <input type="checkbox"/> Domestic water supply | <input type="checkbox"/> Industrial water supply |
| <input type="checkbox"/> Park activities | <input type="checkbox"/> Other(s), specify |

C. Waterbody aesthetics

Check one of the following that best describes the aesthetics of the receiving water and the surrounding area.

- ☐ Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional
- ☐ Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored
- ☒ Common Setting: not offensive; developed but uncluttered; water may be colored or turbid
- ☒ Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored

DOMESTIC WORKSHEET 2.1

STREAM PHYSICAL CHARACTERISTICS

Required for new applications, major facilities, and applications adding an outfall

Worksheet 2.1 is not required for discharges to intermittent streams or discharges directly to (or within 300 feet of) a classified segment.

Section 1. General Information (Instructions Page 75)

Date of study: _____ Time of study: _____

Stream name: _____

Location: _____

Type of stream upstream of existing discharge or downstream of proposed discharge (check one).

☐ Perennial

☐ Intermittent with perennial pools

Section 2. Data Collection (Instructions Page 75)

Number of stream bends that are well defined: _____

Number of stream bends that are moderately defined: _____

Number of stream bends that are poorly defined: _____

Number of riffles: _____

Evidence of flow fluctuations (check one):

☐ Minor

☐ moderate

☐ severe

Indicate the observed stream uses and if there is evidence of flow fluctuations or channel obstruction/modification.

--

Stream transects

In the table below, provide the following information for each transect downstream of the existing or proposed discharges. Use a separate row for each transect.

Table 2.1(1) - Stream Transect Records

Stream type at transect Select riffle, run, glide, or pool. See Instructions, Definitions section.	Transect location	Water surface width (ft)	Stream depths (ft) at 4 to 10 points along each transect from the channel bed to the water surface. Separate the measurements with commas.
Choose an item.			
Choose an item.			
Choose an item.			
Choose an item.			
Choose an item.			
Choose an item.			
Choose an item.			
Choose an item.			
Choose an item.			
Choose an item.			

Section 3. Summarize Measurements (Instructions Page 76)

Streambed slope of entire reach, from USGS map in feet/feet:

Approximate drainage area above the most downstream transect (from USGS map or county highway map, in square miles):

Length of stream evaluated, in feet:

Number of lateral transects made:

Average stream width, in feet:

Average stream depth, in feet:

Average stream velocity, in feet/second:

Instantaneous stream flow, in cubic feet/second:

Indicate flow measurement method (type of meter, floating chip timed over a fixed distance, etc.):

Size of pools (large, small, moderate, none):

Maximum pool depth, in feet:

DOMESTIC WORKSHEET 3.0

LAND DISPOSAL OF EFFLUENT

The following is required for all permit applications
Renewal, New, and Amendments

Section 1. Type of Disposal System (Instructions Page 77)

Identify the method of land disposal:

- | | |
|--|--|
| <input type="checkbox"/> Surface application | <input type="checkbox"/> Subsurface application |
| <input type="checkbox"/> Irrigation | <input type="checkbox"/> Subsurface soils absorption |
| <input type="checkbox"/> Drip irrigation system | <input type="checkbox"/> Subsurface area drip dispersal system |
| <input type="checkbox"/> Evaporation | |
| <input type="checkbox"/> Evapotranspiration beds | |
| <input type="checkbox"/> Other (describe in detail): | |

NOTE: All applicants without authorization or proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0.

For existing authorizations, provide Registration Number:

Section 2. Land Application Site(s) (Instructions Page 77)

In table 3.0(1), provide the requested information for the land application sites. Include the agricultural or cover crop type (wheat, cotton, alfalfa, bermuda grass, native grasses, etc.), land use (golf course, hayland, pastureland, park, row crop, etc.), irrigation area, amount of effluent applied, and whether or not the public has access to the area. Specify the amount of land area and the amount of effluent that will be allotted to each agricultural or cover crop, if more than one crop will be used.

Table 3.0(1) - Land Application Site Crops

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N

Section 3. Storage and Evaporation Lagoons/Ponds (Instructions Page 77)

Table 3.0(2) - Storage and Evaporation Ponds

Pond Number	Surface Area (acres)	Storage Volume (acre-feet)	Dimensions	Liner Type

Attach a copy of a liner certification that was prepared, signed, and sealed by a Texas licensed professional engineer for each pond.

Attachment:

Section 4. Flood and Runoff Protection (Instructions Page 77)

Is the land application site within the 100-year frequency flood level?

Yes ☐ No ☐

If yes, describe how the site will be protected from inundation.

Provide the source used to determine the 100-year frequency flood level:

Provide a description of tailwater controls and rainfall run-on controls used for the land application site.

Section 5. Annual Cropping Plan (Instructions Page 77)

Attach an Annual Cropping Plan which includes a discussion of each of the following items. If not applicable, provide a detailed explanation indicating why.

Attachment:

- Soils map with crops
- Cool and warm season plant species
- Crop yield goals
- Crop growing season
- Crop nutrient requirements
- Additional fertilizer requirements
- Minimum/maximum harvest height (for grass crops)
- Supplemental watering requirements
- Crop salt tolerances
- Harvesting method/number of harvests
- Justification for not removing existing vegetation to be irrigated

Section 6. Well and Map Information (Instructions Page 78)

Attach a USGS map with the following information shown and labeled. If not applicable, provide a detailed explanation (on a separate page) indicating why.

Attachment:

- The boundaries of the land application site(s)
- Waste disposal or treatment facility site(s)

- On-site buildings
- Buffer zones
- Effluent storage and tailwater control facilities
- All water wells within 1 mile of the disposal site or property boundaries
- All springs and seeps onsite and within 500 feet of the property boundaries
- All surface waters in the state onsite and within 500 feet of the property boundaries
- All faults and sinkholes onsite and within 500 feet of the property

List and cross reference all water wells shown on the USGS map in the following table. Attach additional pages as necessary to include all of the wells.

Table 3.0(3) - Water Well Data

Well ID	Well Use	Producing? Y/N	Open, cased, capped, or plugged?	Proposed Best Management Practice
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	

If water quality data or well log information is available please include the information in an attachment listed by Well ID.

Attachment:

Section 7. Groundwater Quality (Instructions Page 79)

Attach a Groundwater Quality Technical Report which assesses the impact of the wastewater disposal system on groundwater. This report shall include an evaluation of the water wells (including the information in the well table provided in Item 6. above), the wastewater application rate, and pond liners.

Indicate by a check mark that this report is provided.

Attachment:

Are groundwater monitoring wells available onsite? Yes ☐ No ☐

Do you plan to install ground water monitoring wells or lysimeters around the land application site? Yes ☐ No ☐

If yes, then provide the proposed location of the monitoring wells or lysimeters on a site map.

Attachment:

Section 8. Soil Map and Soil Analyses (Instructions Page 79)

A. Soil map

Attach a USDA Soil Survey map that shows the area to be used for effluent disposal.

Attachment:

B. Soil analyses

Attach the laboratory results sheets from the soil analyses. **Note:** for renewal applications, the current annual soil analyses required by the permit are acceptable as long as the test date is less than one year prior to the submission of the application.

Attachment:

List all USDA designated soil series on the proposed land application site. Attach additional pages as necessary.

Table 3.0(4) - Soil Data

Soil Series	Depth from Surface	Permeability	Available Water Capacity	Curve Number

Soil Series	Depth from Surface	Permeability	Available Water Capacity	Curve Number

Section 9. Effluent Monitoring Data (Instructions Page 80)

Is the facility in operation?

Yes ☐ No ☐

If **no**, this section is not applicable and the worksheet is complete.

If **yes**, provide the effluent monitoring data for the parameters regulated in the existing permit. If a parameter is not regulated in the existing permit, enter N/A.

Table 3.0(5) - Effluent Monitoring Data

Date	30 Day Avg Flow MGD	BOD ₅ mg/l	TSS mg/l	pH	Chlorine Residual mg/l	Acres irrigated

Date	30 Day Avg Flow MGD	BOD ₅ mg/l	TSS mg/l	pH	Chlorine Residual mg/l	Acres irrigated

Provide a discussion of all persistent excursions above the permitted limits and any corrective actions taken.

DOMESTIC WORKSHEET 3.1

SURFACE LAND DISPOSAL OF EFFLUENT

The following is required for new and major amendment applications.

Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

Section 1. Surface Disposal (Instructions Page 81)

Complete the item that applies for the method of disposal being used.

A. Irrigation

Area under irrigation, in acres:

Design application frequency:

hours/day

And days/week

Land grade (slope):

average percent (%):

maximum percent (%):

Design application rate in acre-feet/acre/year:

Design total nitrogen loading rate, in lbs N/acre/year:

Soil conductivity (mmhos/cm):

Method of application:

Attach a separate engineering report with the water balance and storage volume calculations, method of application, irrigation efficiency, and nitrogen balance.

Attachment:

B. Evaporation ponds

Daily average effluent flow into ponds, in gallons per day:

Attach a separate engineering report with the water balance and storage volume calculations.

Attachment: [REDACTED]

C. Evapotranspiration beds

Number of beds: [REDACTED]

Area of bed(s), in acres: [REDACTED]

Depth of bed(s), in feet: [REDACTED]

Void ratio of soil in the beds: [REDACTED]

Storage volume within the beds, in acre-feet: [REDACTED]

Attach a separate engineering report with the water balance and storage volume calculations, and a description of the lining.

Attachment: [REDACTED]

D. Overland flow

Area used for application, in acres: [REDACTED]

Slopes for application area, percent (%): [REDACTED]

Design application rate, in gpm/foot of slope width: [REDACTED]

Slope length, in feet: [REDACTED]

Design BOD₅ loading rate, in lbs BOD₅/acre/day: [REDACTED]

Design application frequency:

hours/day: [REDACTED] And days/week: [REDACTED]

Attach a separate engineering report with the method of application and design requirements according to *30 TAC Chapter 217*.

Attachment: [REDACTED]

Section 2. Edwards Aquifer (Instructions Page 82)

Is the facility subject to *30 TAC Chapter 213*, Edwards Aquifer Rules?

Yes ☐ No ☐

If yes, attach a report concerning the recharge zone.

Attachment: 

DOMESTIC WORKSHEET 3.2

SUBSURFACE LAND DISPOSAL OF EFFLUENT

The following is required for new and major amendment applications.
Renewal and minor amendments may require the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that does not meet the definition of a subsurface area drip dispersal system as defined in 30 TAC Chapter 222, *Subsurface Area Drip Dispersal System*.

Section 1. Subsurface Application (Instructions Page 83)

Identify the type of system:

- ☐ Conventional Gravity Drainfield, Beds, or Trenches (new systems must be less than 5,000 GPD)
- ☐ Low Pressure Dosing
- ☐ Other, specify: _____

Application area, in acres: _____

Area of drainfield, in square feet: _____

Application rate, in gal/square foot/day: _____

Depth to groundwater, in feet: _____

Area of trench, in square feet: _____

Dosing duration per area, in hours: _____

Number of beds: _____

Dosing amount per area, in inches/day: _____

Infiltration rate, in inches/hour: _____

Storage volume, in gallons: _____

Area of bed(s), in square feet: _____

Soil Classification:

Attach a separate engineering report with the information required in *30 TAC § 309.20*, excluding the requirements of § 309.20 b(3)(A) and (B) design analysis which may be asked for on a case by case basis. Include a description of the schedule of dosing basin rotation.

Attachment:

Section 2. Edwards Aquifer (Instructions Page 83)

Is the subsurface system located on the Edwards Aquifer Recharge Zone as mapped by the TCEQ?

Yes ☐ No ☐

Is the subsurface system located on the Edwards Aquifer Transition Zone as mapped by the TCEQ?

Yes ☐ No ☐

If yes to either question, the subsurface system may be prohibited by *30 TAC §213.8*. Please call the Municipal Permits Team, at 512-239-4671, to schedule a pre-application meeting.

DOMESTIC WORKSHEET 3.3

SUBSURFACE AREA DRIP DISPERSAL SYSTEM (SADDS) LAND DISPOSAL OF EFFLUENT

The following is required for new and major amendment subsurface area drip dispersal system applications. Renewal and minor amendments may require the worksheet on a case by case basis.

NOTE: All applicants proposing new or amended subsurface disposal **MUST** complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that meets the definition of a subsurface area drip dispersal system as defined in *30 TAC Chapter 222, Subsurface Area Drip Dispersal System*.

Section 1. Administrative Information (Instructions Page 84)

- A. Provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the treatment facility.

- B. Is the owner of the land where the treatment facility is located the same as the owner of the treatment facility?

Yes ☐ No ☐

If **no**, provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the land where the treatment facility is located.

- C. Owner of the subsurface area drip dispersal system:

- D. Is the owner of the subsurface area drip dispersal system the same as the owner of the wastewater treatment facility or the site where the wastewater treatment facility is located?

Yes ☐ No ☐

If **no**, identify the names of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in Item 1.C.

E. Owner of the land where the subsurface area drip dispersal system is located:

F. Is the owner of the land where the subsurface area drip dispersal system is located the same as owner of the wastewater treatment facility, the site where the wastewater treatment facility is located, or the owner of the subsurface area drip dispersal system?

Yes ☐ No ☐

If **no**, identify the name of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in item 1.E.

Section 2. Subsurface Area Drip Dispersal System (Instructions Page 84)

A. Type of system

☐ Subsurface Drip Irrigation

☐ Surface Drip Irrigation

☐ Other, specify:

B. Irrigation operations

Application area, in acres:

Infiltration Rate, in inches/hour:

Average slope of the application area, percent (%):

Maximum slope of the application area, percent (%):

Storage volume, in gallons:

Major soil series:

Depth to groundwater, in feet:

C. Application rate

Is the facility located **west** of the boundary shown in 30 TAC § 222.83 and also using a vegetative cover of non-native grasses over seeded with cool

season grasses during the winter months (October-March)?

Yes ☐ No ☐

If **yes**, then the facility may propose a hydraulic application rate not to exceed 0.1 gal/square foot/day.

Is the facility located **east** of the boundary shown in 30 TAC § 222.83 or in any part of the state when the vegetative cover is any crop other than non-native grasses?

Yes ☐ No ☐

If **yes**, the facility must use the formula in 30 TAC §222.83 to calculate the maximum hydraulic application rate.

Do you plan to submit an alternative method to calculate the hydraulic application rate for approval by the executive director?

Yes ☐ No ☐

Hydraulic application rate, in gal/square foot/day:

Nitrogen application rate, in lbs/gal/day:

D. Dosing information

Number of doses per day:

Dosing duration per area, in hours:

Rest period between doses, in hours:

Dosing amount per area, in inches/day:

Number of zones:

Does the proposed subsurface drip irrigation system use tree vegetative cover as a crop?

Yes ☐ No ☐

If **yes**, provide a vegetation survey by a certified arborist. Please call the Water Quality Assessment Team at (512) 239-4671 to schedule a pre-application meeting.

Attachment:

Section 3. Required Plans (Instructions Page 84)

A. Recharge feature plan

Attach a Recharge Feature Plan with all information required in *30 TAC §222.79*.

Attachment: 

B. Soil evaluation

Attach a Soil Evaluation with all information required in *30 TAC §222.73*.

Attachment: 

C. Site preparation plan

Attach a Site Preparation Plan with all information required in *30 TAC §222.75*.

Attachment: 

D. Soil sampling/testing

Attach soil sampling and testing that includes all information required in *30 TAC §222.157*.

Attachment: 

Section 4. Floodway Designation (Instructions Page 85)

A. Site location

Is the existing/proposed land application site within a designated floodway?

Yes ☐ No ☐

B. Flood map

Attach either the FEMA flood map or alternate information used to determine the floodway.

Attachment: 

Section 5. Surface Waters in the State (Instructions Page 85)

A. Buffer Map

Attach a map showing appropriate buffers on surface waters in the state, water wells, and springs/seeps.

Attachment: 

B. Buffer variance request

Do you plan to request a buffer variance from water wells or waters in the state?

Yes ☐ No ☐

If yes, then attach the additional information required in 30 TAC § 222.81(c).

Attachment: 

Section 6. Edwards Aquifer (Instructions Page 85)

A. Is the SADDs located on the Edwards Aquifer Recharge Zone as mapped by the TCEQ?

Yes ☐ No ☐

B. Is the SADDs located on the Edwards Aquifer Transition Zone as mapped by the TCEQ?

Yes ☐ No ☐

If yes to either question, then the SADDs may be prohibited by 30 TAC §213.8. Please call the Municipal Permits Team at 512-239-4671 to schedule a pre-application meeting.

DOMESTIC WORKSHEET 4.0

POLLUTANT ANALYSES REQUIREMENTS*

The following is required for facilities with a permitted or proposed flow of 1.0 MGD or greater, facilities with an approved pretreatment program, or facilities classified as a major facility. See instructions for further details.

This worksheet is not required for minor amendments without renewal

Section 1. Toxic Pollutants (Instructions Page 87)

For pollutants identified in Table 4.0(1), indicate the type of sample.

Grab ☐ Composite ☐

Date and time sample(s) collected:

Table 4.0(1) - Toxics Analysis

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrylonitrile				50
Aldrin				0.01
Aluminum				2.5
Anthracene				10
Antimony				5
Arsenic				0.5
Barium				3
Benzene				10
Benzidine				50
Benzo(a)anthracene				5

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Benzo(a)pyrene				5
Bis(2-chloroethyl)ether				10
Bis(2-ethylhexyl)phthalate				10
Bromodichloromethane				10
Bromoform				10
Cadmium				1
Carbon Tetrachloride				2
Carbaryl				5
Chlordane*				0.2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroform				10
Chlorpyrifos				0.05
Chromium (Total)				3
Chromium (Tri) (*1)				N/A
Chromium (Hex)				3
Copper				2
Chrysene				5
p-Chloro-m-Cresol				10
4,6-Dinitro-o-Cresol				50
p-Cresol				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Cyanide (*2)				10
4,4'- DDD				0.1
4,4'- DDE				0.1
4,4'- DDT				0.02
2,4-D				0.7
Demeton (O and S)				0.20
Diazinon				0.5/0.1
1,2-Dibromoethane				10
m-Dichlorobenzene				10
o-Dichlorobenzene				10
p-Dichlorobenzene				10
3,3'-Dichlorobenzidine				5
1,2-Dichloroethane				10
1,1-Dichloroethylene				10
Dichloromethane				20
1,2-Dichloropropane				10
1,3-Dichloropropene				10
Dicofol				1
Dieldrin				0.02
2,4-Dimethylphenol				10
Di-n-Butyl Phthalate				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Diuron				0.09
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Ethylbenzene				10
Fluoride				500
Guthion				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclohexane (alpha)				0.05
Hexachlorocyclohexane (beta)				0.05
gamma-Hexachlorocyclohexane (Lindane)				0.05
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Hexachlorophene				10
Lead				0.5
Malathion				0.1

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Mercury				0.005
Methoxychlor				2
Methyl Ethyl Ketone				50
Mirex				0.02
Nickel				2
Nitrate-Nitrogen				100
Nitrobenzene				10
N-Nitrosodiethylamine				20
N-Nitroso-di-n-Butylamine				20
Nonylphenol				333
Parathion (ethyl)				0.1
Pentachlorobenzene				20
Pentachlorophenol				5
Phenanthrene				10
Polychlorinated Biphenyls (PCB's) (*3)				0.2
Pyridine				20
Selenium				5
Silver				0.5
1,2,4,5-Tetrachlorobenzene				20
1,1,2,2-Tetrachloroethane				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Tetrachloroethylene				10
Thallium				0.5
Toluene				10
Toxaphene				0.3
2,4,5-TP (Silvex)				0.3
Tributyltin (see instructions for explanation)				0.01
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene				10
2,4,5-Trichlorophenol				50
TTHM (Total Trihalomethanes)				10
Vinyl Chloride				10
Zinc				5

(*1) Determined by subtracting hexavalent Cr from total Cr.

(*2) Cyanide, amenable to chlorination or weak-acid dissociable.

(*3) The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

Section 2. Priority Pollutants

For pollutants identified in Tables 4.0(2)A-E, indicate type of sample.

Grab ☐ Composite ☐

Date and time sample(s) collected:

Table 4.0(2)A - Metals, Cyanide, Phenols

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Antimony				5
Arsenic				0.5
Beryllium				0.5
Cadmium				1
Chromium (Total)				3
Chromium (Hex)				3
Chromium (Tri) (*1)				N/A
Copper				2
Lead				0.5
Mercury				0.005
Nickel				2
Selenium				5
Silver				0.5
Thallium				0.5
Zinc				5
Cyanide (*2)				10
Phenols, Total				10

(*1) Determined by subtracting hexavalent Cr from total Cr.

(*2) Cyanide, amenable to chlorination or weak-acid dissociable

Table 4.0(2)B – Volatile Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrolein				50
Acrylonitrile				50
Benzene				10
Bromoform				10
Carbon Tetrachloride				2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroethane				50
2-Chloroethylvinyl Ether				10
Chloroform				10
Dichlorobromomethane [Bromodichloromethane]				10
1,1-Dichloroethane				10
1,2-Dichloroethane				10
1,1-Dichloroethylene				10
1,2-Dichloropropane				10
1,3-Dichloropropylene [1,3-Dichloropropene]				10
1,2-Trans-Dichloroethylene				10
Ethylbenzene				10
Methyl Bromide				50
Methyl Chloride				50
Methylene Chloride				20
1,1,2,2-Tetrachloroethane				10
Tetrachloroethylene				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Toluene				10
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene				10
Vinyl Chloride				10

Table 4.0(2)C - Acid Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2-Chlorophenol				10
2,4-Dichlorophenol				10
2,4-Dimethylphenol				10
4,6-Dinitro-o-Cresol				50
2,4-Dinitrophenol				50
2-Nitrophenol				20
4-Nitrophenol				50
P-Chloro-m-Cresol				10
Pentalchlorophenol				5
Phenol				10
2,4,6-Trichlorophenol				10

Table 4.0(2)D – Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acenaphthene				10
Acenaphthylene				10
Anthracene				10
Benzidine				50
Benzo(a)Anthracene				5
Benzo(a)Pyrene				5
3,4-Benzofluoranthene				10
Benzo(ghi)Perylene				20
Benzo(k)Fluoranthene				5
Bis(2-Chloroethoxy)Methane				10
Bis(2-Chloroethyl)Ether				10
Bis(2-Chloroisopropyl)Ether				10
Bis(2-Ethylhexyl)Phthalate				10
4-Bromophenyl Phenyl Ether				10
Butyl benzyl Phthalate				10
2-Chloronaphthalene				10
4-Chlorophenyl phenyl ether				10
Chrysene				5
Dibenzo(a,h)Anthracene				5
1,2-(o)Dichlorobenzene				10
1,3-(m)Dichlorobenzene				10
1,4-(p)Dichlorobenzene				10
3,3-Dichlorobenzidine				5
Diethyl Phthalate				10
Dimethyl Phthalate				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Di-n-Butyl Phthalate				10
2,4-Dinitrotoluene				10
2,6-Dinitrotoluene				10
Di-n-Octyl Phthalate				10
1,2-Diphenylhydrazine (as Azo- benzene)				20
Fluoranthene				10
Fluorene				10
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclo-pentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene				5
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10

Table 4.0(2)E - Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Aldrin				0.01
alpha-BHC (Hexachlorocyclohexane)				0.05
beta-BHC (Hexachlorocyclohexane)				0.05
gamma-BHC (Hexachlorocyclohexane)				0.05
delta-BHC (Hexachlorocyclohexane)				0.05
Chlordane				0.2
4,4-DDT				0.02
4,4-DDE				0.1
4,4,-DDD				0.1
Dieldrin				0.02
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Endrin Aldehyde				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
PCB-1242				0.2
PCB-1254				0.2
PCB-1221				0.2
PCB-1232				0.2

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
PCB-1248				0.2
PCB-1260				0.2
PCB-1016				0.2
Toxaphene				0.3

* For PCBs, if all are non-detects, enter the highest non-detect preceded by a "<".

Section 3. Dioxin/Furan Compounds

A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user. Check all that apply.

- ☐ 2,4,5-trichlorophenoxy acetic acid
Common Name 2,4,5-T, CASRN 93-76-5
- ☐ 2-(2,4,5-trichlorophenoxy) propanoic acid
Common Name Silvex or 2,4,5-TP, CASRN 93-72-1
- ☐ 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate
Common Name Erbon, CASRN 136-25-4
- ☐ 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate
Common Name Ronnel, CASRN 299-84-3
- ☐ 2,4,5-trichlorophenol
Common Name TCP, CASRN 95-95-4
- ☐ hexachlorophene
Common Name HCP, CASRN 70-30-4

For each compound identified, provide a brief description of the conditions of its/their presence at the facility.

B. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent?

Yes ☐ No ☐

If **yes**, provide a brief description of the conditions for its presence.

If any of the compounds in Subsection A or B are present, complete Table 4.0(2)F.

For pollutants identified in Table 4.0(2)F, indicate the type of sample.

Grab ☐ Composite ☐

Date and time sample(s) collected:

TABLE 4.0(2)F - DIOXIN/FURAN COMPOUNDS

Compound	Toxic Equivalency Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
2,3,7,8 TCDD	1					10
1,2,3,7,8	0.5					50
2,3,7,8 HxCDDs	0.1					50
1,2,3,4,6,7,8 HpCDD	0.01					50
2,3,7,8 TCDF	0.1					10
1,2,3,7,8 PeCDF	0.05					50
2,3,4,7,8 PeCDF	0.5					50
2,3,7,8 HxCDFs	0.1					50
2,3,4,7,8	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					0.5
PCB 81	0.0003					0.5

Compound	Toxic Equivalency Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
PCB 126	0.1					0.5
PCB 169	0.03					0.5
Total						

TOXICITY TESTING REQUIREMENTS

The following is required for facilities with a currently-operating design flow greater than or equal to 1.0 MGD, with an EPA-approved pretreatment program (or those that are required to have one under 40 CFR Part 403), or are required by the TCEQ to perform Whole Effluent Toxicity testing. This worksheet is not required for minor amendments without renewal.

Indicate the number of 7-day chronic or 48-hour acute Whole Effluent Toxicity (WET) tests performed in the four and one-half years prior to submission of the application.

48-hour Acute:

Has this facility completed a TRE in the past four and a half years? Or is the facility currently performing a TRE?

No ☐

--

Section 3. Summary of WET Tests

If the required biomonitoring test information has not been previously submitted via both the Discharge Monitoring Reports (DMRs) and the Table 1 (as found in the permit), provide a summary of the testing results for all valid and invalid tests performed over the past four and one-half years. Make additional copies of this table as needed.

Table 5.0(1) - Summary of WET Tests

Test Date	Test Species	NOEC Survival	NOEC Sub-lethal

C. Treatment plant pass through

In the past three years, has your POTW experienced pass through (see instructions)?

Yes ☐ No ☐

If yes, identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.

--

D. Pretreatment program

Does your POTW have an approved pretreatment program?

Yes ☐ No ☐

If yes, complete Section 2 only of this Worksheet.

Is your POTW required to develop an approved pretreatment program?

Yes ☐ No ☐

If yes, complete Section 2.c. and 2.d. only, and skip Section 3.

If no to either question above, skip Section 2 and complete Section 3 for each significant industrial user and categorical industrial user.

Section 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 100)

A. Substantial modifications

Have there been any **substantial modifications** to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?

Yes ☐ No ☐

If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.

B. Non-substantial modifications

Have there been any **non-substantial modifications** to the approved pretreatment program that have not been submitted to TCEQ for review and acceptance?

Yes ☐ No ☐

If yes, identify all non-substantial modifications that have not been submitted to TCEQ, including the purpose of the modification.

C. Effluent parameters above the MAL

In Table 6.0(1), list all parameters measured above the MAL in the POTW's effluent monitoring during the last three years. Submit an attachment if necessary.

Table 6.0(1) - Parameters Above the MAL

Pollutant	Concentration	MAL	Units	Date

D. Industrial user interruptions

Has any SIU, CIU, or other IU caused or contributed to any problems (excluding interferences or pass throughs) at your POTW in the past three years?

Yes ☐ No ☐

If yes, identify the industry, describe each episode, including dates, duration, description of the problems, and probable pollutants.

Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 100)

A. General information

Company Name:

SIC Code:

Telephone number: Fax number:

Contact name:

Address:

City, State, and Zip Code:

B. Process information

Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).

C. Product and service information

Provide a description of the principal product(s) or services performed.

D. Flow rate information

See the Instructions for definitions of “process” and “non-process wastewater.”

Process Wastewater:

Discharge, in gallons/day:

Discharge Type: ☐ Continuous ☐ Batch ☐ Intermittent

Non-Process Wastewater:

Discharge, in gallons/day:

Discharge Type: ☐ Continuous ☐ Batch ☐ Intermittent

E. Pretreatment standards

Is the SIU or CIU subject to technically based local limits as defined in the instructions?

Yes ☐ No ☐

Is the SIU or CIU subject to categorical pretreatment standards found in *40 CFR Parts 405-471*?

Yes ☐ No ☐

If subject to categorical pretreatment standards, indicate the applicable category and subcategory for each categorical process.

Category:

Subcategories:

Category:

Subcategories:

Category:

Subcategories:

Category:

Subcategories:

Category:

Subcategories:

F. Industrial user interruptions

Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?

Yes ☐

No ☐

If yes, identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.

--

WORKSHEET 7.0

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY CLASS V INJECTION WELL INVENTORY/AUTHORIZATION FORM

Submit to:
TCEQ
IUC Permits Team
Radioactive Materials Division
MC-233
PO Box 13087
Austin, Texas 78711-3087
512-239-6466

For TCEQ Use Only

Reg. No. _____

Date Received _____

Date Authorized _____

Section 1. General Information (Instructions Page 102)

1. TCEQ Program Area

Program Area (PST, VCP, IHW, etc.): _____

Program ID: _____

Contact Name: _____

Phone Number: _____

2. Agent/Consultant Contact Information

Contact Name: _____

Address: _____

City, State, and Zip Code: _____

Phone Number: _____

3. Owner/Operator Contact Information

Owner ☐

Operator ☐

Owner/Operator Name: _____

Contact Name: _____

Address: _____

City, State, and Zip Code: _____

Phone Number: _____

4. Facility Contact Information

Facility Name: _____

Address: [REDACTED]

City, State, and Zip Code: [REDACTED]

Location description (if no address is available): [REDACTED]

Facility Contact Person: [REDACTED]

Phone Number: [REDACTED]

5. Latitude and Longitude, in degrees-minutes-seconds

Latitude: [REDACTED] Longitude: [REDACTED]

Method of determination (GPS, TOPO, etc.): [REDACTED]

Attach topographic quadrangle map as attachment A.

6. Well Information

Type of Well Construction, select one:

- ☐ Vertical Injection
- ☐ Subsurface Fluid Distribution System
- ☐ Infiltration Gallery
- ☐ Temporary Injection Points
- ☐ Other, Specify: [REDACTED]

Number of Injection Wells: [REDACTED]

7. Purpose

Detailed Description regarding purpose of Injection System:

Attach a Site Map as Attachment B (Attach the Approved Remediation Plan, if appropriate.)

8. Water Well Driller/Installer

Water Well Driller/Installer Name: [REDACTED]

City, State, and Zip Code: [REDACTED]

Phone Number: [REDACTED]

License Number: [REDACTED]

Section 2. Proposed Down Hole Design

Attach a diagram signed and sealed by a licensed engineer as Attachment C.

Table 7.0(1) -Down Hole Design Table

Name of String	Size	Setting Depth	Sacks Cement/Grout - Slurry Volume - Top of Cement	Hole Size	Weight (lbs/ft) PVC/Steel
Casing					
Tubing					
Screen					

Section 3. Proposed Trench System, Subsurface Fluid Distribution System, or Infiltration Gallery

Attach a diagram signed and sealed by a licensed engineer as Attachment D.

System(s) Dimensions: [REDACTED]

System(s) Construction: [REDACTED]

Section 4. Site Hydrogeological and Injection Zone Data

1. Name of Contaminated Aquifer: [REDACTED]
2. Receiving Formation Name of Injection Zone: [REDACTED]
3. Well/Trench Total Depth: [REDACTED]
4. Surface Elevation: [REDACTED]
5. Depth to Ground Water: [REDACTED]
6. Injection Zone Depth: [REDACTED]
7. Injection Zone vertically isolated geologically? Yes ☐ No ☐

Impervious Strata between Injection Zone and nearest Underground

Source of Drinking Water:

Name: [REDACTED]

Thickness: [REDACTED]

8. Provide a list of contaminants and the levels (ppm) in contaminated aquifer
Attach as Attachment E.
9. Horizontal and Vertical extent of contamination and injection plume
Attach as Attachment F.
10. Formation (Injection Zone) Water Chemistry (Background levels) TDS, etc.
Attach as Attachment G.
11. Injection Fluid Chemistry in PPM at point of injection
Attach as Attachment H.
12. Lowest Known Depth of Ground Water with < 10,000 PPM TDS: [REDACTED]
[REDACTED]
13. Maximum injection Rate/Volume/Pressure: [REDACTED]
14. Water wells within 1/4 mile radius (attach map as Attachment I): [REDACTED]
[REDACTED]
15. Injection wells within 1/4 mile radius (attach map as Attachment J): [REDACTED]
[REDACTED]
16. Monitor wells within 1/4 mile radius (attach drillers logs and map as Attachment K): [REDACTED]
17. Sampling frequency: [REDACTED]
18. Known hazardous components in injection fluid: [REDACTED]

Section 5. Site History

1. Type of Facility: [REDACTED]
2. Contamination Dates: [REDACTED]
3. Original Contamination (VOCs, TPH, BTEX, etc.) and Concentrations
(attach as Attachment L): [REDACTED]
4. Previous Remediation: [REDACTED]

Attach results of any previous remediation as attachment M

NOTE: Authorization Form should be completed in detail and authorization given by the TCEQ before construction, operation, and/or conversion can

begin. Attach additional pages as necessary.

Class V Injection Well Designations

- 5A07 Heat Pump/AC return (IW used for groundwater to heat and/or cool buildings)
- 5A19 Industrial Cooling Water Return Flow (IW used to cool industrial process equipment)
- 5B22 Salt Water Intrusion Barrier (IW used to inject fluids to prevent the intrusion of salt water into an aquifer)
- 5D02 Storm Water Drainage (IW designed for the disposal of rain water)
- 5D04 Industrial Stormwater Drainage Wells (IW designed for the disposal of rain water associated with industrial facilities)
- 5F01 Agricultural Drainage (IW that receive agricultural runoff)
- 5R21 Aquifer Recharge (IW used to inject fluids to recharge an aquifer)
- 5S23 Subsidence Control Wells (IW used to control land subsidence caused by ground water withdrawal)
- 5W09 Untreated Sewage
- 5W10 Large Capacity Cesspools (Cesspools that are designed for 5,000 gpd or greater)
- 5W11 Large Capacity Septic systems (Septic systems designed for 5,000 gpd or greater)
- 5W12 WTPP disposal
- 5W20 Industrial Process Waste Disposal Wells
- 5W31 Septic System (Well Disposal method)
- 5W32 Septic System Drainfield Disposal
- 5X13 Mine Backfill (IW used to control subsidence, dispose of mining byproducts, and/or fill sections of a mine)
- 5X25 Experimental Wells (Pilot Test) (IW used to test new technologies or tracer dye studies)
- 5X26 Aquifer Remediation (IW used to clean up, treat, or prevent contamination of a USDW)
- 5X27 Other Wells
- 5X28 Motor Vehicle Waste Disposal Wells (IW used to dispose of waste from a motor vehicle site - These are currently banned)
- 5X29 Abandoned Drinking Water Wells (waste disposal)



TCEQ Use Only

TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for Submission (If other is checked please describe in space provided.)		
<input type="checkbox"/> New Permit, Registration or Authorization (Core Data Form should be submitted with the program application.)		
<input checked="" type="checkbox"/> Renewal (Core Data Form should be submitted with the renewal form)		<input type="checkbox"/> Other
2. Customer Reference Number (if issued)	Follow this link to search for CN or RN numbers in Central Registry**	3. Regulated Entity Reference Number (if issued)
CN 605844786		RN 101608586

SECTION II: Customer Information

4. General Customer Information		5. Effective Date for Customer Information Updates (mm/dd/yyyy)	
<input type="checkbox"/> New Customer <input checked="" type="checkbox"/> Update to Customer Information <input checked="" type="checkbox"/> Change in Regulated Entity Ownership			
<input type="checkbox"/> Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts)			
<i>The Customer Name submitted here may be updated automatically based on what is current and active with the Texas Secretary of State (SOS) or Texas Comptroller of Public Accounts (CPA).</i>			
6. Customer Legal Name (If an individual, print last name first: eg: Doe, John)		<i>If new Customer, enter previous Customer below:</i>	
CSWR-Texas Utility Operating Company LLC		Douglas Utility Company (CN600693022)	
7. TX SOS/CPA Filing Number	8. TX State Tax ID (11 digits)	9. Federal Tax ID (9 digits)	10. DUNS Number (if applicable)
803367893	32071353422	84-3250493	N/A
11. Type of Customer:		Partnership: <input type="checkbox"/> General <input type="checkbox"/> Limited	
<input checked="" type="checkbox"/> Corporation		<input type="checkbox"/> Individual	
Government: <input type="checkbox"/> City <input type="checkbox"/> County <input type="checkbox"/> Federal <input type="checkbox"/> Local <input type="checkbox"/> State <input type="checkbox"/> Other		<input type="checkbox"/> Sole Proprietorship <input type="checkbox"/> Other:	
12. Number of Employees		13. Independently Owned and Operated?	
<input type="checkbox"/> 0-20 <input type="checkbox"/> 21-100 <input checked="" type="checkbox"/> 101-250 <input type="checkbox"/> 251-500 <input type="checkbox"/> 501 and higher		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
14. Customer Role (Proposed or Actual) – as it relates to the Regulated Entity listed on this form. Please check one of the following			
<input checked="" type="checkbox"/> Owner <input type="checkbox"/> Operator <input type="checkbox"/> Owner & Operator <input type="checkbox"/> Other:			
<input type="checkbox"/> Occupational Licensee <input type="checkbox"/> Responsible Party <input type="checkbox"/> VCP/BSA Applicant			
15. Mailing Address:			
1630 Des Peres Road			
Ste. 140			
City	Des Peres	State	MO
ZIP	63131	ZIP + 4	
16. Country Mailing Information (if outside USA)		17. E-Mail Address (if applicable)	
		adobbins@cswrgroup.com	
18. Telephone Number		19. Extension or Code	
		20. Fax Number (if applicable)	

SECTION III: Regulated Entity Information**21. General Regulated Entity Information** (If 'New Regulated Entity' is selected, a new permit application is also required.)
☐ New Regulated Entity
 ☒ Update to Regulated Entity Name
 ☒ Update to Regulated Entity Information

The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).

22. Regulated Entity Name (Enter name of the site where the regulated action is taking place.)

CSWR - Fountainview Wastewater Treatment Facility

23. Street Address of the Regulated Entity:

5530 North Sam Houston Parkway East

(No PO Boxes)

City	Houston	State	TX	ZIP	77032	ZIP + 4	
------	---------	-------	----	-----	-------	---------	--

24. County

Harris

If no Street Address is provided, fields 25-28 are required.

25. Description to Physical Location:

N/A

26. Nearest City

State

Nearest ZIP Code

N/A

NA

N/A

Latitude/Longitude are required and may be added/updated to meet TCEQ Core Data Standards. (Geocoding of the Physical Address may be used to supply coordinates where none have been provided or to gain accuracy).

27. Latitude (N) In Decimal:

29.938047

28. Longitude (W) In Decimal:

-95.310827

Degrees

Minutes

Seconds

Degrees

Minutes

Seconds

29. Primary SIC Code**30. Secondary SIC Code****31. Primary NAICS Code****32. Secondary NAICS Code**

(4 digits)

(4 digits)

(5 or 6 digits)

(5 or 6 digits)

4952

33. What is the Primary Business of this entity? (Do not repeat the SIC or NAICS description.)

Wastewater Treatment

34. Mailing Address:

1630 Des Peres Road

Ste. 140

City

Des Peres

State

MO

ZIP

63131

ZIP + 4

35. E-Mail Address:

adobbins@CSWRgroup.com

36. Telephone Number**37. Extension or Code****38. Fax Number** (if applicable)

(314) 380-9508

() -

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.


<input type="checkbox"/> Dam Safety	<input type="checkbox"/> Districts	<input type="checkbox"/> Edwards Aquifer	<input type="checkbox"/> Emissions Inventory Air	<input type="checkbox"/> Industrial Hazardous Waste
<input type="checkbox"/> Municipal Solid Waste	<input type="checkbox"/> New Source Review Air	<input type="checkbox"/> OSSF	<input type="checkbox"/> Petroleum Storage Tank	<input checked="" type="checkbox"/> PWS
				TX1010127
<input type="checkbox"/> Sludge	<input type="checkbox"/> Storm Water	<input type="checkbox"/> Title V Air	<input type="checkbox"/> Tires	<input type="checkbox"/> Used Oil
<input type="checkbox"/> Voluntary Cleanup	<input type="checkbox"/> Wastewater	<input type="checkbox"/> Wastewater Agriculture	<input type="checkbox"/> Water Rights	<input type="checkbox"/> Other:

SECTION IV: Preparer Information

40. Name:	Amberly Schulz			41. Title:	Compliance Specialist
42. Telephone Number	43. Ext./Code	44. Fax Number	45. E-Mail Address		
(573) 214-1075		() -	aschulz@trccompanies.com		

SECTION V: Authorized Signature

46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39.


Company:	CSWR-Texas Utility Operating Company	Job Title:	Vice President
Name (In Print):	Michael Duncan	Phone:	(314) 7490820
Signature:		Date:	4-16-24



ATTACHMENT 1

FOUNTAINVIEW SUBDIVISION WASTEWATER TREATMENT PLANT (FV-WWTP) HARRIS COUNTY, TEXAS

CONTACT STABILIZATION TREATMENT PLANT PROCESS FLOW



NOTES

THIS SYSTEM FLOW DIAGRAM REPRESENTS THE SETUP OF THE WASTEWATER TREATMENT PLANT BASED ON THE INFORMATION PROVIDED BY THE OWNER, OPERATOR, AND THE VISUAL INSPECTION CONDUCTED BY LPE. THEREFORE, THE PROCESS FLOW IS AN ESTIMATE AND MUST BE FIELD VERIFIED.

NOT TO SCALE.

LIGHTPOINT
 ENGINEERING, LLC

604 W. VORSHAM ST., STE 100
 WILLIS, TEXAS 77378
 TEL (936) 256-2626
 TBE FIRM No. 18938


SYSTEM FLOW DIAGRAM: FV-WWTP

PROJECT #: GCL 706-02

DATE: November 2022



ATTACHMENT 2



TREATMENT FACILITY BOUNDARY

OUTFALL 001

FOUNTAINVIEW SERVICE AREA

SOURCE NOTE: USGS 7.5 MINUTE US TOPO SERIES TOPOGRAPHIC MAP, HUMBLE, 2022.



**PROJECT: CENTRAL STATES WATER RESOURCES
FOUNTAINVIEW WASTEWATER TREATMENT FACILITY
5530 NORTH SAM HOUSTON PARKWAY EAST
HOUSTON, TEXAS 77032**

TITLE: **SUBJECT PROPERTY LOCATION MAP**

DRAWN BY	J. KONIAR	PROJ NO.:	503581.0011.0001
----------	-----------	-----------	------------------

CHECKED BY: A. SCHULZ

APPROVED BY: A. SCHULZ

DATE: FEBRUARY 2024

FIGURE 1

1000 Clark Ave.
Fl 4

St. Louis, MO 63102
Phone: 314.241.2694





SOURCE NOTE: AERIAL PROVIDED BY GOOGLE EARTH. APRIL, 2023.

1

LEGEND

— TREATMENT FACILITY BOUNDARY
- - - DISCHARGE PATH (PIPED)



**PROJECT CENTRAL STATES WATER RESOURCES
FOUNTAINVIEW WASTEWATER TREATMENT FACILITY
5530 NORTH SAM HOUSTON PARKWAY EAST
HOUSTON, TEXAS 77032**

SUBJECT PROPERTY LAYOUT

CREATED BY	J. KONIAR	PROJ NO: 503581.0011 0001
CHECKED BY	A. SCHULZ	
APPROVED BY	A. SCHULZ	
DATE	FEBRUARY 2024	


FIGURE 2



1000 Clark Ave.
FL 4
St. Louis, MO 63102
Phone: 314.241.2894

503581.0011.0001-01 dwg

Fountainview Service Area Map WQ0011200001



\\server\wei\cad\current\jobs\5442.02 douglas utility\wwtp rehab\wei current\05 site plan.dwg

BELTWAY 8
300' R.O.W.

N 86°08'12" E
CHD. 101.41'
TAN. 50.71'
ARC = 101.41'
R=5879.58
Δ=0°59'18"

EASTGROUP PROPERTIES
4220 WORLD HOUSTON PKWY STE 170
HOUSTON TX 77032-2492
HCAD ACCT. 1317680010001

RESTRICTED RESERVE "A"
WORLD HOUSTON INTERNATIONAL
BUSINESS CENTER
SECTION 9
FC NO. 630180
M.R.H.C.T.

CONCRETE PAVING

EXIST. COMMERCIAL
OFFICE BUILDING

CENTERPOINT ENERGY
EASEMENT W/ 11.5' AERIAL EASEMENT
H.C.C.F. No. 2009184702

CONCRETE PAVING

ADDITIONAL
PROPOSED BUFFER
ZONE AREA = 9850 SQ. FT.

EASTGROUP PROPERTIES
4220 WORLD HOUSTON PKWY STE 170
HOUSTON TX 77032-2492
HCAD ACCT. 1317680010001

RESTRICTED RESERVE "A"
WORLD HOUSTON INTERNATIONAL
BUSINESS CENTER
SECTION 9
FC NO. 630180
M.R.H.C.T.

CONCRETE PAVING

25' PUBLIC EASEMENT
HCCF No. B314195
VOL. 78 PG. 74

25' PUBLIC EASEMENT
HCCF No. B314195
VOL. 4323 PG. 371

10' PUBLIC EASEMENT
HCCF No. X134903
VOL. 544 PG. 142

TIMBER RIDGE HOUSING LTD
18729 FM 1887 RD
HEMPSTEAD TX 77445-3493
HCAD ACCT. 1246420010003

36.13 AC
BLDGS 1-49 BLK 1
RES A BLK 1
(BLDGS 1-15)
TIMBER RIDGE APARTMENTS
SEC 2
TIMBER RIDGE APTS

PROPERTY ADDRESS:
5350 AEROPARK DR # 316
HOUSTON TX 77032

TIMBER RIDGE APARTMENTS
FC NO. 544142
M.R.H.C.T.

ESTATE OF J. HERBERT ZIEBEN
1980 POST OAK BLVD STE 2020
HOUSTON TX 77056-3820
HCAD ACCT. 0470890000006

1.13 AC
TR 7 (009PT TR 3)
ABST 1482 WCRR CO SEC 4 BLK 6
CF NO. J107606
R.P.R.H.C.T.

WANG LI-FENG
11714 PECAN CREEK DR
HOUSTON TX 77043-4512
HCAD ACCT. 0470890000006

CALLED 4.577 ACRES
CF NO. M776813
R.P.R.H.C.T.

WOODED AREA
WASTEWATER TREATMENT
PLANT SITE

PROP. TREE LINE

PROP. 20' W. ROLLING GATE

CONCRETE PAVING

PROP. ELEC. SERVICE RACK

PROP. LIFT STATION
(PHASE I)

PROP. SAN. SEWER MANHOLE

CL DITCH

HARRIS COUNTY FLOOD CONTROL DISTRICT
CHANNEL P133-04-00 (TRIBUTARY OF GREENS BAYOU)

PROP. 10" SAN. SEWER
PROP. 6'-0" CHAIN LINK
FENCE WITH RAZOR WIRE

PROP. SPLITTER BOX
(PHASE I)

PROP. GENSET
PROP. BLOWER FACILITY
PROP. DUMPSTER

PROP. AEROBIC DIGESTER
BASINS 1-3
(PHASE II)

PROP. CLARIFIER
(PHASE I)

PROP. AERATION
BASINS 1-4
(PHASE I)

PROP. 24" OUTFALL

PROP. 8" EFFLUENT

CHLORINE CONTACT
BASIN No. 2
(PHASE I)

CHLORINE CONTACT
BASIN No. 1
(PHASE I)


PROP. TREE LINE
PROP. CHEMICAL ENCLOSURE

PROP. OUTFALL INLET

50' H.C.F.C.D.
EASEMENT
VOL. 2180,
PG. 277


20' PUBLIC EASEMENT
HCCF No. X134903
VOL. 544 PG. 142

EXISTING 150' RADIUS
BUFFER ZONE
PROPOSED 150' RADIUS
BUFFER ZONE



WIND ROSE

DEPICTING % OF TIME THE WIND
BLOWS IN INDICATED DIRECTION.
BASED ON DATA AT HOUSTON
INTERCONTINENTAL AIRPORT.



ADDITIONAL
PROPOSED BUFFER
ZONE AREA = 9850 SQ. FT.


EXISTING 150' RADIUS BUFFER ZONE
PROPOSED 150' RADIUS BUFFER ZONE

REVISION	DATE
DESCRIPTION	M/D/YY

**WaterEngineers, Inc.**
Water & Wastewater Treatment Consultants
TEXAS BOARD OF PROFESSIONAL ENGINEERS FIRM No. 2066
17230 HUFFMEISTER ROAD
CYPRESS, TEXAS 77429
TEL: 281-373-0500
FAX: 281-373-1113

THIS DRAWING CONTAINS CONFIDENTIAL PROPRIETARY INFORMATION AND MAY NOT BE
TRANSFERRED, REPRODUCED, OR USED TO CONSTRUCT ANY PROJECT OTHER THAN THAT
FOR WHICH IT WAS ISSUED WITHOUT FIRST OBTAINING WRITTEN PERMISSION FROM WATERENGINEERS, INC.

DOUGLAS UTILITY COMPANY
FOUNTAINVIEW
0.380 MGD ADF
WASTEWATER TREATMENT FACILITY


D. Ray Young
07-17-2017

SHEET NAME:
**PROPOSED
SITE PLAN**

DRAWN BY: JLW
CHECKED BY: DRY
PROJECT No.: 5442.1
DATE: 7/27/2017
SHEET No.:

Erwin Madrid

From: Mandy Sappington <msappington@cswrgroup.com>
Sent: Wednesday, June 5, 2024 12:37 PM
To: Erwin Madrid
Cc: April Dobbins; Schulz, Amberly
Subject: RE: Application for Permit No. WQ0011200001 Deficiencies

Hi Erwin –

As Vice President, Mike Duncan meets the definition of a Corporate Officer. We had him sign because he was in the office and Mr. Cox was not. I understand him to be authorized to sign this type of document in accordance with state and federal rules.

Thanks
Mandy

Amanda Sappington
EHS Compliance Manager
(314) 464-3976
ADDRESS: 1630 Des Peres Rd., Ste. 140, Des Peres, MO 63131
www.centralstateswaterresources.com

From: Erwin Madrid <Erwin.Madrid@tceq.texas.gov>
Sent: Wednesday, June 5, 2024 10:38 AM
To: Mandy Sappington <msappington@cswrgroup.com>
Cc: April Dobbins <adobbins@cswrgroup.com>; Schulz, Amberly <ASchulz@trccompanies.com>
Subject: RE: Application for Permit No. WQ0011200001 Deficiencies
Importance: High

Hi Mandy,

I am working to declare the renewal application administratively complete. However, I noticed a discrepancy while working to complete everything. The application lists Mr. Josiah Cox as the individual responsible for signing the application, but the application was signed by the Vice President Mr. Michael Duncan.

Can you please confirm if Mr. Duncan is authorized to sign? Otherwise, we would need a new updated original signature page from Mr. Cox.

Regards,

Erwin Madrid
Team Lead
ARP Team | Water Quality Division
512-239-2191
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail.

From: Mandy Sappington <msappington@cswrgroup.com>
Sent: Tuesday, May 14, 2024 4:04 PM
To: Erwin Madrid <Erwin.Madrid@tceq.texas.gov>
Cc: April Dobbins <adobbins@cswrgroup.com>; Schulz, Amberly <ASchulz@trccompanies.com>
Subject: Application for Permit No. WQ0011200001 Deficiencies

Erwin –

Please find the items your requested attached. This is our first permit renewal in TX, so we appreciate any guidance you can provide about what the next steps are in the process. We don't want to overlook any requirements, and we also look forward to an opportunity to review any draft changes you have in mind.

Thank you
Mandy



Amanda Sappington
EHS Compliance Manager

Email: msappington@cswrgroup.com

(314) 464-3976

ADDRESS: 1630 Des Peres Rd., Ste. 140, Des Peres, MO 63131

www.centralstateswaterresources.com

Erwin Madrid

From: Mandy Sappington <msappington@cswrgroup.com>
Sent: Tuesday, May 14, 2024 4:04 PM
To: Erwin Madrid
Cc: April Dobbins; Schulz, Amberly
Subject: Application for Permit No. WQ0011200001 Deficiencies
Attachments: 24.05.14 Fountainview TX0031461 NODI Resp.pdf; NORI English and Spanish.docx; PLS English and Spanish.docx

Erwin –

Please find the items your requested attached. This is our first permit renewal in TX, so we appreciate any guidance you can provide about what the next steps are in the process. We don't want to overlook any requirements, and we also look forward to an opportunity to review any draft changes you have in mind.

Thank you
Mandy



Amanda Sappington
EHS Compliance Manager

Email: msappington@cswrgroup.com

(314) 464-3976

ADDRESS: 1630 Des Peres Rd., Ste. 140, Des Peres, MO 63131

www.centralstateswaterresources.com

May 14, 2024

Erwin Madrid
Texas Commission Environmental Quality
ARP Team | Water Quality Division

Subject: Fountainview Wastewater Treatment Plant – WQ0011200001
Application for Renewal without Changes – Notice of Deficiency Letter

Submitted via email – erwin.madrid@tceq.texas.gov

Mr. Madrid -

In response to your Notice of Deficiency dated April 30, 2024, we provide the following additional information:

1. Payment of \$7,394.48 was made electronically today, the receipt is included here as Attachment 1.
2. Section 9.E on Page 8 of the Administrative Report was completed in error. CSWR-Texas does not wish to add disposal provisions to the permit.
3. I have attached the completed English language Word version of the Plain Language Summary to the email transmitting this letter.
4. I have attached the completed Spanish language Word version of the Plain Language Summary to the email transmitting this letter.
5. The completed Supplemental Permit Information Form is included here as Attachment 2.
6. CSWR-Texas is not requesting to reduce the permitted average flow for this facility. A corrected Section 1 of the Domestic Technical Report is included here as Attachment 3.
7. The portion of the NORI provided in your letter appears complete and accurate.
8. The Spanish language version of the NORI language is attached to the email transmitting this letter.

We appreciate your assistance in developing a complete application. If you have any questions regarding this submittal, please reach out to me directly at 314-464-3976 or msappington@cswrgroup.com.

Sincerely,



EHS Compliance Manager
Central States Water Resources

ATTACHMENT 1

Your transaction is complete. Thank you for using TCEQ ePay.

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt and the vouchers for your records. An email receipt has also been sent.

Transaction Information

Trace Number: 582EA000610238
Date: 05/14/2024 12:54 PM
Payment Method: ACH - Authorization 0072588298
ePay Actor: KRISTA OBERNUEFEMANN
Actor Email: krista@cswrgroup.com
IP: 35.134.151.130
TCEQ Amount: \$7,746.59
Texas.gov Price: \$7,746.59*

* This service is provided by Texas.gov, the official website of Texas. The price of this service includes funds that support the ongoing operations and enhancements of Texas.gov, which is provided by a third party in partnership with the State.

Payment Contact Information

Name: KRISTA OBERNUEFEMANN
Company: CSWR TEXAS UTILITY OPERATING CO
Address: 1630 DES PERES RD STE 140, ST LOUIS, MO 63131
Phone: 314-380-8515

Cart Items

Click on the voucher number to see the voucher details.

Voucher	Fee Description	AR Number	Amount
705363	REGULATORY ASSESSMENT FEE	89911369	\$7,746.59
TCEQ Amount:			\$7,746.59

[ePay Again](#)[Exit ePay](#)

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt for your records.

[Site Help](#) | [Disclaimer](#) | [Web Policies](#) | [Accessibility](#) | [Our Compact with Texans](#) | [TCEQ Homeland Security](#) | [Contact Us](#)
[Statewide Links](#): [Texas.gov](#) | [Texas Homeland Security](#) | [TRAIL](#) | [Statewide Archive](#) | [Texas Veterans Portal](#)

© 2002-2024 Texas Commission on Environmental Quality

ATTACHMENT 2

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:

Application type: ☒ Renewal ☐ Major Amendment ☐ Minor Amendment ☐ New

County: Harris Segment Number: _____

Admin Complete Date: _____

Agency Receiving SPIF:

☐ Texas Historical Commission

☐ U.S. Fish and Wildlife

☐ Texas Parks and Wildlife Department

☐ U.S. Army Corps of Engineers

This form applies to TPDES permit applications only. (Instructions, Page 53)

The SPIF must be completed as a separate document. The TCEQ will mail a copy of the SPIF to each agency as required by the TCEQ agreement with EPA. If any of the items are not completely addressed or further information is needed, you will be contacted to provide the information before the permit is issued. Each item must be completely addressed.

Do not refer to a response of any item in the permit application form. Each attachment must be provided with this form separately from the administrative report of the application. The application will not be declared administratively complete without this form being completed in its entirety including all attachments.

The following applies to all applications:

1. Permittee: **CSWR - Texas Utility Operating Company**.

Permit No. WQ00 **11200001**

EPA ID No. TX **0031461**

Address of the project (or a location description that includes street/highway, city/vicinity, and county):

5530 North Sam Houston Parkway East, Houston, Harris County, Texas 77032

Provide the name, address, phone and fax number of an individual that can be contacted to answer specific questions about the property.

Prefix (Mr., Ms., Miss): Mrs. text.

First and Last Name: April Dobbins

Credential (P.E, P.G., Ph.D., etc.): MBA

Title: EHS Compliance

Mailing Address: 1630 Des Peres Road

City, State, Zip Code: Des Peres, MO 63131

Phone No.: 314-380-9508

Ext.:

Fax No.:

text.

E-mail Address: adobbins@cswrgroup.com

2. List the county in which the facility is located: Harris
3. If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.

N/A

4. Provide a description of the effluent discharge route. The discharge route must follow the flow of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.


Plant site to Harris County Flood Control District Ditch; thence to Greens Bayou above tidal.

5. Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report).


Provide original photographs of any structures 50 years or older on the property.

Does your project involve any of the following? Check all that apply.

- ☐ Proposed access roads, utility lines, construction easements
- ☐ Visual effects that could damage or detract from a historic property's integrity
- ☐ Vibration effects during construction or as a result of project design
- ☐ Additional phases of development that are planned for the future




SOURCE NOTE: USGS 7.5 MINUTE US TOPO SERIES TOPOGRAPHIC MAP, HUMBLE, 2022.



QUADRANGLE LOCATION
HARRIS COUNTY, TEXAS



0 1,000 2,000



SCALE IN FEET
1" = 2,000'

**PROJECT: CENTRAL STATES WATER RESOURCES
FOUNTAINVIEW WASTEWATER TREATMENT FACILITY
5530 NORTH SAM HOUSTON PARKWAY EAST
HOUSTON, TEXAS 77032**

TITLE: **SUBJECT PROPERTY LOCATION MAP**


DRAWN BY:	J. KONIAR	PROJ NO.:	503581.0011.0001
CHECKED BY:	A. SCHULZ	<div style="text-align: center;">  <p>FIGURE 3</p> </div>	
APPROVED BY:	A. SCHULZ		
DATE:	FEBRUARY 2024		

FIGURE 3

1000 Clark Ave.
El 4

St. Louis, MO 63102
Phone: 314,241,2694



FILE NO.: 503581.0011.0001-01.dwg

ATTACHMENT 3



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
DOMESTIC WASTEWATER PERMIT APPLICATION

DOMESTIC TECHNICAL REPORT 1.0

**The Following Is Required For All Applications
Renewal, New, And Amendment**

Section 1. Permitted or Proposed Flows (Instructions Page 51)

A. Existing/Interim I Phase

Design Flow (MGD): 0.038 MGD

2-Hr Peak Flow (MGD): 50 gpm

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

B. Interim II Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

C. Final Phase

Design Flow (MGD): 0.038 MGD

2-Hr Peak Flow (MGD): 50 gpm

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

D. Current operating phase: 0.038 MGD

Provide the startup date of the facility: Operating

Section 2. Treatment Process (Instructions Page 51)

A. Treatment process description

Provide a detailed description of the treatment process. **Include the type of**

CSWR-Texas Utility Operating Company, LLC (*pending transfer of ownership application*), 1630 Des Peres Road, Suite 140, Des Peres, Missouri 63131, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0011200001 (EPA I.D. No. TX0031461) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 380,000 gallons per day. The domestic wastewater treatment facility is located at 5530 North Sam Houston Parkway East, Houston, in Harris County, Texas 77032. The discharge route is from the plant site to a Harris County Flood Control District ditch; thence to Greens Bayou Above Tidal. TCEQ received this application on April 16, 2024. The permit application will be available for viewing and copying at United States Postal Service, 1411 Wunsche Loop, Spring, in Harris County, Texas prior to the date this notice is published in the newspaper.

This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application. <https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.310783,29.937964&level=18>

Further information may also be obtained from CSWR-Texas Utility Operating Company, LLC at the address stated above or by calling Ms. April Dobbins, M.B.A., EHS Compliance, at 314-380-9508.

CSWR-Texas Utility Operating Company, LLC (*pendiente de transferencia de propiedad solicitud*), 1630 Des Peres Road, Suite 140, Des Peres, Missouri 63131, ha solicitado a la La Comisión de Calidad Ambiental de Texas (TCEQ) para renovar el Permiso No. Permiso No. WQ0011200001 (EPA I.D. No. TX0031461) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio de 380.000 galones por día. La planta está ubicada en 5530 North Sam Houston Parkway East, Houston, en el Condado de Harris, Texas 77032. La descarga la ruta es desde el sitio de la planta hasta una zanja del Distrito de Control de Inundaciones del Condado de Harris; de allí a los verdes Pantano por encima de la marea. TCEQ recibió esta solicitud el 16 de abril de 2024. La solicitud para el permiso estará disponible para leerla y copiarla en United States Postal Service, 1411 Wunsche Loop, Spring, en el condado de Harris, Texas, antes de la fecha de publicación de este aviso en el periódico.

Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

<https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.310783,29.937964&level=18>

También se puede obtener más información de CSWR-Texas Utility Operating Company, LLC a la dirección indicada arriba o llamando a la Sra. April Dobbins, M.B.A., Cumplimiento de EHS, al 314-380-9508.

CSWR-Texas (CN605844786) operates Fountainview wastewater treatment facility (WWTF), (RN101608586), a wastewater treatment plant used in the transportation, storage, and disposal of domestic sewage under the jurisdiction of the Texas Commission on Environmental Quality (TCEQ). The facility is located at 5530 N Sam Houston Parkway, in Houston, Harris County, Texas 77032.

This application is for a renewal to discharge an average annual flow of 380,000 gallons per day of treated domestic wastewater through Outfall 001.

The facility is expected to discharge carbonaceous biochemical oxygen demand (CBOD), total suspended solids (TSS), ammoniacal nitrogen (NH₃-N) and *Escherichia coli*. At this plant, domestic wastewater is treated by removing large solids, aeration and clarification. Sludge is further treated in digester basins. Wastewater is disinfected with chlorine before being discharged.

CSWR-Texas (CN605844786) opera la instalación de tratamiento de aguas residuales de Fountainview, (RN101608586), una planta de tratamiento de aguas residuales utilizada en el transporte, almacenamiento y eliminación de aguas residuales domésticas bajo la jurisdicción de la Comisión de Calidad Ambiental de Texas (TCEQ). La instalación está ubicada en 5530 N Sam Houston Parkway, en Houston, Condado de Harris, Texas 77032.

Esta solicitud es para una renovación para descargar un flujo anual promedio de 380,000 galones por día de aguas residuales domésticas tratadas a través del Emisario 001.

Se espera que la instalación descargue demanda bioquímica de oxígeno carbonoso (CBOD), sólidos suspendidos totales (SST), nitrógeno amoniacal (NH₃-N) y *Escherichia coli*. En esta planta se realizan el tratamiento de aguas residuales domésticas mediante eliminación de sólidos grandes, aireación y clarificación. Los lodos se tratan posteriormente en cuencas digestoras. Las aguas residuales se desinfectan con cloro antes de ser vertidas.