

This file contains the following documents:

- 1. Summary of application (in plain language)
 - English
 - Alternative Language (Spanish)
- 2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
 - English
 - Alternative Language (Spanish)
- 3. Second notice (NAPD-Notice of Preliminary Decision)
 - English
 - Alternative Language (Spanish)
- 4. Application materials
- 5. Draft permit
- 6. Technical summary or fact sheet



Este archivo contiene los siguientes documentos:

- 1. Resumen de la solicitud (en lenguaje sencillo)
 - Inglés
 - Idioma alternativo (español)
- 2. Primer aviso (NORI, Aviso de Recepción de Solicitud e Intención de Obtener un Permiso)
 - Inglés
 - Idioma alternativo (español)
- 3. Segundo aviso (NAPD, Aviso de Decisión Preliminar)
 - Inglés
 - Idioma alternativo (español)
- 4. Materiales de la solicitud
- 5. Proyecto de permiso
- 6. Resumen técnico u hoja de datos



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter 'INDUSTRIAL' or 'DOMESTIC' here WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Undine Texas Environmental, LLC (CN604519330) operates Sugartree WWTP (RN101522464), a activated sludge process plant operated in the complete mix mode. The facility is located at 1,700 feet south-southwest of the Brazos River Bridge crossing on FM 1189, in Weatherford, Parker County, Texas 76462. The applicant is requesting a renewal of a 150,000 gallons per day wastewater discharge permit.

Discharges from the facility are expected to contain contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Domestic wastewater is treated by an activated sludge process plant and the treatment units will include a bar screen, aeration basins, final clarifiers, sludge digesters, and chlorine contact chambers.

Undine Texas Environmental, LLC (CN604519330) opera la planta de tratamiento de aguas residuales Sugartree (RN101522464), una planta de procesamiento de lodos activados que funciona en el modo de mezcla completa. La instalación está ubicada a 1,700 pies al sursuroeste del cruce del puente del río Brazos en FM 1189, en Weatherford, condado de Parker, Texas 76462. El solicitante solicita la renovación de un permiso de descarga de aguas residuales de 150,000 galones por día.

Se espera que las descargas de la instalación contengan una demanda bioquímica carbonosa de oxígeno (CBOD5) de cinco días, sólidos suspendidos totales (TSS), nitrógeno amoniacal (NH3-N) y Escherichia coli. Las aguas residuales domésticas son tratadas por una planta de procesamiento de lodos activados y las unidades de tratamiento incluirán una criba de barras, cuencas de aireación, clarificadores finales, digestores de lodos y cámaras de contacto con cloro.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT RENEWAL

PERMIT NO. WQ0014163001

APPLICATION. Undine Texas Environmental, LLC, 17681 Telge Road, Cypress, Texas 77429, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0014163001 (EPA I.D. No. TX0122271) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 150,000 gallons per day. The domestic wastewater treatment facility is located approximately 1,700 feet south-southwest of the Brazos River bridge crossing on Farm-to-Market Road 1189, near the city of Weatherford, in Parker County, Texas 76462. The discharge route is from the plant site to a series of impoundments on an unnamed tributary, thence to Brazos River Below Possum Kingdom Lake. TCEQ received this application on December 3, 2024. The permit application will be available for viewing and copying at Weatherford Public Library, Info Desk, 1014 Charles Street, Weatherford, in Parker County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.927222,32.608055&level=18

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. Notice of the Application and Preliminary Decision will be published and mailed to those who are on the countywide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a

public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at https://www14.tceq.texas.gov/epic/eComment/, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Undine Texas Environmental, LLC at the address stated above or by calling Mr. Jeff Goebel, Business Development, at 713-724-9321.

Issuance Date: March 10, 2025

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO. WQ0014163001

SOLICITUD. Undine Texas Environmental, LLC, 17681 Telge Road, Cypress, Texas 77429, ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para renovar el Permiso No. WQ0014163001 (EPA I.D. No. TX0122271) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 150,000 galones por día. La planta está ubicada aproximadamente 1.700 pies al sursuroeste del cruce del puente del río Brazos en Farm-to-Market Road 1189, cerca de la ciudad de Weatherford en el Condado de Parker, Texas. La ruta de descarga es del sitio de la planta a una serie de embalses en un afluente sin nombre, de allí al río Brazos debajo del lago Possum Kingdom. La TCEQ recibió esta solicitud el 3 de diciembre de 2024. La solicitud para el permiso estará disponible para leerla y copiarla en Biblioteca pública de Weatherford, mostrador de información, 1014 Charles Street, Weatherford, condado de Parker, Texas antes de la fecha de publicación de este aviso en el periódico. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.927222,32.608055&level=18

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos

esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO. USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, v número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta: proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y

solicitudes deben ser presentadas electrónicamente vía http://www14.tceq.texas.gov/epic/eComment/o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Undine Texas Environmental, LLC a la dirección indicada arriba o llamando a Señor Jeff Goebel al 713-724-9321.

Fecha de emission: 10 de marzo de 2025

Texas Commission on Environmental Quality



NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR MUNICIPAL WASTEWATER

RENEWAL

PERMIT NO. WQ0014163001

APPLICATION AND PRELIMINARY DECISION. Undine Texas Environmental LLC, 17681 Telge Road, Cypress, Texas 77429, has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0014163001 which authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 150,000 gallons per day. TCEQ received this application on December 3, 2024.

The facility is located approximately 1,700 feet south-southwest of the Brazos River bridge crossing on Farm-to-Market Road 1189, in Parker County, Texas 76462. The treated effluent is discharged to a series of impoundments on an unnamed tributary, thence to the Brazos River Below Possum Kingdom Lake in Segment No. 1206 of the Brazos River Basin. The unclassified receiving water use is limited aquatic life use for the unnamed tributary. The designated uses for Segment No. 1206 are primary contact recreation and high aquatic life use. All determinations are preliminary and subject to additional review and/or revisions. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.927222,32.608055&level=18

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at Weatherford Public Library, Info Desk, 1014 Charles Street, Weatherford, in Parker County, Texas. The application, including any updates, and associated notices are available electronically at the following webpage:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public<u>notices</u>. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting about this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ holds a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision. A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period. TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

EXECUTIVE DIRECTOR ACTION. The Executive Director may issue final approval of the application unless a timely contested case hearing request or request for reconsideration is filed.

If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, Texas Commission on Environmental Quality, P.O. Box 13087, Austin, TX 78711-3087 or electronically at www.tceq.texas.gov/goto/comment within 30 days from the date of newspaper publication of this notice.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. Public comments and requests must be submitted either electronically at www.tceq.texas.gov/goto/comment, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC 105, P.O. Box 13087, Austin, Texas 78711-3087. Any personal information you submit to the TCEQ will become part of the agency's record; this includes email addresses. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Undine Texas Environmental LLC at the address stated above or by calling Mr. Jeff Goebel at 713-724-9321.

Issuance Date: September 18, 2025

Comisión de Calidad Ambiental de Texas



NOTIFICACIÓN DE LA DEMANDA Y DECISIÓN PRELIMINAR PARA EL PERMISO TPDES PARA AGUAS RESIDUALES MUNICIPALES

RENOVACIÓN

PERMISO NO. WQ0014163001

SOLICITUD Y RESOLUCIÓN PRELIMINAR. Undine Texas Environmental LLC, 17681 Telge Road, Cypress, Texas 77429, ha solicitado a la Comisión de Calidad Ambiental de Texas (TCEQ) una renovación del Permiso No. WQ0014163001 que autoriza la descarga de aguas residuales domésticas tratadas a un flujo promedio diario que no exceda los 150,000 galones por día. La TCEQ recibió esta solicitud el 3 de diciembre de 2024.

La instalación está ubicada aproximadamente a 1,700 pies al sur-suroeste del cruce del puente del río Brazos en Farm-to-Market Road 1189, en el condado de Parker, Texas 76462. El efluente tratado se descarga a una serie de embalses en un afluente sin nombre, de allí al río Brazos debajo del lago Possum Kingdom en el segmento No. 1206 de la cuenca del río Brazos. El uso de agua receptora no clasificado es un uso limitado de la vida acuática para el afluente sin nombre. Los usos designados para el segmento No. 1206 son recreación de contacto primario y alto uso de vida acuática. Todas las determinaciones son preliminares y están sujetas a revisión y/o revisiones adicionales. Este enlace a un mapa electrónico de la ubicación general del sitio o instalación se proporciona como cortesía pública y no forma parte de la solicitud o aviso. Para conocer la ubicación exacta, consulte la aplicación.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.927222,32.608055&level=18

El Director Ejecutivo de la TCEQ ha completado la revisión técnica de la solicitud y ha preparado un borrador del permiso. El borrador del permiso, si se aprueba, establecería las condiciones bajo las cuales debe operar la instalación. El Director Ejecutivo ha tomado una decisión preliminar de que este permiso, si se emite, cumple con todos los requisitos legales y reglamentarios. La solicitud de permiso, la decisión preliminar del Director Ejecutivo y el borrador del permiso están disponibles para ver y copiar en la Biblioteca Pública de Weatherford, Info Desk, 1014 Charles Street, Weatherford, en el condado de Parker, Texas. La solicitud, incluidas las actualizaciones y los avisos asociados, están disponibles electrónicamente en la siguiente página web: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

AVISO DE LENGUAJE ALTERNATIVO. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices.

COMENTARIO PÚBLICO / REUNIÓN PÚBLICA. Puede enviar comentarios públicos o solicitar una reunión pública sobre esta solicitud. El propósito de una reunión pública es brindar la oportunidad de enviar comentarios o hacer preguntas sobre la solicitud. La TCEQ celebra una reunión pública si el Director Ejecutivo determina que existe un grado significativo de interés público en la solicitud o si lo solicita un legislador local. Una reunión pública no es una audiencia de caso impugnado.

OPORTUNIDAD PARA UNA AUDIENCIA DE CASO IMPUGNADO. Después de la fecha límite para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios oportunos y preparará una respuesta a todos los comentarios públicos relevantes y materiales, o significativos. A menos que la solicitud se remita directamente para una audiencia de caso impugnado, la respuesta a los comentarios se enviará por correo a todos los que enviaron comentarios públicos y a aquellas personas que están en la lista de correo de esta solicitud. Si se reciben comentarios, el correo también proporcionará instrucciones para solicitar una audiencia de caso impugnado o la reconsideración de la decisión del Director Ejecutivo. Una audiencia de caso impugnado es un procedimiento legal similar a un juicio civil en un tribunal de distrito estatal.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO. DEBE INCLUIR LOS SIGUIENTES ELEMENTOS EN SU SOLICITUD: su nombre, dirección, número de teléfono; nombre del solicitante y número de permiso propuesto; la ubicación y distancia de su propiedad/actividades en relación con la instalación propuesta; una descripción específica de cómo se vería afectado negativamente por la instalación de una manera que no es común para el público en general; una lista de todas las cuestiones de hecho en disputa que envíe durante el período de comentarios; y la declaración "[Yo/somos] una audiencia de caso impugnado". Si la solicitud de audiencia de caso impugnado se presenta en nombre de un grupo o asociación, la solicitud debe designar al representante del grupo para recibir correspondencia futura; identificar por nombre y dirección física a un miembro individual del grupo que se vería afectado negativamente por la instalación o actividad propuesta: proporcionar la información discutida anteriormente sobre la ubicación del miembro afectado y la distancia de la instalación o actividad; explicar cómo y por qué el miembro se vería afectado; y explicar cómo los intereses que el grupo busca proteger son relevantes para el propósito del grupo.

Después del cierre de todos los períodos de comentarios y solicitudes aplicables, el Director Ejecutivo enviará la solicitud y cualquier solicitud de reconsideración o de una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración en una reunión programada de la Comisión.

La Comisión solo puede acceder a una solicitud de audiencia de un caso impugnado sobre cuestiones que el solicitante presentó en sus observaciones oportunas y que no fueron retiradas posteriormente. Si se concede una audiencia, el tema de una audiencia se limitará a cuestiones de hecho en disputa o cuestiones mixtas de hecho y derecho

relacionadas con preocupaciones relevantes y materiales sobre la calidad del agua presentadas durante el período de comentarios. La TCEQ puede actuar sobre una solicitud para renovar un permiso de descarga de aguas residuales sin brindar la oportunidad de una audiencia de caso impugnado si se cumplen ciertos criterios.

ACCIÓN DEL DIRECTOR EJECUTIVO. El Director Ejecutivo puede emitir la aprobación final de la solicitud a menos que se presente una solicitud de audiencia de caso impugnado oportuna o una solicitud de reconsideración. Si se presenta una solicitud de audiencia oportuna o una solicitud de reconsideración, el Director Ejecutivo no emitirá la aprobación final del permiso y enviará la solicitud y la solicitud a los Comisionados de la TCEQ para su consideración en una reunión programada de la Comisión.

LISTA DE CORREO. Si envía comentarios públicos, una solicitud para una audiencia de caso impugnado o una reconsideración de la decisión del Director Ejecutivo, se lo agregará a la lista de correo de esta solicitud específica para recibir futuros avisos públicos enviados por correo por la Oficina del Secretario Principal. Además, puede solicitar ser incluido en: (1) la lista de correo permanente para un nombre de solicitante específico y número de permiso; y/o (2) la lista de correo de un condado específico. Si desea ser incluido en la lista de correo permanente y / o del condado, especifique claramente qué lista (s) y envíe su solicitud a la Oficina del Secretario Principal de la TCEQ a la dirección a continuación.

Todos los comentarios públicos por escrito y las solicitudes de reuniones públicas deben enviarse a la Oficina del Secretario Principal, MC 105, Comisión de Calidad Ambiental de Texas, PO Box 13087, Austin, TX 78711-3087 o electrónicamente a www.tceq.texas.gov/goto/comment dentro de los 30 días a partir de la fecha de publicación de este aviso en el periódico.

INFORMACIÓN DISPONIBLE EN LÍNEA. Para obtener detalles sobre el estado de la solicitud, visite la Base de datos integrada de los comisionados en www.tceq.texas.gov/goto/cid. Busque en la base de datos utilizando el número de permiso para esta solicitud, que se proporciona en la parte superior de este aviso.

CONTACTOS E INFORMACIÓN DE LA AGENCIA. Los comentarios públicos y las solicitudes deben enviarse electrónicamente a www.tceq.texas.gov/goto/comment o por escrito a la Comisión de Calidad Ambiental de Texas, Oficina del Secretario Principal, MC 105, PO Box 13087, Austin, Texas 78711-3087. Cualquier información personal que envíe a la TCEQ pasará a formar parte del registro de la agencia; Esto incluye direcciones de correo electrónico. Para obtener más información sobre esta solicitud de permiso o el proceso de permisos, llame al Programa de Educación Pública de la TCEQ, sin cargo, al 1-800-687-4040 o visite su sitio web en www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener más información de Undine Texas Environmental LLC en la dirección indicada anteriormente o llamando al Sr. Jeff Goebel al 713-724-9321.

Fecha de emisión: 18 de septiembre de 2025



November 26, 2024

Executive Director Texas Commission on Environmental Quality Attn: Water Quality Division Wastewater Permits Section/Application Team (MC 148) P.O. Box 13087 Austin, Texas 78711-3087

To Whom It May Concern:

Please find enclosed one original application, and three copies for a Domestic Wastewater Discharge Permit application according to the following:

Type of Application: Domestic Wastewater Discharge Permit Renweal

Applicant:

Undine Texas Environmental, LLC

Permit Number:

14163-001

Name of the Facility: Sugartree WWTP

An application fee of \$815.00 has been sent under separate cover to the revenue section as required.

Thank you,

Jeff Goebel

Water Quality Applications Team

APPLICATION FOR RENEWAL TO AN DOMESTIC WASTEWATER DISCHARGE PERMIT

Permit No.: 14163-001

Sugartree Wastewater Treatment Facility

Submitted to:

Executive Director
Texas Commission on Environmental Quality
Attn: Water Quality Division
Wastewater Permits Section/Application Team (MC 148)
P.O. Box 13087
Austin, Texas 78711-3087

Submitted by:

Undine Texas Environmental, LLC

PARONMISSION OF THE PROPERTY O

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

APPLICANT NAME: <u>Undine Texas Environmental, LLC</u>
PERMIT NUMBER (If new, leave blank): WQ00 <u>14163001</u>

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	\boxtimes		Original USGS Map	\boxtimes	
Administrative Report 1.1		\boxtimes	Affected Landowners Map		\boxtimes
SPIF	\boxtimes		Landowner Disk or Labels		\boxtimes
Core Data Form	\boxtimes		Buffer Zone Map	\boxtimes	
Public Involvement Plan Form		\boxtimes	Flow Diagram	\boxtimes	
Technical Report 1.0	\boxtimes		Site Drawing	\boxtimes	
Technical Report 1.1		\boxtimes	Original Photographs		\boxtimes
Worksheet 2.0	\boxtimes		Design Calculations		\boxtimes
Worksheet 2.1		\boxtimes	Solids Management Plan	\boxtimes	
Worksheet 3.0		\boxtimes	Water Balance		
Worksheet 3.1		\boxtimes			
Worksheet 3.2		\boxtimes			
Worksheet 3.3		\boxtimes			
Worksheet 4.0		\boxtimes			
Worksheet 5.0		\boxtimes			
Worksheet 6.0		\boxtimes	RECEI	VE	5
Worksheet 7.0		\boxtimes	DEC 03		1
			Water Quality Appl	cations	leam

For TCEQ Use Only	
Segment Number	County
Expiration Date	Region
Permit Number	

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION **ADMINISTRATIVE REPORT 1.0**

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

Section 1. Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one)

mulcate the amount submitted for the application fee (check only one).						
Flow	New/Major Amendme	ent Renewal				
<0.05 MGD	\$350.00 □	\$315.00 □				
≥0.05 but <0.10 MGD	\$550.00 □	\$515.00 □				
≥0.10 but <0.25 MGD	\$850.00 □	\$815.00 ⊠				
≥0.25 but <0.50 MGD	\$1 , 250.00 □	\$1,215.00 □				
≥0.50 but <1.0 MGD	\$1,650.00 □	\$1,615.00 □				
≥1.0 MGD	\$2,050.00 □	\$2,015.00 □				
Minor Amendment (for any	/ flow) \$150.00 □					
Payment Information:						
Mailed Check,	Money Order Number: Click t	to enter text. 8362				
	Money Order Amount: Click t					
Name l	Printed on Check: Click to ent	iter text. Undine Texas Environmental				
EPAY Vouche	er Number: Click to enter text	t.				
Copy of Payment Vo	ucher enclosed? Ye	es 🗆				
Section 2. Type of	Application (Instructio	ons Page 26)				

50	Cui	JII Z. I	pc	of Application (matrictions rage 20)
a.	Che	ck the box i	next	to the appropriate authorization type.
		Publicly-Ov	wned	Domestic Wastewater
	\boxtimes	Privately-O	wne	d Domestic Wastewater
		Convention	nal W	astewater Treatment
b.	Che	ck the box r	ıext	to the appropriate facility status.
	\boxtimes	Active		Inactive

c.	Che	eck the box next to the appropriate permit typ	e.	
	\boxtimes	TPDES Permit		
		TLAP		
		TPDES Permit with TLAP component		
		Subsurface Area Drip Dispersal System (SAD	DS)	
d.	Che	eck the box next to the appropriate application	ı typ	e
		New		
		Major Amendment with Renewal		Minor Amendment with Renewal
		Major Amendment without Renewal		Minor Amendment without Renewal
	\boxtimes	Renewal without changes		Minor Modification of permit
e.	For	amendments or modifications, describe the p	ropo	sed changes: Click to enter text.
f.	For	existing permits:		
	Perr	nit Number: WQ00 <u>14163001</u>		
	EPA	I.D. (TPDES only): TX <u>0122271</u>		
	Expi	iration Date: <u>12/10/2024</u>		
6				
Se	ctio	on 3. Facility Owner (Applicant) a (Instructions Page 26)	nd (Co-Applicant Information
		(mstructions rage 20)		
		owner of the facility must apply for the per		
		it is the Legal Name of the entity (applicant) ap	plyi	ng for this permit?
	<u>Und</u>	<u>line Texas Environmental, LLC</u>		
		e legal name must be spelled exactly as filed wi legal documents forming the entity.)	th th	e Texas Secretary of State, County, or in
		e applicant is currently a customer with the Temay search for your CN on the TCEQ website		
	C	CN: 604519330		

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in *30 TAC § 305.44*.

Prefix: Mr

Last Name, First Name: Tillman, Vance

Title: CFO

Credential: Click to enter text.

B. Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

Click to enter text.

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the legal documents forming the entity.)

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: http://www15.tceq.texas.gov/crpub/

CN: Click to enter text.

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in *30 TAC § 305.44*.

Prefix: Click to enter text.

Last Name, First Name: Click to enter text.

Title: Click to enter text.

Credential: Click to enter text.

Provide a brief description of the need for a co-permittee: Click to enter text.

C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. <u>A-1</u>

Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Mr.

Last Name, First Name: Jeff Goebel

Title: Business Development

Credential: Click to enter text.

Organization Name: Undine Texas Environmental, LLC

Mailing Address: 17681 Telge Rd

City, State, Zip Code: Cypress Texas 77429

Phone No.: <u>713-724-9321</u>

E-mail Address: jgoebel@undinellc.com

Check one or both:

 □ Technical Contact

B. Prefix: Click to enter text.

Last Name, First Name: Click to enter text.

Title: Click to enter text.

Credential: Click to enter text.

Organization Name: Click to enter text.

Mailing Address: Click to enter text.

City, State, Zip Code: Click to enter text.

Phone No.: Click to enter text.

E-mail Address: Click to enter text.

Check one or both:

☐ Administrative Contact

□ Technical Contact

Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Ms

Last Name, First Name: Carey Thomas

Title: VP

Credential: Click to enter text.

Organization Name: Undine Texas Environmental, LLC

Mailing Address: 17681 Telge Rd

City, State, Zip Code: Cypress Texas 77429

Phone No.: 713-554-7820

E-mail Address: cthomas@undinellc.com

B. Prefix: Mr.

Last Name, First Name: Andy Thomas

Title: VP

Credential: Click to enter text.

Organization Name: Undine Texas Environmental, LLC

Mailing Address: 17681 Telge Rd

City, State, Zip Code: Cypress Texas 77429

Phone No.: 713-554-7820

E-mail Address: athomas@undinellc.com

Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Ms

Last Name, First Name: Carey Thomas

Title: VP

Credential: Click to enter text.

Organization Name: Undine Texas Environmental, LLC

Mailing Address: 17681 Telge Rd

City, State, Zip Code: Cypress Texas 77429

Phone No.: <u>713-554-7820</u>

E-mail Address: cthomas@undinellc.com

Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Ms

Last Name, First Name: Carey Thomas

Title: VP

Credential: Click to enter text.

Organization Name: Undine Texas Environmental, LLC

Mailing Address: 17681 Telge Rd

City, State, Zip Code: Cypress Texas 77429

Phone No.: <u>713-554-7820</u>

E-mail Address: cthomas@undinellc.com

Section 8. Public Notice Information (Instructions Page 27)

A. Individual Publishing the Notices

Prefix: Mr.

Last Name, First Name: Jeff Goebel

Title: Business Development

Credential: Click to enter text.

Organization Name: Undine Texas Environmental, LLC

Mailing Address: 17681 Telge Rd

City, State, Zip Code: Cypress Texas 77429

Phone No.: 713-724-9321

E-mail Address: jgoebel@undinellc.com

В.		ackage	or keceivin	ig No	ouce or	Receipt and intent to Obtain a water Quality Permit
	Ir	ndicate b	y a check n	nark	the pre	eferred method for receiving the first notice and instructions
		E-ma	il Address			
		Fax				
		Regu	lar Mail			
C.	C	ontact p	ermit to be	liste	ed in th	ne Notices
	Pi	refix: <u>Mr</u>	<u>.</u>			Last Name, First Name: <u>Jeff Goebel</u>
	T	itle: <u>Busi</u>	ness Develor	omen	<u>t</u>	Credential: Click to enter text.
	O	rganizat	ion Name: <u>I</u>	Undir	<u>ie Texas</u>	s Environmental, LLC
	M	ailing A	ddress: <u>1768</u>	31 Tel	ge Rd	City, State, Zip Code: Cypress Texas 77429
	Pl	hone No.	: <u>713-724-93</u>	21		E-mail Address: jgoebel@undinellc.com
D.	Pı	ublic Vie	wing Infor	mati	on	
			lity or outfa Ist be provid		ocated i	in more than one county, a public viewing place for each
	Pι	ıblic bui	lding name:	We	atherfo	ord Public Library
	Lo	ocation v	vithin the b	uildii	ng: <u>Info</u>	<u>Desk</u>
	Pł	nysical A	ddress of B	uildi	ng: <u>101</u>	4 Charles Street
	Ci	ty: Wea	therford			County: <u>Parker</u>
	Co	ontact (L	ast Name, F	irst l	Name):	Click to enter text.
	Ph	one No.	817-598-41	<u>50</u> Ex	t.: Clicl	k to enter text.
E.	Bi	lingual 1	Notice Requ	iiren	ients	
			nation is re on, and re r			new, major amendment, minor amendment or minor cations.
	be	needed.		instr	uctions	only used to determine if alternative language notices will son publishing the alternative language notices will be in
	ob					dinator at the nearest elementary and middle schools and to determine whether an alternative language notices are
	1.					am required by the Texas Education Code at the elementary see facility or proposed facility?
		\boxtimes	Yes		No	
		If no , probelow.	ublication o	of an	alterna	ative language notice is not required; skip to Section 9
	2.					ither the elementary school or the middle school enrolled in at that school?
			Yes		No	*

3.	Do the locatio	students a n?	t these	e schools a	ittend	a bilingu	ıal educ	ation pro	ogram (at another
		Yes	\boxtimes	No						
4.	Would waived	the school out of this	be req	uired to p rement un	rovide der 1	e a biling 9 TAC §8	ual edu 9.1205(cation pr g)?	ogram	but the school has
		Yes	\boxtimes	No						
5.		nswer is y e ed. Which la								ative language are
Pla	in Lang	guage Sumi	nary T	Template						
Co	mplete	the Plain La	anguag	e Summar	y (TC	EQ Form	20972)	and inclu	ıde as	an attachment.
At	tachme	nt: <u>A-2</u>								
Pu	blic Inv	olvement I	Plan Fo	orm						
										plication for a
ne	w perm	it or major	amen	dment to	a peri	nit and i	nclude a	as an atta	achmer	ıt.
Att	achmei	nt: <u>NA</u>								
at i	on O	Doguslo	tod T		J D		J Cito	IC		(I
CU	on 9.	Page 29		nuty an	ia Pe	ermitte	a Site	morm	iauor	ı (Instructions
			regula	ated by TC	EQ, p	rovide th	e Regul	ated Enti	ty Nun	nber (RN) issued to
		TCEQ's Cer currently re				/www15.	tceq.tex	xas.gov/c	rpub/	to determine if
Naı	ne of pi	roject or sit	e (the	name kno	wn by	the com	munity	where lo	cated):	
Sug	artree Si	ubdivision								
Ow	ner of t	reatment fa	acility:	Undine Te	kas En	vironmen	tal, LLC			
Ow	nership	of Facility:		Public	\boxtimes	Private		Both		Federal
Ow	ner of la	and where t	treatm	ent facility	is or	will be:				
Pre	fix: Clicl	k to enter t	ext.	Last	Name	, First Na	me: <u>Un</u>	dine Texas	s Enviro	onmental, LLC
Titl	e: Click	to enter te	xt.	Cred	ential	: Click to	enter to	ext.		
Org	anizatio	on Name: <u>U</u>	ndine	Texas En	viron	mental, l	LLC			
Mai	ling Ado	dress: <u>1768</u> 1	Telge	<u>Rd</u>	(City, State	e, Zip C	ode: <u>Cyp</u> r	ess Tex	as 77429
Pho	ne No.:	<u>713-554-782</u>	20	E-ma	ail Ad	dress: <u>cth</u>	omas@	<u>undinellc.</u>	com	
		owner is not or deed rec						or co-ap	plican	t, attach a lease
	Attachn	nent: Click	to ente	er text.						

F.

G.

A.

B.

C.

D.

	Prefix: Click to enter text.	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ente	er text.
	Mailing Address: Click to enter to	ext. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded ease	person as the facility owner or co-applicant, attach a lease ement. See instructions.
	Attachment: Click to enter te	xt.
F.	Owner sewage sludge disposal si property owned or controlled by	te (if authorization is requested for sludge disposal on the applicant)::
	Prefix: Click to enter text.	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ente	er text.
	Mailing Address: Click to enter to	ext. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded ease	person as the facility owner or co-applicant, attach a lease ment. See instructions.
	Attachment: Click to enter te	xt.
C.	stion 10 TDDEC Dischare	so Information (Instrumetions Boss 21)
		ge Information (Instructions Page 31)
	Is the wastewater treatment facili	ge Information (Instructions Page 31) ty location in the existing permit accurate?
	Is the wastewater treatment facili ☑ Yes □ No	ty location in the existing permit accurate?
	Is the wastewater treatment facili Yes No If no, or a new permit application	
	Is the wastewater treatment facili ☑ Yes □ No	ty location in the existing permit accurate?
A.	Is the wastewater treatment facili Yes No If no, or a new permit applicatio Click to enter text.	ty location in the existing permit accurate? n, please give an accurate description:
A.	Is the wastewater treatment facili Yes No If no, or a new permit application Click to enter text. Are the point(s) of discharge and	ty location in the existing permit accurate?
A. B.	Is the wastewater treatment facili ✓ Yes □ No If no, or a new permit applicatio Click to enter text. Are the point(s) of discharge and ✓ Yes □ No	n, please give an accurate description: the discharge route(s) in the existing permit correct?
A. B.	Is the wastewater treatment facili	ty location in the existing permit accurate? n, please give an accurate description:
A. B.	Is the wastewater treatment facili	ty location in the existing permit accurate? n, please give an accurate description: the discharge route(s) in the existing permit correct? ermit application, provide an accurate description of the
A. B.	Is the wastewater treatment facili	ty location in the existing permit accurate? n, please give an accurate description: the discharge route(s) in the existing permit correct? ermit application, provide an accurate description of the
А.	Is the wastewater treatment facili	n, please give an accurate description: the discharge route(s) in the existing permit correct? ermit application, provide an accurate description of the rige route to the nearest classified segment as defined in 30
А.	Is the wastewater treatment facili ✓ Yes □ No If no, or a new permit application Click to enter text. Are the point(s) of discharge and ✓ Yes □ No If no, or a new or amendment perpoint of discharge and the discharge TAC Chapter 307: Click to enter text.	the discharge route(s) in the existing permit correct? The discharge route(s) in the existing permit correct? The application, provide an accurate description of the rige route to the nearest classified segment as defined in 30 accorded.
A. B. C.	Is the wastewater treatment facili Yes □ No If no, or a new permit application of the content text. Are the point(s) of discharge and □ Yes □ No If no, or a new or amendment perpoint of discharge and the discharge and the discharge of the content text. City nearest the outfall(s): Weather County in which the outfalls(s) is/	the discharge route(s) in the existing permit correct? the discharge route(s) in the existing permit correct? trmit application, provide an accurate description of the rige route to the nearest classified segment as defined in 30 route to the nearest classified segment as defined in 30 reford are located: Parker lischarge to a city, county, or state highway right-of-way, or
A. B. C.	Is the wastewater treatment facili ✓ Yes ☐ No If no, or a new permit application Click to enter text. Are the point(s) of discharge and ✓ Yes ☐ No If no, or a new or amendment perpoint of discharge and the discharge and the discharge Click to enter text. City nearest the outfall(s): Weather County in which the outfalls(s) is/ Is or will the treated wastewater discharge and the discharge county in which the outfalls(s) is/	the discharge route(s) in the existing permit correct? the discharge route(s) in the existing permit correct? trmit application, provide an accurate description of the rige route to the nearest classified segment as defined in 30 route to the nearest classified segment as defined in 30 reford are located: Parker lischarge to a city, county, or state highway right-of-way, or

E. Owner of effluent disposal site:

	If yes , indicate by a check mark if:
	☐ Authorization granted ☐ Authorization pending
	For new and amendment applications, provide copies of letters that show proof of contact and the approval letter upon receipt.
	Attachment: Click to enter text.
D.	For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: <u>NA</u>
Se	ection 11. TLAP Disposal Information (Instructions Page 32)
Α.	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?
	☐ Yes ☒ No
	If no, or a new or amendment permit application , provide an accurate description of the disposal site location:
	Click to enter text.
B.	City nearest the disposal site: Click to enter text.
C.	County in which the disposal site is located: Click to enter text.
D.	For TLAPs , describe the routing of effluent from the treatment facility to the disposal site:
	Click to enter text.
E.	For TLAPs , please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: Click to enter text.
Se	ction 12. Miscellaneous Information (Instructions Page 32)
A.	Is the facility located on or does the treated effluent cross American Indian Land?
	□ Yes ⊠ No
	If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?
	□ Yes □ No ⊠ Not Applicable
	If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.
	Click to enter text.

C.				nerly employed by the TCEQ represent your company and get paid for is application?	
		Yes	\boxtimes	No	
				on formerly employed by the TCEQ who represented your company an regarding the application: Click to enter text.	d
D.	Do yo	u owe any	fees	to the TCEQ?	
		Yes	\boxtimes	No	
	If yes,	provide t	he fo	ollowing information:	
	Ac	count nur	nber:	Click to enter text.	
	An	nount pas	t due	: Click to enter text.	
E.	Do you	ı owe any	pena	alties to the TCEQ?	
		Yes	\boxtimes	No	
	If yes,	please pr	ovide	e the following information:	
	Enf	orcement	orde	er number: Click to enter text.	
	Am	ount pas	t due:	: Click to enter text.	
		Veter State Control of			2000
Se	ction	13. At	tach	ments (Instructions Page 33)	
	Figure Parties and State of Control		MR 64 (1797)	ments (Instructions Page 33) ints are included with the Administrative Report. Check all that apply:	
	licate w Lease	hich attad	chme nt or		
Ind	licate w Lease locat	hich attac agreemened ed or the	chme nt or efflu	nts are included with the Administrative Report. Check all that apply: deed recorded easement, if the land where the treatment facility is	
Ind	Lease locat Origin	agreement agreement agreement agreement and full-size applicant applicant applicant applicant application applicat	chme nt or efflue ze US 's pro t faci oint o ed dis wage lispos future lius in	nts are included with the Administrative Report. Check all that apply: deed recorded easement, if the land where the treatment facility is ent disposal site are not owned by the applicant or co-applicant.	
Ind	Lease locat Origin	agreement agreement agreement agreement and full-size and full-size agreement agreemen	chme nt or efflue ze US 's pro t faci oint o ed dis wage lispos future lius in	deed recorded easement, if the land where the treatment facility is ent disposal site are not owned by the applicant or co-applicant. GS Topographic Map with the following information: operty boundary dility boundary of discharge for each discharge point (TPDES only) scharge route for each discharge point (TPDES only) sludge disposal site (if applicable) sal site boundaries (TLAP only) e construction (if applicable) information	
Ind □ ⊠	Lease locat Origin	agreement agreem	chme nt or efflue ze US 's pro t faci oint o ed dis wage lispos future lius in ownst	deed recorded easement, if the land where the treatment facility is ent disposal site are not owned by the applicant or co-applicant. GGS Topographic Map with the following information: operty boundary ility boundary of discharge for each discharge point (TPDES only) scharge route for each discharge point (TPDES only) sludge disposal site (if applicable) sal site boundaries (TLAP only) e construction (if applicable) information tream information (TPDES only)	

Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0014163001

Applicant: Undine Texas Environmental, LLC

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): <u>Vance Tillman</u>
Signatory title: Chief Financial Officer
Signature: Use blue ink) Date: 1/26/24
(Ose blue hik)
Subscribed and Sworn to before me by the said Hyperia Woss
on this day of $NNPMBER$, 2024 .
My commission expires on the 35% day of 30% , 30%
International Control of the Control
Notary Public
HARIS 135000930 00 111111111111111111111111111111
County, Texas

DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

The following information is required for new and amendment applications.

Section 1. Affected Landowner Information (Instructions Page 36)

A		icate by a check mark that the landowners map or drawing, with scale, includes the owing information, as applicable:
		The applicant's property boundaries
		The facility site boundaries within the applicant's property boundaries
		The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone
		The property boundaries of all landowners surrounding the applicant's property (Note: if the application is a major amendment for a lignite mine, the map must include the property boundaries of all landowners adjacent to the new facility (ponds).)
		The point(s) of discharge and highlighted discharge route(s) clearly shown for one mile downstream
		The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge
		The property boundaries of the landowners along the watercourse for a one-half mile radius from the point of discharge if the point of discharge is into a lake, bay, estuary, or affected by tides
		The boundaries of the effluent disposal site (for example, irrigation area or subsurface drainfield site) and all evaporation/holding ponds within the applicant's property
		The property boundaries of all landowners surrounding the effluent disposal site
		The boundaries of the sludge land application site (for land application of sewage sludge for beneficial use) and the property boundaries of landowners surrounding the applicant's property boundaries where the sewage sludge land application site is located
		The property boundaries of landowners within one-half mile in all directions from the applicant's property boundaries where the sewage sludge disposal site (for example, sludge surface disposal site or sludge monofill) is located
3.		Indicate by a check mark that a separate list with the landowners' names and mailing esses cross-referenced to the landowner's map has been provided.
Ξ.	Indi	cate by a check mark in which format the landowners list is submitted: USB Drive Four sets of labels
).	Prov	ide the source of the landowners' names and mailing addresses: Click to enter text.
		equired by <i>Texas Water Code § 5.115</i> , is any permanent school fund land affected by application?
		l Yes □ No

B.

C.

D.

E.

		yes nd(s, provide the location and foreseeable impacts and effects this application has on the s):									
	_		k to enter text.									
.0		- 71-5										
92	to Edward Fall		1 2. Original Photographs (Instructions Page 38)									
			original ground level photographs. Indicate with checkmarks that the following ion is provided.									
		Δ	at least one original photograph of the new or expanded treatment unit location									
	At least two photographs of the existing/proposed point of discharge and as much are downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is t an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.											
		A	at least one photograph of the existing/proposed effluent disposal site									
		A	plot plan or map showing the location and direction of each photograph									
Se	ecti	on	3. Buffer Zone Map (Instructions Page 38)									
A.	inf	orn	zone map. Provide a buffer zone map on 8.5×11 -inch paper with all of the following nation. The applicant's property line and the buffer zone line may be distinguished by dashes or symbols and appropriate labels.									
	 The applicant's property boundary; The required buffer zone; and Each treatment unit; and The distance from each treatment unit to the property boundaries. 											
B. Buffer zone compliance method. Indicate how the buffer zone requirements will be me Check all that apply.												
			Ownership									
			Restrictive easement									
			Nuisance odor control									
			Variance									
C.			able site characteristics. Does the facility comply with the requirements regarding able site characteristic found in 30 TAC § 309.13(a) through (d)?									
			Yes No									

DOMESTIC WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: Click to enter text.

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

Core Data Form (TCEQ Form No. 10400) (Required for all application types. Must be completed in its entirety Note: Form may be signed by applicant representative.)	red for all application types. Must be completed in its entirety and signed.					
Correct and Current Industrial Wastewater Permit Application Form (TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018 or late		Yes				
Water Quality Permit Payment Submittal Form (Page 19) (Original payment sent to TCEQ Revenue Section. See instructions for	iling ad	□ ldres	Yes s.)			
7.5 Minute USGS Quadrangle Topographic Map Attached (Full-size map if seeking "New" permit. 8 ½ x 11 acceptable for Renewals and Amendments)			Yes			
Current/Non-Expired, Executed Lease Agreement or Easement		N/A		Yes		
Landowners Map (See instructions for landowner requirements)		Yes				
 All the items shown on the map must be labeled. The applicant's complete property boundaries must be de boundaries of contiguous property owned by the applicant. The applicant cannot be its own adjacent landowner. You landowners immediately adjacent to their property, regard from the actual facility. If the applicant's property is adjacent to a road, creek, or on the opposite side must be identified. Although the propapplicant's property boundary, they are considered potent of the adjacent road is a divided highway as identified on the control of the adjacent road is a divided highway as identified. 	t identi s of how am, the ses are r affecte	fy the far they are landowners od landowners.				
Landowners Cross Reference List (See instructions for landowner requirements)		Yes				
Landowners Labels or USB Drive attached (See instructions for landowner requirements)		Yes				
7.5 Minute USGS Quadrangle Topographic Map Attached (Full-size map if seeking "New" permit. 8 ½ x 11 acceptable for Renewals and Amendments) Current/Non-Expired, Executed Lease Agreement or Easement				Yes		
Plain Language Summary				Yes		

TCEQ-10053 (01/09/2024) Domestic Wastewater Permit Application Administrative Report

Page 17 of 17

ATTACHMENT

A1



TCEQ Core Data Form

TCEQ Use Only


For detailed instructions regarding completion of this form, please read the Core Data Form Instructions or call 512-239-5175. SECTION I: General Information

		ssion (If other is c				1000		,	J	L				
New Permit, Registration or Authorization (Core Data Form should be submitted with the program application.)														
Renewal (Core Data Form-should be submitted with the renewal form) Other Customer Reference Number (if issued) 3. Regulated Entity Reference Number (if issued)														
		Follow this link to search for CN or RN numbers in			n 🗀									
	3045193			_ <u>С</u> е	Central Registry**			. L	RN 101522464					
1988 1981 AL WOLD USE	Managa Roy Managa	tomer Informati			0					7 7111	- Interview			
4. General (Information	L		Information Updates (mm/dd/yyyy) 10/15/2018									
New Customer Update to Customer Information Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts)														
Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts) The Customer Name submitted here may be updated automatically based on what is current and active with the														
Texas Secretary of State (SOS) or Texas Comptroller of Public Accounts (CPA).														
6. Customer	6. Customer Legal Name (If an individual, print last name first: e.g.: Doe, John) If new Customer, enter previous Customer below:													
Undine Texas Environmental, LLC														
7. TX SOS/0	CPA Filing	g Number	8. TX State	Гах ID	(11 digi	ts)			9. Fed	deral Tax ID (9 digits)	10. DUN	IS Number (if applicable)		
080176806	0801768069 32050717274													
11. Type of	Customer	: Corporation	on			Indivi	dual	dual Partnership: Gene			eral Limited			
Government	: City	County Federal	State Other		Sole Proprietors			orsh	hip Other: LLC					
	12. Number of Employees 13. Independently Owned and Operated?													
	21-100		251-500			nd high			× Y€					
_	r Role (P			ne Regi	-				form. Pl	ease check one of the f	ollowing:			
Occupation	onal Licer	Operationsee Respon	tor nsible Party		0.000		& Opera ry Clea		Applica	ant Other:				
		Telge Rd							NAME OF THE OWNER OWNER OF THE OWNER O					
15. Mailing Address:														
Addiess.	City	Cypress		St	ate	TX		ZIP	77	429	ZIP + 4			
16. Country N	Mailing In	formation (if outside U	JSA)				17. E	-Mai	l Addre	ess (if applicable)				
							cthomas@undinellc.com							
18. Telephone Number 19						9. Extension or Code				20. Fax Number	(if applicable)			
(713)						(713) 647 - 0277								
SECTION II	II: Regu	ulated Entity Inf	ormation								n			
21. General Regulated Entity Information (If `New Regulated Entity" is selected below this form should be accompanied by a permit application)														
New Regulated Entity Update to Regulated Entity Name Update to Regulated Entity Information														
The Regulated Entity Name submitted may be updated in order to meet TCEQ Agency Data Standards (removal														
of organizational endings such as Inc, LP, or LLC). 22. Regulated Entity Name (Enter name of the site where the regulated action is taking place.)														
					THE SHARE	100000000	۱ و ۱		an outstances		Part Development			
Sugartree W	vastewa	ter Treatment Fa	acility											


23. Street Address of the												
Regulated Entity: (No PO Boxes)	0.1		essential des		I	T	1	T	.			
24. County	City	State	<u>1</u>		ZIP	ignetica.		ZIP+	4			
24. Oddity	Enter Physical I	ocation Descripti	ion if n	o etroet	address is	provided		200	4			
T12-20-0-70-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1	Litter i frysicar E	ocation bescripti		O Su cci	auuless is	provided.			will the second of			
25. Description to Physical Location: located approximately 1,700 feet south-southwest of the Brazos River bridge crossing on Farm-to-Market Road 1189 in Parker County, Texas 76462												
26. Nearest City						State	WWW.	Nearest ZIP Code				
Weatherford						TX						
27. Latitude (N) In Decim	al:			28. Loi	ngitude (W) In Deci	mal:					
Degrees	Minutes	Seconds		Degrees		Min	utes	Seco	nds			
32	36	29		97	55			40				
29. Primary SIC Code (4 dig	its) 30. Secondary SIC	Code (4 digits) 31. Prima (5 or 6 digits			/ NAICS C	ode		Secondary NAICS Code 6 digits)				
4952												
33. What is the Primary Bus	siness of this entity? (Do not	repeat the SIC or NA	AICS des	scription.)								
Water/Sewer Utilities												
	17681 Telge Rd											
34. Mailing												
Address:	City Cypress	State	Тт		ZIP	77429		ZIP+	A RIE			
35. E-Mail Address:	Oity Syptose	State State	222	> 24	ZIF] PARES	EURALAS PAR	ZIFT	4 ROOM			
36. Telepho	ne Number	37. Extens	sion or	Code	38. Fax Number (if applicable)							
	574 - 5953	O7. Extend	31011 01	oodc	-	2012-2014) 647 - (
Ambient Ambien	Company September Septembe	(E3849.EQ	SACHISTON	SCHOOL S		***************************************	epideonia e	(A) - Englishmanian				
Form instructions for additional guid	Non-car							ed on this fo	orm. See t	he Core Data		
☐ Dam Safety	Districts	☐ Edwards	☐ Edwards Aquifer			Emissions Inventory Air			Industrial Hazardous Waste			
☐ Municipal Solid Waste	New Source Review Air	OSSF			Petroleum Storage Tank			☐ PWS				
Sludge	Storm Water	Title V Air	and surface solv.	VANAGING DEN	☐ Tires	3	and supplied the supplied to	☐ Used Oil				
☐ Voluntary Cleanup		☐Wastewater Agriculture			☐ Water Rights			Other:				
U Voluntary Cleanup	✓ Waste Water		si Agric	Juliure	vvale	r rigits		Other:				
SECTION IV: Preparer I	nformation											
40. Name: Jeff Goebel			_		41. Title:	Manager o	f Business	s Develop	ment			
42. Telephone Number	43. Ext./Code		45. E-Mail Address									
(713) 356 - 5347		()	間 - 福岡		igoebel@undinellc.com							
SECTION V: Authorize	ed Signature	(Bosell) terrie	ina manni	NAME OF TAXABLE PARTY.	13337		ALC CRESTALLS	2012-00-04-04-05-05-05-05-05-05-05-05-05-05-05-05-05-		PERCHASING NA		
By my signature below, I cert submit this form on behalf of the	ify, to the best of my knowledge	, that the information	on prov	ided in th	nis form is to	rue and comp	olete, and t	hat I have	signature	authority		
	exas Environmental		4411041	1		Sr. Vice Pre		Hold 00.		CAST TOTAL		
			Hall of the All		Marcolina and a second	The state of the s						
Name(In Print): Carey Thomas					Phone:	(713)57						
nature: (WCLL) (1. HOMA) Date: 3.20.2019												

ATTACHMENT

A2



A3



PATRONMENTAL OUT

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

Section 1. Permitted or Proposed Flows (Instructions Page 43)

A. Existing/Interim I Phase

Design Flow (MGD):

2-Hr Peak Flow (MGD): o.o8

Estimated construction start date: online

Estimated waste disposal start date: Click to enter text.

B. Interim II Phase

Design Flow (MGD): 0.15

2-Hr Peak Flow (MGD): 0.45

Estimated construction start date: 1/28

Estimated waste disposal start date: 11/28

C. Final Phase

Design Flow (MGD): <u>0.15</u>

2-Hr Peak Flow (MGD): 0.42

Estimated construction start date: 1/28

Estimated waste disposal start date: 11/28

D. Current Operating Phase

Provide the startup date of the facility: 2020

Section 2. Treatment Process (Instructions Page 43)

A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. If more than one phase exists or is proposed, a description of each phase must be provided. Attachment T-1

B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for all phases of operation.

Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Attachment T-1		
X		
J.		

C. Process Flow Diagram

Provide flow diagrams for the existing facilities and each proposed phase of construction.

Attachment: Attachment T-2

Site Information and Drawing (Instructions Page 44) Section 3.

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

Latitude: 32.607673

• Longitude: -97.926707

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

- Latitude: Click to enter text.
- Longitude: Click to enter text.

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment: <u>T-3</u>

Provide the name and a des	cription of the area	a served by the treatment	t facility.
Sugartree Subdivision			4
Collection System Informati			
each uniquely owned collection systems.	ction system, existi Please see the inst	ng and new, served by th	is facility, including
examples.	rease see the his	ructions for a actunea (explanation and
Collection System Informatio	n		
Collection System Name	Owner Name	Owner Type	Population Serve
Sugartree	U ndine	Privately Owned	
		Choose an item.	
and the state of t		Choose an item.	
		Choose an item.	
Section 4. Unbuilt P	hases (Instruc	tions Page 45)	
Is the application for a renev			se or phases?
☐ Yes ⊠ No	var or a perime tha	contains an ansam pin	oc or primoco.
If yes, does the existing peri	mit contain a nhase	that has not been const	ructed within five
years of being authorized by		that has not been const	racted within five
□ Yes ⊠ No			
f yes , provide a detailed dis	cussion regarding	the continued need for th	ne unbuilt phase.
Failure to provide sufficien	t justification may	result in the Executive	
recommending denial of the	e unbuilt phase or	phases.	
Click to enter text.			
			и
ection 5. Closure P	lans (Instructio	nc Dago 45)	Application Comment
lave any treatment units bee ut of service in the next five		nce permanently, or will	any units be taken
☐ Yes ⊠ No	,		
□ 1C3 ⊠ 110			

11	yes, was a closure plan submitted to the TCEQ!
	□ Yes ⊠ No
If	yes, provide a brief description of the closure and the date of plan approval.
	ection 6. Permit Specific Requirements (Instructions Page 45)
Pro	r applicants with an existing permit, check the Other Requirements or Special ovisions of the permit. Summary transmittal
A	Have plans and specifications been approved for the existing facilities and each proposed phase? Yes No
	If yes, provide the date(s) of approval for each phase: Click to enter text.
	Provide information, including dates, on any actions taken to meet a <i>requirement or provision</i> pertaining to the submission of a summary transmittal letter. Provide a copy of an approval letter from the TCEQ, if applicable.
	Click to enter text.
B.	Buffer zones
	Have the buffer zone requirements been met?
	⊠ Yes □ No
,	Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.
	Click to enter text.

	SI	oes the <i>Other Requirements</i> or <i>Special Provisions</i> section in the existing permit require ubmission of any other information or other required actions? Examples include otification of Completion, progress reports, soil monitoring data, etc.
		□ Yes ⊠ No
		yes, provide information below on the status of any actions taken to meet the onditions of an Other Requirement or Special Provision.
	(Click to enter text.
D.	G	rit and grease treatment
	1.	Acceptance of grit and grease waste
		Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?
		□ Yes ⊠ No
		If No, stop here and continue with Subsection E. Stormwater Management.
	2.	Grit and grease processing
		Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.
		Click to enter text.
	3.	Grit disposal
		Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?
		□ Yes ⊠ No
		If No, contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

C. Other actions required by the current permit

		Describe the method of grit disposal.
		Click to enter text.
	4.	Grease and decanted liquid disposal
		Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.
		Describe how the decant and grease are treated and disposed of after grit separation.
		Click to enter text.
E.	St	ormwater management
	1.	Applicability
		Does the facility have a design flow of 1.0 MGD or greater in any phase?
		□ Yes □ No
		Does the facility have an approved pretreatment program, under 40 CFR Part 403?
		□ Yes □ No
		If no to both of the above, then skip to Subsection F, Other Wastes Received.
	2.	MSGP coverage
		Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?
		□ Yes □ No
		If yes , please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:
		TXR05 <u>Click to enter text.</u> or TXRNE <u>Click to enter text.</u>
		If no, do you intend to seek coverage under TXR050000?
		□ Yes □ No
	3.	Conditional exclusion
		Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?
		□ Yes □ No

	If yes, please explain below then proceed to Subsection F, Other Wastes Received:					
	Click to enter text.					
4.	Existing coverage in individual permit					
	Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?					
	□ Yes □ No					
	If yes , provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.					
	Click to enter text.					
5.	Zero stormwater discharge					
	Do you intend to have no discharge of stormwater via use of evaporation or other means?					
	□ Yes □ No					
	If yes, explain below then skip to Subsection F. Other Wastes Received.					
	Click to enter text.					
	Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.					
6.	Request for coverage in individual permit					
	Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?					
	□ Yes ⊠ No					
	If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you					

		intend to divert stormwater to the treatment plant headworks and indirectly discharge it to water in the state.
		Click to enter text.
		Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.
F.	D	ischarges to the Lake Houston Watershed
	D	oes the facility discharge in the Lake Houston watershed?
		□ Yes ⊠ No
		yes, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions. ick to enter text.
G.	O	ther wastes received including sludge from other WWTPs and septic waste
	1.	Acceptance of sludge from other WWTPs
		Does or will the facility accept sludge from other treatment plants at the facility site?
		□ Yes ⊠ No
		If yes, attach sewage sludge solids management plan. See Example 5 of instructions.
		In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an
		estimate of the BOD_5 concentration of the sludge, and the design BOD_5 concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
		Click to enter text.
		Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	2.	Acceptance of septic waste
		Is the facility accepting or will it accept septic waste?
		□ Yes ⊠ No
		If yes, does the facility have a Type V processing unit?
		□ Yes ⊠ No
		If yes, does the unit have a Municipal Solid Waste permit?

If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD_5 concentration of the septic waste, and the
design BOD ₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
Click to enter text.
Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
3. Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)
Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?
□ Yes ⊠ No
If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.
Click to enter text.
Section 7. Pollutant Analysis of Treated Effluent (Instructions Page 50)
Is the facility in operation?
⊠ Yes □ No
If no, this section is not applicable. Proceed to Section 8.
If yes, provide effluent analysis data for the listed pollutants. <i>Wastewater treatment facilities</i> complete Table 1.0(2). <i>Water treatment facilities</i> discharging filter backwash water, complete Table 1.0(3). Provide copies of the laboratory results sheets. These tables are not applicable for a minor amendment without renewal. See the instructions for guidance.

Yes

No

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD ₅ , mg/l					
Total Suspended Solids, mg/l					
Ammonia Nitrogen, mg/l					
Nitrate Nitrogen, mg/l					
Total Kjeldahl Nitrogen, mg/l					
Sulfate, mg/l					
Chloride, mg/l					
Total Phosphorus, mg/l					
pH, standard units					
Dissolved Oxygen*, mg/l					
Chlorine Residual, mg/l					
E.coli (CFU/100ml) freshwater					
Entercocci (CFU/100ml) saltwater					
Total Dissolved Solids, mg/l					
Electrical Conductivity, µmohs/cm, †					
Oil & Grease, mg/l					
Alkalinity (CaCO ₃)*, mg/l					

^{*}TPDES permits only

Table 1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l					
Total Dissolved Solids, mg/l				Ú.	
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO ₃), mg/l					

Section 8. Facility Operator (Instructions Page 50)

Facility Operator Name: Contract operations

Facility Operator's License Classification and Level: **Contract operations**

Facility Operator's License Number: **Contract operations**

[†]TLAP permits only

Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 51)

A.	WW	TP's Biosonas Management Faculty Type
	Che	eck all that apply. See instructions for guidance
		Design flow>= 1 MGD
		Serves >= 10,000 people
		Class I Sludge Management Facility (per 40 CFR § 503.9)
		Biosolids generator
		Biosolids end user - land application (onsite)
		Biosolids end user - surface disposal (onsite)
		Biosolids end user – incinerator (onsite)
В.	ww	TP's Biosolids Treatment Process
	Che	ck all that apply. See instructions for guidance.
	\boxtimes	Aerobic Digestion
		Air Drying (or sludge drying beds)
		Lower Temperature Composting
		Lime Stabilization
		Higher Temperature Composting
		Heat Drying
		Thermophilic Aerobic Digestion
		Beta Ray Irradiation
		Gamma Ray Irradiation
		Pasteurization
		Preliminary Operation (e.g. grinding, de-gritting, blending)
		Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)
		Sludge Lagoon
		Temporary Storage (< 2 years)
		Long Term Storage (>= 2 years)
į		Methane or Biogas Recovery
İ		Other Treatment Process: Click to enter text.

C. Biosolids Management

Provide information on the *intended* biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the permit will authorize

all biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

Biosolids Management

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.

If "Other" is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): Click to enter text.

D.	Dis	posal	site
ν.	DIS	hosar	SILC

Disposal site name: Contract Sludge Hauler

TCEQ permit or registration number: Click to enter text.

County where disposal site is located: Click to enter text.

E. Transportation method

Method of transportation (truck, train, pipe, other): Contract Sludge Hauler

Name of the hauler: Click to enter text.

Hauler registration number: Click to enter text.

Sludge is transported as a:

Liquid \square semi-liquid \boxtimes semi-solid \square	solid □
---	---------

Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 53)

A. Beneficial use authorization

Does the existing permit include authorization for	land application	of sewage sludge for
beneficial use?		

□ Yes ⊠ No

If yes, are you requesting to continue this authorization to land apply sewage sludge for beneficial use?

□ Yes ⊠ No

If yes, is the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451) attached to this permit application (see the instructions for details)?

□ Yes ⊠ No

B. Slud	ge processing authorization							
Does the existing permit include authorization for any of the following sludge processing, storage or disposal options?								
Sl	ludge Composting		Yes		No			
M	arketing and Distribution of sludge		Yes		No			
Sl	udge Surface Disposal or Sludge Monofill		Yes		No			
Te	emporary storage in sludge lagoons		Yes		No			
autho	s to any of the above sludge options and the orization, is the completed Domestic Wastev nical Report (TCEQ Form No. 10056) attach Yes No	vate	r Permit	Appl	ication:	Sewage Sludge		
Section	n 11. Sewage Sludge Lagoons (Ins	truo	ctions	Page	e 53)			
Does this	s facility include sewage sludge lagoons?							
□ Y	∕es □ No							
If yes, co	mplete the remainder of this section. If no, p	proce	eed to Se	ection	12.			
A. Locat	ion information					*		
	ollowing maps are required to be submitted de the Attachment Number.	as pa	art of th	e app	lication.	For each map,		
	Original General Highway (County) Map:							
	Attachment: Click to enter text.							
•	USDA Natural Resources Conservation Service Soil Map:							
	Attachment: Click to enter text.							
•	Federal Emergency Management Map:							
	Attachment: Click to enter text.							
•	Site map:							
	Attachment: Click to enter text.							
Discus apply.	ss in a description if any of the following exi	st wi	ithin the	lago	on area.	Check all that		
	□ Overlap a designated 100-year frequency flood plain							
	Soils with flooding classification							
	Overlap an unstable area							
	Wetlands							
	Located less than 60 meters from a fault							
	None of the above							
Att	achment: Click to enter text.							

	the protective measures to be utilized including type and size of protective structures:					
	Click to enter text.					
В.	Temporary storage information					
	Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in <i>Section 7 of Technical Report 1.0.</i>					
	Nitrate Nitrogen, mg/kg: Click to enter text.					
	Total Kjeldahl Nitrogen, mg/kg: Click to enter text.					
	Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: Click to enter text.					
	Phosphorus, mg/kg: Click to enter text.					
	Potassium, mg/kg: Click to enter text.					
	pH, standard units: Click to enter text.					
	Ammonia Nitrogen mg/kg: Click to enter text.					
	Arsenic: Click to enter text.					
	Cadmium: Click to enter text.					
	Chromium: Click to enter text.					
	Copper: Click to enter text.					
	Lead: Click to enter text.					
	Mercury: Click to enter text.					
	Molybdenum: Click to enter text.					
	Nickel: Click to enter text.					
	Selenium: <u>Click to enter text.</u>					
	Zinc: Click to enter text.					
	Total PCBs: Click to enter text.					
	Provide the following information:					
	Volume and frequency of sludge to the lagoon(s): Click to enter text.					
	Total dry tons stored in the lagoons(s) per 365-day period: Click to enter text.					
	Total dry tons stored in the lagoons(s) over the life of the unit: <u>Click to enter text.</u>					
C.	Liner information					
	Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of $1x10^{-7}$ cm/sec?					
	□ Yes □ No					

C.

	If yes, describe the liner below. Please note that a liner is required.							
	Clic	k to enter text.						
D	D. Site development plan							
	Provi	de a detailed description of the methods used to deposit sludge in the lagoon(s):						
	Clic	k to enter text.						
		/ w						
		h the following documents to the application.						
	•	Plan view and cross-section of the sludge lagoon(s)						
		Attachment: Click to enter text.						
	•	Copy of the closure plan						
		Attachment: Click to enter text.						
	•	Copy of deed recordation for the site						
		Attachment: Click to enter text.						
	•	Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons						
		Attachment: Click to enter text.						
	•	Description of the method of controlling infiltration of groundwater and surface water from entering the site						
		Attachment: Click to enter text.						
	•	Procedures to prevent the occurrence of nuisance conditions						
		Attachment: Click to enter text.						
Ε.	Groun	ndwater monitoring						
	groun	undwater monitoring currently conducted at this site, or are any wells available for dwater monitoring, or are groundwater monitoring data otherwise available for the lagoon(s)?						
		Yes □ No						
	types	andwater monitoring data are available, provide a copy. Provide a profile of soil encountered down to the groundwater table and the depth to the shallowest dwater as a separate attachment.						
	Att	tachment: Click to enter text.						

E.

Section 12. Authorizations/Compliance/Enforcement (Instructions Page 55)

A.	Additi	ional a	auth	orizations	
				tee have additional authorizations for this facility, such as reuse ludge permit, etc?	
		Yes	\boxtimes	No	
	If yes,	provi	de tl	he TCEQ authorization number and description of the authorization:	
Cl	ick to e	enter t	ext.		a a
В.	Permit	tee er	ıforo	cement status	
	Is the p	permit	tee o	currently under enforcement for this facility?	
		Yes	\boxtimes	No	
	Is the penforce			required to meet an implementation schedule for compliance or	
		Yes	\boxtimes	No	
				uestion, provide a brief summary of the enforcement, the implement e current status:	ation
Cli	ck to e	nter te	ext.		
Sac	tion	12 I	O C D	RA/CERCLA Wastes (Instructions Page 55)	
JEC	UUII .	LO.	CI	My CLRCLA Wastes (Ilistructions Page 33)	X 200
F	las the	facilit azard	ty re	wastes eceived in the past three years, does it currently receive, or will it recewaste? No	eive

B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

□ Yes ⊠ No

C. Details about wastes received

If yes to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: Click to enter text.

Section 14. Laboratory Accreditation (Instructions Page 56)

All laboratory tests performed must meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - o periodically inspected by the TCEQ; or
 - o located in another state and is accredited or inspected by that state; or
 - o performing work for another company with a unit located in the same site; or
 - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Printed Name: Click to enter text.

Title: Click to enter text.

Signature:	
Date:	

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

Section 1.	Domestic Drinking	Water Supply	(Instructions	Page 64)

Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?
□ Yes □ No
If no , proceed it Section 2. If yes , provide the following:
Owner of the drinking water supply: <u>Click to enter text.</u>
Distance and direction to the intake: <u>Click to enter text.</u>
Attach a USGS map that identifies the location of the intake.
Attachment: Click to enter text.
Section 2. Discharge into Tidally Affected Waters (Instructions Page 64)
Does the facility discharge into tidally affected waters?
□ Yes ⊠ No
If no , proceed to Section 3. If yes , complete the remainder of this section. If no, proceed to Section 3.
A. Receiving water outfall
Width of the receiving water at the outfall, in feet: Click to enter text.
B. Oyster waters
Are there oyster waters in the vicinity of the discharge?
□ Yes □ No
If yes, provide the distance and direction from outfall(s).
Click to enter text.
C. Sea grasses
Are there any sea grasses within the vicinity of the point of discharge?
□ Yes □ No
If yes, provide the distance and direction from the outfall(s).
Click to enter text.

Section 5. Classified Segments (instructions Page 64)
Is the discharge directly into (or within 300 feet of) a classified segment?
□ Yes ⊠ No
If yes, this Worksheet is complete.
If no, complete Sections 4 and 5 of this Worksheet.
Section 4. Description of Immediate Receiving Waters (Instructions
Page 65)
Name of the immediate receiving waters: <u>Lake</u>
A. Receiving water type
Identify the appropriate description of the receiving waters.
Stream St
☐ Freshwater Swamp or Marsh
□ Lake or Pond
Surface area, in acres: <u>Click to enter text.</u>
Average depth of the entire water body, in feet: 15'
Average depth of water body within a 500-foot radius of discharge point, in feet
10'
☐ Man-made Channel or Ditch
□ Open Bay
□ Tidal Stream, Bayou, or Marsh
□ Other, specify: <u>Click to enter text.</u>
B. Flow characteristics
If a stream, man-made channel or ditch was checked above, provide the following. For
existing discharges, check one of the following that best characterizes the area <i>upstream</i> of the discharge. For new discharges, characterize the area <i>downstream</i> of the discharge
(check one).
☐ Intermittent - dry for at least one week during most years
☑ Intermittent with Perennial Pools - enduring pools with sufficient habitat to
maintain significant aquatic life uses
☐ Perennial - normally flowing
Check the method used to characterize the area upstream (or downstream for new dischargers).
□ USGS flow records
☐ Historical observation by adjacent landowners
□ Personal observation
□ Other, specify: Click to enter text.

	List the names of all perennial streams that join the receiving water within three miles downstream of the discharge point.						
	Brazos River						
D.	Down	stream characteristics					
		e receiving water characteristics ch arge (e.g., natural or man-made dar		within three miles downstream of the nds, reservoirs, etc.)?			
	\boxtimes	Yes □ No		4 0 ⊈			
	If yes	, discuss how.					
	Lake	to dry stream then to the Brazos River	•				
E.		al dry weather characteristics		1			
	Provide general observations of the water body during normal dry weather conditions. Click to enter text.						
	Chek to enter text.						
	Date and time of observation: <u>Click to enter text.</u>						
	Was th	ne water body influenced by storm	water	runoff during observations?			
		Yes □ No					
Se	Section 5. General Characteristics of the Waterbody (Instructions Page 66)						
A.	Upstre	eam influences					
		immediate receiving water upstreat aced by any of the following? Checl		he discharge or proposed discharge site nat apply.			
		Oil field activities		Urban runoff			
		Upstream discharges		Agricultural runoff			
	The second	Septic tanks		Other(s), specify: Click to enter text.			

C. Downstream perennial confluences

В.	waterbody uses						
	Observ	oserved or evidences of the following uses. Check all that apply.					
		Livestock watering		Contact recreation			
		Irrigation withdrawal		Non-contact recreation			
		Fishing		Navigation			
		Domestic water supply		Industrial water supply			
		Park activities	\boxtimes	Other(s), specify: Click to enter text.			
C.	Waterbody aesthetics						
	Check one of the following that best describes the aesthetics of the receiving water and the surrounding area.						
		Wilderness: outstanding natural beauty; usually wooded or unpastured area; wate clarity exceptional					
		Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored					
		Common Setting: not offensive; developed but uncluttered; water may be colored or turbid					
	Emile Control	Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored					

T1

Facility Dimensions & Facility Features

The facility will employ the complete mix variation of the activated sludge process designed for single stage nitrification - From the lift station the wastewater will travel through a coarse barscreen then to the complete mix basin; from the basin the mix-liquor will be transferred to the clarifier where solids will be settled out and clear water will flow over the weirs then into the chlorine contact basin. The settled solids will either be transferred to the digester or returned to the headworks.


Phase I							
<u>Unit</u> Clarifier	<u>Length</u>	Width 12' Diameter	Height 12'				
Chlorine Contact	300cuft						
Aeration	24'	12'	12'				
Digester	24'	12'	12'				
Phase II							
Unit	Length	Width	Height				
Clarifier		24' Diameter	12'				
	900						
Chlorine Contact	cuft						
Aeration	28'	12'	12'				
Digester	12'	12'	12'				
Digester		15' dia	12'				
Phase III							
Unit	Length	Width	Height				
Clarifier		24' Diameter	12'				
Chlorine Contact		900 cuft					
Aeration	28'	12'	12'				
Aeration	30'	12'	12'				
Digester	22'	12'	12'				
Digester	12'	12'	12'				
Digester		15' dia	12'				

- An Autodialer will be installed to detect power outages; equipment failure (i.e. clarifier drive and blowers). The Autodialer will incorporate high lever sensors on the wastewater treatment plant units as well as the effluent storage facility. Once a problem is detected the Autodialer will call preprogrammed numbers to notify the operator of the situation. Once this notification is answered, the operation company will dispatch an operator to the facility.
- Extended power outages are not anticipated. For short power outages the sewage will be contained in the collection system. Influent is from a triplex lift station which will not function during a general power outage. The plant features one digesters, chlorinator, and stand-by blowers. The collection system will be new, and minimum infiltration is anticipated. The plant is to be maintained and operated by personnel licensed by the State of Texas.
- The plant is designed to be maintained without bypassing. Replacement or repair of the interior coating system is the only maintenance item that would necessitate bypassing and the epoxy system should last 25-30 years.

Facility Dimensions & Facility Features

•	An intruder resistant fence will be placed around the facility.	
	i mi mant i constant remit i mi co piaced arcume me facility.	

T2



PHASE - 1 (38,000 GPD)

WASTEWATER TREATMENT PLANT

RES N.T.S.

RE 0.7 - 23 - 05 | March 10.7 | March 10.7 |


RES N.T.S. | March 10.7 | March 10.7 |


RES N.T.S. | March 10.7 |

RES SUGARTREE

AUC GROUP, L.P.

PHASE 1





PHASE - 3 (160,000 GPD)

WASTEWATER TREATMENT PLANT

SEE N.T.S.

STRONG N. JC

STRO

SUGARTREE

AUC GROUP, L.P.
PHASE 3

T3





T4
PENDING

T5

Jeff Goebel

To:

Jason Witte

Subject:

RE: Undine LLC (City of Fort Worth)

From: Pressley, Jeremy < Jeremy. Pressley@fortworthtexas.gov >

Sent: Wednesday, March 21, 2018 11:10 AM

To: Jason Witte < JWitte@taslp.com >

Subject: RE: Undine Environmental sludge hauling

Jason,

After speaking to my assistant director, he's requesting analytical data for BOD/TSS from each of these facilities before committing to accepting this waste long term.

Do you have analytical data from these sites?

If so, please forward the reports to me.

If not, please contact a 3rd party lab such as Pace or Armstrong and have them collect samples and run BOD/TSS and forward the information to me.

I understand this adds time to your project while your customers are waiting patiently.

So, in the meantime:

I am granting TAS Environmental Services authorization to transport sludge to the City of Fort Worth Waste Transfer Station at 3288 Yuma Drive.

This authorization extends for a period of one month from today's date ending on April 21st, 2018 – pending the results of the aforementioned analytical data.

After reviewing the analytical data, the City of Fort Worth will consider continuing to accept the waste on a regular basis.

Make sure your driver's mark the manifest waste type as "other" and write in either "sludge" or "package plant waste". I guarantee you the TCEQ will audit the manifests for these facilities and they consider it a transporter violation if you mark this type of waste as "septic" on the manifests.

If you have any questions or concerns, please feel free to contact me via email since I'll be in and out of the office while I recover.

Jeremy Pressley
Environmental Specialist
City of Fort Worth Water Department
Pretreatment Services Division
920 Fournier Street
Fort Worth, TX 76102
Office Phone: 817-392-8273

Office Phone: 817-392-8273 Cell Phone: 817-734-1177

City of Fort Worth — Working together to build a strong community.



Follow Fort Worth









How am I doing?

Please contact my supervisor at: Alphonse.Newton@fortworthtexas.gov

From: Jason Witte [mailto:JWitte@taslp.com]
Sent: Wednesday, March 21, 2018 8:51 AM

To: Pressley, Jeremy

Subject: Fwd: Undine Environmental sludge hauling

See addresses below sir.

Sent from my iPhone

Begin forwarded message:

From: Rickey Wallace < RWallace@UndineLLC.com>

Date: March 21, 2018 at 8:45:48 AM CDT **To:** Jason Witte < <u>JWitte@taslp.com</u>>

Subject: FW: Undine Environmental sludge hauling

Rickey Wallace Undine LLC Manager Due Diligence 979-229-9939 (cell) 713-574-7754 (Office)

From: Rickey Wallace

Sent: Tuesday, March 13, 2018 12:15 PM
To: 'jwitte@taslp.com' <jwitte@taslp.com'>
Subject: Undine Environmental sludge hauling

Jason,

Our 4 wastewater plants are

Mayfair 2773 Crowley Plover Rd. Crowley 76036

Grand Ranch 2620 Big Sky dr. Joshua 76058

Country Vista 329 Meadow Oaks Dr. Burleson 76028

Sugartree 141 Lakeside Dr. Lipan 76462

Rickey Wallace Undine LLC Manager Due Diligence 979-229-9939 (cell) 713-574-7754 (Office)

Rainee Trevino

From: Jeff Goebel <jgoebel@undinellc.com>
Sent: Thursday, February 27, 2025 8:58 AM

To: Erwin Madrid
Cc: Rainee Trevino
Subject: Re: WQ0014163001

Attachments: Sugartree SPIF.docx; Sugar Tree PLES Spanish.docx; Translated Nori.docx; Sugartree PLS

20972_PLS_2024-11-08.docx

Categories: NOD Response Review

Please see attachments for the response. The NORI is correct.

I also have the USGS map, but acrobat is not cooperating. I should have resolved by tomorrow

From: Erwin Madrid < Erwin. Madrid@tceq.texas.gov>

Sent: Tuesday, February 25, 2025 9:46 AM **To:** Jeff Goebel < jgoebel@undinellc.com>

Cc: Rainee Trevino < Rainee. Trevino@tceq.texas.gov>

Subject: RE: WQ0014163001

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Jeff,

Thank you for the update, and yes, please provide the response asap as this one is way past our deadlines and in risk of being referred to return.

Regards,

Erwin Madrid
Team Lead
ARP Team | Water Quality Division
512-239-2191
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail.

From: Jeff Goebel <jgoebel@undinellc.com> Sent: Tuesday, February 25, 2025 9:38 AM

To: Erwin Madrid < Erwin. Madrid@tceq.texas.gov>

Cc: Rainee Trevino < Rainee. Trevino@tceq.texas.gov>

Subject: Re: WQ0014163001

Erwin and Raine, I had some issues and plant to get this to you no later than friday.

Thank you for your patience.

Jeff Goebel

From: Jeff Goebel

Subject: Re: WQ0014163001

Thought I did,

I'll get it tomorrow

Thank you Jeff Goebel

Sent from my iPhone

On Feb 19, 2025, at 3:31 PM, Erwin Madrid < Erwin.Madrid@tceq.texas.gov wrote:

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hello Jeff,

Following up on this one, looks like we have not received a response, and this one is past due.

Can you please provide an update on submitting a completed response?

Regards,

Erwin Madrid
Team Lead
ARP Team | Water Quality Division
512-239-2191
Texas Commission on Environmental Quality
<image002.png>
Please consider whether it is necessary to print this e-mail.

Undine Texas Environmental, LLC ((CN604519330) opera la planta de tratamiento de aguas residuales Sugartree (RN101522464), una planta de procesamiento de lodos activados que funciona en el modo de mezcla completa. La instalación está ubicada a 1,700 pies al sur-suroeste del cruce del puente del río Brazos en FM 1189, en 10. Ingrese el nombre de la ciudad aquí, Parker County, Texas 76462. El solicitante solicita la renovación de un permiso de descarga de aguas residuales. << Para las solicitudes de TLAP, incluya la siguiente oración, de lo contrario, elimine:>> Este permiso no autorizará una descarga de contaminantes en el agua del estado. Se espera que las descargas de la instalación contengan una demanda bioquímica carbonosa de oxígeno (CBOD5) de cinco días, sólidos suspendidos totales (TSS), nitrógeno amoniacal (NH3-N) y Escherichia coli. Las aguas residuales domésticas son tratadas por una planta de procesamiento de lodos activados y las unidades de tratamiento incluirán una criba de barras, cuencas de aireación, clarificadores finales, digestores de lodos y cámaras de contacto con cloro.



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter 'INDUSTRIAL' or 'DOMESTIC' here WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Undine Texas Environmental, LLC ((CN604519330) operates Sugartree WWTP (RN101522464), a activated sludge process plant operated in the complete mix mode. The facility is located at 1,700 feet south-southwest of the Brazos River Bridge crossing on FM 1189, in 10. Enter city name here, Parker County, Texas 76462. The applicant is requesting a renewal of a wastewater discharge permit. << For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Domestic wastewater is treated by an activated sludge process plant and the treatment units will include a bar screen, aeration basins, final clarifiers, sludge digesters, and chlorine contact chambers.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

AGUAS RESIDUALES Introduzca 'INDUSTRIALES' o 'DOMÉSTICAS' aquí /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

1. Introduzca el nombre del solicitante aquí (2. Introduzca el número de cliente aquí (es decir, CN6#######).) 3. Elija del menú desplegable 4. Introduzca el nombre de la instalación aquí 5. Introduzca el número de entidad regulada aquí (es decir, RN1######), 6. Elija del menú desplegable 7. Introduzca la descripción de la instalación aquí. La instalación 8. Elija del menú desplegable. ubicada en 9. Introduzca la ubicación aquí, en 10. Introduzca el nombre de la ciudad aquí, Condado de 11. Introduzca el nombre del condado aquí, Texas 12. Introduzca el código postal aquí. 13. Introduzca el resumen de la petición de solicitud aquí. << Para las solicitudes de TLAP incluya la siguiente oración, de lo contrario, elimine:>> Este permiso no autorizará una descarga de contaminantes en el agua en el estado.

Se espera que las descargas de la instalación contengan 14. Liste todos los contaminantes esperados aquí. 15. Introduzca los tipos de aguas residuales descargadas aquí. 16. Elija del menú desplegable tratado por 17. Introduzca una descripción del tratamiento de aguas residuales utilizado en la instalación aquí.

INSTRUCTIONS

- 1. Enter the name of applicant in this section. The applicant name should match the name associated with the customer number.
- 2. Enter the Customer Number in this section. Each Individual or Organization is issued a unique 11-digit identification number called a CN (e.g. CN123456789).
- 3. Choose "operates" in this section for existing facility applications or choose "proposes to operate" for new facility applications.
- 4. Enter the name of the facility in this section. The facility name should match the name associated with the regulated entity number.
- 5. Enter the Regulated Entity number in this section. Each site location is issued a unique 11-digit identification number called an RN (e.g. RN123456789).
- 6. Choose the appropriate article (a or an) to complete the sentence.
- 7. Enter a description of the facility in this section. For example: steam electric generating facility, nitrogenous fertilizer manufacturing facility, etc.
- 8. Choose "is" for an existing facility or "will be" for a new facility.
- 9. Enter the location of the facility in this section.
- 10. Enter the City nearest the facility in this section.
- 11. Enter the County nearest the facility in this section.
- 12. Enter the zip code for the facility address in this section.
- 13. Enter a summary of the application request in this section. For example: renewal to discharge 25,000 gallons per day of treated domestic wastewater, new application to discharge process wastewater and stormwater on an intermittent and flow-variable basis, or major amendment to reduce monitoring frequency for pH, etc. If more than one outfall is included in the application, provide applicable information for each individual outfall.
- 14. List all pollutants expected in the discharge from this facility in this section. If applicable, refer to the pollutants from any federal numeric effluent limitations that apply to your facility.
- 15. Enter the discharge types from your facility in this section (e.g., stormwater, process wastewater, once through cooling water, etc.)
- 16. Choose the appropriate verb tense to complete the sentence.
- 17. Enter a description of the wastewater treatment used at your facility. Include a description of each process, starting with initial treatment and finishing with the outfall/point of disposal. Use additional lines for individual discharge types if necessary.

Questions or comments concerning this form may be directed to the Water Quality Division's Application Review and Processing Team by email at wq-ARPTeam@tceq.texas.gov or by phone at (512) 239-4671.

Example 1: Industrial Wastewater TPDES Application (ENGLISH)

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

ABC Corporation (CN600000000) operates the Starr Power Station (RN10000000000), a two-unit gas-fired electric generating facility. Unit 1 has a generating capacity of 393 megawatts (MWs) and Unit 2 has a generating capacity of 528 MWs. The facility is located at 1356 Starr Street, near the City of Austin, Travis County, Texas 78753.

This application is for a renewal to discharge 870,000,000 gallons per day of once through cooling water, auxiliary cooling water, and also authorizes the following waste streams monitored inside the facility (internal outfalls) before it is mixed with the other wastewaters authorized for discharge via main Outfall 001, referred to as "previously monitored effluents" (low-volume wastewater, metal-cleaning waste, and stormwater (from diked oil storage area yards and storm drains)) via Outfall 001. Low-volume waste sources, metal-cleaning waste, and stormwater drains on a continuous and flow-variable basis via internal Outfall 101.

The discharge of once through cooling water via Outfall 001 and low-volume waste and metal-cleaning waste via Outfall 101 from this facility is subject to federal effluent limitation guidelines at 40 CFR Part 423. The pollutants expected from these discharges based on 40 CFR Part 423 are: free available chlorine, total residual chlorine, total suspended solids, oil and grease, total iron, total copper, and pH. Temperature is also expected from these discharges. Additional potential pollutants are included in the Industrial Wastewater Application Technical Report, Worksheet 2.0.

Cooling water and boiler make-up water are supplied by Lake Starr Reservoir. The City of Austin municipal water plant (CN600000000, PWS 00000) supplies the facility's potable water and serves as an alternate source of boiler make-up water. Water from the Lake Starr Reservoir is withdrawn at the intake structure and treated with sodium hypochlorite to prevent biofouling and sodium bromide as a chlorine enhancer to improve efficacy and then passed through condensers and auxiliary equipment on a once-through basis to cool equipment and condense exhaust steam.

Low-volume wastewater from blowdown of boiler Units 1 and 2 and metal-cleaning wastes receive no treatment prior to discharge via Outfall 101. Plant floor and equipment drains and stormwater runoff from diked oil storage areas, yards, and storm drains are routed through an oil and water separator prior to discharge via Outfall 101. Domestic wastewater, blowdown, and backwash water from the service water filter, clarifier, and sand filter are routed to the Starr Creek Domestic Sewage Treatment Plant, TPDES Permit No. WQ0010000001, for treatment and disposal. Metal-cleaning waste from equipment cleaning is generally disposed of off-site.

Example 2: Domestic Wastewater TPDES Renewal application

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Texas (CN000000000) operates the City of Texas wastewater treatment plant (RN00000000), an activated sludge process plant operated in the complete mix mode. The facility is located at 123 Texas Street, near the City of More Texas, Texas County, Texas 71234.

This application is for a renewal to discharge at an annual average flow of 1,200,000 gallons per day of treated domestic wastewater via Outfalls 001 and 002.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Domestic wastewater is treated by an activated sludge process plant and the treatment units include a bar screen, a grit chamber, aeration basins, final clarifiers, sludge digesters, a belt filter press, chlorine contact chambers and a dechlorination chamber.

Example 3: Domestic Wastewater TPDES New Application

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Texas (CN000000000) proposes to operate the City of Texas wastewater treatment plant (RN00000000), an activated sludge process plant operated in the extended aeration mode. The facility will be located at 123 Texas Street, in the City of More Texas, Texas County, Texas 71234.

This application is for a new application to discharge at a daily average flow of 200,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater will be treated by an activated sludge process plant and the treatment units will include a bar screen, a grit chamber, aeration basins, final clarifiers, sludge digesters, a belt filter press, chlorine contact chambers and a dechlorination chamber.

Example 4: Domestic Wastewater TLAP Renewal application

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations

of the permit application.

The City of Texas (CN000000000) operates the City of Texas wastewater treatment plant (RN00000000), an activated sludge process plant operated in the complete mix mode. The facility is located at 123 Texas Street, near the City of More Texas, Texas County, Texas 71234.

This application is for a renewal to dispose a daily average flow not to exceed 76,500 gallons per day of treated domestic wastewater via public access subsurface drip irrigation system with a minimum area of 32 acres. This permit will not authorize a discharge of pollutants into water in the state.

Land application of domestic wastewater from the facility are expected to contain five-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater is treated by an activated sludge process plant and the treatment units include a bar screen, an equalization basin, an aeration basin, a final clarifier, an aerobic sludge digester, tertiary filters, and a chlorine contact chamber. In addition, the facility includes a temporary storage that equals to at least three days of the daily average flow.

APLICACIÓN. Undine Texas Environmental, LLC, 17681 Telge Road, Cypress, Texas 77429, ha solicitado a la Comisión de Calidad Ambiental de Texas (TCEQ) renovar el Permiso No. WQ0014163001 (N.º de identificación de la EPA TX0122271) autorizar la descarga de aguas residuales tratadas a un volumen que no exceda un flujo promedio diario de 150,000 galones por día. La instalación de tratamiento de aguas residuales domésticas está ubicada aproximadamente a 1,700 pies al sur-suroeste del cruce del puente del río Brazos en Farm-to-Market Road 1189, cerca de la ciudad de Weatherford, en el condado de Parker, Texas 76462. La ruta de descarga es desde el sitio de la planta hasta una serie de embalses en un afluente sin nombre, de allí al río Brazos debajo del lago Possum Kingdom. TCEQ recibió esta solicitud el 3 de diciembre de 2024. La solicitud de permiso estará disponible para ver y copiar en la Biblioteca Pública de Weatherford, Info Desk, 1014 Charles Street, Weatherford, en el condado de Parker, Texas, antes de la fecha en que se publique este aviso en el periódico. La solicitud, incluidas las actualizaciones, y los avisos asociados están disponibles electrónicamente en la siguiente página web: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. Este enlace a un mapa electrónico de la ubicación general del sitio o instalación se proporciona como una cortesía pública y no forma parte de la solicitud o aviso. Para conocer la ubicación exacta, consulte la aplicación. https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.927222,32.608055&level=18

También se puede obtener más información de Undine Texas Environmental, LLC en la dirección indicada anteriormente o llamando al Sr. Jeff Goebel, Desarrollo de Negocios, al 713-724-9321.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:	
Application type:RenewalMajor An	
County:	
Admin Complete Date:	_
Agency Receiving SPIF:	
Texas Historical Commission	U.S. Fish and Wildlife
Texas Parks and Wildlife Department	U.S. Army Corps of Engineers
This form applies to TPDES permit application	<u>us only.</u> (Instructions, Page 53)
	EQ will mail a copy to each agency as required by not completely addressed or further information formation before issuing the permit. Address
Do not refer to your response to any item in tattachment for this form separately from the Adapplication will not be declared administratively completed in its entirety including all attachmed may be directed to the Water Quality Division's email at WQ-ARPTeam@tceq.texas.gov or by phosphological series.	dministrative Report of the application. The y complete without this SPIF form being nts. Questions or comments concerning this form Application Review and Processing Team by
The following applies to all applications:	
1. Permittee: Undine Texas Environmental, LLC	
Permit No. WQ00	EPA ID No. TX
and county):	tion that includes street/highway, city/vicinity,
The Facility will is located 1,700 feet south-sout	hwest of the Brazos River Bridge crossing on FM 1189

answer specific questions about the property.
Prefix (Mr., Ms., Miss): <u>Mr</u>
First and Last Name: <u>Jeff Goebel</u>
Credential (P.E, P.G., Ph.D., etc.):
Title: Consultant
Mailing Address: 32002 Pattys Landing
City, State, Zip Code: <u>Magnolia TX 77354</u>
Phone No.: <u>713-724-9321</u> Ext.: Fax No.:
E-mail Address: <u>texaswater@sbcglobal.net</u>
List the county in which the facility is located: <u>Johnson</u>
If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.
The property is not publicly owned
Provide a description of the effluent discharge route. The discharge route must follow the flor of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.
From the wwtp to a series of ponds thence to the Brazos River
Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report).
Provide original photographs of any structures 50 years or older on the property.
Does your project involve any of the following? Check all that apply.
Proposed access roads, utility lines, construction easements
☐ Visual effects that could damage or detract from a historic property's integrity
□ Vibration effects during construction or as a result of project design
Additional phases of development that are planned for the future
☐ Sealing caves, fractures, sinkholes, other karst features

Provide the name, address, phone and fax number of an individual that can be contacted to

2.3.

4.

5.

	☐ Disturbance of vegetation or wetlands
1.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	None
2.	Describe existing disturbances, vegetation, and land use:
	WWTP
	HE FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR MENDMENTS TO TPDES PERMITS
3.	List construction dates of all buildings and structures on the property: Not known
4.	
	Not Known

Rainee Trevino

From: Jeff Goebel <jgoebel@undinellc.com>
Sent: Friday, February 28, 2025 1:12 PM

To: Rainee Trevino
Cc: Erwin Madrid
Subject: RE: WQ0014163001

Attachments: Sugar Tree PLES Spanish.docx; Sugartree SPIF.docx; Municipal Discharge Renewal

Spanish NORI.docx; Sugartree PLS 20972_PLS_2024-11-08.docx; Sugar Tree USGS

Map.pdf

Categories: NOD Response Review

The SPIF is missing the permit number and EPA ID number. The discharge route under item number 4 does not match the discharge route in the current permit. –

Please see revisions

The PLS both in English and Spanish are missing the final flow and the city. Also, be sure to remove the portion regarding TLAP applications only.

Please see revisions, however the facility is not located in a city, please advise.

The Spanish NORI will need to be translated using the template provided in the original NOD email and attached to this email.

See Attached

USGS Map is also Attached

From: Rainee Trevino <Rainee.Trevino@tceq.texas.gov>

Sent: Thursday, February 27, 2025 2:28 PM **To:** Jeff Goebel < igoebel@undinellc.com>

Cc: Erwin Madrid < Erwin. Madrid@tceq.texas.gov>

Subject: RE: WQ0014163001

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Awesome, thanks!

Rainee Trevino

Water Quality Division | ARP Team Texas Commission on Environmental Quality 512-239-4324



From: Jeff Goebel < <u>igoebel@undinellc.com</u>> Sent: Thursday, February 27, 2025 2:06 PM

To: Rainee Trevino < <u>Rainee.Trevino@tceq.texas.gov</u> > **Cc:** Erwin Madrid < <u>Erwin.Madrid@tceq.texas.gov</u> >

Subject: Re: WQ0014163001

I'll get the revisions to you tomorrow, and hopefully have the usgs pdf issues fixed.

Thank you Jeff Goebel

Sent from my iPhone

On Feb 27, 2025, at 1:55 PM, Rainee Trevino < Rainee. Trevino@tceq.texas.gov > wrote:

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Jeff.

I have reviewed the and some items need correction.

The SPIF is missing the permit number and EPA ID number. The discharge route under item number 4 does not match the discharge route in the current permit.

The PLS both in English and Spanish are missing the final flow and the city. Also, be sure to remove the portion regarding TLAP applications only.

The Spanish NORI will need to be translated using the template provided in the original NOD email and attached to this email.

Please let me know if you have any questions.

Regards,

Rainee Trevino

Water Quality Division | ARP Team Texas Commission on Environmental Quality 512-239-4324 <image001.png>

From: Rainee Trevino

Sent: Thursday, February 27, 2025 10:32 AM

To: Jeff Goebel < jgoebel@undinellc.com >; Erwin Madrid < Erwin Madrid@tceq.texas.gov>

Subject: RE: WQ0014163001

Thanks Jeff.

I will review this here shortly and get back to you if anything else is needed.

Regards,

Rainee Trevino

Water Quality Division | ARP Team Texas Commission on Environmental Quality 512-239-4324 <image001.png>

From: Jeff Goebel < <u>igoebel@undinellc.com</u>>
Sent: Thursday, February 27, 2025 8:58 AM

To: Erwin Madrid < Erwino Madrid@tceq.texas.gov Cc: Rainee Trevino@tceq.texas.gov >

Subject: Re: WQ0014163001

Please see attachments for the response. The NORI is correct.

I also have the USGS map, but acrobat is not cooperating. I should have resolved by tomorrow

From: Erwin Madrid < Erwin.Madrid@tceq.texas.gov>


Sent: Tuesday, February 25, 2025 9:46 AM **To:** Jeff Goebel < <u>igoebel@undinellc.com</u>>

Cc: Rainee Trevino < Rainee. Trevino@tceq.texas.gov>

Subject: RE: WQ0014163001

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Jeff,





TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter 'INDUSTRIAL' or 'DOMESTIC' here WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Undine Texas Environmental, LLC (CN604519330) operates Sugartree WWTP (RN101522464), a activated sludge process plant operated in the complete mix mode. The facility is located at 1,700 feet south-southwest of the Brazos River Bridge crossing on FM 1189, in 10. Enter city name here, Parker County, Texas 76462. The applicant is requesting a renewal of a 150,000 gallon per day wastewater discharge permit.

Discharges from the facility are expected to contain contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Domestic wastewater is treated by an activated sludge process plant and the treatment units will include a bar screen, aeration basins, final clarifiers, sludge digesters, and chlorine contact chambers.

Undine Texas Environmental, LLC (CN604519330) opera la planta de tratamiento de aguas residuales Sugartree (RN101522464), una planta de procesamiento de lodos activados que funciona en el modo de mezcla completa. La instalación está ubicada a 1,700 pies al sursuroeste del cruce del puente del río Brazos en FM 1189, en, condado de Parker, Texas 76462. El solicitante solicita la renovación de un permiso de descarga de aguas residuales de 150,000 galones por día.

Se espera que las descargas de la instalación contengan una demanda bioquímica carbonosa de oxígeno (CBOD5) de cinco días, sólidos suspendidos totales (TSS), nitrógeno amoniacal (NH3-N) y Escherichia coli. Las aguas residuales domésticas son tratadas por una planta de procesamiento de lodos activados y las unidades de tratamiento incluirán una criba de barras, cuencas de aireación, clarificadores finales, digestores de lodos y cámaras de contacto con cloro.

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO.	. WQoo

SOLICITUD. Undine Texas Environmental, LLC, 17681 Telge Road, Cypress, Texas 77429, ha solicitado a la Comisión de Calidad Ambiental de Texas (TCEQ) renovar el Permiso No. WQ0014163001 (N.º de identificación de la EPA TX0122271) autorizar la descarga de aguas residuales tratadas a un volumen que no exceda un flujo promedio diario de 150,000 galones por día. La instalación de tratamiento de aguas residuales domésticas está ubicada aproximadamente a 1,700 pies al sur-suroeste del cruce del puente del río Brazos en Farm-to-Market Road 1189, cerca de la ciudad de Weatherford, en el condado de Parker, Texas 76462. La ruta de descarga es desde el sitio de la planta hasta una serie de embalses en un afluente sin nombre, de allí al río Brazos debajo del lago Possum Kingdom. TCEQ recibió esta solicitud el 3 de diciembre de 2024. La solicitud de permiso estará disponible para ver y copiar en la Biblioteca Pública de Weatherford, Info Desk, 1014 Charles Street, Weatherford, en el condado de Parker, Texas, antes de la fecha en que se publique este aviso en el periódico. La solicitud, incluidas las actualizaciones, y los avisos asociados están disponibles electrónicamente en la siguiente página web: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. Este enlace a un mapa electrónico de la ubicación general del sitio o instalación se proporciona como una cortesía pública y no forma parte de la solicitud o aviso. Para conocer la ubicación exacta, consulte la aplicación.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.927222,32.608055&level=18

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca

de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general: una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas

correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía http://www14.tceq.texas.gov/epic/eComment/o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener más información de Undine Texas Environmental, LLC en la dirección indicada anteriormente o llamando al Sr. Jeff Goebel, Desarrollo de Negocios, al 713-724-9321.

Fecha de emission:

Wq001TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:	
·	ajor AmendmentNew
	Segment Number:
Admin Complete Date:	
Agency Receiving SPIF:	
Texas Historical Commission	U.S. Fish and Wildlife
Texas Parks and Wildlife Depart	ment U.S. Army Corps of Engineers
L	
This form applies to TPDES permit app	<u>lications only.</u> (Instructions, Page 53)
our agreement with EPA. If any of the ite	ent. TCEQ will mail a copy to each agency as required by ms are not completely addressed or further information the information before issuing the permit. Address
attachment for this form separately fron application will not be declared administ completed in its entirety including all at	em in the permit application form. Provide each in the Administrative Report of the application. The tratively complete without this SPIF form being tachments. Questions or comments concerning this form rision's Application Review and Processing Team by the phone at (512) 239-4671.
The following applies to all applications:	
1. Permittee: Undine Texas Environmental	l, LLC
Permit No. WQ00 <u>14163001</u>	EPA ID No. TX 0122271
and county):	description that includes street/highway, city/vicinity,
The Facility is located 1,700 feet south-s	southwest of the Brazos River Bridge crossing on FM 1189

	Provide the name, address, phone and fax number of an individual that can be contacted to answer specific questions about the property.	O
	Prefix (Mr., Ms., Miss): <u>Mr</u>	
	First and Last Name: <u>Jeff Goebel</u>	
	Credential (P.E, P.G., Ph.D., etc.):	
	Title: <u>Consultant</u>	
	Mailing Address: <u>32002 Pattys Landing</u>	
	City, State, Zip Code: <u>Magnolia TX 77354</u>	
	Phone No.: <u>713-724-9321</u> Ext.: Fax No.:	
	E-mail Address: <u>texaswater@sbcglobal.net</u>	
2.	List the county in which the facility is located: <u>Johnson</u>	
3.	If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.	
	The property is not publicly owned	
4.	Provide a description of the effluent discharge route. The discharge route must follow the floof effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identithe classified segment number.	
	To a series of impoundments on an unnamed tributary, thence to the Brazos River Below Possum Kingdon Lake in Segment no 1206 of the Brazos River Basin	
5.	Please provide a separate 7.5-minute USGS quadrangle map with the project boundaries plotted and a general location map showing the project area. Please highlight the discharge route from the point of discharge for a distance of one mile downstream. (This map is required in addition to the map in the administrative report).	e
	Provide original photographs of any structures 50 years or older on the property.	
	Does your project involve any of the following? Check all that apply.	
	☑ Proposed access roads, utility lines, construction easements	
	☐ Visual effects that could damage or detract from a historic property's integrity	
	☐ Vibration effects during construction or as a result of project design	
	Additional phases of development that are planned for the future	
	☐ Sealing caves, fractures, sinkholes, other karst features	

		Disturbance of vegetation or wetlands
1.		oposed construction impact (surface acres to be impacted, depth of excavation, sealing es, or other karst features):
	None	
0	D	
2.	WWT	oe existing disturbances, vegetation, and land use: <u>P</u>
		OWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR ENTS TO TPDES PERMITS
3.	List co	nstruction dates of all buildings and structures on the property:
	INOU K.	<u>nown</u>
4.	Provide	e a brief history of the property, and name of the architect/builder, if known.
	Not K	<u>nown</u>



TPDES PERMIT NO. WQ0014163001 [For TCEQ office use only - EPA I.D. No. TX0122271]

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY P.O. Box 13087 Austin, Texas 78711-3087

This is a renewal that replaces TPDES Permit No. WQ0014163001 issued on December 10, 2019.

PERMIT TO DISCHARGE WASTES

under provisions of Section 402 of the Clean Water Act and Chapter 26 of the Texas Water Code

Undine Texas Environmental LLC

whose mailing address is

17681 Telge Road Cypress, Texas 77429

is authorized to treat and discharge wastes from the Sugartree Wastewater Treatment Facility, SIC Code 4952

located approximately 1,700 feet south-southwest of the Brazos River bridge crossing on Farm-to-Market Road 1189, in Parker County, Texas 76462

to a series of impoundments on an unnamed tributary, thence to the Brazos River Below Possum Kingdom Lake in Segment No. 1206 of the Brazos River Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does not grant to the permittee the right to use private or public property for conveyance of wastewater along the discharge route described in this permit. This includes, but is not limited to, property belonging to any individual, partnership, corporation or other entity. Neither does this permit authorize any invasion of personal rights nor any violation of federal, state, or local laws or regulations. It is the responsibility of the permittee to acquire property rights as may be necessary to use the discharge route.

This permit shall expire at midnight, five years from the date of issuance.

ISSUED DATE:	
	For the Commission

INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the date of issuance and lasting through the completion of expansion to the 0.15 million gallons per day (MGD) facility, the permittee is authorized to discharge subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.080 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 167 gallons per minute.

Effluent Characteristic		Discharge Limitations				Min. Self-Monitoring Requirements	
	Daily Avg mg/l (lbs/day)	7-day Avg mg/l	Daily Max mg/l	Single Grab mg/l	Report Daily A Measurement Frequency	vg. & Max. Single Grab Sample Type	
Flow, MGD	Report	N/A	Report	N/A	Continuous	Totalizing Meter	
Carbonaceous Biochemical Oxygen Demand (5-day)	10 (6.7)	15	25	35	One/week	Grab	
Total Suspended Solids	15 (10)	25	40	60	One/week	Grab	
Ammonia Nitrogen	3 (2.0)	6	10	15	One/week	Grab	
Total Phosphorus	1 (0.67)	2	4	6	One/week	Grab	
E. coli, colony-forming units or most probable number per 100 ml	126	N/A	N/A	399	One/quarter	Grab	

- 2. The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes (based on peak flow), and shall be monitored five times per week by grab sample. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per month by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored once per week by grab sample.

FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the completion of expansion to the 0.15 million gallons per day (MGD) facility and lasting through the date of expiration, the permittee is authorized to discharge subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.15 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 312 gallons per minute.

Effluent Characteristic	Discharge Limitations			Min. Self-Monitoring Requirements		
	Daily Avg mg/l (lbs/day)	7-day Avg mg/l	Daily Max mg/l	Single Grab mg/l	Report Daily Av Measurement Frequency	g. & Max. Single Grab Sample Type
Flow, MGD	Report	N/A	Report	N/A	Continuous	Totalizing Meter
Carbonaceous Biochemical Oxygen Demand (5-day)	10 (13)	15	25	35	One/week	Grab
Total Suspended Solids	15 (19)	25	40	60	One/week	Grab
Ammonia Nitrogen	3 (3.8)	6	10	15	One/week	Grab
Total Phosphorus	1 (1.3)	2	4	6	One/week	Grab
<i>E. coli</i> , colony-forming units or most probable number per 100 ml	126	N/A	N/A	399	One/month	Grab

- 2. The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes (based on peak flow), and shall be monitored five times per week by grab sample. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per month by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored once per week by grab sample.

DEFINITIONS AND STANDARD PERMIT CONDITIONS

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC § 305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§ 5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§ 361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in TWC § 26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

1. Flow Measurements

- a. Annual average flow the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder and limited to major domestic wastewater discharge facilities with one million gallons per day or greater permitted flow.
- b. Daily average flow the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) the highest 2-hour peak flow for any 24-hour period in a calendar month.

2. Concentration Measurements

- a. Daily average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
 - i. For domestic wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.

- ii. For all other wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day.

The daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the daily discharge determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.

- e. Bacteria concentration (*E. coli* or Enterococci) Colony Forming Units (CFU) or Most Probable Number (MPN) of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the nth root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or, computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substituted value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
- f. Daily average loading (lbs/day) the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD x Concentration, mg/l x 8.34).
- g. Daily maximum loading (lbs/day) the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.

3. Sample Type

a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (b).

- b. Grab sample an individual sample collected in less than 15 minutes.
- 4. Treatment Facility (facility) wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation and/or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
- 5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
- 6. The term "biosolids" is defined as sewage sludge that has been tested or processed to meet Class A, Class AB, or Class B pathogen standards in 30 TAC Chapter 312 for beneficial use.
- 7. Bypass the intentional diversion of a waste stream from any portion of a treatment facility.

MONITORING AND REPORTING REQUIREMENTS

1. Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§ 319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Enforcement Division (MC 224), by the 20th day of the following month for each discharge which is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act (CWA); TWC §§ 26, 27, and 28; and THSC § 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§ 319.11 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC § 25, Environmental Testing Laboratory Accreditation and Certification.

3. Records of Results

a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.

- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge or biosolids use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR § 264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:
 - i. date, time and place of sample or measurement;
 - ii. identity of individual who collected the sample or made the measurement.
 - iii. date and time of analysis;
 - iv. identity of the individual and laboratory who performed the analysis;
 - v. the technique or method of analysis; and
 - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site and/or shall be readily available for review by a TCEQ representative for a period of three years.

6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the Regional Office and the Enforcement

Division (MC 224).

7. Noncompliance Notification

- a. In accordance with 30 TAC § 305.125(9) any noncompliance which may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Except as allowed by 30 TAC § 305.132, report of such information shall be provided orally or by facsimile transmission (FAX) to the Regional Office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the Regional Office and the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
- b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
 - i. Unauthorized discharges as defined in Permit Condition 2(g).
 - ii. Any unanticipated bypass that exceeds any effluent limitation in the permit.
 - iii. Violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
- c. In addition to the above, any effluent violation which deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the Regional Office and the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
- d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
- 8. In accordance with the procedures described in 30 TAC §§ 35.301 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
- 9. Changes in Discharges of Toxic Substances
 - All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the Regional Office, orally or by facsimile transmission within 24 hours, and both the Regional Office and the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. One hundred micrograms per liter (100 μ g/L);
 - ii. Two hundred micrograms per liter (200 μ g/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 μ g/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. The level established by the TCEQ.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. Five hundred micrograms per liter (500 μg/L);
 - ii. One milligram per liter (1 mg/L) for antimony;
 - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. The level established by the TCEO.

10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC § 305.128 (relating to Signatories to Reports).

- 11. All POTWs must provide adequate notice to the Executive Director of the following:
 - a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to CWA § 301 or § 306 if it were directly discharging those pollutants;
 - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and
 - c. For the purpose of this paragraph, adequate notice shall include information on:
 - i. The quality and quantity of effluent introduced into the POTW; and
 - ii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

PERMIT CONDITIONS

1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
 - i. Violation of any terms or conditions of this permit;
 - ii. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
 - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment, revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.
- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance

with 30 TAC §§ 305.62 and 305.66 and TWC§ 7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC § 305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility which does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under TWC §§ 7.051 7.075 (relating to Administrative Penalties), 7.101 7.111 (relating to Civil Penalties), and 7.141 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§ 301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA § 402, or any requirement imposed in a pretreatment program approved under the CWA §§ 402 (a)(3) or 402 (b)(8).

3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC § 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC § 7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

4. Permit Amendment and/or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC § 305.534 (relating to New Sources and New Dischargers); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
 - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes which are not described in the permit application or which would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC § 26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA § 307(a) for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or

prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA § 307(a) for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC § 305.64 (relating to Transfer of Permits) and 30 TAC § 50.133 (relating to Executive Director Action on Application or WQMP update).

6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to TWC Chapter 11.

8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

11. Notice of Bankruptcy

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
 - i. the permittee;
 - ii. an entity (as that term is defined in 11 USC, § 101(14)) controlling the permittee or listing the permit or permittee as property of the estate; or

- iii. an affiliate (as that term is defined in 11 USC, § 101(2)) of the permittee.
- b. This notification must indicate:
 - i. the name of the permittee;
 - ii. the permit number(s);
 - iii. the bankruptcy court in which the petition for bankruptcy was filed; and
 - iv. the date of filing of the petition.

OPERATIONAL REQUIREMENTS

- 1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
- 2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge or biosolids use and disposal and 30 TAC §§ 319.21 319.29 concerning the discharge of certain hazardous metals.
- 3. Domestic wastewater treatment facilities shall comply with the following provisions:
 - a. The permittee shall notify the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
 - b. The permittee shall submit a closure plan for review and approval to the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment and/or other treatment unit regulated by this permit.
- 4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, and/or retention of inadequately treated wastewater.
- 5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.

6. The permittee shall remit an annual water quality fee to the Commission as required by 30 TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC § 7.302(b)(6).

7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §§ 1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words confidential business information on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

- 8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
 - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion and/or upgrading of the domestic wastewater treatment and/or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment and/or collection facilities. In the case of a domestic wastewater treatment facility which reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been

secured.

- c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
- Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
- 10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
- 11. Facilities that generate industrial solid waste as defined in 30 TAC § 335.1 shall comply with these provisions:
 - a. Any solid waste, as defined in 30 TAC § 335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
 - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
 - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC § 335.8(b)(1), to the Corrective Action Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
 - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC § 335.5.

- e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well, container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.
- f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC § 335 and must include the following, as it pertains to wastewater treatment and discharge:
 - i. Volume of waste and date(s) generated from treatment process;
 - ii. Volume of waste disposed of on-site or shipped off-site;
 - iii. Date(s) of disposal;
 - iv. Identity of hauler or transporter;
 - v. Location of disposal site; and
 - vi. Method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC § 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC § 361.

TCEQ Revision 06/2020

SLUDGE PROVISIONS

The permittee is authorized to dispose of sludge or biosolids only at a Texas Commission on Environmental Quality (TCEQ) authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge. The disposal of sludge or biosolids by land application on property owned, leased or under the direct control of the permittee is a violation of the permit unless the site is authorized with the TCEQ. This provision does not authorize Distribution and Marketing of Class A or Class AB Biosolids. This provision does not authorize the permittee to land apply biosolids on property owned, leased or under the direct control of the permittee.

SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS LAND APPLICATION

A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge or biosolids.
- 2. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
- 3. The land application of processed or unprocessed chemical toilet waste, grease trap waste, grit trap waste, milk solids, or similar non-hazardous municipal or industrial solid wastes, or any of the wastes listed in this provision combined with biosolids, WTP residuals or domestic septage is prohibited unless the grease trap waste is added at a fats, oil and grease (FOG) receiving facility as part of an anaerobic digestion process.

B. Testing Requirements

1. Sewage sludge or biosolids shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other method that receives the prior approval of the TCEQ for the contaminants listed in 40 CFR Part 261.24, Table 1. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal. Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 4) within seven (7) days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P.O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. The permittee must submit this annual report by September 30th of each year using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 4) and the Enforcement Division (MC 224).

2. Biosolids shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Section I.C. of this permit.

TABLE 1

<u>Pollutant</u>	Ceiling Concentration
	(Milligrams per kilogram)*
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

^{*} Dry weight basis

3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site must be treated by one of the following methods to ensure that the sludge meets either the Class A, Class AB or Class B biosolids pathogen requirements.

a. For sewage sludge to be classified as Class A biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 most probable number (MPN) per gram of total solids (dry weight basis), or the density of Salmonella sp. bacteria in the sewage sludge must be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

Alternative 1 - The temperature of the sewage sludge that is used or disposed shall be maintained at or above a specific value for a period of time. See 30 TAC § 312.82(a)(3)(A) for specific information;

Alternative 5 (PFRP) - Sewage sludge that is used or disposed of must be treated in one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR Part 503, Appendix B. PFRP include composting, heat drying, heat treatment, and thermophilic aerobic digestion; or

Alternative 6 (PFRP Equivalent) - Sewage sludge that is used or disposed of must be treated in a process that has been approved by the U. S. Environmental Protection Agency as being equivalent to those in Alternative 5.

b. For sewage sludge to be classified as Class AB biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 MPN per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 2</u> - The pH of the sewage sludge that is used or disposed shall be raised to above 12 std. units and shall remain above 12 std. units for 72 hours.

The temperature of the sewage sludge shall be above 52° Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12 std. units.

At the end of the 72-hour period during which the pH of the sewage sludge is above 12 std. units, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50%; or

<u>Alternative 3</u> - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is less than one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC \S 312.82(a)(2)(C)(i-iii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC \S 312.82(a)(2)(C)(iv-vi) for specific information; or

<u>Alternative 4</u> - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed.

- c. Sewage sludge that meets the requirements of Class AB biosolids may be classified a Class A biosolids if a variance request is submitted in writing that is supported by substantial documentation demonstrating equivalent methods for reducing odors and written approval is granted by the executive director. The executive director may deny the variance request or revoke that approved variance if it is determined that the variance may potentially endanger human health or the environment, or create nuisance odor conditions.
- d. Three alternatives are available to demonstrate compliance with Class B biosolids criteria.

Alternative 1

- i. A minimum of seven random samples of the sewage sludge shall be collected within 48 hours of the time the sewage sludge is used or disposed of during each monitoring episode for the sewage sludge.
- ii. The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

<u>Alternative 2</u> - Sewage sludge that is used or disposed of shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR Part 503, Appendix B, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. An independent Texas Licensed Professional Engineer must make a certification to the generator of a sewage sludge that the wastewater treatment facility generating the sewage sludge is designed to achieve one of the PSRP at the permitted design loading of the facility. The certification need only be repeated if the design loading of the facility is increased. The certification shall include a statement indicating the design meets all the applicable standards specified in Appendix B of 40 CFR Part 503;
- iii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iv. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review; and
- v. If the sewage sludge is generated from a mixture of sources, resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the PSRP, and shall meet the certification, operation, and record keeping requirements of this paragraph.

<u>Alternative 3</u> - Sewage sludge shall be treated in an equivalent process that has been approved by the U.S. Environmental Protection Agency, so long as all of the following requirements are met by the generator of the sewage sludge.

i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;

- ii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iii. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review;
- iv. The Executive Director will accept from the U.S. Environmental Protection Agency a finding of equivalency to the defined PSRP; and
- v. If the sewage sludge is generated from a mixture of sources resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the Processes to Significantly Reduce Pathogens, and shall meet the certification, operation, and record keeping requirements of this paragraph.

In addition to the Alternatives 1 - 3, the following site restrictions must be met if Class B biosolids are land applied:

- i. Food crops with harvested parts that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
- v. Domestic livestock shall not be allowed to graze on the land for 30 days after application of biosolids.
- vi. Turf grown on land where biosolids are applied shall not be harvested for 1 year after application of the biosolids when the harvested turf is placed on either land with a high potential for public exposure or a lawn.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of biosolids.
- viii. Public access to land with a low potential for public exposure shall be restricted

for 30 days after application of biosolids.

ix. Land application of biosolids shall be in accordance with the buffer zone requirements found in 30 TAC § 312.44.

4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following Alternatives 1 through 10 for vector attraction reduction.

- <u>Alternative 1</u> The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38%.
- Alternative 2 If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30° and 37° Celsius. Volatile solids must be reduced by less than 17% to demonstrate compliance.
- Alternative 3 If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20° Celsius. Volatile solids must be reduced by less than 15% to demonstrate compliance.
- Alternative 4 The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20° Celsius.
- Alternative 5 Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40° Celsius and the average temperature of the sewage sludge shall be higher than 45° Celsius.
- Alternative 6 The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali shall remain at 12 or higher for two hours and then remain at a pH of 11.5 or higher for an additional 22 hours at the time the sewage sludge is prepared for sale or given away in a bag or other container.
- Alternative 7 The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75% based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.
- <u>Alternative 8</u> The percent solids of sewage sludge that contains unstabilized solids

generated in a primary wastewater treatment process shall be equal to or greater than 90% based on the moisture content and total solids prior to mixing with other materials at the time the sludge is used. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

Alternative 9 -

- i. Biosolids shall be injected below the surface of the land.
- ii. No significant amount of the biosolids shall be present on the land surface within one hour after biosolids are injected.
- iii. When sewage sludge that is injected below the surface of the land is Class A or Class AB with respect to pathogens, the biosolids shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.

Alternative 10-

- i. Biosolids applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
- ii. When biosolids that are incorporated into the soil is Class A or Class AB with respect to pathogens, the biosolids shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

C. Monitoring Requirements

Toxicity Characteristic Leaching Procedure
(TCLP) Test
PCBs
- once during the term of this permit
- once during the term of this permit

All metal constituents and fecal coliform or *Salmonella* sp. bacteria shall be monitored at the appropriate frequency shown below, pursuant to 30 TAC § 312.46(a)(1):

Amount of biosolids (*)

metric tons per 365-day period Monitoring Frequency

o to less than 290 Once/Year

290 to less than 1,500 Once/Quarter

1,500 to less than 15,000 Once/Two Months

15,000 or greater Once/Month

(*) The amount of bulk biosolids applied to the land (dry wt. basis).

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 30 TAC § 312.7

Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal

coliforms, helminth ova, Salmonella sp., and other regulated parameters.

Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.

Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge or biosolids for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.

SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE FOR APPLICATION TO THE LAND MEETING CLASS A, CLASS AB or B BIOSOLIDS PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A, Class AB or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below listed in Table 3, the following conditions apply:

A. Pollutant Limits

Table 2

	Cumulative Pollutant Loading Rate
<u>Pollutant</u>	(pounds per acre)*
Arsenic	36
Cadmium	35
Chromium	2677
Copper	1339
Lead	268
Mercury	15
Molybdenum	Report Only
Nickel	375
Selenium	89
Zinc	2500

Table 3

	Monthly Average
	Concentration
<u>Pollutant</u>	(milligrams per kilogram)*
Arsenic	41
Cadmium	39
Chromium	1200
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report Only
Nickel	420
Selenium	36
Zinc	2800

^{*}Dry weight basis

B. Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, shall be treated by either Class A, Class AB or Class B biosolids pathogen reduction requirements as defined above in Section I.B.3.

C. Management Practices

- 1. Bulk biosolids shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk biosolids enters a wetland or other waters in the State.
- 2. Bulk biosolids not meeting Class A biosolids requirements shall be land applied in a manner which complies with Applicability in accordance with 30 TAC §312.41 and the Management Requirements in accordance with 30 TAC § 312.44.
- 3. Bulk biosolids shall be applied at or below the agronomic rate of the cover crop.
- 4. An information sheet shall be provided to the person who receives bulk Class A or AB biosolids sold or given away. The information sheet shall contain the following information:
 - a. The name and address of the person who prepared the Class A or AB biosolids that are sold or given away in a bag or other container for application to the land.
 - b. A statement that application of the biosolids to the land is prohibited except in accordance with the instruction on the label or information sheet.
 - c. The annual whole sludge application rate for the biosolids application rate for the biosolids that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Section II above are met.

D. Notification Requirements

- 1. If bulk biosolids are applied to land in a State other than Texas, written notice shall be provided prior to the initial land application to the permitting authority for the State in which the bulk biosolids are proposed to be applied. The notice shall include:
 - a. The location, by street address, and specific latitude and longitude, of each land application site.
 - b. The approximate time period bulk biosolids will be applied to the site.
 - c. The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk biosolids.

E. Record Keeping Requirements

The documents will be retained at the facility site and/or shall be readily available for review by a TCEQ representative. The person who prepares bulk sewage sludge or a biosolids material shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative for a period of <u>five years</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply.

- 1. The concentration (mg/kg) in the sludge of each pollutant listed in Table 3 above and the applicable pollutant concentration criteria (mg/kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (lbs/ac) listed in Table 2 above.
- 2. A description of how the pathogen reduction requirements are met (including site restrictions for Class AB and Class B biosolids, if applicable).
- 3. A description of how the vector attraction reduction requirements are met.
- 4. A description of how the management practices listed above in Section II.C are being met.
- 5. The following certification statement:
 - "I certify, under penalty of law, that the applicable pathogen requirements in 30 TAC § 312.82(a) or (b) and the vector attraction reduction requirements in 30 TAC § 312.83(b) have been met for each site on which bulk biosolids are applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."
- 6. The recommended agronomic loading rate from the references listed in Section II.C.3. above, as well as the actual agronomic loading rate shall be retained. The person who applies bulk biosolids shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative <u>indefinitely</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply:
 - a. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii), as applicable, and to the permittee's specific sludge treatment activities.
 - b. The location, by street address, and specific latitude and longitude, of each site on which biosolids are applied.
 - c. The number of acres in each site on which bulk biosolids are applied.
 - d. The date and time biosolids are applied to each site.

- e. The cumulative amount of each pollutant in pounds/acre listed in Table 2 applied to each site.
- f. The total amount of biosolids applied to each site in dry tons.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

F. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 4) and Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.
- 3. Results of tests performed for pollutants found in either Table 2 or 3 as appropriate for the permittee's land application practices.
- 4. The frequency of monitoring listed in Section I.C. that applies to the permittee.
- 5. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 6. PCB concentration in sludge or biosolids in mg/kg.
- 7. Identity of hauler(s) and TCEQ transporter number.
- 8. Date(s) of transport.
- 9. Texas Commission on Environmental Quality registration number, if applicable.
- 10. Amount of sludge or biosolids disposal dry weight (lbs/acre) at each disposal site.
- 11. The concentration (mg/kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/kg) listed in Table 3 above, or the applicable pollutant loading rate limit (lbs/acre) listed in Table 2 above if it exceeds 90% of the limit.
- 12. Level of pathogen reduction achieved (Class A, Class AB or Class B).
- 13. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B biosolids, include information on how site restrictions were met.

- 14. Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.
- 15. Vector attraction reduction alternative used as listed in Section I.B.4.
- 16. Amount of sludge or biosolids transported in dry tons/year.
- 17. The certification statement listed in either 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii) as applicable to the permittee's sludge or biosolids treatment activities, shall be attached to the annual reporting form.
- 18. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the annual reporting form.
 - a. The location, by street address, and specific latitude and longitude.
 - b. The number of acres in each site on which bulk biosolids are applied.
 - c. The date and time bulk biosolids are applied to each site.
 - d. The cumulative amount of each pollutant (i.e., pounds/acre) listed in Table 2 in the bulk biosolids applied to each site.
 - e. The amount of biosolids (i.e., dry tons) applied to each site.

The above records shall be maintained on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

SECTION III. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL

- A. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 330 and all other applicable state and federal regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge or biosolids meets the requirements in 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- B. If the permittee generates sewage sludge or biosolids and supplies that sewage sludge or biosolids to the owner or operator of a municipal solid waste landfill (MSWLF) for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
- C. Sewage sludge or biosolids shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I (Toxicity Characteristic Leaching Procedure) or other method, which receives the prior approval of the TCEQ for contaminants listed in Table 1 of 40 CFR § 261.24. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal.

Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 4) of the appropriate TCEQ field office within 7 days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P. O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 4) and the Enforcement Division (MC 224) by September 30 of each year.

- D. Sewage sludge or biosolids shall be tested as needed, in accordance with the requirements of 30 TAC Chapter 330.
- E. Record Keeping Requirements

The permittee shall develop the following information and shall retain the information for five years.

- 1. The description (including procedures followed and the results) of all liquid Paint Filter Tests performed.
- 2. The description (including procedures followed and results) of all TCLP tests performed.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

F. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 4) and Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 3. Annual sludge or biosolids production in dry tons/year.
- 4. Amount of sludge or biosolids disposed in a municipal solid waste landfill in dry tons/year.
- 5. Amount of sludge or biosolids transported interstate in dry tons/year.
- 6. A certification that the sewage sludge or biosolids meets the requirements of 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- 7. Identity of hauler(s) and transporter registration number.
- 8. Owner of disposal site(s).
- 9. Location of disposal site(s).
- 10. Date(s) of disposal.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

SECTION IV. REQUIREMENTS APPLYING TO SLUDGE OR BIOSOLIDS TRANSPORTED TO ANOTHER FACILITY FOR FURTHER PROCESSING

These provisions apply to sludge or biosolids that is transported to another wastewater treatment facility or facility that further processes sludge or biosolids. These provisions are intended to allow transport of sludge or biosolids to facilities that have been authorized to accept sludge or biosolids. These provisions do not limit the ability of the receiving facility to determine whether to accept the sludge or biosolids, nor do they limit the ability of the receiving facility to request additional testing or documentation.

A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC Chapter 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
- 2. Sludge or biosolids may only be transported using a registered transporter or using an approved pipeline.

B. Record Keeping Requirements

- 1. For sludge or biosolids transported by an approved pipeline, the permittee must maintain records of the following:
 - a. the amount of sludge or biosolids transported;
 - b. the date of transport;
 - c. the name and TCEQ permit number of the receiving facility or facilities;
 - d. the location of the receiving facility or facilities;
 - e. the name and TCEQ permit number of the facility that generated the waste; and
 - f. copy of the written agreement between the permittee and the receiving facility to accept sludge or biosolids.
- 2. For sludge or biosolids transported by a registered transporter, the permittee must maintain records of the completed trip tickets in accordance with 30 TAC § 312.145(a)(1)-(7) and amount of sludge or biosolids transported.
- 3. The above records shall be maintained on-site on a monthly basis and shall be made available to the TCEQ upon request. These records shall be retained for at least five years.

C. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 4) and Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. the annual sludge or biosolids production;
- 3. the amount of sludge or biosolids transported;
- 4. the owner of each receiving facility;
- 5. the location of each receiving facility; and
- 6. the date(s) of disposal at each receiving facility.

TCEQ Revision 06/2020

OTHER REQUIREMENTS

- 1. The permittee shall employ or contract with one or more licensed wastewater treatment facility operators or wastewater system operations companies holding a valid license or registration according to the requirements of 30 TAC Chapter 30, Occupational Licenses and Registrations, and in particular 30 TAC Chapter 30, Subchapter J, Wastewater Operators and Operations Companies.
 - This Category C facility must be operated by a chief operator or an operator holding a Class C license or higher. The facility must be operated a minimum of five days per week by the licensed chief operator or an operator holding the required level of license or higher. The licensed chief operator or operator holding the required level of license or higher must be available by telephone or pager seven days per week. Where shift operation of the wastewater treatment facility is necessary, each shift which does not have the on-site supervision of the licensed chief operator must be supervised by an operator in charge who is licensed not less than one level below the category for the facility.
- 2. The facility is not located in the Coastal Management Program boundary.
- 3. The permittee shall comply with the requirements of 30 TAC § 309.13(a) through (d). In addition, by ownership of the required buffer zone area, the permittee shall comply with the requirements of 30 TAC § 309.13(e).
- 4. The permittee shall provide facilities for the protection of its wastewater treatment facility from a 100-year flood.
- In accordance with 30 TAC § 319.9, a permittee that has at least twelve months of uninterrupted compliance with its bacteria limit may notify the commission in writing of its compliance and request a less frequent measurement schedule. To request a less frequent schedule, the permittee shall submit a written request to the TCEQ Wastewater Permitting Section (MC 148) for each phase that includes a different monitoring frequency. The request must contain all of the reported bacteria values (Daily Avg. and Daily Max/Single Grab) for the twelve consecutive months immediately prior to the request. If the Executive Director finds that a less frequent measurement schedule is protective of human health and the environment, the permittee may be given a less frequent measurement schedule. For this permit, one/quarter may be reduced to one/six months in the Interim II phase and one/month may be reduced to one/quarter in the Final phase. A violation of any bacteria limit by a facility that has been granted a less frequent measurement schedule will require the permittee to return to the standard frequency schedule and submit written notice to the TCEQ Wastewater Permitting Section (MC 148). The permittee may not apply for another reduction in measurement frequency for at least 24 months from the date of the last violation. The Executive Director may establish a more frequent measurement schedule if necessary to protect human health or the environment.
- 6. Prior to construction of the 0.15 MGD treatment facility, the permittee shall submit to the TCEQ Wastewater Permitting Section (MC 148) a summary transmittal letter in accordance with the requirements in 30 TAC § 217.6(d). If requested by the Wastewater Permitting Section, the permittee shall submit plans, specifications, and a final engineering design report which comply with 30 TAC Chapter 217, Design Criteria for Domestic Wastewater Systems. The permittee shall clearly show how the treatment system will meet the effluent

limitations required on Page 2a of this permit. A copy of the summary transmittal letter shall be available at the plant site for inspection by authorized representatives of the TCEQ.

Plans and specifications have been approved for the 0.80 MGD wastewater treatment facility, in accordance with 30 TAC § 217, Design Criteria for Domestic Wastewater Systems. A summary transmittal approval letter was issued August 9, 2019 (Log No. 0819/025). A copy of the summary transmittal letter shall be available at the plant site for inspection by authorized representatives of the TCEQ.

7. The permittee shall notify the TCEQ Regional Office (MC Region 4) and the Applications Review and Processing Team (MC 148) of the Water Quality Division, in writing at least forty-five days prior to the completion of the 0.15 MGD facility on Notification of Completion Form 20007.

STATEMENT OF BASIS/TECHNICAL SUMMARY AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

DESCRIPTION OF APPLICATION

Applicant: Undine Texas Environmental LLC

Texas Pollutant Discharge Elimination System (TPDES) Permit

No. WQ0014163001, EPA ID No. TX0122271

Regulated Activity: Domestic Wastewater Permit

Type of Application: Renewal

Request: Renewal with no changes

Authority: Federal Clean Water Act (CWA) § 402; Texas Water Code (TWC)

§ 26.027; 30 Texas Administrative Code (TAC) Chapters 30, 305, 307, 309, 312, and 319; Commission policies; and United States Environmental Protection Agency (EPA) guidelines.

EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **five years from the date of issuance**.

REASON FOR PROJECT PROPOSED

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for a renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.080 million gallons per day (MGD) in the Interim phase and a daily average flow not to exceed 0.15 MGD in the Final phase. The existing wastewater treatment facility serves the Sugartree Subdivision.

PROJECT DESCRIPTION AND LOCATION

The Sugartree Wastewater Treatment Facility is an activated sludge process plant operated in the complete mix mode. Treatments units in the Interim phase include a bar screen, an aeration basin, a final clarifier, two sludge digesters, and a chlorine contact chamber. Treatment units in the final phase include a bar screen, two aeration basins, a final clarifier, three sludge digesters, and a chlorine contact chamber. The facility is operating in the Interim phase.

The draft permit authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, or wastewater treatment facility, or facility that further processes sludge.

The plant site is located approximately 1,700 feet south-southwest of the Brazos River bridge crossing on Farm-to-Market Road 1189, in Parker County, Texas 76462.

Undine Texas Environmental LLC TPDES Permit No. WQoo14163001 Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

Outfall Location:

Outfall Number	Latitude	Longitude	
001	32.607673 N	97.926707 W	

The treated effluent is discharged to a series of impoundments on an unnamed tributary, thence to the Brazos River Below Possum Kingdom Lake in Segment No. 1206 of the Brazos River Basin. The unclassified receiving water use is limited aquatic life use for the unnamed tributary. The designated uses for Segment No. 1206 are primary contact recreation and high aquatic life use. The effluent limitations in the draft permit will maintain and protect the existing instream uses. All determinations are preliminary and subject to additional review and/or revisions.

Effluent limitations for the conventional effluent parameters (i.e., Five-Day Biochemical Oxygen Demand or Five-Day Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water-quality limited streams as established in the Texas Surface Water Quality Standards (TSWQS) and the State of Texas Water Quality Management Plan (WQMP).

In a case such as this, end-of-pipe compliance with pH limits between 6.0 and 9.0 standard units reasonably assures instream compliance with the TSWQS for pH when the discharge authorized is from a minor facility. This technology-based approach reasonably assures instream compliance with TSWQS criteria due to the relatively smaller discharge volumes authorized by these permits. This conservative assumption is based on TCEQ sampling conducted throughout the state which indicates that instream buffering quickly restores pH levels to ambient conditions. Similarly, this approach has been historically applied within EPA issued NPDES general permits where technology-based pH limits were established to be protective of water quality criteria.

The existing effluent limits have been reviewed for consistency with the State of Texas Water Quality Management Plan (WQMP). The existing limits are consistent with the approved WQMP.

The discharge from this permit action is not expected to have an effect on any federal endangered or threatened aquatic or aquatic-dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS's) biological opinion on the State of Texas authorization of the TPDES (September 14, 1998; October 21, 1998, update). To make this determination for TPDES permits, TCEQ and EPA only considered aquatic or aquatic-dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Segment 1206 is not currently listed on the State's inventory of impaired and threatened waters (the 2024 Clean Water Act Section 303(d) list).

Undine Texas Environmental LLC TPDES Permit No. WQ0014163001 Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

SUMMARY OF EFFLUENT DATA

The following is a summary of the applicant's effluent monitoring data for the period February 2023 through February 2025. The average of Daily Average value is computed by the averaging of all 30-day average values for the reporting period for each parameter: flow, five-day carbonaceous biochemical oxygen demand ($CBOD_5$), total suspended solids (TSS), ammonia nitrogen (NH_3 -N), and total phosphorus (TP). The average of Daily Average value for *Escherichia coli* (E. coli) in colony-forming units (CFU) or most probable number (MPN) per 100 ml is calculated via geometric mean.

<u>Parameter</u>	<u>Average of Daily Average</u>
Flow, MGD	0.018
CBOD ₅ , mg/l	2.4
TSS, mg/l	8.7
NH_3 -N, mg/l	7.4
TP, mg/l	1.1
E. coli, CFU or MPN per 100 ml	2

DRAFT PERMIT CONDITIONS

The draft permit authorizes a discharge of treated domestic wastewater at an interim volume not to exceed a daily average flow of 0.08 MGD and a final volume not to exceed a daily average flow of 0.15 MGD.

The effluent limitations in all phases of the draft permit, based on a 30-day average, are 10 mg/l $CBOD_5$, 15 mg/l TSS, 3 mg/l NH_3 -N, 126 CFU or MPN of *E. coli* per 100 ml, and 5.0 mg/l minimum dissolved oxygen (DO). The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes based on peak flow.

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal, and Transportation. The draft permit authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, or wastewater treatment facility, or facility that further processes sludge.

SUMMARY OF CHANGES FROM APPLICATION

None.

SUMMARY OF CHANGES FROM EXISTING PERMIT

Effluent limitations and monitoring requirements in the draft permit remain the same as the existing permit requirements.

The Standard Permit Conditions, Sludge Provisions, and Other Requirements sections of the draft permit have been updated.

The Interim I phase in the existing permit has been removed in the draft permit as the facility is currently operating in the Interim II phase. The draft permit authorizes the discharge of treated

Undine Texas Environmental LLC TPDES Permit No. WQ0014163001

Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

domestic wastewater at an annual average flow not to exceed 0.80 MGD in the Interim II phase and an annual average flow not to exceed 0.15 MGD in the Final phase.

Other Requirements No. 5, 6, and 7 have been revised in the draft permit.

The draft permit includes all updates based on the 30 TAC 312 rule change effective April 23, 2020.

BASIS FOR DRAFT PERMIT

The following items were considered in developing the draft permit:

- 1. Application received on December 3, 2024, and additional information received on March 3, 2025.
- 2. TPDES Permit No. WQ0014163001 issued on December 10, 2019.
- 3. The effluent limitations and conditions in the draft permit comply with EPA-approved portions of the 2018 Texas Surface Water Quality Standards (TSWQS), 30 TAC §§ 307.1 307.10, effective March 1, 2018; 2014 TSWQS, effective March 6, 2014; 2010 TSWQS, effective July 22, 2010; and 2000 TSWQS, effective July 26, 2000.
- 4. The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Effluent Limitations.
- 5. Interoffice Memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division.
- 6. Consistency with the Coastal Management Plan: The facility is not located in the Coastal Management Program boundary.
- 7. Procedures to Implement the Texas Surface Water Quality Standards (IP), Texas Commission on Environmental Quality, June 2010, as approved by EPA, and the IP, January 2003, for portions of the 2010 IP not approved by EPA.
- 8. Texas 2024 Clean Water Act Section 303(d) List, Texas Commission on Environmental Quality, June 26, 2024; approved by the U.S. Environmental Protection Agency on November 13, 2024.
- 9. Texas Natural Resource Conservation Commission, Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.

PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a

Undine Texas Environmental LLC TPDES Permit No. WQ0014163001 Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application, and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment, and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Preston Tracy at (512) 239-3581.

Preston Tracy	August 6, 2025
Preston Tracy	Date
Municipal Permits Team	
Wastewater Permitting Section (MC 148)	