

This file contains the following documents:

- 1. Summary of application (in plain language)
 - English
 - Alternative Language (Spanish)
- 2. First Notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
 - English
 - Alternative Language (Spanish)
- 3. Application materials



Este archivo contiene los siguientes documentos:

- 1. Resumen en lenguaje sencillo (PLS, por sus siglas en inglés) de la actividad propuesta
 - Inglés
 - Idioma alternativo (español)
- 2. Primer aviso (NORI, por sus siglas en inglés)
 - Inglés
 - Idioma alternativo (español)
- 3. Solicitud original



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Brownsville Navigation District (CN600520126) operates Turning Basin Wastewater Treatment Plant ((RN1020780940), an activated sludge process plant operated in the conventional mode.. The facility is located at 3005 Levee Road, in Brownsville, Texas. 78521, Cameron, County, Texas 78521 located on the north side of Old State Highway 48, approximately 0.7 mile east of the intersection of Old State Highway 48 and State Road 550, northeast of the city of Brownsville, Cameron County. Texas. 78521. Renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.1 million gallons per day (MGF) the Turning Basin Wastewater Plant serves Ostos Road along the entire south side of the Brownsville Ship Channel (BSC), Windhaus Road, and Milo Road west of (BSC), Foust Road north of the (BSC), from 511 to Old SH 48, and W. Oil Dock Ramp up to Oil Dock No. 5. << *For TLAP applications include the following*

sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain Chlorine residual of at least 1.0 mg/l and shall not exceed 4.0 mg/l, based on peak flow, and shall be monitored five times per week PH shall not be less than 6.0 nor greater than 9.0 once per month, Do, containing 2.0 minimum shall be monitored once per week., BOD, TSS once a week, E. Coli monthly and flow MGD on a dialy basis additional potential pollutants are include in the Domestic Technical Report 1.0 Section 7 Pollutant Analysis of Treated Effluent in the Permit Application Package. The treated effuent is discharged to an unnamed ditch; thence to Cameron County Drainage Ditch No. 1 thence San Martin Lake, thence to the Brownsville Ship Channel in Segment No. 2494 of the erBays and Estuaries. is treated by activated sludge process plant operated in the conventional mode, treatments units include bar screen, grit chamber grease removal, aertion basin, final clarifier and chlornine contact chamber, facility is in operation.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

AGUAS RESIDUALES DOMESTICA /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

El Districto de Navegación de Brownsville (CN6005201265)) opera Turning Basin Wastewater Treatment Plant RN102078094, un una renovación para autorizar el permiso del Sistema de Eliminación de Descargas de Contaminantes de Texas, que autoriza al Districto de Navegación de Brownsville la descarga de aguas residuales tratadas en un volumen que no exceda una descarga de promedio de 100,000 galones por día.. La instalación está ubicada en 3005 Levee Rd., , en Brownsville, Condado de Cameron, Texas 78521. located on the north side of Old State Highway 48, approximately 0.7 mile east of the intersection of Old State Highway 48 and State Road 550, northeast of the city of Brownsville, Cameron County. Texas. 78521 78521 situada en el lado norte de la antigua carretera estatal 48, aproximadamente a 0,7 millas al este de la intersección de la antigua carretera estatal 48 y la carretera estatal 550, al noreste de la ciudad de Brownsville, condado de Cameron. Texas. 78521 El efluente tratado es descargado a un dren sin nombré, de hi a Dren No. 1 del Condado de Cameron, después al lago San Martin y finalmente al Canal de Navegación de Brownsville en el Segmento No 2494 de la Cuenca de Bahías y Estatuarios, los unos designados para el Segmento No 2494 son uso excepcional de vida acuática y recreación sin contacto. . << Para las solicitudes de TLAP incluya la siguiente oración, de lo contrario, elimine:>> Este permiso no autorizará una descarga de contaminantes en el agua en el estado.

Se espera que las descargas de la instalación contengan 14. Liste todos los contaminantes esperados aquí. 15. Introduzca los tipos de aguas residuales descargadas aquí. 16. Elija del menú desplegable tratado por 17. Introduzca una descripción del tratamiento de aguas residuales utilizado en la instalación aquí.

INSTRUCTIONS

- 1. Enter the name of applicant in this section. The applicant name should match the name associated with the customer number.
- 2. Enter the Customer Number in this section. Each Individual or Organization is issued a unique 11-digit identification number called a CN (e.g. CN123456789).
- 3. Choose "operates" in this section for existing facility applications or choose "proposes to operate" for new facility applications.
- 4. Enter the name of the facility in this section. The facility name should match the name associated with the regulated entity number.
- 5. Enter the Regulated Entity number in this section. Each site location is issued a unique 11-digit identification number called an RN (e.g. RN123456789).
- 6. Choose the appropriate article (a or an) to complete the sentence.
- 7. Enter a description of the facility in this section. For example: steam electric generating facility, nitrogenous fertilizer manufacturing facility, etc.
- 8. Choose "is" for an existing facility or "will be" for a new facility.
- 9. Enter the location of the facility in this section.
- 10. Enter the City nearest the facility in this section.
- 11. Enter the County nearest the facility in this section.
- 12. Enter the zip code for the facility address in this section.
- 13. Enter a summary of the application request in this section. For example: renewal to discharge 25,000 gallons per day of treated domestic wastewater, new application to discharge process wastewater and stormwater on an intermittent and flow-variable basis, or major amendment to reduce monitoring frequency for pH, etc. If more than one outfall is included in the application, provide applicable information for each individual outfall.
- 14. List all pollutants expected in the discharge from this facility in this section. If applicable, refer to the pollutants from any federal numeric effluent limitations that apply to your facility.
- 15. Enter the discharge types from your facility in this section (e.g., stormwater, process wastewater, once through cooling water, etc.)
- 16. Choose the appropriate verb tense to complete the sentence.
- 17. Enter a description of the wastewater treatment used at your facility. Include a description of each process, starting with initial treatment and finishing with the outfall/point of disposal. Use additional lines for individual discharge types if necessary.

Questions or comments concerning this form may be directed to the Water Quality Division's Application Review and Processing Team by email at <a href="https://www.wq-arthu.org/wq-arthu.or

Example 1: Industrial Wastewater TPDES Application (ENGLISH)

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

ABC Corporation (CN600000000) operates the Starr Power Station (RN10000000000), a two-unit gas-fired electric generating facility. Unit 1 has a generating capacity of 393 megawatts (MWs) and Unit 2 has a generating capacity of 528 MWs. The facility is located at 1356 Starr Street, near the City of Austin, Travis County, Texas 78753.

This application is for a renewal to discharge 870,000,000 gallons per day of once through cooling water, auxiliary cooling water, and also authorizes the following waste streams monitored inside the facility (internal outfalls) before it is mixed with the other wastewaters authorized for discharge via main Outfall 001, referred to as "previously monitored effluents" (low-volume wastewater, metal-cleaning waste, and stormwater (from diked oil storage area yards and storm drains)) via Outfall 001. Low-volume waste sources, metal-cleaning waste, and stormwater drains on a continuous and flow-variable basis via internal Outfall 101.

The discharge of once through cooling water via Outfall 001 and low-volume waste and metal-cleaning waste via Outfall 101 from this facility is subject to federal effluent limitation guidelines at 40 CFR Part 423. The pollutants expected from these discharges based on 40 CFR Part 423 are: free available chlorine, total residual chlorine, total suspended solids, oil and grease, total iron, total copper, and pH. Temperature is also expected from these discharges. Additional potential pollutants are included in the Industrial Wastewater Application Technical Report, Worksheet 2.0.

Cooling water and boiler make-up water are supplied by Lake Starr Reservoir. The City of Austin municipal water plant (CN600000000, PWS 00000) supplies the facility's potable water and serves as an alternate source of boiler make-up water. Water from the Lake Starr Reservoir is withdrawn at the intake structure and treated with sodium hypochlorite to prevent biofouling and sodium bromide as a chlorine enhancer to improve efficacy and then passed through condensers and auxiliary equipment on a once-through basis to cool equipment and condense exhaust steam.

Low-volume wastewater from blowdown of boiler Units 1 and 2 and metal-cleaning wastes receive no treatment prior to discharge via Outfall 101. Plant floor and equipment drains and stormwater runoff from diked oil storage areas, yards, and storm drains are routed through an oil and water separator prior to discharge via Outfall 101. Domestic wastewater, blowdown, and backwash water from the service water filter, clarifier, and sand filter are routed to the Starr Creek Domestic Sewage Treatment Plant, TPDES Permit No. WQ0010000001, for treatment and disposal. Metal-cleaning waste from equipment cleaning is generally disposed of off-site.

Example 2: Domestic Wastewater TPDES Renewal application

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Texas (CN000000000) operates the City of Texas wastewater treatment plant (RN00000000), an activated sludge process plant operated in the complete mix mode. The facility is located at 123 Texas Street, near the City of More Texas, Texas County, Texas 71234.

This application is for a renewal to discharge at an annual average flow of 1,200,000 gallons per day of treated domestic wastewater via Outfalls 001 and 002.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent and Domestic Worksheet 4.0 in the permit application package. Domestic wastewater is treated by an activated sludge process plant and the treatment units include a bar screen, a grit chamber, aeration basins, final clarifiers, sludge digesters, a belt filter press, chlorine contact chambers and a dechlorination chamber.

Example 3: Domestic Wastewater TPDES New Application

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

The City of Texas (CN000000000) proposes to operate the City of Texas wastewater treatment plant (RN00000000), an activated sludge process plant operated in the extended aeration mode. The facility will be located at 123 Texas Street, in the City of More Texas, Texas County, Texas 71234.

This application is for a new application to discharge at a daily average flow of 200,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater will be treated by an activated sludge process plant and the treatment units will include a bar screen, a grit chamber, aeration basins, final clarifiers, sludge digesters, a belt filter press, chlorine contact chambers and a dechlorination chamber.

Example 4: Domestic Wastewater TLAP Renewal application

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations

of the permit application.

The City of Texas (CN000000000) operates the City of Texas wastewater treatment plant (RN00000000), an activated sludge process plant operated in the complete mix mode. The facility is located at 123 Texas Street, near the City of More Texas, Texas County, Texas 71234.

This application is for a renewal to dispose a daily average flow not to exceed 76,500 gallons per day of treated domestic wastewater via public access subsurface drip irrigation system with a minimum area of 32 acres. This permit will not authorize a discharge of pollutants into water in the state.

Land application of domestic wastewater from the facility are expected to contain five-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater is treated by an activated sludge process plant and the treatment units include a bar screen, an equalization basin, an aeration basin, a final clarifier, an aerobic sludge digester, tertiary filters, and a chlorine contact chamber. In addition, the facility includes a temporary storage that equals to at least three days of the daily average flow.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT RENEWAL.

PERMIT NO. WQ0014355001

APPLICATION. Brownsville Navigation District, 1000 Foust Road, Brownsville, Texas 78521, has applied to the Texas Commission on Environmental Quality (TCEQ) to renew Texas Pollutant Discharge Elimination System (TPDES) Permit No. WO0014355001 (EPA I.D. No. TX0074047) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 100,000 gallons per day. The domestic wastewater treatment facility is located at 3005 Levee Road, and approximately 0.7 miles east of the intersection of Old State Highway 48 and State Road 550 in the city of Brownsville, in Cameron County, Texas 78521. The discharge route is from the plant site to an unnamed ditch; thence to Cameron County Drainage Ditch No. 1; thence to San Martin Lake; thence to the Brownsville Ship Channel. TCEQ received this application on October 1, 2025. The permit application will be available for viewing and copying at Brownsville Navigation District, Administration Building, 1000 Foust Road. Brownsville, in Cameron County, Texas prior to the date this notice is published in the newspaper. The application is available for viewing and copying at the following webpage: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes- applications. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.394722,25.962222&level=18

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. Notice of the Application and Preliminary Decision will be published and mailed to those who are on the countywide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a

public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at https://www14.tceq.texas.gov/epic/eComment/, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Brownsville Navigation District at the address stated above or by calling Mr. Manuel Martinez, Acting Director of Engineering Services, at 956-551-2602.

Issuance Date: November 25, 2025

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO. WQ0014355001

SOLICITUD. Distrito de Navegacion de Brownsville, 1000 Foust Road, Brownsville, Texas 78521, ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEO) para renovar el Permiso No. WQ0014355001 (EPA I.D. No. TX 0074047) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 100,000 galones por día. La planta está ubicada en 3005 Levee Road, y aproximadamente a 0,7 millas al este de la intersección de la antigua carretera estatal 48 y la carretera estatal 550 en la ciudad de Brownsville, en el condado de Cameron, Texas 78521. La ruta de descarga va desde el emplazamiento de la planta hasta una zanja sin nombre; de ahí hasta la Zanja de Drenaje del Condado de Cameron nº 1; de allí al lago San Martin; de allí al canal de navegación de Brownsville. La TCEQ recibió esta solicitud el 1 del octubre, 2025. La solicitud para el permiso estará disponible para leerla y copiarla en las Oficinas Administrativas del Distrito de Navegacíon de Brownsville en 1000 Foust Road, Brownsville, en el condado de Cameron, Tx 78521, antes de la fecha de publicación de este aviso en el periódico. La solicitud (cualquier actualización y aviso inclusive) está disponible electrónicamente en la siguiente página web: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.394722,25.962222&level=18

AVISO DE IDIOMA ALTERNATIVO. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO. Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión.

La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de

una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos del solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envía por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

INFORMACIÓN DISPONIBLE EN LÍNEA. Para detalles sobre el estado de la solicitud, favor de visitar la Base de Datos Integrada de los Comisionados en www.tceq.texas.gov/goto/cid. Para buscar en la base de datos, utilizar el número de permiso para esta solicitud que aparece en la parte superior de este aviso.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía http://www14.tceq.texas.gov/epic/eComment/o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Distrito de Navegacíon de Brownsville a la dirección indicada arriba o llamando al Sr. Manuel Martinez, Director en funciones de ingenería al 956-551-2602.

Fecha de emisión: 25 de noviembre de 2025



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Brownsville Navigation District (CN600520126) operates Turning Basin Wastewater Treatment Plant ((RN1020780940), an activated sludge process plant operated in the conventional mode.. The facility is located at 3005 Levee Road, in Brownsville, Texas. 78521, Cameron, County, Texas 78521. Renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.1 million gallons per day (MGF) the Turning Basin Wastewater Plant serves Ostos Road along the entire south side of the Brownsville Ship Channel (BSC), Windhaus Road, and Milo Road west of (BSC), Foust Road north of the (BSC), from 511 to Old SH 48, and W. Oil Dock Ramp up to Oil Dock No. 5. << *For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain Chlorine residual of at least 1.0~mg/l and shall not exceed 4.0~mg/l, based on peak flow, and shall be monitored five times per

week PH shall not be less than 6.0 nor greater than 9.0 once per month, Do, containing 2.0 minimum shall be monitored once per week., BOD, TSS once a week, E. Coli monthly and flow MGD on a dialy basis additional potential pollutants are include in the Domestic Technical Report 1.0 Section 7 Pollutant Analysis of Treated Effluent in the Permit Application Package. The treated effuent is discharged to an unnamed ditch; thence to Cameron County Drainage Ditch No. 1 thence San Martin Lake, thence to the Brownsville Ship Channel in Segment No. 2494 of the erBays and Estuaries. is treated by activated sludge process plant operated in the conventional mode, treatments units include bar screen, grit chamber grease removal, aertion basin, final clarifier and chlornine contact chamber, facility is in operation.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

AGUAS RESIDUALES DOMESTICA /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

El Districto de Navegación de Brownsville (CN6005201265)) opera Turning Basin Wastewater Treatment Plant RN102078094, un una renovación para autorizar el permiso del Sistema de Eliminación de Descargas de Contaminantes de Texas, que autoriza al Districto de Navegación de Brownsville la descarga de aguas residuales tratadas en un volumen que no exceda una descarga de promedio de 100,000 galones por día.. La instalación está ubicada en 3005 Levee Rd., , en Brownsville, Condado de Cameron, Texas 78521. El efluente tratado es descargado a un dren sin nombré, de hi a Dren No. 1 del Condado de Cameron, después al lago San Martin y finalmente al Canal de Navegación de Brownsville en el Segmento No 2494 de la Cuenca de Bahías y Estatuarios, los unos designados para el Segmento No 2494 son uso excepcional de vida acuática y recreación sin contacto. . << Para las solicitudes de TLAP incluya la siguiente oración, de lo contrario, elimine:>> Este permiso no autorizará una descarga de contaminantes en el agua en el estado.

Se espera que las descargas de la instalación contengan 14. Liste todos los contaminantes esperados aquí. 15. Introduzca los tipos de aguas residuales descargadas aquí. 16. Elija del menú desplegable tratado por 17. Introduzca una descripción del tratamiento de aguas residuales utilizado en la instalación aquí.



September 30, 2025

Texas Commission on Environmental Quality Water Quality Division Applications Review and Process Team (MC148) 12100 Park 35 Circle Austin, Texas 78753

RE: Application to Renew Permit No. WQ0014355001

Brownsville Navigation District: (CN 600520126)

Regulated Entity: (RN 102078094)

Dear Review Team:

Find the enclosed one original TCEQ Water Quality Permit Renewal Application forms 10053, 10054, and 10400, along with necessary attachments for the facility referenced above. The Facility is situated at 3005 Levee Road located on the north side of State Highway 48 approximately 0.7 mile east of the intersection of State Highway 48 and Farm-to-market Road 511, northeast of the City of Brownsville, Cameron County, Texas.

Currently, the Turning Basin Wastewater Plant treatment facility has permission to discharge domestic water effluent at a daily flow of no more than .0.10 MGD. To consider the application complete we also uploaded an electronic copy via TCEQ FTP Server. Fee application paid via ePay, see enclosed receipt.

Should questions remain, please notify us at your earliest convenience, so we can immediately respond and address any additional concerns you might have.

Sincerely,

BROWNSVILLE NAVIGATION DISTRICT

dba PORT OF BROWNSVILLE

Manuel Martinez.

Acting Director of Engineering Services Email: mmartinez@portofbrownsville.com

Enclosures: TCEQ forms 10053, 10054 10400 and attachments.

Cc: Nora Alicia Gonzalez, Engineering Administrative Specialist



Brownsville Navigation District d/b/a Port of Brownsville

Turning Basin Wastewater Treatment Facility

TPDES Discharge Permit Application (RENEWAL)

TPDES Permit No. WQ0014355001 CN600520126 RN102078094

September 30, 2025

Prepared by:

Nora Alicia Gonzalez
Engineering Administrative Specialist
Engineering Department
1000 Foust Rd
Brownsville, Texas
Tel: 956-551-9205

Email: nagonzalez@portofbrownsville.com

THE COMMISSION OF THE PROPERTY OF THE PROPERTY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

APPLICANT NAME: Brownsville Navigation District

PERMIT NUMBER (If new, leave blank): WQ000014355001

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	\boxtimes		Original USGS Map	\boxtimes	
Administrative Report 1.1		\boxtimes	Affected Landowners Map		\boxtimes
SPIF	\boxtimes		Landowner Disk or Labels		\boxtimes
Core Data Form	\boxtimes		Buffer Zone Map		\boxtimes
Summary of Application (PLS)	\boxtimes		Flow Diagram	\boxtimes	
Public Involvement Plan Form			Site Drawing		
Technical Report 1.0	\boxtimes	\boxtimes	Original Photographs		\boxtimes
Technical Report 1.1			Design Calculations		\boxtimes
Worksheet 2.0			Solids Management Plan	30	\boxtimes
Worksheet 2.1		\boxtimes	Water Balance		\boxtimes
Worksheet 3.0		\boxtimes			
Worksheet 3.1					
Worksheet 3.2					
Worksheet 3.3					
Worksheet 4.0		\boxtimes			
Worksheet 5.0		\boxtimes			
Worksheet 6.0	\boxtimes				
Worksheet 7.0		\boxtimes			
For TCEQ Use Only					
Segment NumberExpiration Date			County Region		

Permit Number _____

SCOMMISSION OF STREET OF S

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

Section 1. Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
<0.05 MGD	\$350.00 □	\$315.00 □
≥0.05 but <0.10 MGD	\$550.00	\$515.00 □
≥0.10 but <0.25 MGD	\$850.00 □	\$815.00 ⊠
≥0.25 but <0.50 MGD	\$1,250.00 □	\$1,215.00 □
≥0.50 but <1.0 MGD	\$1,650.00 □	\$1,615.00 □
≥1.0 MGD	\$2,050.00 □	\$2,015.00

Minor Amendment (for any flow) \$150.00 \square

Par	yment	Inform	ation

Mailed Check/Money Order Number: <u>E-Pay</u>

Check/Money Order Amount: Click to enter text.

Name Printed on Check: Click to enter text.

EPAY Voucher Number: Click to enter text.

Copy of Payment Voucher enclosed? Yes ⊠

Section 2. Type of Application (Instructions Page 26)

a.	Che	eck the box next to the appropriate authorization type.
	\boxtimes	Publicly Owned Domestic Wastewater
		Privately-Owned Domestic Wastewater
		Conventional Water Treatment
b.	Che	eck the box next to the appropriate facility status.

Inactive

Active

c.	Che	eck the box next to the appropriate permit typ	e.			
	\boxtimes	TPDES Permit				
		TLAP				
		TPDES Permit with TLAP component				
		Subsurface Area Drip Dispersal System (SAD	DS)			
d.	l. Check the box next to the appropriate application type					
		New				
		Major Amendment with Renewal		Minor Amendment with Renewal		
		Major Amendment without Renewal		Minor Amendment without Renewal		
	\boxtimes	Renewal without changes		Minor Modification of permit		
e.	For	amendments or modifications, describe the p	ropo	osed changes: Click to enter text.		
f.	For	existing permits:				
	Per	mit Number: WQ00 <u>14355001</u>				
	EPA	A I.D. (TPDES only): TX <u>0074047</u>				
	Exp	oiration Date: <u>May 19, 2026</u>				
Se	ctic	on 3. Facility Owner (Applicant) a (Instructions Page 26)	nd	Co-Applicant Information		
A.	The	e owner of the facility must apply for the pe	rmit	•		
	Wh	at is the Legal Name of the entity (applicant) a	pply	ing for this permit?		
	Bro	wnsville Navigation District				
		e legal name must be spelled exactly as filed w legal documents forming the entity.)	ith ti	he Texas Secretary of State, County, or ii		
	If th	he applicant is currently a customer with the				

You may search for your CN on the TCEQ website at <u>http://www15.tceq.texas.gov/crpub/</u>

CN: 600520126

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: Mr.

Last Name, First Name: Martinez Manuel

Title: Acting Director of Engineering Credential: Click to enter text.

B. Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

Click to enter text.

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the *legal documents forming the entity.)*

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: http://www15.tceq.texas.gov/crpub/

CN: Click to enter text.

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in *30 TAC § 305.44*.

Prefix: Click to enter text.

Last Name, First Name: Click to enter text.

Title: Click to enter text.

Credential: Click to enter text.

Provide a brief description of the need for a co-permittee: Click to enter text.

C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. <u>Attachment. Admin 1.0-3c</u>

Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Mr.

Last Name, First Name: Martinez Manuel

Title: Acting Director of Engineering Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: <u>956-551-2602</u>

E-mail Address: <u>mmartinez@portofbrownsville.com</u>

Check one or both:

□ Administrative Contact

⊠ Technical Contact

B. Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Check one or both:

 □ Technical Contact

Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Mr.

Last Name, First Name: Martinez Manuel

Title: Acting Director of Engineering Services

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Rd

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-2602

E-mail Address: mmartinez@portofbrownsville.com

B. Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Section 8. Public Notice Information (Instructions Page 27)

A. Individual Publishing the Notices

Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

В.		ethod fo .ckage	or Receivin	ig Not	ice of R	Receipt an	d Inte	ent to Obt	ain a Wa	ter Qua	lity Pern	uit
	Inc	dicate b	y a check r	nark t	he prefe	erred meth	od fo	r receivin	g the firs	st notice	and inst	ructions:
	\boxtimes	E-ma	il Address									
		Fax										
		Regul	lar Mail									
C.	Co	ntact p	ermit to be	e liste	d in the	Notices						
	Pr	efix: <u>Mr</u>	<u>.</u>			Last Name	, First	Name: <u>M</u>	artinez M	anuel		
	Tit	tle: <u>Acti</u> ı	ng Director o	of Engi	neering	<u>Services</u>		Credenti	al: Click	to enter	text.	
	Or	ganizat	ion Name:	Brown	sville Na	vigation Di	strict					
	Ma	ailing A	ddress: <u>100</u>	o Fous	t Road	1	City, S	State, Zip	Code: Cli	ck to en	ter text.	
	Ph	one No.	: Click to e	nter te	ext.	E-mail Ad	dress	: Click to	enter tex	t.		
D.	Pu	blic Vie	ewing Info	rmatio	n	,						
			lity or outfo ust be provi		cated ir	n more tha	n one	county, a	ı public v	iewing p	olace for	each
	Pu	blic bui	lding name	: Brow	nsville 1	Navigation 1	Distric	<u>:t</u>				
	Lo	cation v	vithin the b	ouildin	ıg: <u>Admi</u>	inistration l	Buildir	ng				
	Ph	ysical A	ddress of l	Buildir	ng: <u>1000</u>	Foust Roa	<u>d</u>					
	Cit	ty: <u>Brow</u>	<u>nsville</u>			County	: <u>Cam</u>	<u>eron</u>				
	Co	ntact (L	ast Name,	First N	lame): <u>C</u>	Gonzalez No	ora Ali	<u>cia</u>				
	Ph	one No.	: <u>956-551-9</u> :	205 Ex	t.: Click	to enter t	ext.					
E.	Bil	ingual i	Notice Reg	uirem	ents							
			mation <mark>is</mark> r ion, and re				ame	ndment, 1	minor an	iendme:	nt or mi	ıor
	be	needed	on of the ay l. Complete ic notice pa	instru	actions							
	ob		the bilingue following									
	1.		ingual eduo dle school							n Code a	it the ele	mentary
			Yes		No							
		If no , p	oublication	of an	alternat	tive langua	age no	otice is no	t require	d; skip t	t o Section	19
	2.		e students gual educat					tary scho	ol or the	middle	school ei	ırolled in
			Yes		No							

	3.	Do the locatio	students at n?	these s	chools	attend	a bilingua	al educa	tion prog	ram a	t another
			Yes	⊠ N	lo						
	4.		the school l l out of this							gram l	out the school has
			Yes	\boxtimes N	lo						
	5.		answer is ye ed. Which la								tive language are enter text.
F.	Su	mmary	of Applicat	ion in I	lain La	nguag	e Templa	te			
			the F. Sumr n as the pla) Form 20972), ment.
	At	tachme	nt: <u>20972</u>								
G.	Pu	blic Inv	olvement P	lan For	m						
			the Public Ii iit or major								plication for a t.
	At	tachme	nt: <u>N/A</u>								
			N				an				
Se	cti	on 9.			itity a	nd Po	ermitte	d Site	Inform	ation	(Instructions
			Page 29						THE ELECTION		
A.			is currently RN <u>RN10207</u> 8		ed by T	CEQ, p	rovide the	e Regula	ited Entity	y Num	ber (RN) issued to
			e TCEQ's Cer currently re				//www15.	tceq.tex	as.gov/cr	pub/	to determine if
B.	Na	me of p	project or sit	e (the n	ame kn	own b	y the com	munity	where loc	ated):	
	<u>Tu</u>	rning Ba	ısin Wastewa	ter Plant							
C.	Ov	vner of	treatment fa	acility: <u>F</u>	rownsvi	lle Nav	igation Dis	<u>trict</u>			
	Ov	vnershij	o of Facility:	⊠ P	ublic		Private		Both		Federal
D.	Ov	vner of	land where	treatme	nt facili	ty is o	r will be:				
	Pre	efix: Cli	ck to enter t	ext.	Las	t Nam	e, First Na	me: Cli	ck to ente	r text.	
	Tit	le: Clicl	k to enter te	xt.	Cre	edentia	l: Click to	enter to	ext.		
	Or	ganizat	ion Name: <u>B</u>	rownsvi	lle Navig	ation I	<u>District</u>				
	Ma	iling A	ddress: <u>1000</u>	Foust R	<u>oad</u>		City, Stat	e, Zip C	ode: <u>Brow</u>	<u>nsville</u>	, Texas. 78521
	Ph	one No.	: <u>956-551-92</u> 0	05	E-1	nail A	ddress: <u>na</u>	gonzalez	@portofb	rownsv	rille.com
			lowner is no t or deed red						or co-ap	plican	t, attach a lease
		Attach	ment: N/A								

	Prefix: <u>SAME</u>	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ent	er text.
	Mailing Address: Click to enter t	ext. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded eas	e person as the facility owner or co-applicant, attach a lease sement. See instructions.
	Attachment: Click to enter to	ext.
F.	Owner sewage sludge disposal s property owned or controlled by	site (if authorization is requested for sludge disposal on y the applicant)::
	Prefix: Click to enter text.	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ent	er text.
	Mailing Address: Click to enter t	text. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded eas	e person as the facility owner or co-applicant, attach a lease sement. See instructions.
	Attachment: Click to enter to	ext.
Se	ection 10. TPDES Dischar	ge Information (Instructions Page 31)
A.	Is the wastewater treatment faci	ility location in the existing permit accurate?
	⊠ Yes □ No	
	If no or a new nermit applicati	an place give an acquirete description
		on, please give an accurate description:
	Click to enter text.	on, please give an accurate description.
	Click to enter text.	
В.	Click to enter text.	d the discharge route(s) in the existing permit correct?
В.	Click to enter text.	
В.	Click to enter text. Are the point(s) of discharge and ✓ Yes □ No If no, or a new or amendment point of discharge and the discharge and the discharge 307:	
В.	Click to enter text. Are the point(s) of discharge and	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the
В.	Click to enter text. Are the point(s) of discharge and	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30
В.	Click to enter text. Are the point(s) of discharge and ✓ Yes □ No If no, or a new or amendment point of discharge and the discharge and the discharge 307:	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30 as a
	Click to enter text. Are the point(s) of discharge and	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30 nsville is/are located: Cameron r discharge to a city, county, or state highway right-of-way, or
	Click to enter text. Are the point(s) of discharge and with the point of discharge and the discharge	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30 nsville is/are located: Cameron r discharge to a city, county, or state highway right-of-way, or

E. Owner of effluent disposal site:

	If yes , indicate by a check mark if:
	oxdot Authorization granted $oxdot$ Authorization pending
	For new and amendment applications, provide copies of letters that show proof of contact and the approval letter upon receipt.
	Attachment: Click to enter text.
D.	For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: Click to enter text.
Se	ction 11. TLAP Disposal Information (Instructions Page 32)
	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?
7 11	☐ Yes ☐ No
	If no, or a new or amendment permit application , provide an accurate description of the disposal site location:
	Click to enter text.
В.	City nearest the disposal site: Click to enter text.
C.	County in which the disposal site is located: Click to enter text.
D.	For TLAPs , describe the routing of effluent from the treatment facility to the disposal site:
	Click to enter text.
E.	For TLAPs , please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: Click to enter text.
Se	ction 12. Miscellaneous Information (Instructions Page 32)
A.	Is the facility located on or does the treated effluent cross American Indian Land?
	□ Yes ⊠ No
В.	If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?
	□ Yes □ No ⊠ Not Applicable
	If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.
	Click to enter text.

C.	Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?
	□ Yes ⊠ No
	If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application: Click to enter text.
D.	Do you owe any fees to the TCEQ?
	□ Yes ⊠ No
	If yes , provide the following information:
	Account number: Click to enter text.
	Amount past due: Click to enter text.
E.	Do you owe any penalties to the TCEQ?
	□ Yes ⊠ No
	If yes , please provide the following information:
	Enforcement order number: Click to enter text.
	Amount past due: Click to enter text.
Se	ection 13. Attachments (Instructions Page 33)
Inc	dicate which attachments are included with the Administrative Report. Check all that apply:
	Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.
\boxtimes	Original full-size USGS Topographic Map with the following information:
	Applicant's property boundary
	 Treatment facility boundary Labeled point of discharge for each discharge point (TPDES only) Highlighted discharge route for each discharge point (TPDES only) Onsite sewage sludge disposal site (if applicable) Effluent disposal site boundaries (TLAP only) New and future construction (if applicable) 1 mile radius information
	 3 miles downstream information (TPDES only) All ponds.
	Attachment 1 for Individuals as so applicants
	Attachment 1 for Individuals as co-applicants
	Other Attachments. Please specify: Click to enter text.
1000	AND THE CONTRACT OF CONTRACT O

Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0014355001

Applicant: Brownsville Navigation District

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): Manuel Martinez
Signatory title: Acting Director of Engineering Services
Signature:
(Use blue ink)
Subscribed and Sworn to before me by the said Maruel Matine2
on this day of September , 2015.
My commission expires on the $\frac{1200}{100}$ day of $\frac{100}{100}$ day of $\frac{100}{100}$.
NIDIA MAGALI OVALLE Notary ID #126087722 My Commission Expires

March 23, 2027

() ames

Notary Public

DOMESTIC WASTEWATER PERMIT APPLICATION **ADMINISTRATIVE REPORT 1.0**

The following information is required for new and amendment applications.

Section 1. Affected Landowner Information (Instructions Page 36)

A.		cate by a check mark that the landowners map or drawing, with scale, includes the owing information, as applicable:
		The applicant's property boundaries
		The facility site boundaries within the applicant's property boundaries
		The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone
		The property boundaries of all landowners surrounding the applicant's property (Note: if the application is a major amendment for a lignite mine, the map must include the property boundaries of all landowners adjacent to the new facility (ponds).)
		The point(s) of discharge and highlighted discharge route(s) clearly shown for one mile downstream
		The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge
		The property boundaries of the landowners along the watercourse for a one-half mile radius from the point of discharge if the point of discharge is into a lake, bay, estuary, or affected by tides
		The boundaries of the effluent disposal site (for example, irrigation area or subsurface drainfield site) and all evaporation/holding ponds within the applicant's property
		The property boundaries of all landowners surrounding the effluent disposal site
		The boundaries of the sludge land application site (for land application of sewage sludge for beneficial use) and the property boundaries of landowners surrounding the applicant's property boundaries where the sewage sludge land application site is located
		The property boundaries of landowners within one-half mile in all directions from the applicant's property boundaries where the sewage sludge disposal site (for example, sludge surface disposal site or sludge monofill) is located
В.	The state of the s	Indicate by a check mark that a separate list with the landowners' names and mailing resses cross-referenced to the landowner's map has been provided.
C.	-	Indicate by a check mark that the landowners list has also been provided as mailing ls in electronic format (Avery 5160).
D.	Prov	vide the source of the landowners' names and mailing addresses: Click to enter text.
E.		equired by $Texas\ Water\ Code\ \S\ 5.115$, is any permanent school fund land affected by application?
	E	□ Yes □ No

	If ye :	s, provide the location and foreseeable impacts and effects this application has on the s):
		k to enter text.
Se	ctio	n 2. Original Photographs (Instructions Page 38)
Pr	ovide	original ground level photographs. Indicate with checkmarks that the following tion is provided.
		At least one original photograph of the new or expanded treatment unit location
		At least two photographs of the existing/proposed point of discharge and as much area downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is to an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.
		At least one photograph of the existing/proposed effluent disposal site
		A plot plan or map showing the location and direction of each photograph
Se	ctio	n 3. Buffer Zone Map (Instructions Page 38)
A.	infor	er zone map. Provide a buffer zone map on 8.5×11 -inch paper with all of the following mation. The applicant's property line and the buffer zone line may be distinguished by a dashes or symbols and appropriate labels.
	•	The applicant's property boundary; The required buffer zone; and Each treatment unit; and The distance from each treatment unit to the property boundaries.
В.		er zone compliance method. Indicate how the buffer zone requirements will be met. k all that apply.
		Ownership
		Restrictive easement
		Nuisance odor control
		Variance
C.		itable site characteristics. Does the facility comply with the requirements regarding itable site characteristic found in 30 TAC § 309.13(a) through (d)?
		Yes □ No

DOMESTIC WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: SPIF Attached

WATER QUALITY PERMIT

PAYMENT SUBMITTAL FORM

Use this form to submit the Application Fee, if the mailing the payment.

- Complete items 1 through 5 below.
- Staple the check or money order in the space provided at the bottom of this document.
- Do Not mail this form with the application form.
- Do not mail this form to the same address as the application.
- Do not submit a copy of the application with this form as it could cause duplicate permit entries.

Mail this form and the check or money order to:

BY REGULAR U.S. MAIL

Texas Commission on Environmental Quality Financial Administration Division Cashier's Office, MC-214

P.O. Box 13088

Austin, Texas 78711-3088

BY OVERNIGHT/EXPRESS MAIL

Texas Commission on Environmental Quality

Financial Administration Division

Cashier's Office, MC-214 12100 Park 35 Circle

Austin, Texas 78753

Fee Code: WQP Waste Permit No: WQ0014355001

- 1. Check or Money Order Number: E-Pay
- 2. Check or Money Order Amount: Click to enter text.
- 3. Date of Check or Money Order: Click to enter text.
- 4. Name on Check or Money Order: Click to enter text.
- 5. APPLICATION INFORMATION

Name of Project or Site: Click to enter text.

Physical Address of Project or Site: Click to enter text.

If the check is for more than one application, attach a list which includes the name of each Project or Site (RE) and Physical Address, exactly as provided on the application.

Staple Check or Money Order in This Space

ATTACHMENT 1

INDIVIDUAL INFORMATION

Section 1. Individual Information (Instructions Page 41)

Complete this attachment if the facility applicant or co-applicant is an individual. Make additional copies of this attachment if both are individuals.

Prefix (Mr., Ms., Miss): Click to enter text.

Full legal name (Last Name, First Name, Middle Initial): Click to enter text.

Driver's License or State Identification Number: Click to enter text.

Date of Birth: Click to enter text.

Mailing Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text. Fax Number: Click to enter text.

E-mail Address: Click to enter text.

CN: Click to enter text.

For Commission Use Only:

Customer Number:

Regulated Entity Number:

Permit Number:

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

application until the items below have been addressed.						
Core Data Form (TCEQ Form No. 10400) (Required for all application types. Must be completed in its en Note: Form may be signed by applicant representative.)		Yes				
Correct and Current Industrial Wastewater Permit Application (TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018		Yes				
Water Quality Permit Payment Submittal Form (Page 19) (Original payment sent to TCEQ Revenue Section. See instruction	⊠ ldress	Yes s.)				
7.5 Minute USGS Quadrangle Topographic Map Attached (Full-size map if seeking "New" permit. 8 ½ x 11 acceptable for Renewals and Amendments)				Yes		
Current/Non-Expired, Executed Lease Agreement or Easement ⊠ N/A				Yes		
Landowners Map (See instructions for landowner requirements)				Yes		
 Things to Know: All the items shown on the map must be labeled. The applicant's complete property boundaries must be delineated which includes boundaries of contiguous property owned by the applicant. The applicant cannot be its own adjacent landowner. You must identify the landowners immediately adjacent to their property, regardless of how far they are from the actual facility. If the applicant's property is adjacent to a road, creek, or stream, the landowners on the opposite side must be identified. Although the properties are not adjacent to applicant's property boundary, they are considered potentially affected landowners if the adjacent road is a divided highway as identified on the USGS topographic map, the applicant does not have to identify the landowners on the opposite side of the highway. 						
Landowners Labels and Cross Reference List (See instructions for landowner requirements)				Yes		
Electronic Application Submittal (See application submittal requirements on page 23 of the instructions.)				Yes		
Original signature per 30 TAC § 305.44 – Blue Ink Preferred \boxtimes Yes (If signature page is not signed by an elected official or principle executive officer, a copy of signature authority/delegation letter must be attached)						
Summary of Application (in Plain Language)				Yes		

COMMISSION OF THE PROPERTY OF

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

Section 1. Permitted or Proposed Flows (Instructions Page 42)

A. Existing/Interim I Phase

Design Flow (MGD): <u>0.10</u>

2-Hr Peak Flow (MGD): 025

Estimated construction start date: January 28, 1976

Estimated waste disposal start date: N/A

B. Interim II Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

C. Final Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

D. Current Operating Phase

Provide the startup date of the facility: January 28, 1976

Section 2. Treatment Process (Instructions Page 42)

A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. If more than one phase exists or is proposed, a description of *each phase* must be provided.

Conventional active sludge: bar screen-grit chamber-grease removal- aeration tank- final clarifier-chlorine contact chamber- discharge pipeline to ditch at outfall 001. Sludge is hauled offsite for disposal.

B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Grit Chamber	1	7'5 x 5'4 60'
Oil Skimmer	1	12' x 30' x 30'
Aeration Tank	1	10' x 130' x 130'
Clarifier	1	14' x 70' x 70'
Sludge Holding Ponds Out of service	2	34' x 34' x 9'6"
Chlorine Disinfectant Chamber	1	9' 6" x 34' x 34'

C. Process Flow Diagram

Provide flow diagrams for the existing facilities and each proposed phase of construction.

Attachment: Attachment. Admin 1.0-2C

Section 3. Site Information and Drawing (Instructions Page 43)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

- Latitude: <u>25 deg. 57 min. 44 sec</u>
- Longitude: <u>97 deg. 23 min. 38 sec.</u>

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

- Latitude: Click to enter text.
- Longitude: Click to enter text.

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or

Attachment: Attachment Admin 1.0-13 & Tech 1.0-3 Provide the name and a description of the area served by the treatment facility. Plant serves Ostos Road along the entire South side of the Brownsville Ship Channel, (BSC) Windhaus Road and Milo Road West, of the BSC, Foust Road North of BSC from 511 to Old SH 48 and W. Oil Dock Road up to Oil Dock No. 5 Collection System Information for wastewater TPDES permits only: Provide information for each **uniquely owned** collection system, existing and new, served by this facility, including satellite collection systems. Please see the instructions for a detailed explanation and examples. **Collection System Information Collection System Name Owner Name Owner Type Population Served** Choose an item. Choose an item. Choose an item. Choose an item. Section 4. Unbuilt Phases (Instructions Page 44) Is the application for a renewal of a permit that contains an unbuilt phase or phases? Yes If yes, does the existing permit contain a phase that has not been constructed within five **years** of being authorized by the TCEQ? Yes No If yes, provide a detailed discussion regarding the continued need for the unbuilt phase. Failure to provide sufficient justification may result in the Executive Director recommending denial of the unbuilt phase or phases. N/A

Section 5. Closure Plans (Instructions Page 44)

disposal site.

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

	□ Yes ⊠ No
If y	yes, was a closure plan submitted to the TCEQ?
	□ Yes □ No :
If y	yes, provide a brief description of the closure and the date of plan approval.
N	/A
	, · · · · · · · · · · · · · · · · · · ·
	· ·
	ction 6. Permit Specific Requirements (Instructions Page 44)
	r applicants with an existing permit, check the Other Requirements or Special ovisions of the permit.
Α.	Summary transmittal
	Have plans and specifications been approved for the existing facilities and each proposed phase?
	⊠ Yes □ No
	If yes, provide the date(s) of approval for each phase: <u>Click to enter text.</u>
	Provide information, including dates, on any actions taken to meet a <i>requirement or</i>
	provision pertaining to the submission of a summary transmittal letter. Provide a copy of
	an approval letter from the TCEQ, if applicable.
	N/A
В.	Buffer zones
	Have the buffer zone requirements been met?
	⊠ Yes □ No
	Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the
	buffer zones.
	Not Applicable

C.	Ot	her actions required by the current permit
	sul	bes the Other Requirements or Special Provisions section in the existing permit require busission of any other information or other required actions? Examples include tification of Completion, progress reports, soil monitoring data, etc.
		□ Yes ⊠ No
		y es , provide information below on the status of any actions taken to meet the nditions of an <i>Other Requirement</i> or <i>Special Provision</i> .
	C	lick to enter text.
		tage of the state
D.	Gr	it and grease treatment
	1.	Acceptance of grit and grease waste
		Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?
		□ Yes ⊠ No
		If No, stop here and continue with Subsection E. Stormwater Management.
	2.	Grit and grease processing
		Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.
		Click to enter text.
	3.	Grit disposal
		Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?
		□ Yes ⊠ No
		If No, contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

		Describe the method of grit disposal.
		Click to enter text.
	4.	Grease and decanted liquid disposal
		Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.
		Describe how the decant and grease are treated and disposed of after grit separation.
		Click to enter text.
		·
E.	Sto	ormwater management
	1.	Applicability
		Does the facility have a design flow of 1.0 MGD or greater in any phase?
		⊠ Yes ⊠ No
		Does the facility have an approved pretreatment program, under 40 CFR Part 403?
		□ Yes ⊠ No
		If no to both of the above, then skip to Subsection F, Other Wastes Received.
	2.	MSGP coverage
		Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?
		□ Yes □ No
		If yes , please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:
		TXR05 <u>Click to enter text.</u> or TXRNE <u>Click to enter text.</u>
		If no, do you intend to seek coverage under TXR050000?
		□ Yes □ No
	3.	Conditional exclusion
		Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?
		□ Yes □ No

	If yes, please explain below then proceed to Subsection F, Other Wastes Received:					
	Click to enter text.					
	No. 6 at a					
4.	Existing coverage in individual permit					
	Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?					
	□ Yes □ No					
	If yes, provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.					
	Click to enter text.					
	*					
5.	Zero stormwater discharge					
	Do you intend to have no discharge of stormwater via use of evaporation or other means?					
	□ Yes □ No					
	If yes, explain below then skip to Subsection F. Other Wastes Received.					
	Click to enter text.					
	Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.					
6.	Request for coverage in individual permit					
	Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?					
	□ Yes □ No					
	If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you					

		it to water in the state.
		Click to enter text.
		Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.
F.	Di	scharges to the Lake Houston Watershed
	Do	oes the facility discharge in the Lake Houston watershed?
		□ Yes ⊠ No
		yes, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions. ick to enter text.
G.	Ot	ther wastes received including sludge from other WWTPs and septic waste
	1.	Acceptance of sludge from other WWTPs
		Does or will the facility accept sludge from other treatment plants at the facility site?
		□ Yes ⊠ No
		If yes, attach sewage sludge solids management plan. See Example 5 of instructions.
		In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an
		estimate of the BOD ₅ concentration of the sludge, and the design BOD ₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
		Click to enter text.
		Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	2.	Acceptance of septic waste
		Is the facility accepting or will it accept septic waste?
		□ Yes ⊠ No
		If yes, does the facility have a Type V processing unit?
		□ Yes □ No
		If yes, does the unit have a Municipal Solid Waste permit?
		□ Yes □ No

]	If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD ₅ concentration of the septic waste, and the
	design BOD ₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
	Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)
	Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?
	□ Yes ⊠ No
	If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.
	Click to enter text.
Section	on 7. Pollutant Analysis of Treated Effluent (Instructions Page 49)
Is the f	facility in operation?
	Yes □ No
If no, t	his section is not applicable. Proceed to Section 8.
faciliti	provide effluent analysis data for the listed pollutants. <i>Wastewater treatment</i> es complete Table 1.0(2). <i>Water treatment facilities</i> discharging filter backwash water, etc Table 1.0(3). Provide copies of the laboratory results sheets. These tables are not

complete Table 1.0(3). Provide copies of the laboratory results sheets. **These tables are rapplicable for a minor amendment without renewal.** See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD ₅ , mg/l					
Total Suspended Solids, mg/l					
Ammonia Nitrogen, mg/l					
Nitrate Nitrogen, mg/l					
Total Kjeldahl Nitrogen, mg/l					
Sulfate, mg/l					
Chloride, mg/l					
Total Phosphorus, mg/l					
pH, standard units					
Dissolved Oxygen*, mg/l					
Chlorine Residual, mg/l					
E.coli (CFU/100ml) freshwater					
Entercocci (CFU/100ml) saltwater					
Total Dissolved Solids, mg/l					
Electrical Conductivity, µmohs/cm, †					
Oil & Grease, mg/l					
Alkalinity (CaCO ₃)*, mg/l					

^{*}TPDES permits only †TLAP permits only

Table1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l					0
Total Dissolved Solids, mg/l					
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO ₃), mg/l					

Section 8. Facility Operator (Instructions Page 49)

Facility Operator Name: Click to enter text.

Facility Operator's License Classification and Level: Click to enter text.

Facility Operator's License Number: Click to enter text.

Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 50)

Α.	WW.	WTP's Sewage Sludge or Biosolids Management Facility Type				
	Che	ck all that apply. See instructions for guidance				
		Design flow>= 1 MGD				
		Serves >= 10,000 people				
	profess.	Class I Sludge Management Facility (per 40 CFR § 503.9)				
		Biosolids generator				
		Biosolids end user - land application (onsite)				
		Biosolids end user - surface disposal (onsite)				
		Biosolids end user - incinerator (onsite)				
B.	ww	ΓP's Sewage Sludge or Biosolids Treatment Process				
	Che	ck all that apply. See instructions for guidance.				
		Aerobic Digestion				
		Air Drying (or sludge drying beds)				
		Lower Temperature Composting				
		Lime Stabilization				
		Higher Temperature Composting				
		Heat Drying				
		Thermophilic Aerobic Digestion				
		Beta Ray Irradiation				
		Gamma Ray Irradiation				
		Pasteurization				
		Preliminary Operation (e.g. grinding, de-gritting, blending)				
	1.	Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)				
		Sludge Lagoon				
		Temporary Storage (< 2 years)				
		Long Term Storage (>= 2 years)				
	П	Methane or Biogas Recovery				
		Other Treatment Process: Click to enter text.				

C. Sewage Sludge or Biosolids Management

Provide information on the *intended* sewage sludge or biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the

permit will authorize all sewage sludge or biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

Biosolids Management

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.

If "Other" is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): Click to enter text.

		-	
1)	Die	posal	CITA
L.	פוע	hosar	DICC

Disposal site name: Click to enter text.

TCEQ permit or registration number: <u>Click to enter text.</u>
County where disposal site is located: <u>Click to enter text.</u>

E. Transportation method

Method of transportation (truck, train, pipe, other): truck

Name of the hauler: <u>Brownville Navigation District</u>

Hauler registration number: 21816

Sludge is transported as a:

Liquid ⊠	semi-liquid 🗆	semi-solid \square	solid \square

Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 52)

A. Beneficial use authorization

Does t benefi			g permit include authorization for land application of biosolids for
	Yes	\boxtimes	No
If yes , benefi			equesting to continue this authorization to land apply biosolids for
	Yes		No
If was	ie the	com	polated Application for Dormit for Ranaficial Land Lice of Sawage

If yes, is the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451) attached to this permit application (see the instructions for details)?

	Yes	No
100000	1 00	 110

B.	Sludge	ge processing authorization							
		he existing permit inclu e or disposal options?	de authorization f	or any	of the	follow	ing slu	dge proces	sing,
	Slu	dge Composting	a ^a		Yes		No		
	Ma	rketing and Distribution	n of Biosolids		Yes	\boxtimes	No		
	Slu	dge Surface Disposal o	Sludge Monofill		Yes	\boxtimes	No		
	Ter	nporary storage in slud	ge lagoons		Yes		No	K.	
	author Techn	to any of the above sludication, is the complete ical Report (TCEQ Form	ed Domestic Waste n No. 10056) attac	water hed to	: Permi o this p	t Appl ermit a	ication applica	: Sewage S	
		11. Sewage Sludg		struc	ctions	Page	2 53)		
Do		facility include sewage	sludge lagoons?						
	□ Ye				_				
If y	es, con	nplete the remainder of	this section. If no,	proce	eed to S	Section	12.		
A.	Location	on information							
		llowing maps are requi e the Attachment Numl		d as p	art of tl	he app	licatior	ı. For each	map,
	•	Original General Highw	ay (County) Map:						
		Attachment: Click to e	nter text.						
	•	USDA Natural Resource	es Conservation Ser	rvice S	Soil Mar):			
		Attachment: Click to en	<u>nter text.</u>						
		Federal Emergency Mar							
		Attachment: Click to en	nter text.						
		Site map:							
		Attachment: Click to ex		•					
	Discus apply.	s in a description if any	of the following e	xist w	ithin th	ie lago	on area	a. Check all	that
		Overlap a designated 100-year frequency flood plain							
		Soils with flooding classification							
		Overlap an unstable a	rea						
		Wetlands							
		Located less than 60 r	neters from a fault						
		None of the above							
	Attachment: Click to enter text.								

If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide	1
the protective measures to be utilized including type and size of protective structures:	

N/A		
	Sec.	
	a	(4
	SAP A	

B. Temporary storage information

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in *Section 7 of Technical Report 1.0.*

Nitrate Nitrogen, mg/kg: Click to enter text.

Total Kjeldahl Nitrogen, mg/kg: Click to enter text.

Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: Click to enter text.

Phosphorus, mg/kg: Click to enter text.

Potassium, mg/kg: Click to enter text.

pH, standard units: Click to enter text.

Ammonia Nitrogen mg/kg: Click to enter text.

Arsenic: Click to enter text.

Cadmium: Click to enter text.

Chromium: Click to enter text.

Copper: Click to enter text.

Lead: Click to enter text.

Mercury: Click to enter text.

Molybdenum: Click to enter text.

Nickel: Click to enter text.

Selenium: Click to enter text.

Zinc: Click to enter text.

Total PCBs: <u>Click to enter text.</u>

Provide the following information:

Volume and frequency of sludge to the lagoon(s): Click to enter text.

Total dry tons stored in the lagoons(s) per 365-day period: Click to enter text.

Total dry tons stored in the lagoons(s) over the life of the unit: <u>Click to enter text.</u>

C. Liner information

Does the active,	/proposed	sludge	lagoon(s)	have a	liner	with a	ı maximum	hydraulic
conductivity of	1x10 ⁻⁷ cm/	'sec?						

12000		10.00	
125	Yes	1	No
	163	4.00	1111

330	If yes, describe the liner below. Please note that a liner is required.
	N/A
D.	Site development plan
	Provide a detailed description of the methods used to deposit sludge in the lagoon(s):
	N/A
	*
	Attach the following documents to the application.
	 Plan view and cross-section of the sludge lagoon(s)
	Attachment: Click to enter text.
	Copy of the closure plan
	Attachment: Click to enter text.
	 Copy of deed recordation for the site
	Attachment: Click to enter text.
	 Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons
	Attachment: Click to enter text.
	 Description of the method of controlling infiltration of groundwater and surface water from entering the site
	Attachment: Click to enter text.
	 Procedures to prevent the occurrence of nuisance conditions
	Attachment: Click to enter text.
E.	Groundwater monitoring
	Is groundwater monitoring currently conducted at this site, or are any wells available for groundwater monitoring, or are groundwater monitoring data otherwise available for the sludge lagoon(s)?
	□ Yes ⊠ No
	If groundwater monitoring data are available, provide a copy. Provide a profile of soil types encountered down to the groundwater table and the depth to the shallowest groundwater as a separate attachment.
	Attachment: Click to enter text.

Section 12. Authorizations/Compliance/Enforcement (Instructions Page 54)

A. Additional authorizations
Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?
□ Yes ⊠ No
If yes, provide the TCEQ authorization number and description of the authorization:
Click to enter text.
B. Permittee enforcement status
Is the permittee currently under enforcement for this facility?
□ Yes ⊠ No
Is the permittee required to meet an implementation schedule for compliance or enforcement?
□ Yes ⊠ No
If yes to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:
Click to enter text.
C . L 10 DODA (CEDCIA IV
Section 13. RCRA/CERCLA Wastes (Instructions Page 55)
A. RCRA hazardous wastes
Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

□ Yes ⊠ No

B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

□ Yes ⊠ No

C. Details about wastes received

If yes to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: Click to enter text.

Section 14. Laboratory Accreditation (Instructions Page 55)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25*, *Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - o periodically inspected by the TCEQ; or
 - o located in another state and is accredited or inspected by that state; or
 - o performing work for another company with a unit located in the same site; or
 - o performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Printed Name: <u>Manuel Martinez</u>
Title: Acting Director of Engineering

Signature:	
Date:	

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.1

The following information is required for new and amendment major applications.

Section 1. Justification for Permit (Instructions Page 56)

A.	Iustification	of permit need
7 7	JACOLARACACACACA	OI POILITE INCOM

B.

Provide a detailed discussion regarding the need for any phase(s) not currently permitted
Failure to provide sufficient justification may result in the Executive Director
recommending denial of the proposed phase(s) or permit.

rec	nmending denial of the proposed phase(s) or permit.
N	
Reg	onalization of facilities
	dditional guidance, please review $\underline{TCEQ's}$ Regionalization Policy for Wastewater \underline{ment}^1 .
	de the following information concerning the potential for regionalization of domestic water treatment facilities:
1.	unicipally incorporated areas
	the applicant is a city, then Item 1 is not applicable. Proceed to Item 2 Utility CCN eas.
	any portion of the proposed service area located in an incorporated city?
	□ Yes □ No □ Not Applicable
	yes, within the city limits of: <u>Click to enter text.</u>
	yes, attach correspondence from the city.
	Attachment: Click to enter text.
	consent to provide service is available from the city, attach a justification for the oposed facility and a cost analysis of expenditures that includes the cost of onnecting to the city versus the cost of the proposed facility or expansion attached.
	Attachment: Click to enter text.
2.	tility CCN areas
	any portion of the proposed service area located inside another utility's CCN area?
	□ Yes □ No

¹ https://www.tceq.texas.gov/permitting/wastewater/tceq-regionalization-for-wastewater

If yes, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the CCN facilities versus the cost of the proposed facility or expansion. Attachment: Click to enter text. 3. Nearby WWTPs or collection systems Are there any domestic permitted wastewater treatment facilities or collection systems located within a three-mile radius of the proposed facility? Yes \boxtimes No If yes, attach a list of these facilities and collection systems that includes each permittee's name and permit number, and an area map showing the location of these facilities and collection systems. Attachment: Click to enter text. If yes, attach proof of mailing a request for service to each facility and collection system, the letters requesting service, and correspondence from each facility and collection system. Attachment: Click to enter text. If the facility or collection system agrees to provide service, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the facility or collection system versus the cost of the proposed facility or expansion. Attachment: Click to enter text. **Proposed Organic Loading (Instructions Page 58)** Section 2. Is this facility in operation? Yes □ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading Facility Design Flow (flow being requested in application): Click to enter text. Average Influent Organic Strength or BOD₅ Concentration in mg/l: Click to enter text. Average Influent Loading (lbs/day = total average flow X average BOD₅ conc. X 8.34): Click to enter text. Provide the source of the average organic strength or BOD₅ concentration.

Click to enter text.

B. Proposed organic loading

This table must be completed if this application is for a facility that is not in operation or if this application is to request an increased flow that will impact organic loading.

Table 1.1(1) - Design Organic Loading

Source	Total Average Flow (MGD)	Influent BOD5 Concentration (mg/l)
Municipality		
Subdivision		
Trailer park - transient		
Mobile home park		
School with cafeteria and showers		
School with cafeteria, no showers		
Recreational park, overnight use		
Recreational park, day use		
Office building or factory		
Motel		
Restaurant		Н
Hospital		
Nursing home		
Other		
TOTAL FLOW from all sources		
AVERAGE BOD₅ from all sources		

Section 3. Proposed Effluent Quality and Disinfection (Instructions Page 58)

A. Existing/Interim I Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.

Total Suspended Solids, mg/l: Click to enter text.

Ammonia Nitrogen, mg/l: <u>Click to enter text.</u>

Total Phosphorus, mg/l: Click to enter text.

Dissolved Oxygen, mg/l: Click to enter text.

Other: Click to enter text.

В.	Interim II Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.
	Total Suspended Solids, mg/l: Click to enter text.
	Ammonia Nitrogen, mg/l: <u>Click to enter text.</u>
	Total Phosphorus, mg/l: <u>Click to enter text.</u>
	Dissolved Oxygen, mg/l: Click to enter text.
	Other: Click to enter text.
C.	Final Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.
	Total Suspended Solids, mg/l: Click to enter text.
	Ammonia Nitrogen, mg/l: Click to enter text.
	Total Phosphorus, mg/l: Click to enter text.
	Dissolved Oxygen, mg/l: <u>Click to enter text.</u>
	Other: Click to enter text.
D.	Disinfection Method
	Identify the proposed method of disinfection.
	\Box Chlorine: Click to enter text. mg/l after Click to enter text. minutes detention time at peak flow
	Dechlorination process: Click to enter text.
	☐ Ultraviolet Light: <u>Click to enter text.</u> seconds contact time at peak flow
	□ Other: Click to enter text.
Se	ction 4. Design Calculations (Instructions Page 58)
	tach design calculations and plant features for each proposed phase. Example 4 of the
	tructions includes sample design calculations and plant features.
	Attachment: Click to enter text.
So	ction 5. Facility Site (Instructions Page 59)
JC	ction 3. Tacinty site (instructions rage 33)
A.	100-year floodplain
	Will the proposed facilities be located <u>above</u> the 100-year frequency flood level?
	□ Yes □ No
	If no , describe measures used to protect the facility during a flood event. Include a site map showing the location of the treatment plant within the 100-year frequency flood level. If applicable, provide the size and types of protective structures.
	Click to enter text.

	Provide	e the source(s) used to determine 100-year frequency flood plain.
	Click	to enter text.
	For a n	ew or expansion of a facility, will a wetland or part of a wetland be filled?
		Yes □ No
	If yes,	has the applicant applied for a US Corps of Engineers 404 Dredge and Fill Permit?
		Yes □ No
	If yes,	provide the permit number: <u>Click to enter text.</u>
		provide the approximate date you anticipate submitting your application to the <u>Click to enter text.</u>
В.	Wind r	rose
	Attach	a wind rose: Click to enter text.
So	ction	6. Permit Authorization for Sewage Sludge Disposal
<i>5</i> €	ction	(Instructions Page 59)
A.	Benefi	cial use authorization
		u requesting to include authorization to land apply sewage sludge for beneficial use perty located adjacent to the wastewater treatment facility under the wastewater ?
		Yes □ No
		attach the completed Application for Permit for Beneficial Land Use of Sewage (TCEQ Form No. 10451): Click to enter text.
В.	Sludge	processing authorization
		y the sludge processing, storage or disposal options that will be conducted at the vater treatment facility:
		Sludge Composting
		Marketing and Distribution of sludge
		Sludge Surface Disposal or Sludge Monofill
	Waster	of the above, sludge options are selected, attach the completed Domestic water Permit Application: Sewage Sludge Technical Report (TCEQ Form No.): Click to enter text.
Se	ection	7. Sewage Sludge Solids Management Plan (Instructions Page 60)

Attach a solids management plan to the application.

Attachment: Click to enter text.

The sewage sludge solids management plan must contain the following information:

• Treatment units and processes dimensions and capacities

- Solids generated at 100, 75, 50, and 25 percent of design flow
- Mixed liquor suspended solids operating range at design and projected actual flow
- Quantity of solids to be removed and a schedule for solids removal
- Identification and ownership of the ultimate sludge disposal site
- For facultative lagoons, design life calculations, monitoring well locations and depths, and the ultimate disposal method for the sludge from the facultative lagoon

An example of a sewage sludge solids management plan has been included as Example 5 of the instructions.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

Section 1. Domestic Drinking Water Supply (Instructions Page 63)
Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?
□ Yes ⊠ No
If no , proceed it Section 2. If yes , provide the following:
Owner of the drinking water supply: Click to enter text.
Distance and direction to the intake: Click to enter text.
Attach a USGS map that identifies the location of the intake.
Attachment: Click to enter text.
Section 2. Discharge into Tidally Affected Waters (Instructions Page 63)
Does the facility discharge into tidally affected waters?
□ Yes ⊠ No
If no , proceed to Section 3. If yes , complete the remainder of this section. If no, proceed to Section 3.
A. Receiving water outfall
Width of the receiving water at the outfall, in feet: Click to enter text.
B. Oyster waters
Are there oyster waters in the vicinity of the discharge?
□ Yes □ No
If yes, provide the distance and direction from outfall(s).
Click to enter text.
C. Sea grasses
Are there any sea grasses within the vicinity of the point of discharge?
□ Yes □ No
If yes, provide the distance and direction from the outfall(s).
Click to enter text.

section 5. Classified segments (instructions rage 05)			
Is the discharge directly into (or within 300 feet of) a classified segment?			
□ Yes ⊠ No			
If yes, this Worksheet is complete.			
If no, complete Sections 4 and 5 of this Worksheet.			
Section 4. Description of Immediate Receiving Waters (Instructions			
Page 63)			
Name of the immediate receiving waters: <u>Click to enter text.</u>			
A. Receiving water type			
Identify the appropriate description of the receiving waters.			
□ Stream			
☐ Freshwater Swamp or Marsh			
□ Lake or Pond			
Surface area, in acres: Click to enter text.			
Average depth of the entire water body, in feet: Click to enter text.			
Average depth of water body within a 500-foot radius of discharge point, in feet Click to enter text.			
Man-made Channel or Ditch			
□ Open Bay			
□ Tidal Stream, Bayou, or Marsh			
□ Other, specify: <u>Click to enter text.</u>			
B. Flow characteristics			
If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area <i>upstream</i> of the discharge. For new discharges, characterize the area <i>downstream</i> of the discharge (check one).			
☑ Intermittent - dry for at least one week during most years			
\square Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses			
☐ Perennial - normally flowing			
Check the method used to characterize the area upstream (or downstream for new dischargers).			
□ USGS flow records			
☐ Historical observation by adjacent landowners			
□ Personal observation			
Other, specify: Click to enter text.			

C.	C. Downstream perennial confluences						
	List the names of all perennial streams that join the receiving water within three miles downstream of the discharge point.						
	Click to enter text.						
	105						
D.	D. Downstream characteristics						
		receiving water characteristics char rge (e.g., natural or man-made dams		rithin three miles downstream of the ads, reservoirs, etc.)?			
		Yes ⊠ No					
	If yes,	discuss how.					
	Click	to enter text.		566			
E.	Norma	l dry weather characteristics					
(STORE)	Provide general observations of the water body during normal dry weather conditions.						
	Click to enter text.						
	Date a	nd time of observation: Click to ente	er tex	ct.			
	Was th	e water body influenced by stormwa	ater 1	runoff during observations?			
		Yes □ No					
	District Control						
Se	ection	5. General Characteristics Page 65)	s of	the Waterbody (Instructions			
Α.	Upstre	eam influences					
		mmediate receiving water upstream need by any of the following? Check		he discharge or proposed discharge site nat apply.			
		Oil field activities	\boxtimes	Urban runoff			
		Upstream discharges		Agricultural runoff			
		Septic tanks		Other(s), specify: Click to enter text.			

B.	wateri	aterbody uses				
	Observ	oserved or evidences of the following uses. Check all that apply.				
		Livestock watering		Contact recreation		
		Irrigation withdrawal		Non-contact recreation		
		Fishing		Navigation		
		Domestic water supply		Industrial water supply		
		Park activities		Other(s), specify: Click to enter text.		
C.	Waterk	oody aesthetics				
		k one of the following that best describes the aesthetics of the receiving water and urrounding area.				
		Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional				
		Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored				
		Common Setting: not offensive; developed but uncluttered; water may be colored or turbid				
		Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored				

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.1: STREAM PHYSICAL CHARACTERISTICS

Required for new applications, major facilities, and applications adding an outfall.

Worksheet 2.1 is not required for discharges to intermittent streams or discharges directly to (or within 300 feet of) a classified segment.

Section 1. General information (instructions Page 63)					
Date of study: Click to enter text. Time of study: Click to enter text.					
Stream name: Click to enter text.					
Location: Click to enter text.					
Type of stream upstream of existing discharge or downstream of proposed discharge (check one).					
□ Perennial □ Intermittent with perennial pools					
Section 2. Data Collection (Instructions Page 65)					
Number of stream bends that are well defined: Click to enter text.					
Number of stream bends that are moderately defined: Click to enter text.					
Number of stream bends that are poorly defined: Click to enter text.					
Number of riffles: Click to enter text.					
Evidence of flow fluctuations (check one):					
□ Minor □ moderate □ severe					
Indicate the observed stream uses and if there is evidence of flow fluctuations or channel obstruction/modification.					
Click to enter text.					

Stream transects

In the table below, provide the following information for each transect downstream of the existing or proposed discharges. Use a separate row for each transect.

Table 2.1(1) - Stream Transect Records

Stream type at transect	Transect location	Water surface	Stream depths (ft) at 4 to 10 points along each
Select riffle, run, glide, or pool. See Instructions,		width (ft)	transect from the channel bed to the water surface. Separate the measurements
Definitions section.			with commas.
Choose an item.			
Choose an item.			9
Choose an item.			

Section 3. Summarize Measurements (Instructions Page 65)

Streambed slope of entire reach, from USGS map in feet/feet: Click to enter text.

Approximate drainage area above the most downstream transect (from USGS map or county highway map, in square miles): <u>Click to enter text.</u>

Length of stream evaluated, in feet: Click to enter text.

Number of lateral transects made: Click to enter text.

Average stream width, in feet: Click to enter text.

Average stream depth, in feet: Click to enter text.

Average stream velocity, in feet/second: Click to enter text.

Instantaneous stream flow, in cubic feet/second: Click to enter text.

Indicate flow measurement method (type of meter, floating chip timed over a fixed distance, etc.): <u>Click to enter text.</u>

Size of pools (large, small, moderate, none): Click to enter text.

Maximum pool depth, in feet: Click to enter text.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.0: LAND DISPOSAL OF EFFLUENT

The following is required for renewal, new, and amendment permit applications.

Section 1. Type of Disposal System (Instructions Page 67)

Identify the method of land disposal:				
	Surface application		Subsurface application	
	Irrigation		Subsurface soils absorption	
	Drip irrigation system		Subsurface area drip dispersal system	
100	Evaporation		Evapotranspiration beds	
	Other (describe in detail): <u>Click to enter text.</u>			
NOTE: All applicants without authorization or proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0.				
Parameter Vie	and the second s			

For existing authorizations, provide Registration Number: Click to enter text.

Section 2. Land Application Site(s) (Instructions Page 67)

In table 3.0(1), provide the requested information for the land application sites. Include the agricultural or cover crop type (wheat, cotton, alfalfa, bermuda grass, native grasses, etc.), land use (golf course, hayland, pastureland, park, row crop, etc.), irrigation area, amount of effluent applied, and whether or not the public has access to the area. Specify the amount of land area and the amount of effluent that will be allotted to each agricultural or cover crop, if more than one crop will be used.

Table 3.0(1) - Land Application Site Crops

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N

Section 3. Storage and Evaporation Lagoons/Ponds (Instructions Page 67)

Table 3.0(2) - Storage and Evaporation Ponds

Pond Number	Surface Area (acres)	Storage Volume (acre-feet)	Dimensions	Liner Type
D.				

Attach a copy of a liner certification that was prepared, signed, and sealed by a Texas licensed professional engineer for each pond.

licensed professional engineer for each pond.
Attachment: Click to enter text.
Section 4. Flood and Runoff Protection (Instructions Page 67)
Is the land application site within the 100-year frequency flood level?
□ Yes □ No
If yes, describe how the site will be protected from inundation.
Click to enter text.
Provide the source used to determine the 100-year frequency flood level:
Click to enter text.
_ #
Provide a description of tailwater controls and rainfall run-on controls used for the land application site.
Click to enter text.

Section 5. Annual Cropping Plan (Instructions Page 67)

Attach an Annual Cropping Plan which includes a discussion of each of the following items. If not applicable, provide a detailed explanation indicating why. **Attachment**: Click to enter text.

- Soils map with crops
- Cool and warm season plant species
- Crop yield goals
- Crop growing season
- Crop nutrient requirements
- · Additional fertilizer requirements
- Minimum/maximum harvest height (for grass crops)
- Supplemental watering requirements
- Crop salt tolerances
- Harvesting method/number of harvests
- Justification for not removing existing vegetation to be irrigated

Section 6. Well and Map Information (Instructions Page 68)

Attach a USGS map with the following information shown and labeled. If not applicable, provide a detailed explanation indicating why. **Attachment**: <u>Click to enter text.</u>

- The boundaries of the land application site(s)
- Waste disposal or treatment facility site(s)
- On-site buildings
- Buffer zones
- Effluent storage and tailwater control facilities
- All water wells within 1-mile radius of the disposal site or property boundaries
- All springs and seeps onsite and within 500 feet of the property boundaries
- All surface waters in the state onsite and within 500 feet of the property boundaries
- All faults and sinkholes onsite and within 500 feet of the property

List and cross reference all water wells located within a half-mile radius of the disposal site or property boundaries shown on the USGS map in the following table. Attach additional pages as necessary to include all of the wells.

Table 3.0(3) - Water Well Data

Well ID	Well Use	Producing? Y/N	Open, cased, capped, or plugged?	Proposed Best Management Practice
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	

If water quality data or well log information is available please include the information in an attachment listed by Well ID.

Attachment: Click to enter text.

Section 7. Groundwater Quality (Instructions Page 68)

Attach a Groundwater Quality Technical Report which assesses the impact of the wastewater disposal system on groundwater. This report shall include an evaluation of the water wells (including the information in the well table provided in Item 6. above), the wastewater application rate, and pond liners. Indicate by a check mark that this report is provided.

Attachment: Click to enter text.
Are groundwater monitoring wells available onsite? \square Yes \square No
Do you plan to install ground water monitoring wells or lysimeters around the land application site? \Box Yes \Box No
If yes, provide the proposed location of the monitoring wells or lysimeters on a site map.
Attachment: Click to enter text.

Section 8. Soil Map and Soil Analyses (Instructions Page 69)

A. Soil map

Attach a USDA Soil Survey map that shows the area to be used for effluent disposal.

Attachment: Click to enter text.

B. Soil analyses

Attach the laboratory results sheets from the soil analyses. **Note**: for renewal applications, the current annual soil analyses required by the permit are acceptable as long as the test date is less than one year prior to the submission of the application.

Attachment: Click to enter text.

List all USDA designated soil series on the proposed land application site. Attach additional pages as necessary.

Table 3.0(4) - Soil Data

Soil Series	Depth from Surface	Permeability	Available Water Capacity	Curve Number
				·

Section 9. Effluent Monitoring Data (Instructions Page 70)

□ Yes □					_	
	on is not applica					
yes, provide t ermit. If a para	the effluent mo ameter is not re	nitoring o gulated i	data for the n the exist	ie parame ting perm	eters regulated in th nit, enter N/A.	ne existing
able 3.0(5) – Ef	ffluent Monitorin	ng Data			×	
Date	30 Day Avg Flow MGD	BOD5 mg/l	TSS mg/l	рН	Chlorine Residual mg/l	Acres irrigated
					-	
					F	
1812						
			8			
•						
Turbe (
						V.
	1					
						x
44						
	1	25				

Provide a discussion of all persistent excursions above the permitted limits and any corrective actions taken.
Click to enter text.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.1: SURFACE LAND DISPOSAL OF EFFLUENT

The following is required for new and major amendment permit applications. Renewal and minor amendment permit applications may be asked for this worksheet on a case by case basis.

Section 1. Surface Disposal (Instructions Page 71)

Complete the item that applies for the method of disposal being used.

A. Irrigation

Area under irrigation, in acres: Click to enter text.

Design application frequency:

hours/day Click to enter text. And days/week Click to enter text.

Land grade (slope):

average percent (%): Click to enter text.

maximum percent (%): Click to enter text.

Design application rate in acre-feet/acre/year: Click to enter text.

Design total nitrogen loading rate, in lbs N/acre/year: Click to enter text.

Soil conductivity (mmhos/cm): Click to enter text.

Method of application: <u>Click to enter text.</u>

Attach a separate engineering report with the water balance and storage volume calculations, method of application, irrigation efficiency, and nitrogen balance.

Attachment: Click to enter text.

B. Evaporation ponds

Daily average effluent flow into ponds, in gallons per day: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations.

Attachment: Click to enter text.

C. Evapotranspiration beds

Number of beds: Click to enter text.

Area of bed(s), in acres: <u>Click to enter text.</u>

Depth of bed(s), in feet: Click to enter text.

Void ratio of soil in the beds: <u>Click to enter text.</u>

Storage volume within the beds, in acre-feet: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations, and a description of the lining.

Attachment: Click to enter text.

D	Over	bacl	FLOXA
v.	Over	Idliu	HOW

Area used for application, in acres: Click to enter text.

Slopes for application area, percent (%): Click to enter text.

Design application rate, in gpm/foot of slope width: Click to enter text.

Slope length, in feet: Click to enter text.

Design BOD₅ loading rate, in lbs BOD₅/acre/day: Click to enter text.

Design application frequency:

hours/day: Click to enter text. And days/week: Click to enter text.

Attach a separate engineering report with the method of application and design requirements according to *30 TAC Chapter 217*.

Attachment: Click to enter text.

Section 2. Edwards Aquifer (Instructions Page 72)

Is the facility sub	ject to 30	TAC C	hapter 213,	Edwards Ad	uifer	Rules?
---------------------	------------	-------	-------------	------------	-------	--------

□ Yes □ No

If yes, is the facility located on the Edwards Aquifer Recharge Zone?

□ Yes □ No

If yes, attach a geological report addressing potential recharge features.

Attachment: Click to enter text.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.2: SURFACE LAND DISPOSAL OF EFFLUENT

The following **is required** for **new and major amendment** permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **does not meet** the definition of a subsurface area drip dispersal system as defined in *30 TAC Chapter 222, Subsurface Area Drip Dispersal System.*

Section 1. Subsurface Application (Instructions Page 73)
Identify the type of system:
□ Conventional Gravity Drainfield, Beds, or Trenches (new systems must be less than 5,000 GPD)
□ Low Pressure Dosing
☐ Other, specify: <u>Click to enter text.</u>
Application area, in acres: Click to enter text.
Area of drainfield, in square feet: Click to enter text.
Application rate, in gal/square foot/day: Click to enter text.
Depth to groundwater, in feet: Click to enter text.
Area of trench, in square feet: Click to enter text.
Dosing duration per area, in hours: Click to enter text.
Number of beds: Click to enter text.
Dosing amount per area, in inches/day: Click to enter text.
Infiltration rate, in inches/hour: Click to enter text.
Storage volume, in gallons: <u>Click to enter text.</u>
Area of bed(s), in square feet: Click to enter text.
Soil Classification: Click to enter text.
Attach a separate engineering report with the information required in $30\ TAC\ \S\ 309.20$, excluding the requirements of $\S\ 309.20\ b(3)(A)$ and (B) design analysis which may be asked for on a case by case basis. Include a description of the schedule of dosing basin rotation.
Attachment: Click to enter text.
Section 2. Edwards Aquifer (Instructions Page 73)
Is the subsurface system over the Edwards Aquifer Recharge Zone as mapped by TCEQ?
□ Yes □ No
Is the subsurface system over the Edwards Aquifer Transition Zone as mapped by TCEQ?
□ Yes □ No
If yes to either question , the subsurface system may be prohibited by <i>30 TAC §213.8</i> . Please

call the Municipal Permits Team, at 512-239-4671, to schedule a pre-application meeting.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.3: SUBSURFACE AREA DRIP DISPERSAL (SADDS) LAND DISPOSAL OF EFFLUENT

The following **is required** for **new and major amendment** subsurface area drip dispersal system permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **meets** the definition of a subsurface area drip dispersal system as defined in *30 TAC Chapter 222*, *Subsurface Area Drip Dispersal System*.

Se	ection 1. Administrative Information (Instructions Page 74)
Α.	Provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the treatment facility:
В.	<u>Click to enter text.</u> Is the owner of the land where the treatment facility is located the same as the owner of the treatment facility?
	□ Yes □ No
	If no , provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the land where the treatment facility is located.
	Click to enter text.
C.	Owner of the subsurface area drip dispersal system: Click to enter text.
D.	Is the owner of the subsurface area drip dispersal system the same as the owner of the wastewater treatment facility or the site where the wastewater treatment facility is located?
	□ Yes □ No
	If no , identify the names of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in Item 1.C.
	Click to enter text.
Е.	Owner of the land where the subsurface area drip dispersal system is located: <u>Click to enter text.</u>
F.	Is the owner of the land where the subsurface area drip dispersal system is located the same as owner of the wastewater treatment facility, the site where the wastewater treatment facility is located, or the owner of the subsurface area drip dispersal system?
	□ Yes □ No
	If no , identify the name of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in item 1.E.
	Click to enter text.

Section 2. Subsurface Area Drip Dispersal System (Instructions Page 74)

A.	Type of system
	□ Subsurface Drip Irrigation
	□ Surface Drip Irrigation
	□ Other, specify: <u>Click to enter text.</u>
B.	Irrigation operations
	Application area, in acres: Click to enter text.
	Infiltration Rate, in inches/hour: Click to enter text.
	Average slope of the application area, percent (%): Click to enter text.
	Maximum slope of the application area, percent (%): Click to enter text.
	Storage volume, in gallons: <u>Click to enter text.</u>
	Major soil series: <u>Click to enter text.</u>
	Depth to groundwater, in feet: Click to enter text.
C.	Application rate
	Is the facility located west of the boundary shown in <i>30 TAC § 222.83</i> and also using a vegetative cover of non-native grasses over seeded with cool season grasses during the winter months (October-March)?
	□ Yes □ No
	If yes , then the facility may propose a hydraulic application rate not to exceed 0.1 gal/square foot/day.
	Is the facility located east of the boundary shown in <i>30 TAC § 222.83</i> or in any part of the state when the vegetative cover is any crop other than non-native grasses?
	□ Yes □ No
	If yes , the facility must use the formula in $30\ TAC\ \S 222.83$ to calculate the maximum hydraulic application rate.
	Do you plan to submit an alternative method to calculate the hydraulic application rate for approval by the executive director?
	□ Yes □ No
	Hydraulic application rate, in gal/square foot/day: Click to enter text.
	Nitrogen application rate, in lbs/gal/day: Click to enter text.
D.	Dosing information
	Number of doses per day: Click to enter text.
	Dosing duration per area, in hours: Click to enter text.
	Rest period between doses, in hours: Click to enter text.
	Dosing amount per area, in inches/day: Click to enter text.

Number of zones: Click to enter text.
Does the proposed subsurface drip irrigation system use tree vegetative cover as a crop?
□ Yes □ No
If yes , provide a vegetation survey by a certified arborist. Please call the Water Quality Assessment Team at (512) 239-4671 to schedule a pre-application meeting.
Attachment: Click to enter text.

Section 3. Required Plans (Instructions Page 74)

A. Recharge feature plan

Attach a Recharge Feature Plan with all information required in 30 TAC §222.79.

Attachment: Click to enter text.

B. Soil evaluation

Attach a Soil Evaluation with all information required in 30 TAC §222.73.

Attachment: Click to enter text.

C. Site preparation plan

Attach a Site Preparation Plan with all information required in 30 TAC §222.75.

Attachment: Click to enter text.

D. Soil sampling/testing

Attach soil sampling and testing that includes all information required in *30 TAC §222.157*.

Attachment: Click to enter text.

Section 4. Floodway Designation (Instructions Page 75)

A. Site location

Is the existing/proposed land application site within a designated floodway?

□ Yes □ No

B. Flood map

Attach either the FEMA flood map or alternate information used to determine the floodway.

Attachment: Click to enter text.

Section 5. Surface Waters in the State (Instructions Page 75)

A. Buffer Map

Attach a map showing appropriate buffers on surface waters in the state, water wells, and springs/seeps.

Attachment: Click to enter text.

B. Buffer variance request
Do you plan to request a buffer variance from water wells or waters in the state?
□ Yes □ No
If yes, then attach the additional information required in $30\ TAC\ \S\ 222.81(c)$.
Attachment: Click to enter text.
Section 6. Edwards Aquifer (Instructions Page 75)
A. Is the SADDS located over the Edwards Aquifer Recharge Zone as mapped by TCEQ? ☐ Yes ☐ No
and and

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 4.0: POLLUTANT ANALYSIS REQUIREMENTS

The following **is required** for facilities with a permitted or proposed flow of **1.0 MGD or greater**, facilities with an approved **pretreatment** program, or facilities classified as a **major** facility. See instructions for further details.

This worksheet is not required minor amendments without renewal.

Section 1. Toxic Pollutants (Instructions Page 76)

For pollutan	ts identified in T	Table 4.0(1),	indicate the	type of sample	<u>.</u>
Grab □	Composite □				

Date and time sample(s) collected: Click to enter text.

Table 4.0(1) - Toxics Analysis

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acrylonitrile				50
Aldrin				0.01
Aluminum				2.5
Anthracene				10
Antimony				5
Arsenic				0.5
Barium				3
Benzene				10
Benzidine	e e			50
Benzo(a)anthracene				5
Benzo(a)pyrene				5
Bis(2-chloroethyl)ether			2,	10
Bis(2-ethylhexyl)phthalate				10
Bromodichloromethane			+	10
Bromoform				10
Cadmium	1500			1
Carbon Tetrachloride				2
Carbaryl				5
Chlordane*		1010		0.2
Chlorobenzene			27	10
Chlorodibromomethane				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (μg/l)	Number of Samples	MAL (μg/l)
Chloroform				10
Chlorpyrifos				0.05
Chromium (Total)				3
Chromium (Tri) (*1)				N/A
Chromium (Hex)				3
Copper				2
Chrysene				5
p-Chloro-m-Cresol				10
4,6-Dinitro-o-Cresol				50
p-Cresol				10
Cyanide (*2)				10
4,4'- DDD				0.1
4,4'- DDE				0.1
4,4'- DDT				0.02
2,4-D				0.7
Demeton (O and S)				0.20
Diazinon				0.5/0.1
1,2-Dibromoethane				10
m-Dichlorobenzene				10
o-Dichlorobenzene				10
p-Dichlorobenzene				10
3,3'-Dichlorobenzidine				5
1,2-Dichloroethane				10
1,1-Dichloroethylene	Α			10
Dichloromethane				20
1,2-Dichloropropane				10
1,3-Dichloropropene				10
Dicofol				1
Dieldrin				0.02
2,4-Dimethylphenol				10
Di-n-Butyl Phthalate				10
Diuron				0.09
Endosulfan I (alpha)				0.01

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (μg/l)	Number of Samples	MAL (μg/l)
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Epichlorohydrin			*******	
Ethylbenzene				10
Ethylene Glycol				
Fluoride				500
Guthion				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclohexane (alpha)	25			0.05
Hexachlorocyclohexane (beta)				0.05
gamma-Hexachlorocyclohexane				0.05
(Lindane)		,		
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Hexachlorophene				10
4,4'-Isopropylidenediphenol				1
Lead				0.5
Malathion				0.1
Mercury				0.005
Methoxychlor				2
Methyl Ethyl Ketone			30.0	50
Methyl tert-butyl ether		77		-
Mirex				0.02
Nickel				2
Nitrate-Nitrogen				100
Nitrobenzene				10
N-Nitrosodiethylamine				20
N-Nitroso-di-n-Butylamine				20
Nonylphenol				333

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Parathion (ethyl)				0.1
Pentachlorobenzene				20
Pentachlorophenol				5
Phenanthrene				10
Polychlorinated Biphenyls (PCB's) (*3)				0.2
Pyridine				20
Selenium				5
Silver				0.5
1,2,4,5-Tetrachlorobenzene				20
1,1,2,2-Tetrachloroethane				10
Tetrachloroethylene				10
Thallium				0.5
Toluene				10
Toxaphene				0.3
2,4,5-TP (Silvex)				0.3
Tributyltin (see instructions for explanation)		2:		0.01
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene	,			10
2,4,5-Trichlorophenol				50
TTHM (Total Trihalomethanes)				10
Vinyl Chloride				10
Zinc				5

^(*1) Determined by subtracting hexavalent Cr from total Cr.

^(*2) Cyanide, amenable to chlorination or weak-acid dissociable.

^(*3) The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

Section 2. Priority Pollutants

For pollutants	s identified in	Tables	4.0(2)A-E	indicate	type	of	sample.
----------------	-----------------	---------------	-----------	----------	------	----	---------

Grab □ Composite □

Date and time sample(s) collected: Click to enter text.

Table 4.0(2)A - Metals, Cyanide, and Phenols

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Antimony				5
Arsenic				0.5
Beryllium				0.5
Cadmium				1
Chromium (Total)				3
Chromium (Hex)				3
Chromium (Tri) (*1)				N/A
Copper				2
Lead				0.5
Mercury	×			0.005
Nickel				2
Selenium	-			5
Silver				0.5
Thallium				0.5
Zinc				5
Cyanide (*2)				10
Phenols, Total				10

^(*1) Determined by subtracting hexavalent Cr from total Cr.

^(*2) Cyanide, amenable to chlorination or weak-acid dissociable

Table 4.0(2)B - Volatile Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrolein				50
Acrylonitrile				50
Benzene				10
Bromoform				10
Carbon Tetrachloride				2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroethane				50
2-Chloroethylvinyl Ether				10
Chloroform				10
Dichlorobromomethane [Bromodichloromethane]				10
1,1-Dichloroethane				10
1,2-Dichloroethane				10
1,1-Dichloroethylene				10
1,2-Dichloropropane				10
1,3-Dichloropropylene				10
[1,3-Dichloropropene]				
1,2-Trans-Dichloroethylene				10
Ethylbenzene				10
Methyl Bromide				50
Methyl Chloride				50
Methylene Chloride				20
1,1,2,2-Tetrachloroethane				10
Tetrachloroethylene				10
Toluene				10
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene				10
Vinyl Chloride				10

Table 4.0(2)C - Acid Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2-Chlorophenol				10
2,4-Dichlorophenol				10
2,4-Dimethylphenol				10
4,6-Dinitro-o-Cresol				50
2,4-Dinitrophenol				50
2-Nitrophenol		ii.		20
4-Nitrophenol				50
P-Chloro-m-Cresol	- A			10
Pentalchlorophenol				5
Phenol				10
2,4,6-Trichlorophenol				10

Table 4.0(2)D - Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acenaphthene				10
Acenaphthylene				10
Anthracene				10
Benzidine				50
Benzo(a)Anthracene				5
Benzo(a)Pyrene				5
3,4-Benzofluoranthene				10
Benzo(ghi)Perylene				20
Benzo(k)Fluoranthene				5
Bis(2-Chloroethoxy)Methane				10
Bis(2-Chloroethyl)Ether				10
Bis(2-Chloroisopropyl)Ether				10
Bis(2-Ethylhexyl)Phthalate			TI TI	10
4-Bromophenyl Phenyl Ether				10
Butyl benzyl Phthalate				10
2-Chloronaphthalene				10
4-Chlorophenyl phenyl ether				10
Chrysene				5
Dibenzo(a,h)Anthracene				5
1,2-(o)Dichlorobenzene				10
1,3-(m)Dichlorobenzene				10
1,4-(p)Dichlorobenzene				10
3,3-Dichlorobenzidine				5
Diethyl Phthalate				10
Dimethyl Phthalate				10
Di-n-Butyl Phthalate				10
2,4-Dinitrotoluene				10
2,6-Dinitrotoluene				10
Di-n-Octyl Phthalate				10
1,2-Diphenylhydrazine (as Azobenzene)			8	20
Fluoranthene				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Fluorene				10
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclo-pentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene		85		5
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10

Table 4.0(2)E - Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Aldrin		2.00.00		0.01
alpha-BHC (Hexachlorocyclohexane)				0.05
beta-BHC (Hexachlorocyclohexane)				0.05
gamma-BHC (Hexachlorocyclohexane)	9			0.05
delta-BHC (Hexachlorocyclohexane)				0.05
Chlordane				0.2
4,4-DDT				0.02
4,4-DDE				0.1
4,4,-DDD				0.1
Dieldrin				0.02
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Endrin Aldehyde		4		0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
PCB-1242			55	0.2
PCB-1254			,	0.2
PCB-1221				0.2
PCB-1232				0.2
PCB-1248				0.2
PCB-1260				0.2
PCB-1016				0.2
Toxaphene				0.3

^{*} For PCBS, if all are non-detects, enter the highest non-detect preceded by a "<".

A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user. Check all that apply. 2,4,5-trichlorophenoxy acetic acid Common Name 2,4,5-T, CASRN 93-76-5 2-(2,4,5-trichlorophenoxy) propanoic acid Common Name Silvex or 2,4,5-TP, CASRN 93-72-1 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate Common Name Erbon, CASRN 136-25-4 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate Common Name Ronnel, CASRN 299-84-3 2,4,5-trichlorophenol Common Name TCP, CASRN 95-95-4 hexachlorophene Common Name HCP, CASRN 70-30-4 For each compound identified, provide a brief description of the conditions of its/their presence at the facility. Click to enter text. B. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent? Yes No If yes, provide a brief description of the conditions for its presence. Click to enter text.

Section 3. Dioxin/Furan Compounds

C.	C. If any of the compounds in S	ubsection A or B are present, complete Table 4.0(2)F.
	For pollutants identified in T	able 4.0(2)F, indicate the type of sample.
	Grab □ Composite □	
	Date and time sample(s) colle	ected: <u>Click to enter text.</u>

Table 4.0(2)F - Dioxin/Furan Compounds

Compound	Toxic Equivalenc y Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
2,3,7,8 TCDD	1					10
1,2,3,7,8 PeCDD	0.5					50
2,3,7,8 HxCDDs	0.1			*	311143	50
1,2,3,4,6,7,8 HpCDD	0.01	12				50
2,3,7,8 TCDF	0.1			8		10
1,2,3,7,8 PeCDF	0.05					50
2,3,4,7,8 PeCDF	0.5					50
2,3,7,8 HxCDFs	0.1					50
2,3,4,7,8 HpCDFs	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					0.5
PCB 81	0.0003					0.5
PCB 126	0.1					0.5
PCB 169	0.03					0.5
Total						

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 5.0: TOXICITY TESTING REQUIREMENTS

The following **is required** for facilities with a current operating design flow of **1.0 MGD or greater**, with an EPA-approved **pretreatment** program (or those required to have one under 40 CFR Part 403), or are required to perform Whole Effluent Toxicity testing. See Page 86 of the instructions for further details.

This worksheet is not required minor amendments without renewal.

Section	1.	Rea	uired	Tests
the state of the state of the state of	THE REAL PROPERTY.	The second second second	The second second	

Indicate the number of 7-day chronic or 48-hour acute Whole Effluent Toxicity (WET) tests performed in the four and one-half years prior to submission of the application.

7-day Chronic: <u>Click to enter text.</u> 48-hour Acute: <u>Click to enter text.</u>

Section 2.	Toxicity Reduction Evaluations (TREs)
Has this facility performing a TR	completed a TRE in the past four and a half years? Or is the facility currently E?
□ Yes □	No
If yes, describe	the progress to date, if applicable, in identifying and confirming the toxicant.
Click to enter to	ext.

Section 3. Summary of WET Tests

If the required biomonitoring test information has not been previously submitted via both the Discharge Monitoring Reports (DMRs) and the Table 1 (as found in the permit), provide a summary of the testing results for all valid and invalid tests performed over the past four and one-half years. Make additional copies of this table as needed.

Table 5.0(1) Summary of WET Tests

Test Date	Test Species	NOEC Survival	NOEC Sub-lethal
-			
		77, 20	
- <u>172</u> 7			
		0	

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following is required for all publicly owned treatment works.

Section 1. All POTWs (Instructions Page 87)

A.	Industrial	users	(IUs)
			(,

Provide the number of each of the following types of industrial users (IUs) that discharge to your POTW and the daily flows from each user. See the Instructions for definitions of Categorical IUs, Significant IUs – non-categorical, and Other IUs.

B. Treatment plant interference

instructions)?

	Yes		No							
possib	le sou	rce(s	e dates,) of eacl erence.	duration interfer	n, descrij ence eve	ption of in ent. Includ	nterferend de the nar	ce, and pr nes of th	robable o e IUs tha	ause(s) and t may have
Click	to ent	er te	xt.			0				

In the past three years, has your POTW experienced treatment plant interference (see

C.	Treatment plant pass through
	In the past three years, has your POTW experienced pass through (see instructions)?
	□ Yes ⊠ No
	If yes, identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.
	Click to enter text.
D.	Pretreatment program
	Does your POTW have an approved pretreatment program?
	□ Yes □ No
	If yes, complete Section 2 only of this Worksheet.
	Is your POTW required to develop an approved pretreatment program?
	□ Yes □ No
	If yes, complete Section 2.c. and 2.d. only, and skip Section 3.
	If no to either question above , skip Section 2 and complete Section 3 for each significant industrial user and categorical industrial user.
Se	ection 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 87)
A.	Substantial modifications
	Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to <i>40 CFR §403.18</i> ?
	□ Yes ⊠ No
	If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
	Click to enter text.
	e a

B.	Non-substantial n	nodifications			
		ny non-substantial e not been submitte			
	□ Yes □	No			
	If yes, identify all including the purp	non-substantial mo oose of the modifica	difications that ation.	have not been	submitted to TCEQ,
	Click to enter tex	t.		x	
					3
C.	Effluent paramete	ers above the MAL			
	In Table 6.0(1), list	t all parameters me	asured above th	e MAL in the PO	OTW's effluent
	monitoring during	the last three year	s. Submit an att	achment if nece	essary.
Tal	ble 6.0(1) – Paramet	ters Above the MAL			
P	ollutant	Concentration	MAL	Units	Date
				0.0	
		11			
D.	Industrial user int	erruntions			
	Has any SIU, CIU, o	or other IU caused ouses throughs) at you	or contributed to ir POTW in the i	o any problems past three years	(excluding
	and burn	No			
		industry, describe nd probable polluta		icluding dates,	duration, description
	Click to enter text	l.			
					,
	20				
	Al.				

Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 88)

A.	General information
	Company Name: Click to enter text.
	SIC Code: Click to enter text.
	Contact name: <u>Click to enter text.</u>
	Address: Click to enter text.
	City, State, and Zip Code: <u>Click to enter text.</u>
	Telephone number: Click to enter text.
	Email address: Click to enter text.
В.	Process information
	Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).
	Click to enter text.
C.	Product and service information
	Provide a description of the principal product(s) or services performed.
	Click to enter text.
D.	Flow rate information
	See the Instructions for definitions of "process" and "non-process wastewater."
	Dec the motivations for decimations of productions
	Process Wastewater:
	Process Wastewater: Discharge, in gallons/day: Click to enter text.
	Process Wastewater: Discharge, in gallons/day: Click to enter text.
	Process Wastewater: Discharge, in gallons/day: <u>Click to enter text.</u> Discharge Type: □ Continuous □ Batch □ Intermittent Non-Process Wastewater:
	Process Wastewater: Discharge, in gallons/day: Click to enter text. Discharge Type: \square Continuous \square Batch \square Intermittent

E.	Pretreatment standards
	Is the SIU or CIU subject to technically based local limits as defined in the <i>i</i> nstructions?
	□ Yes □ No
	Is the SIU or CIU subject to categorical pretreatment standards found in $40\ CFR\ Parts\ 405-471$?
	□ Yes □ No
	If subject to categorical pretreatment standards , indicate the applicable category and subcategory for each categorical process.
	Category: Subcategories: Click to enter text.
	Click or tap here to enter text. Click to enter text.
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
	Category: <u>Click to enter text.</u>
	Subcategories: <u>Click to enter text.</u>
	Category: <u>Click to enter text.</u>
	Subcategories: <u>Click to enter text.</u>
F.	Industrial user interruptions
	Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?
	□ Yes □ No
	If yes , identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.
	Click to enter text.

WORKSHEET 7.0

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

CLASS V INJECTION WELL INVENTORY/AUTHORIZATION FORM

Submit the complet	ted form to:
--------------------	--------------

TCEQ IUC Permits Team Radioactive Materials Division MC-233 PO Box 13087 Austin, Texas 78711-3087 512-239-6466

For TCEQ Use Only		
Reg. No		
Date Received		
Date Authorized		

Section 1. General Information (Instructions Page 90)

1. TCEQ Progra	m Area
----------------	--------

Program Area (PST, VCP, IHW, etc.): Click to enter text.

Program ID: Click to enter text.

Contact Name: Click to enter text.

Phone Number: Click to enter text.

2. Agent/Consultant Contact Information

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

3. Owner/Operator Contact Information

□ Owner □ Operator

Owner/Operator Name: Click to enter text.

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

4. Facility Contact Information

Facility Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Location description (if no address is available): Click to enter text.

Facility Contact Person: Click to enter text.

Phone Number: Click to enter text.

5.	Latitude and Longitude, in degrees-minutes-seconds
	Latitude: Click to enter text.
	Longitude: Click to enter text.
	Method of determination (GPS, TOPO, etc.): Click to enter text.
	Attach topographic quadrangle map as attachment A.
6.	Well Information
	Type of Well Construction, select one:
	□ Vertical Injection
	☐ Subsurface Fluid Distribution System
	□ Infiltration Gallery
	☐ Temporary Injection Points
	□ Other, Specify: <u>Click to enter text.</u>
	Number of Injection Wells: Click to enter text.
7.	Purpose
	Detailed Description regarding purpose of Injection System:
	Click to enter text.
	Attach a Site Map as Attachment B (Attach the Approved Remediation Plan, if appropriate.)
8.	Water Well Driller/Installer
	Water Well Driller/Installer Name: Click to enter text.
	City, State, and Zip Code: Click to enter text.
	Phone Number: Click to enter text.
	License Number: Click to enter text.

Section 2. Proposed Down Hole Design

Attach a diagram signed and sealed by a licensed engineer as Attachment C.

Table 7.0(1) - Down Hole Design Table

Name of String	Size	Setting Depth	Sacks Cement/Grout – Slurry Volume – Top of Cement	Hole Size	Weight (lbs/ft) PVC/Steel
Casing					
Tubing					
Screen					

Section 3. Proposed Trench System, Subsurface Fluid Distribution System, or Infiltration Gallery

Attach a diagram signed and sealed by a licensed engineer as Attachment D.

System(s) Dimensions: <u>Click to enter text.</u> System(s) Construction: <u>Click to enter text.</u>

Section 4. Site Hydrogeological and Injection Zone Data

- 1. Name of Contaminated Aquifer: <u>Click to enter text.</u>
- 2. Receiving Formation Name of Injection Zone: Click to enter text.
- 3. Well/Trench Total Depth: <u>Click to enter text.</u>
- 4. Surface Elevation: Click to enter text.
- 5. Depth to Ground Water: <u>Click to enter text.</u>
- 6. Injection Zone Depth: <u>Click to enter text.</u>
- 7. Injection Zone vertically isolated geologically? ☐ Yes ☐ No Impervious Strata between Injection Zone and nearest Underground Source of Drinking Water:

Name: Click to enter text.

Thickness: Click to enter text.

- 8. Provide a list of contaminants and the levels (ppm) in contaminated aquifer Attach as Attachment E.
- 9. Horizontal and Vertical extent of contamination and injection plume Attach as Attachment F.
- **10.** Formation (Injection Zone) Water Chemistry (Background levels) TDS, etc. Attach as Attachment G.
- 11. Injection Fluid Chemistry in PPM at point of injection Attach as Attachment H.
- 12. Lowest Known Depth of Ground Water with < 10,000 PPM TDS: Click to enter text.
- 13. Maximum injection Rate/Volume/Pressure: Click to enter text.
- 14. Water wells within 1/4 mile radius (attach map as Attachment I): Click to enter text.
- **15.** Injection wells within 1/4 mile radius (attach map as Attachment J): <u>Click to enter text.</u>
- 16. Monitor wells within 1/4 mile radius (attach drillers logs and map as Attachment K): Click to enter text.
- 17. Sampling frequency: Click to enter text.
- **18.** Known hazardous components in injection fluid: <u>Click to enter text.</u>

Section 5. Site History

- **1.** Type of Facility: <u>Click to enter text.</u>
- Contamination Dates: Click to enter text.
- 3. Original Contamination (VOCs, TPH, BTEX, etc.) and Concentrations (attach as Attachment L): Click to enter text.
- 4. Previous Remediation (attach results of any previous remediation as attachment M): Click to enter text.

NOTE: Authorization Form should be completed in detail and authorization given by the TCEQ before construction, operation, and/or conversion can begin. Attach additional pages as necessary.

Class V Injection Well Designations

- 5A07 Heat Pump/AC return (IW used for groundwater to heat and/or cool buildings)
- 5A19 Industrial Cooling Water Return Flow (IW used to cool industrial process equipment)
- 5B22 Salt Water Intrusion Barrier (IW used to inject fluids to prevent the intrusion of salt water into an aquifer)
- 5D02 Storm Water Drainage (IW designed for the disposal of rain water)
- 5D04 Industrial Stormwater Drainage Wells (IW designed for the disposal of rain water associated with industrial facilities)
- 5F01 Agricultural Drainage (IW that receive agricultural runoff)
- 5R21 Aquifer Recharge (IW used to inject fluids to recharge an aquifer)
- 5S23 Subsidence Control Wells (IW used to control land subsidence caused by ground water withdrawal)
- 5W09 Untreated Sewage
- 5W10 Large Capacity Cesspools (Cesspools that are designed for 5,000 gpd or greater)
- 5W11 Large Capacity Septic systems (Septic systems designed for 5,000 gpd or greater)
- 5W12 WTTP disposal
- 5W20 Industrial Process Waste Disposal Wells
- 5W31 Septic System (Well Disposal method)
- 5W32 Septic System Drainfield Disposal
- 5X13 Mine Backfill (IW used to control subsidence, dispose of mining byproducts, and/or fill sections of a mine)
- 5X25 Experimental Wells (Pilot Test) (IW used to test new technologies or tracer dye studies)
- 5X26 Aquifer Remediation (IW used to clean up, treat, or prevent contamination of a USDW)
- 5X27 Other Wells
- 5X28 Motor Vehicle Waste Disposal Wells (IW used to dispose of waste from a motor vehicle site These are currently banned)
- 5X29 Abandoned Drinking Water Wells (waste disposal)



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for Submission (If other is checked please describe in space provided.)

New Permit, Registration or Authorization (Core Data Form should be submitted with the program application.)

Renewal	(Core Data	Form should be submit	ted with the re	enewal form,)		Other			
2. Customer Reference Number (if issued) CN 600520126				Follow this link to searce for CN or RN numbers i Central Registry**		100				
						RN 102078094				
ECTIO	N II:	Customer	Inforn	natior	1					
l. General C	ıstomer l	nformation	5. Effective	Date for C	Date for Customer Information Updates (mm/dd/yyyy)					
New Custo	mer	Пυ	pdate to Custo	mer Informa	ation	Cha	nge in Regulated Er	ntity Own	ership	
15		(Verifiable with the Tex	50			(Feb. 1981)	#W W# J	W.	3/8/	
		ubmitted here may b oller of Public Accou	Manager Control	utomatica	lly based on	what is a	current and activ	e with th	he Texas Sec	retary of State
. Customer	Legal Nan	ne (If an individual, pri	nt last name fi	rst: eg: Doe, .	John)		If new Customer	, enter pre	evious Custon	ner below:
Brownsville Na	vigation Di	strict								
7. TX SOS/CPA Filing Number 8. TX Star			8. TX State	te Tax ID (11 digits)			9. Federal Tax ID (9 digits) 7460004198		10. DUNS Number (if applicable) 88-6247	
1. Type of C	ustomer:	☐ Corporat	ion			☐ Indivi	dual	Partne	ership: 🔲 Ge	neral 🔲 Limited
overnment: [City 🔲	County 🔲 Federal 🔲	Local 🔲 State	e 🛛 Other		Sole P	Proprietorship	☐ Ot	her:	
2. Number	of Employ	rees				5	13. Independe	ently Ow	ned and Op	erated?
0-20	21-100	☑ 101-250 ☐ 251-:	500 🗌 501	and higher			⊠ Yes	☐ No		
14. Custome	r Role (Pro	pposed or Actual) – as it	relates to the	Regulated E	ntity listed on	this form.	Please check one o	of the follo	owing	
Owner Occupation	al Licensee	Operator Responsible Par		wner & Oper VCP/BSA App			☐ Other	ri		
.5. Mailing	1000 For	ust Rd								
Address:	City Brownsville State TX					ZIP	78521		ZIP + 4	T
.6. Country I	Mailing In	formation (if outside	USA)		17.	17. E-Mail Address (if applicable)				
N/A						mmartinez@portofbrownsville.com				

TCEQ-10400 (11/22) Page 1 of 3

18. Telephone Number			19. Extension o	r Code		20. Fax Number	if applicable)			
(956) 551-2602			19900 200			() -				
ECTION III:	Regula	ited Ent	ity Inform	matio	<u>1</u>	¥				
21. General Regulated En	tity Informa	tion (If 'New Reg	ulated Entity" is sele	ected, a new	permit applicat	ion is also required.)				
New Regulated Entity	Update to	Regulated Entity	Name 🗌 Update	to Regulate	d Entity Informa	ition		I FIRE A		
The Regulated Entity Naras Inc, LP, or LLC).	ne submitted	d may be upda	ted, in order to m	eet TCEQ C	ore Data Stan	dards (removal oj	^f organization	al endings such		
22. Regulated Entity Nam	ne (Enter name	e of the site wher	e the regulated action	on is taking p	lace.)					
Brownsville Navigation Distri	ct							e		
23. Street Address of the Regulated Entity:	1000 Foust Rd									
(No PO Boxes)	City Brownsville		State	ТХ	ZIP	78521	ZIP + 4			
24. County	Cameron		· •							
Section 1		If no Stre	et Address is prov	ided, fields	25-28 are red	quired.				
25. Description to Physical Location:			e Texas. 78521, locat v 48 and Farm-to-Ma							
26. Nearest City						State	Nea	rest ZIP Code		
12H 2		81								
Latitude/Longitude are r used to supply coordinat						rds. (Geocoding o	f the Physical	Address may be		
27. Latitude (N) In Decim	al:	25.962160		28.	Longitude (W	/) In Decimal:	-97.3955	84		
Degrees	Minutes		Seconds	Deg	rees	Minutes		Seconds		
25		52	04		97		23 15			
29. Primary SIC Code 30. Secondary SIC Code			Code		ary NAICS Co	de 32. S	econdary NAI	CS Code		
(4 digits)	(4 d	(4 digits)			(5 or 6 digits) (5 or 6 digits)					
4592				22132						
33. What is the Primary	Business of t	his entity? (D	o not repeat the SIC	or NAICS de	scription.)					
	Brownsvill	le Navigation Dis	trict				va			
34. Mailing	1000 Fous				ulou — usu					
Address:	City	Brownsville	State	тх	ZIP	78521	ZIP + 4	0.		
35. E-Mail Address:	mm	artinez@portofb	prownsville.com			1		1		
36. Telephone Number			37. Extension o	r Code	38. F	ax Number (if app	licable)			
(956)551-2602		The state of the s) -				

Page 2 of 3 TCEQ-10400 (11/22)

(956) 551-2602

PWS Used Oil Other:		
Other:		
that I have signature autho d in field 39.		
ineering Department		
56) 551- 2602		
30/2025		

TCEQ-10400 (11/22) Page 3 of 3

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS


TCEQ USE ONLY: A limit to the second of the	
Application type:RenewalMajor AmendmentMinor AmendmentNew	
County: Segment Number:	
Admin Complete Date:	
Agency Receiving SPIF:	
Texas Historical Commission U.S. Fish and Wildlife	
Texas Parks and Wildlife Department U.S. Army Corps of Engineers	
This form applies to TPDES permit applications only. (Instructions, Page 53)	
Complete this form as a separate document. TCEQ will mail a copy to each agency as required our agreement with EPA. If any of the items are not completely addressed or further information needed, we will contact you to provide the information before issuing the permit. Address each item completely.	d by tion
Do not refer to your response to any item in the permit application form. Provide each attachment for this form separately from the Administrative Report of the application. The application will not be declared administratively complete without this SPIF form being completed in its entirety including all attachments. Questions or comments concerning this f may be directed to the Water Quality Division's Application Review and Processing Team by email at	

		the name, address, phone and fax number of an individual that can be contacted to specific questions about the property.					
	Prefix (Mr., Ms., Miss): <u>Mr.</u>					
	First ar	nd Last Name: <u>Manuel Martinez</u>					
	Creden	itial (P.E, P.G., Ph.D., etc.):					
		acting Director of Engineering Department					
	Mailing	g Address: 1000 Foust Rd					
	City, St	ate, Zip Code: <u>Brownsville, Texas. 78521</u>					
	Phone	No.: <u>956-551-2602</u> Ext.: Allegation of the Fax No.: Allegation of the Fax No.:					
	E-mail	Address: mmartinez@portofbrownsville.com					
2.	List the	e county in which the facility is located: <u>Cameron</u>					
3.	If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.						
	N/A						
		· 9					
	Provide a description of the effluent discharge route. The discharge route must follow the flow of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.						
		nt discharge to an unnamed ditch; thence along to Cameron County drainage ditch thence to San Martin Lake, thence to the Brownsville Ship Channel.					
5.	plotted route f	provide a separate 7.5-minute USGS quadrangle map with the project boundaries and a general location map showing the project area. Please highlight the discharge from the point of discharge for a distance of one mile downstream. (This map is ed in addition to the map in the administrative report).					
	Provide original photographs of any structures 50 years or older on the property.						
	Does y	our project involve any of the following? Check all that apply.					
		Proposed access roads, utility lines, construction easements					
		Visual effects that could damage or detract from a historic property's integrity					
		Vibration effects during construction or as a result of project design					
		Additional phases of development that are planned for the future					
		Sealing caves, fractures, sinkholes, other karst features					


	☐ Disturbance of vegetation or wetlands
1.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	White being to design feet.
2.	Describe existing disturbances, vegetation, and land use:
	That has a topical taller.
	·
AN	E FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR ENDMENTS TO TPDES PERMITS
3.	List construction dates of all buildings and structures on the property:
4.	Provide a brief history of the property, and name of the architect/builder, if known.
	() 制。取 为() () () () () () () () () () () () () (

Attachment Tech 1.0-2C Process Flow Diagram

Schematic of Existing Wastewater Flow Turning Basin Wastewater Treatment Plant Brownsville Navigation District




Attachment T C 1.0-Maps











the port that works

SEPTEMBER 2025



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for Submission (If other is checked please describe in space provided.)												
☐ New Per	mit, Regi	stration or Authori	zation (<i>Core</i>	Data Form	should	d be si	ubmitte	d with	the progr	am app	plication.)	
☑ Renewal (Core Data Form should be submitted with the renewal form) ☐ Other												
2. Custome	er Refer	ence Number (if	issued)	Follow this			3. Re	3. Regulated Entity Reference Number (if issued)				
CN 60052	20126			numbers ir	ı Cent		RN	1020	78094			
CECTIO	Registry**											
SECTION II: Customer Information												
4. General Customer Information 5. Effective Date for Customer Information Updates (mm/dd/yyyy)												
☐ New Cust☐Change in		me (Verifiable with	_	ate to Custo ecretary of S				ptroll		_	-	d Entity Ownership
		ne submitted he	-	-			-			curre	nt and act	tive with the
		State (SOS) or T	<u>-</u>	<u>-</u>				(CPA	<i>.</i>).			
6. Custome	er Legal	Name (If an indivi	idual, print la	ast name fir	st: eg:	Doe, J	ohn)	<u>If ne</u>	w Custome	er, ente	r previous (Customer below:
Brownsville	Navigatio	n District										
7. TX SOS/	CPA Fili	ng Number	8. TX Stat	te Tax ID (11 dig	its)			ederal Ta	x ID		S Number (if
								(9 di 7460	gits))004198		applicable 88-6247	2)
11. Type o	f Custor	ner: Corpor	ation] Indivi	dual		Partn	ership: 🔲 (General □ Limited
		☐ County ☐ Feder	ral 🗌 Local	☐ State 🛛	Other		- Sole P	ropri	etorship	□ Ot		
12. Numbe			_					13.	Independ			nd Operated?
	21-100		251-500	□ 501 an				<u> </u>				C.1 C.11
	ier koie	(Proposed or Actu					-	ea on	tnis form. I	Please (спеск опе о	f the following
□Owner □Occupatio	nal Licen	☐ Operato see ☐ Respons			wner & CP/BS/	_			Other	:		
15.	1000 Fc	oust Rd										
Mailing												
Address:	City	Brownsville		State	TX		ZIP	7852	21		ZIP + 4	
16. Countr	y Mailin	g Information (i)	f outside USA	1)		17. E	-Mail A	Address (if applicable)				
N/A						mmai	rtinez@	porto	fbrownsvil	lle.com		
18. Teleph	one Nur	nber	1	19. Extensi	ion or	r Cod	e		20. Fax	Numb	er (if appli	cable)
(956) 551-	2602								()	-		
SECTION III: Regulated Entity Information												
21. General Regulated Entity Information (If 'New Regulated Entity" is selected, a new permit application is also required.)												
☑ New Regulated Entity ☐ Update to Regulated Entity Name ☐ Update to Regulated Entity Information												
	The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).											
22. Regula	ted Entit	y Name (Enter no	ame of the sit	te where the	regul	ated a	ction is	takin	g place.)			
Turning Basi	n Wastev	vater Treatment Pla	nnt									

TCEQ-10400 (11/22) Page 1 of 2

23. Street Address	3005 Levee Road											
of the Regulated Entity:												
(No PO Boxes)	City	Brownsvil	le	State	TX		ZIP	7852	1	ZIP + 4		
24. County Cameron												
25. Description to Physical Location: If no Street Address is provided, fields 25-28 are required. 3005 Levee Road, Brownsville Texas. 78521, located on the north side of State Highway 48. approximately 0.7 mile east of the intersection of Old State Highway 48 and State Road 550 northeast of the city of Brownsville, Cameron County, Texas. 78521.												
26. Nearest City State Nearest ZIP Code												
Latitude/Longitude a	ro roauir	od and ma	ıv he a	dded/unda	tod to	n m <i>o</i>	ot TCFO	<u>Core</u> Γ	ata Standi	ards (God	ocodina of the	
Physical Address ma												
27. Latitude (N) In De	cimal:	25.962160	١			28. I	Longitud	e (W) Ir	n Decimal:	-97.3955	584	
Degrees	Minutes		Seco			Degr			Minutes		Seconds	
25		52	CIC C	04	21	D!	97	CC C- 1	23		15	
29. Primary SIC Code (4 digits)		. Secondar ligits)	y SIC C	.oae		Prim r 6 di	ary NAI(igits)	LS Code	5 or 6		IAICS Code	
4592					2213	32						
33. What is the Prima	ry Busine	ess of this	entity	? (Do not re	epeat	the SI	IC or NAIC	S descri	ption.)			
	4											
24 Mailing	Brownsv	ille Navigat	ion Dis	trict								
34. Mailing Address:	1000 Fot	ust Rd										
Address.	City	Brownsvi	lle	State	TX		ZIP	7852	1	ZIP + 4		
35. E-Mail Address:	mn	nartinez@po	ortofbro	wnsville.com	n							
36. Telephone Numb	er		37.	Extension	or Co	ode	38.	Fax Nu	ımber (if ap	plicable)		
(956) 551-2602							() -				
9. TCEQ Programs and pdates submitted on this									n numbers t	hat will be	affected by the	
☐ Dam Safety	□ Dis	stricts	☐ Ed	☐ Edwards Aquifer			☐ Emissions Inventory Air			☐ Industrial Hazardous Waste		
☐ Municipal Solid Wast	e Reviev	w Source v Air	□os	SF			☐ Petrol	eum Sto	rage Tank	☐ PWS		
☐ Sludge	□ Sto	rm Water	☐ Tit	le V Air			☐ Tires			☐ Used O		
		TIII TYUCCI										
☐ Voluntary Cleanup	□Wa	stewater	☐ Wa	stewater Agr	icultu	ıre	□ Water	Rights		☐ Other:		
SECTION IV: P	repar	<u>er Info</u>	rma	<u>ition</u>								
40. Name: Nora Alicia	Gonzalez				41.	Title	e: Engir	eering A	Adminstrativ	e Special		
42. Telephone Numbe	r 43. Ext	t./Code 4	l4. Fax	Number	45	5. E-N	Mail Addı	ess				
(956) 551-9205		()	-	na	igonz	alez@port	ofbrown	nsville.com			
SECTION V. A	uthori	ized Si	anst	riira	•							
SECTION V: A 6. By my signature below			_		t the i	inforr	mation pro	wided in	n this form is	s true and o	complete and	
nat I have signature autho												

that I have signature authority to submit this for updates to the ID numbers identified in field 39.

Company:	Brownsville Navigation District	Job Title:	Acting D	Acting Director of Engineering Department			
Name (In Print):	Manuel Martinez			Phone:	(956) 551- 2602		
Signature:				Date:	9/30/2025		

TCEQ-10400 (11/22) Page 2 of 2

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:	
Application type:RenewalMajor An	
County:	Segment Number:
Admin Complete Date:	_
Agency Receiving SPIF:	
Texas Historical Commission	U.S. Fish and Wildlife
Texas Parks and Wildlife Department	U.S. Army Corps of Engineers
This form applies to TPDES permit application	ns only. (Instructions, Page 53)
	CEQ will mail a copy to each agency as required by not completely addressed or further information formation before issuing the permit. Address
Do not refer to your response to any item in tattachment for this form separately from the A application will not be declared administratively completed in its entirety including all attachme may be directed to the Water Quality Division's email at WQ-ARPTeam@tceq.texas.gov or by ph	dministrative Report of the application. The y complete without this SPIF form being ents. Questions or comments concerning this form Application Review and Processing Team by
The following applies to all applications:	
1. Permittee: <u>Brownsville Navigation District</u>	
Permit No. WQ00 <u>14355001</u>	EPA ID No. TX <u>0074047</u>
Address of the project (or a location descripand county):	otion that includes street/highway, city/vicinity,
3005 Levee Road, Brownsville Texas. 78521 loc approximately 0.7 mile east of the intersection of northeast of the city of Brownsville, Cameron C	of Old State Highway 48 and State Road 550,

		e the name, address, phone and fax number of an individual that can be contacted to specific questions about the property.
	Prefix	(Mr., Ms., Miss): <u>Mr.</u>
	First a	nd Last Name: <u>Manuel Martinez</u>
	Creder	atial (P.E, P.G., Ph.D., etc.):
	Title: A	acting Director of Engineering Department
	Mailing	g Address: <u>1000 Foust Rd</u>
	City, S	tate, Zip Code: <u>Brownsville, Texas. 78521</u>
	Phone	No.: <u>956-551-2602</u> Ext.: Fax No.:
	E-mail	Address: <u>mmartinez@portofbrownsville.com</u>
2.	List the	e county in which the facility is located: <u>Cameron</u>
3.	please	property is publicly owned and the owner is different than the permittee/applicant, list the owner of the property.
	N/A	
	D	
4.		e a description of the effluent discharge route. The discharge route must follow the flow tent from the point of discharge to the nearest major watercourse (from the point of
	discha	rge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify
	_	ssified segment number.
		ant discharge to an unnamed ditch; thence along to Cameron County drainage ditch thence to San Martin Lake, thence to the Brownsville Ship Channel.
	110. 1	thence to sun Martin Luke, thence to the brownsyme sing channel.
5.	plotted route f	provide a separate 7.5-minute USGS quadrangle map with the project boundaries and a general location map showing the project area. Please highlight the discharge from the point of discharge for a distance of one mile downstream. (This map is ed in addition to the map in the administrative report).
	Provid	e original photographs of any structures 50 years or older on the property.
	Does y	our project involve any of the following? Check all that apply.
		Proposed access roads, utility lines, construction easements
		Visual effects that could damage or detract from a historic property's integrity
		Vibration effects during construction or as a result of project design
		Additional phases of development that are planned for the future
		Sealing caves, fractures, sinkholes, other karst features

	☐ Disturbance of vegetation or wetlands
1.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	Click here to enter text.
2.	Describe existing disturbances, vegetation, and land use:
	Click here to enter text.
ΤН	LE FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR
	MENDMENTS TO TPDES PERMITS
3.	List construction dates of all buildings and structures on the property:
4.	Provide a brief history of the property, and name of the architect/builder, if known.



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Brownsville Navigation District (CN600520126) operates Turning Basin Wastewater Treatment Plant ((RN1020780940), an activated sludge process plant operated in the conventional mode.. The facility is located at 3005 Levee Road, in Brownsville, Texas. 78521, Cameron, County, Texas 78521 located on the north side of Old State Highway 48, approximately 0.7 mile east of the intersection of Old State Highway 48 and State Road 550, northeast of the city of Brownsville, Cameron County. Texas. 78521. Renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.1 million gallons per day (MGF) the Turning Basin Wastewater Plant serves Ostos Road along the entire south side of the Brownsville Ship Channel (BSC), Windhaus Road, and Milo Road west of (BSC), Foust Road north of the (BSC), from 511 to Old SH 48, and W. Oil Dock Ramp up to Oil Dock No. 5. << *For TLAP applications include the following*

sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain Chlorine residual of at least 1.0 mg/l and shall not exceed 4.0 mg/l, based on peak flow, and shall be monitored five times per week PH shall not be less than 6.0 nor greater than 9.0 once per month, Do, containing 2.0 minimum shall be monitored once per week., BOD, TSS once a week, E. Coli monthly and flow MGD on a dialy basis additional potential pollutants are include in the Domestic Technical Report 1.0 Section 7 Pollutant Analysis of Treated Effluent in the Permit Application Package. The treated effuent is discharged to an unnamed ditch; thence to Cameron County Drainage Ditch No. 1 thence San Martin Lake, thence to the Brownsville Ship Channel in Segment No. 2494 of the erBays and Estuaries. is treated by activated sludge process plant operated in the conventional mode, treatments units include bar screen, grit chamber grease removal, aertion basin, final clarifier and chlornine contact chamber, facility is in operation.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

AGUAS RESIDUALES DOMESTICA /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

El Districto de Navegación de Brownsville (CN6005201265)) opera Turning Basin Wastewater Treatment Plant RN102078094, un una renovación para autorizar el permiso del Sistema de Eliminación de Descargas de Contaminantes de Texas, que autoriza al Districto de Navegación de Brownsville la descarga de aguas residuales tratadas en un volumen que no exceda una descarga de promedio de 100,000 galones por día.. La instalación está ubicada en 3005 Levee Rd., , en Brownsville, Condado de Cameron, Texas 78521. located on the north side of Old State Highway 48, approximately 0.7 mile east of the intersection of Old State Highway 48 and State Road 550, northeast of the city of Brownsville, Cameron County. Texas. 78521 78521 situada en el lado norte de la antigua carretera estatal 48, aproximadamente a 0,7 millas al este de la intersección de la antigua carretera estatal 48 y la carretera estatal 550, al noreste de la ciudad de Brownsville, condado de Cameron. Texas. 78521 El efluente tratado es descargado a un dren sin nombré, de hi a Dren No. 1 del Condado de Cameron, después al lago San Martin y finalmente al Canal de Navegación de Brownsville en el Segmento No 2494 de la Cuenca de Bahías y Estatuarios, los unos designados para el Segmento No 2494 son uso excepcional de vida acuática y recreación sin contacto. . << Para las solicitudes de TLAP incluya la siguiente oración, de lo contrario, elimine:>> Este permiso no autorizará una descarga de contaminantes en el agua en el estado.

Se espera que las descargas de la instalación contengan 14. Liste todos los contaminantes esperados aquí. 15. Introduzca los tipos de aguas residuales descargadas aquí. 16. Elija del menú desplegable tratado por 17. Introduzca una descripción del tratamiento de aguas residuales utilizado en la instalación aquí.

Your transaction is complete. Thank you for using TCEQ ePay.

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt and the vouchers for your records. An email receipt has also been sent.

Transaction Information

Trace Number: 582EA000687020

Date: 09/30/2025 04:59 PM

Payment Method: CC - Authorization 0000030507

ePay Actor: NORA ALICIA GONZALEZ

Actor Email: nagonzalez@portofbrownsville.com

IP: 12.69.113.194

TCEQ Amount: \$815.00

Texas.gov Fee: \$18.59

Texas.gov Price: \$833.59*

* This service is provided by Texas.gov, the official website of Texas. The price of this service includes funds that support the ongoing operations and enhancements of Texas.gov, which is provided by a third party in partnership with the State.

Payment Contact Information

Name: NORA ALICIA GONZALEZ

Company: PORT OF BROWNSVILLE

Address: 1000 FOUST RD, BROWNSVILLE, TX 78521

Phone: 956-551-9205

Cart Items

Click on the voucher number to see the voucher details.

Voucher	Fee Description	

AR Number Amount

785547 WW PERMIT - FACILITY WITH FLOW >= .10 & < .25 MGD - RENEWAL

\$800.00

785548 30 TAC 305.53B WQ RENEWAL NOTIFICATION FEE

\$15.00

The state of the s

\$13.00

TCEQ Amount:

\$815.00

ePay Again Exit ePay

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt for your records.

D.	Package	
	Indicate by a check mark the preferred method for receiving the first notice and instruction	ıs:
	⊠ E-mail Address	
	□ Fax	
	□ Regular Mail	
C.	Contact permit to be listed in the Notices	
	Prefix: Mr. Last Name, First Name: Martinez Manuel	
	Title: <u>Acting Director of Engineering Services</u> Credential: Click to enter text.	
	Organization Name: Brownsville Navigation District	
	Mailing Address: 1000 Foust Road City, State, Zip Code: Brownsville, Texas. 78521	
	Phone No.: <u>956-551-2602</u> E-mail Address: <u>mmartinez@portofbrownsville.com</u>	
D.	Public Viewing Information	
	If the facility or outfall is located in more than one county, a public viewing place for each county must be provided.	
	Public building name: Brownsville Navigation District	
	Location within the building: Administration Building	
	Physical Address of Building: 1000 Foust Road	
	City: <u>Brownsville</u> County: <u>Cameron</u>	
	Contact (Last Name, First Name): Gonzalez Nora Alicia	
	Phone No.: <u>956-551-9205</u> Ext.: Click to enter text.	
E.	Bilingual Notice Requirements	
	This information is required for new, major amendment, minor amendment or minor modification, and renewal applications.	
	This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.	
	Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.	
	1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?	y
	⊠ Yes □ No	
	If no , publication of an alternative language notice is not required; skip to Section 9 below.	
	2. Are the students who attend either the elementary school or the middle school enrolled is a bilingual education program at that school?	in
	⊠ Yes □ No	

	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to enter	text.
	Mailing Address: Click to enter tex	t. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same p agreement or deed recorded easen	erson as the facility owner or co-applicant, attach a lease nent. See instructions.
	Attachment: Click to enter text	
F.	Owner sewage sludge disposal site property owned or controlled by the	(if authorization is requested for sludge disposal on ne applicant)::
	Prefix: Click to enter text.	ast Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to enter	text.
	Mailing Address: Click to enter tex	t. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same p agreement or deed recorded easen	erson as the facility owner or co-applicant, attach a lease nent. See instructions.
	Attachment: Click to enter text	
eroure.		van de la transporte de la companya
Se	ection 10. TPDES Discharge	e Information (Instructions Page 31)
		e Information (Instructions Page 31) y location in the existing permit accurate?
	. Is the wastewater treatment facility ☑ Yes □ No	
	. Is the wastewater treatment facility ☑ Yes □ No	y location in the existing permit accurate?
	. Is the wastewater treatment facility ☑ Yes □ No If no, or a new permit application	y location in the existing permit accurate?
A.	Is the wastewater treatment facility ✓ Yes □ No If no, or a new permit application Click to enter text.	y location in the existing permit accurate?
A.	Is the wastewater treatment facility ✓ Yes □ No If no, or a new permit application Click to enter text.	y location in the existing permit accurate? , please give an accurate description:
A.	. Is the wastewater treatment facility ☑ Yes □ No If no, or a new permit application Click to enter text. Are the point(s) of discharge and to ☑ Yes □ No If no, or a new or amendment per point of discharge and the discharge TAC Chapter 307:	y location in the existing permit accurate? , please give an accurate description:
A.	 Is the wastewater treatment facility 	y location in the existing permit accurate? y please give an accurate description: the discharge route(s) in the existing permit correct? mit application, provide an accurate description of the
A.	. Is the wastewater treatment facility ☑ Yes □ No If no, or a new permit application Click to enter text. Are the point(s) of discharge and to ☑ Yes □ No If no, or a new or amendment per point of discharge and the discharge TAC Chapter 307:	y location in the existing permit accurate? In please give an accurate description: The discharge route(s) in the existing permit correct? In the application, provide an accurate description of the ge route to the nearest classified segment as defined in 30.
A.	 Is the wastewater treatment facility 	y location in the existing permit accurate? In please give an accurate description: The discharge route(s) in the existing permit correct? In the discharge route an accurate description of the ge route to the nearest classified segment as defined in 30 called
А.	Is the wastewater treatment facility ✓ Yes ☐ No If no, or a new permit application Click to enter text. Are the point(s) of discharge and to ✓ Yes ☐ No If no, or a new or amendment per point of discharge and the discharge are discharged as a discharge and the discharge and the discharged are discharged as a discharged and the discharged are discharged as a discharged and the discharged are discharged as a di	y location in the existing permit accurate? In please give an accurate description: The discharge route(s) in the existing permit correct? In the discharge route an accurate description of the ge route to the nearest classified segment as defined in 30 and the general section of the general sec

Last Name, First Name: Click to enter text.

E. Owner of effluent disposal site:

Prefix: SAME

week PH shall not be less than 6.0 nor greater than 9.0 once per month, Do, containing 2.0 minimum shall be monitored once per week., BOD, TSS once a week, E. Coli monthly and flow MGD on a dialy basis additional potential pollutants are include in the Domestic Technical Report 1.0 Section 7 Pollutant Analysis of Treated Effluent in the Permit Application Package. The treated effuent is discharged to an unnamed ditch; thence to Cameron County Drainage Ditch No. 1 thence San Martin Lake, thence to the Brownsville Ship Channel in Segment No. 2494 of the erbays and Estuaries. is treated by activated sludge process plant operated in the conventional mode, treatments units include bar screen, grit chamber grease removal, aertion basin, final clarifier and chlornine contact chamber, facility is in operation.



September 30, 2025

Texas Commission on Environmental Quality Water Quality Division Applications Review and Process Team (MC148) 12100 Park 35 Circle Austin, Texas 78753

RE: Application to Renew Permit No. WQ0014355001

Brownsville Navigation District: (CN 600520126)

Regulated Entity: (RN 102078094)

Dear Review Team:

Find the enclosed one original TCEQ Water Quality Permit Renewal Application forms 10053, 10054, and 10400, along with necessary attachments for the facility referenced above. The Facility is situated at 3005 Levee Road located on the north side of State Highway 48 approximately 0.7 mile east of the intersection of State Highway 48 and Farm-to-market Road 511, northeast of the City of Brownsville, Cameron County, Texas.

Currently, the Turning Basin Wastewater Plant treatment facility has permission to discharge domestic water effluent at a daily flow of no more than .0.10 MGD. To consider the application complete we also uploaded an electronic copy via TCEQ FTP Server. Fee application paid via ePay, see enclosed receipt.

Should questions remain, please notify us at your earliest convenience, so we can immediately respond and address any additional concerns you might have.

Sincerely,

BROWNSVILLE NAVIGATION DISTRICT

dba PORT OF BROWNSVILLE

Manuel Martinez.

Acting Director of Engineering Services Email: mmartinez@portofbrownsville.com

Enclosures: TCEQ forms 10053, 10054 10400 and attachments.

Cc: Nora Alicia Gonzalez, Engineering Administrative Specialist



Brownsville Navigation District d/b/a Port of Brownsville

Turning Basin Wastewater Treatment Facility

TPDES Discharge Permit Application (RENEWAL)

TPDES Permit No. WQ0014355001 CN600520126 RN102078094

September 30, 2025

Prepared by:

Nora Alicia Gonzalez
Engineering Administrative Specialist
Engineering Department
1000 Foust Rd
Brownsville, Texas
Tel: 956-551-9205

Email: nagonzalez@portofbrownsville.com

THE COMMISSION OF THE PROPERTY OF THE PROPERTY

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

APPLICANT NAME: Brownsville Navigation District

PERMIT NUMBER (If new, leave blank): WQ000014355001

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	\boxtimes		Original USGS Map	\boxtimes	
Administrative Report 1.1		\boxtimes	Affected Landowners Map		\boxtimes
SPIF	\boxtimes		Landowner Disk or Labels		\boxtimes
Core Data Form	\boxtimes		Buffer Zone Map		\boxtimes
Summary of Application (PLS)	\boxtimes		Flow Diagram	\boxtimes	
Public Involvement Plan Form			Site Drawing		
Technical Report 1.0	\boxtimes	\boxtimes	Original Photographs		\boxtimes
Technical Report 1.1			Design Calculations		\boxtimes
Worksheet 2.0			Solids Management Plan	30	\boxtimes
Worksheet 2.1		\boxtimes	Water Balance		\boxtimes
Worksheet 3.0		\boxtimes			
Worksheet 3.1					
Worksheet 3.2					
Worksheet 3.3					
Worksheet 4.0		\boxtimes			
Worksheet 5.0		\boxtimes			
Worksheet 6.0	\boxtimes				
Worksheet 7.0		\boxtimes			
For TCEQ Use Only					
Segment NumberExpiration Date			County Region		

Permit Number _____

SCOMMISSION OF STREET OF S

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

Section 1. Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
<0.05 MGD	\$350.00 □	\$315.00 □
≥0.05 but <0.10 MGD	\$550.00	\$515.00 □
≥0.10 but <0.25 MGD	\$850.00 □	\$815.00 ⊠
≥0.25 but <0.50 MGD	\$1,250.00 □	\$1,215.00 □
≥0.50 but <1.0 MGD	\$1,650.00 □	\$1,615.00 □
≥1.0 MGD	\$2,050.00 □	\$2,015.00

Minor Amendment (for any flow) \$150.00 \square

Par	yment	Inform	ation

Mailed Check/Money Order Number: <u>E-Pay</u>

Check/Money Order Amount: Click to enter text.

Name Printed on Check: Click to enter text.

EPAY Voucher Number: Click to enter text.

Copy of Payment Voucher enclosed? Yes ⊠

Section 2. Type of Application (Instructions Page 26)

a.	Check the box next to the appropriate authorization type.						
	☑ Publicly Owned Domestic Wastewater						
		Privately-Owned Domestic Wastewater					
		Conventional Water Treatment					
b.	Che	eck the box next to the appropriate facility status.					

Inactive

Active

c.	c. Check the box next to the appropriate permit type.						
	□ TPDES Permit						
		TLAP					
		TPDES Permit with TLAP component					
		Subsurface Area Drip Dispersal System (SAD	DS)				
d.	Che	eck the box next to the appropriate application	ı typ	e			
		New					
		Major Amendment with Renewal		Minor Amendment with Renewal			
		Major Amendment <u>without</u> Renewal		Minor Amendment without Renewal			
	\boxtimes	Renewal without changes		Minor Modification of permit			
e.	For	amendments or modifications, describe the p	ropo	osed changes: Click to enter text.			
f.	For	existing permits:					
	Per	mit Number: WQ00 <u>14355001</u>					
	EPA	A I.D. (TPDES only): TX <u>0074047</u>					
	Expiration Date: May 19, 2026						
Se	ctio	on 3. Facility Owner (Applicant) a (Instructions Page 26)	nd	Co-Applicant Information			
A.	The	e owner of the facility must apply for the pe	rmit	•			
	Wh	at is the Legal Name of the entity (applicant) a	pply	ing for this permit?			
	Bro	wnsville Navigation District					
		e legal name must be spelled exactly as filed w legal documents forming the entity.)	ith ti	he Texas Secretary of State, County, or in			
	If the applicant is currently a customer with the TCEQ, what is the Customer Number (CN)?						

You may search for your CN on the TCEQ website at <u>http://www15.tceq.texas.gov/crpub/</u>

CN: 600520126

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: Mr.

Last Name, First Name: Martinez Manuel

Title: Acting Director of Engineering Credential: Click to enter text.

B. Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

Click to enter text.

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the *legal documents forming the entity.)*

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: http://www15.tceq.texas.gov/crpub/

CN: Click to enter text.

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in *30 TAC § 305.44*.

Prefix: Click to enter text.

Last Name, First Name: Click to enter text.

Title: Click to enter text.

Credential: Click to enter text.

Provide a brief description of the need for a co-permittee: Click to enter text.

C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. <u>Attachment. Admin 1.0-3c</u>

Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Mr.

Last Name, First Name: Martinez Manuel

Title: Acting Director of Engineering Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: <u>956-551-2602</u>

E-mail Address: <u>mmartinez@portofbrownsville.com</u>

Check one or both:

□ Administrative Contact

B. Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Check one or both:

 □ Technical Contact

Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Mr.

Last Name, First Name: Martinez Manuel

Title: Acting Director of Engineering Services

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Rd

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-2602

E-mail Address: mmartinez@portofbrownsville.com

B. Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

Section 8. Public Notice Information (Instructions Page 27)

A. Individual Publishing the Notices

Prefix: Ms.

Last Name, First Name: Gonzalez Nora Alicia

Title: Engineering Administrative Specialist

Credential: Click to enter text.

Organization Name: Brownsville Navigation District

Mailing Address: 1000 Foust Road

City, State, Zip Code: Brownsville, Texas. 78521

Phone No.: 956-551-9205

E-mail Address: nagonzalez@portofbrownsville.com

В.		ethod fo .ckage	or Receivin	ig Not	ice of R	Receipt an	d Inte	ent to Obt	ain a Wa	ter Qua	lity Pern	uit
	Inc	dicate b	y a check r	nark t	he prefe	erred meth	od fo	r receivin	g the firs	st notice	and inst	ructions:
	\boxtimes	E-ma	il Address									
		Fax										
		Regul	lar Mail									
C.	Co	ntact p	ermit to be	e liste	d in the	Notices						
	Pr	efix: <u>Mr</u>	<u>.</u>		9	Last Name	, First	Name: <u>M</u>	artinez M	anuel		
	Tit	tle: <u>Acti</u> ı	ng Director o	of Engi	neering	<u>Services</u>		Credenti	al: Click	to enter	text.	
	Or	ganizat	ion Name:	Brown	sville Na	vigation Di	strict					
	Ma	ailing A	ddress: <u>100</u>	o Fous	t Road	1	City, S	State, Zip	Code: Cli	ck to en	ter text.	
	Ph	one No.	: Click to e	nter te	ext.	E-mail Ad	dress	: Click to	enter tex	t.		
D.	Pu	blic Vie	ewing Info	rmatio	n	,						
			lity or outfo ust be provi		cated ir	n more tha	n one	county, a	ı public v	iewing p	olace for	each
	Pu	blic bui	lding name	: Brow	nsville 1	Navigation 1	Distric	<u>:t</u>				
	Lo	cation v	vithin the b	ouildin	ıg: <u>Admi</u>	inistration l	Buildir	ng				
	Ph	ysical A	ddress of l	Buildir	ng: <u>1000</u>	Foust Roa	<u>d</u>					
	Cit	ty: <u>Brow</u>	<u>nsville</u>			County	: <u>Cam</u>	<u>eron</u>				
	Co	ntact (L	ast Name,	First N	Iame): <u>C</u>	Gonzalez No	ora Ali	<u>cia</u>				
	Ph	one No.	: <u>956-551-9</u> :	205 Ex	t.: Click	to enter t	ext.					
E.	Bil	ingual i	Notice Reg	uirem	ents							
			mation <mark>is</mark> r ion, and re				ame	ndment, 1	minor an	iendme:	nt or mi	ıor
	be	needed	on of the ay l. Complete ic notice pa	instru	actions							
	ob		the bilingue following									
	1.		ingual eduo dle school							n Code a	it the ele	mentary
			Yes		No							
		If no , p	oublication	of an	alternat	tive langua	age no	otice is no	t require	d; skip t	t o Section	19
	2.		e students gual educat					tary scho	ol or the	middle	school ei	ırolled in
			Yes		No							

	3.	Do the locatio	students at n?	these so	hools a	ıttend	a bilingı	ıal educa	tion prog	ram a	t another
			Yes	⊠ N	O						
	4.		the school b l out of this							gram l	out the school has
			Yes	⊠ N	O						
	5.		nnswer is ye : ed. Which la:								tive language are enter text.
F.	Su	mmary	of Applicat	ion in P	lain Laı	1guage	e Templ	ate			
			the F. Sumr n as the plai) Form 20972), ment.
	At	tachme	nt: <u>20972</u>								
G.	Pu	blic Inv	olvement P	lan Fori	n				領		
			the Public Ir iit or major								plication for a t.
	At	tachme	nt: <u>N/A</u>								
							al .				
Se	cti	on 9.			tity a	nd Pe	ermitte	d Site	Inform	ation	(Instructions
			Page 29	})				Liveria de la composición della composición dell			
A.			is currently RN <u>RN102078</u>		d by To	CEQ, p	rovide tl	ne Regula	ited Entity	y Num	ber (RN) issued to
			e TCEQ's Cer currently re				//www15	5.tceq.tex	as.gov/cr	pub/	to determine if
B.	Na	me of p	project or sit	e (the na	ıme kn	own by	the cor	nmunity	where loc	ated):	
	<u>Tu</u>	rning Ba	ısin Wastewat	ter Plant							
C.	Ov	vner of	treatment fa	cility: <u>B</u>	<u>ownsvi</u>	le Nav	igation D	<u>istrict</u>			
	Ov	vnershij	o of Facility:	⊠ Pı	ıblic		Private		Both		Federal
D.	Ov	vner of i	land where t	reatmer	ıt facili	ty is or	will be:				
	Pre	efix: Cli	ck to enter t	ext.	Las	t Name	e, First N	ame: Cli	ck to ente	r text.	
	Tit	le: Clicl	k to enter te	xt.	Cre	dentia	l: Click t	o enter t	ext.		
	Or	ganizat	ion Name: <u>B</u>	rownsvil	<u>e Navig</u>	<u>ation D</u>	<u>istrict</u>				
	Ma	iling Ac	ddress: <u>1000</u>	Foust Re	<u>ad</u>		City, Sta	ite, Zip C	ode: <u>Brow</u>	nsville	, Texas. 78521
	Ph	one No.	: <u>956-551-920</u>	25	E-r	nail Ao	ddress: <u>n</u>	agonzalez	@portofb	rownsv	ville.com
			lowner is no t or deed rec						or co-ap	plican	t, attach a lease
		Attach	ment: N/A								

	Prefix: <u>SAME</u>	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ent	er text.
	Mailing Address: Click to enter t	ext. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded eas	e person as the facility owner or co-applicant, attach a lease sement. See instructions.
	Attachment: Click to enter to	ext.
F.	Owner sewage sludge disposal s property owned or controlled by	site (if authorization is requested for sludge disposal on y the applicant)::
	Prefix: Click to enter text.	Last Name, First Name: Click to enter text.
	Title: Click to enter text.	Credential: Click to enter text.
	Organization Name: Click to ent	er text.
	Mailing Address: Click to enter t	text. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	E-mail Address: Click to enter text.
	If the landowner is not the same agreement or deed recorded eas	e person as the facility owner or co-applicant, attach a lease sement. See instructions.
	Attachment: Click to enter to	ext.
Se	ection 10. TPDES Dischar	ge Information (Instructions Page 31)
A.	Is the wastewater treatment faci	ility location in the existing permit accurate?
	⊠ Yes □ No	
	✓ Yes □ NoIf no, or a new permit application	on, please give an accurate description:
	⊠ Yes □ No	
	✓ Yes □ NoIf no, or a new permit application	
	✓ Yes □ No If no, or a new permit applicati Click to enter text.	
	✓ Yes □ No If no, or a new permit applicati Click to enter text.	ion, please give an accurate description:
	✓ Yes ☐ No If no, or a new permit application of the point of discharge and the di	ion, please give an accurate description:
	 ✓ Yes □ No If no, or a new permit application Click to enter text. Are the point(s) of discharge and ✓ Yes □ No If no, or a new or amendment point of discharge and the discharge 	d the discharge route(s) in the existing permit correct?
	✓ Yes ☐ No If no, or a new permit application of the point of discharge and the di	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30
	✓ Yes ☐ No If no, or a new permit application of the content text. Are the point(s) of discharge and which will be content to the content of the content	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30 nsville
В.	✓ Yes ☐ No If no, or a new permit application of the content text. Are the point(s) of discharge and which with the content of the content	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30 nsville is/are located: Cameron r discharge to a city, county, or state highway right-of-way, or
В.	✓ Yes ☐ No If no, or a new permit application of the content text. Are the point(s) of discharge and with the point of discharge and the discharge and th	d the discharge route(s) in the existing permit correct? permit application, provide an accurate description of the narge route to the nearest classified segment as defined in 30 nsville is/are located: Cameron r discharge to a city, county, or state highway right-of-way, or

E. Owner of effluent disposal site:

	If yes , indicate by a check mark if:
	oxtimes Authorization granted $oxtimes$ Authorization pending
	For new and amendment applications, provide copies of letters that show proof of contact and the approval letter upon receipt.
	Attachment: Click to enter text.
D.	For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: Click to enter text.
Se	ction 11. TLAP Disposal Information (Instructions Page 32)
	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?
7 11	☐ Yes ☐ No
	If no, or a new or amendment permit application , provide an accurate description of the disposal site location:
	Click to enter text.
В.	City nearest the disposal site: Click to enter text.
C.	County in which the disposal site is located: Click to enter text.
D.	For TLAPs , describe the routing of effluent from the treatment facility to the disposal site:
	Click to enter text.
E.	For TLAPs , please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: Click to enter text.
Se	ction 12. Miscellaneous Information (Instructions Page 32)
A.	Is the facility located on or does the treated effluent cross American Indian Land?
	□ Yes ⊠ No
В.	If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?
	□ Yes □ No ⊠ Not Applicable
	If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.
	Click to enter text.

C.	Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?
	□ Yes ⊠ No
	If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application: Click to enter text.
D.	Do you owe any fees to the TCEQ?
	□ Yes ⊠ No
	If yes , provide the following information:
	Account number: Click to enter text.
	Amount past due: Click to enter text.
E.	Do you owe any penalties to the TCEQ?
	□ Yes ⊠ No
	If yes , please provide the following information:
	Enforcement order number: Click to enter text.
	Amount past due: Click to enter text.
Se	ection 13. Attachments (Instructions Page 33)
Inc	dicate which attachments are included with the Administrative Report. Check all that apply:
	Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.
\boxtimes	Original full-size USGS Topographic Map with the following information:
	Applicant's property boundary
	 Treatment facility boundary Labeled point of discharge for each discharge point (TPDES only) Highlighted discharge route for each discharge point (TPDES only) Onsite sewage sludge disposal site (if applicable) Effluent disposal site boundaries (TLAP only) New and future construction (if applicable) 1 mile radius information
	 3 miles downstream information (TPDES only) All ponds.
	Attachment 1 for Individuals as co-applicants
	Other Attachments. Please specify: Click to enter text.

Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0014355001

Applicant: Brownsville Navigation District

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): Manuel Martinez								
Signatory title: Acting Director of Engineering Services								
Signature:								
(Use blue ink)								
Subscribed and Sworn to before me by the said Manuel Matine2								
on this day of September, 2015.								
My commission expires on the $\frac{1200}{100}$ day of $\frac{100}{100}$ day of $\frac{100}{100}$.								
NIDIA MAGALI OVALLE Notary ID #126087722 My Commission Expires								

March 23, 2027

() ames

Notary Public

DOMESTIC WASTEWATER PERMIT APPLICATION **ADMINISTRATIVE REPORT 1.0**

The following information is required for new and amendment applications.

Section 1. Affected Landowner Information (Instructions Page 36)

A.	Indicate by a check mark that the landowners map or drawing, with scale, includes the following information, as applicable:						
		The applicant's property boundaries					
		The facility site boundaries within the applicant's property boundaries					
		The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone					
		The property boundaries of all landowners surrounding the applicant's property (Note: if the application is a major amendment for a lignite mine, the map must include the property boundaries of all landowners adjacent to the new facility (ponds).)					
		The point(s) of discharge and highlighted discharge route(s) clearly shown for one mile downstream					
		The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge					
		The property boundaries of the landowners along the watercourse for a one-half mile radius from the point of discharge if the point of discharge is into a lake, bay, estuary, or affected by tides					
		The boundaries of the effluent disposal site (for example, irrigation area or subsurface drainfield site) and all evaporation/holding ponds within the applicant's property					
		The property boundaries of all landowners surrounding the effluent disposal site					
		The boundaries of the sludge land application site (for land application of sewage sludge for beneficial use) and the property boundaries of landowners surrounding the applicant's property boundaries where the sewage sludge land application site is located					
		The property boundaries of landowners within one-half mile in all directions from the applicant's property boundaries where the sewage sludge disposal site (for example, sludge surface disposal site or sludge monofill) is located					
В.	The state of the s	Indicate by a check mark that a separate list with the landowners' names and mailing resses cross-referenced to the landowner's map has been provided.					
C.	-	Indicate by a check mark that the landowners list has also been provided as mailing ls in electronic format (Avery 5160).					
D.	Prov	vide the source of the landowners' names and mailing addresses: Click to enter text.					
E.		equired by $Texas\ Water\ Code\ \S\ 5.115$, is any permanent school fund land affected by application?					
	E	□ Yes □ No					

	If ye :	s, provide the location and foreseeable impacts and effects this application has on the s):
		k to enter text.
Se	ctio	n 2. Original Photographs (Instructions Page 38)
Pr	ovide	original ground level photographs. Indicate with checkmarks that the following tion is provided.
		At least one original photograph of the new or expanded treatment unit location
		At least two photographs of the existing/proposed point of discharge and as much area downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is to an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.
		At least one photograph of the existing/proposed effluent disposal site
		A plot plan or map showing the location and direction of each photograph
Se	ctio	n 3. Buffer Zone Map (Instructions Page 38)
A.	infor	er zone map. Provide a buffer zone map on 8.5×11 -inch paper with all of the following mation. The applicant's property line and the buffer zone line may be distinguished by a dashes or symbols and appropriate labels.
	•	The applicant's property boundary; The required buffer zone; and Each treatment unit; and The distance from each treatment unit to the property boundaries.
В.		er zone compliance method. Indicate how the buffer zone requirements will be met. k all that apply.
		Ownership
		Restrictive easement
		Nuisance odor control
		Variance
C.		itable site characteristics. Does the facility comply with the requirements regarding itable site characteristic found in 30 TAC § 309.13(a) through (d)?
		Yes □ No

DOMESTIC WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: SPIF Attached

WATER QUALITY PERMIT

PAYMENT SUBMITTAL FORM

Use this form to submit the Application Fee, if the mailing the payment.

- Complete items 1 through 5 below.
- Staple the check or money order in the space provided at the bottom of this document.
- Do Not mail this form with the application form.
- Do not mail this form to the same address as the application.
- Do not submit a copy of the application with this form as it could cause duplicate permit entries.

Mail this form and the check or money order to:

BY REGULAR U.S. MAIL

Texas Commission on Environmental Quality Financial Administration Division Cashier's Office, MC-214

P.O. Box 13088

Austin, Texas 78711-3088

BY OVERNIGHT/EXPRESS MAIL

Texas Commission on Environmental Quality

Financial Administration Division

Cashier's Office, MC-214 12100 Park 35 Circle

Austin, Texas 78753

Fee Code: WQP Waste Permit No: WQ0014355001

- 1. Check or Money Order Number: E-Pay
- 2. Check or Money Order Amount: Click to enter text.
- 3. Date of Check or Money Order: Click to enter text.
- 4. Name on Check or Money Order: Click to enter text.
- 5. APPLICATION INFORMATION

Name of Project or Site: Click to enter text.

Physical Address of Project or Site: Click to enter text.

If the check is for more than one application, attach a list which includes the name of each Project or Site (RE) and Physical Address, exactly as provided on the application.

Staple Check or Money Order in This Space

ATTACHMENT 1

INDIVIDUAL INFORMATION

Section 1. Individual Information (Instructions Page 41)

Complete this attachment if the facility applicant or co-applicant is an individual. Make additional copies of this attachment if both are individuals.

Prefix (Mr., Ms., Miss): Click to enter text.

Full legal name (Last Name, First Name, Middle Initial): Click to enter text.

Driver's License or State Identification Number: Click to enter text.

Date of Birth: Click to enter text.

Mailing Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text. Fax Number: Click to enter text.

E-mail Address: Click to enter text.

CN: Click to enter text.

For Commission Use Only:

Customer Number:

Regulated Entity Number:

Permit Number:

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

application until the tems below have been addressed.							
Core Data Form (TCEQ Form No. 10400) (Required for all application types. Must be completed in its en Note: Form may be signed by applicant representative.)		Yes					
Correct and Current Industrial Wastewater Permit Application (TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018		Yes					
Water Quality Permit Payment Submittal Form (Page 19) (Original payment sent to TCEQ Revenue Section. See instructi	⊠ !dress	Yes s.)					
7.5 Minute USGS Quadrangle Topographic Map Attached (Full-size map if seeking "New" permit. 8 ½ x 11 acceptable for Renewals and Amendments)				Yes			
Current/Non-Expired, Executed Lease Agreement or Easement		N/A		Yes			
Landowners Map (See instructions for landowner requirements)		Yes					
 Things to Know: All the items shown on the map must be labeled. The applicant's complete property boundaries must be delineated which includes boundaries of contiguous property owned by the applicant. The applicant cannot be its own adjacent landowner. You must identify the landowners immediately adjacent to their property, regardless of how far they ar from the actual facility. If the applicant's property is adjacent to a road, creek, or stream, the landowners on the opposite side must be identified. Although the properties are not adjacent applicant's property boundary, they are considered potentially affected landowners if the adjacent road is a divided highway as identified on the USGS topographic map, the applicant does not have to identify the landowners on the opposite side the highway. 							
Landowners Labels and Cross Reference List (See instructions for landowner requirements)	N/A		Yes				
Electronic Application Submittal (See application submittal requirements on page 23 of the inst	ructions.)		\boxtimes	Yes			
Original signature per 30 TAC § 305.44 – Blue Ink Preferred (If signature page is not signed by an elected official or principal copy of signature authority/delegation letter must be attached.)		e office	r,	Yes			
Summary of Application (in Plain Language)	\boxtimes	Yes					

COMMISSION OF THE PROPERTY OF

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

Section 1. Permitted or Proposed Flows (Instructions Page 42)

A. Existing/Interim I Phase

Design Flow (MGD): <u>0.10</u>

2-Hr Peak Flow (MGD): 025

Estimated construction start date: January 28, 1976

Estimated waste disposal start date: N/A

B. Interim II Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

C. Final Phase

Design Flow (MGD): N/A

2-Hr Peak Flow (MGD): N/A

Estimated construction start date: N/A

Estimated waste disposal start date: N/A

D. Current Operating Phase

Provide the startup date of the facility: January 28, 1976

Section 2. Treatment Process (Instructions Page 42)

A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. If more than one phase exists or is proposed, a description of *each phase* must be provided.

Conventional active sludge: bar screen-grit chamber-grease removal- aeration tank- final clarifier-chlorine contact chamber- discharge pipeline to ditch at outfall 001. Sludge is hauled offsite for disposal.

B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Grit Chamber	1	7'5 x 5'4 60'
Oil Skimmer	1	12' x 30' x 30'
Aeration Tank	1	10' x 130' x 130'
Clarifier	1	14' x 70' x 70'
Sludge Holding Ponds Out of service	2	34' x 34' x 9'6"
Chlorine Disinfectant Chamber	1	9' 6" x 34' x 34'

C. Process Flow Diagram

Provide flow diagrams for the existing facilities and each proposed phase of construction.

Attachment: Attachment. Admin 1.0-2C

Section 3. Site Information and Drawing (Instructions Page 43)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

- Latitude: <u>25 deg. 57 min. 44 sec</u>
- Longitude: <u>97 deg. 23 min. 38 sec.</u>

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

- Latitude: Click to enter text.
- Longitude: Click to enter text.

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or

Attachment: Attachment Admin 1.0-13 & Tech 1.0-3 Provide the name and a description of the area served by the treatment facility. Plant serves Ostos Road along the entire South side of the Brownsville Ship Channel, (BSC) Windhaus Road and Milo Road West, of the BSC, Foust Road North of BSC from 511 to Old SH 48 and W. Oil Dock Road up to Oil Dock No. 5 Collection System Information for wastewater TPDES permits only: Provide information for each **uniquely owned** collection system, existing and new, served by this facility, including satellite collection systems. Please see the instructions for a detailed explanation and examples. **Collection System Information Collection System Name Owner Name Owner Type Population Served** Choose an item. Choose an item. Choose an item. Choose an item. Section 4. Unbuilt Phases (Instructions Page 44) Is the application for a renewal of a permit that contains an unbuilt phase or phases? Yes If yes, does the existing permit contain a phase that has not been constructed within five **years** of being authorized by the TCEQ? Yes No If yes, provide a detailed discussion regarding the continued need for the unbuilt phase. Failure to provide sufficient justification may result in the Executive Director recommending denial of the unbuilt phase or phases. N/A

Section 5. Closure Plans (Instructions Page 44)

disposal site.

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

	□ Yes ⊠ No
If y	yes, was a closure plan submitted to the TCEQ?
	□ Yes □ No :
If y	yes, provide a brief description of the closure and the date of plan approval.
N	/A
	, · · · · · · · · · · · · · · · · · · ·
	· ·
	ction 6. Permit Specific Requirements (Instructions Page 44)
	r applicants with an existing permit, check the Other Requirements or Special ovisions of the permit.
Α.	Summary transmittal
	Have plans and specifications been approved for the existing facilities and each proposed phase?
	⊠ Yes □ No
	If yes, provide the date(s) of approval for each phase: <u>Click to enter text.</u>
	Provide information, including dates, on any actions taken to meet a <i>requirement or</i>
	provision pertaining to the submission of a summary transmittal letter. Provide a copy of
	an approval letter from the TCEQ, if applicable.
	N/A
В.	Buffer zones
	Have the buffer zone requirements been met?
	⊠ Yes □ No
	Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the
	buffer zones.
	Not Applicable

C.	Ot	her actions required by the current permit
	sul	bes the Other Requirements or Special Provisions section in the existing permit require busission of any other information or other required actions? Examples include tification of Completion, progress reports, soil monitoring data, etc.
		□ Yes ⊠ No
		y es , provide information below on the status of any actions taken to meet the nditions of an <i>Other Requirement</i> or <i>Special Provision</i> .
	C	lick to enter text.
		tage of the state
D.	Gr	it and grease treatment
	1.	Acceptance of grit and grease waste
		Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?
		□ Yes ⊠ No
		If No, stop here and continue with Subsection E. Stormwater Management.
	2.	Grit and grease processing
		Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.
		Click to enter text.
	3.	Grit disposal
		Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?
		□ Yes ⊠ No
		If No, contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

		Describe the method of grit disposal.
		Click to enter text.
	4.	Grease and decanted liquid disposal
		Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.
		Describe how the decant and grease are treated and disposed of after grit separation.
		Click to enter text.
		·
E.	Sto	ormwater management
	1.	Applicability
		Does the facility have a design flow of 1.0 MGD or greater in any phase?
		⊠ Yes ⊠ No
		Does the facility have an approved pretreatment program, under 40 CFR Part 403?
		□ Yes ⊠ No
		If no to both of the above, then skip to Subsection F, Other Wastes Received.
	2.	MSGP coverage
		Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?
		□ Yes □ No
		If yes , please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:
		TXR05 <u>Click to enter text.</u> or TXRNE <u>Click to enter text.</u>
		If no, do you intend to seek coverage under TXR050000?
		□ Yes □ No
	3.	Conditional exclusion
		Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?
		□ Yes □ No

	If yes, please explain below then proceed to Subsection F, Other Wastes Received:					
	Click to enter text.					
	No. 6 at a					
4.	Existing coverage in individual permit					
	Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?					
	□ Yes □ No					
	If yes, provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.					
	Click to enter text.					
	*					
5.	Zero stormwater discharge					
	Do you intend to have no discharge of stormwater via use of evaporation or other means?					
	□ Yes □ No					
	If yes, explain below then skip to Subsection F. Other Wastes Received.					
	Click to enter text.					
	Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.					
6.	Request for coverage in individual permit					
	Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?					
	□ Yes □ No					
	If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you					

		it to water in the state.
		Click to enter text.
		Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.
F.	Di	scharges to the Lake Houston Watershed
	Do	oes the facility discharge in the Lake Houston watershed?
		□ Yes ⊠ No
		yes, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions. ick to enter text.
G.	Ot	ther wastes received including sludge from other WWTPs and septic waste
	1.	Acceptance of sludge from other WWTPs
		Does or will the facility accept sludge from other treatment plants at the facility site?
		□ Yes ⊠ No
		If yes, attach sewage sludge solids management plan. See Example 5 of instructions.
		In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an
		estimate of the BOD ₅ concentration of the sludge, and the design BOD ₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
		Click to enter text.
		Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	2.	Acceptance of septic waste
		Is the facility accepting or will it accept septic waste?
		□ Yes ⊠ No
		If yes, does the facility have a Type V processing unit?
		□ Yes □ No
		If yes, does the unit have a Municipal Solid Waste permit?
		□ Yes □ No

]	If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD ₅ concentration of the septic waste, and the
	design BOD ₅ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
	Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)
	Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?
	□ Yes ⊠ No
	If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.
	Click to enter text.
Section	on 7. Pollutant Analysis of Treated Effluent (Instructions Page 49)
Is the f	facility in operation?
	Yes □ No
If no, t	his section is not applicable. Proceed to Section 8.
faciliti	provide effluent analysis data for the listed pollutants. <i>Wastewater treatment</i> es complete Table 1.0(2). <i>Water treatment facilities</i> discharging filter backwash water, etc Table 1.0(3). Provide copies of the laboratory results sheets. These tables are not

complete Table 1.0(3). Provide copies of the laboratory results sheets. **These tables are rapplicable for a minor amendment without renewal.** See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD ₅ , mg/l					
Total Suspended Solids, mg/l					
Ammonia Nitrogen, mg/l					
Nitrate Nitrogen, mg/l					
Total Kjeldahl Nitrogen, mg/l					
Sulfate, mg/l					
Chloride, mg/l					
Total Phosphorus, mg/l					
pH, standard units					
Dissolved Oxygen*, mg/l					
Chlorine Residual, mg/l					
E.coli (CFU/100ml) freshwater					
Entercocci (CFU/100ml) saltwater					
Total Dissolved Solids, mg/l					
Electrical Conductivity, µmohs/cm, †					
Oil & Grease, mg/l					
Alkalinity (CaCO ₃)*, mg/l					

^{*}TPDES permits only †TLAP permits only

Table1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l					0
Total Dissolved Solids, mg/l					
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO ₃), mg/l					

Section 8. Facility Operator (Instructions Page 49)

Facility Operator Name: Click to enter text.

Facility Operator's License Classification and Level: Click to enter text.

Facility Operator's License Number: Click to enter text.

Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 50)

Α.	WW.	WTP's Sewage Sludge or Biosolids Management Facility Type				
	Che	ck all that apply. See instructions for guidance				
		Design flow>= 1 MGD				
		Serves >= 10,000 people				
	profess.	Class I Sludge Management Facility (per 40 CFR § 503.9)				
		Biosolids generator				
		Biosolids end user - land application (onsite)				
		Biosolids end user - surface disposal (onsite)				
		Biosolids end user - incinerator (onsite)				
B.	ww	ΓP's Sewage Sludge or Biosolids Treatment Process				
	Che	ck all that apply. See instructions for guidance.				
		Aerobic Digestion				
		Air Drying (or sludge drying beds)				
		Lower Temperature Composting				
		Lime Stabilization				
		Higher Temperature Composting				
		Heat Drying				
		Thermophilic Aerobic Digestion				
		Beta Ray Irradiation				
		Gamma Ray Irradiation				
		Pasteurization				
		Preliminary Operation (e.g. grinding, de-gritting, blending)				
	1.	Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)				
		Sludge Lagoon				
		Temporary Storage (< 2 years)				
		Long Term Storage (>= 2 years)				
	П	Methane or Biogas Recovery				
		Other Treatment Process: Click to enter text.				

C. Sewage Sludge or Biosolids Management

Provide information on the *intended* sewage sludge or biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the

permit will authorize all sewage sludge or biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

Biosolids Management

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.

If "Other" is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): Click to enter text.

		-	
1)	Die	posal	CITA
L.	פוע	hosar	DICC

Disposal site name: Click to enter text.

TCEQ permit or registration number: <u>Click to enter text.</u>
County where disposal site is located: <u>Click to enter text.</u>

E. Transportation method

Method of transportation (truck, train, pipe, other): truck

Name of the hauler: <u>Brownville Navigation District</u>

Hauler registration number: 21816

Sludge is transported as a:

Liquid ⊠	semi-liquid 🗆	semi-solid \square	solid \square

Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 52)

A. Beneficial use authorization

Does t benefi			g permit include authorization for land application of biosolids for
	Yes	\boxtimes	No
If yes , benefi			equesting to continue this authorization to land apply biosolids for
	Yes		No
If was	ie the	com	polated Application for Dormit for Ranaficial Land Lice of Sawage

If yes, is the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451) attached to this permit application (see the instructions for details)?

	Yes	No
100000	1 00	 110

B.	Sludge	ge processing authorization							
		he existing permit inclu e or disposal options?	de authorization f	or any	of the	follow	ing slu	dge proces	sing,
	Slu	dge Composting	a ^a		Yes		No		
	Ma	rketing and Distribution	n of Biosolids		Yes	\boxtimes	No		
	Slu	dge Surface Disposal o	Sludge Monofill		Yes	\boxtimes	No		
	Ter	nporary storage in slud	ge lagoons		Yes		No	K.	
	author Techn	to any of the above sludication, is the complete ical Report (TCEQ Form	ed Domestic Waste n No. 10056) attac	water hed to	: Permi o this p	t Appl ermit a	ication applica	: Sewage S	
		11. Sewage Sludg		struc	ctions	Page	2 53)		
Do		facility include sewage	sludge lagoons?						
	□ Ye				_				
If y	es, con	nplete the remainder of	this section. If no,	proce	eed to S	Section	12.		
A.	Location	on information							
		llowing maps are requi e the Attachment Numl		d as p	art of tl	he app	licatior	ı. For each	map,
	•	Original General Highw	ay (County) Map:						
		Attachment: Click to e	nter text.						
	•	USDA Natural Resource	es Conservation Ser	rvice S	Soil Mar):			
		Attachment: Click to en	<u>nter text.</u>						
		Federal Emergency Mar							
		Attachment: Click to en	nter text.						
		Site map:							
		Attachment: Click to ex		•					
	Discus apply.	s in a description if any	of the following e	xist w	ithin th	ie lago	on area	a. Check all	that
		Overlap a designated 100-year frequency flood plain							
		Soils with flooding classification							
		Overlap an unstable a	rea						
		Wetlands							
		Located less than 60 r	neters from a fault						
		None of the above							
	Attachment: Click to enter text.								

If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide	1
the protective measures to be utilized including type and size of protective structures:	

N/A		
	Sec.	
	a	(4
	SAP A	

B. Temporary storage information

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in *Section 7 of Technical Report 1.0.*

Nitrate Nitrogen, mg/kg: Click to enter text.

Total Kjeldahl Nitrogen, mg/kg: Click to enter text.

Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: Click to enter text.

Phosphorus, mg/kg: Click to enter text.

Potassium, mg/kg: Click to enter text.

pH, standard units: Click to enter text.

Ammonia Nitrogen mg/kg: Click to enter text.

Arsenic: Click to enter text.

Cadmium: Click to enter text.

Chromium: Click to enter text.

Copper: Click to enter text.

Lead: Click to enter text.

Mercury: Click to enter text.

Molybdenum: Click to enter text.

Nickel: Click to enter text.

Selenium: Click to enter text.

Zinc: Click to enter text.

Total PCBs: <u>Click to enter text.</u>

Provide the following information:

Volume and frequency of sludge to the lagoon(s): Click to enter text.

Total dry tons stored in the lagoons(s) per 365-day period: Click to enter text.

Total dry tons stored in the lagoons(s) over the life of the unit: <u>Click to enter text.</u>

C. Liner information

Does the active,	/proposed	sludge	lagoon(s)	have a	liner	with a	ı maximum	hydraulic
conductivity of	1x10 ⁻⁷ cm/	'sec?						

12000		10.00	
125	Yes	1	No
	163	4.00	1111

330	If yes, describe the liner below. Please note that a liner is required.
	N/A
D.	Site development plan
	Provide a detailed description of the methods used to deposit sludge in the lagoon(s):
	N/A
	*
	Attach the following documents to the application.
	 Plan view and cross-section of the sludge lagoon(s)
	Attachment: Click to enter text.
	Copy of the closure plan
	Attachment: Click to enter text.
	 Copy of deed recordation for the site
	Attachment: Click to enter text.
	 Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons
	Attachment: Click to enter text.
	 Description of the method of controlling infiltration of groundwater and surface water from entering the site
	Attachment: Click to enter text.
	 Procedures to prevent the occurrence of nuisance conditions
	Attachment: Click to enter text.
E.	Groundwater monitoring
	Is groundwater monitoring currently conducted at this site, or are any wells available for groundwater monitoring, or are groundwater monitoring data otherwise available for the sludge lagoon(s)?
	□ Yes ⊠ No
	If groundwater monitoring data are available, provide a copy. Provide a profile of soil types encountered down to the groundwater table and the depth to the shallowest groundwater as a separate attachment.
	Attachment: Click to enter text.

Section 12. Authorizations/Compliance/Enforcement (Instructions Page 54)

A. Additional authorizations
Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?
□ Yes ⊠ No
If yes, provide the TCEQ authorization number and description of the authorization:
Click to enter text.
B. Permittee enforcement status
Is the permittee currently under enforcement for this facility?
□ Yes ⊠ No
Is the permittee required to meet an implementation schedule for compliance or enforcement?
□ Yes ⊠ No
If yes to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:
Click to enter text.
C . L 10 DODA (CEDCIA IV
Section 13. RCRA/CERCLA Wastes (Instructions Page 55)
A. RCRA hazardous wastes
Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

□ Yes ⊠ No

B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

□ Yes ⊠ No

C. Details about wastes received

If yes to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: Click to enter text.

Section 14. Laboratory Accreditation (Instructions Page 55)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25*, *Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - o periodically inspected by the TCEQ; or
 - o located in another state and is accredited or inspected by that state; or
 - o performing work for another company with a unit located in the same site; or
 - o performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Printed Name: <u>Manuel Martinez</u>
Title: Acting Director of Engineering

Signature:	
Date:	

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.1

The following information is required for new and amendment major applications.

Section 1. Justification for Permit (Instructions Page 56)

A.	Iustification	of permit need
7 7	JACOLARACACACACA	OI POILITE INCOM

B.

Provide a detailed discussion regarding the need for any phase(s) not currently permitted
Failure to provide sufficient justification may result in the Executive Director
recommending denial of the proposed phase(s) or permit.

rec	nmending denial of the proposed phase(s) or permit.
N	
Reg	onalization of facilities
	dditional guidance, please review $\underline{TCEQ's}$ Regionalization Policy for Wastewater \underline{ment}^1 .
	de the following information concerning the potential for regionalization of domestic water treatment facilities:
1.	unicipally incorporated areas
	the applicant is a city, then Item 1 is not applicable. Proceed to Item 2 Utility CCN eas.
	any portion of the proposed service area located in an incorporated city?
	□ Yes □ No □ Not Applicable
	yes, within the city limits of: <u>Click to enter text.</u>
	yes, attach correspondence from the city.
	Attachment: Click to enter text.
	consent to provide service is available from the city, attach a justification for the oposed facility and a cost analysis of expenditures that includes the cost of onnecting to the city versus the cost of the proposed facility or expansion attached.
	Attachment: Click to enter text.
2.	tility CCN areas
	any portion of the proposed service area located inside another utility's CCN area?
	□ Yes □ No

¹ https://www.tceq.texas.gov/permitting/wastewater/tceq-regionalization-for-wastewater

If yes, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the CCN facilities versus the cost of the proposed facility or expansion. Attachment: Click to enter text. 3. Nearby WWTPs or collection systems Are there any domestic permitted wastewater treatment facilities or collection systems located within a three-mile radius of the proposed facility? Yes \boxtimes No If yes, attach a list of these facilities and collection systems that includes each permittee's name and permit number, and an area map showing the location of these facilities and collection systems. Attachment: Click to enter text. If yes, attach proof of mailing a request for service to each facility and collection system, the letters requesting service, and correspondence from each facility and collection system. Attachment: Click to enter text. If the facility or collection system agrees to provide service, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the facility or collection system versus the cost of the proposed facility or expansion. Attachment: Click to enter text. **Proposed Organic Loading (Instructions Page 58)** Section 2. Is this facility in operation? Yes □ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading Facility Design Flow (flow being requested in application): Click to enter text. Average Influent Organic Strength or BOD₅ Concentration in mg/l: Click to enter text. Average Influent Loading (lbs/day = total average flow X average BOD₅ conc. X 8.34): Click to enter text. Provide the source of the average organic strength or BOD₅ concentration.

Click to enter text.

B. Proposed organic loading

This table must be completed if this application is for a facility that is not in operation or if this application is to request an increased flow that will impact organic loading.

Table 1.1(1) - Design Organic Loading

Source	Total Average Flow (MGD)	Influent BOD5 Concentration (mg/l)
Municipality		
Subdivision		
Trailer park - transient		
Mobile home park		
School with cafeteria and showers		
School with cafeteria, no showers		
Recreational park, overnight use		
Recreational park, day use		
Office building or factory		
Motel		
Restaurant		Н
Hospital		
Nursing home		
Other		
TOTAL FLOW from all sources		
AVERAGE BOD₅ from all sources		

Section 3. Proposed Effluent Quality and Disinfection (Instructions Page 58)

A. Existing/Interim I Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.

Total Suspended Solids, mg/l: Click to enter text.

Ammonia Nitrogen, mg/l: <u>Click to enter text.</u>

Total Phosphorus, mg/l: Click to enter text.

Dissolved Oxygen, mg/l: Click to enter text.

Other: Click to enter text.

В.	Interim II Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.
	Total Suspended Solids, mg/l: Click to enter text.
	Ammonia Nitrogen, mg/l: <u>Click to enter text.</u>
	Total Phosphorus, mg/l: <u>Click to enter text.</u>
	Dissolved Oxygen, mg/l: Click to enter text.
	Other: Click to enter text.
C.	Final Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: Click to enter text.
	Total Suspended Solids, mg/l: Click to enter text.
	Ammonia Nitrogen, mg/l: Click to enter text.
	Total Phosphorus, mg/l: Click to enter text.
	Dissolved Oxygen, mg/l: <u>Click to enter text.</u>
	Other: Click to enter text.
D.	Disinfection Method
	Identify the proposed method of disinfection.
	\Box Chlorine: Click to enter text. mg/l after Click to enter text. minutes detention time at peak flow
	Dechlorination process: Click to enter text.
	☐ Ultraviolet Light: <u>Click to enter text.</u> seconds contact time at peak flow
	□ Other: Click to enter text.
Se	ction 4. Design Calculations (Instructions Page 58)
	tach design calculations and plant features for each proposed phase. Example 4 of the
	tructions includes sample design calculations and plant features.
	Attachment: Click to enter text.
So	ction 5. Facility Site (Instructions Page 59)
JC	ction 3. Tacinty site (instructions rage 33)
A.	100-year floodplain
	Will the proposed facilities be located <u>above</u> the 100-year frequency flood level?
	□ Yes □ No
	If no , describe measures used to protect the facility during a flood event. Include a site map showing the location of the treatment plant within the 100-year frequency flood level. If applicable, provide the size and types of protective structures.
	Click to enter text.

	Provide	e the source(s) used to determine 100-year frequency flood plain.
	Click	to enter text.
	For a n	ew or expansion of a facility, will a wetland or part of a wetland be filled?
		Yes □ No
	If yes,	has the applicant applied for a US Corps of Engineers 404 Dredge and Fill Permit?
		Yes □ No
	If yes,	provide the permit number: <u>Click to enter text.</u>
		provide the approximate date you anticipate submitting your application to the <u>Click to enter text.</u>
В.	Wind r	rose
	Attach	a wind rose: Click to enter text.
So	ction	6. Permit Authorization for Sewage Sludge Disposal
<i>5</i> €	ction	(Instructions Page 59)
A.	Benefi	cial use authorization
		u requesting to include authorization to land apply sewage sludge for beneficial use perty located adjacent to the wastewater treatment facility under the wastewater ?
		Yes □ No
		attach the completed Application for Permit for Beneficial Land Use of Sewage (TCEQ Form No. 10451): Click to enter text.
В.	Sludge	processing authorization
		y the sludge processing, storage or disposal options that will be conducted at the vater treatment facility:
		Sludge Composting
		Marketing and Distribution of sludge
		Sludge Surface Disposal or Sludge Monofill
	Waster	of the above, sludge options are selected, attach the completed Domestic water Permit Application: Sewage Sludge Technical Report (TCEQ Form No.): Click to enter text.
Se	ection	7. Sewage Sludge Solids Management Plan (Instructions Page 60)

Attach a solids management plan to the application.

Attachment: Click to enter text.

The sewage sludge solids management plan must contain the following information:

• Treatment units and processes dimensions and capacities

- Solids generated at 100, 75, 50, and 25 percent of design flow
- Mixed liquor suspended solids operating range at design and projected actual flow
- Quantity of solids to be removed and a schedule for solids removal
- Identification and ownership of the ultimate sludge disposal site
- For facultative lagoons, design life calculations, monitoring well locations and depths, and the ultimate disposal method for the sludge from the facultative lagoon

An example of a sewage sludge solids management plan has been included as Example 5 of the instructions.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

Section 1. Domestic Drinking Water Supply (Instructions Page 63)
Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?
□ Yes ⊠ No
If no , proceed it Section 2. If yes , provide the following:
Owner of the drinking water supply: Click to enter text.
Distance and direction to the intake: Click to enter text.
Attach a USGS map that identifies the location of the intake.
Attachment: Click to enter text.
Section 2. Discharge into Tidally Affected Waters (Instructions Page 63)
Does the facility discharge into tidally affected waters?
□ Yes ⊠ No
If no , proceed to Section 3. If yes , complete the remainder of this section. If no, proceed to Section 3.
A. Receiving water outfall
Width of the receiving water at the outfall, in feet: Click to enter text.
B. Oyster waters
Are there oyster waters in the vicinity of the discharge?
□ Yes □ No
If yes, provide the distance and direction from outfall(s).
Click to enter text.
C. Sea grasses
Are there any sea grasses within the vicinity of the point of discharge?
□ Yes □ No
If yes, provide the distance and direction from the outfall(s).
Click to enter text.

section 5. Classified segments (instructions rage 05)			
Is the discharge directly into (or within 300 feet of) a classified segment?			
□ Yes ⊠ No			
If yes, this Worksheet is complete.			
If no, complete Sections 4 and 5 of this Worksheet.			
Section 4. Description of Immediate Receiving Waters (Instructions			
Page 63)			
Name of the immediate receiving waters: <u>Click to enter text.</u>			
A. Receiving water type			
Identify the appropriate description of the receiving waters.			
□ Stream			
☐ Freshwater Swamp or Marsh			
□ Lake or Pond			
Surface area, in acres: Click to enter text.			
Average depth of the entire water body, in feet: Click to enter text.			
Average depth of water body within a 500-foot radius of discharge point, in feet Click to enter text.			
Man-made Channel or Ditch			
□ Open Bay			
□ Tidal Stream, Bayou, or Marsh			
□ Other, specify: <u>Click to enter text.</u>			
B. Flow characteristics			
If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area <i>upstream</i> of the discharge. For new discharges, characterize the area <i>downstream</i> of the discharge (check one).			
☑ Intermittent - dry for at least one week during most years			
\square Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses			
☐ Perennial - normally flowing			
Check the method used to characterize the area upstream (or downstream for new dischargers).			
□ USGS flow records			
☐ Historical observation by adjacent landowners			
□ Personal observation			
Other, specify: Click to enter text.			

C.	C. Downstream perennial confluences						
	List the names of all perennial streams that join the receiving water within three miles downstream of the discharge point.						
	Click to enter text.						
	105						
D.	D. Downstream characteristics						
		receiving water characteristics char rge (e.g., natural or man-made dams		rithin three miles downstream of the ads, reservoirs, etc.)?			
		Yes ⊠ No					
	If yes,	discuss how.					
	Click	to enter text.		566			
E.	Norma	l dry weather characteristics					
(STORE)	Provide general observations of the water body during normal dry weather conditions.						
	Click to enter text.						
	Date a	nd time of observation: Click to ente	er tex	ct.			
	Was th	e water body influenced by stormwa	ater 1	runoff during observations?			
		Yes □ No					
	District Control						
Se	ection	5. General Characteristics Page 65)	s of	the Waterbody (Instructions			
Α.	Upstre	eam influences					
		mmediate receiving water upstream need by any of the following? Check		he discharge or proposed discharge site nat apply.			
		Oil field activities	\boxtimes	Urban runoff			
		Upstream discharges		Agricultural runoff			
		Septic tanks		Other(s), specify: Click to enter text.			

B.	wateri	aterbody uses				
	Observ	oserved or evidences of the following uses. Check all that apply.				
		Livestock watering		Contact recreation		
		Irrigation withdrawal		Non-contact recreation		
		Fishing		Navigation		
		Domestic water supply		Industrial water supply		
		Park activities		Other(s), specify: Click to enter text.		
C.	Waterk	oody aesthetics				
		k one of the following that best describes the aesthetics of the receiving water and urrounding area.				
		Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional				
		Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored				
		Common Setting: not offensive; developed but uncluttered; water may be colored or turbid				
		Offensive: stream does not enhance aesthetics; cluttered; highly developed; dumping areas; water discolored				

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.1: STREAM PHYSICAL CHARACTERISTICS

Required for new applications, major facilities, and applications adding an outfall.

Worksheet 2.1 is not required for discharges to intermittent streams or discharges directly to (or within 300 feet of) a classified segment.

Section 1. General information (instructions Page 63)					
Date of study: Click to enter text. Time of study: Click to enter text.					
Stream name: Click to enter text.					
Location: Click to enter text.					
Type of stream upstream of existing discharge or downstream of proposed discharge (check one).					
□ Perennial □ Intermittent with perennial pools					
Section 2. Data Collection (Instructions Page 65)					
Number of stream bends that are well defined: Click to enter text.					
Number of stream bends that are moderately defined: Click to enter text.					
Number of stream bends that are poorly defined: Click to enter text.					
Number of riffles: Click to enter text.					
Evidence of flow fluctuations (check one):					
□ Minor □ moderate □ severe					
Indicate the observed stream uses and if there is evidence of flow fluctuations or channel obstruction/modification.					
Click to enter text.					

Stream transects

In the table below, provide the following information for each transect downstream of the existing or proposed discharges. Use a separate row for each transect.

Table 2.1(1) - Stream Transect Records

Stream type at transect	Transect location	Water surface	Stream depths (ft) at 4 to 10 points along each
Select riffle, run, glide, or pool. See Instructions,		width (ft)	transect from the channel bed to the water surface. Separate the measurements
Definitions section.			with commas.
Choose an item.			
Choose an item.			9
Choose an item.			

Section 3. Summarize Measurements (Instructions Page 65)

Streambed slope of entire reach, from USGS map in feet/feet: Click to enter text.

Approximate drainage area above the most downstream transect (from USGS map or county highway map, in square miles): <u>Click to enter text.</u>

Length of stream evaluated, in feet: Click to enter text.

Number of lateral transects made: Click to enter text.

Average stream width, in feet: Click to enter text.

Average stream depth, in feet: Click to enter text.

Average stream velocity, in feet/second: Click to enter text.

Instantaneous stream flow, in cubic feet/second: Click to enter text.

Indicate flow measurement method (type of meter, floating chip timed over a fixed distance, etc.): <u>Click to enter text.</u>

Size of pools (large, small, moderate, none): Click to enter text.

Maximum pool depth, in feet: Click to enter text.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.0: LAND DISPOSAL OF EFFLUENT

The following is required for renewal, new, and amendment permit applications.

Section 1. Type of Disposal System (Instructions Page 67)

Identify the method of land disposal:				
	Surface application		Subsurface application	
	Irrigation		Subsurface soils absorption	
	Drip irrigation system		Subsurface area drip dispersal system	
100	Evaporation		Evapotranspiration beds	
	Other (describe in detail): <u>Click to enter text.</u>			
NOTE: All applicants without authorization or proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0.				
Parameter Vie	and the second s			

For existing authorizations, provide Registration Number: Click to enter text.

Section 2. Land Application Site(s) (Instructions Page 67)

In table 3.0(1), provide the requested information for the land application sites. Include the agricultural or cover crop type (wheat, cotton, alfalfa, bermuda grass, native grasses, etc.), land use (golf course, hayland, pastureland, park, row crop, etc.), irrigation area, amount of effluent applied, and whether or not the public has access to the area. Specify the amount of land area and the amount of effluent that will be allotted to each agricultural or cover crop, if more than one crop will be used.

Table 3.0(1) - Land Application Site Crops

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N

Section 3. Storage and Evaporation Lagoons/Ponds (Instructions Page 67)

Table 3.0(2) - Storage and Evaporation Ponds

Pond Number	Surface Area (acres)	Storage Volume (acre-feet)	Dimensions	Liner Type
D.				

Attach a copy of a liner certification that was prepared, signed, and sealed by a Texas licensed professional engineer for each pond.

licensed professional engineer for each pond.
Attachment: Click to enter text.
Section 4. Flood and Runoff Protection (Instructions Page 67)
Is the land application site within the 100-year frequency flood level?
□ Yes □ No
If yes, describe how the site will be protected from inundation.
Click to enter text.
Provide the source used to determine the 100-year frequency flood level:
Click to enter text.
_ #
Provide a description of tailwater controls and rainfall run-on controls used for the land application site.
Click to enter text.

Section 5. Annual Cropping Plan (Instructions Page 67)

Attach an Annual Cropping Plan which includes a discussion of each of the following items. If not applicable, provide a detailed explanation indicating why. **Attachment**: Click to enter text.

- Soils map with crops
- Cool and warm season plant species
- Crop yield goals
- Crop growing season
- Crop nutrient requirements
- · Additional fertilizer requirements
- Minimum/maximum harvest height (for grass crops)
- Supplemental watering requirements
- Crop salt tolerances
- Harvesting method/number of harvests
- Justification for not removing existing vegetation to be irrigated

Section 6. Well and Map Information (Instructions Page 68)

Attach a USGS map with the following information shown and labeled. If not applicable, provide a detailed explanation indicating why. **Attachment**: <u>Click to enter text.</u>

- The boundaries of the land application site(s)
- Waste disposal or treatment facility site(s)
- On-site buildings
- Buffer zones
- Effluent storage and tailwater control facilities
- All water wells within 1-mile radius of the disposal site or property boundaries
- All springs and seeps onsite and within 500 feet of the property boundaries
- All surface waters in the state onsite and within 500 feet of the property boundaries
- All faults and sinkholes onsite and within 500 feet of the property

List and cross reference all water wells located within a half-mile radius of the disposal site or property boundaries shown on the USGS map in the following table. Attach additional pages as necessary to include all of the wells.

Table 3.0(3) - Water Well Data

Well ID	Well Use	Producing? Y/N	Open, cased, capped, or plugged?	Proposed Best Management Practice
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	

If water quality data or well log information is available please include the information in an attachment listed by Well ID.

Attachment: Click to enter text.

Section 7. Groundwater Quality (Instructions Page 68)

Attach a Groundwater Quality Technical Report which assesses the impact of the wastewater disposal system on groundwater. This report shall include an evaluation of the water wells (including the information in the well table provided in Item 6. above), the wastewater application rate, and pond liners. Indicate by a check mark that this report is provided.

Attachment: Click to enter text.
Are groundwater monitoring wells available onsite? \square Yes \square No
Do you plan to install ground water monitoring wells or lysimeters around the land application site? \Box Yes \Box No
If yes, provide the proposed location of the monitoring wells or lysimeters on a site map.
Attachment: Click to enter text.

Section 8. Soil Map and Soil Analyses (Instructions Page 69)

A. Soil map

Attach a USDA Soil Survey map that shows the area to be used for effluent disposal.

Attachment: Click to enter text.

B. Soil analyses

Attach the laboratory results sheets from the soil analyses. **Note**: for renewal applications, the current annual soil analyses required by the permit are acceptable as long as the test date is less than one year prior to the submission of the application.

Attachment: Click to enter text.

List all USDA designated soil series on the proposed land application site. Attach additional pages as necessary.

Table 3.0(4) - Soil Data

Soil Series	Depth from Surface	Permeability	Available Water Capacity	Curve Number
				·

Section 9. Effluent Monitoring Data (Instructions Page 70)

□ Yes □					_	
	on is not applica					
yes, provide t ermit. If a para	the effluent mo ameter is not re	nitoring o gulated i	data for the n the exist	ie parame ting perm	eters regulated in th nit, enter N/A.	ne existing
able 3.0(5) – Ef	ffluent Monitorin	ng Data			×	
Date	30 Day Avg Flow MGD	BOD5 mg/l	TSS mg/l	рН	Chlorine Residual mg/l	Acres irrigated
					-	
					F	
1812						
			8			
•						
Turbe (
						V.
	1					
						x
44						
	1	25				

Provide a discussion of all persistent excursions above the permitted limits and any corrective actions taken.
Click to enter text.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.1: SURFACE LAND DISPOSAL OF EFFLUENT

The following is required for new and major amendment permit applications. Renewal and minor amendment permit applications may be asked for this worksheet on a case by case basis.

Section 1. Surface Disposal (Instructions Page 71)

Complete the item that applies for the method of disposal being used.

A. Irrigation

Area under irrigation, in acres: Click to enter text.

Design application frequency:

hours/day Click to enter text. And days/week Click to enter text.

Land grade (slope):

average percent (%): Click to enter text.

maximum percent (%): Click to enter text.

Design application rate in acre-feet/acre/year: Click to enter text.

Design total nitrogen loading rate, in lbs N/acre/year: Click to enter text.

Soil conductivity (mmhos/cm): Click to enter text.

Method of application: <u>Click to enter text.</u>

Attach a separate engineering report with the water balance and storage volume calculations, method of application, irrigation efficiency, and nitrogen balance.

Attachment: Click to enter text.

B. Evaporation ponds

Daily average effluent flow into ponds, in gallons per day: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations.

Attachment: Click to enter text.

C. Evapotranspiration beds

Number of beds: Click to enter text.

Area of bed(s), in acres: <u>Click to enter text.</u>

Depth of bed(s), in feet: Click to enter text.

Void ratio of soil in the beds: <u>Click to enter text.</u>

Storage volume within the beds, in acre-feet: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations, and a description of the lining.

Attachment: Click to enter text.

D	Over	bacl	FLOXA
v.	Over	Idliu	HOW

Area used for application, in acres: Click to enter text.

Slopes for application area, percent (%): Click to enter text.

Design application rate, in gpm/foot of slope width: Click to enter text.

Slope length, in feet: Click to enter text.

Design BOD₅ loading rate, in lbs BOD₅/acre/day: Click to enter text.

Design application frequency:

hours/day: Click to enter text. And days/week: Click to enter text.

Attach a separate engineering report with the method of application and design requirements according to *30 TAC Chapter 217*.

Attachment: Click to enter text.

Section 2. Edwards Aquifer (Instructions Page 72)

Is the facility sub	ject to 30	TAC C	hapter 213,	Edwards Ad	uifer	Rules?
---------------------	------------	-------	-------------	------------	-------	--------

□ Yes □ No

If yes, is the facility located on the Edwards Aquifer Recharge Zone?

□ Yes □ No

If yes, attach a geological report addressing potential recharge features.

Attachment: Click to enter text.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.2: SURFACE LAND DISPOSAL OF EFFLUENT

The following **is required** for **new and major amendment** permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **does not meet** the definition of a subsurface area drip dispersal system as defined in *30 TAC Chapter 222, Subsurface Area Drip Dispersal System.*

Section 1. Subsurface Application (Instructions Page 73)
Identify the type of system:
□ Conventional Gravity Drainfield, Beds, or Trenches (new systems must be less than 5,000 GPD)
□ Low Pressure Dosing
☐ Other, specify: <u>Click to enter text.</u>
Application area, in acres: Click to enter text.
Area of drainfield, in square feet: Click to enter text.
Application rate, in gal/square foot/day: Click to enter text.
Depth to groundwater, in feet: Click to enter text.
Area of trench, in square feet: Click to enter text.
Dosing duration per area, in hours: Click to enter text.
Number of beds: Click to enter text.
Dosing amount per area, in inches/day: Click to enter text.
Infiltration rate, in inches/hour: Click to enter text.
Storage volume, in gallons: <u>Click to enter text.</u>
Area of bed(s), in square feet: Click to enter text.
Soil Classification: Click to enter text.
Attach a separate engineering report with the information required in $30\ TAC\ \S\ 309.20$, excluding the requirements of $\S\ 309.20\ b(3)(A)$ and (B) design analysis which may be asked for on a case by case basis. Include a description of the schedule of dosing basin rotation.
Attachment: Click to enter text.
Section 2. Edwards Aquifer (Instructions Page 73)
Is the subsurface system over the Edwards Aquifer Recharge Zone as mapped by TCEQ?
□ Yes □ No
Is the subsurface system over the Edwards Aquifer Transition Zone as mapped by TCEQ?
□ Yes □ No
If yes to either question , the subsurface system may be prohibited by <i>30 TAC §213.8</i> . Please

call the Municipal Permits Team, at 512-239-4671, to schedule a pre-application meeting.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.3: SUBSURFACE AREA DRIP DISPERSAL (SADDS) LAND DISPOSAL OF EFFLUENT

The following **is required** for **new and major amendment** subsurface area drip dispersal system permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **meets** the definition of a subsurface area drip dispersal system as defined in *30 TAC Chapter 222*, *Subsurface Area Drip Dispersal System*.

Se	ection 1. Administrative Information (Instructions Page 74)
Α.	Provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the treatment facility:
В.	<u>Click to enter text.</u> Is the owner of the land where the treatment facility is located the same as the owner of the treatment facility?
	□ Yes □ No
	If no , provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the land where the treatment facility is located.
	Click to enter text.
C.	Owner of the subsurface area drip dispersal system: Click to enter text.
D.	Is the owner of the subsurface area drip dispersal system the same as the owner of the wastewater treatment facility or the site where the wastewater treatment facility is located?
	□ Yes □ No
	If no , identify the names of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in Item 1.C.
	Click to enter text.
Е.	Owner of the land where the subsurface area drip dispersal system is located: <u>Click to enter text.</u>
F.	Is the owner of the land where the subsurface area drip dispersal system is located the same as owner of the wastewater treatment facility, the site where the wastewater treatment facility is located, or the owner of the subsurface area drip dispersal system?
	□ Yes □ No
	If no , identify the name of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in item 1.E.
	Click to enter text.

Section 2. Subsurface Area Drip Dispersal System (Instructions Page 74)

A.	Type of system
	□ Subsurface Drip Irrigation
	□ Surface Drip Irrigation
	□ Other, specify: <u>Click to enter text.</u>
B.	Irrigation operations
	Application area, in acres: Click to enter text.
	Infiltration Rate, in inches/hour: Click to enter text.
	Average slope of the application area, percent (%): Click to enter text.
	Maximum slope of the application area, percent (%): Click to enter text.
	Storage volume, in gallons: <u>Click to enter text.</u>
	Major soil series: <u>Click to enter text.</u>
	Depth to groundwater, in feet: Click to enter text.
C.	Application rate
	Is the facility located west of the boundary shown in <i>30 TAC § 222.83</i> and also using a vegetative cover of non-native grasses over seeded with cool season grasses during the winter months (October-March)?
	□ Yes □ No
	If yes , then the facility may propose a hydraulic application rate not to exceed 0.1 gal/square foot/day.
	Is the facility located east of the boundary shown in <i>30 TAC § 222.83</i> or in any part of the state when the vegetative cover is any crop other than non-native grasses?
	□ Yes □ No
	If yes , the facility must use the formula in $30\ TAC\ \S 222.83$ to calculate the maximum hydraulic application rate.
	Do you plan to submit an alternative method to calculate the hydraulic application rate for approval by the executive director?
	□ Yes □ No
	Hydraulic application rate, in gal/square foot/day: Click to enter text.
	Nitrogen application rate, in lbs/gal/day: Click to enter text.
D.	Dosing information
	Number of doses per day: Click to enter text.
	Dosing duration per area, in hours: Click to enter text.
	Rest period between doses, in hours: Click to enter text.
	Dosing amount per area, in inches/day: Click to enter text.

Number of zones: Click to enter text.
Does the proposed subsurface drip irrigation system use tree vegetative cover as a crop?
□ Yes □ No
If yes , provide a vegetation survey by a certified arborist. Please call the Water Quality Assessment Team at (512) 239-4671 to schedule a pre-application meeting.
Attachment: Click to enter text.

Section 3. Required Plans (Instructions Page 74)

A. Recharge feature plan

Attach a Recharge Feature Plan with all information required in 30 TAC §222.79.

Attachment: Click to enter text.

B. Soil evaluation

Attach a Soil Evaluation with all information required in 30 TAC §222.73.

Attachment: Click to enter text.

C. Site preparation plan

Attach a Site Preparation Plan with all information required in 30 TAC §222.75.

Attachment: Click to enter text.

D. Soil sampling/testing

Attach soil sampling and testing that includes all information required in *30 TAC §222.157*.

Attachment: Click to enter text.

Section 4. Floodway Designation (Instructions Page 75)

A. Site location

Is the existing/proposed land application site within a designated floodway?

□ Yes □ No

B. Flood map

Attach either the FEMA flood map or alternate information used to determine the floodway.

Attachment: Click to enter text.

Section 5. Surface Waters in the State (Instructions Page 75)

A. Buffer Map

Attach a map showing appropriate buffers on surface waters in the state, water wells, and springs/seeps.

Attachment: Click to enter text.

B. Buffer variance request
Do you plan to request a buffer variance from water wells or waters in the state?
□ Yes □ No
If yes, then attach the additional information required in $30\ TAC\ \S\ 222.81(c)$.
Attachment: Click to enter text.
Section 6. Edwards Aquifer (Instructions Page 75)
A. Is the SADDS located over the Edwards Aquifer Recharge Zone as mapped by TCEQ? ☐ Yes ☐ No
and and

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 4.0: POLLUTANT ANALYSIS REQUIREMENTS

The following **is required** for facilities with a permitted or proposed flow of **1.0 MGD or greater**, facilities with an approved **pretreatment** program, or facilities classified as a **major** facility. See instructions for further details.

This worksheet is not required minor amendments without renewal.

Section 1. Toxic Pollutants (Instructions Page 76)

For pollutan	ts identified in T	Table 4.0(1),	indicate the	type of sample	<u>.</u>
Grab □	Composite □				

Date and time sample(s) collected: Click to enter text.

Table 4.0(1) - Toxics Analysis

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acrylonitrile				50
Aldrin				0.01
Aluminum				2.5
Anthracene				10
Antimony				5
Arsenic				0.5
Barium				3
Benzene				10
Benzidine	e e			50
Benzo(a)anthracene				5
Benzo(a)pyrene				5
Bis(2-chloroethyl)ether			2,	10
Bis(2-ethylhexyl)phthalate				10
Bromodichloromethane			+	10
Bromoform				10
Cadmium	1500			1
Carbon Tetrachloride				2
Carbaryl				5
Chlordane*		1010		0.2
Chlorobenzene			27	10
Chlorodibromomethane				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (μg/l)	Number of Samples	MAL (μg/l)
Chloroform				10
Chlorpyrifos				0.05
Chromium (Total)				3
Chromium (Tri) (*1)				N/A
Chromium (Hex)				3
Copper				2
Chrysene				5
p-Chloro-m-Cresol				10
4,6-Dinitro-o-Cresol				50
p-Cresol				10
Cyanide (*2)				10
4,4'- DDD				0.1
4,4'- DDE				0.1
4,4'- DDT				0.02
2,4-D				0.7
Demeton (O and S)				0.20
Diazinon				0.5/0.1
1,2-Dibromoethane				10
m-Dichlorobenzene				10
o-Dichlorobenzene				10
p-Dichlorobenzene				10
3,3'-Dichlorobenzidine				5
1,2-Dichloroethane				10
1,1-Dichloroethylene	Α			10
Dichloromethane				20
1,2-Dichloropropane				10
1,3-Dichloropropene				10
Dicofol				1
Dieldrin				0.02
2,4-Dimethylphenol				10
Di-n-Butyl Phthalate				10
Diuron				0.09
Endosulfan I (alpha)				0.01

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (μg/l)	Number of Samples	MAL (μg/l)
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Epichlorohydrin			*******	
Ethylbenzene				10
Ethylene Glycol				
Fluoride				500
Guthion				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclohexane (alpha)	25			0.05
Hexachlorocyclohexane (beta)				0.05
gamma-Hexachlorocyclohexane				0.05
(Lindane)		,		
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Hexachlorophene				10
4,4'-Isopropylidenediphenol				1
Lead				0.5
Malathion				0.1
Mercury				0.005
Methoxychlor				2
Methyl Ethyl Ketone			30.0	50
Methyl tert-butyl ether		77		-
Mirex				0.02
Nickel				2
Nitrate-Nitrogen				100
Nitrobenzene				10
N-Nitrosodiethylamine				20
N-Nitroso-di-n-Butylamine				20
Nonylphenol				333

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Parathion (ethyl)				0.1
Pentachlorobenzene				20
Pentachlorophenol				5
Phenanthrene				10
Polychlorinated Biphenyls (PCB's) (*3)				0.2
Pyridine				20
Selenium				5
Silver				0.5
1,2,4,5-Tetrachlorobenzene				20
1,1,2,2-Tetrachloroethane				10
Tetrachloroethylene				10
Thallium				0.5
Toluene				10
Toxaphene				0.3
2,4,5-TP (Silvex)				0.3
Tributyltin (see instructions for explanation)		2:		0.01
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene	,			10
2,4,5-Trichlorophenol				50
TTHM (Total Trihalomethanes)				10
Vinyl Chloride				10
Zinc				5

^(*1) Determined by subtracting hexavalent Cr from total Cr.

^(*2) Cyanide, amenable to chlorination or weak-acid dissociable.

^(*3) The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

Section 2. Priority Pollutants

For pollutants	s identified in	Tables	4.0(2)A-E	indicate	type	of	sample.
----------------	-----------------	---------------	-----------	----------	------	----	---------

Grab □ Composite □

Date and time sample(s) collected: Click to enter text.

Table 4.0(2)A - Metals, Cyanide, and Phenols

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Antimony				5
Arsenic				0.5
Beryllium				0.5
Cadmium				1
Chromium (Total)				3
Chromium (Hex)				3
Chromium (Tri) (*1)				N/A
Copper				2
Lead				0.5
Mercury	×			0.005
Nickel				2
Selenium	-			5
Silver				0.5
Thallium				0.5
Zinc				5
Cyanide (*2)				10
Phenols, Total				10

^(*1) Determined by subtracting hexavalent Cr from total Cr.

^(*2) Cyanide, amenable to chlorination or weak-acid dissociable

Table 4.0(2)B - Volatile Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acrolein				50
Acrylonitrile				50
Benzene				10
Bromoform				10
Carbon Tetrachloride				2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroethane				50
2-Chloroethylvinyl Ether				10
Chloroform				10
Dichlorobromomethane [Bromodichloromethane]				10
1,1-Dichloroethane				10
1,2-Dichloroethane				10
1,1-Dichloroethylene				10
1,2-Dichloropropane				10
1,3-Dichloropropylene				10
[1,3-Dichloropropene]				
1,2-Trans-Dichloroethylene				10
Ethylbenzene				10
Methyl Bromide				50
Methyl Chloride				50
Methylene Chloride				20
1,1,2,2-Tetrachloroethane				10
Tetrachloroethylene				10
Toluene				10
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene				10
Vinyl Chloride				10

Table 4.0(2)C - Acid Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2-Chlorophenol				10
2,4-Dichlorophenol				10
2,4-Dimethylphenol				10
4,6-Dinitro-o-Cresol				50
2,4-Dinitrophenol				50
2-Nitrophenol		ii.		20
4-Nitrophenol				50
P-Chloro-m-Cresol	- A			10
Pentalchlorophenol				5
Phenol				10
2,4,6-Trichlorophenol				10

Table 4.0(2)D - Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Acenaphthene				10
Acenaphthylene				10
Anthracene				10
Benzidine				50
Benzo(a)Anthracene				5
Benzo(a)Pyrene				5
3,4-Benzofluoranthene				10
Benzo(ghi)Perylene				20
Benzo(k)Fluoranthene				5
Bis(2-Chloroethoxy)Methane				10
Bis(2-Chloroethyl)Ether				10
Bis(2-Chloroisopropyl)Ether				10
Bis(2-Ethylhexyl)Phthalate			TI TI	10
4-Bromophenyl Phenyl Ether				10
Butyl benzyl Phthalate				10
2-Chloronaphthalene				10
4-Chlorophenyl phenyl ether				10
Chrysene				5
Dibenzo(a,h)Anthracene				5
1,2-(o)Dichlorobenzene				10
1,3-(m)Dichlorobenzene				10
1,4-(p)Dichlorobenzene				10
3,3-Dichlorobenzidine				5
Diethyl Phthalate				10
Dimethyl Phthalate				10
Di-n-Butyl Phthalate				10
2,4-Dinitrotoluene				10
2,6-Dinitrotoluene				10
Di-n-Octyl Phthalate				10
1,2-Diphenylhydrazine (as Azobenzene)			8	20
Fluoranthene				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Fluorene				10
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclo-pentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene		85		5
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10

Table 4.0(2)E - Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
Aldrin		2.00.00		0.01
alpha-BHC (Hexachlorocyclohexane)				0.05
beta-BHC (Hexachlorocyclohexane)				0.05
gamma-BHC (Hexachlorocyclohexane)	9			0.05
delta-BHC (Hexachlorocyclohexane)				0.05
Chlordane				0.2
4,4-DDT				0.02
4,4-DDE				0.1
4,4,-DDD				0.1
Dieldrin				0.02
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Endrin Aldehyde		4		0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
PCB-1242			55	0.2
PCB-1254			,	0.2
PCB-1221				0.2
PCB-1232				0.2
PCB-1248				0.2
PCB-1260				0.2
PCB-1016				0.2
Toxaphene				0.3

^{*} For PCBS, if all are non-detects, enter the highest non-detect preceded by a "<".

A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user. Check all that apply. 2,4,5-trichlorophenoxy acetic acid Common Name 2,4,5-T, CASRN 93-76-5 2-(2,4,5-trichlorophenoxy) propanoic acid Common Name Silvex or 2,4,5-TP, CASRN 93-72-1 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate Common Name Erbon, CASRN 136-25-4 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate Common Name Ronnel, CASRN 299-84-3 2,4,5-trichlorophenol Common Name TCP, CASRN 95-95-4 hexachlorophene Common Name HCP, CASRN 70-30-4 For each compound identified, provide a brief description of the conditions of its/their presence at the facility. Click to enter text. B. Do you know or have any reason to believe that 2,3,7,8 Tetrachlorodibenzo-P-Dioxin (TCDD) or any congeners of TCDD may be present in your effluent? Yes No If yes, provide a brief description of the conditions for its presence. Click to enter text.

Section 3. Dioxin/Furan Compounds

C.	C. If any of the compounds in S	ubsection A or B are present, complete Table 4.0(2)F.
	For pollutants identified in T	able 4.0(2)F, indicate the type of sample.
	Grab □ Composite □	
	Date and time sample(s) colle	ected: <u>Click to enter text.</u>

Table 4.0(2)F - Dioxin/Furan Compounds

Compound	Toxic Equivalenc y Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
2,3,7,8 TCDD	1					10
1,2,3,7,8 PeCDD	0.5					50
2,3,7,8 HxCDDs	0.1			*	311143	50
1,2,3,4,6,7,8 HpCDD	0.01	12				50
2,3,7,8 TCDF	0.1			8		10
1,2,3,7,8 PeCDF	0.05					50
2,3,4,7,8 PeCDF	0.5					50
2,3,7,8 HxCDFs	0.1					50
2,3,4,7,8 HpCDFs	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					0.5
PCB 81	0.0003					0.5
PCB 126	0.1					0.5
PCB 169	0.03					0.5
Total						

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 5.0: TOXICITY TESTING REQUIREMENTS

The following **is required** for facilities with a current operating design flow of **1.0 MGD or greater**, with an EPA-approved **pretreatment** program (or those required to have one under 40 CFR Part 403), or are required to perform Whole Effluent Toxicity testing. See Page 86 of the instructions for further details.

This worksheet is not required minor amendments without renewal.

Section	1.	Rea	uired	Tests
the state of the state of the state of	THE REAL PROPERTY.	The second second second	The second second	

Indicate the number of 7-day chronic or 48-hour acute Whole Effluent Toxicity (WET) tests performed in the four and one-half years prior to submission of the application.

7-day Chronic: <u>Click to enter text.</u> 48-hour Acute: <u>Click to enter text.</u>

Section 2.	Toxicity Reduction Evaluations (TREs)
Has this facility performing a TR	completed a TRE in the past four and a half years? Or is the facility currently E?
□ Yes □	No
If yes, describe	the progress to date, if applicable, in identifying and confirming the toxicant.
Click to enter to	ext.

Section 3. Summary of WET Tests

If the required biomonitoring test information has not been previously submitted via both the Discharge Monitoring Reports (DMRs) and the Table 1 (as found in the permit), provide a summary of the testing results for all valid and invalid tests performed over the past four and one-half years. Make additional copies of this table as needed.

Table 5.0(1) Summary of WET Tests

Test Date	Test Species	NOEC Survival	NOEC Sub-lethal
-			
		77, 20	
- <u>172</u> 7			
		0	

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following is required for all publicly owned treatment works.

Section 1. All POTWs (Instructions Page 87)

A.	Industrial	users	(IUs)
			(,

Provide the number of each of the following types of industrial users (IUs) that discharge to your POTW and the daily flows from each user. See the Instructions for definitions of Categorical IUs, Significant IUs – non-categorical, and Other IUs.

B. Treatment plant interference

instructions)?

	Yes		No							
possib	le sou	rce(s	e dates,) of eacl erence.	duration interfer	n, descrij ence eve	ption of in ent. Includ	nterferend de the nar	ce, and pr nes of th	robable o e IUs tha	ause(s) and t may have
Click	to ent	er te	xt.			0				

In the past three years, has your POTW experienced treatment plant interference (see

C.	Treatment plant pass through
	In the past three years, has your POTW experienced pass through (see instructions)?
	□ Yes ⊠ No
	If yes, identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.
	Click to enter text.
D.	Pretreatment program
	Does your POTW have an approved pretreatment program?
	□ Yes □ No
	If yes, complete Section 2 only of this Worksheet.
	Is your POTW required to develop an approved pretreatment program?
	□ Yes □ No
	If yes, complete Section 2.c. and 2.d. only, and skip Section 3.
	If no to either question above , skip Section 2 and complete Section 3 for each significant industrial user and categorical industrial user.
Se	ection 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 87)
A.	Substantial modifications
	Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to <i>40 CFR §403.18</i> ?
	□ Yes ⊠ No
	If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
	Click to enter text.
	e a

B.	Non-substantial n	nodifications			
		ny non-substantial e not been submitte			
	□ Yes □	No			
	If yes, identify all including the purp	non-substantial mo oose of the modifica	difications that ation.	have not been	submitted to TCEQ,
	Click to enter tex	t.		x	
					3
C.	Effluent paramete	ers above the MAL			
	In Table 6.0(1), list	t all parameters me	asured above th	e MAL in the PO	OTW's effluent
	monitoring during	the last three year	s. Submit an att	achment if nece	essary.
Tal	ble 6.0(1) – Paramet	ters Above the MAL			
P	ollutant	Concentration	MAL	Units	Date
				0.0	
		11			
D.	Industrial user int	erruntions			
	Has any SIU, CIU, o	or other IU caused ouses throughs) at you	or contributed to ir POTW in the i	o any problems past three years	(excluding
	and burn	No			
		industry, describe nd probable polluta		icluding dates,	duration, description
	Click to enter text	l.			
					,
	20				
	Al.				

Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 88)

A.	General information
	Company Name: Click to enter text.
	SIC Code: Click to enter text.
	Contact name: <u>Click to enter text.</u>
	Address: Click to enter text.
	City, State, and Zip Code: <u>Click to enter text.</u>
	Telephone number: Click to enter text.
	Email address: Click to enter text.
В.	Process information
	Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).
	Click to enter text.
C.	Product and service information
	Provide a description of the principal product(s) or services performed.
	Click to enter text.
D.	Flow rate information
	See the Instructions for definitions of "process" and "non-process wastewater."
	Dec the motivations for decimations of productions
	Process Wastewater:
	Process Wastewater: Discharge, in gallons/day: Click to enter text.
	Process Wastewater: Discharge, in gallons/day: Click to enter text.
	Process Wastewater: Discharge, in gallons/day: <u>Click to enter text.</u> Discharge Type: □ Continuous □ Batch □ Intermittent Non-Process Wastewater:
	Process Wastewater: Discharge, in gallons/day: Click to enter text. Discharge Type: \square Continuous \square Batch \square Intermittent

E.	Pretreatment standards
	Is the SIU or CIU subject to technically based local limits as defined in the <i>i</i> nstructions?
	□ Yes □ No
	Is the SIU or CIU subject to categorical pretreatment standards found in $40\ CFR\ Parts\ 405-471$?
	□ Yes □ No
	If subject to categorical pretreatment standards , indicate the applicable category and subcategory for each categorical process.
	Category: Subcategories: Click to enter text.
	Click or tap here to enter text. Click to enter text.
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
	Category: Click to enter text.
	Subcategories: <u>Click to enter text.</u>
	Category: <u>Click to enter text.</u>
	Subcategories: <u>Click to enter text.</u>
	Category: <u>Click to enter text.</u>
	Subcategories: <u>Click to enter text.</u>
F.	Industrial user interruptions
	Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?
	□ Yes □ No
	If yes , identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.
	Click to enter text.

WORKSHEET 7.0

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

CLASS V INJECTION WELL INVENTORY/AUTHORIZATION FORM

Submit the complet	ted form to:
--------------------	--------------

TCEQ IUC Permits Team Radioactive Materials Division MC-233 PO Box 13087 Austin, Texas 78711-3087 512-239-6466

For TCEQ Use Only		
Reg. No		
Date Received		
Date Authorized		

Section 1. General Information (Instructions Page 90)

1. TCEQ Progra	m Area
----------------	--------

Program Area (PST, VCP, IHW, etc.): Click to enter text.

Program ID: Click to enter text.

Contact Name: Click to enter text.

Phone Number: Click to enter text.

2. Agent/Consultant Contact Information

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

3. Owner/Operator Contact Information

□ Owner □ Operator

Owner/Operator Name: Click to enter text.

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

4. Facility Contact Information

Facility Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Location description (if no address is available): Click to enter text.

Facility Contact Person: Click to enter text.

Phone Number: Click to enter text.

5.	Latitude and Longitude, in degrees-minutes-seconds
	Latitude: Click to enter text.
	Longitude: Click to enter text.
	Method of determination (GPS, TOPO, etc.): Click to enter text.
	Attach topographic quadrangle map as attachment A.
6.	Well Information
	Type of Well Construction, select one:
	□ Vertical Injection
	☐ Subsurface Fluid Distribution System
	□ Infiltration Gallery
	☐ Temporary Injection Points
	□ Other, Specify: <u>Click to enter text.</u>
	Number of Injection Wells: Click to enter text.
7.	Purpose
	Detailed Description regarding purpose of Injection System:
	Click to enter text.
	Attach a Site Map as Attachment B (Attach the Approved Remediation Plan, if appropriate.)
8.	Water Well Driller/Installer
	Water Well Driller/Installer Name: Click to enter text.
	City, State, and Zip Code: Click to enter text.
	Phone Number: Click to enter text.
	License Number: Click to enter text.

Section 2. Proposed Down Hole Design

Attach a diagram signed and sealed by a licensed engineer as Attachment C.

Table 7.0(1) - Down Hole Design Table

Name of String	Size	Setting Depth	Sacks Cement/Grout – Slurry Volume – Top of Cement	Hole Size	Weight (lbs/ft) PVC/Steel
Casing					
Tubing					
Screen					

Section 3. Proposed Trench System, Subsurface Fluid Distribution System, or Infiltration Gallery

Attach a diagram signed and sealed by a licensed engineer as Attachment D.

System(s) Dimensions: <u>Click to enter text.</u> System(s) Construction: <u>Click to enter text.</u>

Section 4. Site Hydrogeological and Injection Zone Data

- 1. Name of Contaminated Aquifer: <u>Click to enter text.</u>
- 2. Receiving Formation Name of Injection Zone: Click to enter text.
- 3. Well/Trench Total Depth: <u>Click to enter text.</u>
- 4. Surface Elevation: Click to enter text.
- 5. Depth to Ground Water: <u>Click to enter text.</u>
- 6. Injection Zone Depth: <u>Click to enter text.</u>
- 7. Injection Zone vertically isolated geologically? ☐ Yes ☐ No Impervious Strata between Injection Zone and nearest Underground Source of Drinking Water:

Name: Click to enter text.

Thickness: Click to enter text.

- 8. Provide a list of contaminants and the levels (ppm) in contaminated aquifer Attach as Attachment E.
- 9. Horizontal and Vertical extent of contamination and injection plume Attach as Attachment F.
- **10.** Formation (Injection Zone) Water Chemistry (Background levels) TDS, etc. Attach as Attachment G.
- 11. Injection Fluid Chemistry in PPM at point of injection Attach as Attachment H.
- 12. Lowest Known Depth of Ground Water with < 10,000 PPM TDS: Click to enter text.
- 13. Maximum injection Rate/Volume/Pressure: Click to enter text.
- 14. Water wells within 1/4 mile radius (attach map as Attachment I): Click to enter text.
- **15.** Injection wells within 1/4 mile radius (attach map as Attachment J): <u>Click to enter text.</u>
- 16. Monitor wells within 1/4 mile radius (attach drillers logs and map as Attachment K): Click to enter text.
- 17. Sampling frequency: Click to enter text.
- **18.** Known hazardous components in injection fluid: <u>Click to enter text.</u>

Section 5. Site History

- **1.** Type of Facility: <u>Click to enter text.</u>
- Contamination Dates: Click to enter text.
- 3. Original Contamination (VOCs, TPH, BTEX, etc.) and Concentrations (attach as Attachment L): Click to enter text.
- 4. Previous Remediation (attach results of any previous remediation as attachment M): Click to enter text.

NOTE: Authorization Form should be completed in detail and authorization given by the TCEQ before construction, operation, and/or conversion can begin. Attach additional pages as necessary.

Class V Injection Well Designations

- 5A07 Heat Pump/AC return (IW used for groundwater to heat and/or cool buildings)
- 5A19 Industrial Cooling Water Return Flow (IW used to cool industrial process equipment)
- 5B22 Salt Water Intrusion Barrier (IW used to inject fluids to prevent the intrusion of salt water into an aquifer)
- 5D02 Storm Water Drainage (IW designed for the disposal of rain water)
- 5D04 Industrial Stormwater Drainage Wells (IW designed for the disposal of rain water associated with industrial facilities)
- 5F01 Agricultural Drainage (IW that receive agricultural runoff)
- 5R21 Aquifer Recharge (IW used to inject fluids to recharge an aquifer)
- 5S23 Subsidence Control Wells (IW used to control land subsidence caused by ground water withdrawal)
- 5W09 Untreated Sewage
- 5W10 Large Capacity Cesspools (Cesspools that are designed for 5,000 gpd or greater)
- 5W11 Large Capacity Septic systems (Septic systems designed for 5,000 gpd or greater)
- 5W12 WTTP disposal
- 5W20 Industrial Process Waste Disposal Wells
- 5W31 Septic System (Well Disposal method)
- 5W32 Septic System Drainfield Disposal
- 5X13 Mine Backfill (IW used to control subsidence, dispose of mining byproducts, and/or fill sections of a mine)
- 5X25 Experimental Wells (Pilot Test) (IW used to test new technologies or tracer dye studies)
- 5X26 Aquifer Remediation (IW used to clean up, treat, or prevent contamination of a USDW)
- 5X27 Other Wells
- 5X28 Motor Vehicle Waste Disposal Wells (IW used to dispose of waste from a motor vehicle site These are currently banned)
- 5X29 Abandoned Drinking Water Wells (waste disposal)



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for Submission (If other is checked please describe in space provided.)

New Permit, Registration or Authorization (Core Data Form should be submitted with the program application.)

Renewal	(Core Data	Form should be submit	ted with the re	enewal form,)		Other			
2. Customer Reference Number (if issued) CN 600520126				Follow this link to searce for CN or RN numbers i Central Registry**		100				
						RN 102078094				
ECTIO	N II:	Customer	Inforn	natior	1					
l. General C	ıstomer l	nformation	5. Effective	Date for C	Date for Customer Information Updates (mm/dd/yyyy)					
New Custo	mer	Пυ	pdate to Custo	mer Informa	ation	Cha	nge in Regulated Er	ntity Own	ership	
15		(Verifiable with the Tex	50			(Feb. 1981)	#W W# J	W.	3/8/	
		ubmitted here may b oller of Public Accou	Manager Control	utomatica	lly based on	what is a	current and activ	e with th	he Texas Sec	retary of State
. Customer	Legal Nan	ne (If an individual, pri	nt last name fi	rst: eg: Doe, .	John)		If new Customer	, enter pre	evious Custon	ner below:
Brownsville Na	vigation Di	strict								
7. TX SOS/CPA Filing Number 8. TX Star			8. TX State	te Tax ID (11 digits)			9. Federal Tax ID (9 digits) 7460004198		10. DUNS Number (if applicable) 88-6247	
1. Type of C	ustomer:	☐ Corporat	ion			☐ Indivi	dual	Partne	ership: 🔲 Ge	neral 🔲 Limited
overnment: [City 🔲	County 🔲 Federal 🔲	Local 🔲 State	e 🛛 Other		Sole P	Proprietorship	☐ Ot	her:	
2. Number	of Employ	rees				5	13. Independe	ently Ow	ned and Op	erated?
0-20	21-100	☑ 101-250 ☐ 251-:	500 🗌 501	and higher			⊠ Yes	☐ No		
14. Custome	r Role (Pro	pposed or Actual) – as it	relates to the	Regulated E	ntity listed on	this form.	Please check one o	of the follo	owing	
Owner Occupation	al Licensee	Operator Responsible Par		wner & Oper VCP/BSA App			☐ Other	ri		
.5. Mailing	1000 For	ust Rd								
Address:	City Brownsville State TX					ZIP	78521		ZIP + 4	T
.6. Country I	Mailing In	formation (if outside	USA)		17.	17. E-Mail Address (if applicable)				
N/A						mmartinez@portofbrownsville.com				

TCEQ-10400 (11/22) Page 1 of 3

18. Telephone Number			19. Extension o	r Code		20. Fax Number	if applicable)			
(956) 551-2602			19900 200			() -				
ECTION III:	Regula	ited Ent	ity Inform	matio	<u>1</u>	¥				
21. General Regulated En	tity Informa	tion (If 'New Reg	ulated Entity" is sele	ected, a new	permit applicat	ion is also required.)				
New Regulated Entity	Update to	Regulated Entity	Name 🗌 Update	to Regulate	d Entity Informa	ition		I FIRE A		
The Regulated Entity Naras Inc, LP, or LLC).	ne submitted	d may be upda	ted, in order to m	eet TCEQ C	ore Data Stan	dards (removal oj	^f organization	al endings such		
22. Regulated Entity Nam	ne (Enter name	e of the site wher	e the regulated action	on is taking p	lace.)					
Brownsville Navigation Distri	ct							e		
23. Street Address of the Regulated Entity:	1000 Foust Rd									
(No PO Boxes)	City Brownsville		State	ТХ	ZIP	78521	ZIP + 4			
24. County	Cameron		· •							
Section 1		If no Stre	et Address is prov	ided, fields	25-28 are red	quired.				
25. Description to Physical Location:			e Texas. 78521, locat v 48 and Farm-to-Ma							
26. Nearest City						State	Nea	rest ZIP Code		
12H 2		81								
Latitude/Longitude are r used to supply coordinat						rds. (Geocoding o	f the Physical	Address may be		
27. Latitude (N) In Decim	al:	25.962160		28.	Longitude (W	/) In Decimal:	-97.3955	84		
Degrees	Minutes		Seconds	Deg	rees	Minutes		Seconds		
25		52	04		97		23 15			
29. Primary SIC Code 30. Secondary SIC Code			Code		ary NAICS Co	de 32. S	econdary NAI	CS Code		
(4 digits)	(4 d	(4 digits)			(5 or 6 digits) (5 or 6 digits)					
4592				22132						
33. What is the Primary	Business of t	his entity? (D	o not repeat the SIC	or NAICS de	scription.)					
	Brownsvill	le Navigation Dis	trict				va			
34. Mailing	1000 Fous				ulou — usu					
Address:	City	Brownsville	State	тх	ZIP	78521	ZIP + 4	0.		
35. E-Mail Address:	mm	artinez@portofb	prownsville.com			1		1		
36. Telephone Number			37. Extension o	r Code	38. F	ax Number (if app	licable)			
(956)551-2602		The state of the s) -				

Page 2 of 3 TCEQ-10400 (11/22)

(956) 551-2602

PWS Used Oil Other:		
Other:		
that I have signature autho d in field 39.		
ineering Department		
56) 551- 2602		
30/2025		

TCEQ-10400 (11/22) Page 3 of 3

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS


TCEQ USE ONLY: A limit to the second of the	
Application type:RenewalMajor AmendmentMinor AmendmentNew	
County: Segment Number:	
Admin Complete Date:	
Agency Receiving SPIF:	
Texas Historical Commission U.S. Fish and Wildlife	
Texas Parks and Wildlife Department U.S. Army Corps of Engineers	
This form applies to TPDES permit applications only. (Instructions, Page 53)	
Complete this form as a separate document. TCEQ will mail a copy to each agency as required our agreement with EPA. If any of the items are not completely addressed or further information needed, we will contact you to provide the information before issuing the permit. Address each item completely.	d by tion
Do not refer to your response to any item in the permit application form. Provide each attachment for this form separately from the Administrative Report of the application. The application will not be declared administratively complete without this SPIF form being completed in its entirety including all attachments. Questions or comments concerning this f may be directed to the Water Quality Division's Application Review and Processing Team by email at	

		the name, address, phone and fax number of an individual that can be contacted to specific questions about the property.					
	Prefix (Mr., Ms., Miss): <u>Mr.</u>					
	First ar	nd Last Name: <u>Manuel Martinez</u>					
	Creden	itial (P.E, P.G., Ph.D., etc.):					
		acting Director of Engineering Department					
	Mailing	g Address: 1000 Foust Rd					
	City, St	ate, Zip Code: <u>Brownsville, Texas. 78521</u>					
	Phone	No.: <u>956-551-2602</u> Ext.: Allegation of the Fax No.: Allegation of the Fax No.:					
	E-mail	Address: mmartinez@portofbrownsville.com					
2.	List the	e county in which the facility is located: <u>Cameron</u>					
3.	If the property is publicly owned and the owner is different than the permittee/applicant, please list the owner of the property.						
	N/A						
		· 9					
	Provide a description of the effluent discharge route. The discharge route must follow the flow of effluent from the point of discharge to the nearest major watercourse (from the point of discharge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify the classified segment number.						
		nt discharge to an unnamed ditch; thence along to Cameron County drainage ditch thence to San Martin Lake, thence to the Brownsville Ship Channel.					
5.	plotted route f	provide a separate 7.5-minute USGS quadrangle map with the project boundaries and a general location map showing the project area. Please highlight the discharge from the point of discharge for a distance of one mile downstream. (This map is ed in addition to the map in the administrative report).					
	Provide original photographs of any structures 50 years or older on the property.						
	Does y	our project involve any of the following? Check all that apply.					
		Proposed access roads, utility lines, construction easements					
		Visual effects that could damage or detract from a historic property's integrity					
		Vibration effects during construction or as a result of project design					
		Additional phases of development that are planned for the future					
		Sealing caves, fractures, sinkholes, other karst features					


	☐ Disturbance of vegetation or wetlands
1.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	White being to design feet.
2.	Describe existing disturbances, vegetation, and land use:
	That has a topical taller.
	·
AN	E FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR ENDMENTS TO TPDES PERMITS
3.	List construction dates of all buildings and structures on the property:
4.	Provide a brief history of the property, and name of the architect/builder, if known.
	() 制。取 为() () () () () () () () () () () () () (

Attachment Tech 1.0-2C Process Flow Diagram

Schematic of Existing Wastewater Flow Turning Basin Wastewater Treatment Plant Brownsville Navigation District




Attachment T C 1.0-Maps











the port that works

SEPTEMBER 2025

Brooke T. Paup, *Chairwoman*Tonya R. Miller, *Commissioner*Catarina R. Gonzales, *Commissioner*Kelly Keel, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

October 17, 2025

Mr. Manuel Martinez, Acting Director of Engineering Services Brownsville Navigation District 1000 Foust Road Brownsville, Texas 78521

Re: Brownsville Navigation District- TPDES Permit No. WQ0014355001, EPA ID No. TX0074047 (CN 600520126; RN 102078094)

Dear Mr. Martinez,

We are in receipt of your letter dated September 3, 2025, requesting the Texas Commission on Environmental Quality (TCEQ) to authorize to temporary use of the sludge drying beds that are situated to the west of the plant, during repair and rehabilitation of the Brownsville Navigation District's Turning Basin Wastewater Treatment Facility (WWTF) clarifier. The letter provided an Exhibit Map showing the location of the drying beds within the WWTF site.

We have evaluated your request and understand that this activity will not cause a change in the terms and conditions of the permit or the ability of the permittee to meet these terms and conditions. Your request is approved based on the following conditions:

- 1. The authorization is temporary, and will expire at the end of 30 days from the date of this letter.
- 2. Two existing drying beds will serve to temporarily store the partially treated wastewater from the aeration chamber at times when the clarifier is emptied for repairs.
- 3. Both drying beds have been adequately lined to control seepage in accordance with 30 Texas Administrative Code (TAC) Section 217. 203.
- 4. Any liquid waste placed in the sludge drying beds is to be recycled to the plant headworks.

Mr. Manuel Martinez, Page 2 October 16, 2025

- 5. There will be no direct discharge of any effluent from these drying beds into water in the state.
- 6. The permittee shall meet the buffer zone requirements in 30 TAC § 309.13 with a 500-foot buffer zone and the requirements for temporary storage of waste in 30 TAC § 312.147.
- 7. The permittee shall notify the TCEQ Region 15 office about the clarifier's repair and rehabilitation work progress in a timely manner prior to beginning and ending use of these drying beds.

Based on the above facts and conditions, the TCEQ does not hold any objection on your request to use the existing sludge drying beds for temporary storage of partially treated wastewater during repair of the clarifier.

If you have any questions regarding this matter, please contact me at (512) 239-4608, or if by correspondence include MC 148 in the letterhead address following my name.

Sincerely,

Deba Dutta

Deba Dutta, P.E., Team Leader Domestic Permits Team Domestic Wastewater Section (MC 148) Water Quality Division Texas Commission on Environmental Quality

cc: Erwin Madrid, Team Leader, Application Review and processing Team (MC 148). Monica Galvan, Water Section Manager, TCEQ Region 15 (MC R15).

Francesca Findlay

From: Francesca Findlay

Sent: Friday, October 31, 2025 11:49 AM **To:** 'Nora Gonzalez'; Manuel Martinez

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon.

The verification sent in the previous response is from a different intersection than what was provided in the Core Data Form. Please confirm what intersection description is to be used in the NORI and submit the corrected Core Data From, PLS, and SPIF if applicable.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Wednesday, October 29, 2025 11:10 AM

To: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Francesca

Attached is the requested document.

Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Tuesday, October 21, 2025 2:54 PM

To: Manuel Martinez < mmartinez@portofbrownsville.com >; Nora Gonzalez < nagonzalez@portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

I am just checking to see if you send the Translated Spanish Nori, I do not see it in any of the emails. I have attached another one for you to complete and return back to me. Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Manuel Martinez < mmartinez@portofbrownsville.com >

Sent: Thursday, October 16, 2025 4:15 PM

To: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>; Nora Gonzalez <nagonzalez@portofbrownsville.com>

Subject: Re: WQ0014355001 Brownsville Navigation District

Good afternoon Ms. Francesca, I apologize for the confusion. Please see our responses below:

1. Please verify that the site address of 3005 Levee Road is a 911 address.

This road is an internal road inside Port of Brownsville premises and might not be in the 911 address map. This is a renewal permit, not sure if this address was used previously.

2. Please confirm that the site coordinates are correct.

The coordinates for this treatment plant are: 25.962253 -97.394652 (25'57'43"N and 97'23'40"W)

3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Description: 3005 Levee Rd, Brownsville TX 78521; located on the north side of Old State Highway 48, approximately 0.7 miles east of the intersection of Old State Highway 48 and State Highway 550 Toll (Bill Reed Road) Brownsville, Cameron County, Texas. (Please see image below for clarification).



We greatly appreciate your time and any comments;

Best regards

Mr. Manuel Martinez / Acting Director of Engineering Serv. / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7029 **M:** (956) 551-2602 **F:** (956) 831-6153





From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Thursday, October 16, 2025 2:33 PM

To: Nora Gonzalez <nagonzalez@portofbrownsville.com>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon.

The coordinates I sent, are the directions that were sent to me for the plant site. I have attached the coordinates that were given on the Core Data Form.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- **3.** The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Thank you,

Francesca Findlay License & Permit Specialist ARP Team | Water Quality Division 512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez < nagonzalez @portofbrownsville.com >

Sent: Thursday, October 16, 2025 11:55 AM

To: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good Morning

Fransesca

The coordinates you sent do not belong to the Turning Basin Wastewater Treatment Plant.

Send us the correct information needed.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Thursday, October 16, 2025 11:45 AM

To: Manuel Martinez < mmartinez@portofbrownsville.com > Cc: Nora Gonzalez < nagonzalez@portofbrownsville.com > Subject: FW: WQ0014355001 Brownsville Navigation District

Good morning,

I am reviewing your application, and I have a few questions.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information

Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

Francesca Findlay

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Tuesday, November 4, 2025 4:58 PM

To: Francesca Findlay

Subject: FW: WQ0014355001 Brownsville Navigation District

Attachments: Municipal Discharge Renewal Spanish NORI (V311-4-25).docx; TB Responses

Administrative 10-3-2025v2.pdf

Good Morning

Francesca

See attached NORI, with corrections, Core data was resent to you back on October 3rd, see attached PDF, about the SPIF, I will send you the file for TB Permit Renewal in a separate email file is to big. If you have any question or if I have to submit any other documents let me know.

Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Friday, October 31, 2025 11:49 AM

To: Nora Gonzalez < nagonzalez@portofbrownsville.com >; Manuel Martinez < mmartinez@portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon.

The verification sent in the previous response is from a different intersection than what was provided in the Core Data Form. Please confirm what intersection description is to be used in the NORI and submit the corrected Core Data From, PLS, and SPIF if applicable.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez < nagonzalez@portofbrownsville.com >

Sent: Wednesday, October 29, 2025 11:10 AM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Manuel Martinez < mmartinez@portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Francesca

Attached is the requested document.

Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville 1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>

Sent: Tuesday, October 21, 2025 2:54 PM

To: Manuel Martinez <mmartinez@portofbrownsville.com>; Nora Gonzalez <nagonzalez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

I am just checking to see if you send the Translated Spanish Nori, I do not see it in any of the emails. I have attached another one for you to complete and return back to me. Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Manuel Martinez <mmartinez@portofbrownsville.com>

Sent: Thursday, October 16, 2025 4:15 PM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Nora Gonzalez < nagonzalez@portofbrownsville.com >

Subject: Re: WQ0014355001 Brownsville Navigation District

Good afternoon Ms. Francesca, I apologize for the confusion. Please see our responses below:

1. Please verify that the site address of 3005 Levee Road is a 911 address.

This road is an internal road inside Port of Brownsville premises and might not be in the 911 address map. This is a renewal permit, not sure if this address was used previously.

2. Please confirm that the site coordinates are correct.

The coordinates for this treatment plant are: 25.962253 -97.394652 (25'57'43"N and 97'23'40"W)

3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Description: 3005 Levee Rd, Brownsville TX 78521; located on the north side of Old State Highway 48, approximately 0.7 miles east of the intersection of Old State Highway 48 and State Highway 550 Toll (Bill Reed Road) Brownsville, Cameron County, Texas. (Please see image below for clarification).



We greatly appreciate your time and any comments;

Best regards

Mr. Manuel Martinez Acting Director of Engineering Serv. Port of Brownsville

D: (956) 838-7029 **M:** (956) 551-2602 **F:** (956) 831-6153





From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Thursday, October 16, 2025 2:33 PM

To: Nora Gonzalez < nagonzalez @portofbrownsville.com >; Manuel Martinez < mmartinez @portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

The coordinates I sent, are the directions that were sent to me for the plant site. I have attached the coordinates that were given on the Core Data Form.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Thursday, October 16, 2025 11:55 AM

To: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good Morning

Fransesca

The coordinates you sent do not belong to the Turning Basin Wastewater Treatment Plant.

Send us the correct information needed.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Thursday, October 16, 2025 11:45 AM

To: Manuel Martinez <<u>mmartinez@portofbrownsville.com</u>>
Cc: Nora Gonzalez <<u>nagonzalez@portofbrownsville.com</u>>
Subject: FW: WQ0014355001 Brownsville Navigation District

Good morning,

I am reviewing your application, and I have a few questions.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any

attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

Francesca Findlay

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Tuesday, November 4, 2025 4:59 PM

To: Francesca Findlay

Subject: FW: WQ0014355001 Brownsville Navigation District

Attachments: Turning Basin 2026 Permit Renewal.pdf

Here are the TB Renewal documents the SPIF, is there.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153





From: Nora Gonzalez

Sent: Tuesday, November 4, 2025 4:51 PM **To:** francesca.findlay@tceq.texas.gov

Subject: FW: WQ0014355001 Brownsville Navigation District

From: Nora Gonzalez

Sent: Tuesday, November 4, 2025 11:47 AM

To: 'francesca.findlay@tceq.texas.gov' <francesca.findlay@tceq.texas.gov>

Subject: FW: WQ0014355001 Brownsville Navigation District

From: Nora Gonzalez

Sent: Tuesday, November 4, 2025 11:40 AM **To:** Francesca.Findlay@tceq.texas.gov

Subject: FW: WQ0014355001 Brownsville Navigation District

From: Nora Gonzalez

Sent: Tuesday, November 4, 2025 11:37 AM

To: 'Francesca Findlay' <Francesca.Findlay@tceq.texas.gov>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good Morning

Francesca

See attached NORI, with corrections, Core data was resent to you back on October 3rd, see attached PDF, about the SPIF, see attached file for TB Permit Renewal. If you have any question or if I have to submit any other documents let me know.

Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Friday, October 31, 2025 11:49 AM

To: Nora Gonzalez <nagonzalez@portofbrownsville.com>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

The verification sent in the previous response is from a different intersection than what was provided in the Core Data Form. Please confirm what intersection description is to be used in the NORI and submit the corrected Core Data From, PLS, and SPIF if applicable.

Thank you,

Francesca Findlay

License & Permit Specialist ARP Team | Water Quality Division 512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez < nagonzalez@portofbrownsville.com >

Sent: Wednesday, October 29, 2025 11:10 AM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Manuel Martinez < mmartinez@portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Francesca

Attached is the requested document.

Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Tuesday, October 21, 2025 2:54 PM

To: Manuel Martinez < martinez@portofbrownsville.com >; Nora Gonzalez < nagonzalez@portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon.

I am just checking to see if you send the Translated Spanish Nori, I do not see it in any of the emails. I have attached another one for you to complete and return back to me. Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Manuel Martinez < mmartinez@portofbrownsville.com >

Sent: Thursday, October 16, 2025 4:15 PM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Nora Gonzalez < nagonzalez@portofbrownsville.com >

Subject: Re: WQ0014355001 Brownsville Navigation District

Good afternoon Ms. Francesca, I apologize for the confusion. Please see our responses below:

1. Please verify that the site address of 3005 Levee Road is a 911 address.

This road is an internal road inside Port of Brownsville premises and might not be in the 911 address map. This is a renewal permit, not sure if this address was used previously.

2. Please confirm that the site coordinates are correct.

The coordinates for this treatment plant are: 25.962253 -97.394652 (25'57'43"N and 97'23'40"W)

3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Description: 3005 Levee Rd, Brownsville TX 78521; located on the north side of Old State Highway 48, approximately 0.7 miles east of the intersection of Old State Highway 48 and State Highway 550 Toll (Bill Reed Road) Brownsville, Cameron County, Texas. (Please see image below for clarification).



We greatly appreciate your time and any comments;

Best regards

Mr. Manuel Martinez Acting Director of Engineering Serv. Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7029 **M:** (956) 551-2602 **F:** (956) 831-6153





From: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>

Sent: Thursday, October 16, 2025 2:33 PM

To: Nora Gonzalez <nagonzalez@portofbrownsville.com>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

The coordinates I sent, are the directions that were sent to me for the plant site. I have attached the coordinates that were given on the Core Data Form.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez < nagonzalez @portofbrownsville.com >

Sent: Thursday, October 16, 2025 11:55 AM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Manuel Martinez < mmartinez@portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Good Morning

Fransesca

The coordinates you sent do not belong to the Turning Basin Wastewater Treatment Plant.

Send us the correct information needed.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Thursday, October 16, 2025 11:45 AM

To: Manuel Martinez <<u>mmartinez@portofbrownsville.com</u>> **Cc:** Nora Gonzalez <<u>nagonzalez@portofbrownsville.com</u>> **Subject:** FW: WQ0014355001 Brownsville Navigation District

Good morning,

I am reviewing your application, and I have a few questions.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Please let me know if you have any questions.

Thank you,

Francesca Findlay

License & Permit Specialist ARP Team | Water Quality Division 512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

Francesca Findlay

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Thursday, November 13, 2025 12:28 PM **To:** Francesca Findlay; Manuel Martinez

Subject: RE: WQ0014355001 Brownsville Navigation District

Attachments: 10400 Core Data Turning Basin 2025v1-11-13-25resubmitted.docx; 20972_PLS_

2024-09-26-2025V211-13-25resubmitted.docx; 20971 Supplemental Turning Basin

2025v211-13-25.docx

Follow Up Flag: Follow up Flag Status: Flagged

Good Afternoon

Francesca

As per our conversation about location, made a change to documents, TLAP added Old to state highway 48, Core data, same change and 511 to 550, SPIF, I added old to state HW 48 and changed 511 to 550.

If you have any questions, give me a call.

Regards.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521 **D:** (956) 838-7003 **M:** (956) 551-9205 **F:** (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Friday, October 31, 2025 11:49 AM

To: Nora Gonzalez <nagonzalez@portofbrownsville.com>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

The verification sent in the previous response is from a different intersection than what was provided in the Core Data Form. Please confirm what intersection description is to be used in the NORI and submit the corrected Core Data From, PLS, and SPIF if applicable.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez < nagonzalez @portofbrownsville.com >

Sent: Wednesday, October 29, 2025 11:10 AM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Manuel Martinez < mmartinez@portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Francesca

Attached is the requested document.

Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville 1000 Foust Road, Brownsville, TX 78521 D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Tuesday, October 21, 2025 2:54 PM

To: Manuel Martinez <martinez@portofbrownsville.com>; Nora Gonzalez <martinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

I am just checking to see if you send the Translated Spanish Nori, I do not see it in any of the emails. I have attached another one for you to complete and return back to me. Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Manuel Martinez < mmartinez@portofbrownsville.com >

Sent: Thursday, October 16, 2025 4:15 PM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Nora Gonzalez < nagonzalez@portofbrownsville.com >

Subject: Re: WQ0014355001 Brownsville Navigation District

Good afternoon Ms. Francesca, I apologize for the confusion. Please see our responses below:

1. Please verify that the site address of 3005 Levee Road is a 911 address.

This road is an internal road inside Port of Brownsville premises and might not be in the 911 address map. This is a renewal permit, not sure if this address was used previously.

2. Please confirm that the site coordinates are correct.

The coordinates for this treatment plant are: 25.962253 -97.394652 (25'57'43"N and 97'23'40"W)

3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Description: 3005 Levee Rd, Brownsville TX 78521; located on the north side of Old State Highway 48, approximately 0.7 miles east of the intersection of Old State Highway 48 and State Highway 550 Toll (Bill Reed Road) Brownsville, Cameron County, Texas. (Please see image below for clarification).



We greatly appreciate your time and any comments;

Best regards

Mr. Manuel Martinez Acting Director of Engineering Serv. Port of Brownsville

D: (956) 838-7029 **M:** (956) 551-2602 **F:** (956) 831-6153





From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Thursday, October 16, 2025 2:33 PM

To: Nora Gonzalez < nagonzalez @portofbrownsville.com >; Manuel Martinez < mmartinez @portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

The coordinates I sent, are the directions that were sent to me for the plant site. I have attached the coordinates that were given on the Core Data Form.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Thursday, October 16, 2025 11:55 AM

To: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good Morning

Fransesca

The coordinates you sent do not belong to the Turning Basin Wastewater Treatment Plant.

Send us the correct information needed.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Thursday, October 16, 2025 11:45 AM

To: Manuel Martinez < mmartinez@portofbrownsville.com > Cc: Nora Gonzalez < nagonzalez@portofbrownsville.com > Subject: FW: WQ0014355001 Brownsville Navigation District

Good morning,

I am reviewing your application, and I have a few questions.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any

attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

Francesca Findlay

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Wednesday, October 29, 2025 11:10 AM **To:** Francesca Findlay; Manuel Martinez

Subject: RE: WQ0014355001 Brownsville Navigation District

Attachments: Municipal Discharge Renewal Spanish NORI v110+-22-2025.docx

Francesca

Attached is the requested document.

Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521 D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Tuesday, October 21, 2025 2:54 PM

To: Manuel Martinez <mmartinez@portofbrownsville.com>; Nora Gonzalez <nagonzalez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

I am just checking to see if you send the Translated Spanish Nori, I do not see it in any of the emails. I have attached another one for you to complete and return back to me. Please let me know if you have any questions.

Thank you,

Francesca Findlay License & Permit Specialist

ARP Team | Water Quality Division 512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Manuel Martinez <mmartinez@portofbrownsville.com>

Sent: Thursday, October 16, 2025 4:15 PM

To: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >; Nora Gonzalez < nagonzalez@portofbrownsville.com >

Subject: Re: WQ0014355001 Brownsville Navigation District

Good afternoon Ms. Francesca, I apologize for the confusion. Please see our responses below:

1. Please verify that the site address of 3005 Levee Road is a 911 address.

This road is an internal road inside Port of Brownsville premises and might not be in the 911 address map. This is a renewal permit, not sure if this address was used previously.

2. Please confirm that the site coordinates are correct.

The coordinates for this treatment plant are: 25.962253 -97.394652 (25'57'43"N and 97'23'40"W)

3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Description: 3005 Levee Rd, Brownsville TX 78521; located on the north side of Old State Highway 48, approximately 0.7 miles east of the intersection of Old State Highway 48 and State Highway 550 Toll (Bill Reed Road) Brownsville, Cameron County, Texas. (Please see image below for clarification).



We greatly appreciate your time and any comments;

Best regards

Mr. Manuel Martinez Acting Director of Engineering Serv. Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7029 **M:** (956) 551-2602 **F:** (956) 831-6153





From: Francesca Findlay < Francesca.Findlay@tceq.texas.gov>

Sent: Thursday, October 16, 2025 2:33 PM

To: Nora Gonzalez <nagonzalez@portofbrownsville.com>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

The coordinates I sent, are the directions that were sent to me for the plant site. I have attached the coordinates that were given on the Core Data Form.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Tayas Commission on Environmental O

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Thursday, October 16, 2025 11:55 AM

To: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good Morning

Fransesca

The coordinates you sent do not belong to the Turning Basin Wastewater Treatment Plant.

Send us the correct information needed.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Thursday, October 16, 2025 11:45 AM

To: Manuel Martinez <<u>mmartinez@portofbrownsville.com</u>>
Cc: Nora Gonzalez <<u>nagonzalez@portofbrownsville.com</u>>
Subject: FW: WQ0014355001 Brownsville Navigation District

Good morning,

I am reviewing your application, and I have a few questions.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Please let me know if you have any questions.

Thank you,

Francesca Findlay

License & Permit Specialist ARP Team | Water Quality Division 512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA RENOVACION

PERMISO NO. WQ0014355001

SOLICITUD. Distrito de Navegacion de Brownsville, 1000 Foust Road, Brownsville, Texas 78521, ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEO) para renovar el Permiso No. WQ0014355001 (EPA I.D. No. TX 0074047) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 100,000 galones por día. La planta está ubicada en 3005 Levee Roady aproximadamente 0.7 millas al este de la intersección de la carretera estatal 48 y la carretera Farm-to-Market Road 511, en la ciudad de Brownsville, en el condado de Cameron, Texas 78521. La ruta de descarga es del sitio de la planta a un dren sin nombre; después al Dren No. 1 del Condado de Cameron, después al Lago de San Martín y finalmente de allí hacia el sur, al canal de Navegacíon de Brownsville. La TCEQ recibió esta solicitud el 1 del octubre, 2025. La solicitud para el permiso estará disponible para leerla y copiarla en las Oficinas Administrativas del Distrito de Navegacíon de Brownsville en 1000 Foust Road, Brownsville, en el condado de Cameron, Texas 78521, antes de la fecha de publicación de este aviso en el periódico. La solicitud (cualquier actualización y aviso inclusive) está disponible electrónicamente en la siguiente página web: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.394722,25.962222&level=18

AVISO DE IDIOMA ALTERNATIVO. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO. Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión.

La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios. Si ciertos criterios se cumplen, la TCEQ puede actuar sobre una solicitud para renovar un permiso sin proveer una oportunidad de

una audiencia administrativa de lo contencioso.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Además, puede pedir que la TCEQ ponga su nombre en una o más de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos del solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envía por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

INFORMACIÓN DISPONIBLE EN LÍNEA. Para detalles sobre el estado de la solicitud, favor de visitar la Base de Datos Integrada de los Comisionados en www.tceq.texas.gov/goto/cid. Para buscar en la base de datos, utilizar el número de permiso para esta solicitud que aparece en la parte superior de este aviso.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía http://www14.tceq.texas.gov/epic/eComment/o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Distrito de Navegacíon de Brownsville a la dirección indicada arriba o llamando al Sr. Manuel Martinez, Director en funciones de ingenería al 956-551-2602.

Fecha de emisión: [Date notice issued]

Your transaction is complete. Thank you for using TCEQ ePay.

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt and the vouchers for your records. An email receipt has also been sent.

Transaction Information

Trace Number: 582EA000687020

Date: 09/30/2025 04:59 PM

Payment Method: CC - Authorization 0000030507

ePay Actor: NORA ALICIA GONZALEZ

Actor Email: nagonzalez@portofbrownsville.com

IP: 12.69.113.194

TCEQ Amount: \$815.00

Texas.gov Fee: \$18.59

Texas.gov Price: \$833.59*

* This service is provided by Texas.gov, the official website of Texas. The price of this service includes funds that support the ongoing operations and enhancements of Texas.gov, which is provided by a third party in partnership with the State.

Payment Contact Information

Name: NORA ALICIA GONZALEZ

Company: PORT OF BROWNSVILLE

Address: 1000 FOUST RD, BROWNSVILLE, TX 78521

Phone: 956-551-9205

Cart Items

Click on the voucher number to see the voucher details.

Voucher	Fee Description	

AR Number Amount

785547 WW PERMIT - FACILITY WITH FLOW >= .10 & < .25 MGD - RENEWAL

\$800.00

785548 30 TAC 305.53B WQ RENEWAL NOTIFICATION FEE

\$15.00

The state of the s

\$13.00

TCEQ Amount:

\$815.00

ePay Again Exit ePay

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt for your records.

D.	Package						
	Indicate by a check mark the preferred method for receiving the first notice and instruction	ıs:					
	⊠ E-mail Address						
	□ Fax						
	□ Regular Mail						
C.	Contact permit to be listed in the Notices						
	Prefix: Mr. Last Name, First Name: Martinez Manuel						
	Title: <u>Acting Director of Engineering Services</u> Credential: Click to enter text.						
	Organization Name: Brownsville Navigation District						
	Mailing Address: 1000 Foust Road City, State, Zip Code: Brownsville, Texas. 78521						
	Phone No.: <u>956-551-2602</u> E-mail Address: <u>mmartinez@portofbrownsville.com</u>						
D.	Public Viewing Information						
	If the facility or outfall is located in more than one county, a public viewing place for each county must be provided.						
	Public building name: Brownsville Navigation District						
	Location within the building: Administration Building						
	Physical Address of Building: 1000 Foust Road						
	City: <u>Brownsville</u> County: <u>Cameron</u>						
	Contact (Last Name, First Name): Gonzalez Nora Alicia						
	Phone No.: <u>956-551-9205</u> Ext.: Click to enter text.						
E.	Bilingual Notice Requirements						
	This information is required for new, major amendment, minor amendment or minor modification, and renewal applications.						
	This section of the application is only used to determine if alternative language notices will be needed. Complete instructions on publishing the alternative language notices will be in your public notice package.						
	Please call the bilingual/ESL coordinator at the nearest elementary and middle schools and obtain the following information to determine whether an alternative language notices are required.						
	1. Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?	y					
	⊠ Yes □ No						
	If no , publication of an alternative language notice is not required; skip to Section 9 below.						
	2. Are the students who attend either the elementary school or the middle school enrolled is a bilingual education program at that school?	in					
	⊠ Yes □ No						

(956) 551-2602						() =		
ECTION III:	Regu	lated Ent	ity Info	rmatio	<u>n</u>			
21. General Regulated	Entity Inforr	mation (If 'New Re	gulated Entity" is s	elected, a nev	v permit appl	ication is also required.)		
New Regulated Entity	Update	to Regulated Entity	Name Upda	ite to Regulat	ed Entity Info	rmation		
The Regulated Entity National Inc., LP, or LLC).	ame submit	ted may be upda	ted, in order to i	meet TCEQ (Core Data S	tandards (removal of	organizatio	nal endings suc
22. Regulated Entity Na	ime (Enter na	me of the site wher	re the regulated ac	tion is taking	place.)			
Turning Basin Wastewater	Treatment Pla	int						
23. Street Address of the Regulated Entity:	3005 Leve	ee Road	y					
(No PO Boxes)								
NOTO BOXES	City	Brownsville	State	TX	ZIP	78521	ZIP + 4	
24. County	Cameron							
7		If no Stree	et Address is pro	vided, field:	25-28 are	required.		
5. Description to	3005 Leve	e Road, Brownsville	Texas. 78521, loca	ated on the no	orth side of St	ate Highway 48. approx	imately 0.7 m	ile east of the
hysical Location:	intersectio	n of State Highway	48 and Farm-to-M	larket Road 5	.1 northeast	of the city of Brownsville	e, Cameron Co	ounty, Texas.
6. Nearest City						State	Nea	arest ZIP Code
atitude/Longitude are	required an	d may be added/	updated to mee	t TCEQ Core	Data Stand	lards. (Geocoding of	the Physical	Address may b
sed to supply coordina	tes where n	one have been pi	rovided or to gai	in accuracy)				
7. Latitude (N) In Decin	nal:	25.962160		28.	Longitude (W) In Decimal:	-97.3955	84
egrees	Minutes		Seconds	Deg	rees	Minutes		Seconds
25		52	04		97	23	3	15
9. Primary SIC Code	30	. Secondary SIC C	Code	31. Prim	ary NAICS C	ode 32. Sec	ondary NAI	CS Code
digits)	(4	digits)		(5 or 6 di		(5 or 6 c	ligits)	
592				22132				
3. What is the Primary	Business of	this entity? (Do	not repeat the SIC	or NAICS des	cription.)			
A BASILIS	Brownsvil	le Navigation Distr	ict					
I. Mailing	1000 Fous	st Rd						
ddress:	City	Brownsville	State	TX	ZIP	78521	ZIP+4	
. E-Mail Address:	mm	artinez@portofbro	ownsville.com					
. Telephone Number			37. Extension of	r Code	38. 1	Fax Number (if applica	ble)	
56) 551-2602								
,					()		

19. Extension or Code

20. Fax Number (if applicable)

18. Telephone Number

Dam Safety Municipal Solid Waste Sludge Voluntary Cleanup		☐ Districts ☐ Edwards Aquifer ☐ New Source Review Air ☐ OSSF				ions Inventory Air	☐ Industrial Hazardous Wast	
						leum Storage Tank		
		Storm Water	Storm Water		Tires		Used Oil	
		☐ Wastewater ☐ Wastewater Agricu		iculture	ture Water Rights		Other:	
ECTION	IV: Pr	eparer Inf	ormation					
	ora Alicia Gor		ormation 44. Fax Number	41. Title:	Engin	neering Adminstrative	Special	
O. Name: No	ora Alicia Gor	nzalez		45. E-Ma	ail Addres		Special	
2. Telephone Nu 956) 551-9205 ECTION By my signature bubmit this form on	ora Alicia Gor Imber V: Au Delow, I certify In behalf of the	43. Ext./Code thorized S y, to the best of my knove entity specified in Sec	44. Fax Number () - ignature	45. E-Managonzale nagonzale ation provided in required for the	ez@portof	brownsville.com	, and that I have signature authorit ntified in field 39.	
O. Name: No. No. No. No. No. No. No. Strategies of the stra	ora Alicia Gor Imber V: Au Delow, I certify In behalf of the	43. Ext./Code thorized S y, to the best of my knore entity specified in Security speci	44. Fax Number () - ignature wledge, that the informa	45. E-Managonzale	ez@portof	brownsville.com	, and that I have signature authorit ntified in field 39.	

	Title: Click to enter text. Credential: Click to enter text.
	Organization Name: Click to enter text.
	Mailing Address: Click to enter text. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text. E-mail Address: Click to enter text.
	If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.
	Attachment: Click to enter text.
F.	Owner sewage sludge disposal site (if authorization is requested for sludge disposal on property owned or controlled by the applicant)::
	Prefix: Click to enter text. Last Name, First Name: Click to enter text.
	Title: Click to enter text. Credential: Click to enter text.
	Organization Name: Click to enter text.
	Mailing Address: Click to enter text. City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text. E-mail Address: Click to enter text.
	If the landowner is not the same person as the facility owner or co-applicant, attach a lease agreement or deed recorded easement. See instructions.
	Attachment: Click to enter text.
Se	ction 10. TPDES Discharge Information (Instructions Page 31)
	ction 10. TPDES Discharge Information (Instructions Page 31)
	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate?
	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate? Yes □ No
	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate? ☑ Yes □ No If no, or a new permit application, please give an accurate description:
A.	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate? ☑ Yes □ No If no, or a new permit application, please give an accurate description:
A.	Is the wastewater treatment facility location in the existing permit accurate? ✓ Yes □ No If no, or a new permit application, please give an accurate description: Click to enter text.
A.	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate? □ Yes □ No If no, or a new permit application, please give an accurate description: □ Click to enter text. Are the point(s) of discharge and the discharge route(s) in the existing permit correct? □ Yes □ No If no, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307:
A.	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate? ☐ Yes ☐ No If no, or a new permit application, please give an accurate description: ☐ Click to enter text. Are the point(s) of discharge and the discharge route(s) in the existing permit correct? ☐ Yes ☐ No If no, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30.
A.	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate? □ Yes □ No If no, or a new permit application, please give an accurate description: □ Click to enter text. Are the point(s) of discharge and the discharge route(s) in the existing permit correct? □ Yes □ No If no, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307:
А.	ction 10. TPDES Discharge Information (Instructions Page 31) Is the wastewater treatment facility location in the existing permit accurate? □ Yes □ No If no, or a new permit application, please give an accurate description: □ Click to enter text. Are the point(s) of discharge and the discharge route(s) in the existing permit correct? □ Yes □ No If no, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307: □ Click to enter text. □ City nearest the outfall(s): Brownsville □ County in which the outfall(s) is/are located: Cameron
А.	Is the wastewater treatment facility location in the existing permit accurate? ✓ Yes □ No If no, or a new permit application, please give an accurate description: Click to enter text. Are the point(s) of discharge and the discharge route(s) in the existing permit correct? ✓ Yes □ No If no, or a new or amendment permit application, provide an accurate description of the point of discharge and the discharge route to the nearest classified segment as defined in 30 TAC Chapter 307: Click to enter text.

Last Name, First Name: Click to enter text.

E. Owner of effluent disposal site:

Prefix: SAME



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS Enter DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Brownsville Navigation District (CN600520126) operates Turning Basin Wastewater Treatment Plant ((RN1020780940), an activated sludge process plant operated in the conventional mode.. The facility is located at 3005 Levee Road, in Brownsville, Texas. 78521, Cameron, County, Texas 78521 located on the north side of State Highway 48, approximately 0.7 mile east of the intersection of State Highway 48 and Farm-to-Market Road 511, northeast of the city of Brownsville, Cameron County. Texas. 78521. Renewal of the existing permit that authorizes the discharge of treated domestic wastewater at a daily average flow not to exceed 0.1 million gallons per day (MGF) the Turning Basin Wastewater Plant serves Ostos Road along the entire south side of the Brownsville Ship Channel (BSC), Windhaus Road, and Milo Road west of (BSC), Foust Road north of the (BSC), from 511 to Old SH 48, and W. Oil Dock Ramp up to Oil Dock No. 5. << For TLAP applications include the following sentence, otherwise delete:>> This permit will not authorize a discharge of pollutants into water in the state.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TOPO MOD ONEX	
TCEQ USE ONLY:	
Application type:RenewalMajor Am	
County:	
Admin Complete Date:	_
Agency Receiving SPIF:	
Texas Historical Commission	
Texas Parks and Wildlife Department	U.S. Army Corps of Engineers
This form applies to TPDES permit application	us only. (Instructions, Page 53)
Complete this form as a separate document. To our agreement with EPA. If any of the items are is needed, we will contact you to provide the infleach item completely.	EQ will mail a copy to each agency as required by not completely addressed or further information formation before issuing the permit. Address
Do not refer to your response to any item in the attachment for this form separately from the Acapplication will not be declared administratively completed in its entirety including all attachmentary be directed to the Water Quality Division's attachmentary because of the Water Division Divis	dministrative Report of the application. The complete without this SPIF form being nts. Questions or comments concerning this form Application Review and Processing Team by
The following applies to all applications:	and the second s
. Permittee: <u>Brownsville Navigation District</u>	
Permit No. WQ00 <u>14355001</u>	EPA ID No. TX <u>0074047</u>
and county): 3005 Levee Road, Brownsville Texas. 78521 loca approximately 0.7 mile east of the intersection of northeast of the city of Brownsville, Cameron Co	f State Highway 48 and Farm-to-Market Road 511, bunty, Texas. 78521

Francesca Findlay

From: Francesca Findlay

Sent:Thursday, October 16, 2025 11:45 AMTo:mmartinez@portofbrownsville.comCc:nagonzalez@portofbrownsville.com

Subject: FW: WQ0014355001 Brownsville Navigation District

Attachments: wq0010365001-map.pdf

Good morning,

I am reviewing your application, and I have a few questions.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Please let me know if you have any questions.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

Francesca Findlay

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Wednesday, October 8, 2025 10:22 AM **To:** Francesca Findlay; Manuel Martinez

Cc: Manuel Martinez

Subject: RE: WQ0014355001 Brownsville Navigation District

Attachments: BRNB42200BE0725_000086.pdf; TB Responses Administrative 10-3-2025v2.pdf

Good Morning

Francesca

Attached are the response documents for October 3, 2025 items.

Although I have a question on administrative report section 10. A marked with marked black, Location of plant has been corrected on all documents requested, see attached, or do we have to correct it? I answered yes or do I answer no and add location of plant, please advise.

Kindly Regards

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Friday, October 3, 2025 3:36 PM

To: Manuel Martinez <mmartinez@portofbrownsville.com> **Cc:** Nora Gonzalez <nagonzalez@portofbrownsville.com> **Subject:** FW: WQ0014355001 Brownsville Navigation District

Dear Mr. Martinez:

The attached Notice of Deficiency letter sent on October 3, 2025, requesting additional information needed to declare the application administratively complete. Please send the complete response to my attention October 18, 2025.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

Francesca Findlay

From: Manuel Martinez <mmartinez@portofbrownsville.com>

Sent: Thursday, October 16, 2025 4:15 PM **To:** Francesca Findlay; Nora Gonzalez

Subject: Re: WQ0014355001 Brownsville Navigation District

Attachments: Outlook-round face; Outlook-youtube ic; Outlook-tmjprynl

Good afternoon Ms. Francesca, I apologize for the confusion. Please see our responses below:

1. Please verify that the site address of 3005 Levee Road is a 911 address.

This road is an internal road inside Port of Brownsville premises and might not be in the 911 address map. This is a renewal permit, not sure if this address was used previously.

2. Please confirm that the site coordinates are correct.

The coordinates for this treatment plant are: 25.962253 -97.394652 (25'57'43"N and 97'23'40"W)

3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Description: 3005 Levee Rd, Brownsville TX 78521; located on the north side of Old State Highway 48, approximately 0.7 miles east of the intersection of Old State Highway 48 and State Highway 550 Toll (Bill Reed Road) Brownsville, Cameron County, Texas. (Please see image below for clarification).



We greatly appreciate your time and any comments;

Best regards

Mr. Manuel Martinez / Acting Director of Engineering Serv. / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7029 **M:** (956) 551-2602 **F:** (956) 831-6153





From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov>

Sent: Thursday, October 16, 2025 2:33 PM

To: Nora Gonzalez < nagonzalez @portofbrownsville.com >; Manuel Martinez < mmartinez @portofbrownsville.com >

Subject: RE: WQ0014355001 Brownsville Navigation District

Good afternoon,

The coordinates I sent, are the directions that were sent to me for the plant site. I have attached the coordinates that were given on the Core Data Form.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Thank you,

Francesca Findlay
License & Permit Specialist
ARP Team | Water Quality Division
512-239-2441
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

From: Nora Gonzalez <nagonzalez@portofbrownsville.com>

Sent: Thursday, October 16, 2025 11:55 AM

To: Francesca Findlay <Francesca.Findlay@tceq.texas.gov>; Manuel Martinez <mmartinez@portofbrownsville.com>

Subject: RE: WQ0014355001 Brownsville Navigation District

Good Morning

Fransesca

The coordinates you sent do not belong to the Turning Basin Wastewater Treatment Plant.

Send us the correct information needed.

Nora Alicia Gonzalez / Engineering Administrative Specialist / Port of Brownsville

1000 Foust Road, Brownsville, TX 78521

D: (956) 838-7003 M: (956) 551-9205 F: (956) 831-6153



From: Francesca Findlay < Francesca. Findlay@tceq.texas.gov >

Sent: Thursday, October 16, 2025 11:45 AM

To: Manuel Martinez <<u>mmartinez@portofbrownsville.com</u>>
Cc: Nora Gonzalez <<u>nagonzalez@portofbrownsville.com</u>>
Subject: FW: WQ0014355001 Brownsville Navigation District

Good morning,

I am reviewing your application, and I have a few questions.

- 1. Please verify that the site address of 3005 Levee Road is a 911 address.
- 2. Please confirm that the site coordinates are correct.
- 3. The description given for the site is showing approximately 1.4 miles. I have attached the verification I have showing the miles.

Please let me know if you have any questions.

Thank you,

Francesca Findlay

License & Permit Specialist ARP Team | Water Quality Division 512-239-2441

Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail

How is our customer service? Fill out our online customer satisfaction survey at http://www.tceq.texas.gov/customersurvey.

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

CONFIDENTIALITY NOTICE: The information contained in this email may be legally privileged and confidential. If you are not an intended recipient, you are hereby notified that any dissemination, distribution, or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please notify the sender and permanently delete the e-mail and any attachments immediately. You should not retain, copy or use this e-mail or any attachments for any purpose, nor disclose all or any part of the contents to any other person. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors in the contents of this message. If verification is required please contact the Information Technology Office of the Brownsville Navigation District. Employees of the Brownsville Navigation District are expressly required not to make defamatory statements and not to infringe or authorize any infringement of copyright, privacy rights or any other legal right by email communications. Any such communication is contrary to BND policy and outside the scope of the employment of the individual concerned. BND will not accept any liability in respect of such communication, and the employee responsible will be personally liable for any damages or other liability arising. Brownsville Navigation District - 1000 Foust Rd. Brownsville TX 78521 USA - Tel. (956) 831-4592

Brooke T. Paup, *Chairwoman*Tonya R. Miller, *Commissioner*Catarina R. Gonzales, *Commissioner*Kelly Keel, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

October 17, 2025

Mr. Manuel Martinez, Acting Director of Engineering Services Brownsville Navigation District 1000 Foust Road Brownsville, Texas 78521

Re: Brownsville Navigation District- TPDES Permit No. WQ0014355001, EPA ID No. TX0074047 (CN 600520126; RN 102078094)

Dear Mr. Martinez,

We are in receipt of your letter dated September 3, 2025, requesting the Texas Commission on Environmental Quality (TCEQ) to authorize to temporary use of the sludge drying beds that are situated to the west of the plant, during repair and rehabilitation of the Brownsville Navigation District's Turning Basin Wastewater Treatment Facility (WWTF) clarifier. The letter provided an Exhibit Map showing the location of the drying beds within the WWTF site.

We have evaluated your request and understand that this activity will not cause a change in the terms and conditions of the permit or the ability of the permittee to meet these terms and conditions. Your request is approved based on the following conditions:

- 1. The authorization is temporary, and will expire at the end of 30 days from the date of this letter.
- 2. Two existing drying beds will serve to temporarily store the partially treated wastewater from the aeration chamber at times when the clarifier is emptied for repairs.
- 3. Both drying beds have been adequately lined to control seepage in accordance with 30 Texas Administrative Code (TAC) Section 217. 203.
- 4. Any liquid waste placed in the sludge drying beds is to be recycled to the plant headworks.

Mr. Manuel Martinez, Page 2 October 16, 2025

- 5. There will be no direct discharge of any effluent from these drying beds into water in the state.
- 6. The permittee shall meet the buffer zone requirements in 30 TAC § 309.13 with a 500-foot buffer zone and the requirements for temporary storage of waste in 30 TAC § 312.147.
- 7. The permittee shall notify the TCEQ Region 15 office about the clarifier's repair and rehabilitation work progress in a timely manner prior to beginning and ending use of these drying beds.

Based on the above facts and conditions, the TCEQ does not hold any objection on your request to use the existing sludge drying beds for temporary storage of partially treated wastewater during repair of the clarifier.

If you have any questions regarding this matter, please contact me at (512) 239-4608, or if by correspondence include MC 148 in the letterhead address following my name.

Sincerely,

Deba Dutta

Deba Dutta, P.E., Team Leader Domestic Permits Team Domestic Wastewater Section (MC 148) Water Quality Division Texas Commission on Environmental Quality

cc: Erwin Madrid, Team Leader, Application Review and processing Team (MC 148). Monica Galvan, Water Section Manager, TCEQ Region 15 (MC R15).