

#### This file contains the following documents:

- 1. Summary of application (in plain language)
  - English
  - Alternative Language (Spanish)
- 2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
  - English
  - Alternative Language (Spanish)
- 3. Second notice (NAPD-Notice of Preliminary Decision)
  - English
  - Alternative Language (Spanish)
- 4. Application materials
- 5. Draft permit
- 6. Technical summary or fact sheet



#### Este archivo contiene los siguientes documentos:

- 1. Resumen de la solicitud (en lenguaje sencillo)
  - Inglés
  - Idioma alternativo (español)
- 2. Primer aviso (NORI, Aviso de Recepción de Solicitud e Intención de Obtener un Permiso)
  - Inglés
  - Idioma alternativo (español)
- 3. Segundo aviso (NAPD, Aviso de Decisión Preliminar)
  - Inglés
  - Idioma alternativo (español)
- 4. Materiales de la solicitud
- 5. Proyecto de permiso
- 6. Resumen técnico u hoja de datos



#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

# Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Fort Bend County Municipal Utility District No. 162 (CN602863896) operates Fort Bend County Municipal Utility District No. 162 WWTP No. 1 (RN104443551), a wastewater treatment plant. The facility is located at 7102 ½ Koeblen Road, in Richmond, Fort Bend County, Texas 77469. The District is applying to discharge up to 0.45 MGD from the existing WWTP.

Discharges from the facility are expected to contain suspended solids, ammonia nitrogen, and e. coli. Treated domestic wastewater is treated by an activated sludge process.

## PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

#### AGUAS RESIDUALES DOMÉSTICAS /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

Fort Bend County Municipal Utility District No. 162 (CN602863896) opera Fort Bend County Municipal Utility District No. 162 WWTP No. 1 RN104443551, una planta de tratamiento de aguas residuales. La instalación está ubicada en 7102 ½ Koeblen Rd, en Richmond, Condado de Fort Bend, Texas 77469. El Distrito está solicitando descargar hasta 0,45 MGD de la planta de tratamiento de aguas residuales existente.

Se espera que las descargas de la instalación contengan sólidos suspendidos, nitrógeno amoniacal, y e. coli. Aguas residuals domésticas tratadas. están tratado por lodos activados.

#### **TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**



### NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT

#### PROPOSED PERMIT NO. WQ0014564002

APPLICATION. Fort Bend County Municipal Utility District No. 162, 3200 Southwest Freeway, Suite 2600, Houston, Texas 77027, has applied to the Texas Commission on Environmental Quality (TCEQ) for proposed Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0014564002 (EPA I.D. No. TX0147559) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 450,000 gallons per day. The domestic wastewater treatment facility is located at 7102 1/2 Koeblen Road, Richmond, in Fort Bend County, Texas 77469. The discharge route is from the plant site via storm sewer system to Fort Bend County Drainage District Ditch II-B-7, thence to Big Creek, thence to the Brazos River below Navasota River. Authorization to discharge was previously permitted by expired Permit No. WQ0014564001. TCEQ received this application on February 28, 2025. The permit application will be available for viewing and copying at George Memorial Library, 1001 Golfview Drive, Richmond, in Fort Bend County, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.758611,29.501111&level=18

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at: <a href="https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications">https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications</a>. El aviso de idioma alternativo en español está disponible en <a href="https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications">https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications</a>.

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. Notice of the Application and Preliminary Decision will be published and mailed to those who are on the countywide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public

interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at <a href="https://www.tceq.texas.gov/goto/cid">www.tceq.texas.gov/goto/cid</a>. Search the database using the permit number for this application, which is provided at the top of this notice.

**AGENCY CONTACTS AND INFORMATION.** All public comments and requests must be submitted either electronically at <a href="https://www14.tceq.texas.gov/epic/eComment/">https://www14.tceq.texas.gov/epic/eComment/</a>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105,

P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at <a href="www.tceq.texas.gov/goto/pep">www.tceq.texas.gov/goto/pep</a>. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Fort Bend County Municipal Utility District No. 162 at the address stated above or by calling Mr. Blake Ahrendsen, E.I.T., Senior Project Engineer, Odyssey Engineering Group, LLC, at 281-306-0240, Extension 112.

Issuance Date: March 12, 2025

#### Comisión de Calidad Ambiental del Estado de Texas



#### AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA

#### PERMISO PROPUESTO NO. WQoo14564002

**SOLICITUD.** Fort Bend County Municipal Utility District No. 162, 3200 Southwest Fwy, Ste 2600, Houston, Texas 77027 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) para el propuesto Permiso No. WQ0014564002 (EPA I.D. No. TX0147559) del Sistema de Eliminación de Descargas de Contaminantes de Texas (TPDES) para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 450,000 galones por día. La planta está ubicada en 7102 ½ Koeblen Road en el Condado de Fort Bend, Texas. La ruta de descarga es del sitio de la planta a través del sistema de alcantarillado pluvial al Fort Bend County Drainage District Ditch II-B-7, de allí a Big Creek, desde allí hasta el río Brazos por debajo del río Navasota. La TCEQ recibió esta solicitud el 28 de febrero de 2025. La solicitud para el permiso está disponible para leerla y copiarla en 1001 Golfview Drive, Richmond. La solicitud (cualquier actualización y aviso inclusive) está disponible electrónicamente en la siguiente página web:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.758611,29.501111&level=18

El Director Ejecutivo de la TCEQ ha revisado esta medida para ver si está de acuerdo con los objetivos y las regulaciones del Programa de Administración Costero de Texas (CMP) de acuerdo con las regulaciones del Consejo Coordinador de la Costa (CCC) y ha determinado que la acción es conforme con las metas y regulaciones pertinentes del CMP.

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay

un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

#### OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios.

**LISTA DE CORREO.** Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas

designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN DE LA TCEQ. Todos los comentarios escritos del público y los para pedidos una reunión deben ser presentados a la Oficina del Secretario Principal, MC 105, TCEQ, P.O. Box 13087, Austin, TX 78711-3087 o por el internet at <a href="www.tceq.texas.gov/about/comments.html">www.tceq.texas.gov/about/comments.html</a>. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Si necesita más información en Español sobre esta solicitud para un permiso o el proceso del permiso, por favor llame a El Programa de Educación Pública de la TCEQ, sin cobro, al 1-800-687-4040. La información general sobre la TCEQ puede ser encontrada en nuestro sitio de la red: <a href="www.tceq.texas.gov">www.tceq.texas.gov</a>.

También se puede obtener información adicional del Fort Bend County Municipal Utility District No. 162 a la dirección indicada arriba o llamando a Blake Ahrendsen, E.I.T., Senior Project Engineer, Odyssey Engineering Group, LLC al 281-306-0240, extensión 112.

Fecha de emisión 12 de marzo de 2025

#### **Texas Commission on Environmental Quality**



### NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR MUNICIPAL WASTEWATER

#### **NEW**

#### **PERMIT NO. WQ0014564002**

**APPLICATION AND PRELIMINARY DECISION.** Fort Bend County Municipal Utility District No. 162, 3200 Southwest Freeway, Suite 2600, Houston, Texas 77027, has applied to the Texas Commission on Environmental Quality (TCEQ) for new Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0014564002, to authorize the discharge of treated domestic wastewater at a daily average flow not to exceed 450,000 gallons per day. The facility was previously permitted under TPDES Permit No. WQ0014564001. TCEQ received this application on February 28, 2025.

The facility is located at 7102 1/2 Koeblen Road, in Fort Bend County, Texas 77469. The treated effluent is discharged to Fort Bend County Drainage District (FBCDD Ditch II-B-7), thence to Big Creek, thence to the Brazos River Below Navasota River in Segment No. 1202 of the Brazos River Basin. The unclassified receiving water use is minimal aquatic life use for FBCDD Ditch II-B-7. The designated uses for Segment No. 1202 are primary contact recreation, public water supply, and high aquatic life use. In accordance with 30 Texas Administrative Code §307.5 and the TCEO's Procedures to Implement the Texas Surface Water Quality Standards (June 2010), an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. This review has preliminarily determined that no water bodies with exceptional, high, or intermediate aquatic life uses are present within the stream reach assessed; therefore, no Tier 2 degradation determination is required. No significant degradation of water quality is expected in water bodies with exceptional, high, or intermediate aquatic life uses downstream, and existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.758611,29.501111&level=18

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at George Memorial Library, 1001 Golfview Drive, Richmond, in Fort Bend County, Texas. The application, including any updates, and associated notices are available electronically at the following webpage:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

**ALTERNATIVE LANGUAGE NOTICE.** Alternative language notice in Spanish is available at <a href="https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices">https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices</a>. El aviso de idioma alternativo en español está disponible en <a href="https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices">https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices</a>.

**PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting about this application.** The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ holds a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision. A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

**EXECUTIVE DIRECTOR ACTION.** The Executive Director may issue final approval of the application unless a timely contested case hearing request or request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

**MAILING LIST.** If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, Texas Commission on Environmental Quality, P.O. Box 13087, Austin, TX 78711-3087 or electronically at <a href="https://www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a> within 30 days from the date of newspaper publication of this notice.

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at <a href="www.tceq.texas.gov/goto/cid">www.tceq.texas.gov/goto/cid</a>. Search the database using the permit number for this application, which is provided at the top of this notice.

**AGENCY CONTACTS AND INFORMATION.** Public comments and requests must be submitted either electronically at <a href="www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a>, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC 105, P.O. Box 13087, Austin, Texas 78711-3087. Any personal information you submit to the TCEQ will become part of the agency's record; this includes email addresses. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at <a href="www.tceq.texas.gov/goto/pep">www.tceq.texas.gov/goto/pep</a>. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from Fort Bend County Municipal Utility District No. 162 at the address stated above or by calling Mr. Blake Ahrendsen, E.I.T., Senior Project Engineer, Odyssey Engineering Group, LLC, at 281-306-0240, Extension 112.

Issuance Date: September 4, 2025

#### Comisión De Calidad Ambiental Del Estado De Texas



#### AVISO DE LA SOLICITUD Y DECISIÓN PRELIMINAR PARA EL PERMISO DEL SISTEMA DE ELIMINACION DE DESCARGAS DE CONTAMINANTES DE TEXAS (TPDES) PARA AGUAS RESIDUALES MUNICIPALES

#### **NUEVO**

#### PERMISO PROPUESTO NO. WQ0014564002

**SOLICITUD Y DECISIÓN PRELIMINAR.** Fort Bend County Municipal Utility District No. 162, 3200 Southwest Fwy, Ste 2600 ha solicitado a la Comisión de Calidad Ambiental del Estado de Texas (TCEQ) por un nuevo para autorizar la descarga de aguas residuales tratadas en un volumen que no sobrepasa un flujo promedio diario de 450,000 galones por día. La planta *estaba previamente permitida bajo el permiso número WQ0014564001*. La TCEQ recibió esta solicitud el 28 de febrero de 2025.

La planta está ubicada en 7102 ½ Koeblen Road en el Condado de Fort Bend, Texas. Este enlace a un mapa electrónico de la ubicación general del sitio o de la instalación es proporcionado como una cortesía y no es parte de la solicitud o del aviso. Para la ubicación exacta, consulte la solicitud. El efluente tratado es descargado al Fort Bend County Drainage District Ditch II-B-7, de allí a Big Creek, desde allí hasta el Río Brazos por debajo del Río Navasota en el Segmento No. 1202 de la Cuenca del Río Brazos. Los usos no clasificados de las aguas receptoras son no significativos usos de la vida acuática para FBCDD Ditch II-B-7. Los usos designados para el Segmento No. 1202 son elevados uso de vida acuática; abastecimiento de agua potable. De acuerdo con el 30 TAC §307.5 y los procedimientos de implementación de la TCEQ (Enero 2010) para las Normas de Calidad de Aguas Superficiales en Texas, fue realizada una revisión de la antidegradación de las aguas recibidas. Una revisión de antidegradación del Nivel 1 ha determinado preliminarmente que los usos de la calidad del agua existente no serán perjudicados por la acción de este permiso. Se mantendrá un criterio narrativo y numérico para proteger los usos existentes. Esta revisión ha determinado preliminarmente que ninguno de los cuerpos de agua con usos intermedio, alto o excepcional de vida acuática están presentes dentro del acceso para llegar a la corriente; por lo tanto, no se requiere ninguna determinación de degradación del Nivel 2. No se espera ninguna degradación significativa de la calidad del agua en los cuerpos de agua con usos intermedios, elevados o excepcionales de la vida acuática río abajo y que los usos existentes serán mantenidos y protegidos. La determinación preliminar puede ser reexaminada y puede ser modificada, si se recibe alguna información nueva. https://gisweb.tceq.texas.gov/LocationMapper/?marker=-95.758611,29.501111&level=18

El Director Ejecutivo de la TCEQ ha completado la revisión técnica de la solicitud y ha preparado un borrador del permiso. El borrador del permiso, si es aprobado, establecería las condiciones bajo las cuales la instalación debe operar. El Director Ejecutivo ha tomado una decisión preliminar que si este permiso es emitido, cumple con todos los requisitos normativos y legales. La solicitud del permiso, la decisión preliminar del Director Ejecutivo y el borrador del permiso están disponibles para leer y copiar en 1001 Golfview Drive, Richmond, Condado de Fort Bend. La solicitud (cualquier actualización y aviso inclusive) está disponible electrónicamente en la siguiente página web:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

**AVISO DE IDIOMA ALTERNATIVO.** El aviso de idioma alternativo en español está disponible <a href="https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications">https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications</a>.

## COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud.

El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

#### OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después de la fecha límite para presentar comentarios públicos, el Director Ejecutivo considerará los comentarios y preparará una respuesta a todos los comentarios públicos relevantes y materiales, o significativos. A menos que la solicitud sea remitida directamente para una audiencia de caso impugnado, la respuesta a los comentarios se enviará por correo a todos los que enviaron comentarios públicos y a aquellas personas que estén en la lista de correo para esta solicitud. Si se reciben comentarios, el correo también proporcionará instrucciones para solicitar una audiencia de caso impugnado o reconsiderar la decisión del Director Ejecutivo. Una audiencia de caso impugnado es un procedimiento legal similar a un juicio civil en un tribunal de distrito estatal.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Tras el cierre de todos los periodos de comentarios y solicitudes aplicables, el Director Ejecutivo remitirá la solicitud y cualquier solicitud de reconsideración o de una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración en una reunión programada de la Comisión.

La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios.

**ACCIÓN DEL DIRECTOR EJECUTIVO.** El Director Ejecutivo puede emitir la aprobación final de la solicitud a menos que se presente una solicitud de audiencia de caso impugnado oportunamente o una solicitud de reconsideración. Si se presenta una solicitud de audiencia oportuna o una solicitud de reconsideración, el Director Ejecutivo no emitirá la aprobación final del permiso y enviará la solicitud y la solicitud a los Comisionados de TCEQ para su consideración en una reunión programada de la Comisión.

**LISTA DE CORREO**. Si envía comentarios públicos, una solicitud de una audiencia de caso impugnado o una reconsideración de la decisión del Director Ejecutivo, se le agregará a la lista de correo de esta solicitud específica para recibir futuros avisos públicos enviados por correo por la Oficina del Secretario Oficial. Además, puede solicitar ser colocado en: (1) la lista de correo permanente para un nombre de solicitante específico y número de permiso; y/o (2) la lista de correo para un condado específico. Si desea ser colocado en la lista de correo permanente y / o del condado, especifique claramente qué lista (s) y envíe su solicitud a la Oficina del Secretario Oficial de la TCEQ a la dirección a continuación.

Todos los comentarios públicos escritos y las solicitudes de reunión pública deben enviarse a Office of the Chief Clerk, MC 105, TCEQ, P.O. Box 13087, Austin, TX 78711-3087 o electrónicamente a <a href="https://www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a> dentro de los 30 días a partir de la fecha de publicación de este aviso en el periódico.


**CONTACTOS E INFORMACIÓN DE LA AGENCIA.** Los comentarios y solicitudes públicas deben enviarse electrónicamente a <a href="www.tceq.texas.gov/goto/comment">www.tceq.texas.gov/goto/comment</a>, o por escrito a Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Cualquier información personal que envíe a la TCEQ pasará a formar parte del registro de la agencia; esto incluye las direcciones de correo electrónico. Para obtener más información sobre esta solicitud de permiso o el proceso de permisos, llame al Programa de Educación Pública de TCEQ, línea gratuita, al 1-800-687-4040 o visite su sitio web en <a href="www.tceq.texas.gov/goto/pep">www.tceq.texas.gov/goto/pep</a>. Si desea información en español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del Fort Bend County Municipal utility District No. 162 a la dirección indicada arriba o llamando a Blake Ahrendsen, E.I.T., Senior Project Engineer, Odyssey Engineering Group, LLC, al 281306-0240 extensión 112.

Fecha de emission: el 4 de septiembre de 2025

## Fort Bend County MUD No. 162 WWTP No. 1 New Permit Application

Project #: 16-009-215





#### LIST OF ATTACHMENTS FORT BEND COUNTY MUD NO. 162 MUNICIPAL UTILITY DISTRICT WASTEWATER TREATMENT PLANT

- Attachment 1 Administrative Report
- Attachment 2 Technical Report
- Attachment 3 TCEQ Core Data Form
- Attachment 4 USGS Map
- Attachment 5 Buffer Zone Map
- Attachment 6 Process Flow Diagram
- Attachment 7 Site Map
- Attachment 8 Payment Voucher
- Attachment 9 TCEQ Letter of Approval for Project Summary of 0.45 MGD
- Attachment 10 TCEQ Letter of Approval for Project Summary of 0.35 MGD
- Attachment 11 Supplemental Permit Information Form
- Attachment 12 Downstream Landowners Address Information
- Attachment 13 Downstream Exhibit
- Attachment 14 Original Photograph Exhibit
- Attachment 15 Sludge Agreement Letter
- Attachment 16 Plain Language Summary
- Attachment 17 Public Involvement Plan Form
- Attachment 18 Setback Easement



### FORT BEND COUNTY MUD NO. 162 WWTP DISCHARGE PERMIT MAJOR AMENDMENT PERMIT NO. WQ0014564002

ATTACHMENT 1

Administrative Report

# THE TONMENTAL OUR LEVEL OF THE PROPERTY OF THE

#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

APPLICANT NAME: FORT BEND COUNTY MUNICIPAL UTILITY DISTRICT No. 162

PERMIT NUMBER (If new, leave blank): WQ0014564002

Indicate if each of the following items is included in your application.

	Y	N		Y	N
Administrative Report 1.0	$\boxtimes$		Original USGS Map	$\boxtimes$	
Administrative Report 1.1	$\boxtimes$		Affected Landowners Map	$\boxtimes$	
SPIF	$\boxtimes$		Landowner Disk or Labels	$\boxtimes$	
Core Data Form	$\boxtimes$		Buffer Zone Map	$\boxtimes$	
Summary of Application (PLS)	$\boxtimes$		Flow Diagram	$\boxtimes$	
Public Involvement Plan Form	$\boxtimes$		Site Drawing	$\boxtimes$	
Technical Report 1.0	$\boxtimes$		Original Photographs	$\boxtimes$	
Technical Report 1.1	$\boxtimes$		Design Calculations		$\boxtimes$
Worksheet 2.0	$\boxtimes$		Solids Management Plan		$\boxtimes$
Worksheet 2.1	$\boxtimes$		Water Balance		$\boxtimes$
Worksheet 3.0					
Worksheet 3.1		$\boxtimes$			
Worksheet 3.2		$\boxtimes$			
Worksheet 3.3					
Worksheet 4.0		$\boxtimes$			
Worksheet 5.0		$\boxtimes$			
Worksheet 6.0	$\boxtimes$				
Worksheet 7.0		$\boxtimes$			
For TCEQ Use Only					
			County Region		
Permit Number					

# THE THE PART OF TH

#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

# DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

#### **Section 1.** Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
< 0.05 MGD	\$350.00 □	\$315.00 □
≥0.05 but <0.10 MGD	\$550.00 □	\$515.00 □
≥0.10 but <0.25 MGD	\$850.00 □	\$815.00 □
≥0.25 but <0.50 MGD	\$1,250.00 ⊠	\$1,215.00
$\geq$ 0.50 but <1.0 MGD	\$1,650.00 <b>□</b>	\$1,615.00
≥1.0 MGD	\$2,050.00	\$2,015.00

Minor Amendment (for any flow) \$150.00 □

<b>Payment</b>	Inform	ation
ravineni	шиони	auvii.

Mailed Check/Money Order Number: Click to enter text.

Check/Money Order Amount: Click to enter text.

Name Printed on Check: Click to enter text.

EPAY Voucher Number: 751146 and 751147

Copy of Payment Voucher enclosed? Yes  $\boxtimes$ 

#### Section 2. Type of Application (Instructions Page 26)

a.	Che	ck the box next to the appropriate authorization type.
	$\boxtimes$	Publicly Owned Domestic Wastewater
		Privately-Owned Domestic Wastewater
		Conventional Water Treatment
b.	Che	ck the box next to the appropriate facility status.
	$\boxtimes$	Active   Inactive

c.	Che	ck the box next to the appropriate	permit type.		
	$\boxtimes$	TPDES Permit			
		TLAP			
		TPDES Permit with TLAP component	ent		
		Subsurface Area Drip Dispersal S	ystem (SADDS	S)	
А	Che	eck the box next to the appropriate	application to	vn	a.
u.		New	upplication t	) P	
		Major Amendment <i>with</i> Renewal		1	Minor Amendment <i>with</i> Renewal
		Major Amendment <u>without</u> Renew		- -	Minor Amendment <u>without</u> Renewal
		Renewal without changes		- -	Minor Modification of permit
		G			
e.	For	amendments or modifications, des	scribe the pro	po	sed changes: Click to enter text.
f.	For	existing permits:			
	Peri	mit Number: WQ00 <u>WQ0014564-00</u>	<u>2</u>		
	EPA	I.D. (TPDES only): TX <u>0127183</u>			
	Exp	iration Date: <u>April 1, 2026</u>			
0	-1		11	_	
Se	ectio	on 3. Facility Owner (App Instructions Page 2		d (	Co-Applicant Information
		(mstructions rage 2	-0)		
A.	The	owner of the facility must apply	for the perm	it.	
	Wha	at is the Legal Name of the entity (a	applicant) app	olyi	ing for this permit?
	Fort Bend County Municipal Utility District No. 162				
	(The legal name must be spelled exactly as filed with the Texas Secretary of State, County, or in the legal documents forming the entity.)				
					, what is the Customer Number (CN)? ttp://www15.tceq.texas.gov/crpub/
	(	CN: <u>CN602863896</u>			
		at is the name and title of the perse cutive official meeting signatory re			pplication? The person must be an $0 \ TAC \ \S \ 305.44$ .
	]	Prefix: <u>Mr.</u> L	ast Name, Firs	st ]	Name: <u>Clayton, Dale</u>

Title: <u>President</u> Credential: Click to enter text.

**B.** Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

n/a

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the *legal documents forming the entity.)* 

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: <a href="http://www15.tceq.texas.gov/crpub/">http://www15.tceq.texas.gov/crpub/</a>

CN: Click to enter text.

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in *30 TAC § 305.44*.

Prefix: Click to enter text. Last Name, First Name: Click to enter text.

Title: Click to enter text. Credential: Click to enter text.

Provide a brief description of the need for a co-permittee: Click to enter text.

#### C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. <u>Attachment No. 3</u>

#### Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Mr. Last Name, First Name: Ahrendsen, Blake

Title: <u>Senior Project Engineer</u> Credential: Click to enter text.

Organization Name: Odyssey Engineering Group, LLC

Mailing Address: <u>2500 Tanglewilde St., Ste. 300</u> City, State, Zip Code: <u>Houston, TX 77063</u>

Phone No.: 281-306-0240 Ext.: 112 E-mail Address: bahrendsen@odysseveg.com

Check one or both: 

Administrative Contact

Technical Contact

**B.** Prefix: Click to enter text. Last Name, First Name: Click to enter text.

Title: Click to enter text. Credential: Click to enter text.

Organization Name: Click to enter text.

Mailing Address: Click to enter text. City, State, Zip Code: Click to enter text.

Phone No.: Click to enter text. E-mail Address: Click to enter text.

Check one or both: 

Administrative Contact 

Technical Contact

#### Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Mr. Last Name, First Name: Ahrendsen, Blake

Title: <u>Sr. Project Engineer</u> Credential: <u>EIT</u> Organization Name: <u>Odyssey Engineering Group, LLC</u>

Mailing Address: <u>2500 Tanglewilde St., Ste 300</u> City, State, Zip Code: <u>Houston, TX, 77063</u>

Phone No.: <u>281-306-0240</u> E-mail Address: <u>bahrendsen@odysseyeg.com</u>

**B.** Prefix: Mrs. Last Name, First Name: Peters, Angela

Title: <u>Municipal Services Group Manager</u> Credential: <u>PE</u>

Organization Name: Odyssey Engineering Group, LLC

Mailing Address: <u>2500 Tanglewilde St., Ste. 300</u> City, State, Zip Code: <u>Houston, TX, 77063</u>

Phone No.: <u>281-306-0240</u> E-mail Address: <u>apeters@odysseyeg.com</u>

#### Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Ms. Last Name, First Name: Mihills, Mary Ann

Title: Consulant Credential: Click to enter text.

Organization Name: Municipal Accounts and Consulting, L.P.

Mailing Address: <u>1281 Brittmoore Road</u> City, State, Zip Code: <u>Houston, TX 77043</u> Phone No.: <u>832-986-6083</u> E-mail Address: <u>mmihills@municipalaccount.com</u>

#### Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Mr. Last Name, First Name: Thornhill, Mike

Title: <u>Director of Compliance</u> Credential: Click to enter text.

Organization Name: Si Environmental

Mailing Address: <u>6420 Reading Rd</u> City, State, Zip Code: <u>Rosenberg, TX</u>

Phone No.: 832-490-1507 E-mail Address: mthornhill@sienviro.com

#### Section 8. Public Notice Information (Instructions Page 27)

#### A. Individual Publishing the Notices

Prefix: Mr. Last Name, First Name: Ahrendsen, Blake

Title: <u>Sr. Project Manager</u> Credential: <u>EIT</u>
Organization Name: <u>Odyssey Engineering Group, LLC</u>

Mailing Address: <u>2500 Tanglewilde St., Ste, 300</u> City, State, Zip Code: <u>Houston, TX, 77063</u>

Phone No.: 281-306-0240 Ext.: 112 E-mail Address: bahrendsen@odysseyeg.com

В.		thod for Receiving Notice of kage	Receipt and Intent to Obtain a Water Quality Permit
	Ind	icate by a check mark the pre	ferred method for receiving the first notice and instructions:
	$\boxtimes$	E-mail Address	
		Fax	
		Regular Mail	
C.	Cor	ntact permit to be listed in th	e Notices
	Pre	fix: <u>Mr.</u>	Last Name, First Name: <u>Ahrendsen, Blake</u>
	Titl	e: <u>Sr. Project Engineer</u>	Credential: <u>EIT</u>
	Org	ganization Name: <u>Odyssey Engi</u>	neering Group, LLC
	Mai	lling Address: 2500 Tanglewild	e City, State, Zip Code: <u>Houston, TX, 77063</u>
	Pho	one No.: <u>281-306-0240</u> Ext.: 112	E-mail Address: <u>bahrendsen@odysseyeg.com</u>
D.	Puk	olic Viewing Information	
	•	he facility or outfall is located inty must be provided.	in more than one county, a public viewing place for each
	Pub	olic building name: <u>George Mer</u>	norial Library
	Loc	ation within the building: <u>Ref</u>	erence Desk
	Phy	rsical Address of Building: <u>100</u>	1 Golfview Drive
	City	y: <u>Richmond</u>	County: Fort Bend County
	Cor	ntact (Last Name, First Name):	Elizabeth Bullard
	Pho	one No.: <u>281-342-4455</u> Ext.: Clic	ek to enter text.
Ε.	Bili	ngual Notice Requirements	
		s information <b>is required</b> for <b>dification, and renewal</b> appli	new, major amendment, minor amendment or minor cations.
	be i		only used to determine if alternative language notices will s on publishing the alternative language notices will be in
	obt	•	dinator at the nearest elementary and middle schools and to determine whether an alternative language notices are
			am required by the Texas Education Code at the elementary ne facility or proposed facility?
		⊠ Yes □ No	
		If <b>no</b> , publication of an altern below.	ative language notice is not required; <b>skip to</b> Section 9
		Are the students who attend a bilingual education progran	either the elementary school or the middle school enrolled in at that school?

□ No

Yes

	3.	Do the location		s at these	schools at	tend a	bilingual	educa	tion pro	gram a	t another
			Yes		No						
	4.			-	uired to pr ement und				_	ogram l	out the school has
			Yes		No						
	5.			, -	uestion 1, e is require						tive language are enter text.
F.	Su	mmary	of Appl	ication in	Plain Lan	guage	Template	<u> </u>			
					of Applicat guage sum						Form 20972), ment.
	At	tachme	nt: <u>16</u>								
G.	Pu	blic Inv	olvemei	nt Plan Fo	orm						
					ment Plan <b>dment to</b> a						plication for a t.
	At	tachme	nt: <u>17</u>								
									- 0		
Se	cti	on 9.	Regi Page		ntity an	ld Per	mitted	Site 1	Inform	ation	(Instructions
Α.			is currer N <u>10444</u>		ated by TC	EQ, pro	ovide the	Regula	ted Enti	ty Num	ber (RN) issued to
			_		egistry at ed by TCEC		<u>www15.t</u>	<u>ceq.tex</u>	as.gov/c	<u>crpub/</u>	to determine if
B.	Na	me of p	roject oi	site (the	name kno	wn by	the comn	nunity v	where lo	cated):	
	Fo	rt Bend (	County M	unicipal U	tility Distri	<u>ct No. 1</u>	62 Wastev	vater Tr	<u>eatment</u>	<u>Plant</u>	
C.	Ov	vner of	treatmer	it facility:	Fort Bend	County	Municipa	l Utility	District 1	No. 162	
	Ov	vnership	of Facil	ity: 🗵	Public		Private		Both		Federal
D.	Ov	vner of l	land whe	ere treatm	ent facility	y is or v	will be:				
	Pre	efix: Clic	ck to ent	er text.	Last	Name,	First Nar	ne:			
	Tit	le: Click	to ente	r text.	Cred	ential:	Click to	enter te	ext.		
	Or	ganizati	ion Nam	e: <u>Fort Be</u>	end Count	<u>y Mun</u>	icipal Uti	ility Di	strict N	<u>0. 162</u>	
		iling Ad 027	ldress: <u>3</u>	<u> 200 South</u>	west Freew	ay, Suit	<u>e 2600</u>	City	, State,	Zip Cod	le: <u>Houston, TX</u>
	Ph	one No.	: <u>713-860</u>	<u>-6400</u>	E-m	ail Ado	dress: <u>n/a</u>				
					same perso l easement		-		or co-a	oplican	t, attach a lease
		Attach	ment: <u>n</u> /	<u>'a</u>							

F.

	Prefix: Click to enter text.	Last Name, First Nan	ne:
	Title: Click to enter text.	Credential: Click to e	enter text.
	Organization Name: Fort Bend	County Municipal Uti	<u>lity District No. 162</u>
	Mailing Address: <u>3200 Southwestext</u> .	st Freeway, Suite 2600	City, State, Zip Code: Click to enter
	Phone No.: <u>713-860-6400</u>	E-mail Address: <u>n/a</u>	
	If the landowner is not the sam agreement or deed recorded ea		owner or co-applicant, attach a lease as.
	Attachment: Click to enter	text.	
F.	Owner sewage sludge disposal property owned or controlled b		requested for sludge disposal on
	Prefix: <u>n/a</u>	Last Name, First Nan	ne: <u>n/a</u>
	Title: <u>n/a</u>	Credential: <u>n/a</u>	
	Organization Name: <u>n/a</u>		
	Mailing Address: <u>n/a</u>	City, State,	, Zip Code: <u>n/a</u>
	Phone No.: <u>n/a</u>	E-mail Address: <u>n/a</u>	<u>.</u>
	If the landowner is not the sam agreement or deed recorded ea		owner or co-applicant, attach a lease as.
	Attachment: Click to enter	text.	
Se	ection 10. TPDES Discha	rge Information (I	nstructions Page 31)
A.	Is the wastewater treatment fac	cility location in the exi	sting permit accurate?
	□ Yes □ No		
	If no, or a new permit applicat		rrate description:
	7102 ½ Koeblen Road, in Fort Be	end County, Texas 77469	
B.	Are the point(s) of discharge ar	nd the discharge route(s	s) in the existing permit correct?
	□ Yes □ No		
			ovide an accurate description of the est classified segment as defined in 30
	Via storm sewer system to Fort B		trict Ditch II-B-7, thence to Big Creek, nt No. 1202 of the Brazos River Basin
	City nearest the outfall(s): Rose	nberg, TX	
	County in which the outfalls(s)	is/are located: Fort Ben	<u>d</u>
C.	Is or will the treated wastewate a flood control district drainage		ounty, or state highway right-of-way, or

**E.** Owner of effluent disposal site:

	□ Yes ⊠ No
	If <b>yes</b> , indicate by a check mark if:
	$\square$ Authorization granted $\square$ Authorization pending
	For <b>new and amendment</b> applications, provide copies of letters that show proof of contact and the approval letter upon receipt.
	Attachment: <u>n/a</u>
D.	For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: $\underline{n/a}$
Se	ection 11. TLAP Disposal Information (Instructions Page 32)
Α.	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?  — Yes — No
	☐ Yes ☐ No  If <b>no, or a new or amendment permit application</b> , provide an accurate description of the
	disposal site location:
	Click to enter text.
B.	City nearest the disposal site: Click to enter text.
	County in which the disposal site is located: Click to enter text.
	For <b>TLAPs</b> , describe the routing of effluent from the treatment facility to the disposal site:
	Click to enter text.
Е.	For <b>TLAPs</b> , please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: Click to enter text.
So	ection 12. Miscellaneous Information (Instructions Page 32)
	Is the facility located on or does the treated effluent cross American Indian Land?
Α.	☐ Yes No
B.	If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?
	□ Yes □ No ⊠ Not Applicable
	If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.
	Click to enter text.

C.	Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?					
	□ Yes ⊠ No					
	If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application: Click to enter text.					
D.	Do you owe any fees to the TCEQ?					
	□ Yes ⊠ No					
	If <b>yes</b> , provide the following information:					
	Account number: Click to enter text.					
	Amount past due: Click to enter text.					
E.	Do you owe any penalties to the TCEQ?					
	□ Yes ⊠ No					
	If <b>yes</b> , please provide the following information:					
	Enforcement order number: Click to enter text.					
	Amount past due: Click to enter text.					
C	ation 12 Attackments (Instructions Dama 22)					
	ection 13. Attachments (Instructions Page 33)					
	ection 13. Attachments (Instructions Page 33) dicate which attachments are included with the Administrative Report. Check all that apply:					
In	dicate which attachments are included with the Administrative Report. Check all that apply:  Lease agreement or deed recorded easement, if the land where the treatment facility is					
Inc	licate which attachments are included with the Administrative Report. Check all that apply:  Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.					
Inc	Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.  Original full-size USGS Topographic Map with the following information:  • Applicant's property boundary  • Treatment facility boundary  • Labeled point of discharge for each discharge point (TPDES only)  • Highlighted discharge route for each discharge point (TPDES only)  • Onsite sewage sludge disposal site (if applicable)  • Effluent disposal site boundaries (TLAP only)  • New and future construction (if applicable)  • 1 mile radius information  • 3 miles downstream information (TPDES only)					

#### Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: WQ0014564002

Applicant: Fort Bend County Municipal Utility District No. 162

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): <u>Dale Clayton</u>
Signatory title: President
Signature:
(Use blue ink)
Subscribed and Sworn to before me by the said Dall Clayton
on this (pth day of tebruary, 2025.
My commission expires on the $45^{+h}$ day of April , 20 74.

**Notary Public** 

County, Texas

WHITNEY MINTER LINGTON
My Notary ID # 133686457
Expires April 6 5 6 6 6 7

## DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

The following information is required for new and amendment applications.

#### Section 1. Affected Landowner Information (Instructions Page 36)

A.	Indicate by a check mark that the landowners map or drawing, with scale, includes the
	following information, as applicable:

- ☐ The facility site boundaries within the applicant's property boundaries
- The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone
- The property boundaries of all landowners surrounding the applicant's property (Note: if the application is a major amendment for a lignite mine, the map must include the property boundaries of all landowners adjacent to the new facility (ponds).)
- The point(s) of discharge and highlighted discharge route(s) clearly shown for one mile downstream
- The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge
- The property boundaries of the landowners along the watercourse for a one-half mile radius from the point of discharge if the point of discharge is into a lake, bay, estuary, or affected by tides
- The boundaries of the effluent disposal site (for example, irrigation area or subsurface drainfield site) and all evaporation/holding ponds within the applicant's property
- ☐ The property boundaries of all landowners surrounding the effluent disposal site
- The boundaries of the sludge land application site (for land application of sewage sludge for beneficial use) and the property boundaries of landowners surrounding the applicant's property boundaries where the sewage sludge land application site is located
- The property boundaries of landowners within one-half mile in all directions from the applicant's property boundaries where the sewage sludge disposal site (for example, sludge surface disposal site or sludge monofill) is located
- **B.** Indicate by a check mark that a separate list with the landowners' names and mailing addresses cross-referenced to the landowner's map has been provided.
- C. ☑ Indicate by a check mark that the landowners list has also been provided as mailing labels in electronic format (Avery 5160).
- D. Provide the source of the landowners' names and mailing addresses: Attachment 12
- **E.** As required by *Texas Water Code § 5.115*, is any permanent school fund land affected by this application?
  - □ Yes ⊠ No

	If <b>ye</b> land	es, provide the location and foreseeable impacts and effects this application has on the (s):			
	Clio	ek to enter text.			
Se	ctio	n 2. Original Photographs (Instructions Page 38)			
Pro	ovide	original ground level photographs. Indicate with checkmarks that the following ation is provided.			
		At least one original photograph of the new or expanded treatment unit location			
		At least two photographs of the existing/proposed point of discharge and as much area downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is to an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.			
	$\boxtimes$	At least one photograph of the existing/proposed effluent disposal site			
		A plot plan or map showing the location and direction of each photograph			
Se	ctio	n 3. Buffer Zone Map (Instructions Page 38)			
A.	A. Buffer zone map. Provide a buffer zone map on $8.5 \times 11$ -inch paper with all of the following information. The applicant's property line and the buffer zone line may be distinguished to using dashes or symbols and appropriate labels.				
	•	The required buffer zone; and Each treatment unit; and			
В.		er zone compliance method. Indicate how the buffer zone requirements will be met. ck all that apply.			
		☑ Ownership			
		Restrictive easement			
		Nuisance odor control			
		] Variance			
C.		uitable site characteristics. Does the facility comply with the requirements regarding nitable site characteristic found in 30 TAC § 309.13(a) through (d)?			
		☑ Yes □ No			

# DOMESTIC WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: 11

## DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

application until the items below have been addressed.					
Core Data Form (TCEQ Form No. 10400) (Required for all application types. Must be completed in its entirety a Note: Form may be signed by applicant representative.)	nd s	igned.		Yes	
Correct and Current Industrial Wastewater Permit Application Forms (TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018 or later			$\boxtimes$	Yes	
Water Quality Permit Payment Submittal Form (Page 19) (Original payment sent to TCEQ Revenue Section. See instructions for	mai	ling ad	□ dress	Yes	
7.5 Minute USGS Quadrangle Topographic Map Attached (Full-size map if seeking "New" permit. 8½ x 11 acceptable for Renewals and Amendments)				Yes	
Current/Non-Expired, Executed Lease Agreement or Easement	$\boxtimes$	N/A		Yes	
Landowners Map (See instructions for landowner requirements)					
<ul> <li>Things to Know:</li> <li>All the items shown on the map must be labeled.</li> <li>The applicant's complete property boundaries must be del boundaries of contiguous property owned by the applicant.</li> <li>The applicant cannot be its own adjacent landowner. You is landowners immediately adjacent to their property, regard from the actual facility.</li> <li>If the applicant's property is adjacent to a road, creek, or so on the opposite side must be identified. Although the propapplicant's property boundary, they are considered potent If the adjacent road is a divided highway as identified on the map, the applicant does not have to identify the landowner the highway.</li> </ul>	t. mus lless trea erti ially he U	t identi of how m, the es are i affecto	fy they far in lander and the lander and the lander and	e they are owners djacent to ndowners. aphic	
Landowners Labels and Cross Reference List (See instructions for landowner requirements)		N/A		Yes	
Electronic Application Submittal (See application submittal requirements on page 23 of the instructions.)					
Original signature per 30 TAC § 305.44 - Blue Ink Preferred					

a copy of signature authority/delegation letter must be attached)

Summary of Application (in Plain Language)

(If signature page is not signed by an elected official or principle executive officer,

Yes



### FORT BEND COUNTY MUD NO. 162 WWTP DISCHARGE PERMIT MAJOR AMENDMENT PERMIT NO. WQ0014564002

ATTACHMENT 2

Technical Report

# THI THOUNDENTAL OUT IN

#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

#### DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

#### Section 1. Permitted or Proposed Flows (Instructions Page 42)

#### A. Existing/Interim I Phase

Design Flow (MGD): <u>0.35</u> 2-Hr Peak Flow (MGD): 1.4

Estimated construction start date: <u>Complete</u> Estimated waste disposal start date: <u>Current</u>

#### **B.** Interim II Phase

Design Flow (MGD):

2-Hr Peak Flow (MGD):

Estimated construction start date: <u>Click to enter text.</u> Estimated waste disposal start date: <u>Click to enter text.</u>

#### C. Final Phase

Design Flow (MGD): <u>0.45</u> 2-Hr Peak Flow (MGD): 1.8

Estimated construction start date: Future, already permitted

Estimated waste disposal start date: no waste disposal with permit

#### D. Current Operating Phase

Provide the startup date of the facility: 2024

#### Section 2. Treatment Process (Instructions Page 42)

#### A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. **If more than one phase exists or is proposed, a description of** *each phase* **must be provided**.

Existing Plant: Activated Sludge with nitrification. Treatment order is: manual bar screen, seven aeration basins, four final clarifiers, four aerobic digesters, and four chlorine contact chamber. Sludge is processed through a sludge digester before being hauled by a truck to another WWTP. Final Phase: Will act in a similar fashion as the existing plant only with additional tanks acting in parallel after a new mechanical bar screen and splitter box (replacing the existing bar screen and splitter box)

#### **B.** Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

#### Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)		
Mechanical Bar Screen	1	See Process Flow Diagram		
Aeration Basin	7	(attachment No. 6)		
Final Clarifier	4			
Aerobic Digester	4			
Chlorine Contact Chamber	4			

#### C. Process Flow Diagram

Provide flow diagrams for the existing facilities and each proposed phase of construction.

Attachment: Attachment No. 6

#### Section 3. Site Information and Drawing (Instructions Page 43)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

• Latitude: <u>29°30'5.5" N</u>

• Longitude: <u>95°45'32" W</u>

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

• Latitude: <u>N/A</u>

• Longitude: Click to enter text.

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment: Attachment No. 7

Fort Bend County MUD No		<u>,                                      </u>	
Collection System Informate each uniquely owned collesatellite collection systems. examples.	ction system, existi Please see the ins	ng and new, served by th	nis facility, including
Collection System Informatic	Owner Name	Owner Type	Population Served
FBC MUD 162 WWTP 1 Collection System	FBC MUD 162	Publicly Owned	1460 ESFC
,		Choose an item.	
		Choose an item.	
		Choose an item.	
Is the application for a rene  ☐ Yes ☒ No  If yes, does the existing peryears of being authorized by Yes ☐ No	rmit contain a phas by the TCEQ?	e that has not been cons	tructed <b>within five</b>
If yes, provide a detailed de Failure to provide sufficient recommending denial of the	nt justification may	result in the Executive	-
Click to enter text.			

# Section 5. Closure Plans (Instructions Page 44)

Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?

	□ Yes ⊠ No
If y	yes, was a closure plan submitted to the TCEQ?
	□ Yes □ No
If y	yes, provide a brief description of the closure and the date of plan approval.
n/	/a
Se	ection 6. Permit Specific Requirements (Instructions Page 44)
	r applicants with an existing permit, check the Other Requirements or Special ovisions of the permit.
A.	Summary transmittal
	Have plans and specifications been approved for the existing facilities and each proposed phase?
	✓ Yes ✓ No
	If yes, provide the date(s) of approval for each phase: Nov. 3, 2021 & Sept. 9, 2020
	Provide information, including dates, on any actions taken to meet a <i>requirement or provision</i> pertaining to the submission of a summary transmittal letter. <b>Provide a copy of</b> an approval letter from the TCEQ, if applicable.
	A Summary transmittal letter has been submitted and is under review by
	Please see attachments 9 and 10
В.	Buffer zones
	Have the buffer zone requirements been met?
	⊠ Yes □ No
	Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.
	Attachment 5

	su	bes the Other Requirements or Special Provisions section in the existing permit require bimission of any other information or other required actions? Examples include stification of Completion, progress reports, soil monitoring data, etc.
	110	☐ Yes ⊠ No
		yes, provide information below on the status of any actions taken to meet the nditions of an <i>Other Requirement</i> or <i>Special Provision</i> .
	C	lick to enter text.
D.	Gr	it and grease treatment
	1.	Acceptance of grit and grease waste
		Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?
		□ Yes ⊠ No
		If No, stop here and continue with Subsection E. Stormwater Management.
	2.	Grit and grease processing
		Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment works and how it is separated or processed. Provide a flow diagram showing how grit and grease is processed at the facility.
		Click to enter text.
	3.	Grit disposal
		Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?
		□ Yes □ No
		If No, contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.

C. Other actions required by the current permit

		Describe the method of grit disposal.
		Click to enter text.
	4.	Grease and decanted liquid disposal
		Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.
		Describe how the decant and grease are treated and disposed of after grit separation.
		Click to enter text.
E.	Sto	ormwater management
	1.	Applicability
		Does the facility have a design flow of 1.0 MGD or greater in any phase?
		□ Yes ⊠ No
		Does the facility have an approved pretreatment program, under 40 CFR Part 403?
		□ Yes ⊠ No
		If no to both of the above, then skip to Subsection F, Other Wastes Received.
	2.	MSGP coverage
		Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?
		□ Yes □ No
		<b>If yes</b> , please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:
		TXR05 Click to enter text. or TXRNE Click to enter text.
		If no, do you intend to seek coverage under TXR050000?
		□ Yes □ No
	3.	Conditional exclusion
		Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?
		□ Yes □ No

	If yes, please explain below then proceed to Subsection F, Other Wastes Received:
	Click to enter text.
4.	Existing coverage in individual permit
	Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?
	□ Yes □ No
	<b>If yes</b> , provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.
	Click to enter text.
5.	Zero stormwater discharge
	Do you intend to have no discharge of stormwater via use of evaporation or other means?
	□ Yes □ No
	If yes, explain below then skip to Subsection F. Other Wastes Received.
	Click to enter text.
	Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.
6.	Request for coverage in individual permit
	Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?
	□ Yes □ No
	If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you

		intend to divert stormwater to the treatment plant headworks and indirectly discharge it to water in the state.
		Click to enter text.
		Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.
F.	Dis	scharges to the Lake Houston Watershed
	Do	es the facility discharge in the Lake Houston watershed?
		□ Yes ⊠ No
	_	ves, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions. ck to enter text.
G.	Ot	her wastes received including sludge from other WWTPs and septic waste
	1.	Acceptance of sludge from other WWTPs
		Does or will the facility accept sludge from other treatment plants at the facility site?
		□ Yes ⊠ No
		If yes, attach sewage sludge solids management plan. See Example 5 of instructions.
		In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an estimate of the $BOD_5$ concentration of the sludge, and the design $BOD_5$ concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
		Click to enter text.
		Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
	2.	Acceptance of septic waste
		Is the facility accepting or will it accept septic waste?
		□ Yes ⊠ No
		<b>If ves.</b> does the facility have a Type V processing unit?

If yes, does the unit have a Municipal Solid Waste permit?

Yes 🖂

No

□ Yes ⊠ No
If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD <sub>5</sub> concentration of the septic waste, and the
design BOD <sub>5</sub> concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
Click to enter text.
Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
<ol> <li>Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)</li> </ol>
Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?
□ Yes ⊠ No
If yes, provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or other physical characteristic of the waste. Also note if this information has or has not changed since the last permit action.
Click to enter text.
Section 7. Pollutant Analysis of Treated Effluent (Instructions Page 49)
Is the facility in operation?
⊠ Yes □ No
If no, this section is not applicable. Proceed to Section 8.

If yes, provide effluent analysis data for the listed pollutants. Wastewater treatment *facilities* complete Table 1.0(2). *Water treatment facilities* discharging filter backwash water, complete Table 1.0(3). Provide copies of the laboratory results sheets. **These tables are not** applicable for a minor amendment without renewal. See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD <sub>5</sub> , mg/l					
Total Suspended Solids, mg/l					
Ammonia Nitrogen, mg/l			eing sent wi		
Nitrate Nitrogen, mg/l			e permitting		
Total Kjeldahl Nitrogen, mg/l	•		samples ha ce complete		rdered and
Sulfate, mg/l		orrinted orr		.a.	
Chloride, mg/l					
Total Phosphorus, mg/l					
pH, standard units					
Dissolved Oxygen*, mg/l					
Chlorine Residual, mg/l					
E.coli (CFU/100ml) freshwater					
Entercocci (CFU/100ml) saltwater					
Total Dissolved Solids, mg/l					
Electrical Conductivity, µmohs/cm, †					
Oil & Grease, mg/l					
Alkalinity (CaCO <sub>3</sub> )*, mg/l	_				

<sup>\*</sup>TPDES permits only

Table1.0(3) – Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l					
Total Dissolved Solids, mg/l					
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO <sub>3</sub> ), mg/l					

# Section 8. Facility Operator (Instructions Page 49)

Facility Operator Name: Chris Manthei

Facility Operator's License Classification and Level: Wastewater, B

Facility Operator's License Number: WW0018752

<sup>†</sup>TLAP permits only

# Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 50)

A.	ww	TP's Sewage Sludge or Biosolids Management Facility Type			
	Check all that apply. See instructions for guidance				
		Design flow>= 1 MGD			
		Serves >= 10,000 people			
		Class I Sludge Management Facility (per 40 CFR § 503.9)			
		Biosolids generator			
		Biosolids end user – land application (onsite)			
		Biosolids end user – surface disposal (onsite)			
		Biosolids end user – incinerator (onsite)			
B.	ww	TP's Sewage Sludge or Biosolids Treatment Process			
	Che	ck all that apply. See instructions for guidance.			
	$\boxtimes$	Aerobic Digestion			
		Air Drying (or sludge drying beds)			
		Lower Temperature Composting			
		Lime Stabilization			
		Higher Temperature Composting			
		Heat Drying			
		Thermophilic Aerobic Digestion			
		Beta Ray Irradiation			
		Gamma Ray Irradiation			
		Pasteurization			
		Preliminary Operation (e.g. grinding, de-gritting, blending)			
		Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)			
		Sludge Lagoon			
		Temporary Storage (< 2 years)			
		Long Term Storage (>= 2 years)			
		Methane or Biogas Recovery			
	$\boxtimes$	Other Treatment Process: <u>Transport to another WWTP</u>			

# C. Sewage Sludge or Biosolids Management

Provide information on the *intended* sewage sludge or biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the

permit will authorize all sewage sludge or biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

### **Biosolids Management**

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Other	Off-site Third-Party Handler or Preparer	Not Applicable		N/A: Transported to another facility for further processing	N/A: Trasporrted to another facility for further processing
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.

If "Other" is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): <u>Transport to another WWTP</u>. See attachment 15

## D. Disposal site

Disposal site name: <u>City of Rosenberg STP #2</u>

TCEQ permit or registration number: <u>wqoo10607-002</u> County where disposal site is located: <u>Fort Bend County</u>

## E. Transportation method

Method of transportation (truck, train, pipe, other): <u>truck</u>

Name of the hauler: Magna Flow Environmental

Hauler registration number: <u>21484</u>

Sludge is transported as a:

Liquid □	semi-liquid ⊠	semi-solid □	solid □
Liquiu 🗆	ociiii iiquiu	ociiii oona 🗀	Jona L

# Section 10. Permit Authorization for Sewage Sludge Disposal (Instructions Page 52)

### A. Beneficial use authorization

Does the existing permit include authorization for land application of biosolids for beneficial use?

□ Yes ⊠ No

**If yes**, are you requesting to continue this authorization to land apply biosolids for beneficial use?

□ Yes ⊠ No

		Form No.						l <b>Use of Sewage Sludge</b> e instructions for	
		Yes $\square$	No						
B.	Sludge	processii	ng authorization	n					
		-	g permit include sal options?	authorization f	for any	y of the	follow	ving sludge processing,	
	Sluc	dge Comp	osting			Yes	$\boxtimes$	No	
	Mar	keting an	d Distribution o	f Biosolids		Yes		No	
	Sluc	dge Surfac	e Disposal or Sl	udge Monofill		Yes		No	
	Ten	nporary st	orage in sludge	lagoons		Yes		No	
	authori	ization, is	the completed		ewate	r Permi	t Appl	esting to continue this lication: Sewage Sludge application?	•
Se	ection	11. Sev	vage Sludge	Lagoons (In	stru	ctions	Page	e 53)	
			lude sewage slu					,	•
	□ Ye	s 🗵 No	)						
If	yes, com	plete the	remainder of th	is section. If no	, proc	eed to S	ection	12.	
Α.	Locatio	on inform	ation						
			aps are required chment Number		d as p	art of tl	ne app	lication. For each map,	
	•	Original G	eneral Highway	(County) Map:					
			nt: <u>Click to ente</u>						
				Conservation Se	ervice S	Soil Mar	):		
			<b>nt</b> : <u>Click to ente</u>						
			nergency Manag						
			<b>nt</b> : <u>Click to ente</u>	r text.					
		Site map:	01. 1						
			nt: Click to ente			201.2.01	1		
	apply.	s in a desc	eription if any of	the following e	exist w	vithin tr	ie lago	oon area. Check all that	
		Overlap a	a designated 10	0-year frequency	y floo	d plain			
		Soils with	n flooding classi	fication					
		Overlap a	an unstable area	ι					
		Wetlands	<b>,</b>						

	Located less than 60 meters from a fault					
	None of the above					
At	tachment: Click to enter text.					
	If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide the protective measures to be utilized including type and size of protective structures:					
Click	to enter text.					

## **B.** Temporary storage information

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in *Section 7 of Technical Report 1.0.* 

Nitrate Nitrogen, mg/kg: Click to enter text.

Total Kjeldahl Nitrogen, mg/kg: Click to enter text.

Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: Click to enter text.

Phosphorus, mg/kg: <u>Click to enter text.</u>

Potassium, mg/kg: <u>Click to enter text.</u> pH, standard units: Click to enter text.

Ammonia Nitrogen mg/kg: Click to enter text.

Arsenic: Click to enter text.

Cadmium: Click to enter text.

Chromium: Click to enter text.

Copper: Click to enter text.

Lead: Click to enter text.

Mercury: Click to enter text.

Molybdenum: Click to enter text.

Nickel: Click to enter text.

Selenium: <u>Click to enter text.</u>

Zinc: Click to enter text.

Total PCBs: <u>Click to enter text.</u> Provide the following information:

Volume and frequency of sludge to the lagoon(s): <u>Click to enter text.</u>

Total dry tons stored in the lagoons(s) per 365-day period: Click to enter text.

Total dry tons stored in the lagoons(s) over the life of the unit: Click to enter text.

### C. Liner information

Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of  $1x10^{-7}$  cm/sec?

		Yes □ No
	If yes	, describe the liner below. Please note that a liner is required.
	Click	to enter text.
D.	Site d	evelopment plan
	Provid	le a detailed description of the methods used to deposit sludge in the lagoon(s):
	Click	to enter text.
	Attac	n the following documents to the application.
	•	Plan view and cross-section of the sludge lagoon(s)
		Attachment: Click to enter text.
	•	Copy of the closure plan
		Attachment: Click to enter text.
	•	Copy of deed recordation for the site
		Attachment: Click to enter text.
	•	Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons
		Attachment: Click to enter text.
	•	Description of the method of controlling infiltration of groundwater and surface water from entering the site
		Attachment: Click to enter text.
	•	Procedures to prevent the occurrence of nuisance conditions
		Attachment: Click to enter text.
E.	Groui	ndwater monitoring
	groun	undwater monitoring currently conducted at this site, or are any wells available for adwater monitoring, or are groundwater monitoring data otherwise available for the e lagoon(s)?
		Yes □ No
	types	undwater monitoring data are available, provide a copy. Provide a profile of soil encountered down to the groundwater table and the depth to the shallowest dwater as a separate attachment.

 $\label{thm:condition} \mbox{TCEQ-10054 (10/17/2024) Domestic Wastewater Permit Application Technical Report}$ 

Attachment: Click to enter text.

# Section 12. Authorizations/Compliance/Enforcement (Instructions Page 54)

9
A. Additional authorizations
Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?
□ Yes ⊠ No
If yes, provide the TCEQ authorization number and description of the authorization:
Click to enter text.
B. Permittee enforcement status
Is the permittee currently under enforcement for this facility?
□ Yes ⊠ No
Is the permittee required to meet an implementation schedule for compliance or enforcement?
□ Yes ⊠ No
<b>If yes</b> to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:
Click to enter text.
Section 13. RCRA/CERCLA Wastes (Instructions Page 55)

## A. RCRA hazardous wastes

Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

Yes	$\boxtimes$	No

## B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

□ Yes ⊠ No

## C. Details about wastes received

**If yes** to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: Click to enter text.

# Section 14. Laboratory Accreditation (Instructions Page 55)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25*, *Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
  - o periodically inspected by the TCEQ; or
  - o located in another state and is accredited or inspected by that state; or
  - o performing work for another company with a unit located in the same site; or
  - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

### **CERTIFICATION:**

Date: \_\_\_\_\_

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Title:	Click to enter text.
Signature:	

Printed Name: Click to enter text.

# DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.1

The following information is required for new and amendment major applications.

# Section 1. Justification for Permit (Instructions Page 56)

## A. Justification of permit need

Provide a detailed discussion regarding the need for any phase(s) not currently permitted. Failure to provide sufficient justification may result in the Executive Director recommending denial of the proposed phase(s) or permit.

TCEQ failed to update the EPA when updating the expiration date of the active water quality
permit number WQ0014564001, which allowed the existing permit to expire in the EPA ICIS
database 594 days prior to the expiration date on the signed permit without any notification
to the District. Upon discovery, the TCEQ has required the District to submit a new permit.

## B. Regionalization of facilities

For additional guidance, please review <u>TCEO's Regionalization Policy for Wastewater Treatment</u><sup>1</sup>.

Provide the following information concerning the potential for regionalization of domestic wastewater treatment facilities:

### 1. Municipally incorporated areas

If the applicant is a city, then Item 1 is not applicable. Proceed to Item 2 Utility CCN areas.

Is any	portio	n of	the prop	osed	service area located in an incorporated city?
	Yes	$\boxtimes$	No		Not Applicable
If yes,	within	the	city limi	ts of:	Click to enter text.

If yes, attach correspondence from the city.

Attachment: Click to enter text.

If consent to provide service is available from the city, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the city versus the cost of the proposed facility or expansion attached.

Attachment: Click to enter text.

## 2. Utility CCN areas

Is any portion of the proposed service area located inside another utility's CCN area?

□ Yes ⊠ No

<sup>&</sup>lt;sup>1</sup> https://www.tceq.texas.gov/permitting/wastewater/tceq-regionalization-for-wastewater

If yes, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the CCN facilities versus the cost of the proposed facility or expansion. Attachment: Click to enter text. 3. Nearby WWTPs or collection systems Are there any domestic permitted wastewater treatment facilities or collection systems located within a three-mile radius of the proposed facility?  $\boxtimes$ Yes No If ves. attach a list of these facilities and collection systems that includes each permittee's name and permit number, and an area map showing the location of these facilities and collection systems. Attachment: n/a not a proposed facility If yes, attach proof of mailing a request for service to each facility and collection system, the letters requesting service, and correspondence from each facility and collection system. Attachment: Click to enter text. If the facility or collection system agrees to provide service, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the facility or collection system versus the cost of the proposed facility or expansion. **Attachment:** n/a **Proposed Organic Loading (Instructions Page 58)** Yes □ No

Section 2.

Is this facility	in operation?		

**If no**, proceed to Item B, Proposed Organic Loading.

If ves, provide organic loading information in Item A, Current Organic Loading

# A. Current organic loading

Facility Design Flow (flow being requested in application): 0.35

Average Influent Organic Strength or BOD<sub>5</sub> Concentration in mg/l: <u>316</u>

Average Influent Loading (lbs/day = total average flow X average BOD<sub>5</sub> conc. X 8.34): 92.2

Provide the source of the average organic strength or BOD<sub>5</sub> concentration.

Operator provided influent sample		

## B. Proposed organic loading

This table must be completed if this application is for a facility that is not in operation or if this application is to request an increased flow that will impact organic loading.

Table 1.1(1) - Design Organic Loading

Source	Total Average Flow (MGD)	Influent BOD5 Concentration (mg/l)
Municipality		
Subdivision		
Trailer park - transient		
Mobile home park		
School with cafeteria and showers		
School with cafeteria, no showers		
Recreational park, overnight use		
Recreational park, day use		
Office building or factory		
Motel		
Restaurant		
Hospital		
Nursing home		
Other		
TOTAL FLOW from all sources		
AVERAGE BOD <sub>5</sub> from all sources		

# Section 3. Proposed Effluent Quality and Disinfection (Instructions Page 58)

## A. Existing/Interim I Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l: 10

Total Suspended Solids, mg/l: 15

Ammonia Nitrogen, mg/l: 3

Total Phosphorus, mg/l: Click to enter text.

Dissolved Oxygen, mg/l: <u>6.0</u>

Other: Click to enter text.

B.	Interim II Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: <u>10</u>
	Total Suspended Solids, mg/l: <u>15</u>
	Ammonia Nitrogen, mg/l: 3
	Total Phosphorus, mg/l: Click to enter text.
	Dissolved Oxygen, mg/l: <u>6.0</u>
	Other: Click to enter text.
C.	Final Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: <u>10</u>
	Total Suspended Solids, mg/l: <u>15</u>
	Ammonia Nitrogen, mg/l: <u>3</u>
	Total Phosphorus, mg/l: Click to enter text.
	Dissolved Oxygen, mg/l: <u>6</u>
	Other: Click to enter text.
D.	Disinfection Method
	Identify the proposed method of disinfection.
	Chlorine: Click to enter text. mg/l after Click to enter text. minutes detention time at peak flow
	Dechlorination process: Click to enter text.
	☐ Ultraviolet Light: <u>Click to enter text.</u> seconds contact time at peak flow
	☑ Other: <u>Liquid Bleach</u>
So	ection 4. Design Calculations (Instructions Page 58)
	tach design calculations and plant features for each proposed phase. Example 4 of the structions includes sample design calculations and plant features.
	Attachment: Click to enter text.
Se	ection 5. Facility Site (Instructions Page 59)
A.	100-year floodplain
	Will the proposed facilities be located <u>above</u> the 100-year frequency flood level?
	Yes □ No
	<b>If no</b> , describe measures used to protect the facility during a flood event. Include a site map showing the location of the treatment plant within the 100-year frequency flood level. If applicable, provide the size and types of protective structures.
	Click to enter text.

	Provide the source(s) used to determine 100-year frequency flood plain.
	Click to enter text.
	For a new or expansion of a facility, will a wetland or part of a wetland be filled?
	□ Yes □ No
	If yes, has the applicant applied for a US Corps of Engineers 404 Dredge and Fill Permit?
	☐ Yes ☐ No
	If yes, provide the permit number: <u>Click to enter text.</u>
	<b>If no,</b> provide the approximate date you anticipate submitting your application to the Corps: Click to enter text.
B.	Wind rose
	Attach a wind rose: <u>Click to enter text.</u>
Se	ection 6. Permit Authorization for Sewage Sludge Disposal (Instructions Page 59)
	(mstructions rage 33)
Α.	Beneficial use authorization
	Are you requesting to include authorization to land apply sewage sludge for beneficial use on property located adjacent to the wastewater treatment facility under the wastewater permit?
	□ Yes □ No
	If yes, attach the completed <b>Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451)</b> : <u>Click to enter text.</u>
B.	Sludge processing authorization
	Identify the sludge processing, storage or disposal options that will be conducted at the wastewater treatment facility:
	□ Sludge Composting
	□ Marketing and Distribution of sludge
	□ Sludge Surface Disposal or Sludge Monofill
	If any of the above, sludge options are selected, attach the completed <b>Domestic</b> Wastewater Permit Application: Sewage Sludge Technical Report (TCEQ Form No. 10056): Click to enter text.
Se	ection 7. Sewage Sludge Solids Management Plan (Instructions Page
	60)

Attach a solids management plan to the application.

Attachment: Click to enter text.

The sewage sludge solids management plan must contain the following information:

Treatment units and processes dimensions and capacities

- Solids generated at 100, 75, 50, and 25 percent of design flow
- Mixed liquor suspended solids operating range at design and projected actual flow
- Quantity of solids to be removed and a schedule for solids removal
- Identification and ownership of the ultimate sludge disposal site
- For facultative lagoons, design life calculations, monitoring well locations and depths, and the ultimate disposal method for the sludge from the facultative lagoon

An example of a sewage sludge solids management plan has been included as Example 5 of the instructions.

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

Section 1. Domestic Drinking Water Supply (Instructions Page 63)
Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?
□ Yes ⊠ No
If <b>no</b> , proceed it Section 2. <b>If yes</b> , provide the following:
Owner of the drinking water supply: Click to enter text.
Distance and direction to the intake: <u>Click to enter text.</u>
Attach a USGS map that identifies the location of the intake.
Attachment: Click to enter text.
Section 2. Discharge into Tidally Affected Waters (Instructions Page 63)
Does the facility discharge into tidally affected waters?
□ Yes ⊠ No
If <b>no</b> , proceed to Section 3. <b>If yes</b> , complete the remainder of this section. If no, proceed to Section 3.
A. Receiving water outfall
Width of the receiving water at the outfall, in feet: Click to enter text.
B. Oyster waters
Are there oyster waters in the vicinity of the discharge?
□ Yes □ No
If yes, provide the distance and direction from outfall(s).
Click to enter text.
C. Sea grasses
Are there any sea grasses within the vicinity of the point of discharge?
□ Yes ⊠ No
If yes, provide the distance and direction from the outfall(s).
Click to enter text.

## Section 3. **Classified Segments (Instructions Page 63)** Is the discharge directly into (or within 300 feet of) a classified segment? Yes ⊠ No If yes, this Worksheet is complete. **If no**, complete Sections 4 and 5 of this Worksheet. Section 4. **Description of Immediate Receiving Waters (Instructions Page 63)** Name of the immediate receiving waters: Fort Bend 162 Stormwater pipe A. Receiving water type Identify the appropriate description of the receiving waters. Stream Freshwater Swamp or Marsh П Lake or Pond Surface area, in acres: Click to enter text. Average depth of the entire water body, in feet: Click to enter text. Average depth of water body within a 500-foot radius of discharge point, in feet: Click to enter text. Man-made Channel or Ditch Open Bay Tidal Stream, Bayou, or Marsh Other, specify: Stormwater Pipe **B.** Flow characteristics If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area *upstream* of the discharge. For new discharges, characterize the area downstream of the discharge (check one). Intermittent - dry for at least one week during most years Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses Perennial - normally flowing Check the method used to characterize the area upstream (or downstream for new dischargers). USGS flow records Historical observation by adjacent landowners $\boxtimes$ Personal observation Other, specify: Click to enter text.

C.	Downstream perennial confluences							
List the names of all perennial streams that join the receiving water within three n downstream of the discharge point.								
	none							
D.	Downs	stream characteristics						
		receiving water characteristics char rge (e.g., natural or man-made dams		rithin three miles downstream of the ids, reservoirs, etc.)?				
	$\boxtimes$	Yes □ No						
	If yes,	discuss how.						
		ximately 0.8 miles downstream of the d man-made ditch	ischa	rge path, the stormwater pipe discharges				
E.	Norma	l dry weather characteristics						
	Provide general observations of the water body during normal dry weather conditions.							
	An empty stormwater pipe							
	Date and time of observation: <u>02/24/2025 10:00am</u>							
	Was th	e water body influenced by stormwa	ater r	runoff during observations?				
		Yes ⊠ No						
Se	ction	5. General Characteristics	s of	the Waterbody (Instructions				
		Page 65)						
A.	Upstre	am influences						
		mmediate receiving water upstream aced by any of the following? Check		ne discharge or proposed discharge site nat apply.				
		Oil field activities		Urban runoff				
		Upstream discharges		Agricultural runoff				
		Septic tanks		Other(s), specify: Click to enter text.				

### **B.** Waterbody uses Observed or evidences of the following uses. Check all that apply. Livestock watering Contact recreation Irrigation withdrawal Non-contact recreation **Fishing** Navigation Domestic water supply Industrial water supply Other(s), specify: Stormwater Park activities $\boxtimes$ C. Waterbody aesthetics Check one of the following that best describes the aesthetics of the receiving water and the surrounding area. Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional Natural Area: trees and/or native vegetation; some development evident (from fields, pastures, dwellings); water clarity discolored $\boxtimes$ Common Setting: not offensive; developed but uncluttered; water may be colored or turbid Offensive: stream does not enhance aesthetics; cluttered; highly developed;

dumping areas; water discolored

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.1: STREAM PHYSICAL CHARACTERISTICS

Required for new applications, major facilities, and applications adding an outfall.

Worksheet 2.1 is not required for discharges to intermittent streams or discharges directly to (or within 300 feet of) a classified segment.

Section 1. General Information (Instructions Page 65)						
Date of study: n/a Intermittent Stream Time of study: Click to enter text.						
Stream name: <u>Click to enter text.</u>						
Location: Click to enter text.						
Type of stream upstream of existing discharge or downstream of proposed discharge (check one).						
$\square$ Perennial $\square$ Intermittent with perennial pools						
Section 2. Data Collection (Instructions Page 65)						
Number of stream bends that are well defined: Click to enter text.						
Number of stream bends that are moderately defined: Click to enter text.						
Number of stream bends that are poorly defined: Click to enter text.						
Number of riffles: Click to enter text.						
Evidence of flow fluctuations (check one):						
□ Minor □ moderate □ severe						
Indicate the observed stream uses and if there is evidence of flow fluctuations or channel obstruction/modification.						
Click to enter text.						

### Stream transects

In the table below, provide the following information for each transect downstream of the existing or proposed discharges. Use a separate row for each transect.

Table 2.1(1) - Stream Transect Records

Stream type at transect	Transect location	Water surface	Stream depths (ft) at 4 to 10 points along each
Select riffle, run, glide, or pool. See Instructions, Definitions section.		width (ft)	transect from the channel bed to the water surface. Separate the measurements with commas.
Choose an item.			

# Section 3. Summarize Measurements (Instructions Page 65)

Streambed slope of entire reach, from USGS map in feet/feet: Click to enter text.

Approximate drainage area above the most downstream transect (from USGS map or county highway map, in square miles): <u>Click to enter text.</u>

Length of stream evaluated, in feet: Click to enter text.

Number of lateral transects made: <u>Click to enter text.</u>

Average stream width, in feet: <u>Click to enter text</u>. Average stream depth, in feet: <u>Click to enter text</u>.

Average stream velocity, in feet/second: Click to enter text.

Instantaneous stream flow, in cubic feet/second: Click to enter text.

Indicate flow measurement method (type of meter, floating chip timed over a fixed distance, etc.): Click to enter text.

Size of pools (large, small, moderate, none): Click to enter text.

Maximum pool depth, in feet: Click to enter text.

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.0: LAND DISPOSAL OF EFFLUENT

The following is required for renewal, new, and amendment permit applications.

# Section 1. Type of Disposal System (Instructions Page 67)

Identif	y the method of land disposal:	
	Surface application	Subsurface application
	Irrigation	Subsurface soils absorption
	Drip irrigation system	Subsurface area drip dispersal system
	Evaporation	Evapotranspiration beds
	Other (describe in detail): $\underline{n/a}$	
	All applicants without authoriz complete and submit Worksheet	or proposing new/amended subsurface disposal

# Section 2. Land Application Site(s) (Instructions Page 67)

For existing authorizations, provide Registration Number: Click to enter text.

In table 3.0(1), provide the requested information for the land application sites. Include the agricultural or cover crop type (wheat, cotton, alfalfa, bermuda grass, native grasses, etc.), land use (golf course, hayland, pastureland, park, row crop, etc.), irrigation area, amount of effluent applied, and whether or not the public has access to the area. Specify the amount of land area and the amount of effluent that will be allotted to each agricultural or cover crop, if more than one crop will be used.

### Table 3.0(1) - Land Application Site Crops

Crop Type & Land Use	Irrigation Area (acres)	Effluent Application (GPD)	Public Access? Y/N
n/a			

# Section 3. **Storage and Evaporation Lagoons/Ponds (Instructions Page**

## Table 3.0(2) – Storage and Evaporation Ponds

Pond Number	Surface Area (acres)	Storage Volume (acre-feet)	Dimensions	Liner Type
n/a				

licensed professional engineer for each pond.					
Attachment: Click to enter text.					
Section 4. Flood and Runoff Protection (Instructions Page 67)					
Is the land application site <u>within</u> the 100-year frequency flood level?					
□ Yes ⊠ No					
If yes, describe how the site will be protected from inundation.					
Click to enter text.					
Provide the source used to determine the 100-year frequency flood level:					
Click to enter text.					
Provide a description of tailwater controls and rainfall run-on controls used for the land application site.					
Click to enter text.					

# Section 5. Annual Cropping Plan (Instructions Page 67)

Attach an Annual Cropping Plan which includes a discussion of each of the following items. If not applicable, provide a detailed explanation indicating why. **Attachment**: n/a

- Soils map with crops
- Cool and warm season plant species
- Crop yield goals
- Crop growing season
- Crop nutrient requirements
- Additional fertilizer requirements
- Minimum/maximum harvest height (for grass crops)
- Supplemental watering requirements
- Crop salt tolerances
- Harvesting method/number of harvests
- Justification for not removing existing vegetation to be irrigated

# Section 6. Well and Map Information (Instructions Page 68)

Attach a USGS map with the following information shown and labeled. If not applicable, provide a detailed explanation indicating why. **Attachment**: n/a

- The boundaries of the land application site(s)
- Waste disposal or treatment facility site(s)
- On-site buildings
- Buffer zones
- Effluent storage and tailwater control facilities
- All water wells within 1-mile radius of the disposal site or property boundaries
- All springs and seeps onsite and within 500 feet of the property boundaries
- All surface waters in the state onsite and within 500 feet of the property boundaries
- All faults and sinkholes onsite and within 500 feet of the property

List and cross reference all water wells located within a half-mile radius of the disposal site or property boundaries shown on the USGS map in the following table. Attach additional pages as necessary to include all of the wells.

Table 3.0(3) - Water Well Data

Well ID	Well Use	Producing? Y/N	Open, cased, capped, or plugged?	Proposed Best Management Practice
n/a			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	
			Choose an item.	

If water quality data or well log information is available please include the information in an attachment listed by Well ID.

Attachment: Click to enter text.

# Section 7. Groundwater Quality (Instructions Page 68)

Attach a Groundwater Quality Technical Report which assesses the impact of the wastewater disposal system on groundwater. This report shall include an evaluation of the water wells (including the information in the well table provided in Item 6. above), the wastewater application rate, and pond liners. Indicate by a check mark that this report is provided.

Attachment: <u>n/a</u>
Are groundwater monitoring wells available onsite? $\square$ Yes $\boxtimes$ No
Do you plan to install ground water monitoring wells or lysimeters around the land application site? $\Box$ Yes $\Box$ No
If yes, provide the proposed location of the monitoring wells or lysimeters on a site map.
Attachment: Click to enter text.

# Section 8. Soil Map and Soil Analyses (Instructions Page 69)

## A. Soil map

Attach a USDA Soil Survey map that shows the area to be used for effluent disposal.

Attachment: n/a

## B. Soil analyses

Attach the laboratory results sheets from the soil analyses. **Note**: for renewal applications, the current annual soil analyses required by the permit are acceptable as long as the test date is less than one year prior to the submission of the application.

Attachment: n/a

List all USDA designated soil series on the proposed land application site. Attach additional pages as necessary.

## Table 3.0(4) - Soil Data

Soil Series	Depth from Surface	Permeability	Available Water Capacity	Curve Number
n/a				

# **Section 9.** Effluent Monitoring Data (Instructions Page 70) Is the facility in operation? Yes □ No **If no**, this section is not applicable and the worksheet is complete. If yes, provide the effluent monitoring data for the parameters regulated in the existing permit. If a parameter is not regulated in the existing permit, enter N/A. Table 3.0(5) – Effluent Monitoring Data Chlorine **Date** 30 Day Avg BOD<sub>5</sub> **TSS** рН Acres Flow MGD Residual mg/l mg/l mg/l irrigated

ick to enter text.	

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.1: SURFACE LAND DISPOSAL OF EFFLUENT

The following is required for new and major amendment permit applications. Renewal and minor amendment permit applications may be asked for this worksheet on a case by case basis.

# Section 1. Surface Disposal (Instructions Page 71)

Complete the item that applies for the method of disposal being used.

## A. Irrigation

Area under irrigation, in acres: Click to enter text.

Design application frequency:

hours/day Click to enter text. And days/week Click to enter text.

Land grade (slope):

average percent (%): Click to enter text.

maximum percent (%): Click to enter text.

Design application rate in acre-feet/acre/year: Click to enter text.

Design total nitrogen loading rate, in lbs N/acre/year: Click to enter text.

Soil conductivity (mmhos/cm): Click to enter text.

Method of application: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations, method of application, irrigation efficiency, and nitrogen balance.

Attachment: Click to enter text.

## **B.** Evaporation ponds

Daily average effluent flow into ponds, in gallons per day: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations.

**Attachment:** Click to enter text.

### C. Evapotranspiration beds

Number of beds: Click to enter text.

Area of bed(s), in acres: <u>Click to enter text.</u>

Depth of bed(s), in feet: Click to enter text.

Void ratio of soil in the beds: Click to enter text.

Storage volume within the beds, in acre-feet: Click to enter text.

Attach a separate engineering report with the water balance and storage volume calculations, and a description of the lining.

Attachment: Click to enter text.

# D. Overland flow Area used for application, in acres: Click to enter text. Slopes for application area, percent (%): Click to enter text. Design application rate, in gpm/foot of slope width: Click to enter text. Slope length, in feet: Click to enter text. Design BOD<sub>5</sub> loading rate, in lbs BOD<sub>5</sub>/acre/day: Click to enter text. Design application frequency: hours/day: Click to enter text. **And** days/week: Click to enter text. Attach a separate engineering report with the method of application and design requirements according to 30 TAC Chapter 217. Attachment: Click to enter text. Section 2. Edwards Aquifer (Instructions Page 72)

Is the facility subject to 30 TAC Chapter 213, Edwards Aquifer Rules?
□ Yes □ No
If <b>yes</b> , is the facility located on the Edwards Aquifer Recharge Zone?
□ Yes □ No
If yes, attach a geological report addressing potential recharge features.
Attachment: Click to enter text.

## DOMESTIC WASTEWATER PERMIT APPLICATION **WORKSHEET 3.2: SURFACE LAND DISPOSAL OF EFFLUENT**

The following is required for new and major amendment permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **does not meet** the definition of a subsurface area drip dispersal system as defined in 30 TAC Chapter 222, Subsurface Area Drip Dispersal System.

Section 1. Subsurface Application (Instructions Page 73)
Identify the type of system:
Conventional Gravity Drainfield, Beds, or Trenches (new systems must be less than 5,000 GPD)
□ Low Pressure Dosing
☐ Other, specify: <u>Click to enter text.</u>
Application area, in acres: Click to enter text.
Area of drainfield, in square feet: Click to enter text.
Application rate, in gal/square foot/day: Click to enter text.
Depth to groundwater, in feet: Click to enter text.
Area of trench, in square feet: Click to enter text.
Dosing duration per area, in hours: <u>Click to enter text.</u>
Number of beds: Click to enter text.
Dosing amount per area, in inches/day: Click to enter text.
Infiltration rate, in inches/hour: Click to enter text.
Storage volume, in gallons: <u>Click to enter text.</u>
Area of bed(s), in square feet: Click to enter text.
Soil Classification: <u>Click to enter text.</u>
Attach a separate engineering report with the information required in $30\ TAC\ S\ 309.20$ , excluding the requirements of $S\ 309.20\ b(3)(A)$ and (B) design analysis which may be asked for on a case by case basis. Include a description of the schedule of dosing basin rotation.
Attachment: Click to enter text.
Section 2. Edwards Aquifer (Instructions Page 73)
Is the subsurface system over the Edwards Aquifer Recharge Zone as mapped by TCEQ?
□ Yes □ No
Is the subsurface system over the Edwards Aquifer Transition Zone as mapped by TCEQ?
□ Yes □ No
If yes to either question, the subsurface system may be prohibited by 30 TAC §213.8. Please

call the Municipal Permits Team, at 512-239-4671, to schedule a pre-application meeting.

## DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 3.3: SUBSURFACE AREA DRIP DISPERSAL (SADDS) LAND DISPOSAL OF EFFLUENT

The following **is required** for **new and major amendment** subsurface area drip dispersal system permit applications. Renewal and minor amendments applicants may be asked for the worksheet on a case by case basis.

NOTE: All applicants proposing new/amended subsurface disposal MUST complete and submit Worksheet 7.0. This worksheet applies to any subsurface disposal system that **meets** the definition of a subsurface area drip dispersal system as defined in *30 TAC Chapter 222*, *Subsurface Area Drip Dispersal System*.

Se	ction 1. Administrative Information (Instructions Page 74)
Α.	Provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the treatment facility:
В.	<u>Click to enter text.</u> Is the owner of the land where the treatment facility is located the same as the owner of the treatment facility?
	□ Yes □ No
	If <b>no</b> , provide the legal name of all corporations or other business entities managed, owned, or otherwise closely related to the owner of the land where the treatment facility is located.
	Click to enter text.
C.	Owner of the subsurface area drip dispersal system: <u>Click to enter text.</u>
D.	Is the owner of the subsurface area drip dispersal system the same as the owner of the wastewater treatment facility or the site where the wastewater treatment facility is located?
	□ Yes □ No
	If <b>no</b> , identify the names of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in Item 1.C.
	Click to enter text.
Е.	Owner of the land where the subsurface area drip dispersal system is located: <u>Click to enter text.</u>
F.	Is the owner of the land where the subsurface area drip dispersal system is located the same as owner of the wastewater treatment facility, the site where the wastewater treatment facility is located, or the owner of the subsurface area drip dispersal system?
	□ Yes □ No
	If <b>no</b> , identify the name of all corporations or other business entities managed, owned, or otherwise closely related to the entity identified in item 1.E.
	Click to enter text.

## Section 2. Subsurface Area Drip Dispersal System (Instructions Page 74)

A.

B.

C.

D.

Type of system
□ Subsurface Drip Irrigation
□ Surface Drip Irrigation
□ Other, specify: <u>Click to enter text.</u>
Irrigation operations
Application area, in acres: <u>Click to enter text.</u>
Infiltration Rate, in inches/hour: Click to enter text.
Average slope of the application area, percent (%): Click to enter text.
Maximum slope of the application area, percent (%): Click to enter text.
Storage volume, in gallons: <u>Click to enter text.</u>
Major soil series: <u>Click to enter text.</u>
Depth to groundwater, in feet: Click to enter text.
Application rate
Is the facility located <b>west</b> of the boundary shown in <i>30 TAC § 222.83</i> <b>and</b> also using a vegetative cover of non-native grasses over seeded with cool season grasses during the winter months (October-March)?
□ Yes □ No
<b>If yes</b> , then the facility may propose a hydraulic application rate not to exceed 0.1 gal/square foot/day.
Is the facility located <b>east</b> of the boundary shown in <i>30 TAC § 222.83</i> <b>or</b> in any part of the state when the vegetative cover is any crop other than non-native grasses?
□ Yes □ No
If $yes$ , the facility must use the formula in $30\ TAC\ \S 222.83$ to calculate the maximum hydraulic application rate.
Do you plan to submit an alternative method to calculate the hydraulic application rate for approval by the executive director?
□ Yes □ No
Hydraulic application rate, in gal/square foot/day: Click to enter text.
Nitrogen application rate, in lbs/gal/day: Click to enter text.
Dosing information
Number of doses per day: <u>Click to enter text.</u>
Dosing duration per area, in hours: <u>Click to enter text.</u>

Rest period between doses, in hours: Click to enter text.

Dosing amount per area, in inches/day: Click to enter text.

Number of zones: Click to enter text.
Does the proposed subsurface drip irrigation system use tree vegetative cover as a crop?
□ Yes □ No
If <b>yes</b> , provide a vegetation survey by a certified arborist. Please call the Water Quality Assessment Team at (512) 239-4671 to schedule a pre-application meeting.
Attachment: Click to enter text.
Section 3. Required Plans (Instructions Page 74)
A. Recharge feature plan
Attach a Recharge Feature Plan with all information required in 30 TAC §222.79.
Attachment: Click to enter text.
B. Soil evaluation
Attach a Soil Evaluation with all information required in 30 TAC §222.73.
Attachment: Click to enter text.
C. Site preparation plan
Attach a Site Preparation Plan with all information required in 30 TAC §222.75.
Attachment: Click to enter text.
D. Soil sampling/testing
Attach soil sampling and testing that includes all information required in 30 TAC §222.157.
Attachment: Click to enter text.
Section 4. Floodway Designation (Instructions Page 75)
A. Site location
Is the existing/proposed land application site within a designated floodway?
□ Yes □ No
B. Flood map
Attach either the FEMA flood map or alternate information used to determine the
floodway.
Attachment: <u>Click to enter text.</u>
Section 5. Surface Waters in the State (Instructions Page 75)

## S

#### A. Buffer Map

Attach a map showing appropriate buffers on surface waters in the state, water wells, and springs/seeps.

Attachment: Click to enter text.

Do you plan to request a buffer variance from water wells or waters in the state?
□ Yes □ No
If yes, then attach the additional information required in 30 TAC § 222.81(c).
Attachment: Click to enter text.
Section 6. Edwards Aquifer (Instructions Page 75)
A. Is the SADDS located over the Edwards Aquifer Recharge Zone as mapped by TCEQ?  ☐ Yes ☐ No
<b>B.</b> Is the SADDS located over the Edwards Aquifer Transition Zone as mapped by TCEQ?
□ Yes □ No
<b>If yes to either question,</b> then the SADDS may be prohibited by <i>30 TAC §213.8</i> . Please call the Municipal Permits Team at 512-239-4671 to schedule a pre-application meeting.

**B.** Buffer variance request

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 4.0: POLLUTANT ANALYSIS REQUIREMENTS

The following **is required** for facilities with a permitted or proposed flow of **1.0 MGD or greater**, facilities with an approved **pretreatment** program, or facilities classified as a **major** facility. See instructions for further details.

This worksheet is not required minor amendments without renewal.

## Section 1. Toxic Pollutants (Instructions Page 76)

For pollutants identified in Table	4.0(1), indicate	the type of	sample.
------------------------------------	------------------	-------------	---------

Grab □ Composite □

Date and time sample(s) collected: Click to enter text.

#### Table 4.0(1) - Toxics Analysis

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acrylonitrile				50
Aldrin				0.01
Aluminum				2.5
Anthracene				10
Antimony				5
Arsenic				0.5
Barium				3
Benzene				10
Benzidine				50
Benzo(a)anthracene				5
Benzo(a)pyrene				5
Bis(2-chloroethyl)ether				10
Bis(2-ethylhexyl)phthalate				10
Bromodichloromethane				10
Bromoform				10
Cadmium				1
Carbon Tetrachloride				2
Carbaryl				5
Chlordane*				0.2
Chlorobenzene				10
Chlorodibromomethane				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (μg/l)	Number of Samples	MAL (μg/l)
Chloroform				10
Chlorpyrifos				0.05
Chromium (Total)				3
Chromium (Tri) (*1)				N/A
Chromium (Hex)				3
Copper				2
Chrysene				5
p-Chloro-m-Cresol				10
4,6-Dinitro-o-Cresol				50
p-Cresol				10
Cyanide (*2)				10
4,4'- DDD				0.1
4,4'- DDE				0.1
4,4'- DDT				0.02
2,4-D				0.7
Demeton (O and S)				0.20
Diazinon				0.5/0.1
1,2-Dibromoethane				10
m-Dichlorobenzene				10
o-Dichlorobenzene				10
p-Dichlorobenzene				10
3,3'-Dichlorobenzidine				5
1,2-Dichloroethane				10
1,1-Dichloroethylene				10
Dichloromethane				20
1,2-Dichloropropane				10
1,3-Dichloropropene				10
Dicofol				1
Dieldrin				0.02
2,4-Dimethylphenol				10
Di-n-Butyl Phthalate				10
Diuron				0.09
Endosulfan I (alpha)				0.01

Pollutant	AVG Effluent Conc. (μg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Epichlorohydrin				
Ethylbenzene				10
Ethylene Glycol				
Fluoride				500
Guthion				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclohexane (alpha)				0.05
Hexachlorocyclohexane (beta)				0.05
gamma-Hexachlorocyclohexane				0.05
(Lindane)				
Hexachlorocyclopentadiene				10
Hexachloroethane				20
Hexachlorophene				10
4,4'-Isopropylidenediphenol				1
Lead				0.5
Malathion				0.1
Mercury				0.005
Methoxychlor				2
Methyl Ethyl Ketone				50
Methyl tert-butyl ether				
Mirex				0.02
Nickel				2
Nitrate-Nitrogen				100
Nitrobenzene				10
N-Nitrosodiethylamine				20
N-Nitroso-di-n-Butylamine				20
Nonylphenol				333

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Parathion (ethyl)				0.1
Pentachlorobenzene				20
Pentachlorophenol				5
Phenanthrene				10
Polychlorinated Biphenyls (PCB's) (*3)				0.2
Pyridine				20
Selenium				5
Silver				0.5
1,2,4,5-Tetrachlorobenzene				20
1,1,2,2-Tetrachloroethane				10
Tetrachloroethylene				10
Thallium				0.5
Toluene				10
Toxaphene				0.3
2,4,5-TP (Silvex)				0.3
Tributyltin (see instructions for explanation)				0.01
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene				10
2,4,5-Trichlorophenol				50
TTHM (Total Trihalomethanes)				10
Vinyl Chloride				10
Zinc				5

<sup>(\*1)</sup> Determined by subtracting hexavalent Cr from total Cr.

<sup>(\*2)</sup> Cyanide, amenable to chlorination or weak-acid dissociable.

<sup>(\*3)</sup> The sum of seven PCB congeners 1242, 1254, 1221, 1232, 1248, 1260, and 1016.

## **Section 2. Priority Pollutants**

For 1	pollutants	identified	in Ta	bles 4.0	0(2)A-E,	indicate	type o	of samp	ole.
-------	------------	------------	-------	----------	----------	----------	--------	---------	------

Grab □ Composite □

Date and time sample(s) collected: Click to enter text.

### Table 4.0(2)A - Metals, Cyanide, and Phenols

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Antimony				5
Arsenic				0.5
Beryllium				0.5
Cadmium				1
Chromium (Total)				3
Chromium (Hex)				3
Chromium (Tri) (*1)				N/A
Copper				2
Lead				0.5
Mercury				0.005
Nickel				2
Selenium				5
Silver				0.5
Thallium				0.5
Zinc				5
Cyanide (*2)				10
Phenols, Total				10

<sup>(\*1)</sup> Determined by subtracting hexavalent Cr from total Cr.

<sup>(\*2)</sup> Cyanide, amenable to chlorination or weak-acid dissociable

## Table 4.0(2)B - Volatile Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acrolein				50
Acrylonitrile				50
Benzene				10
Bromoform				10
Carbon Tetrachloride				2
Chlorobenzene				10
Chlorodibromomethane				10
Chloroethane				50
2-Chloroethylvinyl Ether				10
Chloroform				10
Dichlorobromomethane [Bromodichloromethane]				10
1,1-Dichloroethane				10
1,2-Dichloroethane				10
1,1-Dichloroethylene				10
1,2-Dichloropropane				10
1,3-Dichloropropylene				10
[1,3-Dichloropropene]				
1,2-Trans-Dichloroethylene				10
Ethylbenzene				10
Methyl Bromide				50
Methyl Chloride				50
Methylene Chloride				20
1,1,2,2-Tetrachloroethane				10
Tetrachloroethylene				10
Toluene				10
1,1,1-Trichloroethane				10
1,1,2-Trichloroethane				10
Trichloroethylene				10
Vinyl Chloride				10

## Table 4.0(2)C - Acid Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (µg/l)
2-Chlorophenol				10
2,4-Dichlorophenol				10
2,4-Dimethylphenol				10
4,6-Dinitro-o-Cresol				50
2,4-Dinitrophenol				50
2-Nitrophenol				20
4-Nitrophenol				50
P-Chloro-m-Cresol				10
Pentalchlorophenol				5
Phenol				10
2,4,6-Trichlorophenol				10

## Table 4.0(2)D - Base/Neutral Compounds

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Acenaphthene				10
Acenaphthylene				10
Anthracene				10
Benzidine				50
Benzo(a)Anthracene				5
Benzo(a)Pyrene				5
3,4-Benzofluoranthene				10
Benzo(ghi)Perylene				20
Benzo(k)Fluoranthene				5
Bis(2-Chloroethoxy)Methane				10
Bis(2-Chloroethyl)Ether				10
Bis(2-Chloroisopropyl)Ether				10
Bis(2-Ethylhexyl)Phthalate				10
4-Bromophenyl Phenyl Ether				10
Butyl benzyl Phthalate				10
2-Chloronaphthalene				10
4-Chlorophenyl phenyl ether				10
Chrysene				5
Dibenzo(a,h)Anthracene				5
1,2-(o)Dichlorobenzene				10
1,3-(m)Dichlorobenzene				10
1,4-(p)Dichlorobenzene				10
3,3-Dichlorobenzidine				5
Diethyl Phthalate				10
Dimethyl Phthalate				10
Di-n-Butyl Phthalate				10
2,4-Dinitrotoluene				10
2,6-Dinitrotoluene				10
Di-n-Octyl Phthalate				10
1,2-Diphenylhydrazine (as Azobenzene)				20
Fluoranthene				10

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Fluorene				10
Hexachlorobenzene				5
Hexachlorobutadiene				10
Hexachlorocyclo-pentadiene				10
Hexachloroethane				20
Indeno(1,2,3-cd)pyrene				5
Isophorone				10
Naphthalene				10
Nitrobenzene				10
N-Nitrosodimethylamine				50
N-Nitrosodi-n-Propylamine				20
N-Nitrosodiphenylamine				20
Phenanthrene				10
Pyrene				10
1,2,4-Trichlorobenzene				10

## Table 4.0(2)E - Pesticides

Pollutant	AVG Effluent Conc. (µg/l)	MAX Effluent Conc. (µg/l)	Number of Samples	MAL (μg/l)
Aldrin				0.01
alpha-BHC (Hexachlorocyclohexane)				0.05
beta-BHC (Hexachlorocyclohexane)				0.05
gamma-BHC (Hexachlorocyclohexane)				0.05
delta-BHC (Hexachlorocyclohexane)				0.05
Chlordane				0.2
4,4-DDT				0.02
4,4-DDE				0.1
4,4,-DDD				0.1
Dieldrin				0.02
Endosulfan I (alpha)				0.01
Endosulfan II (beta)				0.02
Endosulfan Sulfate				0.1
Endrin				0.02
Endrin Aldehyde				0.1
Heptachlor				0.01
Heptachlor Epoxide				0.01
PCB-1242				0.2
PCB-1254				0.2
PCB-1221				0.2
PCB-1232				0.2
PCB-1248				0.2
PCB-1260				0.2
PCB-1016				0.2
Toxaphene				0.3

<sup>\*</sup> For PCBS, if all are non-detects, enter the highest non-detect preceded by a "<".

## Section 3. Dioxin/Furan Compounds A. Indicate which of the following compounds from may be present in the influent from a contributing industrial user or significant industrial user. Check all that apply. 2,4,5-trichlorophenoxy acetic acid Common Name 2,4,5-T, CASRN 93-76-5 2-(2,4,5-trichlorophenoxy) propanoic acid Common Name Silvex or 2,4,5-TP, CASRN 93-72-1 2-(2,4,5-trichlorophenoxy) ethyl 2,2-dichloropropionate Common Name Erbon, CASRN 136-25-4 0,0-dimethyl 0-(2,4,5-trichlorophenyl) phosphorothioate Common Name Ronnel, CASRN 299-84-3 2,4,5-trichlorophenol Common Name TCP, CASRN 95-95-4 hexachlorophene Common Name HCP, CASRN 70-30-4 For each compound identified, provide a brief description of the conditions of its/their presence at the facility. Click to enter text.

В.	Do you kno	ow or l	have any	reason to	believe	that $2,3$	3,7,8 1	Γetrach	lorodi	benzo-l	P-Dioxin
	(TCDD) or	any co	ngeners	of TCDD r	nay be ]	present	in you	ur efflu	ent?		

□ Yes □ No

If **yes**, provide a brief description of the conditions for its presence.

Click to enter text.

C.	If any of the compounds in Subsection A ${f or}$ B are present, complete Table 4.0(2)F.
	For pollutants identified in Table 4.0(2)F, indicate the type of sample.

Grab □ Composite □

Date and time sample(s) collected: Click to enter text.

## Table 4.0(2)F - Dioxin/Furan Compounds

Compound	Toxic Equivalenc y Factors	Wastewater Concentration (ppq)	Wastewater Equivalents (ppq)	Sludge Concentration (ppt)	Sludge Equivalents (ppt)	MAL (ppq)
2,3,7,8 TCDD	1					10
1,2,3,7,8 PeCDD	0.5					50
2,3,7,8 HxCDDs	0.1					50
1,2,3,4,6,7,8 HpCDD	0.01					50
2,3,7,8 TCDF	0.1					10
1,2,3,7,8 PeCDF	0.05					50
2,3,4,7,8 PeCDF	0.5					50
2,3,7,8 HxCDFs	0.1					50
2,3,4,7,8 HpCDFs	0.01					50
OCDD	0.0003					100
OCDF	0.0003					100
PCB 77	0.0001					0.5
PCB 81	0.0003					0.5
PCB 126	0.1					0.5
PCB 169	0.03					0.5
Total						

# DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 5.0: TOXICITY TESTING REQUIREMENTS

The following **is required** for facilities with a current operating design flow of **1.0 MGD or greater**, with an EPA-approved **pretreatment** program (or those required to have one under 40 CFR Part 403), or are required to perform Whole Effluent Toxicity testing. See Page 86 of the instructions for further details.

This worksheet is not required minor amendments without renewal.

### **Section 1. Required Tests**

Indicate the number of 7-day chronic or 48-hour acute Whole Effluent Toxicity (WET) tests performed in the four and one-half years prior to submission of the application.

7-day Chronic: <u>Click to enter text.</u>
48-hour Acute: <u>Click to enter text.</u>

Section 2. Toxic	city Reduction Evaluations (TREs)
Has this facility comple performing a TRE?	eted a TRE in the past four and a half years? Or is the facility currently
□ Yes □ No	
If yes, describe the pro	ogress to date, if applicable, in identifying and confirming the toxicant.
Click to enter text.	

## **Section 3. Summary of WET Tests**

If the required biomonitoring test information has not been previously submitted via both the Discharge Monitoring Reports (DMRs) and the Table 1 (as found in the permit), provide a summary of the testing results for all valid and invalid tests performed over the past four and one-half years. Make additional copies of this table as needed.

Table 5.0(1) Summary of WET Tests

Test Date	Test Species	NOEC Survival	NOEC Sub-lethal

## DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 6.0: INDUSTRIAL WASTE CONTRIBUTION

The following is required for all publicly owned treatment works.

### **Section 1.** All POTWs (Instructions Page 87)

#### A. Industrial users (IUs)

Provide the number of each of the following types of industrial users (IUs) that discharge to your POTW and the daily flows from each user. See the Instructions for definitions of Categorical IUs, Significant IUs – non-categorical, and Other IUs.

#### If there are no users, enter 0 (zero).

Categorical IUs:

Number of IUs: o

Average Daily Flows, in MGD: n/a

Significant IUs - non-categorical:

Number of IUs: o

Average Daily Flows, in MGD: n/a

Other IUs:

Number of IUs: o

Average Daily Flows, in MGD: n/a

#### B. Treatment plant interference

In the past three years, has your POTW experienced treatment plant interference (see instructions)?

□ Yes ⊠ No

**If yes**, identify the dates, duration, description of interference, and probable cause(s) and possible source(s) of each interference event. Include the names of the IUs that may have caused the interference.

Click to enter text.

	in the past three years, has your POTW experienced pass through (see instructions)?
	□ Yes ⊠ No
	<b>If yes</b> , identify the dates, duration, a description of the pollutants passing through the treatment plant, and probable cause(s) and possible source(s) of each pass through event. Include the names of the IUs that may have caused pass through.
	Click to enter text.
D.	Pretreatment program
	Does your POTW have an approved pretreatment program?
	□ Yes ⊠ No
	If yes, complete Section 2 only of this Worksheet.
	Is your POTW required to develop an approved pretreatment program?
	□ Yes □ No
	If yes, complete Section 2.c. and 2.d. only, and skip Section 3.
	<b>If no to either question above</b> , skip Section 2 and complete Section 3 for each significant industrial user and categorical industrial user.
Se	ection 2. POTWs with Approved Programs or Those Required to Develop a Program (Instructions Page 87)
Α.	Substantial modifications
A.	
A.	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program
A.	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?
A.	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to 40 CFR §403.18?  Yes No  If yes, identify the modifications that have not been submitted to TCEQ, including the
A.	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to <i>40 CFR §403.18</i> ?  ☐ Yes ☑ No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
A.	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to <i>40 CFR §403.18</i> ?  ☐ Yes ☑ No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
A.	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to <i>40 CFR §403.18</i> ?  ☐ Yes ☑ No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.
A.	Substantial modifications  Have there been any substantial modifications to the approved pretreatment program that have not been submitted to the TCEQ for approval according to <i>40 CFR §403.18</i> ?  ☐ Yes ☑ No  If yes, identify the modifications that have not been submitted to TCEQ, including the purpose of the modification.

C. Treatment plant pass through

		ny <b>non-substantial r</b> e not been submitted								
	□ Yes □	No								
	If yes, identify all non-substantial modifications that have not been submitted to TCEQ, including the purpose of the modification.									
	Click to enter tex	t.								
C.	Effluent paramete	ers above the MAL								
Tal		t all parameters mea the last three years ters Above the MAL								
P	ollutant	Concentration	MAL	Units	Date					
n	one									
D.	Industrial user in	terruptions								
		or other IU caused o ass throughs) at you			luding					
	□ Yes ⊠	No								
		e industry, describe o nd probable polluta		uding dates, dura	tion, description					
	Click to enter tex	t.								

**B.** Non-substantial modifications

# Section 3. Significant Industrial User (SIU) Information and Categorical Industrial User (CIU) (Instructions Page 88)

A.	General information
	Company Name: <u>No SIU/CIU</u>
	SIC Code: Click to enter text.
	Contact name: Click to enter text.
	Address: Click to enter text.
	City, State, and Zip Code: <u>Click to enter text.</u>
	Telephone number: Click to enter text.
	Email address: Click to enter text.
B.	Process information
	Describe the industrial processes or other activities that affect or contribute to the SIU(s) or CIU(s) discharge (i.e., process and non-process wastewater).
	Click to enter text.
C.	Product and service information
	Provide a description of the principal product(s) or services performed.
	Click to enter text.
D.	Flow rate information
	See the Instructions for definitions of "process" and "non-process wastewater."
	Process Wastewater:
	Discharge, in gallons/day: Click to enter text.
	Discharge Type: □ Continuous □ Batch □ Intermittent
	Non-Process Wastewater:
	Discharge, in gallons/day: Click to enter text.

Batch

Intermittent

Discharge Type: ☐ Continuous

Pretreatment standards
Is the SIU or CIU subject to technically based local limits as defined in the <i>i</i> nstructions?
□ Yes □ No
Is the SIU or CIU subject to categorical pretreatment standards found in 40 CFR Parts 405-471?
□ Yes □ No
<b>If subject to categorical pretreatment standards</b> , indicate the applicable category and subcategory for each categorical process.
Category: Subcategories: Click to enter text.
Click or tap here to enter text. Click to enter text.
Category: Click to enter text.
Subcategories: Click to enter text.
Category: Click to enter text.
Subcategories: <u>Click to enter text.</u>
Category: Click to enter text.
Subcategories: <u>Click to enter text.</u>
Category: Click to enter text.
Subcategories: <u>Click to enter text.</u>
Industrial user interruptions
Has the SIU or CIU caused or contributed to any problems (e.g., interferences, pass through, odors, corrosion, blockages) at your POTW in the past three years?
□ Yes □ No
<b>If yes</b> , identify the SIU, describe each episode, including dates, duration, description of problems, and probable pollutants.
Click to enter text.

E.

F.

## **WORKSHEET 7.0**

#### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

#### CLASS V INJECTION WELL INVENTORY/AUTHORIZATION FORM

Submit the completed form to:

TCEQ IUC Permits Team Radioactive Materials Division MC-233 PO Box 13087 Austin, Texas 78711-3087 512-239-6466

For TCEQ Use Only	
Reg. No	
Date Received	
Date Authorized	

### Section 1. General Information (Instructions Page 90)

1.	TCEQ Program	Area
----	--------------	------

Program Area (PST, VCP, IHW, etc.): Click to enter text.

Program ID: Click to enter text.

Contact Name: <u>Click to enter text.</u> Phone Number: <u>Click to enter text.</u>

#### 2. Agent/Consultant Contact Information

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

#### 3. Owner/Operator Contact Information

□ Owner □ Operator

Owner/Operator Name: Click to enter text.

Contact Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Phone Number: Click to enter text.

#### 4. Facility Contact Information

Facility Name: Click to enter text.

Address: Click to enter text.

City, State, and Zip Code: Click to enter text.

Location description (if no address is available): Click to enter text.

Facility Contact Person: Click to enter text.

Phone Number: Click to enter text.

5.	Latitude and Longitude, in degrees-minutes-seconds
	Latitude: Click to enter text.
	Longitude: Click to enter text.
	Method of determination (GPS, TOPO, etc.): Click to enter text.
	Attach topographic quadrangle map as attachment A.
6.	Well Information
	Type of Well Construction, select one:
	□ Vertical Injection
	□ Subsurface Fluid Distribution System
	□ Infiltration Gallery
	☐ Temporary Injection Points
	□ Other, Specify: <u>Click to enter text.</u>
	Number of Injection Wells: <u>Click to enter text.</u>
7.	Purpose
	Detailed Description regarding purpose of Injection System:
	Click to enter text.
	Attach a Site Map as Attachment B (Attach the Approved Remediation Plan, if appropriate.)
8.	Water Well Driller/Installer
	Water Well Driller/Installer Name: Click to enter text.
	City, State, and Zip Code: Click to enter text.
	Phone Number: Click to enter text.
	License Number: <u>Click to enter text.</u>
ectio	n 2. Proposed Down Hole Design
	diagram signed and sealed by a licensed engineer as Attachment C.
able 7.0	O(1) - Down Hole Design Table

#### Ta

Name of String	Size	Setting Depth	Sacks Cement/Grout - Slurry Volume - Top of Cement	Hole Size	Weight (lbs/ft) PVC/Steel
Casing					
Tubing					
Screen					

## Section 3. Proposed Trench System, Subsurface Fluid Distribution System, or Infiltration Gallery

Attach a diagram signed and sealed by a licensed engineer as Attachment D.

System(s) Dimensions: <u>Click to enter text.</u> System(s) Construction: Click to enter text.

C a a t a a a 4	Cita IId-care	alagiaal am	J T	Zama Data
Section 4.	Site Hydroge	eological and	a injection	. Zone Data

- 1. Name of Contaminated Aguifer: Click to enter text.
- 2. Receiving Formation Name of Injection Zone: Click to enter text.
- **3.** Well/Trench Total Depth: Click to enter text.
- **4.** Surface Elevation: Click to enter text.
- **5.** Depth to Ground Water: <u>Click to enter text.</u>
- **6.** Injection Zone Depth: Click to enter text.
- 7. Injection Zone vertically isolated geologically? ☐ Yes ☐ No Impervious Strata between Injection Zone and nearest Underground Source of Drinking Water:

Name: Click to enter text.

Thickness: Click to enter text.

- **8.** Provide a list of contaminants and the levels (ppm) in contaminated aquifer Attach as Attachment E.
- **9.** Horizontal and Vertical extent of contamination and injection plume Attach as Attachment F.
- **10.** Formation (Injection Zone) Water Chemistry (Background levels) TDS, etc. Attach as Attachment G.
- **11.** Injection Fluid Chemistry in PPM at point of injection Attach as Attachment H.
- 12. Lowest Known Depth of Ground Water with < 10,000 PPM TDS: Click to enter text.
- 13. Maximum injection Rate/Volume/Pressure: Click to enter text.
- 14. Water wells within 1/4 mile radius (attach map as Attachment I): Click to enter text.
- 15. Injection wells within 1/4 mile radius (attach map as Attachment J): <u>Click to enter text.</u>
- 16. Monitor wells within 1/4 mile radius (attach drillers logs and map as Attachment K): Click to enter text.
- 17. Sampling frequency: Click to enter text.
- **18.** Known hazardous components in injection fluid: Click to enter text.

### Section 5. Site History

- **1.** Type of Facility: <u>Click to enter text.</u>
- **2.** Contamination Dates: Click to enter text.
- 3. Original Contamination (VOCs, TPH, BTEX, etc.) and Concentrations (attach as Attachment L): <u>Click to enter text.</u>
- **4.** Previous Remediation (attach results of any previous remediation as attachment M): Click to enter text.

NOTE: Authorization Form should be completed in detail and authorization given by the TCEQ before construction, operation, and/or conversion can begin. Attach additional pages as necessary.

#### Class V Injection Well Designations

- 5A07 Heat Pump/AC return (IW used for groundwater to heat and/or cool buildings)
- 5A19 Industrial Cooling Water Return Flow (IW used to cool industrial process equipment)
- 5B22 Salt Water Intrusion Barrier (IW used to inject fluids to prevent the intrusion of salt water into an aquifer)
- 5D02 Storm Water Drainage (IW designed for the disposal of rain water)
- 5D04 Industrial Stormwater Drainage Wells (IW designed for the disposal of rain water associated with industrial facilities)
- 5F01 Agricultural Drainage (IW that receive agricultural runoff)
- 5R21 Aquifer Recharge (IW used to inject fluids to recharge an aquifer)
- 5S23 Subsidence Control Wells (IW used to control land subsidence caused by ground water withdrawal)
- 5W09 Untreated Sewage
- 5W10 Large Capacity Cesspools (Cesspools that are designed for 5,000 gpd or greater)
- 5W11 Large Capacity Septic systems (Septic systems designed for 5,000 gpd or greater)
- 5W12 WTTP disposal
- 5W20 Industrial Process Waste Disposal Wells
- 5W31 Septic System (Well Disposal method)
- 5W32 Septic System Drainfield Disposal
- 5X13 Mine Backfill (IW used to control subsidence, dispose of mining byproducts, and/or fill sections of a mine)
- 5X25 Experimental Wells (Pilot Test) (IW used to test new technologies or tracer dye studies)
- 5X26 Aguifer Remediation (IW used to clean up, treat, or prevent contamination of a USDW)
- 5X27 Other Wells
- 5X28 Motor Vehicle Waste Disposal Wells (IW used to dispose of waste from a motor vehicle site These are currently banned)
- 5X29 Abandoned Drinking Water Wells (waste disposal)



## FORT BEND COUNTY MUD NO. 162 WWTP DISCHARGE PERMIT MAJOR AMENDMENT PERMIT NO. WQ0014564002

**ATTACHMENT 3** 

TCEQ CORE DATA FORM

Fort Bend County Municipal Utility District No 162

13. Independently Owned and Operated?

☐ No

Other:

10. DUNS Number (if

Partnership: General Limited

Other: Municipal Utility District

applicable)

N/A

ZIP + 4

9. Federal Tax ID

(9 digits)

N/A

☐ Sole Proprietorship

Yes

77027

ZIP

☐ Individual



## **TCEQ Core Data Form**

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

Fort Bend County Municipal Utility District No 162

7. TX SOS/CPA Filing Number

11. Type of Customer:

Occupational Licensee

City

12. Number of Employees

N/A

Owner

15. Mailing

Address:

SECTION I: General In	<u>formation</u>		
1. Reason for Submission (If other is checked	d please describe in space provided.)		
New Permit, Registration or Authorization	(Core Data Form should be submitted with	the program application.)	
Renewal (Core Data Form should be subm	itted with the renewal form)	Other	
2. Customer Reference Number (if issued)	Follow this link to search for CN or RN numbers in	3. Regulated Entity Reference Numb	er (if issued)
CN 602863896	RN 1044435		
SECTION II: Customer	Information		
4. General Customer Information	5. Effective Date for Customer Info	rmation Updates (mm/dd/yyyy)	2/4/2024
☐ New Customer	Jpdate to Customer Information	☐ Change in Regulated Entity Ownership	
Change in Legal Name (Verifiable with the Te	xas Secretary of State or Texas Comptrolle	of Public Accounts)	
The Customer Name submitted here may	be updated automatically based on v	what is current and active with the Texa	s Secretary of State
(SOS) or Texas Comptroller of Public Acco	unts (CPA).		
6. Customer Legal Name (If an individual, pr	int last name first: eq: Doe, John)	If new Customer, enter previous C	ustomer below:

8. TX State Tax ID (11 digits)

14. Customer Role (Proposed or Actual) – as it relates to the Regulated Entity listed on this form. Please check one of the following

Owner & Operator

State

51-0563754

☐ Corporation

Government: 
City County Federal Local State Other

 $\boxtimes$  0-20  $\ \square$  21-100  $\ \square$  101-250  $\ \square$  251-500  $\ \square$  501 and higher

Responsible Party

Operator

3200 Soutwest Freeway, Suite 2600

Houston

16. Country Mailing Information (if outside USA) 17. E-Mail Address (if applicable) lhumphries@abhr.com 18. Telephone Number 19. Extension or Code 20. Fax Number (if applicable)

TX

TCEQ-10400 (11/22) Page 1 of 3

(713)860-6400		( ) -
---------------	--	-------

## **SECTION III: Regulated Entity Information**

21. General Regulated En	tity Infor	matior	n (If 'New Re	gulatea	l Entity" is selec	cted, a	new per	mit ap	plicat	ion is als	so required.)			
New Regulated Entity	Update	to Reg	ulated Entity	Name	⊠ Update t	to Regi	ulated Ei	ntity Inf	forma	ition				
The Regulated Entity Nan as Inc, LP, or LLC).	ne submi	tted m	ay be upda	ited, in	order to med	et TCE	Q Core	Data :	Stan	dards (	removal of	organiza	ition	al endings such
22. Regulated Entity Nam	<b>e</b> (Enter n	ame of	the site whe	re the r	egulated actior	ı is tak	ing plac	e.)						
Fort Bend County Municipal I	Jtility Dist	rict No.	. 162 WWTP											
23. Street Address of the Regulated Entity:	7102 1/2 Koeblen Road													
(No PO Boxes)	City	Ri	ichmond		State	TX		ZIP		77469	)	ZIP+	4	
24. County	Fort Ben	d		•			•							
			If no Stre	et Ado	dress is provid	ded, fi	ields 25	-28 ar	e rec	uired.				
25. Description to														
Physical Location:														
26. Nearest City										State			Near	est ZIP Code
Latitude/Longitude are re used to supply coordinate	-		-	-				ta Sta	ındaı	rds. (Ge	cocoding of	the Phys	ical A	Address may be
_	s where		-	-			асу).			ds. (Ge		the Phys	ical A	Address may be
used to supply coordinate	s where		-	-	ed or to gain		асу).	ngitud				the Phys	ical A	Address may be Seconds
27. Latitude (N) In Decima  Degrees	es where al: Minutes	none h	have been p	Secon	ed or to gain		acy). 28. Lo	ngitud			cimal:			Seconds
used to supply coordinate  27. Latitude (N) In Decima	es where al: Minutes	none h	-	Secon	ed or to gain	31. F	28. Lo	ngitud s	le (W	) In De	cimal:	the Phys		Seconds
27. Latitude (N) In Decima  Degrees	es where al: Minutes	none h	nave been p	Secon	ed or to gain	31. F	<b>28. Lo</b>	ngitud s	le (W	) In De	cimal:	condary		Seconds
27. Latitude (N) In Decima  Degrees  29. Primary SIC Code	es where al: Minutes	none h	nave been p	Secon	ed or to gain	31. F	28. Lon Degree  Primary r 6 digits	ngitud s	le (W	) In De	cimal: Minutes  32. Sec	condary		Seconds
27. Latitude (N) In Decima  Degrees  29. Primary SIC Code  (4 digits)	Minutes	<b>60. Sec</b>	condary SIC	Secon	ed or to gain o	31. F (5 or	28. Loi Degree Primary r 6 digits	ngitud s NAICS	le (W	) In De	cimal: Minutes  32. Sec	condary		Seconds
Degrees  29. Primary SIC Code (4 digits)	Minutes  Gusiness of	<b>60. Sec</b>	condary SIC	Secon	ed or to gain o	31. F (5 or	28. Loi Degree Primary r 6 digits	ngitud s NAICS	le (W	) In De	cimal: Minutes  32. Sec	condary		Seconds
27. Latitude (N) In Decima Degrees  29. Primary SIC Code (4 digits)  4952  33. What is the Primary B	Minutes  Gusiness Coresidents	60. Sec	condary SIC	Secon  Code	ed or to gain o	31. F (5 or	28. Loi Degree Primary r 6 digits	ngitud s NAICS	le (W	) In De	cimal: Minutes  32. Sec	condary		Seconds
27. Latitude (N) In Decima Degrees  29. Primary SIC Code (4 digits)  4952  33. What is the Primary B Provide municipal utilities to	Minutes  Gusiness Coresidents	60. Sec	condary SIC	Secon  Code	ed or to gain o	31. F (5 or	28. Loi Degree Primary r 6 digits	ngitud s NAICS	le (W	) In De	cimal: Minutes  32. Sec	condary		Seconds
27. Latitude (N) In Decima Degrees  29. Primary SIC Code (4 digits)  4952  33. What is the Primary B	Minutes  Gusiness Coresidents	60. Sec	condary SIC	Secon  Code	ed or to gain o	31. F (5 or	28. Loi Degree Primary r 6 digits	ngitud s NAICS	S Coo	) In De	cimal: Minutes  32. Sec (5 or 6 o	condary	NAIC	Seconds
27. Latitude (N) In Decima Degrees  29. Primary SIC Code (4 digits)  4952  33. What is the Primary B Provide municipal utilities to	Minutes  Susiness C  residents  3200 Sc  City	60. Sec	condary SIC  entity? (D	Secon  Code  So not re	ed or to gain o	31. I (5 or 2213	28. Loi Degree Primary r 6 digits	NAICS	S Coo	de	cimal: Minutes  32. Sec (5 or 6 o	condary digits)	NAIC	Seconds
27. Latitude (N) In Decima Degrees  29. Primary SIC Code (4 digits)  4952  33. What is the Primary B Provide municipal utilities to  34. Mailing Address:	Minutes  Susiness C  residents  3200 Sc  City	60. Sec	condary SIC  entity? (D	Secon  Code  Souite 26	ed or to gain o	31. F (5 or 2213	28. Loi Degree Primary r 6 digits	NAICS  otion.)	S Coo	77027	cimal: Minutes  32. Sec (5 or 6 o	condary digits)	NAIC	Seconds

**39. TCEQ Programs and ID Numbers** Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

TCEQ-10400 (11/22) Page 2 of 3

New Source Review Air	OSSF	☐ Petroleum Storage Tank	□PWS
Storm Water	☐ Title V Air	Tires	☐ Used Oil
Wastewater WQ0014564002	☐ Wastewater Agriculture	☐ Water Rights	Other:
	Review Air  Storm Water  Wastewater	Review Air  OSSF  Storm Water  Title V Air  Wastewater Agriculture	Review Air  OSSF Petroleum Storage Tank  Storm Water Title V Air Tires  Wastewater Wastewater Agriculture Water Rights

40. Name:	Blake Ahrendsen			41. Title:	Project Engineer	
42. Telephone Number		43. Ext./Code	44. Fax Number	45. E-Mail Address		
(281) 306-0240		112	(n/a) -	bahrendser	en@odysseyeg.com	

### **SECTION V: Authorized Signature**

46. By my signature below, I certify, to the best of my knowledge, that the information provided in this form is true and complete, and that I have signature authority to submit this form on behalf of the entity specified in Section II, Field 6 and/or as required for the updates to the ID numbers identified in field 39.

Company:	Fort Bend County Municipal Utility District No. 162	Job Title:	President		
Name (In Print):	Dale Clayton	Phone:	(7/3) 860 6400		
Signature:	A B B	Date:	2/6/2025		

TCEQ-10400 (11/22) Page 3 of 3




## FORT BEND COUNTY MUD NO. 162 WWTP DISCHARGE PERMIT MAJOR AMENDMENT PERMIT NO. WQ0014564002


ATTACHMENT 4


**USGS Map** 
















ATTACHMENT 5


Buffer Zone Map





ATTACHMENT 6

Process Flow Diagram



# FORT BEND COUNTY MUD 162 WASTE WATER TREATMENT PLANT EXPANSION

PROCESS FLOW DIAGRAM



2500 Tanglewilde Street, Suite 480 Houston, Texas 77063 t: 281.306.0240 | www.odysseyeg.com


FEB. 2025






ATTACHMENT 7

Site Map





SERVICE AREA MAP

FEB. 2025

ODYSSEY ENGINEERING GROUP

2500 Tanglewilde Street, Suite 300 Houston, Texas 77063 t: 281.306.0240 | www.odysseyeg.com TBPE No. F-17637

DISCLAIMER: NO WARRANTY OR REPRESENTATION OF INTENDED USE DESIGN OR PROPOSED IMPROVEMENTS ARE MADE HEREIN. ALL PLANS FOR LAND OR FACILITIES ARE SUBJECT TO CHANGE WITHOUT NOTICE.



**ATTACHMENT 8** 

Payment Voucher

#### TCEQ ePay Receipt

#### - Transaction Information

**Trace Number:** 582EA000653222 **Date:** 02/19/2025 04:57 PM

**Payment Method:** CC - Authorization 000001394G

ePay Actor: BLAKE AHRENDSEN

**TCEQ Amount:** \$1,250.00 **Texas.gov Price:** \$1,278.38\*

\* This service is provided by Texas.gov, the official website of Texas. The price of this service includes funds that support the ongoing operations and enhancements of Texas.gov, which is provided by a third party in partnership with the State.

#### Payment Contact Information -

Name: BLAKE AHRENDSEN

Company: ODYSSEY ENGINEERING GROUP LLC

Address: 2500 TANGLEWILDE STREET SUITE, HOUSTON, TX 77063

**Phone:** 281-306-0240

#### Cart Items

Voucher 751146	Fee Description  WW PERMIT - FACILITY WITH FLOW >= .25 & < .50 MGD - NEW  AND MAJOR AMENDMENTS	AR Number	<b>Amount</b> \$1,200.00
751147	30 TAC 305.53B WQ NOTIFICATION FEE	TCEQ Amount:	\$50.00 <b>\$1,250.00</b>



**ATTACHMENT 9** 

TCEQ Letter of Approval for Project Summary of 0.45 MGD

Jon Niermann, *Chairman* Emily Lindley, *Commissioner* Bobby Janecka, *Commissioner* Toby Baker, *Executive Director* 



### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

September 9, 2020

Philip W. Huseman, P.E. ODYSSEY ENGINEERING GROUP 2500 Tanglewilde Street Suite 480 Houston, TX 77063

Re: Fort Bend County Municipal Utility District 162
FBCMUD 162 Wastewater Treatment Plant Expansion
Permit No. WQ0014564-001
WWPR Log No. 0920/017
CN602863896, RN104443551
Fort Bend County

Dear Mr. Huseman:

On September 3, 2020, TCEQ received the project summary transmittal letter dated August 31, 2020 for an expansion project at the Fort Bend County Municipal Utility District 162 wastewater treatment plant. The submitted project is designed to expand the treatment plant from an average daily flow of 0.30 MGD to 0.45 MGD with a corresponding peak daily flow of 1.8 MGD. A major amendment to the current Water Quality permit is processing for this wastewater treatment plant to enable raising the treatable flow. The review of this project assumed that the current effluent concentration limits will be written into the completed permit as part of processing the major amendment. The current permitted effluent concentration limits are 10 mg/l for CBOD5, 15 mg/l of TSS, 3 mg/l for NH3-N, 126 cfu/100 ml for E. coli while maintaining a minimum dissolved oxygen concentration of 4.0 mg/l. The specific details of the scope of this project are indicated below.

The rules which regulate the design, installation and testing of domestic wastewater projects are found in 30 TAC, Chapter 217, of the Texas Commission on Environmental Quality (TCEQ) rules titled, <u>Design Criteria for Wastewater Systems</u>.

The work within the scope of this project consists of the following:

- Installing 1 additional aeration basin 52' x 12' x 10.67' SWD, 6,658 ft3 volume
- Installing 1 additional 30' diameter secondary clarifier 11.83' SWD
- Installing 1 additional aerobic sludge digester 46' x 12' x 10.67' SWD, 5,890 ft³ volume
- Installing 1 additional chlorine contact basin 18' x 8' x 8.5' SWD, 1,224 ft<sup>3</sup> volume

The complete 0.45 MGD ADF treatment system will include the following existing units as well

- 4 aeration basins 42' x 12' x 10.67' SWD, total volume 21,510 ft<sup>3</sup>
- 3 secondary clarifiers
  - o 2-22' diameter 10' SWD
  - o 1-24' diameter 10' SWD
- 3 chlorine contact basins 20' x 16' x 8' SWD, total volume 7,680 ft<sup>3</sup>
- 3 aerobic sludge digesters 30' x 12' x 10.67', total volume 11,523 ft<sup>3</sup>

Philip W. Huseman, P.E. Page 2 September 9, 2020

The TCEQ review of the submitted project information seems to indicate that, as designed, the project meets at least the minimum requirements of 30 TAC Chapter 217: Design Criteria for Wastewater Systems. Given the result of the TCEQ review this project is conditionally approved for completion. The conditions on this approval are that the submitted major permit amendment get issued with either an interim or final flow limit at 0.45 MGD ADF/1.8 MGD PDF and that the permit effluent concentration limits be as the existing permit and listed in the first paragraph of this letter. If the issued amended permit contains more stringent effluent concentration limits, or includes a phosphorus limit the project must be resubmitted for further review.

You must keep certain materials on file for the life of the project and provide them to TCEQ upon request. These materials include an engineering report, test results, a summary transmittal letter, and the final version of the project plans and specifications. These materials shall be prepared and sealed by a Professional Engineer licensed in the State of Texas and must show substantial compliance with Chapter 217. All plans and specifications must conform to any waste discharge requirements authorized in a permit by the TCEQ. Certain specific items which shall be addressed in the engineering report are discussed in §217.10. Additionally, the engineering report must include all constants, graphs, equations, and calculations needed to show substantial compliance with Chapter 217.

No variances of any 30 TAC Chapter 217 requirements were requested or granted as part of this project review. If in the future, additional variances from the Chapter 217 requirements are desired for the project, each variance must be requested in writing by the design engineer. Then, the TCEQ will consider granting a written approval to the variance from the rules for the specific project and the specific circumstances.

Within 60 days of the completion of construction, an appointed engineer shall notify both the Wastewater Permits Section of the TCEQ and the appropriate Region Office of the date of completion. The engineer shall also provide written certification that all construction, materials, and equipment were substantially in accordance with the approved project, the rules of the TCEQ, and any change orders filed with the TCEQ. All notifications, certifications, and change orders must include the signed and dated seal of a Professional Engineer licensed in the State of Texas.

Please be reminded of 30 TAC \$217.7(a) of the rules which states, "Approval given by the executive director or other authorized review authority does not relieve an owner of any liability or responsibility with respect to designing, constructing, or operating a collection system or treatment facility in accordance with applicable commission rules and the associated wastewater permit".

Philip W. Huseman, P.E. Page 3 September 9, 2020

If you have any questions, or if we can be of any further assistance, please call me at (512) 239-

1372.

Paul A. Brochi, P.E.

Wastewater Permits Section (MC 148) Water Quality Division

Texas Commission on Environmental Quality

PAB/tc.



# ATTACHMENT 10

TCEQ Letter of Approval for Project Summary of 0.35 MGD

Jon Niermann, *Chairman* Emily Lindley, *Commissioner* Bobby Janecka, *Commissioner* Toby Baker, *Executive Director* 



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

November 3, 2021

Philip W. Huseman, P.E. ODYSSEY ENGINEERING GROUP 2500 Tanglewilde Street Suite 480 Houston, Texas 77063

Re:

Fort Bend County Municipal Utility District No. 162

FBCMUD No 162 WWTP Expansion from 0.3 MGD to 0.35 MGD

Permit No. WQ0014564-001 WWPR Log No. 0821/102 CN602863896, RN104443551

Fort Bend County

#### Dear Mr. Huseman:

On August 20, 2021, TCEQ received the project summary transmittal letter dated August 10, 2021 detailing an expansion from a treatable average daily flow capacity of 0.30 MGD to 0.35 MGD for the Fort Bend County MUD 162 wastewater treatment plant. A major amendment of the current Water Quality permit is being processed to include the 0.35 MGD average daily flow. The plant must produce an effluent to meet the concentration limits of 10 mg/l of CBOD $_5$ , 15 mg/l of TSS, 3 mg/l of NH $_3$ -N, and 126 cfu/100 ml for E. coli while maintaining a minimum dissolved oxygen concentration of 4 mg/l. The details of the expansion projects scope of work are shown below.

The rules which regulate the design, installation and testing of domestic wastewater projects are found in 30 TAC, Chapter 217, of the Texas Commission on Environmental Quality (TCEQ) rules titled, <u>Design Criteria</u> for Wastewater Systems.

To meet the expansion flow the plant will be comprised of existing treatment trains (3) and a new treatment train. The breakdown of the treatment units on site after completion of the plant expansion is as follows:

Treatment Unit Type	Volume/Size Existing Trains 1, 2 and 3	Volume/Size Added Units Train 4
Aeration Basins	17,920 ft³ total volume	4,224 ft <sup>3</sup>
Secondary Clarifiers (Approximate depth 16')	2-20 ft. diameter 1-22 ft. diameter	1-18 ft. diameter
Aerobic Digesters	2 digesters, 11,469.4 ft³	1 digester, 2,318 ft <sup>3</sup>
Chlorine Contact Basins	2,072 ft3 total volume	630 ft <sup>3</sup>

Philip W. Huseman, P.E. Page 2 November 3, 2021

Other in-scope work items include:

- Replacing the existing pumps in the onsite lift station with three new pumps
  - o Firm capacity 972 gpm with 2 pumps operating
  - o 36 ft. TDH, 10HP
- Installation of a new bar screen
- Installation of a new splitter box

The TCEQ review of the submitted information indicates that plant design meets at least the minimum requirements in 30 TAC Chapter 217: <u>Design Criteria for Wastewater Systems</u>. The result of TCEQ's review allows TCEQ to conditionally approve this project for completion.

The condition of this approval is that no work on the expansion project can be completed until the major amendment is finalized and updated permit containing the 0.35 MGD flow phase is issued.

You must keep certain materials on file for the life of the project and provide them to TCEQ upon request. These materials include an engineering report, test results, a summary transmittal letter, and the final version of the project plans and specifications. These materials shall be prepared and sealed by a Professional Engineer licensed in the State of Texas and must show substantial compliance with Chapter 217. All plans and specifications must conform to any waste discharge requirements authorized in a permit by the TCEQ. Certain specific items which shall be addressed in the engineering report are discussed in §217.10. Additionally, the engineering report must include all constants, graphs, equations, and calculations needed to show substantial compliance with Chapter 217.

No variances of any 30 TAC Chapter 217 requirements were requested or granted as part of this project review. If in the future, any variances from the Chapter 217 requirements are desired for the project, each variance must be requested in writing by the design engineer. Then, the TCEQ will consider granting a written approval to the variance from the rules for the specific project and the specific circumstances.

Within 60 days of the completion of construction, an appointed engineer shall notify both the Wastewater Permits Section of the TCEQ and the appropriate Region Office of the date of completion. The engineer shall also provide written certification that all construction, materials, and equipment were substantially in accordance with the approved project, the rules of the TCEQ, and any change orders filed with the TCEQ. All notifications, certifications, and change orders must include the signed and dated seal of a Professional Engineer licensed in the State of Texas.

Please be reminded of 30 TAC §217.7(a) of the rules which states, "Approval given by the executive director or other authorized review authority does not relieve an owner of any liability or responsibility with respect to designing, constructing, or operating a collection system or treatment facility in accordance with applicable commission rules and the associated wastewater permit".

Philip W. Huseman, P.E. Page 3 November 3, 2021

If you have any questions, or if we can be of any further assistance, please call me at (512) 239-1372.

Sin Carly, lassoft

Paul A. Brochi, P.E. Wastewater Permits Section (MC 148) Water Quality Division Texas Commission on Environmental Quality

PAB/tc



# ATTACHMENT 11

SUPPLEMENTAL PERMIT INFORMATION FORM

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

# FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:	
Application type:RenewalMajor Am	nendment Minor Amendment New
County:	
Admin Complete Date:	
Agency Receiving SPIF:	
Texas Historical Commission	U.S. Fish and Wildlife
Texas Parks and Wildlife Department	U.S. Army Corps of Engineers
This form applies to TPDES permit application	s only. (Instructions, Page 53)
	EQ will mail a copy to each agency as required by not completely addressed or further information formation before issuing the permit. Address
may be directed to the Water Quality Division's email at	

	Prefix	Mr., Ms., Miss): <u>Mr.</u>
	First aı	nd Last Name: <u>Blake Ahrendsen</u>
	Creder	itial (P.E, P.G., Ph.D., etc.): <u>E.I.T</u>
	Title: S	r. Project Engineer
	Mailing	g Address: <u>2500 Tanglewilde Street, Suite 300</u>
	City, St	rate, Zip Code: <u>Houston, TX, 77063</u>
	Phone	No.: <u>281-306-0240</u> Ext.: <u>112</u> Fax No.:
	E-mail	Address: <u>bahrendsen@odysseyeg.com</u>
2.	List the	e county in which the facility is located: <u>Fort Bend County</u>
3.	please	property is publicly owned and the owner is different than the permittee/applicant, list the owner of the property.
	<u>Permi</u>	ttee is owner of Property
4.	of efflu dischar	e a description of the effluent discharge route. The discharge route must follow the flow ent from the point of discharge to the nearest major watercourse (from the point of ege to a classified segment as defined in 30 TAC Chapter 307). If known, please identify essified segment number.
	The d	ischarge route remains unchanged from the existing permit
5.	plotted route f	provide a separate 7.5-minute USGS quadrangle map with the project boundaries and a general location map showing the project area. Please highlight the discharge rom the point of discharge for a distance of one mile downstream. (This map is ed in addition to the map in the administrative report).
	Provide	e original photographs of any structures 50 years or older on the property.
	Does y	our project involve any of the following? Check all that apply.
		Proposed access roads, utility lines, construction easements
		Visual effects that could damage or detract from a historic property's integrity
		Vibration effects during construction or as a result of project design
		Additional phases of development that are planned for the future
		Sealing caves, fractures, sinkholes, other karst features

Provide the name, address, phone and fax number of an individual that can be contacted to

answer specific questions about the property.

	☐ Disturbance of vegetation or wetlands
1.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	Construction will only occur in the facility. Construction is not expected to impact more than 0.25 ac. Plant already exists. No proposed construction with this project.
2.	Describe existing disturbances, vegetation, and land use:
	Land use is for an existing WWTP
	IE FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR MENDMENTS TO TPDES PERMITS
3.	List construction dates of all buildings and structures on the property:
	Plant already exists. No proposed construction with this project.
4.	Provide a brief history of the property, and name of the architect/builder, if known.
	The property has served as a wastewater treatment plant for over 15 years.



# ATTACHMENT 12

Downstream Landowners Address Label


	DOWNSTREAM LANDOW	NER INFORMATION
LOT	OWNER NAME	OWNER ADDRESS
А	CORTEZ ROBERT	1124 ALAMO AVE RICHMOND TX 77469-1606
В	FORT BEND COUNTY	301 JACKSON ST RICHMOND TX 77469-3108
С	N/A	N/A
D	DOCWARE TAMYRA MELINDA & BRIAN DAVID	7223 NORTHCHASE LN RICHMOND TX 77469-4120
E	VASQUEZ NAHUM ISSAC	7219 NORTHCHASE LN RICHMOND TX 77469-4120
F	VASQUEZ HERMES NEFTALI	7215 NORTHCHASE LN RICHMOND TX 77469-4120
G	LOPEZ-CONDE YAJAIRA	7211 NORTHCHASE LN RICHMOND TX 77469-4120
н	SAMPSON KIM	3819 MIDDLECREST LN RICHMOND TX 77469-4123
I	MULTIPLE OWNERS	7135 TIMBER MOSS LN RICHMOND TX 77469
J	FORT BEND COUNTY MUD 162	3200 SOUTHWEST FWY STE 2600 HOUSTON TX 77027-7537
К	SUNRISE MEADOW PROPERTY ASSOCIATION INC	C/O REALMANAGE PO BOX 702438 DALLAS TX 75370-2438


L	MULTIPLE OWNERS	7202 NETTLE SPRING CT RICHMOND TX 77469
М	MADUSQUE CYNTHIA & IFEANYICHUKWU J	12906 DOTY AVE HAWTHORNE CA 90250-5441
N	ANDRADE JORGE	4707 MONARCH FALLS LN RICHMOND TX 77469-1872
0	JOHNSON KEVIN LOUIS & MONIQUE SMITH	4711 MONARCH FALLS LN RICHMOND TX 77469-1872



ATTACHMENT 13

Downstream Landowners Exhibit







PERMIT NO. WQ0014564002

ATTACHMENT 14

Original Photograph Exhibit





PHOTO 1



PHOTO 3



PHOTO 2



EFFLUENT DISCHARGE



# FORT BEND COUNTY, TEXAS FORT BEND COUNTY MUD No. 162 ORIGINAL PHOTOGRAPH EXHIBIT

FEB. 2025

ODYSSEY ENGINEERING GROUP

2500 Tanglewilde Street, Suite 480 Houston, Texas 77063 t: 281.306.0240 | www.odysseyeg.com TBPE No. F-17637

DISCLAIMER: NO WARRANTY OR REPRESENTATION OF INTENDED USE DESIGN OR PROPOSED IMPROVEMENTS ARE MADE HEREIN, ALL PLANS FOR LAND OR FACILITIES ARE SUBJECT TO CHANGE WITHOUT NOTICE



ATTACHMENT 15

Sludge Agreement

# CITY OF ROSENBERG PO BOX 32 ROSENBERG, TEXAS 77471

Date: February 20, 2025

Plant: Fort Bend County MUD 162

TCEQ Permit: WQ0014565001

To Whom it May Concern:

The City of Rosenberg owns a Wastewater Treatment Plant (Permit # WQ0010607002) located at 3650 North Fairgrounds Rd.

Magna Flow Environmental and the City of Rosenberg have entered into a contractual agreement, whereby Magna Flow Environmental (TCEQ Permit# 21484) will dewater domestic sewage sludge from properly permitted wastewater treatment plants at our treatment plant. Dewatered Sludge will then be disposed of at a TCEQ permitted disposal site. The City of Rosenberg Wastewater Treatment Plant currently has the Capacity to accept sludge from the above mentioned plant.

Per a contractual agreement with the City of Rosenberg, Magna Flow Environmental agrees to accept and be responsible for the sludge dewatered at the City of Rosenberg wastewater treatment plant located at 3650 North Fairgrounds Road.

John Maresh Assistant City Manager City of Rosenberg

Jerry McCurtain

John Maresh

Vice President

Magna Flow Environmental

steel Muly



ATTACHMENT 16

Plain Language Summary



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

## SUMMARY OF APPLICATION IN PLAIN LANGUAGE FOR TPDES OR TLAP PERMIT APPLICATIONS

# Summary of Application (in plain language) Template and Instructions for Texas Pollutant Discharge Elimination System (TPDES) and Texas Land Application (TLAP) Permit Applications

Applicants should use this template to develop a plain language summary of your facility and application as required by Title 30, Texas Administrative Code (30 TAC), Chapter 39, Subchapter H. You may modify the template as necessary to accurately describe your facility as long as the summary includes the following information: (1) the function of the proposed plant or facility; (2) the expected output of the proposed plant or facility; (3) the expected pollutants that may be emitted or discharged by the proposed plant or facility; and (4) how you will control those pollutants, so that the proposed plant will not have an adverse impact on human health or the environment.

Fill in the highlighted areas below to describe your facility and application in plain language. Instructions and examples are provided below. Make any other edits necessary to improve readability or grammar and to comply with the rule requirements. After filling in the information for your facility delete these instructions.

If you are subject to the alternative language notice requirements in 30 TAC Section 39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

## ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS DOMESTIC WASTEWATER/STORMWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 TAC Chapter 39. The information provided in this summary may change during the technical review of the application and is not a federal enforceable representation of the permit application.

Fort Bend County Municipal Utility District No. 162 (CN602863896) operates Fort Bend County Municipal Utility District No. 162 WWTP No. 1 (RN104443551), a wastewater treatment plant. The facility is located at 7102 ½ Koeblen Road, in Richmond, Fort Bend County, Texas 77469. The District is applying to discharge up to 0.45 MGD from the existing WWTP.

Discharges from the facility are expected to contain suspended solids, ammonia nitrogen, and e. coli. Treated domestic wastewater is treated by an activated sludge process.

## PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS DE TPDES o TLAP

## AGUAS RESIDUALES DOMÉSTICAS /AGUAS PLUVIALES

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo requerido por el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es una representación ejecutiva fedérale de la solicitud de permiso.

Fort Bend County Municipal Utility District No. 162 (CN602863896) opera Fort Bend County Municipal Utility District No. 162 WWTP No. 1 RN104443551, una planta de tratamiento de aguas residuales. La instalación está ubicada en 7102 ½ Koeblen Rd, en Richmond, Condado de Fort Bend, Texas 77469. El Distrito está solicitando descargar hasta 0,45 MGD de la planta de tratamiento de aguas residuales existente.

Se espera que las descargas de la instalación contengan sólidos suspendidos, nitrógeno amoniacal, y e. coli. Aguas residuals domésticas tratadas. están tratado por lodos activados.



## FORT BEND COUNTY MUD NO. 162 WWTP DISCHARGE PERMIT MAJOR AMENDMENT PERMIT NO. WQ0014564002

## ATTACHMENT 17

Public Involvement Plan Form

## Public Involvement Plan Form for Permit and Registration Applications

The Public Involvement Plan is intended to provide applicants and the agency with information about how public outreach will be accomplished for certain types of applications in certain geographical areas of the state. It is intended to apply to new activities; major changes at existing plants, facilities, and processes; and to activities which are likely to have significant interest from the public. This preliminary screening is designed to identify applications that will benefit from an initial assessment of the need for enhanced public outreach.

All applicable sections of this form should be completed and submitted with the permit or registration application. For instructions on how to complete this form, see TCEQ-20960-inst.

## Section 1. Preliminary Screening

New Permit or Registration Application

New Activity - modification, registration, amendment, facility, etc. (see instructions)

If neither of the above boxes are checked, completion of the form is not required and does not need to be submitted.

## Section 2. Secondary Screening

Requires public notice,

Considered to have significant public interest, and

Located within any of the following geographical locations:

- Austin
- Dallas
- Fort Worth
- Houston
- San Antonio
- West Texas
- Texas Panhandle
- Along the Texas/Mexico Border
- Other geographical locations should be decided on a case-by-case basis

If all the above boxes are not checked, a Public Involvement Plan is not necessary. Stop after Section 2 and submit the form.

Public Involvement Plan not applicable to this application. Provide **brief** explanation.

TCEQ-20960 (02-09-2023)

## **Section 3. Application Information**

## Type of Application (check all that apply):

Air Initial Federal Amendment Standard Permit Title V

Waste Municipal Solid Waste Industrial and Hazardous Waste Scrap Tire

Radioactive Material Licensing Underground Injection Control

Water Quality

Texas Pollutant Discharge Elimination System (TPDES)

Texas Land Application Permit (TLAP)

State Only Concentrated Animal Feeding Operation (CAFO)

Water Treatment Plant Residuals Disposal Permit

Class B Biosolids Land Application Permit

Domestic Septage Land Application Registration

Water Rights New Permit

New Appropriation of Water

New or existing reservoir

Amendment to an Existing Water Right

Add a New Appropriation of Water

Add a New or Existing Reservoir

Major Amendment that could affect other water rights or the environment

## Section 4. Plain Language Summary

D ' 1	1 1		C 1 1	
Provide 3	hrigt d	accrintion	of planned	activation
I I OVIUE a	титет и	CSCLIDUOL	от планиси	activities.

## Section 5. Community and Demographic Information

Community information can be found using EPA's EJ Screen, U.S. Census Bureau information, or generally available demographic tools.

Information gathered in this section can assist with the determination of whether alternative language notice is necessary. Please provide the following information.

language notice is n	ecessary. Please pro	ovide the following information.	
(City)			
(County)			
(Census Tract) Please indicate which City	h of these three is the County	ne level used for gathering the following information.  Census Tract	
(a) Percent of people	e over 25 years of age	e who at least graduated from high school	
-		r the specified location ercent of population by race within the specified location	
(d) Percent of Lingui	stically Isolated Hous	seholds by language within the specified location	
(e) Languages comm	only spoken in area b	by percentage	
(f) Community and/o	or Stakeholder Group	ps	
(g) Historic public in	iterest or involvemen	nt	

### Section 6. Planned Public Outreach Activities

(a) Is this application subject to the public participation requirements of Title 30 Texas Administrative Code (30 TAC) Chapter 39?

Yes No

(b) If yes, do you intend at this time to provide public outreach other than what is required by rule?

Yes No

If Yes, please describe.

## If you answered "yes" that this application is subject to 30 TAC Chapter 39, answering the remaining questions in Section 6 is not required.

(c) Will you provide notice of this application in alternative languages?

Yes No

Please refer to Section 5. If more than 5% of the population potentially affected by your application is Limited English Proficient, then you are required to provide notice in the alternative language.

If yes, how will you provide notice in alternative languages?

Publish in alternative language newspaper

Posted on Commissioner's Integrated Database Website

Mailed by TCEQ's Office of the Chief Clerk

Other (specify)

(d) Is there an opportunity for some type of public meeting, including after notice?

Yes No

(e) If a public meeting is held, will a translator be provided if requested?

Yes No

(f) Hard copies of the application will be available at the following (check all that apply):

TCEQ Regional Office

TCEQ Central Office

Public Place (specify)

## Section 7. Voluntary Submittal

For applicants voluntarily providing this Public Involvement Plan, who are not subject to formal public participation requirements.

Will you provide notice of this application, including notice in alternative languages?

Yes No

What types of notice will be provided?

Publish in alternative language newspaper

Posted on Commissioner's Integrated Database Website

Mailed by TCEQ's Office of the Chief Clerk

Other (specify)



## FORT BEND COUNTY MUD NO. 162 WWTP DISCHARGE PERMIT MAJOR AMENDMENT PERMIT NO. WQ0014564002

ATTACHMENT 18

Setback Easement

# METES AND BOUNDS DESCRIPTION FORT BEND COUNTY MUNICIPAL UTILITY DISTRICT NO. 162 FBCMUD NO. 162 WWTP BUFFER ZONE ACQUISITION 0.2631 ACRES IN THE J.J. DICKERSON SURVEY, ABSTRACT-401 FORT BEND COUNTY, TEXAS

A 0.2631-ACRE TRACT SITUATED IN THE J.J. DICKERSON SURVEY, ABSTRACT-401, FORT BEND, COUNTY, TEXAS, BEING WITHIN A CALLED 110.93-ACRE TRACT OF LAND DESCRIBED IN DEED TO ERNEST H. MAHLMANN. RECORDED UNDER FORT BEND COUNTY CLERK'S FILE NUMBER 9780631 OF THE OFFICIAL PUBLIC RECORDS, SAID 0.2631-ACRE TRACT BEING MORE PARTICULARLY DESCRIBED BY METES AND BOUNDS AS FOLLOWS, (BEARINGS BASED ON THE TEXAS COORDINATE SYSTEM OF 1983, SOUTH CENTRAL ZONE (4204):

**BEGINNING** at a 2-inch iron pipe found in the southwesterly right-of-way of Koeblen Road (60-foot width) at the north corner of said called 110.93 acre tract, and being the northwest corner of the herein described tract;

(1) **THENCE** South 48°09'42" East, 25.12 feet, along the southwesterly right-of-way line of said Koeblen Road and the northeasterly line of said called 110.93 acre tract to the northeast corner of the herein described tract:


THENCE over and across said called 110.93 acre tract as follows:

- in a southwesterly direction, 196.26 feet, along the arc of a curve to the right, having a radius of 165.00 feet, a central angle of 68°09'00" and a chord which bears South 36°25'43" West, 184.89 feet to a non-tangent curve to the right;
- in a southwesterly direction, 65.01 feet, along the arc of said curve to the right, having a radius of 150.00 feet, a central angle of 24°49'57" and a chord which bears South 72°59'29" West, 64.50 feet to a non-tangent curve to the right;
- in a southwesterly direction, 15.12 feet, along the arc of said curve to the right, having a radius of 150.00 feet, a central angle of 05°46'36" and a chord which bears South 80°48'49" West, 15.12 feet to a point in the southeast line of Restricted Reserve "B" of Sunrise Meadow Section One recorded under the Fort Bend County Plat Record Number 20050155 of the Official Public Records and the northwest line of said called 110.93 acre tract of land, same being the south corner of the herein described tract;
- (5) THENCE North 41°54'47" East, along the common line of said Restricted Reserve "B" and said called 110.93 acre tract, at 231.51 feet pass the east corner of said Restricted Reserve "B", continuing in all a total distance of 251.02 feet to the POINT OF BEGINNING and containing 0.2631 acres (11,459 square feet) of land.

Kevin Drew McRae Registered Professional Land Surveyor Texas Registration No. 5485 TBPELS Firm #10178700

Date: 10/22/2020 jm Job No: 1507-1802

File No: Z:\KM SURVEY\KM PROJECTS\\\1507-1802- 0.2631 ac tract desc.doc



# FBCMUD NO. 162 WWTP BUFFER ZONE ACQUISITION J.J. DICKERSON SURVEY, A-401 FORT BEND COUNTY, TEXAS

| SCALE: 1" = 100' | SCALE: 1" = 100' | SCALE: 0ctober 22, 2020 | SOUTH C - 100 | ROSENBERG, TEXAS 77471 | T13-234-6627 | Www.kmsurveying.com | SHEET 1 OF 1 | OF 1

#### **Erwin Madrid**

From: Blake Ahrendsen, E.I.T. <bahrendsen@odysseyeg.com>

**Sent:** Monday, March 10, 2025 5:20 PM

To: Erwin Madrid
Cc: Nhan Chau

Subject: RE: Application for Permit No. WQ0014564002 - Notice of Deficiency Letter

Attachments: dom-tpdes-new-nori-munechno FBC 162 WWTP 1.docx; Updated Page from Admin

Report.pdf; Updated Page from Core Data Form.pdf

Erwin,

Thank you for your correspondence on this matter. Below are responses on behalf of the District.

- 1. A change is appropriate. However, upon closer inspection it appears that "No. 1" was inadvertently left off. Please see attached updated page from the core data form
- 2. The language is Spanish. Please see attached updated page from the Administrative report.
- 3. I detect no errors in the notice provided.
- 4. Please see attached Spanish public notice document.

Blake Ahrendsen, E.I.T. Senior Project Engineer



Houston, Texas 77063 Office: 281-306-0240 ext. 112

TBPE No. F-17637

www.odysseyeg.com

HOUSTON BUSINESS JOURNAL



BEST PLACES TO WORK

From: Erwin Madrid < Erwin. Madrid@tceq.texas.gov>

Sent: Friday, March 7, 2025 12:01 PM

To: Blake Ahrendsen, E.I.T. <bahrendsen@odysseyeg.com>

Subject: Application for Permit No. WQ0014564002 - Notice of Deficiency Letter

Importance: High

Dear applicant,

The attached Notice of Deficiency letter sent on <u>March 7, 2025</u>, requests additional information needed to declare the application administratively complete. Please send the complete response to my attention by <u>March 21, 2025</u>.

Regards,

Erwin Madrid
Team Lead
ARP Team | Water Quality Division
512-239-2191
Texas Commission on Environmental Quality



Please consider whether it is necessary to print this e-mail.

(713)860-6400						( )	-		
SECTION III: I	Regula	ated Ent	ity Inform	natio	<u>n</u>				
21. General Regulated En	tity Informa	ition (If 'New Reg	ulated Entity" is selec	ted, a new	permit applica	ation is also	required.)		
☐ New Regulated Entity	Update to	Regulated Entity	Name 🔲 Update to	o Regulate	d Entity Inform	nation			
The Regulated Entity Nan as Inc, LP, or LLC).	ne submitte	d may be updat	ted, in order to mee	et TCEQ Co	ore Data Sta	ndards (re	moval of or	ganization	al endings such
22. Regulated Entity Nam	<b>e</b> (Enter nam	e of the site where	e the regulated action	is taking p	lace.)				
Fort Bend County Municipal (	Jtility District	No. 162 WWTP N	No. 1						
23. Street Address of	7102 1/2 Kd	oeblen Road							
the Regulated Entity:									
(No PO Boxes)	City	Richmond	State	ТХ	ZIP	77469		ZIP + 4	
24. County	Fort Bend	<u> </u>	I						l
		If no Stree	et Address is provid	ed, fields	25-28 are re	equired.			
25. Description to									
Physical Location:									
26. Nearest City						State		Nea	rest ZIP Code
Latitude/Longitude are re used to supply coordinate	-	-	-			ards. (Geod	coding of th	e Physical	Address may be
27. Latitude (N) In Decima		<u> </u>		28. Longitude (W) In Decir			mal:		
Degrees	Minutes		Seconds	Deg	rees	M	linutes		Seconds
29. Primary SIC Code	30.	Secondary SIC (	Code	31. Prima	ary NAICS Co	ode	32. Seco	ndary NAIC	CS Code
(4 digits)	(4 d	igits)	(5 or 6 digits)			(5 or 6 digits)			
4952				221320					
33. What is the Primary B	usiness of t	his entity? (Do	o not repeat the SIC or	NAICS des	cription.)				
Provide municipal utilities to	residents								
3200 Southwest Freeway, Sui			uite 2600						
34. Mailing Address:									
Address.	City	Houston	State	тх	ZIP	77027		ZIP + 4	
35. E-Mail Address:	hthe	ompson@abhr.co	m	<u> </u>					I
36. Telephone Number			37. Extension or 0	Code	38.	Fax Numbe	e <b>r</b> (if applicab	ole)	
( 713 ) 860-6400					(	) -			

19. Extension or Code

20. Fax Number (if applicable)

18. Telephone Number

TCEQ-10400 (11/22) Page 2 of 3

	3.	Do the location	students at n?	thes	e schools at	tend a	bilingual	educa	tion pro	gram a	t another
			Yes		No						
	4.		the school bloom out of this							gram l	out the school has
			Yes		No						
	5.		nnswer is <b>ye</b> ed. Which la								tive language are
F.	Su	mmary	of Applicat	ion i	n Plain Lang	guage T	Template				
			the F. Sumr n as the pla								) Form 20972), ment.
	At	tachme	<b>nt</b> : <u>16</u>								
G.	Pu	blic Inv	olvement P	lan F	orm						
		-					-			_	plication for a
		-	it or major	amei	ndment to a	ı permi	t and inc	lude a	s an atta	chmen	t.
	Αt	tachme	<b>nt:</b> <u>17</u>								
Se	cti	on 9.	Regula	ted 1	Entity an	d Per	mitted	Site 1	Inform	ation	(Instructions
			Page 29								(
Α.			is currently RN <u>10444355</u>	_	lated by TCI	EQ, pro	vide the I	Regula	ted Entit	ty Num	ber (RN) issued to
			TCEQ's Cer currently re				www15.tc	eq.tex	as.gov/c	rpub/	to determine if
B.	Na	me of p	roject or sit	e (the	e name knov	wn by t	he comm	unity	where lo	cated):	
	Fo	rt Bend (	County Munic	cipal 1	Utility Distric	<u>:t No. 16</u>	2 Wastew	ater Tr	eatment :	<u>Plant</u>	
C.	Ov	vner of	treatment fa	cility	: <u>Fort Bend (</u>	County 1	Municipal	<b>Utility</b>	District 1	Vo. 162	
	Ov	vnership	of Facility:	$\boxtimes$	Public		Private		Both		Federal
D.	Ov	vner of	land where t	treatr	nent facility	is or w	vill be:				
	Pre	efix: Clic	ck to enter t	ext.	Last	Name, l	First Nam	ie:			
	Tit	le: Click	k to enter te	xt.	Cred	ential: (	Click to e	nter te	ext.		
	Or	ganizati	ion Name: <u>F</u>	ort B	end County	<u>y Muni</u>	cipal Util	<u>lity Di</u>	strict No	<u>o. 162</u>	
		iling Ac 027	ldress: <u>3200</u>	Sout	hwest Freewa	ay, Suite	<u>2600</u>	City	, State, Z	Zip Coo	de: <u>Houston, TX</u>
	Ph	one No.	: <u>713-860-64</u>	00	E-ma	ail Add	ress: <u>n/a</u>				
			lowner is no t or deed red						or co-ap	plican	t, attach a lease
		Attach	ment: <u>n/a</u>								

F.

## STATEMENT OF BASIS/TECHNICAL SUMMARY AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

#### **DESCRIPTION OF APPLICATION**

Applicant: Fort Bend County Municipal Utility District No. 162;

Texas Pollutant Discharge Elimination System (TPDES) Permit No.

WQ0014564002, EPA I.D. No. TX0147559

Regulated Activity: Domestic Wastewater Permit

Type of Application: New Permit

Request: New Permit

Authority: Federal Clean Water Act (CWA) § 402; Texas Water Code § 26.027; 30

Texas Administrative Code (TAC) Chapters 30, 305, 307, 309, 312, and 319; Commission policies; and United States Environmental Protection

Agency (EPA) guidelines.

## **EXECUTIVE DIRECTOR RECOMMENDATION**

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **five years from the date of issuance**.

#### REASON FOR PROJECT PROPOSED

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for a new permit to authorize the discharge of treated domestic wastewater at a daily average flow not to exceed 0.35 million gallons per day (MGD) in the Interim phase and a daily average flow not to exceed 0.45 MGD in the Final phase. This facility was previously permitted under TPDES Permit No. WQ0014564001. The existing wastewater treatment facility serves Fort Bend County MUD No. 162.

## PROJECT DESCRIPTION AND LOCATION

The Fort Bend County MUD 162 Wastewater Treatment Facility is an activated sludge process plant operated in the complete mix mode with nitrification. Treatment units in the Interim phase include a manual bar screen, seven aeration basins, four final clarifiers, four aerobic digesters and four chlorine contact chambers. Treatment units in the Final phase will include a manual bar screen followed by seven aeration basins, four final clarifiers, four aerobic sludge digesters and four chlorine contact chambers. The facility is operating in the Interim phase.

Sludge generated from the treatment facility is hauled by a registered transporter to City of Rosenberg STP #2, Permit No. WQ0010607002, to be digested, dewatered, and then disposed of with the bulk of the sludge from the plant accepting the sludge. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

The plant site is located at 7102 1/2 Koeblen Road, in Fort Bend County, Texas 77469.

#### Outfall Location:

Outfall Number	Latitude	Longitude	
001	29.501615 N	95.758782 W	

The treated effluent is discharged to Fort Bend County Drainage District (FBCDD Ditch II-B-7), thence to Big Creek, thence to the Brazos River Below Navasota River in Segment No. 1202 of the Brazos River Basin. The unclassified receiving water use is minimal aquatic life use for FBCDD Ditch II-B-7. The designated uses for Segment No. 1202 are primary contact recreation, public water supply, and high aquatic life use. The effluent limitations in the draft permit will maintain and protect the existing instream uses. In accordance with 30 Texas Administrative Code §307.5 and the TCEQ's *Procedures to Implement the Texas Surface Water Quality Standards* (June 2010), an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. This review has preliminarily determined that no water bodies with exceptional, high, or intermediate aquatic life uses are present within the stream reach assessed; therefore, no Tier 2 degradation determination is required. No significant degradation of water quality is expected in water bodies with exceptional, high, or intermediate aquatic life uses downstream, and existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received.

Effluent limitations for the conventional effluent parameters (i.e., Five-Day Biochemical Oxygen Demand or Five-Day Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water-quality limited streams as established in the Texas Surface Water Quality Standards (TSWQS) and the State of Texas Water Quality Management Plan (WQMP).

In a case such as this, end-of-pipe compliance with pH limits between 6.0 and 9.0 standard units reasonably assures instream compliance with the TSWQS for pH when the discharge authorized is from a minor facility. This technology-based approach reasonably assures instream compliance with TSWQS criteria due to the relatively smaller discharge volumes authorized by these permits. This conservative assumption is based on TCEQ sampling conducted throughout the state which indicates that instream buffering quickly restores pH levels to ambient conditions. Similarly, this approach has been historically applied within EPA issued NPDES general permits where technology-based pH limits were established to be protective of water quality criteria.

The effluent limits recommended above have been reviewed for consistency with the State of Texas WQMP. The proposed limits are consistent with the approved WQMP under expired Permit No. WQ0014564001.

The Houston toad (Bufo houstonensis Sanders), an endangered aquatic-dependent species of critical concern, occurs within the watershed of Segment No. 1202 as well as the United States Geological Survey hydrologic unit code 12070104. This determination is based on the United States Fish and Wildlife Service's (USFWS) biological opinion on the State of Texas authorization of the Texas Pollutant Discharge Elimination System (TPDES; September 14, 1998, October 21, 1998 update). To make this determination for TPDES permits, TCEQ and EPA only consider aquatic or aquatic dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. Species distribution information for the Segment 1202 watershed is provided by the USFWS and documents the toad's presence solely in the vicinity of Deep Creek in Austin County, which is farther up the watershed from the facility associated with this permit

action. Based upon this information, it is determined that the facility's discharge is not expected to impact the Houston toad. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Segment No. 1202 is not currently listed in the State's inventory of impaired and threatened waters (the 2024 Clean Water Act Section 303(d) list). However, Big Creek (1202J) is currently listed for bacteria in water (recreation use) from the confluence of the Brazos River upstream to the confluence of Cottonwood Creek and Coon Creek (Assessment Units [AU] 1202J\_01 and 1202J\_02). This facility is designed to provide adequate disinfection and, when operated properly, should not add to the bacterial impairment of the segment. In addition, in order to ensure that the proposed discharge meets the stream bacterial standard, an effluent limitation of 126 colony-forming units (CFU) or most probable number (MPN) of *Escherichia coli* (*E. coli*) per 100 ml has been added to the draft permit.

#### SUMMARY OF EFFLUENT DATA

The following is a summary of the applicant's effluent monitoring data for the period January 2023 through January 2025 under WQ0014564001. The average of Daily Average value is computed by the averaging of all 30-day average values for the reporting period for each parameter: flow, five-day carbonaceous biochemical oxygen demand (CBOD $_5$ ), total suspended solids (TSS), and ammonia nitrogen (NH $_3$ -N). The average of Daily Average value for *E. coli* CFU or MPN per 100 ml is calculated via geometric mean.

<u>Parameter</u>	Average of Daily Average
Flow, MGD	0.30
CBOD <sub>5</sub> , mg/l	3.7
TSS, mg/l	3.8
NH <sub>3</sub> -N, mg/l	0.43
E. coli, CFU or MPN per 100 ml	1.0

#### DRAFT PERMIT CONDITIONS

The draft permit authorizes a discharge of treated domestic wastewater at an Interim volume not to exceed a daily average flow of 0.35 MGD and a Final volume not to exceed a daily average flow of 0.45 MGD.

The effluent limitations in the Interim and Final phases of the draft permit, based on a 30-day average, are 10 mg/l  $CBOD_5$ , 15 mg/l TSS, 3 mg/l  $NH_3$ -N, 126 CFU or MPN of *E. coli* per 100 ml, and 4.0 mg/l minimum dissolved oxygen (DO). The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes based on peak flow.

The permittee shall comply with the requirements of 30 TAC § 309.13(a) through (d). In addition, by ownership of the required buffer zone area, the permittee shall comply with the requirements of 30 TAC § 309.13(e) and the draft permit includes a requirement for the permittee to obtain legal restrictions prohibiting residential structures within the part of the buffer zone not owned by the permittee according to 30 TAC § 309.13(e)(3).

The Fort Bend County MWD No 162 WWTP No. 1 does not appear to receive significant industrial wastewater contributions. Based on the information provided by the permittee in the most recent TPDES permit application, the TCEQ determined that there are no significant industrial wastewater contributions currently being discharged to the permittee's POTW. Permit requirements for pretreatment are based on TPDES regulations contained in 30 TAC Chapter 305, which references 40

Code of Federal Regulations (CFR) Part 403, "General Pretreatment Regulations for Existing and New Sources of Pollution" [rev. Federal Register/Vol. 70/No. 198/Friday, October 14, 2005/Rules and Regulations, pages 60134-60798]. The permit includes specific requirements that establish responsibilities of local government, industry, and the public to implement the standards to control pollutants which pass through or interfere with treatment processes in publicly owned treatment works or which may contaminate the sewage sludge. This permit has appropriate pretreatment language for a facility of this size and complexity.

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal, and Transportation. Sludge generated from the treatment facility is hauled by a registered transporter to City of Rosenberg STP #2, Permit No. WQ0010607002, to be digested, dewatered, and then disposed of with the bulk of the sludge from the plant accepting the sludge. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, codisposal landfill, wastewater treatment facility, or facility that further processes sludge.

## SUMMARY OF CHANGES FROM APPLICATION

None.

#### BASIS FOR DRAFT PERMIT

The following items were considered in developing the draft permit:

- 1. Application received on February 28, 2025, and additional information received on July 18, 2025.
- 2. This facility was previously permitted under TPDES Permit No. WQ0014564001.
- 3. The effluent limitations and conditions in the draft permit comply with EPA-approved portions of the 2018 Texas Surface Water Quality Standards (TSWQS), 30 TAC §§ 307.1 307.10, effective March 1, 2018; 2014 TSWQS, effective March 6, 2014; 2010 TSWQS, effective July 22, 2010; and 2000 TSWQS, effective July 26, 2000.
- 4. The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Effluent Limitations.
- 5. Interoffice Memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division. Interoffice Memorandum from the Pretreatment Team of the TCEQ Water Quality Division.
- 6. Consistency with the Coastal Management Plan: The facility is not located in the Coastal Management Program boundary.
- 7. Procedures to Implement the Texas Surface Water Quality Standards (IP), Texas Commission on Environmental Quality, June 2010, as approved by EPA, and the IP, January 2003, for portions of the 2010 IP not approved by EPA.
- 8. Texas 2024 CWA § 303(d) List, Texas Commission on Environmental Quality, June 26, 2024; approved by the EPA on November 13, 2024.
- 9. Texas Natural Resource Conservation Commission, Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.

## PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Sumitra Pokharel at (512) 239-4722.

Sumítra Pokharel	July 21, 2025
Sumitra Pokharel	Date
Municipal Permits Team	
Wastewater Permitting Section (MC 148)	