

This file contains the following documents:

- 1. Summary of application (in plain language)
 - English
 - Alternative Language (Spanish)
- 2. First notice (NORI-Notice of Receipt of Application and Intent to Obtain a Permit)
 - English
 - Alternative Language (Spanish)
- 3. Second notice (NAPD-Notice of Preliminary Decision)
 - English
 - Alternative Language (Spanish)
- 4. Application materials
- 5. Draft permit
- 6. Technical summary or fact sheet



Este archivo contiene los siguientes documentos:

- 1. Resumen de la solicitud (en lenguaje sencillo)
 - Inglés
 - Idioma alternativo (español)
- 2. Primer aviso (NORI, Aviso de Recepción de Solicitud e Intención de Obtener un Permiso)
 - Inglés
 - Idioma alternativo (español)
- 3. Segundo aviso (NAPD, Aviso de Decisión Preliminar)
 - Inglés
 - Idioma alternativo (español)
- 4. Materiales de la solicitud
- 5. Proyecto de permiso
- 6. Resumen técnico u hoja de datos

Plain Language Summary - TPDES New Application

If you are subject to the alternative language notice requirements in <u>30 Texas Administrative Code</u> §39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

NMCV Taylor Property Investors LLC (CN#606270122) proposes to operate 487 Acre Taylor Tract Wastewater Treatment Plant (RN #111984464). a 0.15 MGD WWTP facility. The facility will be located Approximately 0.16 miles Northeast from the intersection of FM 112 and Tucek Road, in Taylor, Williamson County, Texas 76574.

This is for a new application to discharge processed wastewater at an average daily flow of 150,000 gallons per day on an intermittent and flow-variable basis.

Discharges from the facility are expected to containfive-day carbonaceous biochemical oxygen demand $(CBOD_5)$, total suspended solids (TSS), ammonia nitrogen (NH $_3$ -N), and *Escherichia Coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Domestic wastewater will be treated by a suspended growth activated sludge process in extended aeration mode and the treatment units will include a mechanical auger screen, equalization basin, aeration tanks, a chlorine contact chamber.

PLANTILLA EN INGLÉS PARA SOLICITUDES DE NUEVA/RENOVACIÓN/ENMIENDA TPDES o TLAP

AGUAS RESIDUALES DOMÉSTICAS

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo exige el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es federal. representaciones ejecutables de la solicitud de permiso.

NMCV Taylor Property Investors LLC (CN#606270122) propone operar la planta de tratamiento de aguas residuales de 487 Acre Taylor Tract (RN#111984464). una instalación de PTAR de 0.15 MGD. La instalación estará ubicada aproximadamente a 0,16 millas al noreste de la intersección de FM 112 y Tucek Road, en Taylor, condado de Williamson, Texas 76574.

Esto es para una nueva aplicación para descargar aguas residuales procesadas a un flujo diario promedio de 150,000 galones por día de forma intermitente y de flujo variable.

Se espera que las descargas de la instalación contengan demanda bioquímica de oxígeno carbonoso (CBOD5) de cinco días, sólidos suspendidos totales (SST), nitrógeno amoniacal (NH3-N) y Escherichia coli. Se incluyen contaminantes potenciales adicionales en el Informe Técnico Nacional 1.0, Sección 7. Las aguas residuales domésticas serán tratadas mediante un proceso de lodos activados de crecimiento suspendido en modo de aireación extendida y las unidades de tratamiento incluirán una criba de tornillo mecánico, un estanque de ecualización, tanques de aireación, un sistema de cloro. cámara de contacto.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



NOTICE OF RECEIPT OF APPLICATION AND INTENT TO OBTAIN WATER QUALITY PERMIT PROPOSED

PERMIT NO. WQ0016554001

APPLICATION. NMCV Taylor Property Investors LLC. 2225 High Lonesome, Leander, Texas 78641, has applied to the Texas Commission on Environmental Quality (TCEQ) for proposed Texas Pollutant Discharge Elimination System (TPDES) Permit No. WO0016554001 (EPA I.D. No. TX0146153) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 150,000 gallons per day. The domestic wastewater treatment facility will be located approximately 0.16 miles northeast of the intersection of Farm-to-Market Road 112 and Tucek Road, near the city of Taylor, in Williamson County, Texas 76574. The discharge route will be from the plant site to an unnamed tributary; thence to Mustang Creek; thence to Brushy Creek. TCEQ received this application on May 31, 2024. The permit application will be available for viewing and copying at City of Taylor Public Library, Public Viewing Board, 801 Vance Street, Taylor, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage: https://www.tceq.texas.gov/permitting/wastewater/pendingpermits/tpdes-applications. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceg.texas.gov/LocationMapper/?marker=-97.358888,30.565277&level=18

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

ADDITIONAL NOTICE. TCEQ's Executive Director has determined the application is administratively complete and will conduct a technical review of the application. After technical review of the application is complete, the Executive Director may prepare a draft permit and will issue a preliminary decision on the application. Notice of the Application and Preliminary Decision will be published and mailed to those who are on the countywide mailing list and to those who are on the mailing list for this application. That notice will contain the deadline for submitting public comments.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting on this application. The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ will hold a public meeting if the Executive Director determines that there is a significant degree of public

interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments, and the Executive Director's decision on the application, will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting reconsideration of the Executive Director's decision and for requesting a contested case hearing. A contested case hearing is a legal proceeding similar to a civil trial in state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period and, the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. All public comments and requests must be submitted either electronically at https://www14.tceq.texas.gov/epic/eComment/, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Please be aware that any contact information you provide, including your name, phone number, email address and physical address will become part of the agency's public record. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from NMCV Taylor Property Investors LLC at the address stated above or by calling Ms. Lauren Crone, P.E., Senior Project Manager, LJA Engineering, Inc., at 512-439-4700.

Issuance Date: July 10, 2024

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA

PERMISO PROPUESTO NO. WQ0016554001

SOLICITUD. NMCV Taylor Property Investors LLC, 2225 High Lonesome, Leander, Texas 78641, tiene solicitó a la Comisión de Calidad Ambiental de Texas (TCEQ) la propuesta de Texas Permiso del Sistema de Eliminación de Descarga de Contaminantes (TPDES) No. WQ0016554001 (EPA I.D. No. TX0146153) para autorizar la descarga de aguas residuales tratadas en un volumen que no exceda el diario Flujo promedio de 150,000 galones por día. La instalación de tratamiento de aguas residuales domésticas será ubicado aproximadamente a 0.16 millas al noreste de la intersección de Farm-to-Market Road 112 y Tucek Road, cerca de la ciudad de Taylor, en el condado de Williamson, Texas 76574. La ruta de descarga será desde el sitio de la planta hasta un afluente no identificado; de allí a Mustang Creek; de allí a Brushy Creek. La TCEQ recibió esta solicitud el 31 de mayo de 2024. La solicitud de permiso estará disponible para ver y copiar en la Biblioteca Pública de la Ciudad de Taylor, la Junta de Visualización Pública, 801 Vance Street, Taylor, TX 76574, Taylor, Texas antes de la fecha de publicación de este aviso en el periódico. La aplicación, incluidas las actualizaciones y los avisos asociados, están disponibles. electrónicamente en la siguiente página web: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdesapplications. Este El enlace a un mapa electrónico de la ubicación general del sitio o instalación se proporciona como acceso público. cortesía y no forma parte de la solicitud o notificación. Para conocer la ubicación

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.35881,30.565409&level=18

exacta, consulte la solicitud.

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca

de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general: una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las

solicitudes en un condado especifico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía http://www14.tceq.texas.gov/epic/eComment/ o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del NMCV Taylor Property Investors LLC a la dirección indicada arriba o llamando a Senora Lauren Crone, P.E., Senior Project Manager al (512) 439-4700.

Fecha de emisión 10 de julio de 2024

Texas Commission on Environmental Quality



COMBINED

NOTICE OF PUBLIC MEETING

AND

NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR MUNICIPAL WASTEWATER

NEW

PERMIT NO. WQ0016554001

APPLICATION AND PRELIMINARY DECISION. NMCV Taylor Property Investors LLC, 2225 High Lonesome, Leander, Texas 78641, has applied to the Texas Commission on Environmental Quality (TCEQ) for new Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0016554001, to authorize the discharge of treated domestic wastewater at a daily average flow not to exceed 150,000 gallons per day. TCEQ received this application on May 31, 2024.

The facility will be located approximately 0.16 miles northeast of the intersection of Farm-to-Market Road 112 and Tucek Road, in Williamson County, Texas 76574. The treated effluent will be discharged to an unnamed tributary, thence to Mustang Creek, thence to Brushy Creek in Segment No. 1244 of the Brazos River Basin. The unclassified receiving water use is limited aquatic life use for the unnamed tributary. The designated uses for Segment No. 1244 are primary contact recreation, public water supply, aquifer protection, and high aquatic life use. In accordance with 30 Texas Administrative Code §307.5 and the *Procedures to Implement the Texas Surface Water Quality Standards* (June 2010), an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. This review has preliminarily determined that no water bodies with exceptional, high, or intermediate aquatic life uses are present within the stream reach assessed; therefore, no Tier 2 degradation determination is required. No significant degradation of water quality is expected in water bodies with exceptional, high, or intermediate aquatic life uses downstream, and existing uses will be maintained and protected.

The preliminary determination can be reexamined and may be modified if new information is received. This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.358888.30.565277&level=18

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at City of Taylor Public Library, Public Viewing Board, 801 Vance Street, Taylor, Texas. The application, including any updates, and associated notices are available electronically at the following webpage: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

ALTERNATIVE LANGUAGE NOTICE. Alternative language notice in Spanish is available at https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices.

PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments about this application. The TCEQ will hold a public meeting on this application because it was requested by local and state legislators and the public.

The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. A public meeting will be held and will consist of two parts, an Informal Discussion Period and a Formal Comment Period. A public meeting is not a contested case hearing under the Administrative Procedure Act. During the Informal Discussion Period, the public will be encouraged to ask questions of the applicant and TCEQ staff concerning the permit application. The comments and questions submitted orally during the Informal Discussion Period will not be considered before a decision is reached on the permit application and no formal response will be made. Responses will be provided orally during the Informal Discussion Period. During the Formal Comment Period on the permit application, members of the public may state their formal comments or ally into the official record. A written response to all timely, relevant and material, or significant comments will be prepared by the Executive Director. All formal comments will be considered before a decision is reached on the permit application. A copy of the written response will be sent to each person who submits a formal comment or who requested to be on the mailing list for this permit application and provides a mailing address. Only relevant and material issues raised during the Formal Comment Period can be considered if a contested case hearing is granted on this permit application.

The Public Meeting is to be held:

...26...day, August......, 2025 at 7:00 PM (Venue)

Persons with disabilities who need special accommodations at the meeting should call the Office of the Chief Clerk at (512) 239-3300 or 1-800-RELAY-TX (TDD) at least one week prior to the meeting.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision. A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period.

EXECUTIVE DIRECTOR ACTION. The Executive Director may issue final approval of the application unless a timely contested case hearing request or request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

MAILING LIST. If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, Texas Commission on Environmental Quality, P.O. Box 13087, Austin, TX 78711-3087 or electronically at www.tceq.texas.gov/goto/comment within 30 days from the date of newspaper publication of this notice, or by the date of the public meeting, whichever is later.

INFORMATION AVAILABLE ONLINE. For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. Public comments and requests must be submitted either electronically at www.tceq.texas.gov/goto/comment, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC 105, P.O. Box 13087, Austin, Texas 78711-3087. Any personal information you submit to the TCEQ will become part of the agency's record; this includes email addresses. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from NMCV Taylor Property Investors LLC at the address stated above or by calling Ms. Lauren Crone, P.E., Senior Project Manager, LJA Engineering, Inc., at 512-439-4700.

Issuance Date:	
----------------	--

Comisión de Calidad Ambiental de Texas



COMBINADO

AVISO DE REUNIÓN PÚBLICA

Y

AVISO DE SOLICITUD Y DECISIÓN PRELIMINAR PARA EL PERMISO DEL TPDES PARA AGUAS RESIDUALES MUNICIPALES

NUEVO

PERMISO NO. WQ0016554001

SOLICITUD Y DECISIÓN PRELIMINAR. NMCV Taylor Property Investors LLC, 2225 High Lonesome, Leander, Texas 78641, ha solicitado a la Comisión de Calidad Ambiental de Texas (TCEQ) un nuevo Permiso para el Sistema de Eliminación de Descargas Contaminantes de Texas (TPDES), n.º WQ0016554001, para autorizar la descarga de aguas residuales domésticas tratadas con un caudal promedio diario que no exceda los 150,000 galones por día. La TCEQ recibió esta solicitud el 31 de mayo de 2024.

La instalación estará ubicada aproximadamente a 0.16 millas al noreste de la intersección de Farm-to-Market Road 112 y Tucek Road, en el Condado de Williamson, Texas 76574. El efluente tratado se descargará a un afluente sin nombre, de allí al arroyo Mustang y, posteriormente, al arroyo Brushy, en el segmento n.º 1244 de la cuenca del río Brazos. El uso no clasificado de las aguas receptoras es un uso limitado para la vida acuática en el afluente sin nombre. Los usos designados para el Segmento n.º 1244 son la recreación de contacto primario, el suministro público de agua, la protección de acuíferos y el uso intensivo de la vida acuática. De conformidad con el Título 30 del Código Administrativo de Texas, §307.5, y los *Procedimientos para la Implementación de los Estándares de Calidad de las Aguas Superficiales de Texas* (junio de 2010), se realizó una revisión de antidegradación de las aguas receptoras. Una revisión de antidegradación de Nivel 1 determinó preliminarmente que los usos actuales de la calidad del agua no se verán afectados por esta medida de permiso. Numerical and narrative criteria to protect existing uses will be maintained. Se mantendrán los criterios numéricos y narrativos para proteger los usos existentes.

Esta revisión ha determinado preliminarmente que no existen cuerpos de agua con usos excepcionales, altos o intermedios para la vida acuática dentro del tramo fluvial evaluado; por lo tanto, no se requiere una determinación de degradación de Nivel 2. No se prevé una degradación significativa de la calidad del agua en cuerpos de agua con usos excepcionales, altos o intermedios para la vida acuática aguas abajo, y se mantendrán y protegerán los usos existentes. La determinación preliminar podrá reexaminarse y modificarse si se recibe nueva información. Este enlace a un mapa electrónico de la ubicación general del sitio o instalación se proporciona como cortesía pública y no forma parte de la solicitud ni del aviso. Para conocer la ubicación exacta, consulte la solicitud:

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.358888,30.565277&level=18

El Director Ejecutivo de la TCEQ ha completado la revisión técnica de la solicitud y ha preparado un borrador del permiso. De aprobarse, este borrador establecería las condiciones de funcionamiento de la instalación. El Director Ejecutivo ha determinado preliminarmente que este permiso, de expedirse, cumple con todos los requisitos legales y reglamentarios. La solicitud de permiso, la decisión preliminar del Director Ejecutivo y el borrador del permiso están disponibles para consulta y copia en la Biblioteca Pública de la Ciudad de Taylor, Junta de Consulta Pública, 801 Vance Street, Taylor, Texas. La solicitud, incluyendo sus actualizaciones y los avisos correspondientes, está disponible electrónicamente en la siguiente página web:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications.

AVISO DE LENGUAJE ALTERNATIVO. El aviso de lenguaje alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices. El aviso de idioma alternativo en español está disponible en https://www.tceq.texas.gov/permitting/wastewater/plain-language-summaries-and-public-notices.

COMENTARIOS PÚBLICOS / REUNIÓN PÚBLICA. Puede enviar comentarios públicos sobre esta solicitud. La TCEQ celebrará una reunión pública sobre esta solicitud, ya que así lo solicitaron los legisladores locales y estatales, y el público.

El propósito de una reunión pública es brindar la oportunidad de presentar comentarios o hacer preguntas sobre la solicitud. Se llevará a cabo una reunión pública que constará de dos partes: un Período de Discusión Informal y un Período de Comentarios Formales. Una reunión pública no es una audiencia de caso impugnado según la Ley de Procedimiento Administrativo. Durante el Período de Discusión Informal, se animará al público a hacer preguntas al solicitante y al personal de TCEQ sobre la solicitud de permiso. Los comentarios y preguntas presentados oralmente durante el Período de Discusión Informal no se considerarán antes de que se tome una decisión sobre la solicitud de permiso y no se dará una respuesta formal. Las respuestas se proporcionarán oralmente durante el Período de Discusión Informal. Durante el Período de Comentarios Formales sobre la solicitud de permiso, los miembros del público pueden presentar sus comentarios formales oralmente en el registro oficial. El Director Ejecutivo preparará una respuesta por escrito a todos los comentarios oportunos, relevantes, materiales o significativos. Todos los comentarios formales se considerarán antes de que se tome una decisión sobre la solicitud de permiso. Se enviará una copia de la respuesta escrita a cada persona que presente un comentario formal o que haya solicitado suscribirse a la lista de correo para esta solicitud de permiso y proporcione una dirección postal. Solo se considerarán las cuestiones relevantes y sustanciales planteadas durante el Período de Comentarios Formales si se concede una audiencia de caso contencioso sobre esta solicitud de permiso.

La reunión pública se celebrará:

.....day,, 2025 at 7:00 PM (Venue)

Las personas con discapacidades que necesiten adaptaciones especiales en la reunión deben llamar a la Oficina del Secretario Jefe al (512) 239-3300 o 1-800-RELAY-TX (TDD) al menos una semana antes de la reunión.

OPORTUNIDAD PARA UNA AUDIENCIA DE CASO CONTROVERTIDO. Tras la fecha límite para la presentación de comentarios públicos, el Director Ejecutivo considerará todos los comentarios oportunos y preparará una respuesta a todos los comentarios públicos relevantes, sustanciales o significativos. A menos que la solicitud se remita directamente a una audiencia de caso controvertido, la respuesta a los comentarios se enviará por correo a todos los que presentaron comentarios públicos y a las personas que estén en la lista de correo de esta solicitud. Si se reciben comentarios, el correo también incluirá instrucciones para solicitar una audiencia de caso controvertido o la reconsideración de la decisión del Director Ejecutivo. Una audiencia de caso controvertido es un procedimiento legal similar a un juicio civil en un tribunal de distrito estatal.

PARA SOLICITAR UNA AUDIENCIA DE CASO CONTROVERTIDO, DEBE INCLUIR LOS SIGUIENTES DATOS EN SU SOLICITUD: su nombre, dirección, número de teléfono; nombre del solicitante y número de permiso propuesto; la ubicación y distancia de su propiedad/actividades con respecto a la instalación propuesta; una descripción específica de cómo la instalación le afectaría negativamente de una manera inusual para el público general; una lista de todas las cuestiones de hecho controvertidas que presente durante el período de comentarios; y la declaración "[Yo/Nosotros] solicito/solicitamos una audiencia de caso controvertido". Si la solicitud de audiencia de caso controvertido se presenta en nombre de un grupo o asociación, la solicitud debe designar al representante del grupo para recibir correspondencia futura; identificar por nombre y dirección física a un miembro del grupo que se vería afectado negativamente por la instalación o actividad propuesta; proporcionar la información mencionada anteriormente sobre la ubicación y distancia del miembro afectado con respecto a la instalación o actividad; explicar cómo y por qué el miembro se vería afectado; y explicar cómo los intereses que el grupo busca proteger son relevantes para su propósito.

Una vez finalizados todos los períodos de comentarios y solicitudes aplicables, el Director Ejecutivo enviará la solicitud y cualquier solicitud de reconsideración o de audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración en una reunión programada de la Comisión.

La Comisión solo podrá conceder una solicitud de audiencia de caso controvertido sobre cuestiones que el solicitante presentó en sus oportunas observaciones y que no fueron posteriormente retiradas. Si se concede la audiencia, el tema de la misma se limitará a cuestiones de hecho controvertidas o cuestiones mixtas de hecho y de derecho relacionadas con preocupaciones relevantes y sustanciales sobre la calidad del agua presentadas durante el período de observaciones.

ACCIÓN DEL DIRECTOR EJECUTIVO. El Director Ejecutivo podrá emitir la aprobación final de la solicitud a menos que se presente oportunamente una solicitud de audiencia de caso impugnado o una solicitud de reconsideración. Si se presenta oportunamente una solicitud de audiencia o de reconsideración, el Director Ejecutivo no emitirá la aprobación final del permiso y remitirá la solicitud y la solicitud a los Comisionados de la TCEQ para su consideración en una reunión programada de la Comisión.

LISTA DE CORREO. Si presenta comentarios públicos, solicita una audiencia de caso impugnado o una reconsideración de la decisión del Director Ejecutivo, se le añadirá a la lista de correo de esta solicitud específica para recibir futuras notificaciones públicas enviadas por la Oficina del Secretario General. Además, puede solicitar ser incluido en: (1) la lista de correo permanente para un solicitante y número de permiso específicos; y/o (2) la lista de correo de un condado específico. Si desea ser incluido en la lista de correo permanente o en la lista de correo del condado, especifique claramente cuál(es) y envíe su solicitud a la Oficina del Secretario General de la TCEQ a la dirección que figura a continuación.

Todos los comentarios públicos escritos y las solicitudes de reuniones públicas deben enviarse a la Oficina del Secretario Principal, MC 105, Comisión de Calidad Ambiental de Texas, P.O. Box 13087, Austin, TX 78711-3087 o electrónicamente a www.tceq.texas.gov/goto/comment dentro de los 30 días a partir de la fecha de publicación de este aviso en el periódico, o antes de la fecha de la reunión pública, lo que ocurra más tarde.

INFORMACIÓN DISPONIBLE EN LÍNEA. Para obtener más información sobre el estado de la solicitud, visite la Base de Datos Integrada de Comisionados en www.tceq.texas.gov/goto/cid. Busque en la base de datos utilizando el número de permiso de esta solicitud, que se encuentra en la parte superior de este aviso.

CONTACTOS E INFORMACIÓN DE LA AGENCIA. Los comentarios y solicitudes del público deben enviarse electrónicamente a través de www.tceq.texas.gov/goto/comment o por escrito a la Comisión de Calidad Ambiental de Texas, Oficina del Secretario Principal, MC 105, Apartado Postal 13087, Austin, Texas 78711-3087. Toda información personal que proporcione a la TCEQ formará parte del registro de la agencia, incluidas las direcciones de correo electrónico. Para obtener más información sobre esta solicitud de permiso o el proceso de obtención de permisos, llame al Programa de Educación Pública de la TCEQ, sin costo, al 1-800-687-4040 o visite su sitio web: www.tceq.texas.gov/goto/pep. Si desea información en español, puede llamar al 1-800-687-4040.

También se puede obtener más información de NMCV Taylor Property Investors LLC en la dirección indicada anteriormente o llamando a la Sra. Lauren Crone, P.E., Gerente de Proyecto Sénior, LJA Engineering, Inc., al 512-439-4700.

Issuance Date:	

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY DOMESTIC WASTEWATER PERMIT APPLICATION FOR A TEXAS POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

FOR

487 ACRE TAYLOR TRACT WASTEWATER TREATMENT PLANT

MAY 2024

PREPARED FOR

NMCV TAYLOR PROPERTY INVESTORS, LLC 2225 High Lonesome Leander, TX 78641-3296

PREPARED BY

LJA Engineering, Inc. 7500 RIALTO BLVD BUILDING II, SUITE 100 Austin, Texas 78735 (512) 439-4700



TABLE OF CONTENTS

EXHIBIT 1: ADMINISTRATIVE REPORTS 1.0 AND 1.1

EXHIBIT 2: DOMESTIC TECHNICAL REPORT 1.0

DOMESTIC TECHNICAL REPORT 1.1

DOMESTIC TECHNICAL REPORT WORKSHEET 2.0

DOMESTIC TECHNICAL REPORT WORKSHEET 2.1

APPENDIX A: PLAIN LANGUAGE SUMMARY

APPENDIX B: CORE DATA FORM

APPENDIX C: PUBLIC INVOLVEMENT PLAN FORM

APPENDIX D: USGS MAPS

APPENDIX E: AFFECTED LANDOWNER MAP AND LIST

APPENDIC F: ORIGINAL PHOTOGRAPHS

APPENDIX G: BUFFER ZONE MAP

APPENDIX H: SPIF MAPS

APPENDIX I: PROCESS FLOW DIAGRAM

APPENDIX J: SITE DRAWING

APPENDIX K: DESIGN CALCULATIONS

APPENDIX L: FEMA FLOOD MAPS

APPENDIX M: WIND ROSE

APPENDIX N: SEWAGE SOLIDS MANAGEMENT PLAN

APPENDIX O: NEARBY WWTP MAP AND LETTERS

APPENDIX P: REGIONALIZATION AND COST DISCUSSION

APPENDIX Q: TRANSECT LOCATION MAP

EXHIBIT 1

ADMINISTRATIVE REPORTS 1.0 AND 1.1

THE TONMENTAL OURS

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST

Complete and submit this checklist with the application.

PERMIT NUMBER (If new, leave blank): WQ00 Click to enter text.

Indicate if each of the following items is included in your application.

	1	11		Y	IN
Administrative Report 1.0	\boxtimes		Original USGS Map	\boxtimes	
Administrative Report 1.1	\boxtimes		Affected Landowners Map	\boxtimes	
SPIF	\boxtimes		Landowner Disk or Labels	\boxtimes	
Core Data Form	\boxtimes		Buffer Zone Map	\boxtimes	
Public Involvement Plan Form	\boxtimes		Flow Diagram	\boxtimes	
Technical Report 1.0	\boxtimes		Site Drawing	\boxtimes	
Technical Report 1.1	\boxtimes		Original Photographs	\boxtimes	
Worksheet 2.0	\boxtimes		Design Calculations	\boxtimes	
Worksheet 2.1	\boxtimes		Solids Management Plan	\boxtimes	
Worksheet 3.0			Water Balance		\boxtimes
Worksheet 3.1					
Worksheet 3.2					
Worksheet 3.3		\boxtimes			
Worksheet 4.0					
Worksheet 5.0					
Worksheet 6.0					
Worksheet 7.0		\boxtimes			

For TCEQ Use Only	
Segment Number	County
Expiration Date	Region
Permit Number	

THE TONMENTAL OURS

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

For any questions about this form, please contact the Applications Review and Processing Team at 512-239-4671.

Section 1. Application Fees (Instructions Page 26)

Indicate the amount submitted for the application fee (check only one).

Flow	New/Major Amendment	Renewal
< 0.05 MGD	\$350.00 □	\$315.00 □
≥0.05 but <0.10 MGD	\$550.00 □	\$515.00 □
≥0.10 but <0.25 MGD	\$850.00 ⊠	\$815.00 □
≥0.25 but <0.50 MGD	\$1,250.00 □	\$1,215.00
≥0.50 but <1.0 MGD	\$1,650.00 □	\$1,615.00 □
≥1.0 MGD	\$2,050.00 □	\$2,015.00

Minor Amendment (for any flow) \$150.00 □

Da-		Traform	ti
Pay	yment	шоп	nation

Mailed Check/Money Order Number: Click to enter text.
Check/Money Order Amount: \$850.00
Name Printed on Check: TCEQ

EPAY Voucher Number: Click to enter text.

Copy of Payment Voucher enclosed? Yes □

Section 2. Type of Application (Instructions Page 26)

a.	. Check the box next to the appropriate authorization type	
		Publicly-Owned Domestic Wastewater
	\boxtimes	Privately-Owned Domestic Wastewater
		Conventional Wastewater Treatment
b.	Che	ck the box next to the appropriate facility status.

 \square Active \boxtimes Inactive

c.	Che	ck the box next to the appropriate permit type	e.	
	\boxtimes	TPDES Permit		
		TLAP		
		TPDES Permit with TLAP component		
		Subsurface Area Drip Dispersal System (SAD	DS)	
d. Check the box next to the appropriate application type				e
	\boxtimes	New		
		Major Amendment <u>with</u> Renewal		Minor Amendment <i>with</i> Renewal
		Major Amendment without Renewal		Minor Amendment without Renewal
		Renewal without changes		Minor Modification of permit
e.	For	amendments or modifications, describe the p	ropo	sed changes: Click to enter text.
f.	For	existing permits:		
		mit Number: WQ00 Click to enter text.		
	EPA I.D. (TPDES only): TX Click to enter text.			
	Expiration Date: Click to enter text.			
Se	ctio	on 3. Facility Owner (Applicant) a	nd	Co-Applicant Information
		(Instructions Page 26)		
A.	The	e owner of the facility must apply for the per	mit.	
	Wha	at is the Legal Name of the entity (applicant) a	pply	ing for this permit?
	NM	CV Taylor Property Investors LLC		
		e legal name must be spelled exactly as filed wi legal documents forming the entity.)	ith th	he Texas Secretary of State, County, or in
		ne applicant is currently a customer with the T ne may search for your CN on the TCEQ website		
	(CN· Click to enter text		

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in 30 TAC § 305.44.

Prefix: Mr. Last Name, First Name: Nirav, Shroff

Credential: Click to enter text. Title: Manager

B. Co-applicant information. Complete this section only if another person or entity is required to apply as a co-permittee.

What is the Legal Name of the co-applicant applying for this permit?

Click to enter text.

(The legal name must be spelled exactly as filed with the TX SOS, with the County, or in the *legal documents forming the entity.)*

If the co-applicant is currently a customer with the TCEQ, what is the Customer Number (CN)? You may search for your CN on the TCEQ website at: http://www15.tceq.texas.gov/crpub/

CN: Click to enter text.

What is the name and title of the person signing the application? The person must be an executive official meeting signatory requirements in *30 TAC § 305.44*.

Prefix: Click to enter text. Last Name, First Name: Click to enter text.

Title: Click to enter text. Credential: Click to enter text.

Provide a brief description of the need for a co-permittee: Click to enter text.

C. Core Data Form

Complete the Core Data Form for each customer and include as an attachment. If the customer type selected on the Core Data Form is **Individual**, complete **Attachment 1** of Administrative Report 1.0. <u>Appendix B</u>

Section 4. Application Contact Information (Instructions Page 27)

This is the person(s) TCEQ will contact if additional information is needed about this application. Provide a contact for administrative questions and technical questions.

A. Prefix: Ms. Last Name, First Name: Crone, Lauren

Title: <u>Senior Project Manager</u> Credential: <u>P.E</u>

Organization Name: LJA Engineering

Mailing Address: 7500 Rialto Blvd., Building II, Suite 100 City, State, Zip Code: Austin, Texas,

78735

Phone No.: <u>512-439-4700</u> E-mail Address: <u>lcrone@lja.com</u>

Check one or both:

B. Prefix: Mr. Last Name, First Name: Ryan, Dan

Title: Vice President Credential: P.E

Organization Name: LJA Engineering

Mailing Address: 7500 Rialto Blvd., Building II, Suite 100 City, State, Zip Code: Austin, Texas,

78735

Phone No.:512-439-4702 E-mail Address: dryan@lja.com

Check one or both: Administrative Contact Machine Technical Contact

Section 5. Permit Contact Information (Instructions Page 27)

Provide the names and contact information for two individuals that can be contacted throughout the permit term.

A. Prefix: Ms. Last Name, First Name: Crone, Lauren

Title: Senior Project Manager Credential: P.E

Organization Name: LJA Engineering Inc.

Mailing Address: 7500 Rialto Boulevard, Building II, Suite 100 City, State, Zip Code: Austin,

TX 78735

Phone No.: <u>512-439-4737</u> E-mail Address: <u>lcrone@lja.com</u>

B. Prefix: Mr. Last Name, First Name: Nirav, Shroff

Title: Manager Credential: Click to enter text.

Organization Name: NMCV Taylor Property Investors LLC

Mailing Address:24607 Fairway Springs City, State, Zip Code: San Antonio, Texas 78260

Phone No.: <u>512-825-8837</u> E-mail Address: <u>pkuo@hkredevelopment.com</u>

Section 6. Billing Contact Information (Instructions Page 27)

The permittee is responsible for paying the annual fee. The annual fee will be assessed to permits *in effect on September 1 of each year*. The TCEQ will send a bill to the address provided in this section. The permittee is responsible for terminating the permit when it is no longer needed (using form TCEQ-20029).

Prefix: Mr. Last Name, First Name: Niray, Shroff

Title: Manager Credential: Click to enter text.

Organization Name: NMCV Taylor Property Investors LLC

Mailing Address: <u>24607 Fairway Springs</u> City, State, Zip Code: <u>San Antonio, Texas 78260</u>

Phone No.: <u>512-825-8837</u> E-mail Address: <u>pkuo@hkredevelopment.com</u>

Section 7. DMR/MER Contact Information (Instructions Page 27)

Provide the name and complete mailing address of the person delegated to receive and submit Discharge Monitoring Reports (DMR) (EPA 3320-1) or maintain Monthly Effluent Reports (MER).

Prefix: Mr. Last Name, First Name: Nirav, Shroff

Title: Manager Credential: Click to enter text.

Organization Name: NMCV Taylor Property Investors LLC

Mailing Address: <u>24607 Fairway Springs</u> City, State, Zip Code: <u>San Antonio, Texas 78260</u>

Phone No.: 512-825-8837 E-mail Address: pkuo@hkredevelopment.com

Section 8. Public Notice Information (Instructions Page 27)

A. Individual Publishing the Notices

Prefix: Ms. Last Name, First Name: Crone, Lauren

Title: Senior Project Manager Credential: P.E

Organization Name: LJA Engineering

Mailing Address: 7500 Rialto Blvd., Building II, Suite 100 City, State, Zip Code: Austin, Texas

78735

Phone No.: 512-439-4700 E-mail Address: lcrone@lja.com

B.	. Method for Receiving Notice of Receipt and Intent to Obtain a Water Quality Permit Package		
	Indicate by a check mark the preferred method for receiving the first notice and instruction		
	\boxtimes	E-mail Address	
		Fax	
		Regular Mail	
C.	Co	ntact permit to be listed in the Notices	
		efix: <u>Ms.</u> Last Name, First Name: <u>Crone, Lauren</u>	
	Tit	le: <u>Senior Project Manager</u> Credential: <u>P.E</u>	
	Org	ganization Name: LJA Engineering	
	Ma <u>787</u>	iling Address: <u>7500 Rialto Blvd., Building II, Suite 100</u> City, State, Zip Code: <u>Austin Texas</u>	
	Pho	one No.: <u>512-439-4700</u> E-mail Address: <u>lcrone@lja.com</u>	
D.	Pu	blic Viewing Information	
	-	the facility or outfall is located in more than one county, a public viewing place for each unty must be provided.	
	Pul	blic building name: <u>City of Taylor Public Library</u>	
	Loc	cation within the building: <u>Public Viewing Board</u>	
	Phy	ysical Address of Building: <u>801 Vance Street, Taylor, TX 76574</u>	
	Cit	y: <u>Taylor</u> County: <u>Williamson</u>	
	Co	ntact (Last Name, First Name): <u>Ellis, Karen</u>	
	Pho	one No.: <u>512-269-6257</u> Ext.: Click to enter text.	
E.	Bil	ingual Notice Requirements	
		is information is required for new, major amendment, minor amendment or minor odification, and renewal applications.	
	be	is section of the application is only used to determine if alternative language notices will needed. Complete instructions on publishing the alternative language notices will be in ur public notice package.	
	ob	ase call the bilingual/ESL coordinator at the nearest elementary and middle schools and tain the following information to determine whether an alternative language notices are juired.	
	1.	Is a bilingual education program required by the Texas Education Code at the elementary or middle school nearest to the facility or proposed facility?	
		⊠ Yes □ No	
		If no , publication of an alternative language notice is not required; skip to Section 9 below.	
	2.	Are the students who attend either the elementary school or the middle school enrolled in a bilingual education program at that school?	

No

Yes

	3.	Do the location		these	e schools attend a bilingual education program at another
			Yes	\boxtimes	No
	4.			_	uired to provide a bilingual education program but the school has rement under 19 TAC §89.1205(g)?
			Yes	\boxtimes	No
	5.				uestion 1, 2, 3, or 4 , public notices in an alternative language are ge is required by the bilingual program? Click to enter text.
F.	Pla	in Lang	guage Sumn	nary 7	Template
	Co	mplete	the Plain La	nguag	ge Summary (TCEQ Form 20972) and include as an attachment.
	At	tachme	nt: <u>Appendix</u>	<u> </u>	
G.	Pu	blic Inv	olvement P	lan Fo	orm
	Co	mplete	the Public I	nvolve	ement Plan Form (TCEQ Form 20960) for each application for a
	ne	w perm	it or major	amen	dment to a permit and include as an attachment.
	At	tachme	nt: <u>Appendix</u>	<u> C</u>	
Co		o O	Dogulo	to d T	Cutitus and Dannitta d Cita Information (Instrumetions
5e	CU	on 9.	Page 29		Entity and Permitted Site Information (Instructions
Α.				regul	ated by TCEQ, provide the Regulated Entity Number (RN) issued to text.
					Registry at http://www15.tceq.texas.gov/crpub/ to determine if ed by TCEQ.
B.	Na	me of p	roject or sit	e (the	name known by the community where located):
	<u>48</u>	7 Acre	Taylor Trac	t Was	tewater Treatment Plant
C.	Ov	vner of	treatment fa	acility:	: NMCV Taylor Property Investors LLC
	Ov	vnership	of Facility:		Public ⊠ Private □ Both □ Federal
D.	Ov	vner of l	land where	treatn	nent facility is or will be:
	Pre	efix: <u>Mr.</u>	<u>.</u>		Last Name, First Name: <u>Nirav, Shroff</u>
	Tit	le: <u>Mana</u>	<u>ager</u>		Credential: Click to enter text.
	Or	ganizati	ion Name: <u>N</u>	MCV'	<u> Taylor Property Investors LLC</u>
	Ma	iling Ac	dress: <u>2460</u>	7 Fair	way Springs City, State, Zip Code: San Antonio, Texas 78260
	Ph	one No.	: <u>512-825-88</u>	37	E-mail Address: pkuo@hkredevelopment.com
					same person as the facility owner or co-applicant, attach a lease d easement. See instructions.
		Attach	ment: Click	to en	ter text.

	Prefix: Click to enter text. La	ast Name, First Name: Click to enter text.
	Title: Click to enter text.	redential: Click to enter text.
	Organization Name: Click to enter t	ext.
	Mailing Address: Click to enter text	City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	-mail Address: Click to enter text.
	If the landowner is not the same pe agreement or deed recorded easem	rson as the facility owner or co-applicant, attach a lease ent. See instructions.
	Attachment: Click to enter text.	
F.	F. Owner sewage sludge disposal site property owned or controlled by th	(if authorization is requested for sludge disposal on e applicant)::
	Prefix: Click to enter text.	ast Name, First Name: Click to enter text.
	Title: Click to enter text.	redential: Click to enter text.
	Organization Name: Click to enter t	ext.
	Mailing Address: Click to enter text	City, State, Zip Code: Click to enter text.
	Phone No.: Click to enter text.	-mail Address: Click to enter text.
	If the landowner is not the same pe agreement or deed recorded easem	rson as the facility owner or co-applicant, attach a lease ent. See instructions.
	Attachment: Click to enter text.	
Se	Section 10. TPDES Discharge	Information (Instructions Page 31)
A.	A. Is the wastewater treatment facility	location in the existing permit accurate?
	□ Yes □ No	
		please give an accurate description:
	New Permit: The proposed WWTP is intersection of FM 112 and Tucek Roa	ocated approximately 0.16 miles Northeast of the
	intersection of 1111 112 and 1 deek from	a iii vi iiidiiisoii County, Textas / 0.1/4.
В.	B. Are the point(s) of discharge and th	e discharge route(s) in the existing permit correct?
	□ Yes □ No	
		nit application , provide an accurate description of the e route to the nearest classified segment as defined in 30
	wastewater line that is roughly 1400 li	ment plant, effluent will be discharges using a gravity near feet to its discharge point in an unnamed Tributary on will then travel approximately 3.0 miles to Mustang Creek
	Citation and the control life in	
	City nearest the outfall(s): <u>Taylor</u>	
	County in which the outfalls(s) is/a	re located: <u>Williamson County</u>

E. Owner of effluent disposal site:

	LI TES IN INO						
	If yes , indicate by a check mark if:						
	\square Authorization granted \square Authorization pending						
	For new and amendment applications, provide copies of letters that show proof of contact and the approval letter upon receipt.						
	Attachment: Click to enter text.						
D.	For all applications involving an average daily discharge of 5 MGD or more, provide the names of all counties located within 100 statute miles downstream of the point(s) of discharge: Click to enter text.						
Se	ection 11. TLAP Disposal Information (Instructions Page 32)						
Α.	For TLAPs, is the location of the effluent disposal site in the existing permit accurate?						
	☐ Yes ☐ No						
	If no, or a new or amendment permit application , provide an accurate description of the						
	disposal site location:						
	Click to enter text.						
В.	City nearest the disposal site: Click to enter text.						
	County in which the disposal site is located: Click to enter text.						
	For TLAPs , describe the routing of effluent from the treatment facility to the disposal site:						
	Click to enter text.						
E.	For TLAPs , please identify the nearest watercourse to the disposal site to which rainfall runoff might flow if not contained: Click to enter text.						
Se	ection 12. Miscellaneous Information (Instructions Page 32)						
A.	Is the facility located on or does the treated effluent cross American Indian Land?						
	□ Yes ⊠ No						
B.	If the existing permit contains an onsite sludge disposal authorization, is the location of the sewage sludge disposal site in the existing permit accurate?						
	□ Yes □ No ⊠ Not Applicable						
	If No, or if a new onsite sludge disposal authorization is being requested in this permit application, provide an accurate location description of the sewage sludge disposal site.						
	Click to enter text.						

C.	C. Did any person formerly employed by the TCEQ represent your company and get paid for service regarding this application?					
	□ Yes ⊠ No					
	If yes, list each person formerly employed by the TCEQ who represented your company and was paid for service regarding the application: Click to enter text.					
D.	Do you owe any fees to the TCEQ?					
	□ Yes ⊠ No					
	If yes , provide the following information:					
	Account number: Click to enter text.					
	Amount past due: Click to enter text.					
E.	Do you owe any penalties to the TCEQ?					
	□ Yes ⊠ No					
	If yes , please provide the following information:					
	Enforcement order number: Click to enter text.					
	Amount past due: Click to enter text.					
Se	ection 13. Attachments (Instructions Page 33)					
Inc	dicate which attachments are included with the Administrative Report. Check all that apply:					
	Lease agreement or deed recorded easement, if the land where the treatment facility is located or the effluent disposal site are not owned by the applicant or co-applicant.					
\boxtimes	Original full-size USGS Topographic Map with the following information:					
	Applicant's property boundary					
	 Treatment facility boundary Labeled point of discharge for each discharge point (TPDES only) Highlighted discharge route for each discharge point (TPDES only) Onsite sewage sludge disposal site (if applicable) Effluent disposal site boundaries (TLAP only) New and future construction (if applicable) 1 mile radius information 3 miles downstream information (TPDES only) All ponds. 					
	 Treatment facility boundary Labeled point of discharge for each discharge point (TPDES only) Highlighted discharge route for each discharge point (TPDES only) Onsite sewage sludge disposal site (if applicable) Effluent disposal site boundaries (TLAP only) New and future construction (if applicable) 1 mile radius information 3 miles downstream information (TPDES only) 					

Other Attachments. Please specify: <u>Appendix A- Plain Language Summary Appendix B - Core Data Form</u>; <u>Appendix C - Public Involvement Plan Form</u>; <u>Appendix D - USGS Maps</u>; <u>Appendix E - Affected Landowners Map</u>; <u>Appendix F - Original Photographs</u>; <u>Appendix G - Buffer Zone Map</u>; <u>Appendix H - SPIF Maps</u>; <u>Appendix I - Process Flow Diagram</u>; <u>Appendix J - Site Drawing</u>; <u>Appendix K - Design Calculations</u>; <u>Appendix L - FEMA Flood Maps</u>; <u>Appendix M - Wind Roses</u>; <u>Appendix N - Sewage Solids Management Plan</u>, <u>Appendix O - Nearby WWTP Map</u>, <u>Appendix P - regionalization and Cost Analysis</u>, <u>Appendix Q - Transect Location Map</u>

Section 14. Signature Page (Instructions Page 34)

If co-applicants are necessary, each entity must submit an original, separate signature page.

Permit Number: Click to enter text.

Applicant: NMCV Taylor Property Investors LLC

Certification:

County, Texas

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code § 305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signatory name (typed or printed): <u>Nirav Shroff</u>				
Signatory title: Manager				
Signature:				
(Use blue ink)				
and Nicaus to before me by the gaid Nicau Sh Coff				
Subscribed and Sworn to before me by the said <u>Niray Shroff</u> on this <u>18 th</u> day of <u>Africanted</u> , 20 24. My commission expires on the <u>3157</u> day of <u>October</u> , 20 27.				
on this 8th day of 747, c , 20 27.				
My commission expires on the $3/57$ day of $0.00000000000000000000000000000000000$				
Notary Public Notary Public Notary Public STATE OF TEXAS ID# 134627233 My Comm. Exp. Oct. 31, 2027				
Williamson				

DOMESTIC WASTEWATER PERMIT APPLICATION ADMINISTRATIVE REPORT 1.0

The following information is required for new and amendment applications.

Section 1. Affected Landowner Information (Instructions Page 36)

Α.	. Indicate by a check mark that the landowners map or drawing, with scale, includes the following information, as applicable:						
	☑ The applicant's property boundaries						
	\boxtimes	The facility site boundaries within the applicant's property boundaries					
		The distance the buffer zone falls into adjacent properties and the property boundaries of the landowners located within the buffer zone					
	The property boundaries of all landowners surrounding the applicant's property (the application is a major amendment for a lignite mine, the map must include the property boundaries of all landowners adjacent to the new facility (ponds).)						
		The point(s) of discharge and highlighted discharge route(s) clearly shown for one mile downstream					
		The property boundaries of the landowners located on both sides of the discharge route for one full stream mile downstream of the point of discharge					
		The property boundaries of the landowners along the watercourse for a one-half mile radius from the point of discharge if the point of discharge is into a lake, bay, estuary, or affected by tides					
		The boundaries of the effluent disposal site (for example, irrigation area or subsurface drainfield site) and all evaporation/holding ponds within the applicant's property					
		The property boundaries of all landowners surrounding the effluent disposal site					
		The boundaries of the sludge land application site (for land application of sewage sludge for beneficial use) and the property boundaries of landowners surrounding the applicant's property boundaries where the sewage sludge land application site is located					
		The property boundaries of landowners within one-half mile in all directions from the applicant's property boundaries where the sewage sludge disposal site (for example, sludge surface disposal site or sludge monofill) is located					
В.	⊠ addı	Indicate by a check mark that a separate list with the landowners' names and mailing resses cross-referenced to the landowner's map has been provided.					
C.	. Indicate by a check mark in which format the landowners list is submitted: ☐ USB Drive ☑ Four sets of labels						
D.		ride the source of the landowners' names and mailing addresses: <u>Williamson County Central</u> raisal <u>District</u>					
E.		As required by <i>Texas Water Code § 5.115</i> , is any permanent school fund land affected by this application?					
		□ Yes ⊠ No					

If yes , provide the location and foreseeable impacts and effects this application has on the land(s):									
	Click to enter text.								
Section 2. Original Photographs (Instructions Page 38)									
Provide original ground level photographs. Indicate with checkmarks that the following information is provided.									
		At least one original photograph of the new or expanded treatment unit location							
		At least two photographs of the existing/proposed point of discharge and as much area downstream (photo 1) and upstream (photo 2) as can be captured. If the discharge is to an open water body (e.g., lake, bay), the point of discharge should be in the right or left edge of each photograph showing the open water and with as much area on each respective side of the discharge as can be captured.							
	\Box A	At least one photograph of the existing/proposed effluent disposal site							
		A plot plan or map showing the location and direction of each photograph							
Se	ction	a 3. Buffer Zone Map (Instructions Page 38)							
A.	infor	r zone map. Provide a buffer zone map on 8.5×11 -inch paper with all of the following mation. The applicant's property line and the buffer zone line may be distinguished by dashes or symbols and appropriate labels.							
	•	The applicant's property boundary; The required buffer zone; and Each treatment unit; and The distance from each treatment unit to the property boundaries.							
В.		r zone compliance method. Indicate how the buffer zone requirements will be met. all that apply.							
	\boxtimes	Ownership							
		Restrictive easement							
		Nuisance odor control							
		Variance							
C.		itable site characteristics. Does the facility comply with the requirements regarding table site characteristic found in 30 TAC § 309.13(a) through (d)?							
		Yes No							

DOMESTIC WASTEWATER PERMIT APPLICATION SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

This form applies to TPDES permit applications only. Complete and attach the Supplemental Permit information Form (SPIF) (TCEQ Form 20971).

Attachment: Appendix H

DOMESTIC WASTEWATER PERMIT APPLICATION CHECKLIST OF COMMON DEFICIENCIES

Below is a list of common deficiencies found during the administrative review of domestic wastewater permit applications. To ensure the timely processing of this application, please review the items below and indicate by checking Yes that each item is complete and in accordance applicable rules at 30 TAC Chapters 21, 281, and 305. If an item is not required this application, indicate by checking N/A where appropriate. Please do not submit the application until the items below have been addressed.

аррисацоп	until the items below have been addressed.							
Core Data Form (TCEQ Form No. 10400) (Required for all application types. Must be completed in its entirety and signed. Note: Form may be signed by applicant representative.)					Yes			
Correct and Current Industrial Wastewater Permit Application Forms (TCEQ Form Nos. 10053 and 10054. Version dated 6/25/2018 or later.)					Yes			
Water Qual (Original po	⊠ dress	Yes						
(Full-size m	USGS Quadrangle Topographic Map Attached nap if seeking "New" permit. ceptable for Renewals and Amendments)				Yes			
Current/No	on-Expired, Executed Lease Agreement or Easement	\boxtimes	N/A		Yes			
Landowners Map (See instructions for landowner requirements)					Yes			
 Things to Know: All the items shown on the map must be labeled. The applicant's complete property boundaries must be delineated which includes boundaries of contiguous property owned by the applicant. The applicant cannot be its own adjacent landowner. You must identify the landowners immediately adjacent to their property, regardless of how far they are from the actual facility. If the applicant's property is adjacent to a road, creek, or stream, the landowners on the opposite side must be identified. Although the properties are not adjacent to applicant's property boundary, they are considered potentially affected landowners. If the adjacent road is a divided highway as identified on the USGS topographic map, the applicant does not have to identify the landowners on the opposite side of the highway. 								
	s Cross Reference List etions for landowner requirements)		N/A		Yes			

(If signature page is not signed by an elected official or principle executive officer,

Landowners Labels or USB Drive attached

Plain Language Summary

(See instructions for landowner requirements)

Original signature per 30 TAC § 305.44 - Blue Ink Preferred

a copy of signature authority/delegation letter must be attached)

Yes

Yes

Yes

N/A

EXHIBIT 2

DOMESTIC TECHNICAL REPORTS 1.0 AND 1.1

DOMESTIC TECHNICAL REPORT WORKSHEET 2.0

THE TONMENTAL OUR LEVEL OF THE PROPERTY OF THE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.0

For any questions about this form, please contact the Domestic Wastewater Permitting Team at 512-239-4671.

The following information is required for all renewal, new, and amendment applications.

Section 1. Permitted or Proposed Flows (Instructions Page 43)

A. Existing/Interim I Phase

Design Flow (MGD): <u>o.o5</u> 2-Hr Peak Flow (MGD): <u>o.2</u>

Estimated construction start date: 6/1/2026 Estimated waste disposal start date: 6/1/2027

B. Interim II Phase

Design Flow (MGD): <u>0.10</u> 2-Hr Peak Flow (MGD): <u>0.40</u>

Estimated construction start date: 6/1/2028Estimated waste disposal start date: 6/1/2029

C. Final Phase

Design Flow (MGD): <u>0.15</u> 2-Hr Peak Flow (MGD): <u>0.60</u>

Estimated construction start date: 6/1/2030 Estimated waste disposal start date: 6/1/2031

D. Current Operating Phase

Provide the startup date of the facility: N/A – New Facility

Section 2. Treatment Process (Instructions Page 43)

A. Current Operating Phase

Provide a detailed description of the treatment process. **Include the type of treatment plant, mode of operation, and all treatment units.** Start with the plant's head works and

finish with the point of discharge. Include all sludge processing and drying units. **If more than one phase exists or is proposed, a description of** *each phase* **must be provided**.

The facility is to be constructed in three phases with a total design flow of 150,000 gpd. Phases I, II, and III will treat 50,000 gpd each. Each phase will operate as a suspended-growth activated sludge process in extended aeration mode. The treatment units include a bar screen, aeration basin, clarifier, chlorine contact basin and an aerobic digester. Wastewater will be pumped into plant where it will enter the aeration basin through a bar screen. The influent will then pass through the aeration zone and flow into a clarifier. From there, the effluent will flow to a chlorine contact basin for disinfection. This facility will also use a digester for sludge holding, prior to haul off.

B. Treatment Units

In Table 1.0(1), provide the treatment unit type, the number of units, and dimensions (length, width, depth) of each treatment unit, accounting for *all* phases of operation.

Table 1.0(1) - Treatment Units

Treatment Unit Type	Number of Units	Dimensions (L x W x D)
Clarifier	3 (1 per phase)	Phase 1: 16' DIA x 12' D
		Phase 2: 16' DIA x 12' D
		Phase 3: 16' DIA x 12' D
Aeration Basin	3 (1 per phase)	Phase 1: 58'L x 40'W x 12'D Phase 2: 58'L x 40'W x 12'D
		Phase 3: 58'L x 40'W x 12'D
Aerobic Digester	3 (1 per phase)	Phase 1: 34'L x 20'W x 12'D Phase 2: 34'L x 20'W x 12'D
		Phase 3: 34'L x 20'W x 12'D
Chlorine Contact Chamber	3 (1 per phase)	Phase 1: 8'L x 5'W x 12'D
		Phase 2: 8'L x 5'W x 12'D Phase 3: 8'L x 5'W x 12'D

C. Process Flow Diagram

Provide flow diagrams for the existing facilities and **each** proposed phase of construction.

Attachment: Appendix I

Section 3. Site Information and Drawing (Instructions Page 44)

Provide the TPDES discharge outfall latitude and longitude. Enter N/A if not applicable.

• Latitude: <u>30.565409</u>

• Longitude: -97.358819

Provide the TLAP disposal site latitude and longitude. Enter N/A if not applicable.

Latitude: N/ALongitude: N/A

Provide a site drawing for the facility that shows the following:

- The boundaries of the treatment facility;
- The boundaries of the area served by the treatment facility;
- If land disposal of effluent, the boundaries of the disposal site and all storage/holding ponds; and
- If sludge disposal is authorized in the permit, the boundaries of the land application or disposal site.

Attachment:

Provide the name **and** a description of the area served by the treatment facility.

487 Acre Taylor Tract: A commercial tract consisting of approximately 612 equivalent	
connections on approximately 487 acres being developed in Williamson County	

Collection System Information **for wastewater TPDES permits only**: Provide information for each **uniquely owned** collection system, existing and new, served by this facility, including satellite collection systems. **Please see the instructions for a detailed explanation and examples.**

Collection System Information

Collection System Name	Owner Name	Owner Type	Population Served
487 Acre Taylor Tract WWTP	NMCV Taylor Property Investors LLC	Privately Owned	612 Equivalent Connections
		Choose an item.	
		Choose an item.	
		Choose an item.	

Section 4. Unbuilt Phases (Instructions Page 45)

Is the application fo	or a renewal of a permit	that contains an	unbuilt phase or phases?
-----------------------	--------------------------	------------------	--------------------------

□ Yes ⊠ No

If yes, does the existing permit contain a phase that has not been constructed within five years of being authorized by the TCEQ?

□ Yes ⊠ No

If yes, provide a detailed discussion regarding the continued need for the unbuilt phase. Failure to provide sufficient justification may result in the Executive Director recommending denial of the unbuilt phase or phases.

Click to enter text.	
Section 5. Closure Plans (Instructions Page 45)	
Have any treatment units been taken out of service permanently, or will any units be taken out of service in the next five years?	
□ Yes ⊠ No	
If yes, was a closure plan submitted to the TCEQ?	
□ Yes ⊠ No	
If yes, provide a brief description of the closure and the date of plan approval.	
Click to enter text.	
Section 6. Permit Specific Requirements (Instructions Page 45)	
For applicants with an existing permit, check the Other Requirements or Special Provisions of the permit.	
A. Summary transmittal	
Have plans and specifications been approved for the existing facilities and each propose phase?	d

□ Yes ⊠ No

If yes, provide the date(s) of approval for each phase: N/A

Provide information, including dates, on any actions taken to meet a *requirement or provision* pertaining to the submission of a summary transmittal letter. **Provide a copy of an approval letter from the TCEQ, if applicable**.

	Click to enter text.
В.	Buffer zones
	Have the buffer zone requirements been met?
	⊠ Yes □ No
	Provide information below, including dates, on any actions taken to meet the conditions of the buffer zone. If available, provide any new documentation relevant to maintaining the buffer zones.
	A 150' buffer zone will surround the treatment plant.
C.	Other actions required by the current permit
	Does the <i>Other Requirements</i> or <i>Special Provisions</i> section in the existing permit require submission of any other information or other required actions? Examples include Notification of Completion, progress reports, soil monitoring data, etc.
	□ Yes ⊠ No
	If yes , provide information below on the status of any actions taken to meet the conditions of an <i>Other Requirement</i> or <i>Special Provision</i> .
	Click to enter text.
D.	Grit and grease treatment
	1. Acceptance of grit and grease waste
	Does the facility have a grit and/or grease processing facility onsite that treats and decants or accepts transported loads of grit and grease waste that are discharged directly to the wastewater treatment plant prior to any treatment?

2. Grit and grease processing

No

□ Yes ⊠

Describe below how the grit and grease waste is treated at the facility. In your description, include how and where the grit and grease is introduced to the treatment

If No, stop here and continue with Subsection E. Stormwater Management.

	Click to enter text.
2	Cuit disposal
3.	Grit disposal
	Does the facility have a Municipal Solid Waste (MSW) registration or permit for grit disposal?
	□ Yes □ No
	If No , contact the TCEQ Municipal Solid Waste team at 512-239-2335. Note: A registration or permit is required for grit disposal. Grit shall not be combined with treatment plant sludge. See the instruction booklet for additional information on grit disposal requirements and restrictions.
	Describe the method of grit disposal.
	Click to enter text.
1	Grease and decanted liquid disposal
4.	
	Note: A registration or permit is required for grease disposal. Grease shall not be combined with treatment plant sludge. For more information, contact the TCEQ Municipal Solid Waste team at 512-239-2335.
	Describe how the decant and grease are treated and disposed of after grit separation.
	Click to enter text.
Sto	ormwater management
	ormwater management Applicability
	_
	Applicability

	Li res 🖾 No
	If no to both of the above, then skip to Subsection F, Other Wastes Received.
2.	MSGP coverage
	Is the stormwater runoff from the WWTP and dedicated lands for sewage disposal currently permitted under the TPDES Multi-Sector General Permit (MSGP), TXR050000?
	□ Yes □ No
	If yes , please provide MSGP Authorization Number and skip to Subsection F, Other Wastes Received:
	TXR05 Click to enter text. or TXRNE Click to enter text.
	If no, do you intend to seek coverage under TXR050000?
	□ Yes □ No
3.	Conditional exclusion
	Alternatively, do you intend to apply for a conditional exclusion from permitting based TXR050000 (Multi Sector General Permit) Part II B.2 or TXR050000 (Multi Sector General Permit) Part V, Sector T 3(b)?
	□ Yes □ No
	If yes, please explain below then proceed to Subsection F, Other Wastes Received:
	Click to enter text.
4.	Existing coverage in individual permit
	Is your stormwater discharge currently permitted through this individual TPDES or TLAP permit?
	□ Yes □ No
	If yes , provide a description of stormwater runoff management practices at the site that are authorized in the wastewater permit then skip to Subsection F, Other Wastes Received.
	Click to enter text.
5.	Zero stormwater discharge
<i>.</i>	Do you intend to have no discharge of stormwater via use of evaporation or other
	means?
	□ Yes □ No
	If was avalain helow than skin to Subsection F. Other Wastes Received

		Click to enter text.
		Note: If there is a potential to discharge any stormwater to surface water in the state as the result of any storm event, then permit coverage is required under the MSGP or an individual discharge permit. This requirement applies to all areas of facilities with treatment plants or systems that treat, store, recycle, or reclaim domestic sewage, wastewater or sewage sludge (including dedicated lands for sewage sludge disposal located within the onsite property boundaries) that meet the applicability criteria of above. You have the option of obtaining coverage under the MSGP for direct discharges, (recommended), or obtaining coverage under this individual permit.
	<i>6.</i>	Request for coverage in individual permit
		Are you requesting coverage of stormwater discharges associated with your treatment plant under this individual permit?
		□ Yes □ No
		If yes, provide a description of stormwater runoff management practices at the site for which you are requesting authorization in this individual wastewater permit and describe whether you intend to comingle this discharge with your treated effluent or discharge it via a separate dedicated stormwater outfall. Please also indicate if you intend to divert stormwater to the treatment plant headworks and indirectly discharge it to water in the state.
		Click to enter text.
		Note: Direct stormwater discharges to waters in the state authorized through this individual permit will require the development and implementation of a stormwater pollution prevention plan (SWPPP) and will be subject to additional monitoring and reporting requirements. Indirect discharges of stormwater via headworks recycling will require compliance with all individual permit requirements including 2-hour peak flow limitations. All stormwater discharge authorization requests will require additional information during the technical review of your application.
F.	Di	scharges to the Lake Houston Watershed
	Do	es the facility discharge in the Lake Houston watershed?
		□ Yes ⊠ No
		yes, attach a Sewage Sludge Solids Management Plan. See Example 5 in the instructions. ck to enter text.

G. Other wastes received including sludge from other WWTPs and septic waste

1. Acceptance of sludge from other WWTPs

Does or will the facility accept sludge from other treatment plants at the facility site?

	If yes, attach sewage sludge solids management plan. See Example 5 of instructions
	In addition, provide the date the plant started or is anticipated to start accepting sludge, an estimate of monthly sludge acceptance (gallons or millions of gallons), an
	estimate of the BOD_5 concentration of the sludge, and the design BOD_5 concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
	Click to enter text.
	Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
2.	Acceptance of septic waste
	Is the facility accepting or will it accept septic waste?
	□ Yes ⊠ No
	If yes, does the facility have a Type V processing unit?
	□ Yes □ No
	If yes, does the unit have a Municipal Solid Waste permit?
	□ Yes □ No
	If yes to any of the above, provide the date the plant started or is anticipated to start accepting septic waste, an estimate of monthly septic waste acceptance (gallons or millions of gallons), an estimate of the BOD ₅ concentration of the septic waste, and the
	design BOD_5 concentration of the influent from the collection system. Also note if this information has or has not changed since the last permit action.
	Click to enter text.
	Note: Permits that accept sludge from other wastewater treatment plants may be required to have influent flow and organic loading monitoring.
<i>3.</i>	Acceptance of other wastes (not including septic, grease, grit, or RCRA, CERCLA or as discharged by IUs listed in Worksheet 6)
	Is or will the facility accept wastes that are not domestic in nature excluding the categories listed above?
	□ Yes ⊠ No
	If yes , provide the date that the plant started accepting the waste, an estimate how much waste is accepted on a monthly basis (gallons or millions of gallons), a description of the entities generating the waste, and any distinguishing chemical or

No

changed since the last permit action.				
Click to enter text.				

other physical characteristic of the waste. Also note if this information has or has not

Section 7. Pollutant Analysis of Treated Effluent (Instructions Page 50)

Is the facility in operation?

□ Yes ⊠ No

If no, this section is not applicable. Proceed to Section 8.

If yes, provide effluent analysis data for the listed pollutants. *Wastewater treatment facilities* complete Table 1.0(2). *Water treatment facilities* discharging filter backwash water, complete Table 1.0(3). Provide copies of the laboratory results sheets. **These tables are not applicable for a minor amendment without renewal.** See the instructions for guidance.

Note: The sample date must be within 1 year of application submission.

Table 1.0(2) - Pollutant Analysis for Wastewater Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
CBOD ₅ , mg/l					
Total Suspended Solids, mg/l					
Ammonia Nitrogen, mg/l					
Nitrate Nitrogen, mg/l					
Total Kjeldahl Nitrogen, mg/l					
Sulfate, mg/l					
Chloride, mg/l					
Total Phosphorus, mg/l					
pH, standard units					
Dissolved Oxygen*, mg/l					
Chlorine Residual, mg/l					
E.coli (CFU/100ml) freshwater					
Entercocci (CFU/100ml) saltwater					
Total Dissolved Solids, mg/l					
Electrical Conductivity, µmohs/cm, †					

Oil & Grease, mg/l			
Alkalinity (CaCO ₃)*, mg/l			

^{*}TPDES permits only †TLAP permits only

Table 1.0(3) - Pollutant Analysis for Water Treatment Facilities

Pollutant	Average Conc.	Max Conc.	No. of Samples	Sample Type	Sample Date/Time
Total Suspended Solids, mg/l					
Total Dissolved Solids, mg/l					
pH, standard units					
Fluoride, mg/l					
Aluminum, mg/l					
Alkalinity (CaCO ₃), mg/l					

Section 8. Facility Operator (Instructions Page 50)

Facility Operator Name: Crossroads Utility Services

Facility Operator's License Classification and Level: Wastewater Operator A

Facility Operator's License Number: OC0000182

Section 9. Sludge and Biosolids Management and Disposal (Instructions Page 51)

A. WWTP's Biosolids Management Facility Type

Che	ck all that apply. See instructions for guidance
	Design flow>= 1 MGD
	Serves >= 10,000 people
	Class I Sludge Management Facility (per 40 CFR § 503.9)
\boxtimes	Biosolids generator
	Biosolids end user - land application (onsite)
	Biosolids end user – surface disposal (onsite)

B. WWTP's Biosolids Treatment Process

Check all that apply. See instructions for guidance.

Biosolids end user - incinerator (onsite)

✓ Aerobic Digestion
 ☐ Air Drying (or sludge drying beds)
 ☐ Lower Temperature Composting
 ☐ Lime Stabilization
 ☐ Higher Temperature Composting

Ш	Heat Drying
	Thermophilic Aerobic Digestion
	Beta Ray Irradiation
	Gamma Ray Irradiation
	Pasteurization
	Preliminary Operation (e.g. grinding, de-gritting, blending)
	Thickening (e.g. gravity thickening, centrifugation, filter press, vacuum filter)
	Sludge Lagoon
	Temporary Storage (< 2 years)
	Long Term Storage (>= 2 years)
	Methane or Biogas Recovery
	Other Treatment Process: Click to enter text.

C. Biosolids Management

Provide information on the *intended* biosolids management practice. Do not enter every management practice that you want authorized in the permit, as the permit will authorize all biosolids management practices listed in the instructions. Rather indicate the management practice the facility plans to use.

Biosolids Management

Management Practice	Handler or Preparer Type	Bulk or Bag Container	Amount (dry metric tons)	Pathogen Reduction Options	Vector Attraction Reduction Option
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.
Choose an item.	Choose an item.	Choose an item.		Choose an item.	Choose an item.

If "Other" is selected for Management Practice, please explain (e.g. monofill or transport to another WWTP): <u>Click to enter text.</u>

D. Disposal site

Disposal site name: <u>Click to enter text.</u>

TCEQ permit or registration number: <u>Click to enter text.</u>
County where disposal site is located: <u>Click to enter text.</u>

E. Transportation method

Method of transportation (truck, train, pipe, other): <u>Truck</u>

Name of the hauler: <u>Captex</u>

	Hauler	regist	tratio	on number: <u>20745</u>					
	Sludge	is tra	nspo	rted as a:					
	Liq	uid 🗵		semi-liquid □	semi-solid		sol	id □	
Se	ction			mit Authorizat tructions Page		wag	e Slu	dge E	Disposal
			(1115	diuctions rage	<i>33)</i>				
Α.	Benefi	cial us	se au	thorization					
	Does to benefic		_	permit include aut	horization fo	r lan	d appli	cation	of sewage sludge for
		Yes	\boxtimes	No					
	If yes , benefic			questing to continu	e this author	izati	on to la	and app	ply sewage sludge for
		Yes		No					
		Form		pleted Application 10451) attached to					Use of Sewage Sludge e instructions for
		Yes		No					
B.	Sludge	proc	essin	g authorization					
			_	permit include aut al options?	horization fo	r any	of the	follow	ving sludge processing,
	Slu	dge Co	ompo	osting			Yes	\boxtimes	No
	Ma	rketin	g and	l Distribution of slu	ıdge		Yes		No
	Slu	dge St	ırfac	e Disposal or Sludge	e Monofill		Yes		No
	Ter	npora	ry st	orage in sludge lago	ons		Yes	\boxtimes	No
	author	izatio	n, is		iestic Wastev	vatei	' Permi	t Appl	esting to continue this ication: Sewage Sludge application?
		Yes		No					
Se	ction	11.	Sev	vage Sludge Lag	zoons (Ins	truc	ctions	Page	2 53)
				lude sewage sludge					
	□ Ye		, No		O				
If y				remainder of this se	ection. If no, p	proce	eed to S	Section	12.
A.	Locatio	on inf	orma	ntion					

\mathbf{A}

The following maps are required to be submitted as part of the application. For each map, provide the Attachment Number.

Original General Highway (County) Map:

Attachment: Click to enter text.

• USDA Natural Resources Conservation Service Soil Map:

Attachment: Click to enter text.

• Federal Emergency Management Map:

Attachment: Click to enter text.

• Site map:

Attachment: Click to enter text.

Discuss in a description if any of the following exist within the lagoon area. Check all that apply.

□ Overlap a designated 100-year frequency flood plain

□ Soils with flooding classification

□ Overlap an unstable area

□ Wetlands

□ Located less than 60 meters from a fault

 \square None of the above

Attachment: Click to enter text.

If a portion of the lagoon(s) is located within the 100-year frequency flood plain, provide the protective measures to be utilized including type and size of protective structures:

Click to enter text.

B. Temporary storage information

Provide the results for the pollutant screening of sludge lagoons. These results are in addition to pollutant results in *Section 7 of Technical Report 1.0.*

Nitrate Nitrogen, mg/kg: <u>Click to enter text.</u>

Total Kjeldahl Nitrogen, mg/kg: <u>Click to enter text.</u>

Total Nitrogen (=nitrate nitrogen + TKN), mg/kg: Click to enter text.

Phosphorus, mg/kg: Click to enter text.

Potassium, mg/kg: Click to enter text.

pH, standard units: <u>Click to enter text.</u>

Ammonia Nitrogen mg/kg: Click to enter text.

Arsenic: Click to enter text.

Cadmium: Click to enter text.

Chromium: Click to enter text.

Copper: Click to enter text.

Lead: Click to enter text.

	Molybdenum: Click to enter text.
	Nickel: Click to enter text.
	Selenium: <u>Click to enter text.</u>
	Zinc: Click to enter text.
	Total PCBs: Click to enter text.
	Provide the following information:
	Volume and frequency of sludge to the lagoon(s): Click to enter text.
	Total dry tons stored in the lagoons(s) per 365-day period: Click to enter text.
	Total dry tons stored in the lagoons(s) over the life of the unit: <u>Click to enter text.</u>
C.	Liner information
	Does the active/proposed sludge lagoon(s) have a liner with a maximum hydraulic conductivity of $1x10^{-7}$ cm/sec?
	□ Yes □ No
	If yes, describe the liner below. Please note that a liner is required.
	Click to enter text.
D.	Site development plan
	Provide a detailed description of the methods used to deposit sludge in the lagoon(s):
	Click to enter text.
	Attach the following documents to the application.
	 Plan view and cross-section of the sludge lagoon(s)
	Attachment: Click to enter text.
	Copy of the closure plan
	Attachment: Click to enter text.
	 Copy of deed recordation for the site
	Attachment: Click to enter text.
	• Size of the sludge lagoon(s) in surface acres and capacity in cubic feet and gallons

Mercury: Click to enter text.

Attachment: Click to enter text.

 Description of the method of controlling infiltration of groundwater and surface water from entering the site
Attachment: Click to enter text.
 Procedures to prevent the occurrence of nuisance conditions
Attachment: Click to enter text.
Groundwater monitoring
Is groundwater monitoring currently conducted at this site, or are any wells available for groundwater monitoring, or are groundwater monitoring data otherwise available for the sludge lagoon(s)?
□ Yes □ No
If groundwater monitoring data are available, provide a copy. Provide a profile of soil types encountered down to the groundwater table and the depth to the shallowest groundwater as a separate attachment.
Attachment: Click to enter text.
ection 12. Authorizations/Compliance/Enforcement (Instructions Page 55)
Additional authorizations
Does the permittee have additional authorizations for this facility, such as reuse authorization, sludge permit, etc?
□ Yes ⊠ No
If yes, provide the TCEQ authorization number and description of the authorization:
lick to enter text.
Permittee enforcement status
Is the permittee currently under enforcement for this facility?
☐ Yes ☑ No
Is the permittee required to meet an implementation schedule for compliance or enforcement?
□ Yes ⊠ No
If yes to either question, provide a brief summary of the enforcement, the implementation schedule, and the current status:

E.

B.

Click to enter text.	

Section 13. RCRA/CERCLA Wastes (Instructions Page 55)

A. RCRA hazardous wastes

Has the facility received in the past three years, does it currently receive, or will it receive RCRA hazardous waste?

□ Yes ⊠ No

B. Remediation activity wastewater

Has the facility received in the past three years, does it currently receive, or will it receive CERCLA wastewater, RCRA remediation/corrective action wastewater or other remediation activity wastewater?

□ Yes ⊠ No

C. Details about wastes received

If yes to either Subsection A or B above, provide detailed information concerning these wastes with the application.

Attachment: Click to enter text.

Section 14. Laboratory Accreditation (Instructions Page 56)

All laboratory tests performed must meet the requirements of *30 TAC Chapter 25*, *Environmental Testing Laboratory Accreditation and Certification*, which includes the following general exemptions from National Environmental Laboratory Accreditation Program (NELAP) certification requirements:

- The laboratory is an in-house laboratory and is:
 - o periodically inspected by the TCEQ; or
 - o located in another state and is accredited or inspected by that state; or
 - o performing work for another company with a unit located in the same site; or
 - performing pro bono work for a governmental agency or charitable organization.
- The laboratory is accredited under federal law.
- The data are needed for emergency-response activities, and a laboratory accredited under the Texas Laboratory Accreditation Program is not available.
- The laboratory supplies data for which the TCEQ does not offer accreditation.

The applicant should review 30 TAC Chapter 25 for specific requirements.

The following certification statement shall be signed and submitted with every application. See the Signature Page section in the Instructions, for a list of designated representatives who may sign the certification.

CERTIFICATION:

I certify that all laboratory tests submitted with this application meet the requirements of 30 TAC Chapter 25, Environmental Testing Laboratory Accreditation and Certification.

Printed Name: Nirav Shroff

Title: Manager

Data

DOMESTIC WASTEWATER PERMIT APPLICATION TECHNICAL REPORT 1.1

The following information is required for new and amendment major applications.

Section 1. Justification for Permit (Instructions Page 57)

A. Justification of permit need

Provide a detailed discussion regarding the need for any phase(s) not currently permitted. Failure to provide sufficient justification may result in the Executive Director recommending denial of the proposed phase(s) or permit.

The wastewater treatment plant will serve the proposed residential development. Based on easement and right-of-way limitations, no route exists from this site to an organized wastewater treatment facility. The use of a central collection treatment and disposal system is being preferred to an equivalent number of private residential septic tank/drain field units. Design flows are based on Living Unit Equivalents (LUEs) or connections associated with the service area. A basis of 245 gallons of wastewater per day per connection (maximum 30-day wet weather average) was assumed for flow projections. The ultimate flow is based on the total number of equivalent connections (612 proposed). The total flow needed at full build would be 612 connections x 245 gal/day/connection = 150,000 gal/day assumed.

B. Regionalization of facilities

For additional guidance, please review <u>TCEQ's Regionalization Policy for Wastewater</u> Treatment¹.

Provide the following information concerning the potential for regionalization of domestic wastewater treatment facilities:

1. Municipally incorporated areas

If the applicant is a city, then Item 1 is not applicable. Proceed to Item 2 Utility CCN areas.

Is any portion of the proposed service area located in an incorporated city?

□ Yes ⊠ No □ Not Applicable

If yes, within the city limits of: Click to enter text.

If yes, attach correspondence from the city.

Attachment: Click to enter text.

If consent to provide service is available from the city, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the city versus the cost of the proposed facility or expansion attached.

Attachment: Click to enter text.

2. Utility CCN areas

Is any portion of the proposed service area located inside another utility's CCN area?

¹ https://www.tceq.texas.gov/permitting/wastewater/tceq-regionalization-for-wastewater

□ Yes □ No
If yes , attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the CCN facilities versus the cost of the proposed facility or expansion.
Attachment: Click to enter text.
3. Nearby WWTPs or collection systems
Are there any domestic permitted wastewater treatment facilities or collection systems located within a three-mile radius of the proposed facility?
⊠ Yes □ No
If yes , attach a list of these facilities and collection systems that includes each permittee's name and permit number, and an area map showing the location of these facilities and collection systems.
Attachment: Appendix O
If yes , attach proof of mailing a request for service to each facility and collection system, the letters requesting service, and correspondence from each facility and collection system.
Attachment: Appendix O
If the facility or collection system agrees to provide service, attach a justification for the proposed facility and a cost analysis of expenditures that includes the cost of connecting to the facility or collection system versus the cost of the proposed facility or expansion.
Attachment: Appendix P
Attachment: Appendix P
Attachment: Appendix P Section 2. Proposed Organic Loading (Instructions Page 59)
Attachment: Appendix P Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? □ Yes ⋈ No
Attachment: Appendix P Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation?
Attachment: Appendix P Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? ☐ Yes ☑ No If no, proceed to Item B, Proposed Organic Loading.
Attachment: Appendix P Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? ☐ Yes ☑ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading
Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? ☐ Yes ☑ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading
Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? ☐ Yes ☑ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading Facility Design Flow (flow being requested in application): Click to enter text.
Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? ☐ Yes ☑ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading Facility Design Flow (flow being requested in application): Click to enter text. Average Influent Organic Strength or BOD ₅ Concentration in mg/l: Click to enter text. Average Influent Loading (lbs/day = total average flow X average BOD ₅ conc. X 8.34): Click
Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? ☐ Yes ☒ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading Facility Design Flow (flow being requested in application): Click to enter text. Average Influent Organic Strength or BOD5 Concentration in mg/l: Click to enter text. Average Influent Loading (lbs/day = total average flow X average BOD5 conc. X 8.34): Click to enter text.
Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? □ Yes ⋈ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading Facility Design Flow (flow being requested in application): Click to enter text. Average Influent Organic Strength or BOD5 Concentration in mg/l: Click to enter text. Average Influent Loading (lbs/day = total average flow X average BOD5 conc. X 8.34): Click to enter text. Provide the source of the average organic strength or BOD5 concentration.
Section 2. Proposed Organic Loading (Instructions Page 59) Is this facility in operation? □ Yes ⋈ No If no, proceed to Item B, Proposed Organic Loading. If yes, provide organic loading information in Item A, Current Organic Loading A. Current organic loading Facility Design Flow (flow being requested in application): Click to enter text. Average Influent Organic Strength or BOD5 Concentration in mg/l: Click to enter text. Average Influent Loading (lbs/day = total average flow X average BOD5 conc. X 8.34): Click to enter text. Provide the source of the average organic strength or BOD5 concentration.

B. Proposed organic loading

This table must be completed if this application is for a facility that is not in operation or if this application is to request an increased flow that will impact organic loading.

Table 1.1(1) - Design Organic Loading

Source	Total Average Flow (MGD)	Influent BOD5 Concentration (mg/l)
Municipality		
Subdivision		
Trailer park - transient		
Mobile home park		
School with cafeteria and showers		
School with cafeteria, no showers		
Recreational park, overnight use		
Recreational park, day use		
Office building or factory	0.150	400
Motel		
Restaurant		
Hospital		
Nursing home		
Other		
TOTAL FLOW from all sources	0.150 MGD	400
AVERAGE BOD₅ from all sources		

Section 3. Proposed Effluent Quality and Disinfection (Instructions Page 59)

A. Existing/Interim I Phase Design Effluent Quality

Biochemical Oxygen Demand (5-day), mg/l: <u>5.0</u>

Total Suspended Solids, mg/l: <u>5.0</u>

Ammonia Nitrogen, mg/l: <u>2.0</u> Total Phosphorus, mg/l: <u>1.0</u>

Dissolved Oxygen, mg/l: <u>5.0</u>

Other: Click to enter text.

В.	Interim II Phase Design Effluent Quality Biochemical Oxygen Demand (5-day), mg/l: 5.0 Total Suspended Solids, mg/l: 5.0 Ammonia Nitrogen, mg/l: 2.0 Total Phosphorus, mg/l: 1.0 Dissolved Oxygen, mg/l: 5.0 Other: Click to enter text.
C.	Final Phase Design Effluent Quality
	Biochemical Oxygen Demand (5-day), mg/l: <u>5.0</u>
	Total Suspended Solids, mg/l: <u>5.0</u>
	Ammonia Nitrogen, mg/l: <u>2.0</u>
	Total Phosphorus, mg/l: <u>1.0</u>
	Dissolved Oxygen, mg/l: <u>5.0</u>
	Other: <u>Click to enter text.</u>
D.	Disinfection Method
	Identify the proposed method of disinfection.
	\boxtimes Chlorine: 1 mg/l after 20 minutes detention time at peak flow
	Dechlorination process: <u>Chlorine Contact Basin</u>
	☐ Ultraviolet Light: <u>Click to enter text.</u> seconds contact time at peak flow
	□ Other: <u>Click to enter text.</u>
Se	ection 4. Design Calculations (Instructions Page 59)
	tach design calculations and plant features for each proposed phase. Example 4 of the structions includes sample design calculations and plant features.
	Attachment: Appendix J
Se	ection 5. Facility Site (Instructions Page 60)
٨	100-year floodplain
Λ.	Will the proposed facilities be located <u>above</u> the 100-year frequency flood level?
	✓ Yes □ No
	If no , describe measures used to protect the facility during a flood event. Include a site map showing the location of the treatment plant within the 100-year frequency flood level. If applicable, provide the size and types of protective structures.
	Click to enter text.

Provide the source(s) used to determine 100-year frequency flood plain. FEMA MAP: 48491C0575F (APPENDIX L) For a new or expansion of a facility, will a wetland or part of a wetland be filled? Yes 🖂 If yes, has the applicant applied for a US Corps of Engineers 404 Dredge and Fill Permit? Yes □ No **If yes**, provide the permit number: Click to enter text. If no, provide the approximate date you anticipate submitting your application to the Corps: Click to enter text. B. Wind rose Attach a wind rose: Appendix M Permit Authorization for Sewage Sludge Disposal Section 6. (Instructions Page 60) A. Beneficial use authorization Are you requesting to include authorization to land apply sewage sludge for beneficial use on property located adjacent to the wastewater treatment facility under the wastewater permit? Yes \boxtimes If yes, attach the completed Application for Permit for Beneficial Land Use of Sewage Sludge (TCEQ Form No. 10451): Click to enter text. B. Sludge processing authorization Identify the sludge processing, storage or disposal options that will be conducted at the wastewater treatment facility: Sludge Composting Marketing and Distribution of sludge Sludge Surface Disposal or Sludge Monofill If any of the above, sludge options are selected, attach the completed **Domestic** Wastewater Permit Application: Sewage Sludge Technical Report (TCEQ Form No.

Section 7. Sewage Sludge Solids Management Plan (Instructions Page 61)

Attach a solids management plan to the application.

Attachment: Appendix N

10056): Click to enter text.

The sewage sludge solids management plan must contain the following information:

Treatment units and processes dimensions and capacities

- Solids generated at 100, 75, 50, and 25 percent of design flow
- Mixed liquor suspended solids operating range at design and projected actual flow
- Quantity of solids to be removed and a schedule for solids removal
- Identification and ownership of the ultimate sludge disposal site
- For facultative lagoons, design life calculations, monitoring well locations and depths, and the ultimate disposal method for the sludge from the facultative lagoon

An example of a sewage sludge solids management plan has been included as Example 5 of the instructions.

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.0: RECEIVING WATERS

The following information is required for all TPDES permit applications.

• • • • • • • • • • • • • • • • • • • •
Section 1. Domestic Drinking Water Supply (Instructions Page 64)
Is there a surface water intake for domestic drinking water supply located within 5 miles downstream from the point or proposed point of discharge?
□ Yes ⊠ No
If no , proceed it Section 2. If yes , provide the following:
Owner of the drinking water supply: <u>Click to enter text.</u>
Distance and direction to the intake: <u>Click to enter text.</u>
Attach a USGS map that identifies the location of the intake.
Attachment: Click to enter text.
Section 2. Discharge into Tidally Affected Waters (Instructions Page 64)
Does the facility discharge into tidally affected waters?
□ Yes ⊠ No
If no , proceed to Section 3. If yes , complete the remainder of this section. If no, proceed to Section 3.
A. Receiving water outfall
Width of the receiving water at the outfall, in feet: $\underline{N/A}$
B. Oyster waters
Are there oyster waters in the vicinity of the discharge?
□ Yes ⊠ No
If yes, provide the distance and direction from outfall(s).
Click to enter text.
C. Sea grasses
Are there any sea grasses within the vicinity of the point of discharge?
□ Yes ⊠ No
If yes, provide the distance and direction from the outfall(s).
Click to enter text.

Section 3. **Classified Segments (Instructions Page 64)** Is the discharge directly into (or within 300 feet of) a classified segment? Yes 🗵 No **If yes**, this Worksheet is complete. **If no,** complete Sections 4 and 5 of this Worksheet. Section 4. **Description of Immediate Receiving Waters (Instructions Page 65)** Name of the immediate receiving waters: Unknown Tributary of Mustang Creek A. Receiving water type Identify the appropriate description of the receiving waters. \boxtimes Stream Freshwater Swamp or Marsh П Lake or Pond Surface area, in acres: Click to enter text. Average depth of the entire water body, in feet: Click to enter text. Average depth of water body within a 500-foot radius of discharge point, in feet: Click to enter text. Man-made Channel or Ditch Open Bay Tidal Stream, Bayou, or Marsh Other, specify: Click to enter text. **B.** Flow characteristics If a stream, man-made channel or ditch was checked above, provide the following. For existing discharges, check one of the following that best characterizes the area *upstream* of the discharge. For new discharges, characterize the area downstream of the discharge (check one). Intermittent - dry for at least one week during most years Intermittent with Perennial Pools - enduring pools with sufficient habitat to maintain significant aquatic life uses Perennial - normally flowing Check the method used to characterize the area upstream (or downstream for new dischargers). \boxtimes USGS flow records Historical observation by adjacent landowners \boxtimes Personal observation Other, specify: Click to enter text.

		e names of all perennial strea tream of the discharge point.	ms that joi	n the receiving water within three miles				
	Unkno	own tributary of Mustang Creek						
D.	Downs	stream characteristics						
	discha	rge (e.g., natural or man-made		vithin three miles downstream of the nds, reservoirs, etc.)?				
	\boxtimes	Yes 🗆 No						
		discuss how.						
				lish Lake. After 3 stream miles, the effluent y Creek after approximately 3.5 miles				
E.	Provide	l dry weather characteristic e general observations of the abed is typically dry during norm	water body	during normal dry weather conditions.				
	Date a	nd time of observation: 4/19/:	2024					
		e water body influenced by s		runoff during observations?				
		Yes □ No		ranon daring observations.				
Se	ection	5. General Character Page 66)	ristics of	the Waterbody (Instructions				
A.	Upstre	am influences						
		Is the immediate receiving water upstream of the discharge or proposed discharge site influenced by any of the following? Check all that apply.						
		Oil field activities		Urban runoff				
		Upstream discharges		Agricultural runoff				
		Septic tanks		Other(s), specify: Click to enter text.				

C. Downstream perennial confluences

B. Waterbody uses Observed or evidences of the following uses. Check all that apply. Livestock watering Contact recreation \boxtimes Irrigation withdrawal Non-contact recreation Fishing **Navigation** Domestic water supply Industrial water supply Other(s), specify: Click to enter text. Park activities C. Waterbody aesthetics Check one of the following that best describes the aesthetics of the receiving water and the surrounding area. Wilderness: outstanding natural beauty; usually wooded or unpastured area; water clarity exceptional Natural Area: trees and/or native vegetation; some development evident (from \boxtimes fields, pastures, dwellings); water clarity discolored Common Setting: not offensive; developed but uncluttered; water may be colored

Offensive: stream does not enhance aesthetics; cluttered; highly developed;

or turbid

dumping areas; water discolored

DOMESTIC WASTEWATER PERMIT APPLICATION WORKSHEET 2.1: STREAM PHYSICAL CHARACTERISTICS

Required for new applications, major facilities, and applications adding an outfall.

Worksheet 2.1 is not required for discharges to intermittent streams or discharges directly to (or within 300 feet of) a classified segment.

Section 1. General Information (Instructions Page 66)
Date of study: <u>05/23/22024</u> Time of study: <u>2:25 pm</u>
Stream name: <u>Unknown Tributary of Mustang Creek</u>
Location: 0.16 miles northeast of the intersection of FM 112 and 112 and Tucek Road
Type of stream upstream of existing discharge or downstream of proposed discharge (check one).
\square Perennial \boxtimes Intermittent with perennial pools
Section 2. Data Collection (Instructions Page 66)
Number of stream bends that are well defined: 1
Number of stream bends that are moderately defined: <u>o</u>
Number of stream bends that are poorly defined: <u>o</u>
Number of riffles: 1
Evidence of flow fluctuations (check one):
Indicate the observed stream uses and if there is evidence of flow fluctuations or channel obstruction/modification.
The observed stream use was agricultural irrigation. No major flow fluctuations were visible.

Stream transects

In the table below, provide the following information for each transect downstream of the existing or proposed discharges. Use a separate row for each transect.

Table 2.1(1) - Stream Transect Records

Stream type at transect	Transect location	Water surface	Stream depths (ft) at 4 to 10 points along each
Select riffle, run, glide, or pool. See Instructions, Definitions section.		width (ft)	transect from the channel bed to the water surface. Separate the measurements with commas.
Run	30.566457, -97.358453	5.5	0.25
Run	30.566163, -97.358531	3.5	0.125
Riffle	30.565832, -97.358649	2.5	0.083
Glide	30.565482, -97.358771	2.5	0.083
Run	30.565235, -97.358755	5	0.083
Choose an item.			

Section 3. Summarize Measurements (Instructions Page 66)

Streambed slope of entire reach, from USGS map in feet/feet: 0.008

Approximate drainage area above the most downstream transect (from USGS map or county highway map, in square miles): <u>0.27</u>

Length of stream evaluated, in feet: 600

Number of lateral transects made: <u>5</u> Average stream width, in feet: <u>3.8</u> Average stream depth, in feet: <u>0.125</u>

Average stream velocity, in feet/second: <u>0.5</u>

Instantaneous stream flow, in cubic feet/second: 0.23

Indicate flow measurement method (type of meter, floating chip timed over a fixed distance, etc.): Floating Object timed over a fixed distance

Size of pools (large, small, moderate, none): <u>None measured on studied portion of reach.</u>
<u>Downstream properties are private and fenced which does not allow for access for measurements.</u>

Maximum pool don'th in fact: None measured on studied portion of reach. Downstream properties
Maximum pool depth, in feet: <u>None measured on studied portion of reach. Downstream properties</u> are private and fenced which does not allow for access for measurements.

APPENDIX A:

PLAIN LANGUAGE SUMMARY

Plain Language Summary - TPDES New Application

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

NMCV Taylor Property Investors LLC (CN#) proposes to operate 487 Acre Taylor Tract Wastewater Treatment Plant RN# N/A. a 0.15 MGD WWTP facility. The facility will be located Approximately 0.16 miles Northeast from the intersection of FM 112 and Tucek Road, in Taylor, Williamson County, Texas 76574.

This is for a new application to discharge processed wastewater at an average daily flow of 150,000 gallons per day on an intermittent and flow-variable basis.

Discharges from the facility are expected to containfive-day carbonaceous biochemical oxygen demand $(CBOD_5)$, total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia Coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Domestic wastewater will be treated by a suspended growth activated sludge process in extended aeration mode and the treatment units will include a mechanical auger screen, equalization basin, aeration tanks, a chlorine contact chamber.

PLANTILLA EN INGLÉS PARA SOLICITUDES DE NUEVA/RENOVACIÓN/ENMIENDA TPDES o TLAP

AGUAS RESIDUALES DOMÉSTICAS

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo exige el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es federal. representaciones ejecutables de la solicitud de permiso.

NMCV Taylor Property Investors LLC (CN#) propone operar la planta de tratamiento de aguas residuales de 487 Acre Taylor Tract RN# N/A. una instalación de PTAR de 0.15 MGD. La instalación estará ubicada aproximadamente a 0,16 millas al noreste de la intersección de FM 112 y Tucek Road, en Taylor, condado de Williamson, Texas 76574.

Esto es para una nueva aplicación para descargar aguas residuales procesadas a un flujo diario promedio de 150,000 galones por día de forma intermitente y de flujo variable.

Se espera que las descargas de la instalación contengan demanda bioquímica de oxígeno carbonoso (CBOD5) de cinco días, sólidos suspendidos totales (SST), nitrógeno amoniacal (NH3-N) y Escherichia coli. Se incluyen contaminantes potenciales adicionales en el Informe Técnico Nacional 1.0, Sección 7. Las aguas residuales domésticas serán tratadas mediante un proceso de lodos activados de crecimiento suspendido en modo de aireación extendida y las unidades de tratamiento incluirán una criba de tornillo mecánico, un estanque de ecualización, tanques de aireación, un sistema de cloro. cámara de contacto.

APPENDIX B:

CORE DATA FORM

TCEQ Use Only



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

ECTION II: Customer Information 5. Effective Date for Customer Information Updates (mm/dd/yyyy) New Customer	ecretary of State	
ECTION II: Customer Information S. Effective Date for Customer Information Updates (mm/dd/yyyy) New Customer Update to Customer Information Change in Regulated Entity Ownership Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts) The Customer Name submitted here may be updated automatically based on what is current and active with the Texas S (SOS) or Texas Comptroller of Public Accounts (CPA). 6. Customer Legal Name (If an individual, print last name first: eg: Doe, John) If new Customer, enter previous Cust NMCV Taylor Property Investors LLC 7. TX SOS/CPA Filing Number 0803961657 8. TX State Tax ID (11 digits) 9. Federal Tax ID applicab (9 digits) 10. DUI applicab		
S. Effective Date for Customer Information Updates (mm/dd/yyyy)		
New Customer		
Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts) Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts) Change in Legal Name submitted here may be updated automatically based on what is current and active with the Texas State Sta		
Change in Legal Name (Verifiable with the Texas Secretary of State or Texas Comptroller of Public Accounts) The Customer Name submitted here may be updated automatically based on what is current and active with the Texas S (SOS) or Texas Comptroller of Public Accounts (CPA). 5. Customer Legal Name (If an individual, print last name first: eg: Doe, John) If new Customer, enter previous Custo		
The Customer Name submitted here may be updated automatically based on what is current and active with the Texas S (SOS) or Texas Comptroller of Public Accounts (CPA). 5. Customer Legal Name (If an individual, print last name first: eg: Doe, John) NMCV Taylor Property Investors LLC 7. TX SOS/CPA Filling Number 8. TX State Tax ID (11 digits) 32078082891 9. Federal Tax ID (9 digits) 10. DUI applicab 11. Type of Customer:		
7. TX SOS/CPA Filing Number 8. TX State Tax ID (11 digits) 9. Federal Tax ID 10. DUI applicab 0803961657 32078082891 (9 digits) 11. Type of Customer: Corporation Individual Partnership:		
20803961657 32078082891 (9 digits) applicab 11. Type of Customer: Corporation Individual Partnership:		
11. type of customer:	applicable)	
11.1790.0.0030.000	Partnership: ☐ General ☑ Limited ☑ Other: Limited Liability Company	
Government: City County Federal Local State Other Sole Proprietorship		
12. Number of Employees 13. Independently Owned and	Operated?	
□ 0-20 □ 21-100 □ 101-250 □ 251-500 □ 501 and higher □ Yes □ No		
14. Customer Role (Proposed or Actual) – as it relates to the Regulated Entity listed on this form. Please check one of the following		
Owner ☐ Operator ☐ Owner & Operator ☐ Other: ☐ Occupational Licensee ☐ Responsible Party ☐ VCP/BSA Applicant		
15. Mailing 2225 High Lonesome		
Address: City Leander State TX ZIP 78641 ZIP + 4	3296	
16. Country Mailing Information (if outside USA) 17. E-Mail Address (if applicable)		

TCEQ-10400 (11/22) Page 1 of 3

) -

SECTION III: Regulated Entity Information

1. General Regulated Er ☑ New Regulated Entity		gulated Entity Name						
								l andinae eu
he Regulated Entity Na is Inc, LP, or LLC).	me submitted i	nay be updated, ii	n order to meet	TCEQ Core	Data Stana	aras (removal o) org	junizaciona 1	
22. Regulated Entity Nar	ne (Enter name d	of the site where the	regulated action	is taking place	2.)			
187 Acre Taylor Tract Waste	water Treatment	Plant						
23. Street Address of the Regulated Entity:								
'No PO Boxes)	City		State		ZIP		ZIP + 4	
24. County	Williamson Co	ounty						
		If no Street Ad	dress is provid	ed, fields 25	-28 are req	uired.		
25. Description to Physical Location:	The location is	s approximately 0.16	miles Northeast	of the interse	ction of FM 1	12 and Tucek Road in \	Williamson Co	ounty, Texas.
26. Nearest City				7. 7.		State	Near	est ZIP Code
Taylor					1	TX	76574	1
Latitude/Longitude are used to supply coordina 27. Latitude (N) In Deci	ites where non	e have been provided 30.565409	ded or to gain (accuracy).) In Decimal:	-97.35881	
Degrees	Minutes	Seco	onds	Degree	<u>e</u> s	Minutes		Seconds
30	33		55.5		-97	21		31.8
29. Primary SIC Code (4 digits)	30. S	secondary SIC Code	e	31. Primar (5 or 6 digit	y NAICS Coo	32. Seco (5 or 6 di	ondary NAIC	S Code
4952				22132				
33. What is the Primary	y Business of th	nis entity? (Do not	repeat the SIC o	r NAICS descr	ption.)			
Wastewater Treatment								
34. Mailing	2 225 High l	onesome.						
Address:	201001 <u>1</u> 015	1. ,		TV	710	78641	ZIP + 4	3 296
	City	Leander	State	TX	ZIP	70041		
35. E-Mail Address:			No. 10 Oy 60 To an of 60 California					
		3.	7. Extension or	Code	38. F	ax Number (if applica	ible)	Tabbin tak
36. Telephone Number								

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

TCEQ-10400 (11/22) Page 2 of 3

☐ Dam Safety		Districts	Edwards Aquifer		Emissions Inventory	Air	Industrial Hazardous Waste
Municipal Solid	Waste	New Source	OSSF]	Petroleum Storage T	ānk	PWS
Sludge		Storm Water	☐ Title V Air		Tires		Used Oil
☐ Voluntary Clear	nup		☐ Wastewater Agric	culture [Water Rights		Other:
					1000		
SECTION	IV: Pr	<u>eparer Inf</u>	<u>ormation</u>				
40. Name: La	uren Crone, F	P.E.		41. Title:	Senior Project Mar	nager	
42. Telephone Nu	mber	43. Ext./Code	44. Fax Number	45. E-Ma	il Address	i ivii	
(512)439-4700			() -	lcrone@lja	a.com		
		thorized S					and that I have cignature authority
46. By my signature b to submit this form or	pelow, I certify on behalf of th	y, to the best of my kno le entity specified in Se	owledge, that the informa ction II, Field 6 and/or as	required for the	updates to the ID num	bers ider	and that I have signature authority ntified in field 39.
Company:	NMCV Ta	aylor Property Investors	LLC	Job Title:	Manager		
Name (In Print):	Nirav Shr	roff			Pho	ne:	1512825-8837
Signature:	N	lisaide	54.11		Date	e:	04/18/24

APPENDIX C:

PUBLIC INVOLVEMENT PLAN FORM

Public Involvement Plan Form for Permit and Registration Applications

The Public Involvement Plan is intended to provide applicants and the agency with information about how public outreach will be accomplished for certain types of applications in certain geographical areas of the state. It is intended to apply to new activities; major changes at existing plants, facilities, and processes; and to activities which are likely to have significant interest from the public. This preliminary screening is designed to identify applications that will benefit from an initial assessment of the need for enhanced public outreach.

All applicable sections of this form should be completed and submitted with the permit or registration application. For instructions on how to complete this form, see TCEQ-20960-inst.

Section 1. Preliminary Screening

New Permit or Registration Application

New Activity - modification, registration, amendment, facility, etc. (see instructions)

If neither of the above boxes are checked, completion of the form is not required and does not need to be submitted.

Section 2. Secondary Screening

Requires public notice,

Considered to have significant public interest, and

Located within any of the following geographical locations:

- Austin
- Dallas
- Fort Worth
- Houston
- San Antonio
- West Texas
- Texas Panhandle
- Along the Texas/Mexico Border
- Other geographical locations should be decided on a case-by-case basis

If all the above boxes are not checked, a Public Involvement Plan is not necessary. Stop after Section 2 and submit the form.

Public Involvement Plan not applicable to this application. Provide **brief** explanation.

TCEQ-20960 (02-09-2023)

Section 3. Application Information

Type of Application (check all that apply):

Air Initial Federal Amendment Standard Permit Title V

Waste Municipal Solid Waste Industrial and Hazardous Waste Scrap Tire

Radioactive Material Licensing Underground Injection Control

Water Quality

Texas Pollutant Discharge Elimination System (TPDES)

Texas Land Application Permit (TLAP)

State Only Concentrated Animal Feeding Operation (CAFO)

Water Treatment Plant Residuals Disposal Permit

Class B Biosolids Land Application Permit

Domestic Septage Land Application Registration

Water Rights New Permit

New Appropriation of Water

New or existing reservoir

Amendment to an Existing Water Right

Add a New Appropriation of Water

Add a New or Existing Reservoir

Major Amendment that could affect other water rights or the environment

Section 4. Plain Language Summary

D ' 1	1 1		C 1 1	
Provide 3	hrigt d	accrintion	of planned	activation
I I OVIUE a	титет и	CSCLIDUOL	от планиси	activities.

Section 5. Community and Demographic Information

Community information can be found using EPA's EJ Screen, U.S. Census Bureau information, or generally available demographic tools.

Information gathered in this section can assist with the determination of whether alternative language notice is necessary. Please provide the following information.

language notice is n	ecessary. Please pro	ovide the following info	ormation.	
(City)				
(County)				
(Census Tract) Please indicate which City	of these three is the County	e level used for gatherin Census Tract	ng the following informat	tion.
(a) Percent of people	over 25 years of age	e who at least graduated	from high school	
- -		the specified location	race within the specified	location
(d) Percent of Linguis	stically Isolated Hous	seholds by language wit	hin the specified locatior	1
(e) Languages commo	only spoken in area l	by percentage		
(f) Community and/o	or Stakeholder Group	os		
(g) Historic public int	terest or involvemen	t		

Section 6. Planned Public Outreach Activities

(a) Is this application subject to the public participation requirements of Title 30 Texas Administrative Code (30 TAC) Chapter 39?

Yes No

(b) If yes, do you intend at this time to provide public outreach other than what is required by rule?

Yes No

If Yes, please describe.

If you answered "yes" that this application is subject to 30 TAC Chapter 39, answering the remaining questions in Section 6 is not required.

(c) Will you provide notice of this application in alternative languages?

Yes No

Please refer to Section 5. If more than 5% of the population potentially affected by your application is Limited English Proficient, then you are required to provide notice in the alternative language.

If yes, how will you provide notice in alternative languages?

Publish in alternative language newspaper

Posted on Commissioner's Integrated Database Website

Mailed by TCEQ's Office of the Chief Clerk

Other (specify)

(d) Is there an opportunity for some type of public meeting, including after notice?

Yes No

(e) If a public meeting is held, will a translator be provided if requested?

Yes No

(f) Hard copies of the application will be available at the following (check all that apply):

TCEQ Regional Office

TCEQ Central Office

Public Place (specify)

Section 7. Voluntary Submittal

For applicants voluntarily providing this Public Involvement Plan, who are not subject to formal public participation requirements.

Will you provide notice of this application, including notice in alternative languages?

Yes No

What types of notice will be provided?

Publish in alternative language newspaper


Posted on Commissioner's Integrated Database Website

Mailed by TCEQ's Office of the Chief Clerk

Other (specify)

APPENDIX D:


USGS MAPS



APPENDIX E:

AFFECTED LANDOWNERS MAP AND LIST

Map Number	Landowner Name	Landowner Address (1)	Landowner Address (2)
1	PREWITT FARM & ZIZINIA WILLIAMSON COUNTY LTD	79 HWY/619 FM THRALL, TX 76578	5105 ASPEN ST, BELLAIRE, TX 77401
2	CARLSON, CONNIE R W	6701 FM 112, TAYLOR, TX 76574	2760 COUNTY ROAD 421, TAYLOR, TX 76574
3	S2F HOLDING LLC & SATHISH BABU CHAKKA	FM 112, THRALL, TX 76578	4126 REMINGTON RD, CEDAR PARK, TX 78613
4	MORRIS, JAMES & LISA	3280 FM 112, TAYLOR, TX 76574	PO BOX 1208, TAYLOR, TX 76574
5	WILLIAMS, BOBBIE LEE	FM 112, TAYLOR, TX 76574	3300 FM 112, TAYLOR, TX 76574
6	OMAN, TROY L	3350 FM 112, TAYLOR, TX 76574	3301 FM 112, TAYLOR, TX 76574
7	POKOJSKI, JOHN F	3400 FM 112, TAYLOR, TX 76574	3400 FM 112, TAYLOR, TX 76574
8	SMITH, STEPHEN	3406 FM 112, TAYLOR, TX 76574	3406 FM 112, TAYLOR, TX 76574
9	ZYCHA LONNIE D SR & CONNIE & LONNIE D JR	3450 FM 112, TAYLOR, TX 76574	3450 FM 112, TAYLOR TX 76574
10	WERNER, CHARLES E	3550 FM 112, TAYLOR, TX 76574	3550 FM 112, TAYLOR TX 76574
11	DAUGHERTY, JAMES & HEIDI	3600 FM 112, TAYLOR, TX 76574	3600 FM 112, TAYLOR TX 76574
12	MILLER, JAMES FRANK & NETTIE LYNN	3610 FM 112, TAYLOR, TX 76574	3610 FM 112, TAYLOR, TX 76574
13	TATROW, ROBERT JAMES	3650 FM 112, TAYLOR, TX 76574	3650 FM 112, TAYLOR TX 76574
14	JIRASEK DONALD (LE)	50 CR 446, TAYLOR, TX 76574	50 CR 446, TAYLOR TX 76574
15	BARNETT, ADELINA	71 CR 446, TAYLOR, TX 76574	71 COUNTY ROAD 446 TAYLOR TX 76574
16	ZIESCHANG, MORRIS & BARBARA	4701 FM 112, TAYLOR, TX 76574	4701 FM 112 TAYLOR TX 76574
17	T W FORD LP	Highway 79, TAYLOR, TX 76574	PO BOX 128 TAYLOR TX 76574
18	BDB INDUSTRIES LLC	21545 Highway 79, THRALL, TX 76578	21545 US HWY 79 TAYLOR TX 76574
19	METZGER, KATHY & DON PETERS & T HALL & J FUSILIER	21481 Highway 79, THRALL, TX 76578	4304 MIRAMAR DR GEORGETOWN TX 78628
20	MOUNT VERNON LLC	3701 E 4TH ST, TAYLOR, TX 76574	1900 IH 10 WEST SEQUIN TX 78155
21	JOHNSON, NORMAN	3609 E 4TH ST, TAYLOR, TX 76574	3609 E 4TH ST, TAYLOR, TX 76574
22	CRABBOLL II LLC	20901 US 79, TAYLOR, TX 76574	3509 E 4TH ST TAYLOR TX 76574
23	STAR TECH SERVICE LLC	20875 US 79, TAYLOR, TX 76574	PO BOX 112 TAYLOR TX 76574
24	HARRINGTON, GLENNETH & MISA	220 TUCEK RD, TAYLOR, TX 76574	220 TUCEK RD, TAYLOR, TX 76574
25	SHIPLEY, MICHAEL RICHARD	250 TUCEK RD, TAYLOR, TX 76574	250 TUCEK RD, TAYLOR, TX 76574
26	TUCEK, MATTHEW AARON	300 TUCEK RD, TAYLOR, TX 76574	300 TUCEK RD, TAYLOR, TX 76574
27	HARWELL, WILLIAM G & CYNTHIA D	330 TUCEK RD, TAYLOR, TX 76574	330 TUCEK RD, TAYLOR, TX 76574
28	BAUER, GAYLORD E & CAROLYN S	450 TUCEK RD, TAYLOR, TX 76574	450 TUCEK RD, TAYLOR, TX 76574
29	LOPEZ, PHILLIP S	480 TUCEK DR, TAYLOR, TX 76574	480 TUCEK DR, TAYLOR, TX 76574
30	GANDER, CLYDE EARL & JUDITH KAY	500 TUCEK DR, TAYLOR, TX 76574	209 E 8TH ST, LOS FRESNOS TX, 78566
31	ROCHA, ANNA MARIA RIOS	№10 TUCEK DR, THRALL, TX 76578	510 TUCEK DR, THRALL, TX 76578
32	YOUNG, DARYL L & LAURIE A	600 TUCEK RD, TAYLOR TX, 76574	600 TUCEK RD, TAYLOR TX, 76574
33	S2F HOLDING LLC & SATHISH BABU CHAKKA	4126 REMINGTON RD, CEDAR PARK, TX 78613	FM 112, THRALL, TX 76578
34	ALBRECHT, MARK	29 SUNRISE ROAD, CODY, WY 82414	CR 446, THRALL, TX 76578
35	MALISH, JUDITH M	631 CR 445, TAYLOR, TX 76574	631 CR 445, TAYLOR, TX 76574




(2) (2) (3) (19) (19) (19) (19) (19) (19) (19) (19	79					
			Map Number	Landowner Name	Landowner Address (1)	Landowner Address (2)
			1	PREWITT FARM & ZIZINIA WILLIAMSON COUNTY LTD	79 HWY/619 FM THRALL, TX 76578	5105 ASPEN ST, BELLAIRE, TX 77401
	PROPERTY BOUNDARY — \		2	CARLSON, CONNIE R W	6701 FM 112, TAYLOR, TX 76574	2760 COUNTY ROAD 421, TAYLOR, TX 76574
			3	S2F HOLDING LLC & SATHISH BABU CHAKKA	FM 112, THRALL, TX 76578	4126 REMINGTON RD, CEDAR PARK, TX 78613
			4	MORRIS, JAMES & LISA	3280 FM 112, TAYLOR, TX 76574	PO BOX 1208, TAYLOR, TX 76574
			5	WILLIAMS, BOBBIE LEE	FM 112, TAYLOR, TX 76574	3300 FM 112, TAYLOR, TX 76574
			6	OMAN, TROY L	3350 FM 112, TAYLOR, TX 76574	3301 FM 112, TAYLOR, TX 76574
			7	POKOJSKI, JOHN F	3400 FM 112, TAYLOR, TX 76574	3400 FM 112, TAYLOR, TX 76574
		\	8	SMITH, STEPHEN	3406 FM 112, TAYLOR, TX 76574	3406 FM 112, TAYLOR, TX 76574
	WWTP LOCATION – \	16	9	ZYCHA LONNIE D SR & CONNIE & LONNIE D JR	3450 FM 112, TAYLOR, TX 76574	3450 FM 112, TAYLOR TX 76574
		•	10	WERNER, CHARLES E	3550 FM 112, TAYLOR, TX 76574	3550 FM 112, TAYLOR TX 76574
			11	DAUGHERTY, JAMES & HEIDI	3600 FM 112, TAYLOR, TX 76574	3600 FM 112, TAYLOR TX 76574
			12	MILLER, JAMES FRANK & NETTIE LYNN	3610 FM 112, TAYLOR, TX 76574	3610 FM 112, TAYLOR, TX 76574
150' BUF	FER ZONE — /		13	TATROW, ROBERT JAMES	3650 FM 112, TAYLOR, TX 76574	3650 FM 112, TAYLOR TX 76574
			14	JIRASEK DONALD (LE)	50 CR 446, TAYLOR, TX 76574	50 CR 446, TAYLOR TX 76574
		\	15	BARNETT, ADELINA	71 CR 446, TAYLOR, TX 76574	71 COUNTY ROAD 446 TAYLOR TX 76574
			16	ZIESCHANG, MORRIS & BARBARA	4701 FM 112, TAYLOR, TX 76574	4701 FM 112 TAYLOR TX 76574
GRAVITY WASTEWATER LINE	TO_{\sim}	\	17	T W FORD LP	Highway 79, TAYLOR, TX 76574	PO BOX 128 TAYLOR TX 76574
			18	BDB INDUSTRIES LLC	21545 Highway 79, THRALL, TX 76578	21545 US HWY 79 TAYLOR TX 76574
DISCHARGE PO		M 112	19	METZGER, KATHY & DON PETERS & T HALL & J FUSILIER	21481 Highway 79, THRALL, TX 76578	4304 MIRAMAR DR GEORGETOWN TX 78628
			20	MOUNT VERNON LLC	3701 E 4TH ST, TAYLOR, TX 76574	1900 IH 10 WEST SEQUIN TX 78155
(2)	8 9 10		21	JOHNSON, NORMAN	3609 E 4TH ST, TAYLOR, TX 76574	3609 E 4TH ST, TAYLOR, TX 76574
			22	CRABBOLL II LLC	20901 US 79, TAYLOR, TX 76574	3509 E 4TH ST TAYLOR TX 76574
			23	STAR TECH SERVICE LLC	20875 US 79, TAYLOR, TX 76574	PO BOX 112 TAYLOR TX 76574
DISCHARGE POINT			24	HARRINGTON, GLENNETH & MISA	220 TUCEK RD, TAYLOR, TX 76574	220 TUCEK RD, TAYLOR, TX 76574
DISCHARGE FORM			25	SHIPLEY, MICHAEL RICHARD	250 TUCEK RD, TAYLOR, TX 76574	250 TUCEK RD, TAYLOR, TX 76574
1			26	TUCEK, MATTHEW AARON	300 TUCEK RD, TAYLOR, TX 76574	300 TUCEK RD, TAYLOR, TX 76574
FM 1		1	27	HARWELL, WILLIAM G & CYNTHIA D	330 TUCEK RD, TAYLOR, TX 76574	330 TUCEK RD, TAYLOR, TX 76574
	(24)		28	BAUER, GAYLORD E & CAROLYN S	450 TUCEK RD, TAYLOR, TX 76574	450 TUCEK RD, TAYLOR, TX 76574
3			29	LOPEZ, PHILLIP S	480 TUCEK DR, TAYLOR, TX 76574	480 TUCEK DR, TAYLOR, TX 76574
	25		30	GANDER, CLYDE EARL & JUDITH KAY	500 TUCEK DR, TAYLOR, TX 76574	209 E 8TH ST, LOS FRESNOS TX, 78566
	(26)		31	ROCHA, ANNA MARIA RIOS	510 TUCEK DR, THRALL, TX 76578	510 TUCEK DR, THRALL, TX 76578
\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \			32	YOUNG, DARYL L & LAURIE A	600 TUCEK RD, TAYLOR TX, 76574	600 TUCEK RD, TAYLOR TX, 76574
			33	S2F HOLDING LLC & SATHISH BABU CHAKKA	4126 REMINGTON RD, CEDAR PARK, TX 78613	FM 112, THRALL, TX 76578
			34	ALBRECHT, MARK	29 SUNRISE ROAD, CODY, WY 82414	CR 446, THRALL, TX 76578
	(28)		35	MALISH, JUDITH M	631 CR 445, TAYLOR, TX 76574	631 CR 445, TAYLOR, TX 76574
DISCHARGE PATH	29					
	30					

(20)

1 MILE DOWNSTREAM

APPENDIX F:


ORIGINAL PHOTOGRAPHS



I:\a462 HK\0403\Exhibits\Exhibits\Landowners Map.dwg

APPENDIX G

BUFFER ZONE MAP



APPENDIX H

SPIF USGS MAPS


TEXAS COMMISSION ON ENVIRONMENTAL QUALITY SUPPLEMENTAL PERMIT INFORMATION FORM (SPIF)

FOR AGENCIES REVIEWING DOMESTIC OR INDUSTRIAL TPDES WASTEWATER PERMIT APPLICATIONS

TCEQ USE ONLY:
Application type:RenewalMajor AmendmentMinor AmendmentNew
County: Segment Number:
Admin Complete Date:
Agency Receiving SPIF:
Texas Historical Commission U.S. Fish and Wildlife
Texas Parks and Wildlife Department U.S. Army Corps of Engineers
This form applies to TPDES permit applications only. (Instructions, Page 53)
Complete this form as a separate document. TCEQ will mail a copy to each agency as required be our agreement with EPA. If any of the items are not completely addressed or further information is needed, we will contact you to provide the information before issuing the permit. Address each item completely.
Do not refer to your response to any item in the permit application form. Provide each attachment for this form separately from the Administrative Report of the application. The application will not be declared administratively complete without this SPIF form being completed in its entirety including all attachments. Questions or comments concerning this form may be directed to the Water Quality Division's Application Review and Processing Team by email at


		e the name, address, phone and fax number of an individual that can be contacted to specific questions about the property.
	Prefix (Mr., Ms., Miss): <u>Ms.</u>
	First aı	nd Last Name: <u>Lauren Crone</u>
	Creden	itial (P.E, P.G., Ph.D., etc.): <u>P.E</u>
	Title: <u>S</u>	<u>enior Project Manager</u>
	Mailing	g Address: <u>7500 Rialto Blvd., Building II, Suite 100</u>
	City, St	ate, Zip Code: <u>Austin, TX 78735</u>
	Phone	No.: <u>512-439-4700</u> Ext.: Fax No.:
	E-mail	Address: <u>lcrone@lja.com</u>
2.	List the	e county in which the facility is located: Williamson County
3.		property is publicly owned and the owner is different than the permittee/applicant, list the owner of the property.
	Click	here to enter text.
4.		e a description of the effluent discharge route. The discharge route must follow the flow
		ent from the point of discharge to the nearest major watercourse (from the point of ge to a classified segment as defined in 30 TAC Chapter 307). If known, please identify
		ssified segment number.
	New P	ermit: From the proposed treatment plant, effluent will be flow via gravity pipe roughly 1400 feet to its discharge point in an unnamed Tributary on the applicant's property. The effluent
		en travel approximately 3.0 miles to Mustang Creek (Segment 1244C).
5.	plotted route f	provide a separate 7.5-minute USGS quadrangle map with the project boundaries and a general location map showing the project area. Please highlight the discharge from the point of discharge for a distance of one mile downstream. (This map is ed in addition to the map in the administrative report).
	Provide	e original photographs of any structures 50 years or older on the property.
	Does y	our project involve any of the following? Check all that apply.
		Proposed access roads, utility lines, construction easements
		Visual effects that could damage or detract from a historic property's integrity
		Vibration effects during construction or as a result of project design
		Additional phases of development that are planned for the future
		Sealing caves, fractures, sinkholes, other karst features


	☐ Disturbance of vegetation or wetlands
1.	List proposed construction impact (surface acres to be impacted, depth of excavation, sealing of caves, or other karst features):
	Approximately 487 acres to be impacted through construction of commercial improvements. No planned sealing of caves or other features.
2.	Describe existing disturbances, vegetation, and land use:
	Predominantly ranchland.
AM	HE FOLLOWING ITEMS APPLY ONLY TO APPLICATIONS FOR NEW TPDES PERMITS AND MAJOR MENDMENTS TO TPDES PERMITS List construction dates of all buildings and structures on the property:
٥.	List construction dates of all buildings and structures on the property: N/A
4.	
	The property is mostly undeveloped and has been used as ranchland. No builder has been identified.




APPENDIX I

PROCESS FLOW DIAGRAM








APPENDIX J

SITE DRAWING



APPENDIX K

DESIGN CALCULATIONS

Taylor WWTP - WWTP FLOW PHASES

Phase 1		Phase 2		Phase 3	
<u>Assumptions</u>	0.45	<u>Assumptions</u>	0.45	<u>Assumptions</u>	0.45
Average Flow per LUE =	245 gpd	Average Flow per LUE =	245 gpd	Average Flow per LUE =	245 gpd
Average Density	3 LUEs/Ac	Average Density	3 LUEs/Ac	Average Density	3 LUEs/Ac
I/I for Wet Peak	750 gpd/Ac	I/I for Wet Peak	750 gpd/Ac	I/I for Wet Peak	750 gpd/Ac
lue-	204	LUE	400	1115-	040
LUEs	204	LUEs	408	LUEs	612
Average Daily Flow	49,980 gpd	Average Daily Flow	99,960 gpd	Average Daily Flow	149,940 gpd
	35 gpm	Average Daily Flow	69 gpm	Average Daily Flow	104 gpm
Dry Peaking Factor	3.89	Dry Peaking Factor	3.69	Dry Peaking Factor	3.56
Peak Dry Flow	135 gpm	Peak Dry Flow	256 gpm	Peak Dry Flow	371 gpm
Service Area	487 acres	Service Area	487 acres	Service Area	487 acres
I/I for Peak Wet	365,250 gpd	I/I for Peak Wet	365,250 gpd	I/I for Peak Wet	365,250 gpd
	254 gpm		254 gpm		254 gpm
Total Peak Wet Flow	389 gpm	Total Peak Wet Flow	510 gpm	Total Peak Wet Flow	625 gpm
Minimum Flow Factor	0.17	Minimum Flow Factor	0.20	Minimum Flow Factor	0.22
Minimum Flow	6 gpm	Minimum Flow	14 gpm	Minimum Flow	23 gpm

487 AC Taylor WWTP Extended Air Process Design (TCEQ Checklist)

Phase 1

Design Flow (from Summary Sheet) 0.050 mgd
Peak Flow (from Summary Sheet) 0.200 mgd

Design Organic Load 400 lb BOD / day

Clarifier Design

(Criteria)

Maximum Surface Loading @ Peak Flow 900 gpd/ft²
Minimum Detention Time @ Peak Flow 2 hrs

Maximum Surface Loading @ Design Flow 450 gpd/ft²
Minimum Detention Time @ Design Flow 4 hrs

Surface Area Required (Peak Flow) 222.2 ft² Surface Area Required (Design Flow) 111.1 ft²

> Volume Required (Peak Flow) 2,228 ft³ Volume Required (Design Flow) 1,114 ft³

Depth Required (Peak Flow) 10.0 ft Depth Required (Design Flow) 10.0 ft

Maximum Return Sludge Underflow Rate 400.0 gpd/ft²
Minimum Return Sludge Underflow Rate 200.0 gpd/ft²

(Calculations)

Proposed Sidewater Depth 12 ft

Proposed Clarifier Diameter 16 ft

Clarifier Surface Area 201 ft²

Clarifier Volume 2,413 ft³

Maximum Return Sludge Underflow Rate 56 gpm Minimum Return Sludge Underflow Rate 28 gpm

RAS Line Size (min 3 ft/sec velocity) 4 inches

Note - Min SWD is 8 ft, 10 ft if area > 1250 ft²

Aeration System Des (Criteria)	sign		
	Organic Loading Actual Design Load	15 lb BOD/day/1000 400 lb BOD/day) ft ³
	Required Volume	26667 ft ³	
	Required Air Flow	scf / lb BOD (assumes 4.0% transfer 3200 efficiency)	
(Calculations)	Г		Note - Min SWD is
	Proposed Sidewater Depth	12 ft	8 ft
	Surface Area	2,222 ft ²	
	Air Flow	889 scfm	
Aerobic Digester Des	sign		
(3)	Volume Required or	20 ft ³ / lb BOD 15 days SRT	
	Air Required	30 scfm/ 1000 ft ³ vc	lume
(Calculations)	Proposed Volume	8,000 ft ³	
	Proposed Sidewater Depth	12 ft	
	Surface Area	667 ft ²	
	Required Air Flow	240 scfm	
Chlorine Contact Des (Criteria)	sign		
,	Minimum Contact Time	20 minutes @ Peak	Flow
(Calculations)	Proposed Volume	371 ft ³	
	Proposed Sidewater Depth	12 ft	
	Surface Area	31 ft²	

487 AC Taylor WWTP Extended Air Process Design (TCEQ Checklist)

Phase 2

Design Flow (from Summary Sheet) 0.050 mgd
Peak Flow (from Summary Sheet) 0.200 mgd

Design Organic Load 400 lb BOD / day

Clarifier Design

(Criteria)

Maximum Surface Loading @ Peak Flow 900 gpd/ft²
Minimum Detention Time @ Peak Flow 2 hrs

Maximum Surface Loading @ Design Flow 450 gpd/ft²
Minimum Detention Time @ Design Flow 4 hrs

Surface Area Required (Peak Flow) 222.2 ft² Surface Area Required (Design Flow) 111.1 ft²

> Volume Required (Peak Flow) 2,228 ft³ Volume Required (Design Flow) 1,114 ft³

Depth Required (Peak Flow) 10.0 ft Depth Required (Design Flow) 10.0 ft

Maximum Return Sludge Underflow Rate 400.0 gpd/ft²
Minimum Return Sludge Underflow Rate 200.0 gpd/ft²

(Calculations)

Proposed Sidewater Depth 12 ft

Proposed Clarifier Diameter 16 ft

Clarifier Surface Area 201 ft²

Clarifier Volume 2,413 ft³

Maximum Return Sludge Underflow Rate 56 gpm Minimum Return Sludge Underflow Rate 28 gpm

RAS Line Size (min 3 ft/sec velocity) 4 inches

Note - Min SWD is 8 ft, 10 ft if area > 1250 ft²

Aeration System De (Criteria)	sign		
	Organic Loading Actual Design Load	15 lb BOD/day/100 400	00 ft ³
	Required Volume	26667 ft ³	
	Required Air Flow	3200 scf / lb BOD	(assumes 4.0% transfer efficiency)
(Calculations)			
	Proposed Sidewater Depth	12 ft	Note - Min SWD is 8 ft
	Surface Area	2,222 ft ²	
	Air Flow	889 scfm	
Aerobic Digester De	esign		
(Criteria)	Volume Required or	20 ft ³ / lb BOD 15 days SRT	
	Air Required	30 scfm/ 1000 ft ³ v	rolume
(Calculations)			
	Proposed Volume	8,000 ft ³	
	Proposed Sidewater Depth	12 ft	
	Surface Area	667 ft ²	
	Required Air Flow	240 scfm	
Chlorine Contact De	esign		
(Criteria)	Minimum Contact Time	20 minutes @ Pea	k Flow
(Calculations)	Proposed Volume	371 ft ³	
	Proposed Sidewater Depth	12 ft	
	Surface Area	31 ft²	

487 AC Taylor WWTP Extended Air Process Design (TCEQ Checklist)

Phase 3

Design Flow (from Summary Sheet) 0.050 mgd Peak Flow (from Summary Sheet) 0.200 mgd

Design Organic Load 400 lb BOD / day

Clarifier Design

(Criteria)

Maximum Surface Loading @ Peak Flow 900 gpd/ft²
Minimum Detention Time @ Peak Flow 2 hrs

Maximum Surface Loading @ Design Flow 450 gpd/ft²
Minimum Detention Time @ Design Flow 4 hrs


Surface Area Required (Peak Flow) 222.2 ft² Surface Area Required (Design Flow) 111.11 ft²

> Volume Required (Peak Flow) 2,228 ft³ Volume Required (Design Flow) 1,114 ft³

Depth Required (Peak Flow) 10.0 ft Depth Required (Design Flow) 10.0 ft

Maximum Return Sludge Underflow Rate 400.0 gpd/ft²
Minimum Return Sludge Underflow Rate 200.0 gpd/ft²

(Calculations)



Note - Min SWD is 8 ft, 10 ft if area > 1250 ft²

Proposed Clarifier Diameter 16 ft

Clarifier Surface Area 201 ft²

Clarifier Volume 2,413 ft³

Maximum Return Sludge Underflow Rate 56 gpm Minimum Return Sludge Underflow Rate 28 gpm

RAS Line Size (min 3 ft/sec velocity) 4 inches

Aeration System Design

(Criteria)

Organic Loading 15 lb BOD/day/1000 ft³
Actual Design Load 400 lb BOD/day

Required Volume 26667 ft³

scf / lb BOD (assumes 4.0% transfer

Required Air Flow 3200 efficiency)

2,222

889 scfm

(Calculations)

Proposed Sidewater Depth 12 ft

Surface Area

Air Flow

Note - Min SWD is


8 ft

Aerobic Digester Design


(Criteria)		
,	Volume Required or	20 ft ³ /lb BOD 15 days SRT
	Air Required	30 scfm/ 1000 ft ³ volume
(Calculations)	Proposed Volume	8,000 ft ³
	Proposed Sidewater Depth	12 ft
	Surface Area	667 ft ²
	Required Air Flow	240 scfm
Chlorine Contact De (Criteria)	sign Minimum Contact Time	20 minutes @ Peak Flow
(Calculations)	Proposed Volume	371 ^{ft³}
	Proposed Sidewater Depth	12 ft
	Surface Area	31 ft ²

APPENDIX L

FEMA FLOOD MAPS



SEE FIS REPORT FOR DETAILED LEGEND AND INDEX MAP FOR FIRM PANEL LAYOUT THE INFORMATION DEPICTED ON THIS MAP AND SUPPORTING **DOCUMENTATION ARE ALSO AVAILABLE IN DIGITAL FORMAT AT**



Jurisdiction Boundary

FEATURES

For information and questions about this Flood Insurance Rate Map (FIRM), available products associated with this FIRM, including historic versions, the current map date for each FIRM panel, how to order products, or the National Flood Insurance Program (NFIP) in general, please call the FEMA Map Information eXchange at 1-877-FEMA-MAP (1-877-336-2627) or visit the FEMA Flood Map Service Center website at https://msc.fema.gov. Available products may include previously issued Letters of Map Change, a Flood Insurance Study Report, and/or digital versions of this map. Many of these products can be ordered or obtained directly from the website.

Communities annexing land on adjacent FIRM panels must obtain a current copy of the adjacent panel as well as

the current FIRM Index. These may be ordered directly from the Flood Map Service Center at the number listed For community and countywide map dates refer to the Flood Insurance Study Report for this jurisdiction.

To determine if flood insurance is available in this community, contact your Insurance agent or call the National Flood Insurance Program at 1-800-638-6620.

Base map information shown on this FIRM was derived from digital data obtained from Texas Natural Resource Information Systems (TNRIS), dated 2000; United States Census Bureau, dated 2015; United States Geological

Survey, dated 2005; and the Williamson County Geographic Information Systems (GIS) Department, dated 2014

Map Projection: Texas State Plane Central (FIPS ZONE 4203); North American Datum 1983; Western Hemisphere: Vertical Datum: NAVD 88 1 inch = 2,000 feet1:24,000 8,000 feet 2,000 4,000 meters 1,000 2,000

PANEL LOCATOR 0335 Williamson County 0400 0375 0345 0340 0531 0532 0530 0533 0534 0600 0575 0541 0542 0540 0545 0705 0750 0700 0725

National Flood Insurance Program FEMA PANEL 575 OF 750

NATIONAL FLOOD INSURANCE PROGRAM FLOOD INSURANCE RATE MAP

WILLIAMSON COUNTY, TEXAS and Incorporated Areas

Panel Contains:

COMMUNITY TAYLOR, CITY OF THRALL, CITY OF WILLIAMSON COUNTY

NUMBER PANEL SUFFIX 480670 481632 0575 0575 481079 0575


> **VERSION NUMBER** 2.3.3.3 **MAP NUMBER** 48491C0575F MAP REVISED **DECEMBER 20, 2019**

APPENDIX M

WIND ROSE




Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 03 Jan 2011 08:00 AM - 31 Jan 2023 05:00 AM America/Chicago 4 constraints: Jan



2 - 4.9

5 - 6.9




7 - 9.9 10 - 14.9 15 - 19.9 20+




2 - 4.9

Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Feb 2011 08:00 AM - 28 Feb 2023 11:45 PM America/Chicago 4 constraints: Feb






Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Mar 2011 08:00 AM - 31 Mar 2023 11:45 PM America/Chicago & constraints: Mar







Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Apr 2011 08:00 AM - 30 Apr 2023 11:45 PM America/Chicago \$\diamonds\$ constraints: Apr






Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 May 2011 08:00 AM - 31 May 2023 11:45 PM America/Chicago








Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Jun 2011 08:00 AM - 30 Jun 2023 11:45 PM America/Chicago \$\diamonds\$ constraints: Jun



5 - 6.9 **7** - 9.9 **1**0 - 14.9 **1**5 - 19.9 **2**0+




Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Jul 2011 08:00 AM - 31 Jul 2023 11:45 PM America/Chicago \$\diamonds\$ constraints: Jul



5 - 6.9 **7** - 9.9 **1**0 - 14.9 **1**5 - 19.9 **2**0+




Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Aug 2011 08:00 AM - 31 Aug 2023 11:45 PM America/Chicago \$\diamonds\$ constraints: Aug



5 - 6.9 **7** - 9.9 **1**0 - 14.9 **1**5 - 19.9 **2**0+




Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Sep 2011 08:00 AM - 30 Sep 2023 11:45 PM America/Chicago \$\diamonds\$ constraints: Sep





Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam
Obs Between: 01 Oct 2011 08:00 AM - 31 Oct 2023 11:45 PM America/Chicago
Gonstraints: Oct




5 - 6.9 **7** - 9.9 **1**0 - 14.9 **1**5 - 19.9 **2**0+



2 - 4.9

5 - 6.9


Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 01 Nov 2011 08:00 AM - 30 Nov 2023 11:45 PM America/Chicago 4 constraints: Nov





2 - 4.9

Windrose Plot for [GNGT2] San Gabriel River AT Granger Dam Obs Between: 08 Dec 2010 08:00 AM - 26 Dec 2023 05:45 PM America/Chicago 4 constraints: Dec



APPENDIX N

SEWAGE SOLIDS MANAGEMENT PLAN

First Phase

Design Flow	Vol Dig	Percentage	Flow	P _x	P _{x (ss)}	Q _{Sldg}	HRT _{Sldg}
gpd	ft ³ (gal)		gpd	lbs VSS/day	lbs SS/day	gpd	days
50,000	8,000	25%	12,500	11	14	205	292
		50%	25,000	22	27	410	146
	59,840	75%	37,500	33	41	614	97
		100%	50,000	44	55	819	73

Interim Phase

Design Flow	Vol Dig	Percentage	Flow	P _x	P _{x (ss)}	Q_{Sldg}	HRT _{Sldg}
gpd	ft ³ (gal)		gpd	lbs VSS/day	lbs SS/day	gpd	days
100,000	16,000	25%	25,000	22	27	410	146
		50%	50,000	44	55	819	73
	119,680	75%	75,000	66	82	1,229	49
		100%	100,000	87	109	1,639	37


Final Phase

Design Flow	Vol Dig	Percentage	Flow	P _x	P _{x (ss)}	Q _{Sldg}	HRT _{Sldg}
gpd	ft ³ (gal)		gpd	lbs VSS/day	lbs SS/day	gpd	days
150,000	24,000	25%	37,500	33	41	614	97
		50%	75,000	66	82	1,229	49
	179,520	75%	112,500	98	123	1,843	32
		100%	150,000	131	164	2,458	24

Sludge will be wasted from the clarifier underflow to the digester. Sludge will stay in the digester with the decant returned to the headworks of the plant. Sludge will be removed from the digester on a schedule approximate to the HRT of the digester. The liquid sludge will be hauled by truck to the City of Taylor's Wastewater Treatment Plant for further treatment.

APPENDIX O NEARBY WWTP AND LETTERS

NEARBY WWTP WITHIN 3 MILE RADIUS - TAYLOR, TX







May 29, 2024

The City of Thrall PO Box 346 Thrall, TX 76578-0346

We are working on a TPDES Permit application for a neighboring mixed-use development. Your existing wastewater treatment permit 16391-001 is within a 3-mile radius of the development's proposed outfall. The proposed development is anticipated to have an average daily flow of 0.150 MGD.

Do you have capacity to potentially serve the development?	
Yes	
No	
Signature	Date

Sincerely,

Lauren Crone, P.E. Sr. Project Manager LJA Engineering, Inc. 7500 Rialto Blvd, Bldg II, Suite 100 Austin, TX 78735

P: (512) 439-4700 D: (512) 439-4737 lcrone@lja.com





LJA

The City of Thrall 104 Main St, Thrall, TX 76578

We are working on a TPDES Permit application for a neighboring mixed-use development. Your existing wastewater treatment permit 16391-001 is within a 3-mile radius of the development's proposed outfall. The proposed development is anticipated to have an average daily flow of 0.15 MGD.

Do you have capacity to potentially serve the development?	
Yes	
No	
Signature	Date

Sincerely,


Lauren Crone, P.E. Sr. Project Manager LJA Engineering, Inc. 7500 Rialto Blvd, Bldg II, Suite 100 Austin, TX 78735

P: (512) 439-4700 D: (512) 439-4737 lcrone@lja.com



ARTICLE ADDRESS TO:

The City of Taylor 400 Porter St Taylor TX 76574-3600



Postmark Here/X 78749-9

OUTBOUND TRACKING NUMBER 9414 7118 9956 4481 5989 97

RETURN RECEIPT TRACKING NUMBER 9490 9118 9956 4481 5989 46

ARTICLE ADDRESS TO:

The City of Thrall PO Box 346 Thrall TX 76578-0346 **FEES**

\$0,640 \$4,400 Postage per piece Certified Fee Certified Fee Return Receipt Fee \$3.650 Total Postage & Fees: \$8.690

Postmark/, TX 78749

APPENDIX P

REGIONALIZATION AND COST DISCUSSION

NMCV TAYLOR PROPERTY INVESTORS LLC WWTP REGIONALIZATION & COST ANALYSIS SUMMARY

The proposed NMCV Taylor Property Investors, LLC 487 acre Taylor Tract lies within Williamson County, east of the City of Taylor. The development will have approximately 612 equivalent single family connections consisting of various commercial uses, along with area for rights of way and utilities. While the property is located within 3 miles of the City of Taylor's Wastewater Treatment Plant (Permit WQ0010299-001) and within 3 miles of the City's collection system, it is not within its current CCN. Under the Legislature's authorization in TWC Sec. 13.254, the landowner has chosen another utility to provide service. Taylor's provision of service is uneconomical - see attached cost comparison showing that the initial construction cost for the off-site line is significantly higher than on-site facilities.

Connection to the Taylor Wastewater System using the lower cost alternative (cross country) would cost an estimated \$5.5 million. This connection includes all offsite line extensions, easement acquisition and impact fees from the City of Taylor for connection. The City has indicated it is not interested in funding any portion of the line costs, or offsetting impact fees.

The proposed alternative is to construct an on-site wastewater treatment system to serve the entire subdivision. The on-site wastewater system would cost an estimated \$4.6 million and would include a 150,000 GPD wastewater treatment plant and a lift station on the property. Internal wastewater facilities would be the same cost for both alternatives and therefore are not included in the construction costs.

Construction of an on-site wastewater system is not only more feasible but is also a more cost-effective way of providing wastewater service to the proposed subdivision. Furthermore, acquisition of easements for the offsite main adds uncertainty to the schedule and cost of construction.



Engineer's Estimate of Preliminary Cost

Daniel Ryan, P.E. LJA Engineering, Inc. TBPE F-1386 FM 112 Tract - WWTP

Project Mgr: Project Engr: Project:

Major Wa	lajor Wastewater Improvements								
1	250	LF	6" Yelomine Force Main (to WWTP) - Phase 1	\$60.00	\$	15,000.00			
2	1	LS	500 gpm Influent Lift Station	\$600,000.00	\$	600,000.00			
3	1	LS	WWTP 150,000 GPD (Equipment incl Filter)	\$1,750,000.00	\$	1,750,000.00			
4	1	LS	WWTP Electrical & Instrumentation	\$500,000.00	\$	500,000.00			
5	1	LS	WWTP Site Prep & Access Drive	\$500,000.00	\$	500,000.00			
6	1	LS	WWTP Site Yard Piping	\$300,000.00	\$	300,000.00			
7	200	LF	12" Effluent Discharge Line - Phase 1	\$100.00	\$	20,000.00			
			WASTEWATER IMPROVEMENTS		\$	3,685,000.00			

TOTAL WW IMPROVEMENTS	<u> </u>	\$ 4,606,250.00
	Engineering, Surveying, Testing @ 15%	\$ 552,750.00
	Contingency @ 10%	\$ 368,500.00

 Project:
 FM 112 TRACT

 Client:
 NMCV Taylor Property Investors

 Date:
 5/22/2024

 By:
 D. Ryan

WASTE	WATER IMPROVEMENTS OPTION #1 - CROSS COUNTRY	Unit	Cost/Unit	Quantity	Cost
WW-1	500 gpm Regional Lift Station	L.S.	\$1,250,000.00	1	\$1,250,000.00
WW-2	6" Force Main	L.F.	\$100.00	7,460	\$746,000.00
WW-4	16" Steel Encasement Pipe	L.F.	\$300.00	100	\$30,000.00
WW-5	Bore for 16" Encasement	L.F.	\$350.00	70	, ,
WW-6	C.A.R.V.V.	EA.	\$7,500.00	3	\$22,500.00
WW-7	12" Gravity Line, 0'-8' deep	L.F.	\$125.00	4,261	\$532,625.00
WW-8	12" Gravity Line, 8'-10' deep	L.F.	\$150.00	350	\$52,500.00
WW-9	4' Diameter Manhole	EA.	\$7,500.00	12	\$90,000.00
WW-11	Raise Manhole Castings	EA.	\$500.00	12	\$6,000.00
WW-12	Trench Safety System	L.F.	\$1.00	12,071	\$12,071.00
WW-13	Revegetation	S.Y.	\$5.00	26,824	\$134,122.22
•				Subtotal	\$2,900,318.22

 Contingency @10%
 \$290,031.82

 Engineering, Surveying, Testing @ 15%
 \$435,047.73

 Easement Acquisition (11,750 LF x 20' x \$30,000 per AC)
 \$161,845.73


 Impact Fees (612 ESFC @ 2,799 each)
 \$1,712,988.00

Total \$5,500,231.51

WASTE	WATER IMPROVEMENTS OPTION #2 - ALONG FM 112	Unit	Cost/Unit	Quantity	Cost
WW-1	500 gpm Regional Lift Station	L.S.	\$1,250,000.00	1	\$1,250,000.00
WW-2	6" Force Main	L.F.	\$150.00	7,500	\$1,125,000.00
WW-4	16" Steel Encasement Pipe	L.F.	\$300.00	250	\$75,000.00
WW-5	Bore for 16" Encasement	L.F.	\$350.00	70	\$24,500.00
WW-6	C.A.R.V.V.	EA.	\$7,500.00	3	\$22,500.00
WW-7	12" Gravity Line, 0'-8' deep	L.F.	\$200.00	1,678	\$335,600.00
WW-8	12" Gravity Line, 8'-10' deep	L.F.	\$250.00	350	\$87,500.00
WW-9	4' Diameter Manhole	EA.	\$7,500.00	9	\$67,500.00
WW-11	Raise Manhole Castings	EA.	\$500.00	9	\$4,500.00
WW-12	Traffic Control	LS	\$100,000.00	1	\$100,000.00
WW-13	Trench Safety System	L.F.	\$1.00	9,528	\$9,528.00
WW-14	Revegetation	S.Y.	\$5.00	21,173	\$105,866.67
				Subtotal	\$3,207,494,67


Contingency @10% \$320,749.47
Engineering, Surveying, Testing @ 15% \$481,124.20
Impact Fees (612 ESFC @ 2,799 each) \$1,712,988.00

Total \$5,722,356.33



APPENDIX Q

TRANSECT LOCATION MAP



LJA Engineering, Inc.

7500 Rialto Boulevard

Building II, Suite 100

Austin, Texas 78735

Phone 512.439.4700 Fax 512.439.4716 FRN - F-1386 487 TAYLOR TRACT WWTP

NMCV TAYLOR PROPERTY INVESTORS, LLC

WORKSHEET 2.1 TRANSECT LOCATION MAP

1 OF 1



June 12th, 2024

Abesha Michael abesha.michael@tceq.texas.gov. Applications Review and Processing Team (MC 148) Water Quality Division Texas Commission of Environmental Quality

Re: 487 Acre Taylor Tract Wastewater Treatment Plant

Proposed by NMCV Taylor Property Investors LLC

Application No. WQ0016554001 CN606270122, RN111984464

LJA Project No. A462-

Dear Abesha:

Please find the responses related to the permit application for Elgin Tract WWTP received April 19, 2024 below.

1. Section 1, application fee on page 2 of the administrative report 1.0: The application indicates the application fee for \$850.00 is paid. However, we are unable to locate the proof of payment. Please submit payment of \$850.00 to: TCEQ, Revenue Section (MC 214), P.O. Box 13088, Austin, Texas 78711-3088. Also, email a copy of the check or any proof of payment along with the response.

Response: The proof of payment is attached to this response. A copy of the check has also been emailed.

- 2. Section 8, item E5 page 7 of the administrative report: This item was left blank. However, the type of the bilingual language is required. Please submit a revised page 7. Response: This section has been updated and is attached to this response.
- 3. Section 3, on page 3 and Section 14, signature page on page 11 of the administrative report 1.0: Section 3 and 14 shows that Mr. Shroff Nirav, manager, is the authorized signing person of this application. However, TCEQ rules require that the application be signed by at least the level of Vice President, (CEO, Chairman of the Board, Secretary). Please confirm Mr. Shroff Nirav meets the signatory requirements under 30 TAC 305.44 and authorized to sign the application. If not, please submit a notarized signature page signed by an authorized agent and also update section 3, item A on page 3 of the administrative report accordingly.

Response: It has been confirmed that Mr. Shroff Nirav possesses the needed signatory requirements.

4. Thank you for providing the Plain Language Summary (PLS) in English and Spanish. However, the PLS is not completed with Customer Number (CN) and Regulated Entity Number (RN, facility name number) numbers, since it is a new permit application. Please submit a revised PLS using CN and RN from the subject line of this NOD letter. Response: The Plain Language Summary has been updated with the correct CN and RN numbers.



- 5. Section 1, item 1 & B, landowner information on page 12 of the administrative report 1.1: Thank you for providing the affected landowners map and the cross-referenced mailing list. However, we need a separate landowner map and mailing list, not on one page. we also need one mailing address which we can use to mail the notice information.
- Response: The Landowners map has been updated to show only the map. The mailing list has been updated and attached.
- 6. Section 1, item C, landowner information on page 12 of the administrative report 1.1: We are unable to locate the mailing labels. Please email the affected landowners mailing labels in Avery 5160 label format (3 columns across, 10 columns down) in Microsoft Word format. To ensure we can use the media to print labels, they must be evenly spaced, so that each address prints on one label. Please remove if there is any additional information included with the list, no punctuation.

Response: The updated labels have been attached.

7. The following is a portion of the NORI which contains information relevant to your application.

Please read it carefully and indicate if it contains any errors or omissions. The complete notice will be sent to you once the application is declared administratively complete

APPLICATION. NMCV Taylor Property Investors LLC, 2225 High Lonesome, Leander, has applied to the Texas Commission on Environmental Quality (TCEQ) for proposed Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0016554001 (EPA I.D. No. TX0146153) to authorize the discharge of treated wastewater at a volume not to exceed a daily average flow of 150,000 gallons per day. The domestic wastewater treatment facility will be located at approximately 0.16 miles southwest of the intersection of Farm-to-Market Road 112 and Tucek Road, near the city of Taylor, in Williamson County, Texas 76574. The discharge route will be from the plant site to an unnamed tributary; thence to Mustang Creek (to be confirmed by RWA). TCEQ received this application on May 31, 2024. The permit application will be available for viewing and copying at City of Taylor Public Library, Public Viewing Board, 801 Vance Street, Taylor, TX 76574, Taylor, Texas prior to the date this notice is published in the newspaper. The application, including any updates, and associated notices are available electronically at the following webpage:

https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdes-applications. This link to an electronic map of the site or facility's general location is provided as a public courtesy and not part of the application or notice. For the exact location, refer to the application.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=-97.35881,30.565409&level=18

Response: No errors were found in the notice above.





8. The application indicates that public notices in Spanish are required. After confirming the portion of the NORI above does not contain any errors or omissions, please use the attached template to translate the NORI into Spanish. Only the first and last paragraphs are unique to this application and require translation. Please provide the translated Spanish NORI in a Microsoft Word document.

Response: The translated Spanish NORI has been provided and attached to this response.

Should you have any questions or need any additional information, please do not hesitate to call.

Sincerely,

Lauren Crone, P.E.

Lauren Crome

5/31/24, 9:25 AM TCEQ ePay

Questions or Comments >>

Shopping Cart Select Fee Search Transactions Sign Out

Your transaction is complete. Thank you for using TCEQ ePay.

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt and the vouchers for your records. An email receipt has also been sent.

Transaction Information

Trace Number: 582EA000612328

Date: 05/31/2024 09:24 AM

Payment Method: CC - Authorization 0000031566

ePay Actor: LAUREN CRONE
Actor Email: lcrone@lja.com
IP: 170.55.94.226

TCEQ Amount: \$850.00

Texas.gov Price: \$869.38*

* This service is provided by Texas.gov, the official website of Texas. The price of this service includes funds that support the ongoing operations and enhancements of Texas.gov, which is provided by a third party in partnership with the State.

Payment Contact Information

Name: STEPHEN D MILLER
Company: LJA ENGINEERING INC

Address: 7500 RIALTO BOULEVARD BUILDING, AUSTIN, TX 78735

Phone: 512-439-4700

Cart Items

Click on the voucher number to see the voucher details.

Voucher	Fee Description	AR Number	Amount
707593	WW PERMIT - FACILITY WITH FLOW $>= .10 \ \& < .25 \ MGD$ - NEW AND MAJOR AMENDMENTS		\$800.00
707594	30 TAC 305.53B WQ NOTIFICATION FEE	TCEQ Amount:	\$50.00 \$850.00

ePay Again Exit ePay

Note: It may take up to 3 working days for this electronic payment to be processed and be reflected in the TCEQ ePay system. Print this receipt for your records.

Site Help | Disclaimer | Web Policies | Accessibility | Our Compact with Texans | TCEQ Homeland Security | Contact Us Statewide Links: Texas.gov | Texas Homeland Security | TRAIL Statewide Archive | Texas Veterans Portal

	3.	Do the locatio		these	e schools attend a bilingual education program at another
			Yes	\boxtimes	No
	4.			-	uired to provide a bilingual education program but the school has rement under 19 TAC §89.1205(g)?
			Yes	\boxtimes	No
	5.		-	_	uestion 1, 2, 3, or 4 , public notices in an alternative language are se is required by the bilingual program? Spanish
F.	Pla	in Lang	guage Summ	ary 7	Template
	Co	mplete	the Plain Laı	nguag	ge Summary (TCEQ Form 20972) and include as an attachment.
	At	tachme	nt: <u>Appendix</u>	<u>A</u>	
G.	Pu	blic Inv	olvement P	lan Fo	orm
					ement Plan Form (TCEQ Form 20960) for each application for a
		-	J		dment to a permit and include as an attachment.
	ΑŪ	tacnme	nt: <u>Appendix</u>	<u>C</u>	
Se	cti	on 9.	Regulat	ted F	Entity and Permitted Site Information (Instructions
			Page 29		
Α.			is currently CN Click to e		ated by TCEQ, provide the Regulated Entity Number (RN) issued to
			TCEQ's Cer currently re		Registry at http://www15.tceq.texas.gov/crpub/ to determine if ed by TCEQ.
B.	Na	me of p	roject or sit	e (the	name known by the community where located):
	<u>48</u>	7 Acre	Taylor Tract	Was	tewater Treatment Plant
C.	Ov	vner of	treatment fa	cility:	: NMCV Taylor Property Investors LLC
	Ov	vnership	of Facility:		Public \square Private \square Both \square Federal
D.	Ov	vner of l	land where t	reatn	nent facility is or will be:
	Pre	efix: <u>Mr.</u>			Last Name, First Name: <u>Nirav, Shroff</u>
	Tit	le: <u>Man</u>	ager		Credential: Click to enter text.
	Or	ganizati	ion Name: <u>N</u>	MCV '	Taylor Property Investors LLC
	Ma	iling Ac	ldress: <u>2225</u>	High	<u>Lonesome</u> City, State, Zip Code: <u>Leander, TX 78641</u>
	Ph	one No.	: <u>512-825-88</u> ;	<u>37</u>	E-mail Address: pkuo@hkredevelopment.com
					same person as the facility owner or co-applicant, attach a lease d easement. See instructions.
		Attach	ment: Click	to en	ter text.

Plain Language Summary - TPDES New Application

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package. For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

NMCV Taylor Property Investors LLC (CN#606270122) proposes to operate 487 Acre Taylor Tract Wastewater Treatment Plant RN #111984464. a 0.15 MGD WWTP facility. The facility will be located Approximately 0.16 miles Northeast from the intersection of FM 112 and Tucek Road, in Taylor, Williamson County, Texas 76574.

This is for a new application to discharge processed wastewater at an average daily flow of 150,000 gallons per day on an intermittent and flow-variable basis.

Discharges from the facility are expected to containfive-day carbonaceous biochemical oxygen demand $(CBOD_5)$, total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia Coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Domestic wastewater will be treated by a suspended growth activated sludge process in extended aeration mode and the treatment units will include a mechanical auger screen, equalization basin, aeration tanks, a chlorine contact chamber.

PLANTILLA EN INGLÉS PARA SOLICITUDES DE NUEVA/RENOVACIÓN/ENMIENDA TPDES o TLAP

AGUAS RESIDUALES DOMÉSTICAS

El siguiente resumen se proporciona para esta solicitud de permiso de calidad del agua pendiente que está siendo revisada por la Comisión de Calidad Ambiental de Texas según lo exige el Capítulo 39 del Código Administrativo de Texas 30. La información proporcionada en este resumen puede cambiar durante la revisión técnica de la solicitud y no es federal. representaciones ejecutables de la solicitud de permiso.

NMCV Taylor Property Investors LLC (CN#606270122) propone operar la planta de tratamiento de aguas residuales de 487 Acre Taylor Tract RN#111984464. una instalación de PTAR de 0.15 MGD. La instalación estará ubicada aproximadamente a 0,16 millas al noreste de la intersección de FM 112 y Tucek Road, en Taylor, condado de Williamson, Texas 76574.

Esto es para una nueva aplicación para descargar aguas residuales procesadas a un flujo diario promedio de 150,000 galones por día de forma intermitente y de flujo variable.

Se espera que las descargas de la instalación contengan demanda bioquímica de oxígeno carbonoso (CBOD5) de cinco días, sólidos suspendidos totales (SST), nitrógeno amoniacal (NH3-N) y Escherichia coli. Se incluyen contaminantes potenciales adicionales en el Informe Técnico Nacional 1.0, Sección 7. Las aguas residuales domésticas serán tratadas mediante un proceso de lodos activados de crecimiento suspendido en modo de aireación extendida y las unidades de tratamiento incluirán una criba de tornillo mecánico, un estanque de ecualización, tanques de aireación, un sistema de cloro. cámara de contacto.

Comisión de Calidad Ambiental del Estado de Texas



AVISO DE RECIBO DE LA SOLICITUD Y EL INTENTO DE OBTENER PERMISO PARA LA CALIDAD DEL AGUA

PERMISO PROPUESTO NO. WQoo_____

SOLICITUD. NMCV Taylor Property Investors LLC, 2225 High Lonesome, Leander, tiene solicitó a la Comisión de Calidad Ambiental de Texas (TCEQ) la propuesta de Texas Permiso del Sistema de Eliminación de Descarga de Contaminantes (TPDES) No. WQ0016554001 (EPA I.D. No. TX0146153) para autorizar la descarga de aguas residuales tratadas en un volumen que no exceda el diario Flujo promedio de 150,000 galones por día. La instalación de tratamiento de aguas residuales domésticas será ubicado aproximadamente a 0.16 millas al noreste de la intersección de Farm-to-Market Road 112 y Tucek Road, cerca de la ciudad de Taylor, en el condado de Williamson, Texas 76574. La ruta de descarga será desde el sitio de la planta hasta un afluente sin nombre; de allí a Mustang Creek (para ser confirmado por RWA). La TCEQ recibió esta solicitud el 31 de mayo de 2024. La solicitud de permiso estará disponible para ver y copiar en la Biblioteca Pública de la Ciudad de Taylor, la Junta de Visualización Pública,

801 Vance Street, Taylor, TX 76574, Taylor, Texas antes de la fecha de publicación de este aviso en el periódico. La aplicación, incluidas las actualizaciones y los avisos asociados, están disponibles. electrónicamente en la siguiente página web: https://www.tceq.texas.gov/permitting/wastewater/pending-permits/tpdesapplications. Este El enlace a un mapa electrónico de la ubicación general del sitio o instalación se proporciona como acceso público.

cortesía y no forma parte de la solicitud o notificación. Para conocer la ubicación exacta, consulte la solicitud.

https://gisweb.tceq.texas.gov/LocationMapper/?marker=97.35881,30.565409&level=18

[Include the following non-italicized sentence if the facility is located in the Coastal Management Program boundary. The Coastal Management Program boundary is the area along the Texas Coast of the Gulf of México as depicted on the map in 31 TAC §503.1 and includes part or all of the following counties: Cameron, Willacy, Kenedy, Kleberg, Nueces, San Patricio, Aransas, Refugio, Calhoun, Victoria, Jackson, Matagorda, Brazoria, Galveston, Harris, Chambers, Jefferson y Orange.] El Director Ejecutivo de la TCEQ ha revisado esta medida para ver si está de acuerdo con los objetivos y las regulaciones del Programa de Administración Costero de Texas (CMP) de acuerdo con las regulaciones del Consejo Coordinador de la Costa (CCC) y ha determinado que la acción es conforme con las metas y regulaciones pertinentes del CMP.

AVISO ADICIONAL. El Director Ejecutivo de la TCEQ ha determinado que la solicitud es

administrativamente completa y conducirá una revisión técnica de la solicitud. Después de completar la revisión técnica, el Director Ejecutivo puede preparar un borrador del permiso y emitirá una Decisión Preliminar sobre la solicitud. El aviso de la solicitud y la decisión preliminar serán publicados y enviado a los que están en la lista de correo de las personas a lo largo del condado que desean recibir los avisos y los que están en la lista de correo que desean recibir avisos de esta solicitud. El aviso dará la fecha límite para someter comentarios públicos.

COMENTARIO PUBLICO / REUNION PUBLICA. Usted puede presentar comentarios públicos o pedir una reunión pública sobre esta solicitud. El propósito de una reunión pública es dar la oportunidad de presentar comentarios o hacer preguntas acerca de la solicitud. La TCEQ realiza una reunión pública si el Director Ejecutivo determina que hay un grado de interés público suficiente en la solicitud o si un legislador local lo pide. Una reunión pública no es una audiencia administrativa de lo contencioso.

OPORTUNIDAD DE UNA AUDIENCIA ADMINISTRATIVA DE LO CONTENCIOSO.

Después del plazo para presentar comentarios públicos, el Director Ejecutivo considerará todos los comentarios apropiados y preparará una respuesta a todo los comentarios públicos esenciales, pertinentes, o significativos. A menos que la solicitud haya sido referida directamente a una audiencia administrativa de lo contencioso, la respuesta a los comentarios y la decisión del Director Ejecutivo sobre la solicitud serán enviados por correo a todos los que presentaron un comentario público y a las personas que están en la lista para recibir avisos sobre esta solicitud. Si se reciben comentarios, el aviso también proveerá instrucciones para pedir una reconsideración de la decisión del Director Ejecutivo y para pedir una audiencia administrativa de lo contencioso. Una audiencia administrativa de lo contencioso es un procedimiento legal similar a un procedimiento legal civil en un tribunal de distrito del estado.

PARA SOLICITAR UNA AUDIENCIA DE CASO IMPUGNADO, USTED DEBE INCLUIR EN SU SOLICITUD LOS SIGUIENTES DATOS: su nombre, dirección, y número de teléfono; el nombre del solicitante y número del permiso; la ubicación y distancia de su propiedad/actividad con respecto a la instalación; una descripción específica de la forma cómo usted sería afectado adversamente por el sitio de una manera no común al público en general; una lista de todas las cuestiones de hecho en disputa que usted presente durante el período de comentarios; y la declaración "[Yo/nosotros] solicito/solicitamos una audiencia de caso impugnado". Si presenta la petición para una audiencia de caso impugnado de parte de un grupo o asociación, debe identificar una persona que representa al grupo para recibir correspondencia en el futuro; identificar el nombre y la dirección de un miembro del grupo que sería afectado adversamente por la planta o la actividad propuesta; proveer la información indicada anteriormente con respecto a la ubicación del miembro afectado y su distancia de la planta o actividad propuesta; explicar cómo y porqué el miembro sería afectado; y explicar cómo los intereses que el grupo desea proteger son pertinentes al propósito del grupo.

Después del cierre de todos los períodos de comentarios y de petición que aplican, el Director Ejecutivo enviará la solicitud y cualquier petición para reconsideración o para una audiencia de caso impugnado a los Comisionados de la TCEQ para su consideración durante una reunión programada de la Comisión. La Comisión sólo puede conceder una solicitud de una audiencia de caso impugnado sobre los temas que el solicitante haya presentado en sus comentarios oportunos que no fueron

retirados posteriormente. Si se concede una audiencia, el tema de la audiencia estará limitado a cuestiones de hecho en disputa o cuestiones mixtas de hecho y de derecho relacionadas a intereses pertinentes y materiales de calidad del agua que se hayan presentado durante el período de comentarios.

LISTA DE CORREO. Si somete comentarios públicos, un pedido para una audiencia administrativa de lo contencioso o una reconsideración de la decisión del Director Ejecutivo, la Oficina del Secretario Principal enviará por correo los avisos públicos en relación con la solicitud. Ademas, puede pedir que la TCEQ ponga su nombre en una or mas de las listas correos siguientes (1) la lista de correo permanente para recibir los avisos de el solicitante indicado por nombre y número del permiso específico y/o (2) la lista de correo de todas las solicitudes en un condado específico. Si desea que se agrega su nombre en una de las listas designe cual lista(s) y envia por correo su pedido a la Oficina del Secretario Principal de la TCEQ.

CONTACTOS E INFORMACIÓN A LA AGENCIA. Todos los comentarios públicos y solicitudes deben ser presentadas electrónicamente vía http://www14.tceq.texas.gov/epic/eComment/ o por escrito dirigidos a la Comisión de Texas de Calidad Ambiental, Oficial de la Secretaría (Office of Chief Clerk), MC-105, P.O. Box 13087, Austin, Texas 78711-3087. Tenga en cuenta que cualquier información personal que usted proporcione, incluyendo su nombre, número de teléfono, dirección de correo electrónico y dirección física pasarán a formar parte del registro público de la Agencia. Para obtener más información acerca de esta solicitud de permiso o el proceso de permisos, llame al programa de educación pública de la TCEQ, gratis, al 1-800-687-4040. Si desea información en Español, puede llamar al 1-800-687-4040.

También se puede obtener información adicional del NMCV Taylor Property Investors LLC a la dirección indicada arriba o llamando a Senora Lauren Crone, P.E., Senior Project Manager al (512) 439-4700.

Fecha de emisión	[1	Date	e noti	ice i	issued	
------------------	----	------	--------	-------	--------	--

PREWITT FARM & ZIZINIA WILLIAMSON COUNTY LTD 79 HWY/619 FM THRALL, TX 76578	CARLSON, CONNIE R W 6701 FM 112 TAYLOR, TX 76574	S2F HOLDING LLC & SATHISH BABU CHAKKA 4126 REMINGTON RD CEDAR PARK, TX 78613
MORRIS, JAMES & LISA 3280 FM 112 TAYLOR, TX 76574	WILLIAMS, BOBBIE LEE 3300 FM 112 TAYLOR, TX 76574	OMAN, TROY L 3350 FM 112 TAYLOR, TX 76574
POKOJSKI, JOHN F 3400 FM 112 TAYLOR, TX 76574	SMITH, STEPHEN 3406 FM 112 TAYLOR, TX 76574	ZYCHA LONNIE D SR & CONNIE & LONNIE D JR 3450 FM 112 TAYLOR, TX 76574
WERNER, CHARLES E 3550 FM 112 TAYLOR, TX 76574	DAUGHERTY, JAMES & HEIDI 3600 FM 112 TAYLOR, TX 76574	MILLER, JAMES FRANK & NETTIE LYNN 3610 FM 112 TAYLOR, TX 76574
TATROW, ROBERT JAMES 3650 FM 112 TAYLOR, TX 76574	JIRASEK DONALD (LE) 50 CR 446 TAYLOR, TX 76574	BARNETT, ADELINA 71 CR 446 TAYLOR, TX 76574
ZIESCHANG, MORRIS & BARBARA 4701 FM 112 TAYLOR, TX 76574	T W FORD LP PO BOX 128 TAYLOR TX 76574	BDB INDUSTRIES LLC 21545 Highway 79 THRALL, TX 76578
METZGER, KATHY & DON PETERS & T HALL & J FUSILIER 21481 Highway 79 THRALL, TX 76578	MOUNT VERNON LLC 3701 E 4TH ST TAYLOR, TX 76574	JOHNSON, NORMAN 3609 E 4TH ST TAYLOR, TX 76574
CRABBOLL II LLC 20901 US 79 TAYLOR, TX 76574	STAR TECH SERVICE LLC 20875 US 79 TAYLOR, TX 76574	HARRINGTON, GLENNETH & MISA 220 TUCEK RD TAYLOR, TX 76574
SHIPLEY, MICHAEL RICHARD	TUCEK, MATTHEW AARON	HARWELL, WILLIAM G & CYNTHIA D

BAUER, GAYLORD E & CAROLYN S 450 TUCEK RD TAYLOR, TX 76574

250 TUCEK RD

TAYLOR, TX 76574

LOPEZ, PHILLIP S 480 TUCEK DR TAYLOR, TX 76574

300 TUCEK RD

TAYLOR, TX 76574

GANDER, CLYDE EARL & JUDITH KAY 500 TUCEK DR TAYLOR, TX 76574

330 TUCEK RD

TAYLOR, TX 7657

YOUNG, DARYL L & LAURIE A 600 TUCEK RD TAYLOR TX, 76574	LEEN HOLDING COMPANY HWY 79 LLCCHAKKA PO BOX 1766 MARBLE FALLS, TX 78654
MALISH, JUDITH M 631 CR 445 TAYLOR, TX 76574	CHAPMAN OLIN P JR & AMY 3609 E 4TH ST TAYLOR TX 76574
	600 TUCEK RD TAYLOR TX, 76574 MALISH, JUDITH M 631 CR 445


(210) 373-7827	() -
------------------	-------

SECTION III: Regulated Entity Information

21. General Regulated Entity Information (If 'New Regulated Entity" is selected, a new permit application is also required.)										
☑ New Regulated Entity	New Regulated Entity Update to Regulated Entity Name Update to Regulated Entity Information									
The Regulated Entity Name submitted may be updated, in order to meet TCEQ Core Data Standards (removal of organizational endings such as Inc, LP, or LLC).										
22. Regulated Entity Name (Enter name of the site where the regulated action is taking place.)										
487 Acre Taylor Tract Wastew	vater Treatme	ent Plant								
23. Street Address of the Regulated Entity:										
(No PO Boxes)	City		State			ZIP			ZIP + 4	
24. County	Williamson	County	1							1
		If no Stre	et Address is pr	ovided, f	ields 25-	-28 are re	quired.			
25. Description to	The location	n is approximately	y 0.16 miles North	east of the	e intersec	tion of FM	112 and	Tucek Road in \	Williamson C	ounty. Texas.
Physical Location:			,							,
26. Nearest City							State		Nea	rest ZIP Code
Taylor							TX		7657	'4
Latitude/Longitude are re used to supply coordinate	-	-	-			ta Standa	rds. (Ge	cocoding of th	e Physical	Address may be
27. Latitude (N) In Decima	al:	30.567548			28. Lon	ngitude (W	/) In De	cimal:	-97.35463	3
Degrees	Minutes		Seconds		Degrees	3		Minutes		Seconds
30		34	3.1728			-97		21		
29. Primary SIC Code	/5 or 6 digits)									16.668
(4 digits)		Secondary SIC	Code		-	NAICS Co	de	32. Seco (5 or 6 dig	ndary NAIG	
(4 digits) 4952		-	Code		or 6 digits)	NAICS Co	de		-	
	(4 d	ligits)		(5 o	or 6 digits)	NAICS Co	de		-	
4952	(4 d	ligits)		(5 o	or 6 digits)	NAICS Co	de		-	
4952 33. What is the Primary B Wastewater Treatment	(4 d	ligits)		(5 o	or 6 digits)	NAICS Co	de		-	
4952 33. What is the Primary B Wastewater Treatment 34. Mailing	(4 d	igits)		(5 o	or 6 digits)	NAICS Co	de		-	
4952 33. What is the Primary B Wastewater Treatment	(4 d	igits)		(5 o	or 6 digits)	NAICS Co	78641	(5 or 6 dig	-	
4952 33. What is the Primary B Wastewater Treatment 34. Mailing	Business of f	this entity? (D	o not repeat the S	(5 o	or 6 digits)	NAICS Co		(5 or 6 dig	gits)	CS Code
4952 33. What is the Primary B Wastewater Treatment 34. Mailing Address:	Business of f	this entity? (D	o not repeat the S	(5 o	or 6 digits)	NAICS Co	78641	(5 or 6 dig	gits) ZIP + 4	CS Code
4952 33. What is the Primary B Wastewater Treatment 34. Mailing Address: 35. E-Mail Address:	Business of f	this entity? (D	On not repeat the S	(5 o	or 6 digits)	NAICS Co	78641	(5 or 6 dig	gits) ZIP + 4	CS Code

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

TCEQ-10400 (11/22) Page 2 of 3



Map Number	Landowner Name	Property Address	Mailing Address
1	PREWITT FARM & ZIZINIA WILLIAMSON COUNTY LTD	79 HWY/619 FM THRALL, TX 76578	5105 ASPEN ST, BELLAIRE, TX 77401
2	CARLSON, CONNIE R W	6701 FM 112, TAYLOR, TX 76574	2760 COUNTY ROAD 421, TAYLOR, TX 76574
3	S2F HOLDING LLC & SATHISH BABU CHAKKA	FM 112, THRALL, TX 76578	4126 REMINGTON RD, CEDAR PARK, TX 78613
4	AYALA, LUIS & MARGARET	3280 FM 112, TAYLOR, TX 76574	3280 FM 112, TAYLOR, TX 76574
5	WILLIAMS, BOBBIE LEE	FM 112, TAYLOR, TX 76574	3300 FM 112, TAYLOR, TX 76574
6	OMAN, TROY L	3350 FM 112, TAYLOR, TX 76574	3301 FM 112, TAYLOR, TX 76574
7	POKOJSKI, JOHN F	3400 FM 112, TAYLOR, TX 76574	3400 FM 112, TAYLOR, TX 76574
8	SMITH, STEPHEN	3406 FM 112, TAYLOR, TX 76574	3406 FM 112, TAYLOR, TX 76574
9	ZYCHA LONNIE D SR & CONNIE & LONNIE D JR	3450 FM 112, TAYLOR, TX 76574	3450 FM 112, TAYLOR TX 76574
10	WERNER, CHARLES E	3550 FM 112, TAYLOR, TX 76574	3550 FM 112, TAYLOR TX 76574
11	DAUGHERTY, JAMES & HEIDI	3600 FM 112, TAYLOR, TX 76574	3600 FM 112, TAYLOR TX 76574
12	MILLER, JAMES FRANK & NETTIE LYNN	3610 FM 112, TAYLOR, TX 76574	3610 FM 112, TAYLOR, TX 76574
13	TATROW, ROBERT JAMES	3650 FM 112, TAYLOR, TX 76574	3650 FM 112, TAYLOR TX 76574
14	JIRASEK DONALD (LE)	50 CR 446, TAYLOR, TX 76574	50 CR 446, TAYLOR TX 76574
15	BARNETT, ADELINA	71 CR 446, TAYLOR, TX 76574	71 COUNTY ROAD 446 TAYLOR TX 76574
16	ZIESCHANG, MORRIS & BARBARA	4701 FM 112, TAYLOR, TX 76574	4701 FM 112 TAYLOR TX 76574
17	T W FORD LP	Highway 79, TAYLOR, TX 76574	PO BOX 128 TAYLOR TX 76574
18	BDB INDUSTRIES LLC	21545 Highway 79, THRALL, TX 76578	21545 US HWY 79 TAYLOR TX 76574
19	METZGER, KATHY & DON PETERS & T HALL & J FUSILIER	21481 Highway 79, THRALL, TX 76578	4304 MIRAMAR DR GEORGETOWN TX 78628
20	MOUNT VERNON LLC	3701 E 4TH ST, TAYLOR, TX 76574	1900 IH 10 WEST SEQUIN TX 78155
21	JOHNSON, NORMAN	3609 E 4TH ST, TAYLOR, TX 76574	3609 E 4TH ST, TAYLOR, TX 76574
22	CRABBOLL II LLC	20901 US 79, TAYLOR, TX 76574	3509 E 4TH ST TAYLOR TX 76574
23	STAR TECH SERVICE LLC	20875 US 79, TAYLOR, TX 76574	PO BOX 112 TAYLOR TX 76574
24	HARRINGTON, GLENNETH & MISA	220 TUCEK RD, TAYLOR, TX 76574	220 TUCEK RD, TAYLOR, TX 76574
25	SHIPLEY, MICHAEL RICHARD	250 TUCEK RD, TAYLOR, TX 76574	250 TUCEK RD, TAYLOR, TX 76574
26	TUCEK, MATTHEW AARON	300 TUCEK RD, TAYLOR, TX 76574	300 TUCEK RD, TAYLOR, TX 76574
27	HARWELL, WILLIAM G & CYNTHIA D	330 TUCEK RD, TAYLOR, TX 76574	330 TUCEK RD, TAYLOR, TX 76574
28	BAUER, GAYLORD E & CAROLYN S	450 TUCEK RD, TAYLOR, TX 76574	450 TUCEK RD, TAYLOR, TX 76574
29	LOPEZ, PHILLIP S	480 TUCEK DR, TAYLOR, TX 76574	480 TUCEK DR, TAYLOR, TX 76574
30	GANDER, CLYDE EARL & JUDITH KAY	500 TUCEK DR, TAYLOR, TX 76574	209 E 8TH ST, LOS FRESNOS TX, 78566
31	ROCHA, ANNA MARIA RIOS	510 TUCEK DR, THRALL, TX 76578	510 TUCEK DR, THRALL, TX 76578
32	YOUNG, DARYL L & LAURIE A	600 TUCEK RD, TAYLOR TX, 76574	600 TUCEK RD, TAYLOR TX, 76574
34	ALBRECHT, MARK	CR 446, THRALL, TX 76578	29 SUNRISE ROAD, CODY, WY 82414
35	MALISH, JUDITH M	631 CR 445, TAYLOR, TX 76574	631 CR 445, TAYLOR, TX 76574
36	LEEN HOLDING COMPANY HWY 79 LLC	US 79, TAYLOR, TX 76574	PO BOX 1766 MARBLE FALLS, TX 78654
37	CHAPMAN, OLIN P JR & AMY	3601 E 4TH ST, TAYLOR, TX 76574	3609 E 4TH ST, TAYLOR, TX 76574



TPDES PERMIT NO. WQ0016554001 [For TCEQ office use only - EPA I.D. No. TX00146153]

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY P.O. Box 13087 Austin, Texas 78711-3087

PERMIT TO DISCHARGE WASTES

under provisions of Section 402 of the Clean Water Act and Chapter 26 of the Texas Water Code

NMCV Taylor Property Investors LLC

whose mailing address is

2225 High Lonesome Leander, Texas 78641

is authorized to treat and discharge wastes from the 487 Acre Taylor Tract Wastewater Treatment Facility, SIC Code 4952

located approximately 0.16 miles northeast of the intersection of Farm-to-Market Road 112 and Tucek Road, in Williamson County, Texas 76574.

to an unnamed tributary, thence to Mustang Creek, thence to Brushy Creek in in Segment No. 1244 of the Brazos River Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does not grant to the permittee the right to use private or public property for conveyance of wastewater along the discharge route described in this permit. This includes, but is not limited to, property belonging to any individual, partnership, corporation, or other entity. Neither does this permit authorize any invasion of personal rights nor any violation of federal, state, or local laws or regulations. It is the responsibility of the permittee to acquire property rights as may be necessary to use the discharge route.

This permit shall expire at midnight, five years from	the date of issuance.
ISSUED DATE:	
	For the Commission

INTERIM I EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the date of issuance and lasting through completion of expansion to the 0.10 million gallons per day (MGD) facility, the permittee is authorized to discharge subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.05 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 139 gallons per minute.

Effluent Characteristic	Discharge Limitations				Min. Self-Monito	ring Requirements
	Daily Avg mg/l (lbs/day)	7-day Avg mg/l	Daily Max mg/l	Single Grab mg/l	Report Daily Avg. Measurement Frequency	& Max. Single Grab Sample Type
Flow, MGD	Report	N/A	Report	N/A	Continuous	Totalizing Meter
Carbonaceous Biochemical Oxygen Demand (5-day)	5 (2.1)	10	20	30	One/week	Grab
Total Suspended Solids	5 (2.1)	10	20	30	One/week	Grab
Ammonia Nitrogen	2 (0.83)	5	10	15	One/week	Grab
Total Phosphorus	0.50 (0.21)	1	2	3	One/week	Grab
<i>E. coli</i> , colony-forming units or most probable number per 100 ml	126	N/A	N/A	399	One/quarter	Grab

- 2. The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes (based on peak flow), and shall be monitored five times per week by grab sample. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per month by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored once per week by grab sample.

INTERIM II EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon completion of expansion to the 0.10 million gallons per day (MGD) facility and lasting through completion of expansion to the 0.15 MGD facility, the permittee is authorized to discharge subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.10 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 278 gallons per minute.

Effluent Characteristic	Discharge Limitations				Min. Self-Monito	oring Requirements
	Daily Avg mg/l (lbs/day)	7-day Avg mg/l	Daily Max mg/l	Single Grab mg/l	Report Daily Avg. Measurement Frequency	& Max. Single Grab Sample Type
Flow, MGD	Report	N/A	Report	N/A	Continuous	Totalizing Meter
Carbonaceous Biochemical Oxygen Demand (5-day)	5 (4.2)	10	20	30	One/week	Grab
Total Suspended Solids	5 (4.2)	10	20	30	One/week	Grab
Ammonia Nitrogen	2 (1.7)	5	10	15	One/week	Grab
Total Phosphorus	0.50 (0.42)	1	2	3	One/week	Grab
E. coli, colony-forming units or most probable number per 100 ml	126	N/A	N/A	399	One/month	Grab

- 2. The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes (based on peak flow), and shall be monitored five times per week by grab sample. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per month by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored once per week by grab sample.

FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon completion of expansion to the 0.15 million gallons per day (MGD) facility and lasting through the date of expiration, the permittee is authorized to discharge subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.15 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 417 gallons per minute.

Effluent Characteristic	Discharge Limitations				Min. Self-Monito	ring Requirements
	Daily Avg mg/l (lbs/day)	7-day Avg mg/l	Daily Max mg/l	Single Grab mg/l	Report Daily Avg. Measurement Frequency	& Max. Single Grab Sample Type
Flow, MGD	Report	N/A	Report	N/A	Continuous	Totalizing Meter
Carbonaceous Biochemical Oxygen Demand (5-day)	5 (6.3)	10	20	30	One/week	Grab
Total Suspended Solids	5 (6.3)	10	20	30	One/week	Grab
Ammonia Nitrogen	2 (2.5)	5	10	15	One/week	Grab
Total Phosphorus	0.50 (0.63)	1	2	3	One/week	Grab
E. coli, colony-forming units or most probable number per 100 ml	126	N/A	N/A	399	One/month	Grab

- 2. The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes (based on peak flow), and shall be monitored five times per week by grab sample. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per month by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored once per week by grab sample.

DEFINITIONS AND STANDARD PERMIT CONDITIONS

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC § 305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§ 5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§ 361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in TWC § 26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

1. Flow Measurements

- a. Annual average flow the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder and limited to major domestic wastewater discharge facilities with one million gallons per day or greater permitted flow.
- b. Daily average flow the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) the highest 2-hour peak flow for any 24-hour period in a calendar month.

2. Concentration Measurements

- a. Daily average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
 - i. For domestic wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.

- ii. For all other wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- 7-day average concentration the arithmetic average of all effluent samples, composite
 or grab as required by this permit, within a period of one calendar week, Sunday through
 Saturday.
- c. Daily maximum concentration the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day.

The daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the daily discharge determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.

- e. Bacteria concentration (*E. coli* or Enterococci) Colony Forming Units (CFU) or Most Probable Number (MPN) of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the nth root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or, computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substituted value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
- f. Daily average loading (lbs/day) the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD x Concentration, mg/l x 8.34).
- g. Daily maximum loading (lbs/day) the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.

3. Sample Type

a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (b).

- b. Grab sample an individual sample collected in less than 15 minutes.
- 4. Treatment Facility (facility) wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation and/or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
- 5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
- 6. The term "biosolids" is defined as sewage sludge that has been tested or processed to meet Class A, Class AB, or Class B pathogen standards in 30 TAC Chapter 312 for beneficial use.
- 7. Bypass the intentional diversion of a waste stream from any portion of a treatment facility.

MONITORING AND REPORTING REQUIREMENTS

1. Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§ 319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Enforcement Division (MC 224), by the 20th day of the following month for each discharge which is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act (CWA); TWC §§ 26, 27, and 28; and THSC § 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§ 319.11 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC § 25, Environmental Testing Laboratory Accreditation and Certification.

3. Records of Results

a. Monitoring samples and measurements shall be taken at times and in a manner so as to

be representative of the monitored activity.

- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use or biosolids and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR § 264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:
 - i. date, time and place of sample or measurement;
 - ii. identity of individual who collected the sample or made the measurement.
 - iii. date and time of analysis;
 - iv. identity of the individual and laboratory who performed the analysis;
 - v. the technique or method of analysis; and
 - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site and/or shall be readily available for review by a TCEQ representative for a period of three years.

6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later

than 14 days following each schedule date to the Regional Office and the Enforcement Division (MC 224).

7. Noncompliance Notification

- a. In accordance with 30 TAC § 305.125(9) any noncompliance which may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Except as allowed by 30 TAC § 305.132, report of such information shall be provided orally or by facsimile transmission (FAX) to the Regional Office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the Regional Office and the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEO website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
- b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
 - i. Unauthorized discharges as defined in Permit Condition 2(g).
 - ii. Any unanticipated bypass that exceeds any effluent limitation in the permit.
 - iii. Violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
- c. In addition to the above, any effluent violation which deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the Regional Office and the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
- d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
- 8. In accordance with the procedures described in 30 TAC §§ 35.301 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
- 9. Changes in Discharges of Toxic Substances

All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the Regional Office, orally or by facsimile transmission within 24 hours, and both the Regional Office and the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. One hundred micrograms per liter (100 μ g/L);
 - ii. Two hundred micrograms per liter (200 μ g/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 μ g/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. The level established by the TCEQ.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - i. Five hundred micrograms per liter (500 μ g/L);
 - ii. One milligram per liter (1 mg/L) for antimony;
 - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. The level established by the TCEQ.

10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC § 305.128 (relating to Signatories to Reports).

- 11. All POTWs must provide adequate notice to the Executive Director of the following:
 - a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to CWA § 301 or § 306 if it were directly discharging those pollutants;
 - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and
 - c. For the purpose of this paragraph, adequate notice shall include information on:
 - i. The quality and quantity of effluent introduced into the POTW; and
 - ii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

PERMIT CONDITIONS

1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
 - i. Violation of any terms or conditions of this permit;
 - ii. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
 - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment, revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.
- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance

with 30 TAC §§ 305.62 and 305.66 and TWC§ 7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC § 305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility which does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under TWC §§ 7.051 7.075 (relating to Administrative Penalties), 7.101 7.111 (relating to Civil Penalties), and 7.141 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§ 301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA § 402, or any requirement imposed in a pretreatment program approved under the CWA §§ 402 (a)(3) or 402 (b)(8).

3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC § 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC § 7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

4. Permit Amendment and/or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC § 305.534 (relating to New Sources and New Dischargers); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
 - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes which are not described in the permit application or which would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC § 26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA § 307(a) for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or

prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA § 307(a) for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC § 305.64 (relating to Transfer of Permits) and 30 TAC § 50.133 (relating to Executive Director Action on Application or WQMP update).

6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to TWC Chapter 11.

8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

11. Notice of Bankruptcy

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
 - i. the permittee;
 - ii. an entity (as that term is defined in 11 USC, § 101(14)) controlling the permittee or listing the permit or permittee as property of the estate; or

- iii. an affiliate (as that term is defined in 11 USC, § 101(2)) of the permittee.
- b. This notification must indicate:
 - i. the name of the permittee;
 - ii. the permit number(s);
 - iii. the bankruptcy court in which the petition for bankruptcy was filed; and
 - iv. the date of filing of the petition.

OPERATIONAL REQUIREMENTS

- 1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
- 2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge or biosolids use and disposal and 30 TAC §§ 319.21 319.29 concerning the discharge of certain hazardous metals.
- 3. Domestic wastewater treatment facilities shall comply with the following provisions:
 - a. The permittee shall notify the Domestic Permits Team, Domestic Wastewater Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
 - b. The permittee shall submit a closure plan for review and approval to the Domestic Permits Team, Domestic Wastewater Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment and/or other treatment unit regulated by this permit.
- 4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, and/or retention of inadequately treated wastewater.
- 5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.

6. The permittee shall remit an annual water quality fee to the Commission as required by 30 TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC § 7.302(b)(6).

7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §§ 1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words confidential business information on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

- 8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
 - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion and/or upgrading of the domestic wastewater treatment and/or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment and/or collection facilities. In the case of a domestic wastewater treatment facility which reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been

secured.

- c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
- 9. Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
- 10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
- 11. Facilities that generate industrial solid waste as defined in 30 TAC § 335.1 shall comply with these provisions:
 - a. Any solid waste, as defined in 30 TAC § 335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
 - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
 - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC § 335.8(b)(1), to the Corrective Action Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
 - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC § 335.5.

- e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well, container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.
- f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC § 335 and must include the following, as it pertains to wastewater treatment and discharge:
 - i. Volume of waste and date(s) generated from treatment process;
 - ii. Volume of waste disposed of on-site or shipped off-site;
 - iii. Date(s) of disposal;
 - iv. Identity of hauler or transporter;
 - v. Location of disposal site; and
 - vi. Method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC § 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC § 361.

TCEQ Revision 06/2020

SLUDGE PROVISIONS

The permittee is authorized to dispose of sludge or biosolids only at a Texas Commission on Environmental Quality (TCEQ) authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge. The disposal of sludge or biosolids by land application on property owned, leased or under the direct control of the permittee is a violation of the permit unless the site is authorized with the TCEQ. This provision does not authorize Distribution and Marketing of Class A or Class AB Biosolids. This provision does not authorize the permittee to land apply biosolids on property owned, leased or under the direct control of the permittee.

SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS LAND APPLICATION

A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge or biosolids.
- 2. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
- 3. The land application of processed or unprocessed chemical toilet waste, grease trap waste, grit trap waste, milk solids, or similar non-hazardous municipal or industrial solid wastes, or any of the wastes listed in this provision combined with biosolids, WTP residuals or domestic septage is prohibited unless the grease trap waste is added at a fats, oil and grease (FOG) receiving facility as part of an anaerobic digestion process.

B. Testing Requirements

1. Sewage sludge or biosolids shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other method that receives the prior approval of the TCEQ for the contaminants listed in 40 CFR Part 261.24, Table 1. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal. Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 11) within seven (7) days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P.O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. The permittee must submit this annual report by September 30th of each year, using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 11) and the Enforcement Division (MC 224).

2. Biosolids shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Section I.C. of this permit.

TABLE 1

<u>Pollutant</u>	Ceiling Concentration
	(Milligrams per kilogram)*
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

^{*} Dry weight basis

3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site must be treated by one of the following methods to ensure that the sludge meets either the Class A, Class AB or Class B biosolids pathogen requirements.

a. For sewage sludge to be classified as Class A biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 most probable number (MPN) per gram of total solids (dry weight basis), or the density of Salmonella sp. bacteria in the sewage sludge must be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 1</u> - The temperature of the sewage sludge that is used or disposed shall be maintained at or above a specific value for a period of time. See 30 TAC § 312.82(a)(3)(A) for specific information;

Alternative 5 (PFRP) - Sewage sludge that is used or disposed of must be treated in one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR Part 503, Appendix B. PFRP include composting, heat drying, heat treatment, and thermophilic aerobic digestion; or

Alternative 6 (PFRP Equivalent) - Sewage sludge that is used or disposed of must be treated in a process that has been approved by the U. S. Environmental Protection Agency as being equivalent to those in Alternative 5.

b. For sewage sludge to be classified as Class AB biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 MPN per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 2</u> - The pH of the sewage sludge that is used or disposed shall be raised to above 12 std. units and shall remain above 12 std. units for 72 hours.

The temperature of the sewage sludge shall be above 52° Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12 std. units.

At the end of the 72-hour period during which the pH of the sewage sludge is above 12 std. units, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50%; or

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is less than one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC \S 312.82(a)(2)(C)(i-iii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC \S 312.82(a)(2)(C)(iv-vi) for specific information; or

<u>Alternative 4</u> - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed.

- c. Sewage sludge that meets the requirements of Class AB biosolids may be classified a Class A biosolids if a variance request is submitted in writing that is supported by substantial documentation demonstrating equivalent methods for reducing odors and written approval is granted by the executive director. The executive director may deny the variance request or revoke that approved variance if it is determined that the variance may potentially endanger human health or the environment, or create nuisance odor conditions.
- d. Three alternatives are available to demonstrate compliance with Class B biosolids

criteria.

Alternative 1

- i. A minimum of seven random samples of the sewage sludge shall be collected within 48 hours of the time the sewage sludge is used or disposed of during each monitoring episode for the sewage sludge.
- ii. The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

<u>Alternative 2</u> - Sewage sludge that is used or disposed of shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR Part 503, Appendix B, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. An independent Texas Licensed Professional Engineer must make a certification to the generator of a sewage sludge that the wastewater treatment facility generating the sewage sludge is designed to achieve one of the PSRP at the permitted design loading of the facility. The certification need only be repeated if the design loading of the facility is increased. The certification shall include a statement indicating the design meets all the applicable standards specified in Appendix B of 40 CFR Part 503;
- iii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iv. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review; and
- v. If the sewage sludge is generated from a mixture of sources, resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the PSRP, and shall meet the certification, operation, and record keeping requirements of this paragraph.

<u>Alternative 3</u> - Sewage sludge shall be treated in an equivalent process that has been approved by the U.S. Environmental Protection Agency, so long as all of the following requirements are met by the generator of the sewage sludge.

i. Prior to use or disposal, all the sewage sludge must have been generated from a

single location, except as provided in paragraph v. below;

- ii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iii. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review;
- iv. The Executive Director will accept from the U.S. Environmental Protection Agency a finding of equivalency to the defined PSRP; and
- v. If the sewage sludge is generated from a mixture of sources resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the Processes to Significantly Reduce Pathogens, and shall meet the certification, operation, and record keeping requirements of this paragraph.

In addition to the Alternatives 1 - 3, the following site restrictions must be met if Class B biosolids are land applied:

- i. Food crops with harvested parts that touch the biosolids /soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
- v. Domestic livestock shall not be allowed to graze on the land for 30 days after application of biosolids.
- vi. Turf grown on land where biosolids are applied shall not be harvested for 1 year after application of the biosolids when the harvested turf is placed on either land with a high potential for public exposure or a lawn.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of biosolids.

- viii. Public access to land with a low potential for public exposure shall be restricted for 30 days after application of biosolids.
- ix. Land application of biosolids shall be in accordance with the buffer zone requirements found in 30 TAC § 312.44.

4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following Alternatives 1 through 10 for vector attraction reduction.

- <u>Alternative 1</u> The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38%.
- Alternative 2 If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30° and 37° Celsius. Volatile solids must be reduced by less than 17% to demonstrate compliance.
- Alternative 3 If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20° Celsius. Volatile solids must be reduced by less than 15% to demonstrate compliance.
- Alternative 4 The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20° Celsius.
- Alternative 5 Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40° Celsius and the average temperature of the sewage sludge shall be higher than 45° Celsius.
- Alternative 6 The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali shall remain at 12 or higher for two hours and then remain at a pH of 11.5 or higher for an additional 22 hours at the time the sewage sludge is prepared for sale or given away in a bag or other container.
- Alternative 7 The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75% based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

Alternative 8 -

The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90% based on the moisture content and total solids prior to mixing with other materials at the time the sludge is used. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

Alternative 9 -

- i. Biosolids shall be injected below the surface of the land.
- ii. No significant amount of the biosolids shall be present on the land surface within one hour after the biosolids are injected.
- iii. When sewage sludge that is injected below the surface of the land is Class A or Class AB with respect to pathogens, the biosolids shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.

Alternative 10-

- i. Biosolids applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
- ii. When biosolids that is incorporated into the soil is Class A or Class AB with respect to pathogens, the biosolids shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

C. Monitoring Requirements

Toxicity Characteristic Leaching Procedure (TCLP) Test
PCBs
- once during the term of this permit
- once during the term of this permit

All metal constituents and fecal coliform or *Salmonella* sp. bacteria shall be monitored at the appropriate frequency shown below, pursuant to 30 TAC § 312.46(a)(1):

Amount of biosolids (*)

metric tons per 365-day period Monitoring Frequency

o to less than 290 Once/Year

290 to less than 1,500 Once/Quarter

1,500 to less than 15,000 Once/Two Months

15,000 or greater Once/Month

(*) The amount of bulk biosolids applied to the land (dry wt. basis).

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 30 TAC § 312.7

Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.

Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.

Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge or biosolids for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.

SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE FOR APPLICATION TO THE LAND MEETING CLASS A, CLASS AB or B BIOSOLIDS PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A, Class AB or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below listed in Table 3, the following conditions apply:

A. Pollutant Limits

Table 2

	Cumulative Pollutant Loading Rate
<u>Pollutant</u>	(pounds per acre)*
Arsenic	36
Cadmium	35
Chromium	2677
Copper	1339
Lead	268
Mercury	15
Molybdenum	Report Only
Nickel	375
Selenium	89
Zinc	2500

Table 3

Monthly Average
Concentration
(milligrams per kilogram)*
41
39
1200
1500
300
17
Report Only
420
36
2800

^{*}Dry weight basis

B. Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, shall be treated by either Class A, Class AB or Class B biosolids pathogen reduction requirements as defined above in Section I.B.3.

C. Management Practices

- 1. Bulk biosolids shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk biosolids enters a wetland or other waters in the State.
- 2. Bulk biosolids not meeting Class A biosolids requirements shall be land applied in a manner which complies with Applicability in accordance with 30 TAC §312.41 and the Management Requirements in accordance with 30 TAC § 312.44.
- 3. Bulk biosolids shall be applied at or below the agronomic rate of the cover crop.
- 4. An information sheet shall be provided to the person who receives bulk Class A or AB biosolids sold or given away. The information sheet shall contain the following information:
 - a. The name and address of the person who prepared the Class A or AB biosolids that are sold or given away in a bag or other container for application to the land.
 - b. A statement that application of the biosolids to the land is prohibited except in accordance with the instruction on the label or information sheet.
 - c. The annual whole sludge application rate for the biosolids application rate for the biosolids that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Section II above are met.

D. Notification Requirements

- 1. If bulk biosolids are applied to land in a State other than Texas, written notice shall be provided prior to the initial land application to the permitting authority for the State in which the bulk biosolids are proposed to be applied. The notice shall include:
 - a. The location, by street address, and specific latitude and longitude, of each land application site.
 - b. The approximate time period bulk biosolids will be applied to the site.
 - c. The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk biosolids.

E. Record Keeping Requirements

The documents will be retained at the facility site and/or shall be readily available for review by a TCEQ representative. The person who prepares bulk sewage sludge or a biosolids material shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative for a period of <u>five years</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply.

- 1. The concentration (mg/kg) in the sludge of each pollutant listed in Table 3 above and the applicable pollutant concentration criteria (mg/kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (lbs/ac) listed in Table 2 above.
- 2. A description of how the pathogen reduction requirements are met (including site restrictions for Class AB and Class B biosolids, if applicable).
- 3. A description of how the vector attraction reduction requirements are met.
- 4. A description of how the management practices listed above in Section II.C are being met.
- 5. The following certification statement:
 - "I certify, under penalty of law, that the applicable pathogen requirements in 30 TAC § 312.82(a) or (b) and the vector attraction reduction requirements in 30 TAC § 312.83(b) have been met for each site on which bulk biosolids are applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."
- 6. The recommended agronomic loading rate from the references listed in Section II.C.3. above, as well as the actual agronomic loading rate shall be retained. The person who applies bulk biosolids shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative <u>indefinitely</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply:
 - a. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii), as applicable, and to the permittee's specific sludge treatment activities.
 - b. The location, by street address, and specific latitude and longitude, of each site on which biosolids is applied.
 - c. The number of acres in each site on which bulk biosolids are applied.
 - d. The date and time biosolids are applied to each site.
 - e. The cumulative amount of each pollutant in pounds/acre listed in Table 2 applied to each site.
 - f. The total amount of biosolids applied to each site in dry tons.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

F. Reporting Requirements

The permittee must submit this annual report by September 30th of each year, using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 11) and the Enforcement Division ((MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.
- 3. Results of tests performed for pollutants found in either Table 2 or 3 as appropriate for the permittee's land application practices.
- 4. The frequency of monitoring listed in Section I.C. that applies to the permittee.
- 5. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 6. PCB concentration in sludge or biosolids in mg/kg.
- 7. Identity of hauler(s) and TCEQ transporter number.
- 8. Date(s) of transport.
- 9. Texas Commission on Environmental Quality registration number, if applicable.
- 10. Amount of sludge or biosolids disposal dry weight (lbs/acre) at each disposal site.
- 11. The concentration (mg/kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/kg) listed in Table 3 above, or the applicable pollutant loading rate limit (lbs/acre) listed in Table 2 above if it exceeds 90% of the limit.
- 12. Level of pathogen reduction achieved (Class A, Class AB or Class B).
- 13. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B biosolids, include information on how site restrictions were met.
- 14. Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.
- 15. Vector attraction reduction alternative used as listed in Section I.B.4.
- 16. Amount of sludge or biosolids transported in dry tons/year.

- 17. The certification statement listed in either 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii) as applicable to the permittee's sludge or biosolids treatment activities, shall be attached to the annual reporting form.
- 18. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the annual reporting form.
 - a. The location, by street address, and specific latitude and longitude.
 - b. The number of acres in each site on which bulk biosolids are applied.
 - c. The date and time bulk biosolids are applied to each site.
 - d. The cumulative amount of each pollutant (i.e., pounds/acre) listed in Table 2 in the bulk biosolids applied to each site.
 - e. The amount of biosolids (i.e., dry tons) applied to each site.

The above records shall be maintained on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

SECTION III. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL

- A. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 330 and all other applicable state and federal regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge or biosolids meets the requirements in 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- B. If the permittee generates sewage sludge or biosolids and supplies that sewage sludge or biosolids to the owner or operator of a municipal solid waste landfill (MSWLF) for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
- C. Sewage sludge or biosolids shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I (Toxicity Characteristic Leaching Procedure) or other method, which receives the prior approval of the TCEQ for contaminants listed in Table 1 of 40 CFR § 261.24. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal.

Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 11) of the appropriate TCEQ field office within 7 days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped, and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P. O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 11) and the Enforcement Division (MC 224) of the by September 30th of each year.

- D. Sewage sludge or biosolids shall be tested as needed, in accordance with the requirements of 30 TAC Chapter 330.
- E. Record Keeping Requirements

The permittee shall develop the following information and shall retain the information for five years.

- 1. The description (including procedures followed and the results) of all liquid Paint Filter Tests performed.
- 2. The description (including procedures followed and results) of all TCLP tests performed.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

F. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 11) and the Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 3. Annual sludge or biosolids production in dry tons/year.
- 4. Amount of sludge or biosolids disposed in a municipal solid waste landfill in dry tons/year.
- 5. Amount of sludge or biosolids transported interstate in dry tons/year.
- 6. A certification that the sewage sludge or biosolids meets the requirements of 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- 7. Identity of hauler(s) and transporter registration number.
- 8. Owner of disposal site(s).
- 9. Location of disposal site(s).
- 10. Date(s) of disposal.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

SECTION IV. REQUIREMENTS APPLYING TO SLUDGE OR BIOSOLIDS TRANSPORTED TO ANOTHER FACILITY FOR FURTHER PROCESSING

These provisions apply to sludge or biosolids that is transported to another wastewater treatment facility or facility that further processes sludge or biosolids. These provisions are intended to allow transport of sludge or biosolids to facilities that have been authorized to accept sludge or biosolids. These provisions do not limit the ability of the receiving facility to determine whether to accept the sludge or biosolids, nor do they limit the ability of the receiving facility to request additional testing or documentation.

A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC Chapter 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
- 2. Sludge or biosolids may only be transported using a registered transporter or using an approved pipeline.

B. Record Keeping Requirements

- 1. For sludge or biosolids transported by an approved pipeline, the permittee must maintain records of the following:
 - a. the amount of sludge or biosolids transported;
 - b. the date of transport;
 - c. the name and TCEQ permit number of the receiving facility or facilities;
 - d. the location of the receiving facility or facilities;
 - e. the name and TCEQ permit number of the facility that generated the waste; and
 - f. copy of the written agreement between the permittee and the receiving facility to accept sludge or biosolids.
- 2. For sludge transported by a registered transporter, the permittee must maintain records of the completed trip tickets in accordance with 30 TAC § 312.145(a)(1)-(7) and amount of sludge or biosolids transported.
- 3. The above records shall be maintained on-site on a monthly basis and shall be made available to the TCEQ upon request. These records shall be retained for at least five years.

C. Reporting Requirements

The permittee shall submit the following information in an annual report to the TCEQ by September 30th of each year. The permittee must submit this annual report using the online electronic reporting system available through TCEQ's website. If the permittee requests and obtains an electronic reporting waiver, the annual report can be submitted in hard copy to the TCEQ Regional Office (MC Region 11) and the Enforcement Division (MC 224).

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. the annual sludge or biosolids production;
- 3. the amount of sludge or biosolids transported;
- 4. the owner of each receiving facility;
- 5. the location of each receiving facility; and
- 6. the date(s) of disposal at each receiving facility.

TCEQ Revision 06/2020

OTHER REQUIREMENTS

- 1. The permittee shall employ or contract with one or more licensed wastewater treatment facility operators or wastewater system operations companies holding a valid license or registration according to the requirements of 30 TAC Chapter 30, Occupational Licenses and Registrations, and in particular 30 TAC Chapter 30, Subchapter J, Wastewater Operators and Operations Companies.
 - This Category C facility must be operated by a chief operator or an operator holding a Class C license or higher. The facility must be operated a minimum of five days per week by the licensed chief operator or an operator holding the required level of license or higher. The licensed chief operator or operator holding the required level of license or higher must be available by telephone or pager seven days per week. Where shift operation of the wastewater treatment facility is necessary, each shift that does not have the on-site supervision of the licensed chief operator must be supervised by an operator in charge who is licensed not less than one level below the category for the facility.
- 2. The facility is not located in the Coastal Management Program boundary.
- 3. The permittee shall comply with the requirements of 30 TAC § 309.13(a) through (d). In addition, by ownership of the required buffer zone area, the permittee shall comply with the requirements of 30 TAC § 309.13(e).
- 4. The permittee shall provide facilities for the protection of its wastewater treatment facility from a 100-year flood.
- 5. In accordance with 30 TAC § 319.9, a permittee that has at least twelve months of uninterrupted compliance with its bacteria limit may notify the commission in writing of its compliance and request a less frequent measurement schedule. To request a less frequent schedule, the permittee shall submit a written request to the TCEQ Domestic Wastewater Section (MC 148) for each phase that includes a different monitoring frequency. The request must contain all of the reported bacteria values (Daily Avg. and Daily Max/Single Grab) for the twelve consecutive months immediately prior to the request. If the Executive Director finds that a less frequent measurement schedule is protective of human health and the environment, the permittee may be given a less frequent measurement schedule. For this permit, one/quarter may be reduced to one/six months in the Interim I phase, and one/month may be reduced to one/quarter in the Interim II and Final phases. A violation of any bacteria limit by a facility that has been granted a less frequent measurement schedule will require the permittee to return to the standard frequency schedule and submit written notice to the TCEQ Domestic Wastewater Section (MC 148). The permittee may not apply for another reduction in measurement frequency for at least 24 months from the date of the last violation. The Executive Director may establish a more frequent measurement schedule if necessary to protect human health or the environment.
- 6. Prior to construction of the Interim I, Interim II, and Final phase treatment facilities, the permittee shall submit to the TCEQ Domestic Wastewater Section (MC 148) a summary transmittal letter in accordance with the requirements in 30 TAC § 217.6(d). If requested by the Domestic Wastewater Section, the permittee shall submit plans and specifications and a final engineering design report which comply with 30 TAC Chapter 217, Design Criteria for Domestic Wastewater Systems. The permittee shall clearly show how the treatment system

- will meet the permitted effluent limitations required on Pages 2, 2a, and 2b of this permit. A copy of the summary transmittal letter shall be available at the plant site for inspection by authorized representatives of the TCEQ.
- 7. Reporting requirements according to 30 TAC §§ 319.1-319.11 and any additional effluent reporting requirements contained in this permit are suspended from the effective date of the permit until plant startup or discharge from the facility described by this permit, whichever occurs first. The permittee shall provide written notice to the TCEQ Regional Office (MC Region 11) and the Applications Review and Processing Team (MC 148) of the Water Quality Division, in writing at least forty-five days prior to plant startup or anticipated discharge, whichever occurs first, and prior to completion of each additional phase on Notification of Completion Form 20007.

STATEMENT OF BASIS/TECHNICAL SUMMARY AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

DESCRIPTION OF APPLICATION

Applicant: NMCV Taylor Property Investors LLC;

Texas Pollutant Discharge Elimination System (TPDES) Permit No.

WQ0016554001, EPA I.D. No. TX00146153

Regulated Activity: Domestic Wastewater Permit

Type of Application: New Permit

Request: New Permit

Authority: Federal Clean Water Act (CWA) § 402; Texas Water Code § 26.027; 30

Texas Administrative Code (TAC) Chapters 30, 305, 307, 309, 312, and 319; Commission policies; and United States Environmental Protection

Agency (EPA) guidelines.

EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **five years from the date of issuance**.

REASON FOR PROJECT PROPOSED

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for a new permit to authorize the discharge of treated domestic wastewater at a daily average flow not to exceed 0.05 million gallons per day (MGD) in the Interim I phase, a daily average flow not to exceed 0.10 MGD in the Interim II phase, and a daily average flow not to exceed 0.15 MGD in the Final phase. The proposed wastewater treatment facility will serve a commercial development on 487 acres.

PROJECT DESCRIPTION AND LOCATION

The 487 Acre Taylor Tract Wastewater Treatment Facility will be a suspended growth activated sludge process operated in the extended aeration mode. The treatment facility will be constructed in three phases. Treatment units in the Interim l Phase will inlcude: one bar screen, one aeration basin, one chlorine contact chamber and one aerobic digester. Treatment units in the Interim ll Phase will inlcude: two bar screens, two aeration basins, two chlorine contact chambers and two aerobic digesters. Treatment units in the Final Phase will inlcude: three bar screens, three aeration basins, three chlorine contact chambers and three aerobic digesters. The facility has not been constructed.

Sludge generated from the treatment facility will be hauled by a registered transporter and disposed of at a TCEQ-permitted facility, WWTS - Austin Wastewater Processing Facility, Permit No. 2384A, in Travis County. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

The plant site will be located approximately 0.16 miles northeast of the intersection of Farm-to-Market Road 112 and Tucek Road, in Williamson County, Texas 76574.

Outfall Location:

Outfall Number	Latitude	Longitude	
001	30.565409 N	97.358819W	

The treated effluent will be discharged to an unnamed tributary, thence to Mustang Creek, thence to Brushy Creek in in Segment No. 1244 of the Brazos River Basin. The unclassified receiving water use is limited aquatic life use for the unnamed tributary. The designated uses for Segment No. 1244 are primary contact recreation, public water supply, aquifer protection, and high aquatic life use. The effluent limitations in the draft permit will maintain and protect the existing instream uses. In accordance with 30 Texas Administrative Code §307.5 and TCEQ's *Procedures to Implement the Texas Surface Water Quality Standards* (June 2010), an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. This review has preliminarily determined that no water bodies with exceptional, high, or intermediate aquatic life uses are present within the stream reach assessed; therefore, no Tier 2 degradation determination is required. No significant degradation of water quality is expected in water bodies with exceptional, high, or intermediate aquatic life uses downstream, and existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received.

Effluent limitations for the conventional effluent parameters (i.e., Five-Day Biochemical Oxygen Demand or Five-Day Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water-quality limited streams as established in the Texas Surface Water Quality Standards (TSWQS) and the State of Texas Water Quality Management Plan (WQMP).

In a case such as this, end-of-pipe compliance with pH limits between 6.0 and 9.0 standard units reasonably assures instream compliance with the TSWQS for pH when the discharge authorized is from a minor facility. This technology-based approach reasonably assures instream compliance with TSWQS criteria due to the relatively smaller discharge volumes authorized by these permits. This conservative assumption is based on TCEQ sampling conducted throughout the state which indicates that instream buffering quickly restores pH levels to ambient conditions. Similarly, this approach has been historically applied within EPA issued NPDES general permits where technology-based pH limits were established to be protective of water quality criteria.

The effluent limits recommended above have been reviewed for consistency with the State of Texas Water Quality Management Plan (WQMP). The proposed limits are not contained in the approved WQMP. However, these limits will be included in the next WQMP update. This discharge is less than 0.2 MGD and has been evaluated consistent with the modeling MOA between the TCEQ and the EPA.

The discharge from this permit action is not expected to have an effect on any federal endangered or threatened aquatic or aquatic-dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS's) biological opinion on the State of Texas authorization of the TPDES (September 14, 1998; October 21, 1998, update). To make this determination for TPDES permits, TCEQ and EPA only considered aquatic or aquatic-dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the

NMCV Taylor Property Investors LLC TPDES Permit No. WQ0016554001 Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

presence of endangered or threatened species.

Segment No. 1244 is currently listed on the state's inventory of impaired and threatened waters (the 2022 CWA § 303(d) list). The listing is for bacteria from the confluence of the San Gabriel River upstream to the confluence of Mustang Creek (Assessment Unit [AU] 1244_01) and from the confluence of Cottonwood Creek upstream to the confluence of Lake Creek (AU 1244_03). This facility is designed to provide adequate disinfection and, when operated properly, should not add to the bacterial impairment of the segment. In addition, in order to ensure that the proposed discharge meets the stream bacterial standard, an effluent limitation of 126 colony-forming units (CFU) or most probable number (MPN) of *Escherichia coli* (*E. coli*) per 100 ml has been added to the draft permit.

SUMMARY OF EFFLUENT DATA

Self-reporting data is not available since the facility is not in operation.

DRAFT PERMIT CONDITIONS

The draft permit authorizes a discharge of treated domestic wastewater at an Interim I volume not to exceed a daily average flow of 0.05 MGD, an Interim II volume not to exceed a daily average flow of 0.10 MGD, and a Final volume not to exceed a daily average flow of 0.15 MGD.

The effluent limitations in the Interim I, Interim II, and Final phases of the draft permit, based on a 30-day average, are 5 mg/l five-day carbonaceous biochemical oxygen demand (CBOD $_5$), 5 mg/l total suspended solids (TSS), 2 mg/l ammonia-nitrogen (NH $_3$ -N), 0.50 mg/L total phosphorous (TP), 126 CFU or MPN of *E. coli* per 100 ml, and 5.0 mg/l minimum dissolved oxygen. The effluent shall contain a total chlorine residual of at least 1.0 mg/l and shall not exceed a total chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes based on peak flow.

The permittee shall comply with the requirements of 30 TAC § 309.13(a) through (d). In addition, by ownership of the required buffer zone area, the permittee shall comply with the requirements of 30 TAC § 309.13(e).

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal, and Transportation. Sludge generated from the treatment facility will be hauled by a registered transporter and disposed of at a TCEQ-permitted facility, WWTS - Austin Wastewater Processing Facility, Permit No. 2384A, in Travis County. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

SUMMARY OF CHANGES FROM APPLICATION

The applicant requested effluent limitations, based on a 30-day average, of 5 mg/l CBOD₅, 5 mg/l TSS, 2 mg/l NH₃-N, 1 mg/l TP and 5.0 mg/l minimum DO. However, effluent limitations in the Interim phase of the draft permit, based on a 30-day average, are 5 mg/l CBOD₅, 5 mg/l TSS, 2 mg/l NH₃-N, 0.5 mg/l TP, 126 CFU or MPN of *E. coli* per 100 ml and 5.0 mg/l minimum DO. The effluent limitations in the Final phase of the draft permit, based on a 30-day average, are 5 mg/l CBOD₅, 5 mg/l TSS, 2 mg/l NH₃-N, 1 mg/l Total Phosphorous and 5.0 mg/l minimum DO.

BASIS FOR DRAFT PERMIT

The following items were considered in developing the draft permit:

NMCV Taylor Property Investors LLC TPDES Permit No. WQ0016554001 Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

- 1. Application received on May 31, 2024, and additional information received on July 24, 2025.
- 2. The effluent limitations and conditions in the draft permit comply with EPA-approved portions of the 2018 Texas Surface Water Quality Standards (TSWQS), 30 TAC §§ 307.1 307.10, effective March 1, 2018; 2014 TSWQS, effective March 6, 2014; 2010 TSWQS, effective July 22, 2010; and 2000 TSWQS, effective July 26, 2000.
- 3. The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Effluent Limitations.
- 4. Interoffice Memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division.
- 5. Consistency with the Coastal Management Plan: The facility is not located in the Coastal Management Program boundary.
- 6. *Procedures to Implement the Texas Surface Water Quality Standards* (IP), Texas Commission on Environmental Quality, June 2010, as approved by EPA, and the IP, January 2003, for portions of the 2010 IP not approved by EPA.
- 7. Texas 2022 Clean Water Act Section 303(d) List, Texas Commission on Environmental Quality, June 1, 2022; approved by the U.S. Environmental Protection Agency on July 7, 2022.
- 8. Texas Natural Resource Conservation Commission, Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.

PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have

NMCV Taylor Property Investors LLC TPDES Permit No. WQ0016554001 Statement of Basis/Technical Summary and Executive Director's Preliminary Decision

filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Chris Graf, P.E. at (512) 239-4541.

Chris Graf	August 29, 2025
Chris Graf, P.E.	Date
Domestic Permits Team	
Domestic Wastewater Section (MC 148)	