

# Public Record Summary Information on Underground Storage Tanks (USTs)

**Public Record Posted Date:** 10/24/2023

## General Information<sup>1</sup>

Total Number of UST Facilities: 19,473

Total Number of USTs: 177,557

In use (41,279) or temporarily out of service (5,819): 47,098

Removed from the ground (120,302) or abandoned in place (10,157): 130,459

## Summary Information for On-Site Inspections<sup>2</sup>

Number of UST Facilities Inspected: 6,485

Inspection Period Dates: October 1, 2022 to September 30, 2023

Percent Compliance (Combined Measure): 86%

## Summary Information for Releases<sup>3</sup>

Number of Confirmed UST Releases: 208

Release Reporting Period Dates: October 1, 2022 to September 30, 2023

### Summary Information for Release Sources and Causes<sup>3</sup>

Source Type	Release by Source Type	Spill	Overfill	Phys/Mech Damage	Corrosion	Install Problem	Other	Unknown
Tank	61 (43%)	3 (30%)	1 (33%)	2 (18%)	8 (57%)	0 (0%)	5 (26%)	42 (49%)
Piping	41 (29%)	2 (20%)	0 (0%)	5 (45%)	3 (21%)	0 (0%)	9 (47%)	22 (26%)
Dispenser	27 (19%)	2 (20%)	0 (0%)	2 (18%)	1 (7%)	0 (0%)	4 (21%)	18 (21%)
STP	7 (5%)	1 (10%)	0 (0%)	1 (9%)	2 (14%)	0 (0%)	1 (5%)	2 (2%)
Del. Prob	1 (1%)	0 (0%)	1 (33%)	0 (0%)	0 (0%)	0 (0%)	0 (0%)	0 (0%)
Other	5 (4%)	2 (20%)	1 (33%)	1 (9%)	0 (0%)	0 (0%)	0 (0%)	1 (1%)
Totals	142 (101%)	10 (7%)	3 (2%)	11 (8%)	14 (10%)	0 (0%)	19 (13%)	85 (60%)

### Footnotes:

1. Tank and facility information is based on PST registration records. For site-specific information regarding tanks and facilities, please call (512) 239-2160 or go to the following web address: <https://www15.tceq.texas.gov/crpub/>
2. On-site inspection compliance is based on the combined release detection and release prevention performance measures for Significant Operational Compliance with state or federal underground storage tank requirements.
3. Release, source and cause information is based on releases reported to the TCEQ. Source and cause data were collected using information supplied by the Responsible Party or their representative. A release at a single tank system might have multiple sources and/or causes. For site-specific information regarding releases, please call (512) 239-2200 or go to the following web address: <https://www15.tceq.texas.gov/crpub/>

Site-specific records regarding tanks, compliance findings, and releases are available at the TCEQ Central File Room, 12100 Park 35 Circle, Austin, Texas, (512) 239-2900 or online at [https://records.tceq.texas.gov/cs/idcplg?IdcService=TCEQ\\_SEARCH](https://records.tceq.texas.gov/cs/idcplg?IdcService=TCEQ_SEARCH) under the PST Facility Registration ID number and/or LPST ID number.