

Allied Development, LLC (CN606223972 ) proposes to operate Madelynn Estates WWTP 1 RN111890562. an activated sludge plant operating in extended aeration mode.. The facility will be located approximately 1.5 miles Southeast of the intersection of FM 150 and RR 12, in Dripping Springs, Hays County, Texas 78619.

This application is for a new wastewater treatment facility to be constructed and operated on a temporary basis to treat and discharge 0.045 MGD.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand, total suspended solids, and ammonia nitrogen..Domestic wastewater will be treated by an activated sludge process plant and the treatment units include an aeration basin, final clarifier, sludge digester, and chlorine contact chamber.

