

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Texas Department of Criminal Justice (CN601550650) operates TDCJ PACK UNIT WWTP , RN102314283. a domestic wastewater treatment facility. The facility is located 2400 Wallace Pack Road, in Navasota, Grimes County, Texas 77868.

The application is to renew the Texas Pollution Discharge Eliminations System permit no. WQ0013743001 (EPA I.D. No. TX0089010) to authorize the discharge at an annual average flow of 500,000 gallons per day of treated domestic wastewater via outfall 001.

Discharges from the facility are expected to contain five day Carbonaceous Biological demand (C-BOD₅), Total Suspended Solids (TSS), Ammonia Nitrogen, Nitrate-Nitrogen and *E. coli* .Domestic wastewater is treated by an activated sludge process plant, the treatment unit contains a bar screen, aeration basin, clarifier, sludge drying bed, chlorination chamber and de-chlorination chamber.

Spanish plain language summary:

El Departamento de Justicia Criminal de Texas (CN601550650) opera la planta de tratamiento de aguas residuales de la Unidad TDCJ PACK UNIT WWTP. RN102314283. Una instalación de tratamiento de aguas residuales domésticas. La instalación está ubicada en 2400 Wallace Pack Road, en Navasota, Condado de Grimes, Texas 77868. La solicitud es para renovar el permiso del Sistema de Eliminación de Descargas de Contaminación de Texas no. WQ0013743001 (EPA I.D. No. TX0089010) para autorizar la descarga a un flujo promedio anual de 500,000 galones por día de aguas residuales domésticas tratadas a través del desagüe 001. Se espera que las descargas de la instalación contengan demanda biológica carbonosa de cinco días (C-DBO₅), sólidos suspendidos totales (TSS), nitrógeno amoníaco, nitrógeno de nitrato y *E. coli*. Las aguas residuales domésticas son tratadas por una planta de proceso de lodos activados, la unidad de tratamiento contiene una pantalla de barra, una cuenca de aireación, un clarificador, un lecho de secado de lodos, una cámara de cloración y una cámara de decloración.